


Detailed Member Calculations

Units: N&mm

Regulation: ASCE 41-17

Calculation No. 1

- column C1, Floor 1
- Limit State: Operational Level (data interpolation between analysis steps 1 and 2)
- Analysis: Uniform +X
- Check: Shear capacity VRd
- Edge: Start
- Local Axis: (2)



- Start Of Calculation of Shear Capacity for element: column JTC1 of floor 1
- At local axis: 2
- Integration Section: (a)
- Section Type: rcjtcs
- Constant Properties
- Knowledge Factor, $\gamma = 0.80$
- Member Shear Force is generally considered as Force-Controlled Action according to Table C7-1, ASCE 41-17.
- Lower-bound strengths are used for Force-Controlled Actions according to 7.5.1.3, ASCE 41-17
- Consequently:
- Jacket
- New material of Secondary Member: Concrete Strength, $f_c = f_{c_lower_bound} = 20.00$
- New material of Secondary Member: Steel Strength, $f_s = f_{s_lower_bound} = 500.00$

Concrete Elasticity, $E_c = 25742.96$
Steel Elasticity, $E_s = 200000.00$
Existing Column
Existing material of Secondary Member: Concrete Strength, $f_c = f_{c_lower_bound} = 16.00$
Existing material of Secondary Member: Steel Strength, $f_s = f_{s_lower_bound} = 420.00$
Concrete Elasticity, $E_c = 23025.204$
Steel Elasticity, $E_s = 200000.00$

Note: Especially for the calculation of γ for displacement ductility demand,
the expected (mean value) strengths are used (7.5.1.3, ASCE 41-17) because bending is considered as
Deformation-Controlled Action (Table C7-1, ASCE 41-17).
Jacket
New material: Concrete Strength, $f_c = f_{cm} = 30.00$
New material: Steel Strength, $f_s = f_{sm} = 625.00$
Existing Column
Existing material: Concrete Strength, $f_c = f_{cm} = 24.00$
Existing material: Steel Strength, $f_s = f_{sm} = 525.00$

Max Height, $H_{max} = 750.00$
Min Height, $H_{min} = 450.00$
Max Width, $W_{max} = 950.00$
Min Width, $W_{min} = 450.00$
Eccentricity, $Ecc = 250.00$
Jacket Thickness, $t_j = 100.00$
Cover Thickness, $c = 25.00$
Element Length, $L = 3000.00$
Secondary Member
Smooth Bars
Ductile Steel
Without Detailing for Earthquake Resistance (including stirrups not closed at 135°)
Longitudinal Bars With Ends Lapped Starting at the End Sections
Adequate Lap Length ($l_o/l_{ou,min} = l_b/l_d \geq 1$)
No FRP Wrapping

Stepwise Properties

EDGE -A-
Bending Moment, $M_a = -1.6657E+007$
Shear Force, $V_a = -5479.017$
EDGE -B-
Bending Moment, $M_b = 215890.77$
Shear Force, $V_b = 5479.017$
BOTH EDGES
Axial Force, $F = -21838.055$
Longitudinal Reinforcement Area Distribution (in 2 divisions)
-Tension: $As_t = 0.00$
-Compression: $As_c = 6691.592$
Longitudinal Reinforcement Area Distribution (in 3 divisions)
-Tension: $As_{t,ten} = 1539.38$
-Compression: $As_{l,com} = 1539.38$
-Middle: $As_{l,mid} = 3612.832$
Mean Diameter of Tension Reinforcement, $Db_{L,ten} = 16.57143$

Existing component: From table 7-7, ASCE 41-17: Final Shear Capacity $VR = \phi V_n = 921337.034$
 V_n ((10.3), ASCE 41-17) = $k_n l \cdot V_{CoI} = 1.1517E+006$
 $V_{CoI} = 1.1517E+006$
 $k_n l = 1.00$
displacement_ductility_demand = 0.00794564

NOTE: In expression (10-3) ' $V_s = A_v \cdot f_y \cdot d/s$ ' is replaced by ' $V_s + \phi \cdot V_f$ '
where V_f is the contribution of FRPs (11.3), ACI 440).

= 1 (normal-weight concrete)

Mean concrete strength: $fc' = (fc'_{jacket} \cdot Area_{jacket} + fc'_{core} \cdot Area_{core}) / Area_{section} = 18.13333$, but $fc'^{0.5} \leq 8.3$ MPa (22.5.3.1, ACI 318-14)

$M/Vd = 4.00$

$\mu_u = 1.6657E+007$

$V_u = 5479.017$

$d = 0.8 \cdot h = 760.00$

$N_u = 21838.055$

$A_g = 427500.00$

From (11.5.4.8), ACI 318-14: $V_s = V_{sjacket} + V_{s,core} = 980981.156$

where:

$V_{sjacket} = V_{sj1} + V_{sj2} = 879645.943$

$V_{sj1} = 282743.339$ is calculated for section web jacket, with:

$d = 360.00$

$A_v = 157079.633$

$f_y = 500.00$

$s = 100.00$

V_{sj1} is multiplied by $Col,j1 = 1.00$

$s/d = 0.27777778$

$V_{sj2} = 596902.604$ is calculated for section flange jacket, with:

$d = 760.00$

$A_v = 157079.633$

$f_y = 500.00$

$s = 100.00$

V_{sj2} is multiplied by $Col,j2 = 1.00$

$s/d = 0.13157895$

$V_{s,core} = V_{s,c1} + V_{s,c2} = 101335.213$

$V_{s,c1} = 0.00$ is calculated for section web core, with:

$d = 200.00$

$A_v = 100530.965$

$f_y = 420.00$

$s = 250.00$

$V_{s,c1}$ is multiplied by $Col,c1 = 0.00$

$s/d = 1.25$

$V_{s,c2} = 101335.213$ is calculated for section flange core, with:

$d = 600.00$

$A_v = 100530.965$

$f_y = 420.00$

$s = 250.00$

$V_{s,c2}$ is multiplied by $Col,c2 = 1.00$

$s/d = 0.41666667$

$V_f ((11-3)-(11.4), ACI 440) = 0.00$

From (11-11), ACI 440: $V_s + V_f \leq 967457.029$

$bw = 450.00$

displacement_ductility_demand is calculated as δ_u / y

- Calculation of δ_u / y for END A -
for rotation axis 3 and integ. section (a)

From analysis, chord rotation $\theta_r = 4.0318467E-005$

$y = (M_y \cdot L_s / 3) / E_{eff} = 0.00507429$ ((4.29), Biskinis Phd)

$M_y = 1.2939E+009$

$L_s = M/V$ (with $L_s > 0.1 \cdot L$ and $L_s < 2 \cdot L$) = 3040.138

From table 10.5, ASCE 41_17: $E_{eff} = factor \cdot E_c \cdot I_g = 2.5841E+014$

$factor = 0.30$

$A_g = 562500.00$

Mean concrete strength: $fc' = (fc'_{jacket} \cdot Area_{jacket} + fc'_{core} \cdot Area_{core}) / Area_{section} = 27.20$

$N = 21838.055$

$E_c \cdot I_g = E_{c,jacket} \cdot I_{g,jacket} + E_{c,core} \cdot I_{g,core} = 8.6137E+014$

Calculation of Yielding Moment M_y

Calculation of δ_u and M_y according to Annex 7 -

```
y = Min( y_ten, y_com)
y_ten = 4.4892910E-006
with fy = 601.9953
d = 907.00
y = 0.26077258
A = 0.01648381
B = 0.00867498
with pt = 0.0037716
pc = 0.0037716
pv = 0.00885172
N = 21838.055
b = 450.00
" = 0.04740904
y_comp = 8.8910413E-006
with fc = 30.00
Ec = 25742.96
y = 0.26012097
A = 0.0162674
B = 0.0085861
with Es = 200000.00
```

Calculation of ratio I_b/I_d

Adequate Lap Length: $I_b/I_d \geq 1$

End Of Calculation of Shear Capacity for element: column JTC1 of floor 1

At local axis: 2

Integration Section: (a)

Calculation No. 2

column C1, Floor 1



Limit State: Operational Level (data interpolation between analysis steps 1 and 2)

Analysis: Uniform +X

Check: Chord rotation capacity (ϕ)

Edge: Start

Local Axis: (2)



Start Of Calculation of Shear Capacity ratio for element: column JTC1 of floor 1

At Shear local axis: 3

(Bending local axis: 2)

Section Type: rcjtcs

Constant Properties

Knowledge Factor, $\gamma = 0.80$

Mean strength values are used for both shear and moment calculations.

Consequently:

Jacket

New material of Secondary Member: Concrete Strength, $f_c = f_{cm} = 30.00$

New material of Secondary Member: Steel Strength, $f_s = f_{sm} = 625.00$

Concrete Elasticity, $E_c = 25742.96$

Steel Elasticity, $E_s = 200000.00$

Existing Column

Existing material of Secondary Member: Concrete Strength, $f_c = f_{cm} = 24.00$

Existing material of Secondary Member: Steel Strength, $f_s = f_{sm} = 525.00$

Concrete Elasticity, $E_c = 23025.204$

Steel Elasticity, $E_s = 200000.00$

#####

Note: Especially for the calculation of moment strengths,

the above steel re-bar strengths are multiplied by 1.25 according to R18.6.5, ACI 318-14

Jacket

New material: Steel Strength, $f_s = 1.25 \cdot f_{sm} = 781.25$

Existing Column

Existing material: Steel Strength, $f_s = 1.25 \cdot f_{sm} = 656.25$

#####

Max Height, $H_{max} = 750.00$

Min Height, $H_{min} = 450.00$

Max Width, $W_{max} = 950.00$

Min Width, $W_{min} = 450.00$

Eccentricity, $E_{cc} = 250.00$

Jacket Thickness, $t_j = 100.00$

Cover Thickness, $c = 25.00$

Mean Confinement Factor overall section = 1.00

Element Length, $L = 3000.00$

Secondary Member

Smooth Bars

Ductile Steel

Without Detailing for Earthquake Resistance (including stirrups not closed at 135°)

Longitudinal Bars With Ends Lapped Starting at the End Sections

Adequate Lap Length ($l_o/l_{o,u,min} \geq 1$)

No FRP Wrapping

Stepwise Properties

At local axis: 3

EDGE -A-

Shear Force, $V_a = -8.5087964E-020$

EDGE -B-

Shear Force, $V_b = 8.5087964E-020$
 BOTH EDGES
 Axial Force, $F = -20792.05$
 Longitudinal Reinforcement Area Distribution (in 2 divisions)
 -Tension: $As_t = 0.00$
 -Compression: $As_c = 6691.592$
 Longitudinal Reinforcement Area Distribution (in 3 divisions)
 -Tension: $As_{t,ten} = 1539.38$
 -Compression: $As_{c,com} = 2475.575$
 -Middle: $As_{mid} = 2676.637$

Calculation of Shear Capacity ratio, $V_e/V_r = 1.11674$
 Member Controlled by Shear ($V_e/V_r > 1$)
 Calculation of Shear Demand from fig. R18.6.5, ACI 318-14 $V_e = (M_{pr1} + M_{pr2})/l_n = 1.4424E+006$
 with
 $M_{pr1} = \text{Max}(\mu_{u1+}, \mu_{u1-}) = 2.1636E+009$
 $\mu_{u1+} = 2.0419E+009$, is the ultimate moment strength at the edge 1 of the member in the actual moment direction which is defined for the static loading combination
 $\mu_{u1-} = 2.1636E+009$, is the ultimate moment strength at the edge 1 of the member in the opposite moment direction which is defined for the static loading combination
 $M_{pr2} = \text{Max}(\mu_{u2+}, \mu_{u2-}) = 2.1636E+009$
 $\mu_{u2+} = 2.0419E+009$, is the ultimate moment strength at the edge 2 of the member in the actual moment direction which is defined for the static loading combination
 $\mu_{u2-} = 2.1636E+009$, is the ultimate moment strength at the edge 2 of the member in the opposite moment direction which is defined for the static loading combination

Calculation of μ_{u1+}

Calculation of ultimate curvature ϕ_u according to 4.1, Biskinis/Fardis 2013:
 $\phi_u = 5.3321191E-005$
 $\mu_u = 2.0419E+009$

with full section properties:

$b = 950.00$
 $d = 707.00$
 $d' = 43.00$
 $v = 0.00103189$
 $N = 20792.05$
 $f_c = 30.00$
 $\phi_{co} (5A.5, TBDY) = 0.002$

Final value of ϕ_{cu} : $\phi_{cu}^* = \text{shear_factor} * \text{Max}(\phi_{cu}, \phi_{cc}) = 0.00832321$

The Shear_factor is considered equal to 1 (pure moment strength)

From (5.4b), TBDY: $\phi_{cu} = 0.00832321$

we (5.4c) = 0.01453958

$\phi_{ase} ((5.4d), TBDY) = (\phi_{ase1} * A_{ext} + \phi_{ase2} * A_{int}) / A_{sec} = 0.53375773$

$\phi_{ase1} = \text{Max}(((A_{conf,max1} - A_{noConf1}) / A_{conf,max1}) * (A_{conf,min1} / A_{conf,max1}), 0) = 0.53375773$

The definitions of A_{noConf} , $A_{conf,min}$ and $A_{conf,max}$ are derived from generalization of the rectangular sections confinement, which is expressed by (5.4d).

The generalization is done according to Mander, J., Priestley, M., and Park, R. (1988)

"Theoretical Stress-Strain Model for Confined Concrete."

J. Struct. Eng., 10.1061/(ASCE)0733-9445(1988)114:8(1804), 1804-1826.

$A_{conf,max1} = 464100.00$ is the confined core area at levels of member with hoops and is calculated as the area of core enclosed by the center lines of the external perimeter hoops.

$A_{conf,min1} = 395025.00$ is the confined core area at midway between the levels of hoops and is calculated by reducing all the dimensions of the area $A_{conf,max1}$ by a length equal to half the clear spacing between external hoops.

$A_{noConf1} = 173066.667$ is the unconfined external core area which is equal to $b_i^2/6$ as defined at (A.2).

$\phi_{ase2} (>= \phi_{ase1}) = \text{Max}(((A_{conf,max2} - A_{noConf2}) / A_{conf,max2}) * (A_{conf,min2} / A_{conf,max2}), 0) = 0.53375773$

The definitions of A_{noConf} , $A_{conf,min}$ and $A_{conf,max}$ are derived from generalization of the rectangular sections confinement, which is expressed by (5.4d).

The generalization is done according to Mander, J., Priestley, M., and Park, R. (1988)

"Theoretical Stress-Strain Model for Confined Concrete."

J. Struct. Eng., 10.1061/(ASCE)0733-9445(1988)114:8(1804), 1804-1826.

$A_{conf,max2} = 252164.00$ is the confined core area at levels of member with hoops and is calculated as the area of core enclosed by the center lines of the internal perimeter hoops.
 $A_{conf,min2} = 111441.00$ is the confined core area at midway between the levels of hoops and is calculated by reducing all the dimensions of the area $A_{conf,max2}$ by a length equal to half the clear spacing between internal hoops.

$A_{noConf2} = 110709.333$ is the unconfined internal core area which is equal to $b_i^2/6$ as defined at (A.2).

$p_{sh,min} \cdot F_{ywe} = \text{Min}(p_{sh,x} \cdot F_{ywe}, p_{sh,y} \cdot F_{ywe}) = 2.724$

Expression (5.4d) for $p_{sh,min} \cdot F_{ywe}$ has been multiplied by 0.3 according to 15.7.1.3 for members without earthquake detailing (90° closed stirrups)

$p_{sh,x} \cdot F_{ywe} = p_{sh1} \cdot F_{ywe1} + p_{s2} \cdot F_{ywe2} = 2.724$

p_{sh1} ((5.4d), TBDY) = $L_{stir1} \cdot A_{stir1} / (A_{sec} \cdot s_1) = 0.00301593$

L_{stir1} (Length of stirrups along Y) = 2160.00

A_{stir1} (stirrups area) = 78.53982

p_{s2} (5.4d) = $L_{stir2} \cdot A_{stir2} / (A_{sec} \cdot s_2) = 0.00056047$

L_{stir2} (Length of stirrups along Y) = 1568.00

A_{stir2} (stirrups area) = 50.26548

$p_{sh,y} \cdot F_{ywe} = p_{sh1} \cdot F_{ywe1} + p_{s2} \cdot F_{ywe2} = 3.25416$

p_{sh1} ((5.4d), TBDY) = $L_{stir1} \cdot A_{stir1} / (A_{sec} \cdot s_1) = 0.00357443$

L_{stir1} (Length of stirrups along X) = 2560.00

A_{stir1} (stirrups area) = 78.53982

p_{s2} ((5.4d), TBDY) = $L_{stir2} \cdot A_{stir2} / (A_{sec} \cdot s_2) = 0.00070345$

L_{stir2} (Length of stirrups along X) = 1968.00

A_{stir2} (stirrups area) = 50.26548

$A_{sec} = 562500.00$

$s_1 = 100.00$

$s_2 = 250.00$

$f_{ywe1} = 781.25$

$f_{ywe2} = 656.25$

$f_{ce} = 30.00$

From ((5.A5), TBDY), TBDY: $cc = 0.002$

c = confinement factor = 1.00

$y_1 = 0.0025$

$sh_1 = 0.008$

$ft_1 = 907.50$

$fy_1 = 756.25$

$su_1 = 0.032$

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor and also multiplied by the shear_factor according to 15.7.1.4, with Shear_factor = 1.00

$l_o/l_{ou,min} = l_b/l_d = 1.00$

$su_1 = 0.4 \cdot esu1_{nominal}$ ((5.5), TBDY) = 0.032

From table 5A.1, TBDY: $esu1_{nominal} = 0.08$,

For calculation of $esu1_{nominal}$ and y_1, sh_1, ft_1, fy_1 , it is considered characteristic value $fsy_1 = fs_1/1.2$, from table 5.1, TBDY.

y_1, sh_1, ft_1, fy_1 , are also multiplied by $\text{Min}(1, 1.25 \cdot (l_b/l_d)^{2/3})$, from 10.3.5, ASCE 41-17.

with $fs_1 = (f_{s,jacket} \cdot A_{sl,ten,jacket} + f_{s,core} \cdot A_{sl,ten,core}) / A_{sl,ten} = 756.25$

with $Es_1 = (E_{s,jacket} \cdot A_{sl,ten,jacket} + E_{s,core} \cdot A_{sl,ten,core}) / A_{sl,ten} = 200000.00$

$y_2 = 0.0025$

$sh_2 = 0.008$

$ft_2 = 900.1904$

$fy_2 = 750.1586$

$su_2 = 0.032$

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor and also multiplied by the shear_factor according to 15.7.1.4, with Shear_factor = 1.00

$l_o/l_{ou,min} = l_b/l_{b,min} = 1.00$

$su_2 = 0.4 \cdot esu2_{nominal}$ ((5.5), TBDY) = 0.032

From table 5A.1, TBDY: $esu2_{nominal} = 0.08$,

For calculation of $esu2_{nominal}$ and y_2, sh_2, ft_2, fy_2 , it is considered characteristic value $fsy_2 = fs_2/1.2$, from table 5.1, TBDY.

y_1, sh_1, ft_1, fy_1 , are also multiplied by $\text{Min}(1, 1.25 \cdot (l_b/l_d)^{2/3})$, from 10.3.5, ASCE 41-17.

with $fs_2 = (f_{s,jacket} \cdot A_{sl,com,jacket} + f_{s,core} \cdot A_{sl,com,core}) / A_{sl,com} = 750.1586$

```

with Es2 = (Es,jacket*Asl,com,jacket + Es,core*Asl,com,core)/Asl,com = 200000.00
yv = 0.0025
shv = 0.008
ftv = 902.993
fyv = 752.4941
suv = 0.032
using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00
lo/lou,min = lb/d = 1.00
suv = 0.4*esuv_nominal ((5.5), TBDY) = 0.032
From table 5A.1, TBDY: esuv_nominal = 0.08,
considering characteristic value fsyv = fsv/1.2, from table 5.1, TBDY
For calculation of esuv_nominal and yv, shv,ftv,fyv, it is considered
characteristic value fsyv = fsv/1.2, from table 5.1, TBDY.
y1, sh1,ft1,fy1, are also multiplied by Min(1,1.25*(lb/d)^2/3), from 10.3.5, ASCE 41-17.
with fsv = (fs,jacket*Asl,mid,jacket + fs,mid*Asl,mid,core)/Asl,mid = 752.4941
with Esv = (Es,jacket*Asl,mid,jacket + Es,mid*Asl,mid,core)/Asl,mid = 200000.00
1 = Asl,ten/(b*d)*(fs1/fc) = 0.05777595
2 = Asl,com/(b*d)*(fs2/fc) = 0.09216477
v = Asl,mid/(b*d)*(fsv/fc) = 0.09996047
and confined core properties:
b = 890.00
d = 677.00
d' = 13.00
fcc (5A.2, TBDY) = 30.00
cc (5A.5, TBDY) = 0.002
c = confinement factor = 1.00
1 = Asl,ten/(b*d)*(fs1/fc) = 0.06440379
2 = Asl,com/(b*d)*(fs2/fc) = 0.10273757
v = Asl,mid/(b*d)*(fsv/fc) = 0.11142757
Case/Assumption: Unconfined full section - Steel rupture
'satisfies Eq. (4.3)
--->
v < vs,y2 - LHS eq.(4.5) is not satisfied
--->
v < vs,c - RHS eq.(4.5) is satisfied
--->
su (4.8) = 0.15115045
Mu = MRc (4.15) = 2.0419E+009
u = su (4.1) = 5.3321191E-005

```

Calculation of ratio lb/d

Adequate Lap Length: lb/d >= 1

Calculation of Mu1-

Calculation of ultimate curvature u according to 4.1, Biskinis/Fardis 2013:

u = 6.8287974E-005
Mu = 2.1636E+009

with full section properties:

b = 450.00
d = 707.00
d' = 43.00
v = 0.00217843
N = 20792.05
fc = 30.00
co (5A.5, TBDY) = 0.002
Final value of cu: cu* = shear_factor * Max(cu, cc) = 0.00832321
The Shear_factor is considered equal to 1 (pure moment strength)

From (5.4b), TBDY: $c_u = 0.00832321$

w_e (5.4c) = 0.01453958

a_{se} ((5.4d), TBDY) = $(a_{se1} \cdot A_{ext} + a_{se2} \cdot A_{int}) / A_{sec} = 0.53375773$

$a_{se1} = \text{Max}(((A_{conf,max1} - A_{noConf1}) / A_{conf,max1}) \cdot (A_{conf,min1} / A_{conf,max1}), 0) = 0.53375773$

The definitions of A_{noConf} , $A_{conf,min}$ and $A_{conf,max}$ are derived from generalization of the rectangular sections confinement, which is expressed by (5.4d).

The generalization is done according to Mander, J., Priestley, M., and Park, R. (1988)

"Theoretical Stress-Strain Model for Confined Concrete."

J. Struct. Eng., 10.1061/(ASCE)0733-9445(1988)114:8(1804), 1804-1826.

$A_{conf,max1} = 464100.00$ is the confined core area at levels of member with hoops and

is calculated as the area of core enclosed by the center lines of the external perimeter hoops.

$A_{conf,min1} = 395025.00$ is the confined core area at midway between the levels of hoops and

is calculated by reducing all the dimensions of the area $A_{conf,max1}$ by a length

equal to half the clear spacing between external hoops.

$A_{noConf1} = 173066.667$ is the unconfined external core area which is equal to $b_i^2/6$ as defined at (A.2).

$a_{se2} (>= a_{se1}) = \text{Max}(((A_{conf,max2} - A_{noConf2}) / A_{conf,max2}) \cdot (A_{conf,min2} / A_{conf,max2}), 0) = 0.53375773$

The definitions of A_{noConf} , $A_{conf,min}$ and $A_{conf,max}$ are derived from generalization of the rectangular sections confinement, which is expressed by (5.4d).

The generalization is done according to Mander, J., Priestley, M., and Park, R. (1988)

"Theoretical Stress-Strain Model for Confined Concrete."

J. Struct. Eng., 10.1061/(ASCE)0733-9445(1988)114:8(1804), 1804-1826.

$A_{conf,max2} = 252164.00$ is the confined core area at levels of member with hoops and

is calculated as the area of core enclosed by the center lines of the internal perimeter hoops.

$A_{conf,min2} = 111441.00$ is the confined core area at midway between the levels of hoops and

is calculated by reducing all the dimensions of the area $A_{conf,max2}$ by a length

equal to half the clear spacing between internal hoops.

$A_{noConf2} = 110709.333$ is the unconfined internal core area which is equal to $b_i^2/6$ as defined at (A.2).

$p_{sh,min} \cdot F_{ywe} = \text{Min}(p_{sh,x} \cdot F_{ywe}, p_{sh,y} \cdot F_{ywe}) = 2.724$

Expression (5.4d) for $p_{sh,min} \cdot F_{ywe}$ has been multiplied by 0.3 according to 15.7.1.3 for members without earthquake detailing (90° closed stirrups)

$p_{sh,x} \cdot F_{ywe} = p_{sh1} \cdot F_{ywe1} + p_{s2} \cdot F_{ywe2} = 2.724$

p_{sh1} ((5.4d), TBDY) = $L_{stir1} \cdot A_{stir1} / (A_{sec} \cdot s_1) = 0.00301593$

L_{stir1} (Length of stirrups along Y) = 2160.00

A_{stir1} (stirrups area) = 78.53982

p_{sh2} (5.4d) = $L_{stir2} \cdot A_{stir2} / (A_{sec} \cdot s_2) = 0.00056047$

L_{stir2} (Length of stirrups along Y) = 1568.00

A_{stir2} (stirrups area) = 50.26548

$p_{sh,y} \cdot F_{ywe} = p_{sh1} \cdot F_{ywe1} + p_{s2} \cdot F_{ywe2} = 3.25416$

p_{sh1} ((5.4d), TBDY) = $L_{stir1} \cdot A_{stir1} / (A_{sec} \cdot s_1) = 0.00357443$

L_{stir1} (Length of stirrups along X) = 2560.00

A_{stir1} (stirrups area) = 78.53982

p_{sh2} ((5.4d), TBDY) = $L_{stir2} \cdot A_{stir2} / (A_{sec} \cdot s_2) = 0.00070345$

L_{stir2} (Length of stirrups along X) = 1968.00

A_{stir2} (stirrups area) = 50.26548

$A_{sec} = 562500.00$

$s_1 = 100.00$

$s_2 = 250.00$

$f_{ywe1} = 781.25$

$f_{ywe2} = 656.25$

$f_{ce} = 30.00$

From ((5.A5), TBDY), TBDY: $c_c = 0.002$

c = confinement factor = 1.00

$y_1 = 0.0025$

$sh_1 = 0.008$

$ft_1 = 900.1904$

$fy_1 = 750.1586$

$su_1 = 0.032$

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor

and also multiplied by the shear_factor according to 15.7.1.4, with

Shear_factor = 1.00

$l_o/l_{ou,min} = l_b/l_d = 1.00$

$su_1 = 0.4 \cdot esu_{1,nominal}$ ((5.5), TBDY) = 0.032

From table 5A.1, TBDY: $esu_{1,nominal} = 0.08$,

For calculation of $esu_{1,nominal}$ and y_1, sh_1, ft_1, fy_1 , it is considered

characteristic value $f_{sy1} = f_{s1}/1.2$, from table 5.1, TBDY.
 $y1, sh1, ft1, fy1$, are also multiplied by $\text{Min}(1, 1.25 \cdot (l_b/l_d)^{2/3})$, from 10.3.5, ASCE 41-17.
with $f_{s1} = (f_{sjacket} \cdot A_{s,ten,jacket} + f_{s,core} \cdot A_{s,ten,core})/A_{s,ten} = 750.1586$
with $E_{s1} = (E_{sjacket} \cdot A_{s,ten,jacket} + E_{s,core} \cdot A_{s,ten,core})/A_{s,ten} = 200000.00$
 $y2 = 0.0025$
 $sh2 = 0.008$
 $ft2 = 907.50$
 $fy2 = 756.25$
 $su2 = 0.032$
using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00
 $l_o/l_{o,min} = l_b/l_{b,min} = 1.00$
 $su2 = 0.4 \cdot esu2_nominal \text{ ((5.5), TBDY)} = 0.032$
From table 5A.1, TBDY: $esu2_nominal = 0.08$,
For calculation of $esu2_nominal$ and $y2, sh2, ft2, fy2$, it is considered
characteristic value $f_{sy2} = f_{s2}/1.2$, from table 5.1, TBDY.
 $y1, sh1, ft1, fy1$, are also multiplied by $\text{Min}(1, 1.25 \cdot (l_b/l_d)^{2/3})$, from 10.3.5, ASCE 41-17.
with $f_{s2} = (f_{sjacket} \cdot A_{s,com,jacket} + f_{s,core} \cdot A_{s,com,core})/A_{s,com} = 756.25$
with $E_{s2} = (E_{sjacket} \cdot A_{s,com,jacket} + E_{s,core} \cdot A_{s,com,core})/A_{s,com} = 200000.00$
 $yv = 0.0025$
 $shv = 0.008$
 $ftv = 902.993$
 $fyv = 752.4941$
 $suv = 0.032$
using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00
 $l_o/l_{o,min} = l_b/l_d = 1.00$
 $suv = 0.4 \cdot esuv_nominal \text{ ((5.5), TBDY)} = 0.032$
From table 5A.1, TBDY: $esuv_nominal = 0.08$,
considering characteristic value $f_{syv} = f_{sv}/1.2$, from table 5.1, TBDY
For calculation of $esuv_nominal$ and yv, shv, ftv, fyv , it is considered
characteristic value $f_{syv} = f_{sv}/1.2$, from table 5.1, TBDY.
 $y1, sh1, ft1, fy1$, are also multiplied by $\text{Min}(1, 1.25 \cdot (l_b/l_d)^{2/3})$, from 10.3.5, ASCE 41-17.
with $f_{sv} = (f_{sjacket} \cdot A_{s,mid,jacket} + f_{s,mid} \cdot A_{s,mid,core})/A_{s,mid} = 752.4941$
with $E_{sv} = (E_{sjacket} \cdot A_{s,mid,jacket} + E_{s,mid} \cdot A_{s,mid,core})/A_{s,mid} = 200000.00$
 $1 = A_{s,ten}/(b \cdot d) \cdot (f_{s1}/f_c) = 0.19457006$
 $2 = A_{s,com}/(b \cdot d) \cdot (f_{s2}/f_c) = 0.12197144$
 $v = A_{s,mid}/(b \cdot d) \cdot (f_{sv}/f_c) = 0.21102767$

and confined core properties:

$b = 390.00$
 $d = 677.00$
 $d' = 13.00$
 $f_{cc} \text{ (5A.2, TBDY)} = 30.00$
 $cc \text{ (5A.5, TBDY)} = 0.002$
 $c = \text{confinement factor} = 1.00$
 $1 = A_{s,ten}/(b \cdot d) \cdot (f_{s1}/f_c) = 0.23445239$
 $2 = A_{s,com}/(b \cdot d) \cdot (f_{s2}/f_c) = 0.14697275$
 $v = A_{s,mid}/(b \cdot d) \cdot (f_{sv}/f_c) = 0.25428343$

Case/Assumption: Unconfined full section - Steel rupture

' satisfies Eq. (4.3)

---->

$v < v_{s,y2}$ - LHS eq.(4.5) is not satisfied

---->

$v < v_{s,c}$ - RHS eq.(4.5) is satisfied

---->

$su \text{ (4.8)} = 0.33719414$

$Mu = MRc \text{ (4.15)} = 2.1636E+009$

$u = su \text{ (4.1)} = 6.8287974E-005$

Calculation of ratio l_b/l_d

Adequate Lap Length: $l_b/l_d \geq 1$

Calculation of Mu2+

Calculation of ultimate curvature μ according to 4.1, Biskinis/Fardis 2013:

$$\mu = 5.3321191E-005$$

$$Mu = 2.0419E+009$$

with full section properties:

$$b = 950.00$$

$$d = 707.00$$

$$d' = 43.00$$

$$v = 0.00103189$$

$$N = 20792.05$$

$$f_c = 30.00$$

$$co(5A.5, TBDY) = 0.002$$

$$\text{Final value of } \mu: \mu^* = \text{shear_factor} * \text{Max}(\mu, co) = 0.00832321$$

The Shear_factor is considered equal to 1 (pure moment strength)

$$\text{From (5.4b), TBDY: } \mu = 0.00832321$$

$$w_e(5.4c) = 0.01453958$$

$$ase((5.4d), TBDY) = (ase1 * A_{ext} + ase2 * A_{int}) / A_{sec} = 0.53375773$$

$$ase1 = \text{Max}(((A_{conf,max1} - A_{noConf1}) / A_{conf,max1}) * (A_{conf,min1} / A_{conf,max1}), 0) = 0.53375773$$

The definitions of A_{noConf} , $A_{conf,min}$ and $A_{conf,max}$ are derived from generalization of the rectangular sections confinement, which is expressed by (5.4d).

The generalization is done according to Mander, J., Priestley, M., and Park, R. (1988)

"Theoretical Stress-Strain Model for Confined Concrete."

J. Struct. Eng., 10.1061/(ASCE)0733-9445(1988)114:8(1804), 1804-1826.

$A_{conf,max1} = 464100.00$ is the confined core area at levels of member with hoops and is calculated as the area of core enclosed by the center lines of the external perimeter hoops.

$A_{conf,min1} = 395025.00$ is the confined core area at midway between the levels of hoops and is calculated by reducing all the dimensions of the area $A_{conf,max1}$ by a length equal to half the clear spacing between external hoops.

$A_{noConf1} = 173066.667$ is the unconfined external core area which is equal to $b_i^2/6$ as defined at (A.2).

$$ase2 (>= ase1) = \text{Max}(((A_{conf,max2} - A_{noConf2}) / A_{conf,max2}) * (A_{conf,min2} / A_{conf,max2}), 0) = 0.53375773$$

The definitions of A_{noConf} , $A_{conf,min}$ and $A_{conf,max}$ are derived from generalization of the rectangular sections confinement, which is expressed by (5.4d).

The generalization is done according to Mander, J., Priestley, M., and Park, R. (1988)

"Theoretical Stress-Strain Model for Confined Concrete."

J. Struct. Eng., 10.1061/(ASCE)0733-9445(1988)114:8(1804), 1804-1826.

$A_{conf,max2} = 252164.00$ is the confined core area at levels of member with hoops and is calculated as the area of core enclosed by the center lines of the internal perimeter hoops.

$A_{conf,min2} = 111441.00$ is the confined core area at midway between the levels of hoops and is calculated by reducing all the dimensions of the area $A_{conf,max2}$ by a length equal to half the clear spacing between internal hoops.

$A_{noConf2} = 110709.333$ is the unconfined internal core area which is equal to $b_i^2/6$ as defined at (A.2).

$$psh_{min} * F_{ywe} = \text{Min}(psh_x * F_{ywe}, psh_y * F_{ywe}) = 2.724$$

Expression (5.4d) for $psh_{min} * F_{ywe}$ has been multiplied by 0.3 according to 15.7.1.3 for members without earthquake detailing (90° closed stirrups)

$$psh_x * F_{ywe} = psh1 * F_{ywe1} + ps2 * F_{ywe2} = 2.724$$

$$psh1((5.4d), TBDY) = L_{stir1} * A_{stir1} / (A_{sec} * s1) = 0.00301593$$

$$L_{stir1} \text{ (Length of stirrups along Y)} = 2160.00$$

$$A_{stir1} \text{ (stirrups area)} = 78.53982$$

$$psh2(5.4d) = L_{stir2} * A_{stir2} / (A_{sec} * s2) = 0.00056047$$

$$L_{stir2} \text{ (Length of stirrups along Y)} = 1568.00$$

$$A_{stir2} \text{ (stirrups area)} = 50.26548$$

$$psh_y * F_{ywe} = psh1 * F_{ywe1} + ps2 * F_{ywe2} = 3.25416$$

$$psh1((5.4d), TBDY) = L_{stir1} * A_{stir1} / (A_{sec} * s1) = 0.00357443$$

$$L_{stir1} \text{ (Length of stirrups along X)} = 2560.00$$

$$A_{stir1} \text{ (stirrups area)} = 78.53982$$

$$psh2((5.4d), TBDY) = L_{stir2} * A_{stir2} / (A_{sec} * s2) = 0.00070345$$

$$L_{stir2} \text{ (Length of stirrups along X)} = 1968.00$$

$$A_{stir2} \text{ (stirrups area)} = 50.26548$$

$$A_{sec} = 562500.00$$

$s1 = 100.00$
 $s2 = 250.00$
 $fyw1 = 781.25$
 $fyw2 = 656.25$
 $fce = 30.00$
 From ((5.A.5), TBDY), TBDY: $cc = 0.002$
 $c = \text{confinement factor} = 1.00$
 $y1 = 0.0025$
 $sh1 = 0.008$
 $ft1 = 907.50$
 $fy1 = 756.25$
 $su1 = 0.032$
 using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
 and also multiplied by the shear_factor according to 15.7.1.4, with
 $\text{Shear_factor} = 1.00$
 $lo/lou, \min = lb/ld = 1.00$
 $su1 = 0.4 * esu1_nominal ((5.5), TBDY) = 0.032$
 From table 5A.1, TBDY: $esu1_nominal = 0.08$,
 For calculation of $esu1_nominal$ and $y1, sh1, ft1, fy1$, it is considered
 characteristic value $fsy1 = fs1/1.2$, from table 5.1, TBDY.
 $y1, sh1, ft1, fy1$, are also multiplied by $\text{Min}(1, 1.25 * (lb/ld)^{2/3})$, from 10.3.5, ASCE 41-17.
 with $fs1 = (fs_jacket * Asl, \text{ten}, \text{jacket} + fs_core * Asl, \text{ten}, \text{core}) / Asl, \text{ten} = 756.25$
 with $Es1 = (Es_jacket * Asl, \text{ten}, \text{jacket} + Es_core * Asl, \text{ten}, \text{core}) / Asl, \text{ten} = 200000.00$
 $y2 = 0.0025$
 $sh2 = 0.008$
 $ft2 = 900.1904$
 $fy2 = 750.1586$
 $su2 = 0.032$
 using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
 and also multiplied by the shear_factor according to 15.7.1.4, with
 $\text{Shear_factor} = 1.00$
 $lo/lou, \min = lb/lb, \min = 1.00$
 $su2 = 0.4 * esu2_nominal ((5.5), TBDY) = 0.032$
 From table 5A.1, TBDY: $esu2_nominal = 0.08$,
 For calculation of $esu2_nominal$ and $y2, sh2, ft2, fy2$, it is considered
 characteristic value $fsy2 = fs2/1.2$, from table 5.1, TBDY.
 $y1, sh1, ft1, fy1$, are also multiplied by $\text{Min}(1, 1.25 * (lb/ld)^{2/3})$, from 10.3.5, ASCE 41-17.
 with $fs2 = (fs_jacket * Asl, \text{com}, \text{jacket} + fs_core * Asl, \text{com}, \text{core}) / Asl, \text{com} = 750.1586$
 with $Es2 = (Es_jacket * Asl, \text{com}, \text{jacket} + Es_core * Asl, \text{com}, \text{core}) / Asl, \text{com} = 200000.00$
 $yv = 0.0025$
 $shv = 0.008$
 $ftv = 902.993$
 $fyv = 752.4941$
 $suv = 0.032$
 using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
 and also multiplied by the shear_factor according to 15.7.1.4, with
 $\text{Shear_factor} = 1.00$
 $lo/lou, \min = lb/ld = 1.00$
 $suv = 0.4 * esuv_nominal ((5.5), TBDY) = 0.032$
 From table 5A.1, TBDY: $esuv_nominal = 0.08$,
 considering characteristic value $fsyv = fsv/1.2$, from table 5.1, TBDY
 For calculation of $esuv_nominal$ and yv, shv, ftv, fyv , it is considered
 characteristic value $fsyv = fsv/1.2$, from table 5.1, TBDY.
 $y1, sh1, ft1, fy1$, are also multiplied by $\text{Min}(1, 1.25 * (lb/ld)^{2/3})$, from 10.3.5, ASCE 41-17.
 with $fsv = (fs_jacket * Asl, \text{mid}, \text{jacket} + fs_mid * Asl, \text{mid}, \text{core}) / Asl, \text{mid} = 752.4941$
 with $Es_v = (Es_jacket * Asl, \text{mid}, \text{jacket} + Es_mid * Asl, \text{mid}, \text{core}) / Asl, \text{mid} = 200000.00$
 $1 = Asl, \text{ten} / (b * d) * (fs1 / fc) = 0.05777595$
 $2 = Asl, \text{com} / (b * d) * (fs2 / fc) = 0.09216477$
 $v = Asl, \text{mid} / (b * d) * (fsv / fc) = 0.09996047$
 and confined core properties:
 $b = 890.00$
 $d = 677.00$
 $d' = 13.00$
 $fcc (5A.2, TBDY) = 30.00$
 $cc (5A.5, TBDY) = 0.002$
 $c = \text{confinement factor} = 1.00$
 $1 = Asl, \text{ten} / (b * d) * (fs1 / fc) = 0.06440379$

$$2 = A_{sl,com}/(b*d)*(f_{s2}/f_c) = 0.10273757$$

$$v = A_{sl,mid}/(b*d)*(f_{sv}/f_c) = 0.11142757$$

Case/Assumption: Unconfined full section - Steel rupture

' satisfies Eq. (4.3)

---->

$v < v_{s,y2}$ - LHS eq.(4.5) is not satisfied

---->

$v < v_{s,c}$ - RHS eq.(4.5) is satisfied

---->

$$s_u(4.8) = 0.15115045$$

$$\mu_u = M_{Rc}(4.15) = 2.0419E+009$$

$$u = s_u(4.1) = 5.3321191E-005$$

Calculation of ratio l_b/d

Adequate Lap Length: $l_b/d \geq 1$

Calculation of μ_{u2} -

Calculation of ultimate curvature μ_u according to 4.1, Biskinis/Fardis 2013:

$$u = 6.8287974E-005$$

$$\mu_u = 2.1636E+009$$

with full section properties:

$$b = 450.00$$

$$d = 707.00$$

$$d' = 43.00$$

$$v = 0.00217843$$

$$N = 20792.05$$

$$f_c = 30.00$$

$$\alpha_{co}(5A.5, TBDY) = 0.002$$

$$\text{Final value of } \alpha_{cu}: \alpha_{cu}^* = \text{shear_factor} * \text{Max}(\alpha_{cu}, \alpha_{cc}) = 0.00832321$$

The Shear_factor is considered equal to 1 (pure moment strength)

$$\text{From (5.4b), TBDY: } \alpha_{cu} = 0.00832321$$

$$\alpha_{we}(5.4c) = 0.01453958$$

$$\alpha_{ase}((5.4d), TBDY) = (\alpha_{ase1} * A_{ext} + \alpha_{ase2} * A_{int}) / A_{sec} = 0.53375773$$

$$\alpha_{ase1} = \text{Max}(((A_{conf,max1} - A_{noConf1}) / A_{conf,max1}) * (A_{conf,min1} / A_{conf,max1}), 0) = 0.53375773$$

The definitions of A_{noConf} , $A_{conf,min}$ and $A_{conf,max}$ are derived from generalization of the rectangular sections confinement, which is expressed by (5.4d).

The generalization is done according to Mander, J., Priestley, M., and Park, R. (1988)

"Theoretical Stress-Strain Model for Confined Concrete."

J. Struct. Eng., 10.1061/(ASCE)0733-9445(1988)114:8(1804), 1804-1826.

$A_{conf,max1} = 464100.00$ is the confined core area at levels of member with hoops and is calculated as the area of core enclosed by the center lines of the external perimeter hoops.

$A_{conf,min1} = 395025.00$ is the confined core area at midway between the levels of hoops and is calculated by reducing all the dimensions of the area $A_{conf,max1}$ by a length equal to half the clear spacing between external hoops.

$A_{noConf1} = 173066.667$ is the unconfined external core area which is equal to $b_i^2/6$ as defined at (A.2).

$$\alpha_{ase2}(\geq \alpha_{ase1}) = \text{Max}(((A_{conf,max2} - A_{noConf2}) / A_{conf,max2}) * (A_{conf,min2} / A_{conf,max2}), 0) = 0.53375773$$

The definitions of A_{noConf} , $A_{conf,min}$ and $A_{conf,max}$ are derived from generalization of the rectangular sections confinement, which is expressed by (5.4d).

The generalization is done according to Mander, J., Priestley, M., and Park, R. (1988)

"Theoretical Stress-Strain Model for Confined Concrete."

J. Struct. Eng., 10.1061/(ASCE)0733-9445(1988)114:8(1804), 1804-1826.

$A_{conf,max2} = 252164.00$ is the confined core area at levels of member with hoops and is calculated as the area of core enclosed by the center lines of the internal perimeter hoops.

$A_{conf,min2} = 111441.00$ is the confined core area at midway between the levels of hoops and is calculated by reducing all the dimensions of the area $A_{conf,max2}$ by a length equal to half the clear spacing between internal hoops.

$A_{noConf2} = 110709.333$ is the unconfined internal core area which is equal to $b_i^2/6$ as defined at (A.2).

$$p_{sh,min} * F_{ywe} = \text{Min}(p_{sh,x} * F_{ywe}, p_{sh,y} * F_{ywe}) = 2.724$$

Expression (5.4d) for $p_{sh,min} * F_{ywe}$ has been multiplied by 0.3 according to 15.7.1.3 for members without

earthquake detailing (90° closed stirrups)

psh_x*Fywe = psh1*Fywe1+ps2*Fywe2 = 2.724
psh1 ((5.4d), TBDY) = Lstir1*Astir1/(Asec*s1) = 0.00301593
Lstir1 (Length of stirrups along Y) = 2160.00
Astir1 (stirrups area) = 78.53982
psh2 (5.4d) = Lstir2*Astir2/(Asec*s2) = 0.00056047
Lstir2 (Length of stirrups along Y) = 1568.00
Astir2 (stirrups area) = 50.26548

psh_y*Fywe = psh1*Fywe1+ps2*Fywe2 = 3.25416
psh1 ((5.4d), TBDY) = Lstir1*Astir1/(Asec*s1) = 0.00357443
Lstir1 (Length of stirrups along X) = 2560.00
Astir1 (stirrups area) = 78.53982
psh2 ((5.4d), TBDY) = Lstir2*Astir2/(Asec*s2) = 0.00070345
Lstir2 (Length of stirrups along X) = 1968.00
Astir2 (stirrups area) = 50.26548

Asec = 562500.00

s1 = 100.00

s2 = 250.00

fywe1 = 781.25

fywe2 = 656.25

fce = 30.00

From ((5.A5), TBDY), TBDY: cc = 0.002

c = confinement factor = 1.00

y1 = 0.0025

sh1 = 0.008

ft1 = 900.1904

fy1 = 750.1586

su1 = 0.032

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00

lo/lou,min = lb/lb = 1.00

su1 = 0.4*esu1_nominal ((5.5), TBDY) = 0.032

From table 5A.1, TBDY: esu1_nominal = 0.08,

For calculation of esu1_nominal and y1, sh1,ft1,fy1, it is considered
characteristic value fsy1 = fs1/1.2, from table 5.1, TBDY.

y1, sh1,ft1,fy1, are also multiplied by $\text{Min}(1, 1.25 \cdot (lb/lb)^{2/3})$, from 10.3.5, ASCE 41-17.

with fs1 = (fs,jacket*Asl,ten,jacket + fs,core*Asl,ten,core)/Asl,ten = 750.1586

with Es1 = (Es,jacket*Asl,ten,jacket + Es,core*Asl,ten,core)/Asl,ten = 200000.00

y2 = 0.0025

sh2 = 0.008

ft2 = 907.50

fy2 = 756.25

su2 = 0.032

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00

lo/lou,min = lb/lb,min = 1.00

su2 = 0.4*esu2_nominal ((5.5), TBDY) = 0.032

From table 5A.1, TBDY: esu2_nominal = 0.08,

For calculation of esu2_nominal and y2, sh2,ft2,fy2, it is considered
characteristic value fsy2 = fs2/1.2, from table 5.1, TBDY.

y1, sh1,ft1,fy1, are also multiplied by $\text{Min}(1, 1.25 \cdot (lb/lb)^{2/3})$, from 10.3.5, ASCE 41-17.

with fs2 = (fs,jacket*Asl,com,jacket + fs,core*Asl,com,core)/Asl,com = 756.25

with Es2 = (Es,jacket*Asl,com,jacket + Es,core*Asl,com,core)/Asl,com = 200000.00

yv = 0.0025

shv = 0.008

ftv = 902.993

fyv = 752.4941

suv = 0.032

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00

lo/lou,min = lb/lb = 1.00

$suv = 0.4 * esuv_nominal ((5.5), TBDY) = 0.032$
 From table 5A.1, TBDY: $esuv_nominal = 0.08$,
 considering characteristic value $fsyv = fsv/1.2$, from table 5.1, TBDY
 For calculation of $esuv_nominal$ and yv , shv , ftv , fyv , it is considered
 characteristic value $fsyv = fsv/1.2$, from table 5.1, TBDY.
 $y1$, $sh1$, $ft1$, $fy1$, are also multiplied by $Min(1, 1.25 * (lb/ld)^{2/3})$, from 10.3.5, ASCE 41-17.
 with $fsv = (fs_jacket * Asl_mid_jacket + fs_mid * Asl_mid_core) / Asl_mid = 752.4941$
 with $Esv = (Es_jacket * Asl_mid_jacket + Es_mid * Asl_mid_core) / Asl_mid = 200000.00$
 $1 = Asl_ten / (b * d) * (fs1 / fc) = 0.19457006$
 $2 = Asl_com / (b * d) * (fs2 / fc) = 0.12197144$
 $v = Asl_mid / (b * d) * (fsv / fc) = 0.21102767$

and confined core properties:

$b = 390.00$
 $d = 677.00$
 $d' = 13.00$
 $fcc (5A.2, TBDY) = 30.00$
 $cc (5A.5, TBDY) = 0.002$
 $c = \text{confinement factor} = 1.00$
 $1 = Asl_ten / (b * d) * (fs1 / fc) = 0.23445239$
 $2 = Asl_com / (b * d) * (fs2 / fc) = 0.14697275$
 $v = Asl_mid / (b * d) * (fsv / fc) = 0.25428343$

Case/Assumption: Unconfined full section - Steel rupture
 ' satisfies Eq. (4.3)

--->
 $v < vs_y2$ - LHS eq.(4.5) is not satisfied
 --->
 $v < vs_c$ - RHS eq.(4.5) is satisfied
 --->
 $su (4.8) = 0.33719414$
 $Mu = MRc (4.15) = 2.1636E+009$
 $u = su (4.1) = 6.8287974E-005$

Calculation of ratio lb/ld

Adequate Lap Length: $lb/ld \geq 1$

Calculation of Shear Strength $Vr = Min(Vr1, Vr2) = 1.2916E+006$

Calculation of Shear Strength at edge 1, $Vr1 = 1.2916E+006$

$Vr1 = VCol ((10.3), ASCE 41-17) = knl * VColO$

$VColO = 1.2916E+006$

$knl = 1$ (zero step-static loading)

NOTE: In expression (10-3) ' $Vs = Av * fy * d / s$ ' is replaced by ' $Vs + f * Vf$ '
 where Vf is the contribution of FRPs (11.3), ACI 440).

$= 1$ (normal-weight concrete)
 Mean concrete strength: $fc' = (fc'_jacket * Area_jacket + fc'_core * Area_core) / Area_section = 27.20$, but $fc'^{0.5} \leq 8.3$
 MPa (22.5.3.1, ACI 318-14)
 $M/Vd = 2.00$
 $Mu = 5174.584$
 $Vu = 8.5087964E-020$
 $d = 0.8 * h = 600.00$
 $Nu = 20792.05$
 $Ag = 337500.00$
 From (11.5.4.8), ACI 318-14: $Vs = Vs_jacket + Vs_core = 1.0354E+006$
 where:
 $Vs_jacket = Vs_j1 + Vs_j2 = 942477.796$
 $Vs_j1 = 589048.623$ is calculated for section web jacket, with:
 $d = 600.00$
 $Av = 157079.633$
 $fy = 625.00$
 $s = 100.00$

$V_{s,j1}$ is multiplied by $Col,j1 = 1.00$
 $s/d = 0.16666667$
 $V_{s,j2} = 353429.174$ is calculated for section flange jacket, with:
 $d = 360.00$
 $A_v = 157079.633$
 $f_y = 625.00$
 $s = 100.00$
 $V_{s,j2}$ is multiplied by $Col,j2 = 1.00$
 $s/d = 0.27777778$
 $V_{s,core} = V_{s,c1} + V_{s,c2} = 92890.612$
 $V_{s,c1} = 92890.612$ is calculated for section web core, with:
 $d = 440.00$
 $A_v = 100530.965$
 $f_y = 525.00$
 $s = 250.00$
 $V_{s,c1}$ is multiplied by $Col,c1 = 1.00$
 $s/d = 0.56818182$
 $V_{s,c2} = 0.00$ is calculated for section flange core, with:
 $d = 200.00$
 $A_v = 100530.965$
 $f_y = 525.00$
 $s = 250.00$
 $V_{s,c2}$ is multiplied by $Col,c2 = 0.00$
 $s/d = 1.25$
 $V_f ((11-3)-(11.4), ACI 440) = 0.00$
 From (11-11), ACI 440: $V_s + V_f \leq 935437.922$
 $bw = 450.00$

Calculation of Shear Strength at edge 2, $V_{r2} = 1.2916E+006$
 $V_{r2} = V_{Col} ((10.3), ASCE 41-17) = knl * V_{Col0}$
 $V_{Col0} = 1.2916E+006$
 $knl = 1$ (zero step-static loading)

NOTE: In expression (10-3) ' $V_s = A_v * f_y * d / s$ ' is replaced by ' $V_s + f * V_f$ '
 where V_f is the contribution of FRPs (11.3), ACI 440).

$= 1$ (normal-weight concrete)
 Mean concrete strength: $f'_c = (f'_{c,jacket} * Area_{jacket} + f'_{c,core} * Area_{core}) / Area_{section} = 27.20$, but $f'_c^{0.5} \leq 8.3$
 MPa (22.5.3.1, ACI 318-14)
 $M/Vd = 2.00$
 $M_u = 5174.584$
 $V_u = 8.5087964E-020$
 $d = 0.8 * h = 600.00$
 $N_u = 20792.05$
 $A_g = 337500.00$
 From (11.5.4.8), ACI 318-14: $V_s = V_{s,jacket} + V_{s,core} = 1.0354E+006$
 where:
 $V_{s,jacket} = V_{s,j1} + V_{s,j2} = 942477.796$
 $V_{s,j1} = 589048.623$ is calculated for section web jacket, with:
 $d = 600.00$
 $A_v = 157079.633$
 $f_y = 625.00$
 $s = 100.00$
 $V_{s,j1}$ is multiplied by $Col,j1 = 1.00$
 $s/d = 0.16666667$
 $V_{s,j2} = 353429.174$ is calculated for section flange jacket, with:
 $d = 360.00$
 $A_v = 157079.633$
 $f_y = 625.00$
 $s = 100.00$
 $V_{s,j2}$ is multiplied by $Col,j2 = 1.00$
 $s/d = 0.27777778$
 $V_{s,core} = V_{s,c1} + V_{s,c2} = 92890.612$
 $V_{s,c1} = 92890.612$ is calculated for section web core, with:
 $d = 440.00$
 $A_v = 100530.965$

$f_y = 525.00$
 $s = 250.00$
 $V_{s,c1}$ is multiplied by $Col,c1 = 1.00$
 $s/d = 0.56818182$
 $V_{s,c2} = 0.00$ is calculated for section flange core, with:
 $d = 200.00$
 $A_v = 100530.965$
 $f_y = 525.00$
 $s = 250.00$
 $V_{s,c2}$ is multiplied by $Col,c2 = 0.00$
 $s/d = 1.25$
 $V_f ((11-3)-(11.4), ACI 440) = 0.00$
 From (11-11), ACI 440: $V_s + V_f \leq 935437.922$
 $bw = 450.00$

End Of Calculation of Shear Capacity ratio for element: column JTC1 of floor 1
 At local axis: 3

Start Of Calculation of Shear Capacity ratio for element: column JTC1 of floor 1
 At Shear local axis: 2
 (Bending local axis: 3)
 Section Type: rcjctcs

Constant Properties

Knowledge Factor, $\phi = 0.80$
 Mean strength values are used for both shear and moment calculations.
 Consequently:
 Jacket
 New material of Secondary Member: Concrete Strength, $f_c = f_{cm} = 30.00$
 New material of Secondary Member: Steel Strength, $f_s = f_{sm} = 625.00$
 Concrete Elasticity, $E_c = 25742.96$
 Steel Elasticity, $E_s = 200000.00$
 Existing Column
 Existing material of Secondary Member: Concrete Strength, $f_c = f_{cm} = 24.00$
 Existing material of Secondary Member: Steel Strength, $f_s = f_{sm} = 525.00$
 Concrete Elasticity, $E_c = 23025.204$
 Steel Elasticity, $E_s = 200000.00$
 #####
 Note: Especially for the calculation of moment strengths,
 the above steel re-bar strengths are multiplied by 1.25 according to R18.6.5, ACI 318-14
 Jacket
 New material: Steel Strength, $f_s = 1.25 \cdot f_{sm} = 781.25$
 Existing Column
 Existing material: Steel Strength, $f_s = 1.25 \cdot f_{sm} = 656.25$
 #####
 Max Height, $H_{max} = 750.00$
 Min Height, $H_{min} = 450.00$
 Max Width, $W_{max} = 950.00$
 Min Width, $W_{min} = 450.00$
 Eccentricity, $Ecc = 250.00$
 Jacket Thickness, $t_j = 100.00$
 Cover Thickness, $c = 25.00$
 Mean Confinement Factor overall section = 1.00
 Element Length, $L = 3000.00$
 Secondary Member
 Smooth Bars
 Ductile Steel
 Without Detailing for Earthquake Resistance (including stirrups not closed at 135°)
 Longitudinal Bars With Ends Lapped Starting at the End Sections
 Adequate Lap Length ($l_o/l_{ou,min} \geq 1$)
 No FRP Wrapping

Stepwise Properties

At local axis: 2

EDGE -A-

Shear Force, $V_a = 5.2099631E-036$

EDGE -B-

Shear Force, $V_b = -5.2099631E-036$

BOTH EDGES

Axial Force, $F = -20792.05$

Longitudinal Reinforcement Area Distribution (in 2 divisions)

-Tension: $As_t = 0.00$

-Compression: $As_c = 6691.592$

Longitudinal Reinforcement Area Distribution (in 3 divisions)

-Tension: $As_{t,ten} = 1539.38$

-Compression: $As_{c,com} = 1539.38$

-Middle: $As_{l,mid} = 3612.832$

Calculation of Shear Capacity ratio, $V_e/V_r = 1.08994$

Member Controlled by Shear ($V_e/V_r > 1$)

Calculation of Shear Demand from fig. R18.6.5, ACI 318-14 $V_e = (M_{pr1} + M_{pr2})/l_n = 1.7820E+006$ with

$M_{pr1} = \text{Max}(\mu_{1+}, \mu_{1-}) = 2.6730E+009$

$\mu_{1+} = 2.6730E+009$, is the ultimate moment strength at the edge 1 of the member in the actual moment direction which is defined for the static loading combination

$\mu_{1-} = 2.6730E+009$, is the ultimate moment strength at the edge 1 of the member in the opposite moment direction which is defined for the static loading combination

$M_{pr2} = \text{Max}(\mu_{2+}, \mu_{2-}) = 2.6730E+009$

$\mu_{2+} = 2.6730E+009$, is the ultimate moment strength at the edge 2 of the member in the actual moment direction which is defined for the static loading combination

$\mu_{2-} = 2.6730E+009$, is the ultimate moment strength at the edge 2 of the member in the opposite moment direction which is defined for the static loading combination

Calculation of μ_{1+}

Calculation of ultimate curvature μ according to 4.1, Biskinis/Fardis 2013:

$\mu = 4.9274896E-005$

$M_u = 2.6730E+009$

with full section properties:

$b = 450.00$

$d = 907.00$

$d' = 43.00$

$v = 0.00169807$

$N = 20792.05$

$f_c = 30.00$

ϕ (5A.5, TBDY) = 0.002

Final value of ϕ : $\phi^* = \text{shear_factor} * \text{Max}(\phi_c, \phi_s) = 0.00832321$

The Shear_factor is considered equal to 1 (pure moment strength)

From (5.4b), TBDY: $\phi_c = 0.00832321$

we (5.4c) = 0.01453958

ϕ_{ase} ((5.4d), TBDY) = $(\phi_{ase1} * A_{ext} + \phi_{ase2} * A_{int}) / A_{sec} = 0.53375773$

$\phi_{ase1} = \text{Max}(((A_{conf,max1} - A_{noConf1}) / A_{conf,max1}) * (A_{conf,min1} / A_{conf,max1}), 0) = 0.53375773$

The definitions of A_{noConf} , $A_{conf,min}$ and $A_{conf,max}$ are derived from generalization of the rectangular sections confinement, which is expressed by (5.4d).

The generalization is done according to Mander, J., Priestley, M., and Park, R. (1988)

"Theoretical Stress-Strain Model for Confined Concrete."

J. Struct. Eng., 10.1061/(ASCE)0733-9445(1988)114:8(1804), 1804-1826.

$A_{conf,max1} = 464100.00$ is the confined core area at levels of member with hoops and

is calculated as the area of core enclosed by the center lines of the external perimeter hoops.

$A_{conf,min1} = 395025.00$ is the confined core area at midway between the levels of hoops and

is calculated by reducing all the dimensions of the area Aconf,max1 by a length equal to half the clear spacing between external hoops.

AnoConf1 = 173066.667 is the unconfined external core area which is equal to $b_i^2/6$ as defined at (A.2).
ase2 (\geq ase1) = $\text{Max}(((A_{\text{conf,max2}} - A_{\text{noConf2}})/A_{\text{conf,max2}}) * (A_{\text{conf,min2}}/A_{\text{conf,max2}}), 0) = 0.53375773$

The definitions of AnoConf, Aconf,min and Aconf,max are derived from generalization of the rectangular sections confinement, which is expressed by (5.4d).

The generalization is done according to Mander, J., Priestley, M., and Park, R. (1988) "Theoretical Stress-Strain Model for Confined Concrete."

J. Struct. Eng., 10.1061/(ASCE)0733-9445(1988)114:8(1804), 1804-1826.

Aconf,max2 = 252164.00 is the confined core area at levels of member with hoops and is calculated as the area of core enclosed by the center lines of the internal perimeter hoops.

Aconf,min2 = 111441.00 is the confined core area at midway between the levels of hoops and is calculated by reducing all the dimensions of the area Aconf,max2 by a length equal to half the clear spacing between internal hoops.

AnoConf2 = 110709.333 is the unconfined internal core area which is equal to $b_i^2/6$ as defined at (A.2).
psh,min*Fywe = $\text{Min}(psh_x * Fywe, psh_y * Fywe) = 2.724$

Expression (5.4d) for psh,min*Fywe has been multiplied by 0.3 according to 15.7.1.3 for members without earthquake detailing (90° closed stirrups)

psh_x*Fywe = psh1*Fywe1 + ps2*Fywe2 = 2.724
psh1 ((5.4d), TBDY) = $L_{\text{stir1}} * A_{\text{stir1}} / (A_{\text{sec}} * s_1) = 0.00301593$
Lstir1 (Length of stirrups along Y) = 2160.00
Astir1 (stirrups area) = 78.53982
psh2 ((5.4d)) = $L_{\text{stir2}} * A_{\text{stir2}} / (A_{\text{sec}} * s_2) = 0.00056047$
Lstir2 (Length of stirrups along Y) = 1568.00
Astir2 (stirrups area) = 50.26548

psh_y*Fywe = psh1*Fywe1 + ps2*Fywe2 = 3.25416
psh1 ((5.4d), TBDY) = $L_{\text{stir1}} * A_{\text{stir1}} / (A_{\text{sec}} * s_1) = 0.00357443$
Lstir1 (Length of stirrups along X) = 2560.00
Astir1 (stirrups area) = 78.53982
psh2 ((5.4d), TBDY) = $L_{\text{stir2}} * A_{\text{stir2}} / (A_{\text{sec}} * s_2) = 0.00070345$
Lstir2 (Length of stirrups along X) = 1968.00
Astir2 (stirrups area) = 50.26548

Asec = 562500.00

s1 = 100.00

s2 = 250.00

fywe1 = 781.25

fywe2 = 656.25

fce = 30.00

From ((5.A5), TBDY), TBDY: cc = 0.002

c = confinement factor = 1.00

y1 = 0.0025

sh1 = 0.008

ft1 = 907.50

fy1 = 756.25

su1 = 0.032

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor and also multiplied by the shear_factor according to 15.7.1.4, with Shear_factor = 1.00

lo/lou,min = lb/ld = 1.00

su1 = $0.4 * esu1_{\text{nominal}} ((5.5), \text{TBDY}) = 0.032$

From table 5A.1, TBDY: esu1_nominal = 0.08,

For calculation of esu1_nominal and y1, sh1, ft1, fy1, it is considered characteristic value fsy1 = fs1/1.2, from table 5.1, TBDY.

y1, sh1, ft1, fy1, are also multiplied by $\text{Min}(1, 1.25 * (lb/ld)^{2/3})$, from 10.3.5, ASCE 41-17.

with fs1 = $(f_{s,jacket} * A_{s,ten,jacket} + f_{s,core} * A_{s,ten,core}) / A_{s,ten} = 756.25$

with Es1 = $(E_{s,jacket} * A_{s,ten,jacket} + E_{s,core} * A_{s,ten,core}) / A_{s,ten} = 200000.00$

y2 = 0.0025

sh2 = 0.008

ft2 = 907.50

fy2 = 756.25

su2 = 0.032

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor and also multiplied by the shear_factor according to 15.7.1.4, with Shear_factor = 1.00

```

lo/lou,min = lb/lbmin = 1.00
su2 = 0.4*esu2,nominal ((5.5), TBDY) = 0.032
From table 5A.1, TBDY: esu2,nominal = 0.08,
For calculation of esu2,nominal and y2, sh2,ft2,fy2, it is considered
characteristic value fsy2 = fs2/1.2, from table 5.1, TBDY.
y1, sh1,ft1,fy1, are also multiplied by Min(1,1.25*(lb/ld)2/3), from 10.3.5, ASCE 41-17.
with fs2 = (fsjacket*Aslcom,jacket + fscore*Aslcom,core)/Aslcom = 756.25
with Es2 = (Esjacket*Aslcom,jacket + Escore*Aslcom,core)/Aslcom = 200000.00
yv = 0.0025
shv = 0.008
ftv = 899.1522
fyv = 749.2935
suv = 0.032
using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00
lo/lou,min = lb/ld = 1.00
suv = 0.4*esuvnominal ((5.5), TBDY) = 0.032
From table 5A.1, TBDY: esuvnominal = 0.08,
considering characteristic value fsyv = fsv/1.2, from table 5.1, TBDY
For calculation of esuvnominal and yv, shv,ftv,fyv, it is considered
characteristic value fsyv = fsv/1.2, from table 5.1, TBDY.
y1, sh1,ft1,fy1, are also multiplied by Min(1,1.25*(lb/ld)2/3), from 10.3.5, ASCE 41-17.
with fsv = (fsjacket*Aslmid,jacket + fsmid*Aslmid,core)/Aslmid = 749.2935
with Esv = (Esjacket*Aslmid,jacket + Esmid*Aslmid,core)/Aslmid = 200000.00
1 = Aslten/(b*d)*(fs1/fc) = 0.09507586
2 = Aslcom/(b*d)*(fs2/fc) = 0.09507586
v = Aslmid/(b*d)*(fsv/fc) = 0.22108466
and confined core properties:
b = 390.00
d = 877.00
d' = 13.00
fcc (5A.2, TBDY) = 30.00
cc (5A.5, TBDY) = 0.002
c = confinement factor = 1.00
1 = Aslten/(b*d)*(fs1/fc) = 0.11345559
2 = Aslcom/(b*d)*(fs2/fc) = 0.11345559
v = Aslmid/(b*d)*(fsv/fc) = 0.26382395
Case/Assumption: Unconfined full section - Steel rupture
'satisfies Eq. (4.3)
---->
v < vs,y2 - LHS eq.(4.5) is not satisfied
---->
v < vs,c - RHS eq.(4.5) is satisfied
---->
su (4.8) = 0.28399348
Mu = MRc (4.15) = 2.6730E+009
u = su (4.1) = 4.9274896E-005

```

Calculation of ratio lb/l_d

Adequate Lap Length: lb/l_d >= 1

Calculation of Mu1-

Calculation of ultimate curvature u according to 4.1, Biskinis/Fardis 2013:

u = 4.9274896E-005

Mu = 2.6730E+009

with full section properties:

b = 450.00

d = 907.00

$d' = 43.00$
 $v = 0.00169807$
 $N = 20792.05$
 $f_c = 30.00$
 $co(5A.5, TBDY) = 0.002$
 Final value of cu : $cu^* = shear_factor * Max(cu, cc) = 0.00832321$
 The Shear_factor is considered equal to 1 (pure moment strength)
 From (5.4b), TBDY: $cu = 0.00832321$
 $we(5.4c) = 0.01453958$
 $ase((5.4d), TBDY) = (ase1 * A_{ext} + ase2 * A_{int}) / A_{sec} = 0.53375773$
 $ase1 = Max(((A_{conf,max1} - A_{noConf1}) / A_{conf,max1}) * (A_{conf,min1} / A_{conf,max1}), 0) = 0.53375773$
 The definitions of A_{noConf} , $A_{conf,min}$ and $A_{conf,max}$ are derived from generalization of the rectangular sections confinement, which is expressed by (5.4d).
 The generalization is done according to Mander, J., Priestley, M., and Park, R. (1988) "Theoretical Stress-Strain Model for Confined Concrete."
 J. Struct. Eng., 10.1061/(ASCE)0733-9445(1988)114:8(1804), 1804-1826.
 $A_{conf,max1} = 464100.00$ is the confined core area at levels of member with hoops and is calculated as the area of core enclosed by the center lines of the external perimeter hoops.
 $A_{conf,min1} = 395025.00$ is the confined core area at midway between the levels of hoops and is calculated by reducing all the dimensions of the area $A_{conf,max1}$ by a length equal to half the clear spacing between external hoops.
 $A_{noConf1} = 173066.667$ is the unconfined external core area which is equal to $b_i^2/6$ as defined at (A.2).
 $ase2 (>= ase1) = Max(((A_{conf,max2} - A_{noConf2}) / A_{conf,max2}) * (A_{conf,min2} / A_{conf,max2}), 0) = 0.53375773$
 The definitions of A_{noConf} , $A_{conf,min}$ and $A_{conf,max}$ are derived from generalization of the rectangular sections confinement, which is expressed by (5.4d).
 The generalization is done according to Mander, J., Priestley, M., and Park, R. (1988) "Theoretical Stress-Strain Model for Confined Concrete."
 J. Struct. Eng., 10.1061/(ASCE)0733-9445(1988)114:8(1804), 1804-1826.
 $A_{conf,max2} = 252164.00$ is the confined core area at levels of member with hoops and is calculated as the area of core enclosed by the center lines of the internal perimeter hoops.
 $A_{conf,min2} = 111441.00$ is the confined core area at midway between the levels of hoops and is calculated by reducing all the dimensions of the area $A_{conf,max2}$ by a length equal to half the clear spacing between internal hoops.
 $A_{noConf2} = 110709.333$ is the unconfined internal core area which is equal to $b_i^2/6$ as defined at (A.2).
 $psh,min * F_{ywe} = Min(psh,x * F_{ywe}, psh,y * F_{ywe}) = 2.724$
 Expression (5.4d) for $psh,min * F_{ywe}$ has been multiplied by 0.3 according to 15.7.1.3 for members without earthquake detailing (90° closed stirrups)

$psh,x * F_{ywe} = psh1 * F_{ywe1} + ps2 * F_{ywe2} = 2.724$
 $psh1((5.4d), TBDY) = L_{stir1} * A_{stir1} / (A_{sec} * s1) = 0.00301593$
 L_{stir1} (Length of stirrups along Y) = 2160.00
 A_{stir1} (stirrups area) = 78.53982
 $psh2(5.4d) = L_{stir2} * A_{stir2} / (A_{sec} * s2) = 0.00056047$
 L_{stir2} (Length of stirrups along Y) = 1568.00
 A_{stir2} (stirrups area) = 50.26548

$psh,y * F_{ywe} = psh1 * F_{ywe1} + ps2 * F_{ywe2} = 3.25416$
 $psh1((5.4d), TBDY) = L_{stir1} * A_{stir1} / (A_{sec} * s1) = 0.00357443$
 L_{stir1} (Length of stirrups along X) = 2560.00
 A_{stir1} (stirrups area) = 78.53982
 $psh2((5.4d), TBDY) = L_{stir2} * A_{stir2} / (A_{sec} * s2) = 0.00070345$
 L_{stir2} (Length of stirrups along X) = 1968.00
 A_{stir2} (stirrups area) = 50.26548

$A_{sec} = 562500.00$
 $s1 = 100.00$
 $s2 = 250.00$
 $f_{ywe1} = 781.25$
 $f_{ywe2} = 656.25$
 $f_{ce} = 30.00$
 From ((5.A5), TBDY), TBDY: $cc = 0.002$
 $c =$ confinement factor = 1.00
 $y1 = 0.0025$
 $sh1 = 0.008$
 $ft1 = 907.50$
 $fy1 = 756.25$
 $su1 = 0.032$

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
 and also multiplied by the shear_factor according to 15.7.1.4, with
 Shear_factor = 1.00
 $l_o/l_{ou,min} = l_b/l_d = 1.00$
 $su_1 = 0.4 * esu_{1,nominal} ((5.5), TBDY) = 0.032$
 From table 5A.1, TBDY: $esu_{1,nominal} = 0.08$,
 For calculation of $esu_{1,nominal}$ and y_1, sh_1, ft_1, fy_1 , it is considered
 characteristic value $fsy_1 = fs_1/1.2$, from table 5.1, TBDY.
 y_1, sh_1, ft_1, fy_1 , are also multiplied by $Min(1, 1.25 * (l_b/l_d)^{2/3})$, from 10.3.5, ASCE 41-17.
 with $fs_1 = (fs_{jacket} * A_{sl,ten,jacket} + fs_{core} * A_{sl,ten,core}) / A_{sl,ten} = 756.25$
 with $Es_1 = (Es_{jacket} * A_{sl,ten,jacket} + Es_{core} * A_{sl,ten,core}) / A_{sl,ten} = 200000.00$
 $y_2 = 0.0025$
 $sh_2 = 0.008$
 $ft_2 = 907.50$
 $fy_2 = 756.25$
 $su_2 = 0.032$
 using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
 and also multiplied by the shear_factor according to 15.7.1.4, with
 Shear_factor = 1.00
 $l_o/l_{ou,min} = l_b/l_{b,min} = 1.00$
 $su_2 = 0.4 * esu_{2,nominal} ((5.5), TBDY) = 0.032$
 From table 5A.1, TBDY: $esu_{2,nominal} = 0.08$,
 For calculation of $esu_{2,nominal}$ and y_2, sh_2, ft_2, fy_2 , it is considered
 characteristic value $fsy_2 = fs_2/1.2$, from table 5.1, TBDY.
 y_2, sh_2, ft_2, fy_2 , are also multiplied by $Min(1, 1.25 * (l_b/l_d)^{2/3})$, from 10.3.5, ASCE 41-17.
 with $fs_2 = (fs_{jacket} * A_{sl,com,jacket} + fs_{core} * A_{sl,com,core}) / A_{sl,com} = 756.25$
 with $Es_2 = (Es_{jacket} * A_{sl,com,jacket} + Es_{core} * A_{sl,com,core}) / A_{sl,com} = 200000.00$
 $y_v = 0.0025$
 $sh_v = 0.008$
 $ft_v = 899.1522$
 $fy_v = 749.2935$
 $suv = 0.032$
 using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
 and also multiplied by the shear_factor according to 15.7.1.4, with
 Shear_factor = 1.00
 $l_o/l_{ou,min} = l_b/l_d = 1.00$
 $suv = 0.4 * esuv_{nominal} ((5.5), TBDY) = 0.032$
 From table 5A.1, TBDY: $esuv_{nominal} = 0.08$,
 considering characteristic value $fsyv = fsv/1.2$, from table 5.1, TBDY
 For calculation of $esuv_{nominal}$ and y_v, sh_v, ft_v, fy_v , it is considered
 characteristic value $fsyv = fsv/1.2$, from table 5.1, TBDY.
 y_1, sh_1, ft_1, fy_1 , are also multiplied by $Min(1, 1.25 * (l_b/l_d)^{2/3})$, from 10.3.5, ASCE 41-17.
 with $fsv = (fs_{jacket} * A_{sl,mid,jacket} + fs_{mid} * A_{sl,mid,core}) / A_{sl,mid} = 749.2935$
 with $Esv = (Es_{jacket} * A_{sl,mid,jacket} + Es_{mid} * A_{sl,mid,core}) / A_{sl,mid} = 200000.00$
 $1 = A_{sl,ten} / (b * d) * (fs_1 / fc) = 0.09507586$
 $2 = A_{sl,com} / (b * d) * (fs_2 / fc) = 0.09507586$
 $v = A_{sl,mid} / (b * d) * (fsv / fc) = 0.22108466$
 and confined core properties:
 $b = 390.00$
 $d = 877.00$
 $d' = 13.00$
 $f_{cc} (5A.2, TBDY) = 30.00$
 $cc (5A.5, TBDY) = 0.002$
 $c = \text{confinement factor} = 1.00$
 $1 = A_{sl,ten} / (b * d) * (fs_1 / fc) = 0.11345559$
 $2 = A_{sl,com} / (b * d) * (fs_2 / fc) = 0.11345559$
 $v = A_{sl,mid} / (b * d) * (fsv / fc) = 0.26382395$
 Case/Assumption: Unconfined full section - Steel rupture
 ' satisfies Eq. (4.3)
 --->
 $v < v_{s,y2}$ - LHS eq.(4.5) is not satisfied
 --->
 $v < v_{s,c}$ - RHS eq.(4.5) is satisfied
 --->
 $su (4.8) = 0.28399348$
 $Mu = MRc (4.15) = 2.6730E+009$
 $u = su (4.1) = 4.9274896E-005$

Calculation of ratio l_b/d

Adequate Lap Length: $l_b/d \geq 1$

Calculation of μ_{2+}

Calculation of ultimate curvature μ according to 4.1, Biskinis/Fardis 2013:

$$\mu = 4.9274896E-005$$

$$\mu_u = 2.6730E+009$$

with full section properties:

$$b = 450.00$$

$$d = 907.00$$

$$d' = 43.00$$

$$\nu = 0.00169807$$

$$N = 20792.05$$

$$f_c = 30.00$$

$$\omega (5A.5, TBDY) = 0.002$$

$$\text{Final value of } \mu_u: \mu_u^* = \text{shear_factor} * \text{Max}(\mu_u, \mu_c) = 0.00832321$$

The Shear_factor is considered equal to 1 (pure moment strength)

$$\text{From (5.4b), TBDY: } \mu_u = 0.00832321$$

$$\mu_{ue} (5.4c) = 0.01453958$$

$$\mu_{ase} ((5.4d), TBDY) = (\mu_{ase1} * A_{ext} + \mu_{ase2} * A_{int}) / A_{sec} = 0.53375773$$

$$\mu_{ase1} = \text{Max}(((A_{conf,max1} - A_{noConf1}) / A_{conf,max1}) * (A_{conf,min1} / A_{conf,max1}), 0) = 0.53375773$$

The definitions of A_{noConf} , $A_{conf,min}$ and $A_{conf,max}$ are derived from generalization of the rectangular sections confinement, which is expressed by (5.4d).

The generalization is done according to Mander, J., Priestley, M., and Park, R. (1988)

"Theoretical Stress-Strain Model for Confined Concrete."

J. Struct. Eng., 10.1061/(ASCE)0733-9445(1988)114:8(1804), 1804-1826.

$A_{conf,max1} = 464100.00$ is the confined core area at levels of member with hoops and is calculated as the area of core enclosed by the center lines of the external perimeter hoops.

$A_{conf,min1} = 395025.00$ is the confined core area at midway between the levels of hoops and is calculated by reducing all the dimensions of the area $A_{conf,max1}$ by a length equal to half the clear spacing between external hoops.

$A_{noConf1} = 173066.667$ is the unconfined external core area which is equal to $b_i^2/6$ as defined at (A.2).

$$\mu_{ase2} (\geq \mu_{ase1}) = \text{Max}(((A_{conf,max2} - A_{noConf2}) / A_{conf,max2}) * (A_{conf,min2} / A_{conf,max2}), 0) = 0.53375773$$

The definitions of A_{noConf} , $A_{conf,min}$ and $A_{conf,max}$ are derived from generalization of the rectangular sections confinement, which is expressed by (5.4d).

The generalization is done according to Mander, J., Priestley, M., and Park, R. (1988)

"Theoretical Stress-Strain Model for Confined Concrete."

J. Struct. Eng., 10.1061/(ASCE)0733-9445(1988)114:8(1804), 1804-1826.

$A_{conf,max2} = 252164.00$ is the confined core area at levels of member with hoops and is calculated as the area of core enclosed by the center lines of the internal perimeter hoops.

$A_{conf,min2} = 111441.00$ is the confined core area at midway between the levels of hoops and is calculated by reducing all the dimensions of the area $A_{conf,max2}$ by a length equal to half the clear spacing between internal hoops.

$A_{noConf2} = 110709.333$ is the unconfined internal core area which is equal to $b_i^2/6$ as defined at (A.2).

$$p_{sh,min} * F_{ywe} = \text{Min}(p_{sh,x} * F_{ywe}, p_{sh,y} * F_{ywe}) = 2.724$$

Expression (5.4d) for $p_{sh,min} * F_{ywe}$ has been multiplied by 0.3 according to 15.7.1.3 for members without earthquake detailing (90° closed stirrups)

$$p_{sh,x} * F_{ywe} = p_{sh1} * F_{ywe1} + p_{sh2} * F_{ywe2} = 2.724$$

$$p_{sh1} ((5.4d), TBDY) = L_{stir1} * A_{stir1} / (A_{sec} * s_1) = 0.00301593$$

$$L_{stir1} (\text{Length of stirrups along } Y) = 2160.00$$

$$A_{stir1} (\text{stirrups area}) = 78.53982$$

$$p_{sh2} (5.4d) = L_{stir2} * A_{stir2} / (A_{sec} * s_2) = 0.00056047$$

$$L_{stir2} (\text{Length of stirrups along } Y) = 1568.00$$

$$A_{stir2} (\text{stirrups area}) = 50.26548$$

$$p_{sh,y} * F_{ywe} = p_{sh1} * F_{ywe1} + p_{sh2} * F_{ywe2} = 3.25416$$

$$p_{sh1} ((5.4d), TBDY) = L_{stir1} * A_{stir1} / (A_{sec} * s_1) = 0.00357443$$

Lstir1 (Length of stirrups along X) = 2560.00
 Astir1 (stirrups area) = 78.53982
 $psh2 ((5.4d), TBDY) = Lstir2 * Astir2 / (Asec * s2) = 0.00070345$
 Lstir2 (Length of stirrups along X) = 1968.00
 Astir2 (stirrups area) = 50.26548

Asec = 562500.00

s1 = 100.00

s2 = 250.00

fywe1 = 781.25

fywe2 = 656.25

fce = 30.00

From ((5.45), TBDY), TBDY: cc = 0.002

c = confinement factor = 1.00

y1 = 0.0025

sh1 = 0.008

ft1 = 907.50

fy1 = 756.25

su1 = 0.032

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
 and also multiplied by the shear_factor according to 15.7.1.4, with
 Shear_factor = 1.00

lo/lou,min = lb/ld = 1.00

su1 = 0.4*esu1_nominal ((5.5), TBDY) = 0.032

From table 5A.1, TBDY: esu1_nominal = 0.08,

For calculation of esu1_nominal and y1, sh1,ft1,fy1, it is considered
 characteristic value fsy1 = fs1/1.2, from table 5.1, TBDY.

y1, sh1,ft1,fy1, are also multiplied by $\text{Min}(1, 1.25 * (lb/ld)^{2/3})$, from 10.3.5, ASCE 41-17.

with fs1 = (fs,jacket*Asl,ten,jacket + fs,core*Asl,ten,core)/Asl,ten = 756.25

with Es1 = (Es,jacket*Asl,ten,jacket + Es,core*Asl,ten,core)/Asl,ten = 200000.00

y2 = 0.0025

sh2 = 0.008

ft2 = 907.50

fy2 = 756.25

su2 = 0.032

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
 and also multiplied by the shear_factor according to 15.7.1.4, with
 Shear_factor = 1.00

lo/lou,min = lb/lb,min = 1.00

su2 = 0.4*esu2_nominal ((5.5), TBDY) = 0.032

From table 5A.1, TBDY: esu2_nominal = 0.08,

For calculation of esu2_nominal and y2, sh2,ft2,fy2, it is considered
 characteristic value fsy2 = fs2/1.2, from table 5.1, TBDY.

y1, sh1,ft1,fy1, are also multiplied by $\text{Min}(1, 1.25 * (lb/ld)^{2/3})$, from 10.3.5, ASCE 41-17.

with fs2 = (fs,jacket*Asl,com,jacket + fs,core*Asl,com,core)/Asl,com = 756.25

with Es2 = (Es,jacket*Asl,com,jacket + Es,core*Asl,com,core)/Asl,com = 200000.00

yv = 0.0025

shv = 0.008

ftv = 899.1522

fyv = 749.2935

suv = 0.032

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
 and also multiplied by the shear_factor according to 15.7.1.4, with
 Shear_factor = 1.00

lo/lou,min = lb/ld = 1.00

suv = 0.4*esuv_nominal ((5.5), TBDY) = 0.032

From table 5A.1, TBDY: esuv_nominal = 0.08,

considering characteristic value fsyv = fsv/1.2, from table 5.1, TBDY

For calculation of esuv_nominal and yv, shv,ftv,fyv, it is considered
 characteristic value fsyv = fsv/1.2, from table 5.1, TBDY.

y1, sh1,ft1,fy1, are also multiplied by $\text{Min}(1, 1.25 * (lb/ld)^{2/3})$, from 10.3.5, ASCE 41-17.

with fsv = (fs,jacket*Asl,mid,jacket + fs,mid*Asl,mid,core)/Asl,mid = 749.2935

with Esv = (Es,jacket*Asl,mid,jacket + Es,mid*Asl,mid,core)/Asl,mid = 200000.00

1 = Asl,ten/(b*d)*(fs1/fc) = 0.09507586

2 = Asl,com/(b*d)*(fs2/fc) = 0.09507586

v = Asl,mid/(b*d)*(fsv/fc) = 0.22108466

and confined core properties:

$b = 390.00$
 $d = 877.00$
 $d' = 13.00$
 $f_{cc} (5A.2, TBDY) = 30.00$
 $cc (5A.5, TBDY) = 0.002$
 $c = \text{confinement factor} = 1.00$
 $1 = A_{sl,ten}/(b*d)*(f_{s1}/f_c) = 0.11345559$
 $2 = A_{sl,com}/(b*d)*(f_{s2}/f_c) = 0.11345559$
 $v = A_{sl,mid}/(b*d)*(f_{sv}/f_c) = 0.26382395$

Case/Assumption: Unconfined full section - Steel rupture
 ' satisfies Eq. (4.3)

--->
 $v < v_{s,y2}$ - LHS eq.(4.5) is not satisfied

--->
 $v < v_{s,c}$ - RHS eq.(4.5) is satisfied

--->
 $su (4.8) = 0.28399348$
 $Mu = MRc (4.15) = 2.6730E+009$
 $u = su (4.1) = 4.9274896E-005$

Calculation of ratio lb/d

Adequate Lap Length: $lb/d \geq 1$

Calculation of $Mu2$ -

Calculation of ultimate curvature u according to 4.1, Biskinis/Fardis 2013:

$u = 4.9274896E-005$
 $Mu = 2.6730E+009$

with full section properties:

$b = 450.00$
 $d = 907.00$
 $d' = 43.00$
 $v = 0.00169807$
 $N = 20792.05$
 $f_c = 30.00$
 $co (5A.5, TBDY) = 0.002$

Final value of cu : $cu^* = \text{shear_factor} * \text{Max}(cu, cc) = 0.00832321$

The Shear_factor is considered equal to 1 (pure moment strength)

From (5.4b), TBDY: $cu = 0.00832321$

we (5.4c) = 0.01453958

$ase ((5.4d), TBDY) = (ase1 * A_{ext} + ase2 * A_{int}) / A_{sec} = 0.53375773$

$ase1 = \text{Max}(((A_{conf,max1} - A_{noConf1}) / A_{conf,max1}) * (A_{conf,min1} / A_{conf,max1}), 0) = 0.53375773$

The definitions of A_{noConf} , $A_{conf,min}$ and $A_{conf,max}$ are derived from generalization of the rectangular sections confinement, which is expressed by (5.4d).

The generalization is done according to Mander, J., Priestley, M., and Park, R. (1988)

"Theoretical Stress-Strain Model for Confined Concrete."

J. Struct. Eng., 10.1061/(ASCE)0733-9445(1988)114:8(1804), 1804-1826.

$A_{conf,max1} = 464100.00$ is the confined core area at levels of member with hoops and is calculated as the area of core enclosed by the center lines of the external perimeter hoops.

$A_{conf,min1} = 395025.00$ is the confined core area at midway between the levels of hoops and is calculated by reducing all the dimensions of the area $A_{conf,max1}$ by a length

equal to half the clear spacing between external hoops.

$A_{noConf1} = 173066.667$ is the unconfined external core area which is equal to $b_i^2/6$ as defined at (A.2).

$ase2 (\geq ase1) = \text{Max}(((A_{conf,max2} - A_{noConf2}) / A_{conf,max2}) * (A_{conf,min2} / A_{conf,max2}), 0) = 0.53375773$

The definitions of A_{noConf} , $A_{conf,min}$ and $A_{conf,max}$ are derived from generalization of the rectangular sections confinement, which is expressed by (5.4d).

The generalization is done according to Mander, J., Priestley, M., and Park, R. (1988)

"Theoretical Stress-Strain Model for Confined Concrete."

J. Struct. Eng., 10.1061/(ASCE)0733-9445(1988)114:8(1804), 1804-1826.

$A_{conf,max2} = 252164.00$ is the confined core area at levels of member with hoops and

is calculated as the area of core enclosed by the center lines of the internal perimeter hoops.

$A_{conf,min2} = 111441.00$ is the confined core area at midway between the levels of hoops and

is calculated by reducing all the dimensions of the area $A_{conf,max2}$ by a length

equal to half the clear spacing between internal hoops.

$A_{noConf2} = 110709.333$ is the unconfined internal core area which is equal to $b_i^2/6$ as defined at (A.2).

$psh_{min} \cdot F_{ywe} = \text{Min}(psh_x \cdot F_{ywe}, psh_y \cdot F_{ywe}) = 2.724$

Expression (5.4d) for $psh_{min} \cdot F_{ywe}$ has been multiplied by 0.3 according to 15.7.1.3 for members without earthquake detailing (90° closed stirrups)

$psh_x \cdot F_{ywe} = psh1 \cdot F_{ywe1} + ps2 \cdot F_{ywe2} = 2.724$

$psh1$ ((5.4d), TBDY) = $L_{stir1} \cdot A_{stir1} / (A_{sec} \cdot s1) = 0.00301593$

L_{stir1} (Length of stirrups along Y) = 2160.00

A_{stir1} (stirrups area) = 78.53982

$psh2$ (5.4d) = $L_{stir2} \cdot A_{stir2} / (A_{sec} \cdot s2) = 0.00056047$

L_{stir2} (Length of stirrups along Y) = 1568.00

A_{stir2} (stirrups area) = 50.26548

$psh_y \cdot F_{ywe} = psh1 \cdot F_{ywe1} + ps2 \cdot F_{ywe2} = 3.25416$

$psh1$ ((5.4d), TBDY) = $L_{stir1} \cdot A_{stir1} / (A_{sec} \cdot s1) = 0.00357443$

L_{stir1} (Length of stirrups along X) = 2560.00

A_{stir1} (stirrups area) = 78.53982

$psh2$ ((5.4d), TBDY) = $L_{stir2} \cdot A_{stir2} / (A_{sec} \cdot s2) = 0.00070345$

L_{stir2} (Length of stirrups along X) = 1968.00

A_{stir2} (stirrups area) = 50.26548

$A_{sec} = 562500.00$

$s1 = 100.00$

$s2 = 250.00$

$f_{ywe1} = 781.25$

$f_{ywe2} = 656.25$

$f_{ce} = 30.00$

From ((5.A5), TBDY), TBDY: $cc = 0.002$

c = confinement factor = 1.00

$y1 = 0.0025$

$sh1 = 0.008$

$ft1 = 907.50$

$fy1 = 756.25$

$su1 = 0.032$

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor

and also multiplied by the shear_factor according to 15.7.1.4, with

Shear_factor = 1.00

$lo/lou,min = lb/ld = 1.00$

$su1 = 0.4 \cdot esu1_{nominal}$ ((5.5), TBDY) = 0.032

From table 5A.1, TBDY: $esu1_{nominal} = 0.08$,

For calculation of $esu1_{nominal}$ and $y1$, $sh1$, $ft1$, $fy1$, it is considered

characteristic value $fsy1 = fs1/1.2$, from table 5.1, TBDY.

$y1$, $sh1$, $ft1$, $fy1$, are also multiplied by $\text{Min}(1, 1.25 \cdot (lb/ld)^{2/3})$, from 10.3.5, ASCE 41-17.

with $fs1 = (fs_{jacket} \cdot A_{sl,ten,jacket} + fs_{core} \cdot A_{sl,ten,core}) / A_{sl,ten} = 756.25$

with $Es1 = (Es_{jacket} \cdot A_{sl,ten,jacket} + Es_{core} \cdot A_{sl,ten,core}) / A_{sl,ten} = 200000.00$

$y2 = 0.0025$

$sh2 = 0.008$

$ft2 = 907.50$

$fy2 = 756.25$

$su2 = 0.032$

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor

and also multiplied by the shear_factor according to 15.7.1.4, with

Shear_factor = 1.00

$lo/lou,min = lb/lb,min = 1.00$

$su2 = 0.4 \cdot esu2_{nominal}$ ((5.5), TBDY) = 0.032

From table 5A.1, TBDY: $esu2_{nominal} = 0.08$,

For calculation of $esu2_{nominal}$ and $y2$, $sh2$, $ft2$, $fy2$, it is considered

characteristic value $fsy2 = fs2/1.2$, from table 5.1, TBDY.

$y1$, $sh1$, $ft1$, $fy1$, are also multiplied by $\text{Min}(1, 1.25 \cdot (lb/ld)^{2/3})$, from 10.3.5, ASCE 41-17.

with $fs2 = (fs_{jacket} \cdot A_{sl,com,jacket} + fs_{core} \cdot A_{sl,com,core}) / A_{sl,com} = 756.25$

with $Es2 = (Es_{jacket} \cdot A_{sl,com,jacket} + Es_{core} \cdot A_{sl,com,core}) / A_{sl,com} = 200000.00$

$yv = 0.0025$

$shv = 0.008$

```

ftv = 899.1522
fyv = 749.2935
suv = 0.032
    using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
    and also multiplied by the shear_factor according to 15.7.1.4, with
    Shear_factor = 1.00
    lo/lo,min = lb/ld = 1.00
    suv = 0.4*esuv_nominal ((5.5), TBDY) = 0.032
    From table 5A.1, TBDY: esuv_nominal = 0.08,
    considering characteristic value fsyv = fsv/1.2, from table 5.1, TBDY
    For calculation of esuv_nominal and yv, shv,ftv,fyv, it is considered
    characteristic value fsyv = fsv/1.2, from table 5.1, TBDY.
    y1, sh1,ft1,fy1, are also multiplied by Min(1,1.25*(lb/ld)^2/3), from 10.3.5, ASCE 41-17.
    with fsv = (fsjacket*Asl,mid,jacket + fs,mid*Asl,mid,core)/Asl,mid = 749.2935
    with Esv = (Es,jacket*Asl,mid,jacket + Es,mid*Asl,mid,core)/Asl,mid = 200000.00
    1 = Asl,ten/(b*d)*(fs1/fc) = 0.09507586
    2 = Asl,com/(b*d)*(fs2/fc) = 0.09507586
    v = Asl,mid/(b*d)*(fsv/fc) = 0.22108466
and confined core properties:
b = 390.00
d = 877.00
d' = 13.00
fcc (5A.2, TBDY) = 30.00
cc (5A.5, TBDY) = 0.002
    c = confinement factor = 1.00
    1 = Asl,ten/(b*d)*(fs1/fc) = 0.11345559
    2 = Asl,com/(b*d)*(fs2/fc) = 0.11345559
    v = Asl,mid/(b*d)*(fsv/fc) = 0.26382395
Case/Assumption: Unconfined full section - Steel rupture
' satisfies Eq. (4.3)
--->
v < vs,y2 - LHS eq.(4.5) is not satisfied
--->
v < vs,c - RHS eq.(4.5) is satisfied
--->
su (4.8) = 0.28399348
Mu = MRc (4.15) = 2.6730E+009
u = su (4.1) = 4.9274896E-005
-----

Calculation of ratio lb/ld
-----
Adequate Lap Length: lb/ld >= 1
-----
-----
-----
Calculation of Shear Strength Vr = Min(Vr1,Vr2) = 1.6349E+006
-----
Calculation of Shear Strength at edge 1, Vr1 = 1.6349E+006
Vr1 = VCol ((10.3), ASCE 41-17) = knl*VCol0
VCol0 = 1.6349E+006
knl = 1 (zero step-static loading)
-----
NOTE: In expression (10-3) 'Vs = Av*fy*d/s' is replaced by 'Vs+ f*Vf'
where Vf is the contribution of FRPs (11.3), ACI 440).
-----
= 1 (normal-weight concrete)
Mean concrete strength: fc' = (fc'_jacket*Area_jacket + fc'_core*Area_core)/Area_section = 27.20, but fc'^0.5 <= 8.3
MPa (22.5.3.1, ACI 318-14)
M/Vd = 2.00
Mu = 4.16869
Vu = 5.2099631E-036
d = 0.8*h = 760.00
Nu = 20792.05
Ag = 427500.00
From (11.5.4.8), ACI 318-14: Vs = Vs,jacket + Vs,core = 1.2262E+006

```

where:

$$V_{sj,jacket} = V_{sj,1} + V_{sj,2} = 1.0996E+006$$

$V_{sj,1} = 353429.174$ is calculated for section web jacket, with:

$$d = 360.00$$

$$A_v = 157079.633$$

$$f_y = 625.00$$

$$s = 100.00$$

$V_{sj,1}$ is multiplied by $Col,j1 = 1.00$

$$s/d = 0.27777778$$

$V_{sj,2} = 746128.255$ is calculated for section flange jacket, with:

$$d = 760.00$$

$$A_v = 157079.633$$

$$f_y = 625.00$$

$$s = 100.00$$

$V_{sj,2}$ is multiplied by $Col,j2 = 1.00$

$$s/d = 0.13157895$$

$$V_{s,core} = V_{s,c1} + V_{s,c2} = 126669.016$$

$V_{s,c1} = 0.00$ is calculated for section web core, with:

$$d = 200.00$$

$$A_v = 100530.965$$

$$f_y = 525.00$$

$$s = 250.00$$

$V_{s,c1}$ is multiplied by $Col,c1 = 0.00$

$$s/d = 1.25$$

$V_{s,c2} = 126669.016$ is calculated for section flange core, with:

$$d = 600.00$$

$$A_v = 100530.965$$

$$f_y = 525.00$$

$$s = 250.00$$

$V_{s,c2}$ is multiplied by $Col,c2 = 1.00$

$$s/d = 0.41666667$$

$$V_f ((11-3)-(11.4), \text{ACI } 440) = 0.00$$

$$\text{From } (11-11), \text{ACI } 440: V_s + V_f \leq 1.1849E+006$$

$$bw = 450.00$$

Calculation of Shear Strength at edge 2, $V_{r2} = 1.6349E+006$

$$V_{r2} = V_{Col} ((10.3), \text{ASCE } 41-17) = knl * V_{Col0}$$

$$V_{Col0} = 1.6349E+006$$

$$knl = 1 \text{ (zero step-static loading)}$$

NOTE: In expression (10-3) ' $V_s = A_v * f_y * d / s$ ' is replaced by ' $V_s + f * V_f$ ' where V_f is the contribution of FRPs (11.3), ACI 440).

$$= 1 \text{ (normal-weight concrete)}$$

$$\text{Mean concrete strength: } f'_c = (f'_c_{jacket} * Area_{jacket} + f'_c_{core} * Area_{core}) / Area_{section} = 27.20, \text{ but } f'_c^{0.5} \leq 8.3 \text{ MPa (22.5.3.1, ACI 318-14)}$$

$$M/Vd = 2.00$$

$$\mu_u = 4.16869$$

$$V_u = 5.2099631E-036$$

$$d = 0.8 * h = 760.00$$

$$N_u = 20792.05$$

$$A_g = 427500.00$$

$$\text{From (11.5.4.8), ACI 318-14: } V_s = V_{sj,jacket} + V_{s,core} = 1.2262E+006$$

where:

$$V_{sj,jacket} = V_{sj,1} + V_{sj,2} = 1.0996E+006$$

$V_{sj,1} = 353429.174$ is calculated for section web jacket, with:

$$d = 360.00$$

$$A_v = 157079.633$$

$$f_y = 625.00$$

$$s = 100.00$$

$V_{sj,1}$ is multiplied by $Col,j1 = 1.00$

$$s/d = 0.27777778$$

$V_{sj,2} = 746128.255$ is calculated for section flange jacket, with:

$$d = 760.00$$

$$A_v = 157079.633$$

$$f_y = 625.00$$

$s = 100.00$
 $V_{s,j2}$ is multiplied by $Col,j2 = 1.00$
 $s/d = 0.13157895$
 $V_{s,core} = V_{s,c1} + V_{s,c2} = 126669.016$
 $V_{s,c1} = 0.00$ is calculated for section web core, with:
 $d = 200.00$
 $A_v = 100530.965$
 $f_y = 525.00$
 $s = 250.00$
 $V_{s,c1}$ is multiplied by $Col,c1 = 0.00$
 $s/d = 1.25$
 $V_{s,c2} = 126669.016$ is calculated for section flange core, with:
 $d = 600.00$
 $A_v = 100530.965$
 $f_y = 525.00$
 $s = 250.00$
 $V_{s,c2}$ is multiplied by $Col,c2 = 1.00$
 $s/d = 0.41666667$
 $V_f ((11-3)-(11.4), ACI 440) = 0.00$
 From (11-11), ACI 440: $V_s + V_f \leq 1.1849E+006$
 $bw = 450.00$

 End Of Calculation of Shear Capacity ratio for element: column JTC1 of floor 1
 At local axis: 2

 Start Of Calculation of Chord Rotation Capacity for element: column JTC1 of floor 1
 At local axis: 2
 Integration Section: (a)
 Section Type: rcjtcs

Constant Properties

 Knowledge Factor, $\phi = 0.80$
 Chord Rotation is generally considered as Deformation-Controlled Action according to Table C7-1, ASCE 41-17.
 Mean strengths are used for Deformation-Controlled Actions according to 7.5.1.3, ASCE 41-17
 Consequently:
 Jacket
 New material of Secondary Member: Concrete Strength, $f_c = f_{cm} = 30.00$
 New material of Secondary Member: Steel Strength, $f_s = f_{sm} = 625.00$
 Concrete Elasticity, $E_c = 25742.96$
 Steel Elasticity, $E_s = 200000.00$
 Existing Column
 Existing material of Secondary Member: Concrete Strength, $f_c = f_{cm} = 24.00$
 Existing material of Secondary Member: Steel Strength, $f_s = f_{sm} = 525.00$
 Concrete Elasticity, $E_c = 23025.204$
 Steel Elasticity, $E_s = 200000.00$
 Max Height, $H_{max} = 750.00$
 Min Height, $H_{min} = 450.00$
 Max Width, $W_{max} = 950.00$
 Min Width, $W_{min} = 450.00$
 Eccentricity, $E_{cc} = 250.00$
 Jacket Thickness, $t_j = 100.00$
 Cover Thickness, $c = 25.00$
 Element Length, $L = 3000.00$
 Secondary Member
 Smooth Bars
 Ductile Steel
 Without Detailing for Earthquake Resistance (including stirrups not closed at 135°)
 Longitudinal Bars With Ends Lapped Starting at the End Sections
 Adequate Lap Length ($l_b/d \geq 1$)
 No FRP Wrapping

Stepwise Properties

Bending Moment, $M = 8159.13$

Shear Force, $V_2 = -5479.017$

Shear Force, $V_3 = -1.3008$

Axial Force, $F = -21838.055$

Longitudinal Reinforcement Area Distribution (in 2 divisions)

-Tension: $As_t = 0.00$

-Compression: $As_c = 6691.592$

Longitudinal Reinforcement Area Distribution (in 3 divisions)

-Tension: $As_{t,ten} = 1539.38$

-Compression: $As_{c,com} = 2475.575$

-Middle: $As_{mid} = 2676.637$

Longitudinal External Reinforcement Area Distribution (in 3 divisions)

-Tension: $As_{t,ten,jacket} = 1231.504$

-Compression: $As_{c,com,jacket} = 1859.823$

-Middle: $As_{mid,jacket} = 2060.885$

Longitudinal Internal Reinforcement Area Distribution (in 3 divisions)

-Tension: $As_{t,ten,core} = 307.8761$

-Compression: $As_{c,com,core} = 615.7522$

-Middle: $As_{mid,core} = 615.7522$

Mean Diameter of Tension Reinforcement, $Db_L = 16.57143$

Existing component: From table 7-7, ASCE 41_17: Final chord rotation Capacity $\phi_R = \phi_u = 0.01054852$
 $\phi_u = \phi_y + \phi_p = 0.01318565$

- Calculation of ϕ_y -

$y = (M_y * L_s / 3) / E_{eff} = 0.01104542$ ((4.29), Biskinis Phd))

$M_y = 9.4092E+008$

$L_s = M/V$ (with $L_s > 0.1 * L$ and $L_s < 2 * L$) = 6000.00

From table 10.5, ASCE 41_17: $E_{eff} = factor * E_c * I_g = 1.7037E+014$

factor = 0.30

$A_g = 562500.00$

Mean concrete strength: $fc' = (fc'_{jacket} * Area_{jacket} + fc'_{core} * Area_{core}) / Area_{section} = 27.20$

$N = 21838.055$

$E_c * I_g = E_{c,jacket} * I_{g,jacket} + E_{c,core} * I_{g,core} = 5.6791E+014$

Calculation of Yielding Moment M_y

Calculation of ϕ_y and M_y according to Annex 7 -

Assuming neutral axis within flange ($y < t/d$, compression zone rectangular) with:

flange width, $b = 950.00$

web width, $b_w = 450.00$

flange thickness, $t = 450.00$

$y = \text{Min}(y_{ten}, y_{com})$

$y_{ten} = 5.3414671E-006$

with $f_y = 601.9953$

$d = 707.00$

$y = 0.20295445$

$A = 0.01001693$

$B = 0.00468389$

with $pt = 0.00229194$

$pc = 0.00368581$

$pv = 0.00398517$

$N = 21838.055$

$b = 950.00$

$\phi = 0.06082037$

$y_{comp} = 1.4673916E-005$

with $f_c = 30.00$
 $E_c = 25742.96$
 $y = 0.20219473$
 $A = 0.00988542$
 $B = 0.00462988$
with $E_s = 200000.00$
CONFIRMATION: $y = 0.20295445 < t/d$

Calculation of ratio I_b/I_d

Adequate Lap Length: $I_b/I_d \geq 1$

- Calculation of p -

From table 10-8: $p = 0.00214022$

with:

- Columns not controlled by inadequate development or splicing along the clear height because $I_b/I_d \geq 1$

shear control ratio $V_y E / V_{col} E = 1.11674$

$d = d_{external} = 707.00$

$s = s_{external} = 0.00$

- $t = s_1 + s_2 + 2 * t_f / b_w * (f_{fe} / f_s) = 0.0035764$

jacket: $s_1 = A_{v1} * L_{stir1} / (s_1 * A_g) = 0.00301593$

$A_{v1} = 78.53982$, is the area of every stirrup parallel to loading (shear) direction

$L_{stir1} = 2160.00$, is the total Length of all stirrups parallel to loading (shear) direction

$s_1 = 100.00$

core: $s_2 = A_{v2} * L_{stir2} / (s_2 * A_g) = 0.00056047$

$A_{v2} = 50.26548$, is the area of every stirrup parallel to loading (shear) direction

$L_{stir2} = 1568.00$, is the total Length of all stirrups parallel to loading (shear) direction

$s_2 = 250.00$

The term $2 * t_f / b_w * (f_{fe} / f_s)$ is implemented to account for FRP contribution

where $f = 2 * t_f / b_w$ is FRP ratio (EC8 - 3, A.4.4.3(6)) and f_{fe} / f_s normalises f to steel strength

All these variables have already been given in Shear control ratio calculation.

For the normalisation f_s of jacket is used.

$NUD = 21838.055$

$A_g = 562500.00$

$f_{cE} = (f_{c,jacket} * Area_{jacket} + f_{c,core} * Area_{core}) / section_area = 27.20$

$f_{yE} = (f_{y,ext_Long_Reinf} * Area_{ext_Long_Reinf} + f_{y,int_Long_Reinf} * Area_{int_Long_Reinf}) / Area_{Tot_Long_Rein} =$

601.9953

$f_{yE} = (f_{y,ext_Trans_Reinf} * s_1 + f_{y,int_Trans_Reinf} * s_2) / (s_1 + s_2) = 609.3286$

$pI = Area_{Tot_Long_Rein} / (b * d) = 0.00996292$

$b = 950.00$

$d = 707.00$

$f_{cE} = 27.20$


End Of Calculation of Chord Rotation Capacity for element: column JTC1 of floor 1

At local axis: 2

Integration Section: (a)

Calculation No. 3

column C1, Floor 1
 Limit State: Operational Level (data interpolation between analysis steps 1 and 2)
 Analysis: Uniform +X
 Check: Shear capacity VRd
 Edge: Start
 Local Axis: (3)



Start Of Calculation of Shear Capacity for element: column JTC1 of floor 1
 At local axis: 3
 Integration Section: (a)
 Section Type: rcjtcs

Constant Properties

Knowledge Factor, $\gamma = 0.80$
 Member Shear Force is generally considered as Force-Controlled Action according to Table C7-1, ASCE 41-17.
 Lower-bound strengths are used for Force-Controlled Actions according to 7.5.1.3, ASCE 41-17
 Consequently:
 Jacket
 New material of Secondary Member: Concrete Strength, $f_c = f_{c_lower_bound} = 20.00$
 New material of Secondary Member: Steel Strength, $f_s = f_{s_lower_bound} = 500.00$
 Concrete Elasticity, $E_c = 25742.96$
 Steel Elasticity, $E_s = 200000.00$
 Existing Column
 Existing material of Secondary Member: Concrete Strength, $f_c = f_{c_lower_bound} = 16.00$
 Existing material of Secondary Member: Steel Strength, $f_s = f_{s_lower_bound} = 420.00$
 Concrete Elasticity, $E_c = 23025.204$
 Steel Elasticity, $E_s = 200000.00$
 #####
 Note: Especially for the calculation of γ for displacement ductility demand,
 the expected (mean value) strengths are used (7.5.1.3, ASCE 41-17) because bending is considered as
 Deformation-Controlled Action (Table C7-1, ASCE 41-17).
 Jacket
 New material: Concrete Strength, $f_c = f_{cm} = 30.00$
 New material: Steel Strength, $f_s = f_{sm} = 625.00$
 Existing Column
 Existing material: Concrete Strength, $f_c = f_{cm} = 24.00$
 Existing material: Steel Strength, $f_s = f_{sm} = 525.00$
 #####
 Max Height, $H_{max} = 750.00$
 Min Height, $H_{min} = 450.00$
 Max Width, $W_{max} = 950.00$
 Min Width, $W_{min} = 450.00$
 Eccentricity, $Ecc = 250.00$
 Jacket Thickness, $t_j = 100.00$
 Cover Thickness, $c = 25.00$

Element Length, L = 3000.00
 Secondary Member
 Smooth Bars
 Ductile Steel
 Without Detailing for Earthquake Resistance (including stirrups not closed at 135°)
 Longitudinal Bars With Ends Lapped Starting at the End Sections
 Adequate Lap Length ($l_o/l_{ou,min} = l_b/l_d \geq 1$)
 No FRP Wrapping

Stepwise Properties

EDGE -A-
 Bending Moment, $M_a = 8159.13$
 Shear Force, $V_a = -1.3008$
 EDGE -B-
 Bending Moment, $M_b = -3480.992$
 Shear Force, $V_b = 1.3008$
 BOTH EDGES
 Axial Force, $F = -21838.055$
 Longitudinal Reinforcement Area Distribution (in 2 divisions)
 -Tension: $A_{st} = 0.00$
 -Compression: $A_{sc} = 6691.592$
 Longitudinal Reinforcement Area Distribution (in 3 divisions)
 -Tension: $A_{st,ten} = 1539.38$
 -Compression: $A_{sc,com} = 2475.575$
 -Middle: $A_{st,mid} = 2676.637$
 Mean Diameter of Tension Reinforcement, $Db_{L,ten} = 16.57143$

Existing component: From table 7-7, ASCE 41_17: Final Shear Capacity $V_R = V_n = 727734.241$
 V_n ((10.3), ASCE 41-17) = $k_n l V_{CoI} = 909667.801$
 $V_{CoI} = 909667.801$
 $k_n l = 1.00$
 displacement_ductility_demand = 0.00075067

NOTE: In expression (10-3) ' $V_s = A_v f_y d/s$ ' is replaced by ' $V_s + f V_f$ '
 where V_f is the contribution of FRPs (11.3), ACI 440).

= 1 (normal-weight concrete)
 Mean concrete strength: $f_c' = (f_c'_{jacket} \text{Area}_{jacket} + f_c'_{core} \text{Area}_{core}) / \text{Area}_{section} = 18.13333$, but $f_c'^{0.5} \leq 8.3$ MPa (22.5.3.1, ACI 318-14)
 $M/Vd = 4.00$
 $M_u = 8159.13$
 $V_u = 1.3008$
 $d = 0.8 \cdot h = 600.00$
 $N_u = 21838.055$
 $A_g = 337500.00$
 From (11.5.4.8), ACI 318-14: $V_s = V_{sjacket} + V_{s,core} = 828294.726$
 where:
 $V_{sjacket} = V_{sj1} + V_{sj2} = 753982.237$
 $V_{sj1} = 471238.898$ is calculated for section web jacket, with:
 $d = 600.00$
 $A_v = 157079.633$
 $f_y = 500.00$
 $s = 100.00$
 V_{sj1} is multiplied by $Col_{j1} = 1.00$
 $s/d = 0.16666667$
 $V_{sj2} = 282743.339$ is calculated for section flange jacket, with:
 $d = 360.00$
 $A_v = 157079.633$
 $f_y = 500.00$
 $s = 100.00$
 V_{sj2} is multiplied by $Col_{j2} = 1.00$
 $s/d = 0.27777778$

$V_{s,core} = V_{s,c1} + V_{s,c2} = 74312.489$
 $V_{s,c1} = 74312.489$ is calculated for section web core, with:
 $d = 440.00$
 $A_v = 100530.965$
 $f_y = 420.00$
 $s = 250.00$
 $V_{s,c1}$ is multiplied by $Col,c1 = 1.00$
 $s/d = 0.56818182$
 $V_{s,c2} = 0.00$ is calculated for section flange core, with:
 $d = 200.00$
 $A_v = 100530.965$
 $f_y = 420.00$
 $s = 250.00$
 $V_{s,c2}$ is multiplied by $Col,c2 = 0.00$
 $s/d = 1.25$
 $V_f ((11-3)-(11.4), ACI 440) = 0.00$
 From (11-11), ACI 440: $V_s + V_f \leq 763781.865$
 $bw = 450.00$

displacement_ductility_demand is calculated as ϕ / y

- Calculation of ϕ / y for END A -
for rotation axis 2 and integ. section (a)

From analysis, chord rotation $\theta = 8.2914751E-006$
 $y = (M_y * L_s / 3) / E_{eff} = 0.01104542 ((4.29), Biskinis Phd)$
 $M_y = 9.4092E+008$
 $L_s = M/V$ (with $L_s > 0.1 * L$ and $L_s < 2 * L$) = 6000.00
 From table 10.5, ASCE 41_17: $E_{eff} = factor * E_c * I_g = 1.7037E+014$
 $factor = 0.30$
 $A_g = 562500.00$
 Mean concrete strength: $f_c' = (f_c'_{jacket} * Area_{jacket} + f_c'_{core} * Area_{core}) / Area_{section} = 27.20$
 $N = 21838.055$
 $E_c * I_g = E_c * I_{g,jacket} + E_c * I_{g,core} = 5.6791E+014$

Calculation of Yielding Moment M_y

Calculation of ϕ and M_y according to Annex 7 -

Assuming neutral axis within flange ($y < t/d$, compression zone rectangular) with:
 flange width, $b = 950.00$
 web width, $bw = 450.00$
 flange thickness, $t = 450.00$

$y = \text{Min}(y_{ten}, y_{com})$
 $y_{ten} = 5.3414671E-006$
 with $f_y = 601.9953$
 $d = 707.00$
 $y = 0.20295445$
 $A = 0.01001693$
 $B = 0.00468389$
 with $p_t = 0.00229194$
 $p_c = 0.00368581$
 $p_v = 0.00398517$
 $N = 21838.055$
 $b = 950.00$
 $" = 0.06082037$
 $y_{comp} = 1.4673916E-005$
 with $f_c = 30.00$
 $E_c = 25742.96$
 $y = 0.20219473$
 $A = 0.00988542$
 $B = 0.00462988$

with $E_s = 200000.00$
CONFIRMATION: $y = 0.20295445 < t/d$

Calculation of ratio I_b/I_d

Adequate Lap Length: $I_b/I_d \geq 1$

End Of Calculation of Shear Capacity for element: column JTC1 of floor 1

At local axis: 3

Integration Section: (a)

Calculation No. 4

column C1, Floor 1


Limit State: Operational Level (data interpolation between analysis steps 1 and 2)

Analysis: Uniform +X

Check: Chord rotation capacity (ϕ)

Edge: Start

Local Axis: (3)



Start Of Calculation of Shear Capacity ratio for element: column JTC1 of floor 1

At Shear local axis: 3

(Bending local axis: 2)

Section Type: rcjtcs

Constant Properties

Knowledge Factor, $\gamma = 0.80$

Mean strength values are used for both shear and moment calculations.

Consequently:

Jacket

New material of Secondary Member: Concrete Strength, $f_c = f_{cm} = 30.00$

New material of Secondary Member: Steel Strength, $f_s = f_{sm} = 625.00$

Concrete Elasticity, $E_c = 25742.96$

Steel Elasticity, $E_s = 200000.00$

Existing Column

Existing material of Secondary Member: Concrete Strength, $f_c = f_{cm} = 24.00$
 Existing material of Secondary Member: Steel Strength, $f_s = f_{sm} = 525.00$
 Concrete Elasticity, $E_c = 23025.204$
 Steel Elasticity, $E_s = 200000.00$
 #####
 Note: Especially for the calculation of moment strengths,
 the above steel re-bar strengths are multiplied by 1.25 according to R18.6.5, ACI 318-14
 Jacket
 New material: Steel Strength, $f_s = 1.25 \cdot f_{sm} = 781.25$
 Existing Column
 Existing material: Steel Strength, $f_s = 1.25 \cdot f_{sm} = 656.25$
 #####
 Max Height, $H_{max} = 750.00$
 Min Height, $H_{min} = 450.00$
 Max Width, $W_{max} = 950.00$
 Min Width, $W_{min} = 450.00$
 Eccentricity, $E_{cc} = 250.00$
 Jacket Thickness, $t_j = 100.00$
 Cover Thickness, $c = 25.00$
 Mean Confinement Factor overall section = 1.00
 Element Length, $L = 3000.00$
 Secondary Member
 Smooth Bars
 Ductile Steel
 Without Detailing for Earthquake Resistance (including stirrups not closed at 135°)
 Longitudinal Bars With Ends Lapped Starting at the End Sections
 Adequate Lap Length ($l_o/l_{ou,min} > 1$)
 No FRP Wrapping

Stepwise Properties

At local axis: 3
 EDGE -A-
 Shear Force, $V_a = -8.5087964E-020$
 EDGE -B-
 Shear Force, $V_b = 8.5087964E-020$
 BOTH EDGES
 Axial Force, $F = -20792.05$
 Longitudinal Reinforcement Area Distribution (in 2 divisions)
 -Tension: $A_{sl,t} = 0.00$
 -Compression: $A_{sl,c} = 6691.592$
 Longitudinal Reinforcement Area Distribution (in 3 divisions)
 -Tension: $A_{sl,ten} = 1539.38$
 -Compression: $A_{sl,com} = 2475.575$
 -Middle: $A_{sl,mid} = 2676.637$

Calculation of Shear Capacity ratio, $V_e/V_r = 1.11674$
 Member Controlled by Shear ($V_e/V_r > 1$)
 Calculation of Shear Demand from fig. R18.6.5, ACI 318-14 $V_e = (M_{pr1} + M_{pr2})/l_n = 1.4424E+006$
 with
 $M_{pr1} = \text{Max}(M_{u1+}, M_{u1-}) = 2.1636E+009$
 $M_{u1+} = 2.0419E+009$, is the ultimate moment strength at the edge 1 of the member in the actual moment direction
 which is defined for the static loading combination
 $M_{u1-} = 2.1636E+009$, is the ultimate moment strength at the edge 1 of the member in the opposite moment
 direction which is defined for the static loading combination
 $M_{pr2} = \text{Max}(M_{u2+}, M_{u2-}) = 2.1636E+009$
 $M_{u2+} = 2.0419E+009$, is the ultimate moment strength at the edge 2 of the member in the actual moment direction
 which is defined for the the static loading combination
 $M_{u2-} = 2.1636E+009$, is the ultimate moment strength at the edge 2 of the member in the opposite moment
 direction which is defined for the the static loading combination

Calculation of M_{u1+}

Calculation of ultimate curvature ϕ_u according to 4.1, Biskinis/Fardis 2013:

$$u = 5.3321191E-005$$

$$\mu = 2.0419E+009$$

with full section properties:

$$b = 950.00$$

$$d = 707.00$$

$$d' = 43.00$$

$$v = 0.00103189$$

$$N = 20792.05$$

$$f_c = 30.00$$

$$\alpha (5A.5, TBDY) = 0.002$$

$$\text{Final value of } \phi_u: \phi_u^* = \text{shear_factor} * \text{Max}(\phi_u, \phi_c) = 0.00832321$$

The Shear_factor is considered equal to 1 (pure moment strength)

$$\text{From (5.4b), TBDY: } \phi_u = 0.00832321$$

$$\phi_{ue} (5.4c) = 0.01453958$$

$$\alpha_{se} ((5.4d), TBDY) = (\alpha_{se1} * A_{ext} + \alpha_{se2} * A_{int}) / A_{sec} = 0.53375773$$

$$\alpha_{se1} = \text{Max}(((A_{conf,max1} - A_{noConf1}) / A_{conf,max1}) * (A_{conf,min1} / A_{conf,max1}), 0) = 0.53375773$$

The definitions of A_{noConf} , $A_{conf,min}$ and $A_{conf,max}$ are derived from generalization of the rectangular sections confinement, which is expressed by (5.4d).

The generalization is done according to Mander, J., Priestley, M., and Park, R. (1988)

"Theoretical Stress-Strain Model for Confined Concrete."

J. Struct. Eng., 10.1061/(ASCE)0733-9445(1988)114:8(1804), 1804-1826.

$A_{conf,max1} = 464100.00$ is the confined core area at levels of member with hoops and is calculated as the area of core enclosed by the center lines of the external perimeter hoops.

$A_{conf,min1} = 395025.00$ is the confined core area at midway between the levels of hoops and is calculated by reducing all the dimensions of the area $A_{conf,max1}$ by a length equal to half the clear spacing between external hoops.

$A_{noConf1} = 173066.667$ is the unconfined external core area which is equal to $b_i d_i / 6$ as defined at (A.2).

$$\alpha_{se2} (> \alpha_{se1}) = \text{Max}(((A_{conf,max2} - A_{noConf2}) / A_{conf,max2}) * (A_{conf,min2} / A_{conf,max2}), 0) = 0.53375773$$

The definitions of A_{noConf} , $A_{conf,min}$ and $A_{conf,max}$ are derived from generalization of the rectangular sections confinement, which is expressed by (5.4d).

The generalization is done according to Mander, J., Priestley, M., and Park, R. (1988)

"Theoretical Stress-Strain Model for Confined Concrete."

J. Struct. Eng., 10.1061/(ASCE)0733-9445(1988)114:8(1804), 1804-1826.

$A_{conf,max2} = 252164.00$ is the confined core area at levels of member with hoops and is calculated as the area of core enclosed by the center lines of the internal perimeter hoops.

$A_{conf,min2} = 111441.00$ is the confined core area at midway between the levels of hoops and is calculated by reducing all the dimensions of the area $A_{conf,max2}$ by a length equal to half the clear spacing between internal hoops.

$A_{noConf2} = 110709.333$ is the unconfined internal core area which is equal to $b_i d_i / 6$ as defined at (A.2).

$$p_{sh,min} * F_{ywe} = \text{Min}(p_{sh,x} * F_{ywe}, p_{sh,y} * F_{ywe}) = 2.724$$

Expression (5.4d) for $p_{sh,min} * F_{ywe}$ has been multiplied by 0.3 according to 15.7.1.3 for members without earthquake detailing (90° closed stirrups)

$$p_{sh,x} * F_{ywe} = p_{sh1} * F_{ywe1} + p_{sh2} * F_{ywe2} = 2.724$$

$$p_{sh1} ((5.4d), TBDY) = L_{stir1} * A_{stir1} / (A_{sec} * s_1) = 0.00301593$$

$$L_{stir1} \text{ (Length of stirrups along Y)} = 2160.00$$

$$A_{stir1} \text{ (stirrups area)} = 78.53982$$

$$p_{sh2} (5.4d) = L_{stir2} * A_{stir2} / (A_{sec} * s_2) = 0.00056047$$

$$L_{stir2} \text{ (Length of stirrups along Y)} = 1568.00$$

$$A_{stir2} \text{ (stirrups area)} = 50.26548$$

$$p_{sh,y} * F_{ywe} = p_{sh1} * F_{ywe1} + p_{sh2} * F_{ywe2} = 3.25416$$

$$p_{sh1} ((5.4d), TBDY) = L_{stir1} * A_{stir1} / (A_{sec} * s_1) = 0.00357443$$

$$L_{stir1} \text{ (Length of stirrups along X)} = 2560.00$$

$$A_{stir1} \text{ (stirrups area)} = 78.53982$$

$$p_{sh2} ((5.4d), TBDY) = L_{stir2} * A_{stir2} / (A_{sec} * s_2) = 0.00070345$$

$$L_{stir2} \text{ (Length of stirrups along X)} = 1968.00$$

$$A_{stir2} \text{ (stirrups area)} = 50.26548$$

$$A_{sec} = 562500.00$$

$$s_1 = 100.00$$

$$s_2 = 250.00$$

```

fywe1 = 781.25
fywe2 = 656.25
fce = 30.00
From ((5A.5), TBDY), TBDY: cc = 0.002
c = confinement factor = 1.00
y1 = 0.0025
sh1 = 0.008
ft1 = 907.50
fy1 = 756.25
su1 = 0.032
using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00
lo/lou,min = lb/lb = 1.00
su1 = 0.4*esu1_nominal ((5.5), TBDY) = 0.032
From table 5A.1, TBDY: esu1_nominal = 0.08,
For calculation of esu1_nominal and y1, sh1,ft1,fy1, it is considered
characteristic value fsy1 = fs1/1.2, from table 5.1, TBDY.
y1, sh1,ft1,fy1, are also multiplied by  $\text{Min}(1, 1.25 \cdot (lb/ld)^{2/3})$ , from 10.3.5, ASCE 41-17.
with fs1 = (fs,jacket*Asl,ten,jacket + fs,core*Asl,ten,core)/Asl,ten = 756.25
with Es1 = (Es,jacket*Asl,ten,jacket + Es,core*Asl,ten,core)/Asl,ten = 200000.00
y2 = 0.0025
sh2 = 0.008
ft2 = 900.1904
fy2 = 750.1586
su2 = 0.032
using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00
lo/lou,min = lb/lb,min = 1.00
su2 = 0.4*esu2_nominal ((5.5), TBDY) = 0.032
From table 5A.1, TBDY: esu2_nominal = 0.08,
For calculation of esu2_nominal and y2, sh2,ft2,fy2, it is considered
characteristic value fsy2 = fs2/1.2, from table 5.1, TBDY.
y1, sh1,ft1,fy1, are also multiplied by  $\text{Min}(1, 1.25 \cdot (lb/ld)^{2/3})$ , from 10.3.5, ASCE 41-17.
with fs2 = (fs,jacket*Asl,com,jacket + fs,core*Asl,com,core)/Asl,com = 750.1586
with Es2 = (Es,jacket*Asl,com,jacket + Es,core*Asl,com,core)/Asl,com = 200000.00
yv = 0.0025
shv = 0.008
ftv = 902.993
fyv = 752.4941
suv = 0.032
using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00
lo/lou,min = lb/lb = 1.00
suv = 0.4*esuv_nominal ((5.5), TBDY) = 0.032
From table 5A.1, TBDY: esuv_nominal = 0.08,
considering characteristic value fsyv = fsv/1.2, from table 5.1, TBDY
For calculation of esuv_nominal and yv, shv,ftv,fyv, it is considered
characteristic value fsyv = fsv/1.2, from table 5.1, TBDY.
y1, sh1,ft1,fy1, are also multiplied by  $\text{Min}(1, 1.25 \cdot (lb/ld)^{2/3})$ , from 10.3.5, ASCE 41-17.
with fsv = (fs,jacket*Asl,mid,jacket + fs,mid*Asl,mid,core)/Asl,mid = 752.4941
with Esv = (Es,jacket*Asl,mid,jacket + Es,mid*Asl,mid,core)/Asl,mid = 200000.00
1 = Asl,ten/(b*d)*(fs1/fc) = 0.05777595
2 = Asl,com/(b*d)*(fs2/fc) = 0.09216477
v = Asl,mid/(b*d)*(fsv/fc) = 0.09996047
and confined core properties:
b = 890.00
d = 677.00
d' = 13.00
fcc (5A.2, TBDY) = 30.00
cc (5A.5, TBDY) = 0.002
c = confinement factor = 1.00
1 = Asl,ten/(b*d)*(fs1/fc) = 0.06440379
2 = Asl,com/(b*d)*(fs2/fc) = 0.10273757
v = Asl,mid/(b*d)*(fsv/fc) = 0.11142757

```

Case/Assumption: Unconfined full section - Steel rupture
' satisfies Eq. (4.3)

--->
 $v < v_{s,y2}$ - LHS eq.(4.5) is not satisfied
--->
 $v < v_{s,c}$ - RHS eq.(4.5) is satisfied
--->
 $s_u(4.8) = 0.15115045$
 $M_u = M_{Rc}(4.15) = 2.0419E+009$
 $u = s_u(4.1) = 5.3321191E-005$

Calculation of ratio I_b/I_d

Adequate Lap Length: $I_b/I_d \geq 1$

Calculation of M_{u1} -

Calculation of ultimate curvature u according to 4.1, Biskinis/Fardis 2013:
 $u = 6.8287974E-005$
 $M_u = 2.1636E+009$

with full section properties:

$b = 450.00$
 $d = 707.00$
 $d' = 43.00$
 $v = 0.00217843$
 $N = 20792.05$
 $f_c = 30.00$
 $\alpha(5A.5, TBDY) = 0.002$
Final value of α : $\alpha^* = \text{shear_factor} * \text{Max}(\alpha_c, \alpha) = 0.00832321$
The Shear_factor is considered equal to 1 (pure moment strength)
From (5.4b), TBDY: $\alpha_c = 0.00832321$
 $w_e(5.4c) = 0.01453958$
 $\alpha_{se}((5.4d), TBDY) = (\alpha_{se1} * A_{ext} + \alpha_{se2} * A_{int}) / A_{sec} = 0.53375773$
 $\alpha_{se1} = \text{Max}(((A_{conf,max1} - A_{noConf1}) / A_{conf,max1}) * (A_{conf,min1} / A_{conf,max1}), 0) = 0.53375773$
The definitions of A_{noConf} , $A_{conf,min}$ and $A_{conf,max}$ are derived from generalization of the rectangular sections confinement, which is expressed by (5.4d).
The generalization is done according to Mander, J., Priestley, M., and Park, R. (1988) "Theoretical Stress-Strain Model for Confined Concrete."
J. Struct. Eng., 10.1061/(ASCE)0733-9445(1988)114:8(1804), 1804-1826.
 $A_{conf,max1} = 464100.00$ is the confined core area at levels of member with hoops and is calculated as the area of core enclosed by the center lines of the external perimeter hoops.
 $A_{conf,min1} = 395025.00$ is the confined core area at midway between the levels of hoops and is calculated by reducing all the dimensions of the area $A_{conf,max1}$ by a length equal to half the clear spacing between external hoops.
 $A_{noConf1} = 173066.667$ is the unconfined external core area which is equal to $b_i^2/6$ as defined at (A.2).
 $\alpha_{se2} (\geq \alpha_{se1}) = \text{Max}(((A_{conf,max2} - A_{noConf2}) / A_{conf,max2}) * (A_{conf,min2} / A_{conf,max2}), 0) = 0.53375773$
The definitions of A_{noConf} , $A_{conf,min}$ and $A_{conf,max}$ are derived from generalization of the rectangular sections confinement, which is expressed by (5.4d).
The generalization is done according to Mander, J., Priestley, M., and Park, R. (1988) "Theoretical Stress-Strain Model for Confined Concrete."
J. Struct. Eng., 10.1061/(ASCE)0733-9445(1988)114:8(1804), 1804-1826.
 $A_{conf,max2} = 252164.00$ is the confined core area at levels of member with hoops and is calculated as the area of core enclosed by the center lines of the internal perimeter hoops.
 $A_{conf,min2} = 111441.00$ is the confined core area at midway between the levels of hoops and is calculated by reducing all the dimensions of the area $A_{conf,max2}$ by a length equal to half the clear spacing between internal hoops.
 $A_{noConf2} = 110709.333$ is the unconfined internal core area which is equal to $b_i^2/6$ as defined at (A.2).
 $p_{sh,min} * F_{ywe} = \text{Min}(p_{sh,x} * F_{ywe}, p_{sh,y} * F_{ywe}) = 2.724$
Expression (5.4d) for $p_{sh,min} * F_{ywe}$ has been multiplied by 0.3 according to 15.7.1.3 for members without earthquake detailing (90° closed stirrups)

$psh_x * Fywe = psh1 * Fywe1 + ps2 * Fywe2 = 2.724$
 $psh1 \text{ ((5.4d), TBDY)} = Lstir1 * Astir1 / (Asec * s1) = 0.00301593$
 $Lstir1 \text{ (Length of stirrups along Y)} = 2160.00$
 $Astir1 \text{ (stirrups area)} = 78.53982$
 $psh2 \text{ (5.4d)} = Lstir2 * Astir2 / (Asec * s2) = 0.00056047$
 $Lstir2 \text{ (Length of stirrups along Y)} = 1568.00$
 $Astir2 \text{ (stirrups area)} = 50.26548$

$psh_y * Fywe = psh1 * Fywe1 + ps2 * Fywe2 = 3.25416$
 $psh1 \text{ ((5.4d), TBDY)} = Lstir1 * Astir1 / (Asec * s1) = 0.00357443$
 $Lstir1 \text{ (Length of stirrups along X)} = 2560.00$
 $Astir1 \text{ (stirrups area)} = 78.53982$
 $psh2 \text{ ((5.4d), TBDY)} = Lstir2 * Astir2 / (Asec * s2) = 0.00070345$
 $Lstir2 \text{ (Length of stirrups along X)} = 1968.00$
 $Astir2 \text{ (stirrups area)} = 50.26548$

$Asec = 562500.00$
 $s1 = 100.00$
 $s2 = 250.00$
 $fywe1 = 781.25$
 $fywe2 = 656.25$
 $fce = 30.00$

From ((5.A5), TBDY), TBDY: $cc = 0.002$
 $c = \text{confinement factor} = 1.00$

$y1 = 0.0025$
 $sh1 = 0.008$
 $ft1 = 900.1904$
 $fy1 = 750.1586$
 $su1 = 0.032$

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
 and also multiplied by the shear_factor according to 15.7.1.4, with
 $Shear_factor = 1.00$
 $lo/lou, min = lb/ld = 1.00$

$su1 = 0.4 * esu1_nominal \text{ ((5.5), TBDY)} = 0.032$

From table 5A.1, TBDY: $esu1_nominal = 0.08$,

For calculation of $esu1_nominal$ and $y1, sh1, ft1, fy1$, it is considered
 characteristic value $fsy1 = fs1/1.2$, from table 5.1, TBDY.

$y1, sh1, ft1, fy1$, are also multiplied by $\text{Min}(1, 1.25 * (lb/ld)^{2/3})$, from 10.3.5, ASCE 41-17.

with $fs1 = (fs_jacket * Asl, ten, jacket + fs_core * Asl, ten, core) / Asl, ten = 750.1586$

with $Es1 = (Es_jacket * Asl, ten, jacket + Es_core * Asl, ten, core) / Asl, ten = 200000.00$

$y2 = 0.0025$
 $sh2 = 0.008$
 $ft2 = 907.50$
 $fy2 = 756.25$
 $su2 = 0.032$

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
 and also multiplied by the shear_factor according to 15.7.1.4, with
 $Shear_factor = 1.00$

$lo/lou, min = lb/lb, min = 1.00$

$su2 = 0.4 * esu2_nominal \text{ ((5.5), TBDY)} = 0.032$

From table 5A.1, TBDY: $esu2_nominal = 0.08$,

For calculation of $esu2_nominal$ and $y2, sh2, ft2, fy2$, it is considered
 characteristic value $fsy2 = fs2/1.2$, from table 5.1, TBDY.

$y2, sh2, ft2, fy2$, are also multiplied by $\text{Min}(1, 1.25 * (lb/ld)^{2/3})$, from 10.3.5, ASCE 41-17.

with $fs2 = (fs_jacket * Asl, com, jacket + fs_core * Asl, com, core) / Asl, com = 756.25$

with $Es2 = (Es_jacket * Asl, com, jacket + Es_core * Asl, com, core) / Asl, com = 200000.00$

$yv = 0.0025$
 $shv = 0.008$
 $ftv = 902.993$
 $fyv = 752.4941$
 $suv = 0.032$

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
 and also multiplied by the shear_factor according to 15.7.1.4, with
 $Shear_factor = 1.00$

$lo/lou, min = lb/ld = 1.00$

$suv = 0.4 * esuv_nominal \text{ ((5.5), TBDY)} = 0.032$

From table 5A.1, TBDY: $esuv_nominal = 0.08$,

considering characteristic value $f_{syv} = f_{sv}/1.2$, from table 5.1, TBDY

For calculation of $e_{suv_nominal}$ and y_v , sh_v , ft_v , f_{yv} , it is considered characteristic value $f_{syv} = f_{sv}/1.2$, from table 5.1, TBDY.

y_1 , sh_1 , ft_1 , f_{y1} , are also multiplied by $\text{Min}(1, 1.25 \cdot (l_b/l_d)^{2/3})$, from 10.3.5, ASCE 41-17.

with $f_{sv} = (f_{sjacket} \cdot A_{sl,mid,jacket} + f_{s,mid} \cdot A_{sl,mid,core}) / A_{sl,mid} = 752.4941$

with $E_{sv} = (E_{sjacket} \cdot A_{sl,mid,jacket} + E_{s,mid} \cdot A_{sl,mid,core}) / A_{sl,mid} = 200000.00$

$1 = A_{sl,ten} / (b \cdot d) \cdot (f_{s1} / f_c) = 0.19457006$

$2 = A_{sl,com} / (b \cdot d) \cdot (f_{s2} / f_c) = 0.12197144$

$v = A_{sl,mid} / (b \cdot d) \cdot (f_{sv} / f_c) = 0.21102767$

and confined core properties:

$b = 390.00$

$d = 677.00$

$d' = 13.00$

f_{cc} (5A.2, TBDY) = 30.00

cc (5A.5, TBDY) = 0.002

c = confinement factor = 1.00

$1 = A_{sl,ten} / (b \cdot d) \cdot (f_{s1} / f_c) = 0.23445239$

$2 = A_{sl,com} / (b \cdot d) \cdot (f_{s2} / f_c) = 0.14697275$

$v = A_{sl,mid} / (b \cdot d) \cdot (f_{sv} / f_c) = 0.25428343$

Case/Assumption: Unconfined full section - Steel rupture

' satisfies Eq. (4.3)

---->

$v < v_{s,y2}$ - LHS eq.(4.5) is not satisfied

---->

$v < v_{s,c}$ - RHS eq.(4.5) is satisfied

---->

su (4.8) = 0.33719414

$Mu = MRc$ (4.15) = 2.1636E+009

$u = su$ (4.1) = 6.8287974E-005

Calculation of ratio l_b/l_d

Adequate Lap Length: $l_b/l_d \geq 1$

Calculation of Mu_{2+}

Calculation of ultimate curvature u according to 4.1, Biskinis/Fardis 2013:

$u = 5.3321191E-005$

$Mu = 2.0419E+009$

with full section properties:

$b = 950.00$

$d = 707.00$

$d' = 43.00$

$v = 0.00103189$

$N = 20792.05$

$f_c = 30.00$

co (5A.5, TBDY) = 0.002

Final value of cu : $cu^* = \text{shear_factor} \cdot \text{Max}(cu, cc) = 0.00832321$

The Shear_factor is considered equal to 1 (pure moment strength)

From (5.4b), TBDY: $cu = 0.00832321$

we (5.4c) = 0.01453958

ase ((5.4d), TBDY) = $(ase1 \cdot A_{ext} + ase2 \cdot A_{int}) / A_{sec} = 0.53375773$

$ase1 = \text{Max}(((A_{conf,max1} - A_{noConf1}) / A_{conf,max1}) \cdot (A_{conf,min1} / A_{conf,max1}), 0) = 0.53375773$

The definitions of A_{noConf} , $A_{conf,min}$ and $A_{conf,max}$ are derived from generalization of the rectangular sections confinement, which is expressed by (5.4d).

The generalization is done according to Mander, J., Priestley, M., and Park, R. (1988)

"Theoretical Stress-Strain Model for Confined Concrete."

J. Struct. Eng., 10.1061/(ASCE)0733-9445(1988)114:8(1804), 1804-1826.

$A_{conf,max1} = 464100.00$ is the confined core area at levels of member with hoops and

is calculated as the area of core enclosed by the center lines of the external perimeter hoops.

$A_{conf,min1} = 395025.00$ is the confined core area at midway between the levels of hoops and

is calculated by reducing all the dimensions of the area Aconf,max1 by a length equal to half the clear spacing between external hoops.

AnoConf1 = 173066.667 is the unconfined external core area which is equal to $b_i^2/6$ as defined at (A.2).
ase2 (\geq ase1) = $\text{Max}(((A_{\text{conf,max2}} - A_{\text{noConf2}})/A_{\text{conf,max2}}) * (A_{\text{conf,min2}}/A_{\text{conf,max2}}), 0) = 0.53375773$

The definitions of AnoConf, Aconf,min and Aconf,max are derived from generalization of the rectangular sections confinement, which is expressed by (5.4d).

The generalization is done according to Mander, J., Priestley, M., and Park, R. (1988) "Theoretical Stress-Strain Model for Confined Concrete."

J. Struct. Eng., 10.1061/(ASCE)0733-9445(1988)114:8(1804), 1804-1826.

Aconf,max2 = 252164.00 is the confined core area at levels of member with hoops and is calculated as the area of core enclosed by the center lines of the internal perimeter hoops.

Aconf,min2 = 111441.00 is the confined core area at midway between the levels of hoops and is calculated by reducing all the dimensions of the area Aconf,max2 by a length equal to half the clear spacing between internal hoops.

AnoConf2 = 110709.333 is the unconfined internal core area which is equal to $b_i^2/6$ as defined at (A.2).
psh,min*Fywe = $\text{Min}(psh_x * Fywe, psh_y * Fywe) = 2.724$

Expression (5.4d) for psh,min*Fywe has been multiplied by 0.3 according to 15.7.1.3 for members without earthquake detailing (90° closed stirrups)

psh_x*Fywe = psh1*Fywe1 + ps2*Fywe2 = 2.724
psh1 ((5.4d), TBDY) = $L_{\text{stir1}} * A_{\text{stir1}} / (A_{\text{sec}} * s_1) = 0.00301593$
Lstir1 (Length of stirrups along Y) = 2160.00
Astir1 (stirrups area) = 78.53982
psh2 ((5.4d)) = $L_{\text{stir2}} * A_{\text{stir2}} / (A_{\text{sec}} * s_2) = 0.00056047$
Lstir2 (Length of stirrups along Y) = 1568.00
Astir2 (stirrups area) = 50.26548

psh_y*Fywe = psh1*Fywe1 + ps2*Fywe2 = 3.25416
psh1 ((5.4d), TBDY) = $L_{\text{stir1}} * A_{\text{stir1}} / (A_{\text{sec}} * s_1) = 0.00357443$
Lstir1 (Length of stirrups along X) = 2560.00
Astir1 (stirrups area) = 78.53982
psh2 ((5.4d), TBDY) = $L_{\text{stir2}} * A_{\text{stir2}} / (A_{\text{sec}} * s_2) = 0.00070345$
Lstir2 (Length of stirrups along X) = 1968.00
Astir2 (stirrups area) = 50.26548

Asec = 562500.00

s1 = 100.00

s2 = 250.00

fywe1 = 781.25

fywe2 = 656.25

fce = 30.00

From ((5.A5), TBDY), TBDY: cc = 0.002

c = confinement factor = 1.00

y1 = 0.0025

sh1 = 0.008

ft1 = 907.50

fy1 = 756.25

su1 = 0.032

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor and also multiplied by the shear_factor according to 15.7.1.4, with Shear_factor = 1.00

lo/lou,min = lb/ld = 1.00

su1 = $0.4 * esu1_{\text{nominal}} ((5.5), \text{TBDY}) = 0.032$

From table 5A.1, TBDY: esu1_nominal = 0.08,

For calculation of esu1_nominal and y1, sh1, ft1, fy1, it is considered characteristic value fsy1 = fs1/1.2, from table 5.1, TBDY.

y1, sh1, ft1, fy1, are also multiplied by $\text{Min}(1, 1.25 * (lb/ld)^{2/3})$, from 10.3.5, ASCE 41-17.

with fs1 = $(f_{s,jacket} * A_{s1,ten,jacket} + f_{s,core} * A_{s1,ten,core}) / A_{s1,ten} = 756.25$

with Es1 = $(E_{s,jacket} * A_{s1,ten,jacket} + E_{s,core} * A_{s1,ten,core}) / A_{s1,ten} = 200000.00$

y2 = 0.0025

sh2 = 0.008

ft2 = 900.1904

fy2 = 750.1586

su2 = 0.032

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor and also multiplied by the shear_factor according to 15.7.1.4, with Shear_factor = 1.00

```

lo/lou,min = lb/lbmin = 1.00
su2 = 0.4*esu2,nominal ((5.5), TBDY) = 0.032
From table 5A.1, TBDY: esu2,nominal = 0.08,
For calculation of esu2,nominal and y2, sh2,ft2,fy2, it is considered
characteristic value fsy2 = fs2/1.2, from table 5.1, TBDY.
y1, sh1,ft1,fy1, are also multiplied by Min(1,1.25*(lb/ld)2/3), from 10.3.5, ASCE 41-17.
with fs2 = (fsjacket*Aslcom,jacket + fscore*Aslcom,core)/Aslcom = 750.1586
with Es2 = (Esjacket*Aslcom,jacket + Escore*Aslcom,core)/Aslcom = 200000.00
yv = 0.0025
shv = 0.008
ftv = 902.993
fyv = 752.4941
suv = 0.032
using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00
lo/lou,min = lb/ld = 1.00
suv = 0.4*esuvnominal ((5.5), TBDY) = 0.032
From table 5A.1, TBDY: esuvnominal = 0.08,
considering characteristic value fsyv = fsv/1.2, from table 5.1, TBDY
For calculation of esuvnominal and yv, shv,ftv,fyv, it is considered
characteristic value fsyv = fsv/1.2, from table 5.1, TBDY.
y1, sh1,ft1,fy1, are also multiplied by Min(1,1.25*(lb/ld)2/3), from 10.3.5, ASCE 41-17.
with fsv = (fsjacket*Aslmid,jacket + fsmid*Aslmid,core)/Aslmid = 752.4941
with Esv = (Esjacket*Aslmid,jacket + Esmid*Aslmid,core)/Aslmid = 200000.00
1 = Aslten/(b*d)*(fs1/fc) = 0.05777595
2 = Aslcom/(b*d)*(fs2/fc) = 0.09216477
v = Aslmid/(b*d)*(fsv/fc) = 0.09996047
and confined core properties:
b = 890.00
d = 677.00
d' = 13.00
fcc (5A.2, TBDY) = 30.00
cc (5A.5, TBDY) = 0.002
c = confinement factor = 1.00
1 = Aslten/(b*d)*(fs1/fc) = 0.06440379
2 = Aslcom/(b*d)*(fs2/fc) = 0.10273757
v = Aslmid/(b*d)*(fsv/fc) = 0.11142757
Case/Assumption: Unconfined full section - Steel rupture
'satisfies Eq. (4.3)
---->
v < vsy2 - LHS eq.(4.5) is not satisfied
---->
v < vsc - RHS eq.(4.5) is satisfied
---->
su (4.8) = 0.15115045
Mu = MRc (4.15) = 2.0419E+009
u = su (4.1) = 5.3321191E-005

```

Calculation of ratio lb/l_d

Adequate Lap Length: lb/l_d >= 1

Calculation of Mu₂-

Calculation of ultimate curvature u according to 4.1, Biskinis/Fardis 2013:

u = 6.8287974E-005

Mu = 2.1636E+009

with full section properties:

b = 450.00

d = 707.00

$d' = 43.00$
 $v = 0.00217843$
 $N = 20792.05$
 $f_c = 30.00$
 $co(5A.5, TBDY) = 0.002$
 Final value of cu : $cu^* = shear_factor * Max(cu, cc) = 0.00832321$
 The Shear_factor is considered equal to 1 (pure moment strength)
 From (5.4b), TBDY: $cu = 0.00832321$
 $we(5.4c) = 0.01453958$
 $ase((5.4d), TBDY) = (ase1 * A_{ext} + ase2 * A_{int}) / A_{sec} = 0.53375773$
 $ase1 = Max(((A_{conf,max1} - A_{noConf1}) / A_{conf,max1}) * (A_{conf,min1} / A_{conf,max1}), 0) = 0.53375773$
 The definitions of A_{noConf} , $A_{conf,min}$ and $A_{conf,max}$ are derived from generalization of the rectangular sections confinement, which is expressed by (5.4d).
 The generalization is done according to Mander, J., Priestley, M., and Park, R. (1988) "Theoretical Stress-Strain Model for Confined Concrete."
 J. Struct. Eng., 10.1061/(ASCE)0733-9445(1988)114:8(1804), 1804-1826.
 $A_{conf,max1} = 464100.00$ is the confined core area at levels of member with hoops and is calculated as the area of core enclosed by the center lines of the external perimeter hoops.
 $A_{conf,min1} = 395025.00$ is the confined core area at midway between the levels of hoops and is calculated by reducing all the dimensions of the area $A_{conf,max1}$ by a length equal to half the clear spacing between external hoops.
 $A_{noConf1} = 173066.667$ is the unconfined external core area which is equal to $b_i^2/6$ as defined at (A.2).
 $ase2 (>= ase1) = Max(((A_{conf,max2} - A_{noConf2}) / A_{conf,max2}) * (A_{conf,min2} / A_{conf,max2}), 0) = 0.53375773$
 The definitions of A_{noConf} , $A_{conf,min}$ and $A_{conf,max}$ are derived from generalization of the rectangular sections confinement, which is expressed by (5.4d).
 The generalization is done according to Mander, J., Priestley, M., and Park, R. (1988) "Theoretical Stress-Strain Model for Confined Concrete."
 J. Struct. Eng., 10.1061/(ASCE)0733-9445(1988)114:8(1804), 1804-1826.
 $A_{conf,max2} = 252164.00$ is the confined core area at levels of member with hoops and is calculated as the area of core enclosed by the center lines of the internal perimeter hoops.
 $A_{conf,min2} = 111441.00$ is the confined core area at midway between the levels of hoops and is calculated by reducing all the dimensions of the area $A_{conf,max2}$ by a length equal to half the clear spacing between internal hoops.
 $A_{noConf2} = 110709.333$ is the unconfined internal core area which is equal to $b_i^2/6$ as defined at (A.2).
 $psh,min * F_{ywe} = Min(psh,x * F_{ywe}, psh,y * F_{ywe}) = 2.724$
 Expression (5.4d) for $psh,min * F_{ywe}$ has been multiplied by 0.3 according to 15.7.1.3 for members without earthquake detailing (90° closed stirrups)

$psh,x * F_{ywe} = psh1 * F_{ywe1} + ps2 * F_{ywe2} = 2.724$
 $psh1((5.4d), TBDY) = L_{stir1} * A_{stir1} / (A_{sec} * s1) = 0.00301593$
 L_{stir1} (Length of stirrups along Y) = 2160.00
 A_{stir1} (stirrups area) = 78.53982
 $psh2(5.4d) = L_{stir2} * A_{stir2} / (A_{sec} * s2) = 0.00056047$
 L_{stir2} (Length of stirrups along Y) = 1568.00
 A_{stir2} (stirrups area) = 50.26548

$psh,y * F_{ywe} = psh1 * F_{ywe1} + ps2 * F_{ywe2} = 3.25416$
 $psh1((5.4d), TBDY) = L_{stir1} * A_{stir1} / (A_{sec} * s1) = 0.00357443$
 L_{stir1} (Length of stirrups along X) = 2560.00
 A_{stir1} (stirrups area) = 78.53982
 $psh2((5.4d), TBDY) = L_{stir2} * A_{stir2} / (A_{sec} * s2) = 0.00070345$
 L_{stir2} (Length of stirrups along X) = 1968.00
 A_{stir2} (stirrups area) = 50.26548

$A_{sec} = 562500.00$
 $s1 = 100.00$
 $s2 = 250.00$
 $f_{ywe1} = 781.25$
 $f_{ywe2} = 656.25$
 $f_{ce} = 30.00$
 From ((5.A5), TBDY), TBDY: $cc = 0.002$
 $c =$ confinement factor = 1.00
 $y1 = 0.0025$
 $sh1 = 0.008$
 $ft1 = 900.1904$
 $fy1 = 750.1586$
 $su1 = 0.032$

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
 and also multiplied by the shear_factor according to 15.7.1.4, with
 Shear_factor = 1.00
 $l_o/l_{ou,min} = l_b/l_d = 1.00$
 $su_1 = 0.4 * esu_{1,nominal} ((5.5), TBDY) = 0.032$
 From table 5A.1, TBDY: $esu_{1,nominal} = 0.08$,
 For calculation of $esu_{1,nominal}$ and y_1, sh_1, ft_1, fy_1 , it is considered
 characteristic value $fsy_1 = fs_1/1.2$, from table 5.1, TBDY.
 y_1, sh_1, ft_1, fy_1 , are also multiplied by $Min(1, 1.25 * (l_b/l_d)^{2/3})$, from 10.3.5, ASCE 41-17.
 with $fs_1 = (fs_{jacket} * A_{sl,ten,jacket} + fs_{core} * A_{sl,ten,core}) / A_{sl,ten} = 750.1586$
 with $Es_1 = (Es_{jacket} * A_{sl,ten,jacket} + Es_{core} * A_{sl,ten,core}) / A_{sl,ten} = 200000.00$
 $y_2 = 0.0025$
 $sh_2 = 0.008$
 $ft_2 = 907.50$
 $fy_2 = 756.25$
 $su_2 = 0.032$
 using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
 and also multiplied by the shear_factor according to 15.7.1.4, with
 Shear_factor = 1.00
 $l_o/l_{ou,min} = l_b/l_{b,min} = 1.00$
 $su_2 = 0.4 * esu_{2,nominal} ((5.5), TBDY) = 0.032$
 From table 5A.1, TBDY: $esu_{2,nominal} = 0.08$,
 For calculation of $esu_{2,nominal}$ and y_2, sh_2, ft_2, fy_2 , it is considered
 characteristic value $fsy_2 = fs_2/1.2$, from table 5.1, TBDY.
 y_2, sh_2, ft_2, fy_2 , are also multiplied by $Min(1, 1.25 * (l_b/l_d)^{2/3})$, from 10.3.5, ASCE 41-17.
 with $fs_2 = (fs_{jacket} * A_{sl,com,jacket} + fs_{core} * A_{sl,com,core}) / A_{sl,com} = 756.25$
 with $Es_2 = (Es_{jacket} * A_{sl,com,jacket} + Es_{core} * A_{sl,com,core}) / A_{sl,com} = 200000.00$
 $y_v = 0.0025$
 $sh_v = 0.008$
 $ft_v = 902.993$
 $fy_v = 752.4941$
 $suv = 0.032$
 using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
 and also multiplied by the shear_factor according to 15.7.1.4, with
 Shear_factor = 1.00
 $l_o/l_{ou,min} = l_b/l_d = 1.00$
 $suv = 0.4 * esuv_{nominal} ((5.5), TBDY) = 0.032$
 From table 5A.1, TBDY: $esuv_{nominal} = 0.08$,
 considering characteristic value $fsyv = fsv/1.2$, from table 5.1, TBDY
 For calculation of $esuv_{nominal}$ and y_v, sh_v, ft_v, fy_v , it is considered
 characteristic value $fsyv = fsv/1.2$, from table 5.1, TBDY.
 y_1, sh_1, ft_1, fy_1 , are also multiplied by $Min(1, 1.25 * (l_b/l_d)^{2/3})$, from 10.3.5, ASCE 41-17.
 with $fsv = (fs_{jacket} * A_{sl,mid,jacket} + fs_{mid} * A_{sl,mid,core}) / A_{sl,mid} = 752.4941$
 with $Esv = (Es_{jacket} * A_{sl,mid,jacket} + Es_{mid} * A_{sl,mid,core}) / A_{sl,mid} = 200000.00$
 $1 = A_{sl,ten} / (b * d) * (fs_1 / fc) = 0.19457006$
 $2 = A_{sl,com} / (b * d) * (fs_2 / fc) = 0.12197144$
 $v = A_{sl,mid} / (b * d) * (fsv / fc) = 0.21102767$
 and confined core properties:
 $b = 390.00$
 $d = 677.00$
 $d' = 13.00$
 $f_{cc} (5A.2, TBDY) = 30.00$
 $cc (5A.5, TBDY) = 0.002$
 $c = \text{confinement factor} = 1.00$
 $1 = A_{sl,ten} / (b * d) * (fs_1 / fc) = 0.23445239$
 $2 = A_{sl,com} / (b * d) * (fs_2 / fc) = 0.14697275$
 $v = A_{sl,mid} / (b * d) * (fsv / fc) = 0.25428343$
 Case/Assumption: Unconfined full section - Steel rupture
 ' satisfies Eq. (4.3)
 --->
 $v < v_{s,y2}$ - LHS eq.(4.5) is not satisfied
 --->
 $v < v_{s,c}$ - RHS eq.(4.5) is satisfied
 --->
 $su (4.8) = 0.33719414$
 $Mu = MRc (4.15) = 2.1636E+009$
 $u = su (4.1) = 6.8287974E-005$

Calculation of ratio l_b/d

Adequate Lap Length: $l_b/d \geq 1$

Calculation of Shear Strength $V_r = \text{Min}(V_{r1}, V_{r2}) = 1.2916\text{E}+006$

Calculation of Shear Strength at edge 1, $V_{r1} = 1.2916\text{E}+006$

$V_{r1} = V_{\text{Col}} ((10.3), \text{ASCE } 41-17) = k_n l V_{\text{Col}0}$

$V_{\text{Col}0} = 1.2916\text{E}+006$

$k_n l = 1$ (zero step-static loading)

NOTE: In expression (10-3) ' $V_s = A_v f_y d/s$ ' is replaced by ' $V_s + f^* V_f$ ' where V_f is the contribution of FRPs (11.3), ACI 440).

$= 1$ (normal-weight concrete)

Mean concrete strength: $f_c' = (f_c'_{\text{jacket}} \text{Area}_{\text{jacket}} + f_c'_{\text{core}} \text{Area}_{\text{core}}) / \text{Area}_{\text{section}} = 27.20$, but $f_c'^{0.5} \leq 8.3$ MPa (22.5.3.1, ACI 318-14)

$M/V_d = 2.00$

$\mu_u = 5174.584$

$V_u = 8.5087964\text{E}-020$

$d = 0.8 \cdot h = 600.00$

$N_u = 20792.05$

$A_g = 337500.00$

From (11.5.4.8), ACI 318-14: $V_s = V_{s,\text{jacket}} + V_{s,\text{core}} = 1.0354\text{E}+006$

where:

$V_{s,\text{jacket}} = V_{s,j1} + V_{s,j2} = 942477.796$

$V_{s,j1} = 589048.623$ is calculated for section web jacket, with:

$d = 600.00$

$A_v = 157079.633$

$f_y = 625.00$

$s = 100.00$

$V_{s,j1}$ is multiplied by $\text{Col},j1 = 1.00$

$s/d = 0.16666667$

$V_{s,j2} = 353429.174$ is calculated for section flange jacket, with:

$d = 360.00$

$A_v = 157079.633$

$f_y = 625.00$

$s = 100.00$

$V_{s,j2}$ is multiplied by $\text{Col},j2 = 1.00$

$s/d = 0.27777778$

$V_{s,\text{core}} = V_{s,c1} + V_{s,c2} = 92890.612$

$V_{s,c1} = 92890.612$ is calculated for section web core, with:

$d = 440.00$

$A_v = 100530.965$

$f_y = 525.00$

$s = 250.00$

$V_{s,c1}$ is multiplied by $\text{Col},c1 = 1.00$

$s/d = 0.56818182$

$V_{s,c2} = 0.00$ is calculated for section flange core, with:

$d = 200.00$

$A_v = 100530.965$

$f_y = 525.00$

$s = 250.00$

$V_{s,c2}$ is multiplied by $\text{Col},c2 = 0.00$

$s/d = 1.25$

$V_f ((11-3)-(11.4), \text{ACI } 440) = 0.00$

From (11-11), ACI 440: $V_s + V_f \leq 935437.922$

$b_w = 450.00$

Calculation of Shear Strength at edge 2, $V_{r2} = 1.2916\text{E}+006$

$V_{r2} = V_{\text{Col}} ((10.3), \text{ASCE } 41-17) = k_n l V_{\text{Col}0}$

VColO = 1.2916E+006
knl = 1 (zero step-static loading)

NOTE: In expression (10-3) ' $V_s = A_v \cdot f_y \cdot d / s$ ' is replaced by ' $V_s + f \cdot V_f$ '
where V_f is the contribution of FRPs (11.3), ACI 440).

= 1 (normal-weight concrete)

Mean concrete strength: $f_c' = (f_c'_{\text{jacket}} \cdot \text{Area}_{\text{jacket}} + f_c'_{\text{core}} \cdot \text{Area}_{\text{core}}) / \text{Area}_{\text{section}} = 27.20$, but $f_c'^{0.5} \leq 8.3$
MPa (22.5.3.1, ACI 318-14)

$M/Vd = 2.00$

$\mu_u = 5174.584$

$V_u = 8.5087964E-020$

$d = 0.8 \cdot h = 600.00$

$N_u = 20792.05$

$A_g = 337500.00$

From (11.5.4.8), ACI 318-14: $V_s = V_{s,\text{jacket}} + V_{s,\text{core}} = 1.0354E+006$

where:

$V_{s,\text{jacket}} = V_{s,j1} + V_{s,j2} = 942477.796$

$V_{s,j1} = 589048.623$ is calculated for section web jacket, with:

$d = 600.00$

$A_v = 157079.633$

$f_y = 625.00$

$s = 100.00$

$V_{s,j1}$ is multiplied by $\text{Col},j1 = 1.00$

$s/d = 0.16666667$

$V_{s,j2} = 353429.174$ is calculated for section flange jacket, with:

$d = 360.00$

$A_v = 157079.633$

$f_y = 625.00$

$s = 100.00$

$V_{s,j2}$ is multiplied by $\text{Col},j2 = 1.00$

$s/d = 0.27777778$

$V_{s,\text{core}} = V_{s,c1} + V_{s,c2} = 92890.612$

$V_{s,c1} = 92890.612$ is calculated for section web core, with:

$d = 440.00$

$A_v = 100530.965$

$f_y = 525.00$

$s = 250.00$

$V_{s,c1}$ is multiplied by $\text{Col},c1 = 1.00$

$s/d = 0.56818182$

$V_{s,c2} = 0.00$ is calculated for section flange core, with:

$d = 200.00$

$A_v = 100530.965$

$f_y = 525.00$

$s = 250.00$

$V_{s,c2}$ is multiplied by $\text{Col},c2 = 0.00$

$s/d = 1.25$

V_f ((11-3)-(11.4), ACI 440) = 0.00

From (11-11), ACI 440: $V_s + V_f \leq 935437.922$

$b_w = 450.00$

End Of Calculation of Shear Capacity ratio for element: column JTC1 of floor 1
At local axis: 3

Start Of Calculation of Shear Capacity ratio for element: column JTC1 of floor 1
At Shear local axis: 2
(Bending local axis: 3)
Section Type: rcjtcs

Constant Properties

Knowledge Factor, $\phi = 0.80$

Mean strength values are used for both shear and moment calculations.

Consequently:

Jacket

New material of Secondary Member: Concrete Strength, $f_c = f_{cm} = 30.00$

New material of Secondary Member: Steel Strength, $f_s = f_{sm} = 625.00$

Concrete Elasticity, $E_c = 25742.96$

Steel Elasticity, $E_s = 200000.00$

Existing Column

Existing material of Secondary Member: Concrete Strength, $f_c = f_{cm} = 24.00$

Existing material of Secondary Member: Steel Strength, $f_s = f_{sm} = 525.00$

Concrete Elasticity, $E_c = 23025.204$

Steel Elasticity, $E_s = 200000.00$

#####

Note: Especially for the calculation of moment strengths,
the above steel re-bar strengths are multiplied by 1.25 according to R18.6.5, ACI 318-14

Jacket

New material: Steel Strength, $f_s = 1.25 \cdot f_{sm} = 781.25$

Existing Column

Existing material: Steel Strength, $f_s = 1.25 \cdot f_{sm} = 656.25$

#####

Max Height, $H_{max} = 750.00$

Min Height, $H_{min} = 450.00$

Max Width, $W_{max} = 950.00$

Min Width, $W_{min} = 450.00$

Eccentricity, $Ecc = 250.00$

Jacket Thickness, $t_j = 100.00$

Cover Thickness, $c = 25.00$

Mean Confinement Factor overall section = 1.00

Element Length, $L = 3000.00$

Secondary Member

Smooth Bars

Ductile Steel

Without Detailing for Earthquake Resistance (including stirrups not closed at 135°)

Longitudinal Bars With Ends Lapped Starting at the End Sections

Adequate Lap Length ($l_o/l_{ou,min} \geq 1$)

No FRP Wrapping

Stepwise Properties

At local axis: 2

EDGE -A-

Shear Force, $V_a = 5.2099631E-036$

EDGE -B-

Shear Force, $V_b = -5.2099631E-036$

BOTH EDGES

Axial Force, $F = -20792.05$

Longitudinal Reinforcement Area Distribution (in 2 divisions)

-Tension: $As_t = 0.00$

-Compression: $As_c = 6691.592$

Longitudinal Reinforcement Area Distribution (in 3 divisions)

-Tension: $As_{t,ten} = 1539.38$

-Compression: $As_{l,com} = 1539.38$

-Middle: $As_{l,mid} = 3612.832$

Calculation of Shear Capacity ratio, $V_e/V_r = 1.08994$

Member Controlled by Shear ($V_e/V_r > 1$)

Calculation of Shear Demand from fig. R18.6.5, ACI 318-14 $V_e = (M_{pr1} + M_{pr2})/l_n = 1.7820E+006$

with

$M_{pr1} = \text{Max}(Mu_{1+}, Mu_{1-}) = 2.6730E+009$

$Mu_{1+} = 2.6730E+009$, is the ultimate moment strength at the edge 1 of the member in the actual moment direction which is defined for the static loading combination

$Mu_{1-} = 2.6730E+009$, is the ultimate moment strength at the edge 1 of the member in the opposite moment direction which is defined for the static loading combination

$M_{pr2} = \text{Max}(Mu_{2+}, Mu_{2-}) = 2.6730E+009$

Mu2+ = 2.6730E+009, is the ultimate moment strength at the edge 2 of the member in the actual moment direction which is defined for the the static loading combination

Mu2- = 2.6730E+009, is the ultimate moment strength at the edge 2 of the member in the opposite moment direction which is defined for the the static loading combination

Calculation of Mu1+

Calculation of ultimate curvature ϕ_u according to 4.1, Biskinis/Fardis 2013:

$$\phi_u = 4.9274896E-005$$

$$M_u = 2.6730E+009$$

with full section properties:

$$b = 450.00$$

$$d = 907.00$$

$$d' = 43.00$$

$$\nu = 0.00169807$$

$$N = 20792.05$$

$$f_c = 30.00$$

$$c_o \text{ (5A.5, TBDY)} = 0.002$$

$$\text{Final value of } \phi_u: \phi_u^* = \text{shear_factor} * \text{Max}(\phi_u, \phi_c) = 0.00832321$$

The Shear_factor is considered equal to 1 (pure moment strength)

$$\text{From (5.4b), TBDY: } \phi_u = 0.00832321$$

$$\phi_{ue} \text{ (5.4c)} = 0.01453958$$

$$\phi_{ase} \text{ ((5.4d), TBDY)} = (\phi_{ase1} * A_{ext} + \phi_{ase2} * A_{int}) / A_{sec} = 0.53375773$$

$$\phi_{ase1} = \text{Max}(((A_{conf,max1} - A_{noConf1}) / A_{conf,max1}) * (A_{conf,min1} / A_{conf,max1}), 0) = 0.53375773$$

The definitions of A_{noConf} , $A_{conf,min}$ and $A_{conf,max}$ are derived from generalization of the rectangular sections confinement, which is expressed by (5.4d).

The generalization is done according to Mander, J., Priestley, M., and Park, R. (1988)

"Theoretical Stress-Strain Model for Confined Concrete."

J. Struct. Eng., 10.1061/(ASCE)0733-9445(1988)114:8(1804), 1804-1826.

$A_{conf,max1} = 464100.00$ is the confined core area at levels of member with hoops and

is calculated as the area of core enclosed by the center lines of the external perimeter hoops.

$A_{conf,min1} = 395025.00$ is the confined core area at midway between the levels of hoops and

is calculated by reducing all the dimensions of the area $A_{conf,max1}$ by a length

equal to half the clear spacing between external hoops.

$A_{noConf1} = 173066.667$ is the unconfined external core area which is equal to $b_i^2/6$ as defined at (A.2).

$$\phi_{ase2} (\geq \phi_{ase1}) = \text{Max}(((A_{conf,max2} - A_{noConf2}) / A_{conf,max2}) * (A_{conf,min2} / A_{conf,max2}), 0) = 0.53375773$$

The definitions of A_{noConf} , $A_{conf,min}$ and $A_{conf,max}$ are derived from generalization of the rectangular sections confinement, which is expressed by (5.4d).

The generalization is done according to Mander, J., Priestley, M., and Park, R. (1988)

"Theoretical Stress-Strain Model for Confined Concrete."

J. Struct. Eng., 10.1061/(ASCE)0733-9445(1988)114:8(1804), 1804-1826.

$A_{conf,max2} = 252164.00$ is the confined core area at levels of member with hoops and

is calculated as the area of core enclosed by the center lines of the internal perimeter hoops.

$A_{conf,min2} = 111441.00$ is the confined core area at midway between the levels of hoops and

is calculated by reducing all the dimensions of the area $A_{conf,max2}$ by a length

equal to half the clear spacing between internal hoops.

$A_{noConf2} = 110709.333$ is the unconfined internal core area which is equal to $b_i^2/6$ as defined at (A.2).

$$\phi_{sh,min} * F_{ywe} = \text{Min}(\phi_{sh,x} * F_{ywe}, \phi_{sh,y} * F_{ywe}) = 2.724$$

Expression (5.4d) for $\phi_{sh,min} * F_{ywe}$ has been multiplied by 0.3 according to 15.7.1.3 for members without earthquake detailing (90° closed stirrups)

$$\phi_{sh,x} * F_{ywe} = \phi_{sh1} * F_{ywe1} + \phi_{sh2} * F_{ywe2} = 2.724$$

$$\phi_{sh1} \text{ ((5.4d), TBDY)} = L_{stir1} * A_{stir1} / (A_{sec} * s_1) = 0.00301593$$

$$L_{stir1} \text{ (Length of stirrups along Y)} = 2160.00$$

$$A_{stir1} \text{ (stirrups area)} = 78.53982$$

$$\phi_{sh2} \text{ (5.4d)} = L_{stir2} * A_{stir2} / (A_{sec} * s_2) = 0.00056047$$

$$L_{stir2} \text{ (Length of stirrups along Y)} = 1568.00$$

$$A_{stir2} \text{ (stirrups area)} = 50.26548$$

$$\phi_{sh,y} * F_{ywe} = \phi_{sh1} * F_{ywe1} + \phi_{sh2} * F_{ywe2} = 3.25416$$

$$\phi_{sh1} \text{ ((5.4d), TBDY)} = L_{stir1} * A_{stir1} / (A_{sec} * s_1) = 0.00357443$$

$$L_{stir1} \text{ (Length of stirrups along X)} = 2560.00$$

$$A_{stir1} \text{ (stirrups area)} = 78.53982$$

$psh2 ((5.4d), TBDY) = Lstir2 * Astir2 / (Asec * s2) = 0.00070345$
 $Lstir2$ (Length of stirrups along X) = 1968.00
 $Astir2$ (stirrups area) = 50.26548

Asec = 562500.00

s1 = 100.00

s2 = 250.00

fywe1 = 781.25

fywe2 = 656.25

fce = 30.00

From ((5.A5), TBDY), TBDY: cc = 0.002

c = confinement factor = 1.00

y1 = 0.0025

sh1 = 0.008

ft1 = 907.50

fy1 = 756.25

su1 = 0.032

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00

lo/lou,min = lb/lb,min = 1.00

su1 = 0.4*esu1_nominal ((5.5), TBDY) = 0.032

From table 5A.1, TBDY: esu1_nominal = 0.08,

For calculation of esu1_nominal and y1, sh1,ft1,fy1, it is considered
characteristic value fsy1 = fs1/1.2, from table 5.1, TBDY.

y1, sh1,ft1,fy1, are also multiplied by $\text{Min}(1, 1.25 * (lb/lb)^{2/3})$, from 10.3.5, ASCE 41-17.

with fs1 = (fs,jacket*Asl,ten,jacket + fs,core*Asl,ten,core)/Asl,ten = 756.25

with Es1 = (Es,jacket*Asl,ten,jacket + Es,core*Asl,ten,core)/Asl,ten = 200000.00

y2 = 0.0025

sh2 = 0.008

ft2 = 907.50

fy2 = 756.25

su2 = 0.032

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00

lo/lou,min = lb/lb,min = 1.00

su2 = 0.4*esu2_nominal ((5.5), TBDY) = 0.032

From table 5A.1, TBDY: esu2_nominal = 0.08,

For calculation of esu2_nominal and y2, sh2,ft2,fy2, it is considered
characteristic value fsy2 = fs2/1.2, from table 5.1, TBDY.

y1, sh1,ft1,fy1, are also multiplied by $\text{Min}(1, 1.25 * (lb/lb)^{2/3})$, from 10.3.5, ASCE 41-17.

with fs2 = (fs,jacket*Asl,com,jacket + fs,core*Asl,com,core)/Asl,com = 756.25

with Es2 = (Es,jacket*Asl,com,jacket + Es,core*Asl,com,core)/Asl,com = 200000.00

yv = 0.0025

shv = 0.008

ftv = 899.1522

fyv = 749.2935

suv = 0.032

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00

lo/lou,min = lb/lb,min = 1.00

suv = 0.4*esuv_nominal ((5.5), TBDY) = 0.032

From table 5A.1, TBDY: esuv_nominal = 0.08,

considering characteristic value fsyv = fsv/1.2, from table 5.1, TBDY
For calculation of esuv_nominal and yv, shv,ftv,fyv, it is considered

characteristic value fsyv = fsv/1.2, from table 5.1, TBDY.

y1, sh1,ft1,fy1, are also multiplied by $\text{Min}(1, 1.25 * (lb/lb)^{2/3})$, from 10.3.5, ASCE 41-17.

with fsv = (fs,jacket*Asl,mid,jacket + fs,mid*Asl,mid,core)/Asl,mid = 749.2935

with Esv = (Es,jacket*Asl,mid,jacket + Es,mid*Asl,mid,core)/Asl,mid = 200000.00

1 = Asl,ten/(b*d)*(fs1/fc) = 0.09507586

2 = Asl,com/(b*d)*(fs2/fc) = 0.09507586

v = Asl,mid/(b*d)*(fsv/fc) = 0.22108466

and confined core properties:

b = 390.00

d = 877.00

```

d' = 13.00
fcc (5A.2, TBDY) = 30.00
cc (5A.5, TBDY) = 0.002
c = confinement factor = 1.00
1 = Asl,ten/(b*d)*(fs1/fc) = 0.11345559
2 = Asl,com/(b*d)*(fs2/fc) = 0.11345559
v = Asl,mid/(b*d)*(fsv/fc) = 0.26382395
Case/Assumption: Unconfined full section - Steel rupture
'satisfies Eq. (4.3)
--->
v < vs,y2 - LHS eq.(4.5) is not satisfied
--->
v < vs,c - RHS eq.(4.5) is satisfied
--->
su (4.8) = 0.28399348
Mu = MRc (4.15) = 2.6730E+009
u = su (4.1) = 4.9274896E-005

```

Calculation of ratio lb/ld

Adequate Lap Length: lb/ld >= 1

Calculation of Mu1-

Calculation of ultimate curvature u according to 4.1, Biskinis/Fardis 2013:

```

u = 4.9274896E-005
Mu = 2.6730E+009

```

with full section properties:

```

b = 450.00
d = 907.00
d' = 43.00
v = 0.00169807
N = 20792.05
fc = 30.00
co (5A.5, TBDY) = 0.002
Final value of cu: cu* = shear_factor * Max( cu, cc) = 0.00832321
The Shear_factor is considered equal to 1 (pure moment strength)
From (5.4b), TBDY: cu = 0.00832321
we (5.4c) = 0.01453958
ase ((5.4d), TBDY) = (ase1*Aext+ase2*Aint)/Asec = 0.53375773
ase1 = Max(((Aconf,max1-AnoConf1)/Aconf,max1)*(Aconf,min1/Aconf,max1),0) = 0.53375773
The definitions of AnoConf, Aconf,min and Aconf,max are derived from generalization
of the rectangular sections confinement, which is expressed by (5.4d).
The generalization is done according to Mander, J., Priestley, M., and Park, R. (1988)
"Theoretical Stress-Strain Model for Confined Concrete."
J. Struct. Eng., 10.1061/(ASCE)0733-9445(1988)114:8(1804), 1804-1826.
Aconf,max1 = 464100.00 is the confined core area at levels of member with hoops and
is calculated as the area of core enclosed by the center lines of the external perimeter hoops.
Aconf,min1 = 395025.00 is the confined core area at midway between the levels of hoops and
is calculated by reducing all the dimensions of the area Aconf,max1 by a length
equal to half the clear spacing between external hoops.
AnoConf1 = 173066.667 is the unconfined external core area which is equal to bi2/6 as defined at (A.2).
ase2 (>=ase1) = Max(((Aconf,max2-AnoConf2)/Aconf,max2)*(Aconf,min2/Aconf,max2),0) = 0.53375773
The definitions of AnoConf, Aconf,min and Aconf,max are derived from generalization
of the rectangular sections confinement, which is expressed by (5.4d).
The generalization is done according to Mander, J., Priestley, M., and Park, R. (1988)
"Theoretical Stress-Strain Model for Confined Concrete."
J. Struct. Eng., 10.1061/(ASCE)0733-9445(1988)114:8(1804), 1804-1826.
Aconf,max2 = 252164.00 is the confined core area at levels of member with hoops and
is calculated as the area of core enclosed by the center lines of the internal perimeter hoops.
Aconf,min2 = 111441.00 is the confined core area at midway between the levels of hoops and

```

is calculated by reducing all the dimensions of the area Aconf,max2 by a length equal to half the clear spacing between internal hoops.

AnoConf2 = 110709.333 is the unconfined internal core area which is equal to $b_i^2/6$ as defined at (A.2).

$$psh_{min} \cdot F_{ywe} = \min(psh_x \cdot F_{ywe}, psh_y \cdot F_{ywe}) = 2.724$$

Expression (5.4d) for $psh_{min} \cdot F_{ywe}$ has been multiplied by 0.3 according to 15.7.1.3 for members without earthquake detailing (90° closed stirrups)

$$\begin{aligned} psh_x \cdot F_{ywe} &= psh1 \cdot F_{ywe1} + ps2 \cdot F_{ywe2} = 2.724 \\ psh1 \text{ ((5.4d), TBDY)} &= Lstir1 \cdot Astir1 / (Asec \cdot s1) = 0.00301593 \\ Lstir1 \text{ (Length of stirrups along Y)} &= 2160.00 \\ Astir1 \text{ (stirrups area)} &= 78.53982 \\ psh2 \text{ (5.4d)} &= Lstir2 \cdot Astir2 / (Asec \cdot s2) = 0.00056047 \\ Lstir2 \text{ (Length of stirrups along Y)} &= 1568.00 \\ Astir2 \text{ (stirrups area)} &= 50.26548 \end{aligned}$$

$$\begin{aligned} psh_y \cdot F_{ywe} &= psh1 \cdot F_{ywe1} + ps2 \cdot F_{ywe2} = 3.25416 \\ psh1 \text{ ((5.4d), TBDY)} &= Lstir1 \cdot Astir1 / (Asec \cdot s1) = 0.00357443 \\ Lstir1 \text{ (Length of stirrups along X)} &= 2560.00 \\ Astir1 \text{ (stirrups area)} &= 78.53982 \\ psh2 \text{ ((5.4d), TBDY)} &= Lstir2 \cdot Astir2 / (Asec \cdot s2) = 0.00070345 \\ Lstir2 \text{ (Length of stirrups along X)} &= 1968.00 \\ Astir2 \text{ (stirrups area)} &= 50.26548 \end{aligned}$$

$$Asec = 562500.00$$

$$s1 = 100.00$$

$$s2 = 250.00$$

$$fywe1 = 781.25$$

$$fywe2 = 656.25$$

$$fce = 30.00$$

$$\text{From ((5.A5), TBDY), TBDY: } cc = 0.002$$

$$c = \text{confinement factor} = 1.00$$

$$y1 = 0.0025$$

$$sh1 = 0.008$$

$$ft1 = 907.50$$

$$fy1 = 756.25$$

$$su1 = 0.032$$

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor and also multiplied by the shear_factor according to 15.7.1.4, with Shear_factor = 1.00

$$lo/lo_{min} = lb/lb_{min} = 1.00$$

$$su1 = 0.4 \cdot esu1_{nominal} \text{ ((5.5), TBDY)} = 0.032$$

From table 5A.1, TBDY: $esu1_{nominal} = 0.08$,

For calculation of $esu1_{nominal}$ and $y1, sh1, ft1, fy1$, it is considered characteristic value $fsy1 = fs1/1.2$, from table 5.1, TBDY.

$y1, sh1, ft1, fy1$, are also multiplied by $\min(1, 1.25 \cdot (lb/lb_{min})^{2/3})$, from 10.3.5, ASCE 41-17.

$$\text{with } fs1 = (fs_{jacket} \cdot Asl_{ten,jacket} + fs_{core} \cdot Asl_{ten,core}) / Asl_{ten} = 756.25$$

$$\text{with } Es1 = (Es_{jacket} \cdot Asl_{ten,jacket} + Es_{core} \cdot Asl_{ten,core}) / Asl_{ten} = 200000.00$$

$$y2 = 0.0025$$

$$sh2 = 0.008$$

$$ft2 = 907.50$$

$$fy2 = 756.25$$

$$su2 = 0.032$$

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor and also multiplied by the shear_factor according to 15.7.1.4, with Shear_factor = 1.00

$$lo/lo_{min} = lb/lb_{min} = 1.00$$

$$su2 = 0.4 \cdot esu2_{nominal} \text{ ((5.5), TBDY)} = 0.032$$

From table 5A.1, TBDY: $esu2_{nominal} = 0.08$,

For calculation of $esu2_{nominal}$ and $y2, sh2, ft2, fy2$, it is considered characteristic value $fsy2 = fs2/1.2$, from table 5.1, TBDY.

$y2, sh2, ft2, fy2$, are also multiplied by $\min(1, 1.25 \cdot (lb/lb_{min})^{2/3})$, from 10.3.5, ASCE 41-17.

$$\text{with } fs2 = (fs_{jacket} \cdot Asl_{com,jacket} + fs_{core} \cdot Asl_{com,core}) / Asl_{com} = 756.25$$

$$\text{with } Es2 = (Es_{jacket} \cdot Asl_{com,jacket} + Es_{core} \cdot Asl_{com,core}) / Asl_{com} = 200000.00$$

$$yv = 0.0025$$

$$shv = 0.008$$

$$ftv = 899.1522$$

$$fyv = 749.2935$$

```

suv = 0.032
using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00
lo/lo,min = lb/d = 1.00
suv = 0.4*esuv_nominal ((5.5), TBDY) = 0.032
From table 5A.1, TBDY: esuv_nominal = 0.08,
considering characteristic value fsyv = fsv/1.2, from table 5.1, TBDY
For calculation of esuv_nominal and yv, shv,ftv,fyv, it is considered
characteristic value fsyv = fsv/1.2, from table 5.1, TBDY.
y1, sh1,ft1,fy1, are also multiplied by Min(1,1.25*(lb/d)^ 2/3), from 10.3.5, ASCE 41-17.
with fsv = (fs,jacket*Asl,mid,jacket + fs,mid*Asl,mid,core)/Asl,mid = 749.2935
with Esv = (Es,jacket*Asl,mid,jacket + Es,mid*Asl,mid,core)/Asl,mid = 200000.00
1 = Asl,ten/(b*d)*(fs1/fc) = 0.09507586
2 = Asl,com/(b*d)*(fs2/fc) = 0.09507586
v = Asl,mid/(b*d)*(fsv/fc) = 0.22108466
and confined core properties:
b = 390.00
d = 877.00
d' = 13.00
fcc (5A.2, TBDY) = 30.00
cc (5A.5, TBDY) = 0.002
c = confinement factor = 1.00
1 = Asl,ten/(b*d)*(fs1/fc) = 0.11345559
2 = Asl,com/(b*d)*(fs2/fc) = 0.11345559
v = Asl,mid/(b*d)*(fsv/fc) = 0.26382395
Case/Assumption: Unconfined full section - Steel rupture
' satisfies Eq. (4.3)
--->
v < vs,y2 - LHS eq.(4.5) is not satisfied
--->
v < vs,c - RHS eq.(4.5) is satisfied
--->
su (4.8) = 0.28399348
Mu = MRc (4.15) = 2.6730E+009
u = su (4.1) = 4.9274896E-005
-----

Calculation of ratio lb/d
-----
Adequate Lap Length: lb/d >= 1
-----
-----
Calculation of Mu2+
-----
-----
Calculation of ultimate curvature u according to 4.1, Biskinis/Fardis 2013:
u = 4.9274896E-005
Mu = 2.6730E+009
-----
with full section properties:
b = 450.00
d = 907.00
d' = 43.00
v = 0.00169807
N = 20792.05
fc = 30.00
co (5A.5, TBDY) = 0.002
Final value of cu: cu* = shear_factor * Max( cu, cc) = 0.00832321
The Shear_factor is considered equal to 1 (pure moment strength)
From (5.4b), TBDY: cu = 0.00832321
we (5.4c) = 0.01453958
ase ((5.4d), TBDY) = (ase1*Aext+ase2*Aint)/Asec = 0.53375773
ase1 = Max(((Aconf,max1-AnoConf1)/Aconf,max1)*(Aconf,min1/Aconf,max1),0) = 0.53375773
The definitions of AnoConf, Aconf,min and Aconf,max are derived from generalization

```

of the rectangular sections confinement, which is expressed by (5.4d).

The generalization is done according to Mander, J., Priestley, M., and Park, R. (1988)

"Theoretical Stress-Strain Model for Confined Concrete."

J. Struct. Eng., 10.1061/(ASCE)0733-9445(1988)114:8(1804), 1804-1826.

$A_{conf,max1} = 464100.00$ is the confined core area at levels of member with hoops and

is calculated as the area of core enclosed by the center lines of the external perimeter hoops.

$A_{conf,min1} = 395025.00$ is the confined core area at midway between the levels of hoops and

is calculated by reducing all the dimensions of the area $A_{conf,max1}$ by a length equal to half the clear spacing between external hoops.

$A_{noConf1} = 173066.667$ is the unconfined external core area which is equal to $b_i^2/6$ as defined at (A.2).

$ase2 (>= ase1) = \text{Max}(((A_{conf,max2} - A_{noConf2})/A_{conf,max2}) * (A_{conf,min2}/A_{conf,max2}), 0) = 0.53375773$

The definitions of A_{noConf} , $A_{conf,min}$ and $A_{conf,max}$ are derived from generalization of the rectangular sections confinement, which is expressed by (5.4d).

The generalization is done according to Mander, J., Priestley, M., and Park, R. (1988)

"Theoretical Stress-Strain Model for Confined Concrete."

J. Struct. Eng., 10.1061/(ASCE)0733-9445(1988)114:8(1804), 1804-1826.

$A_{conf,max2} = 252164.00$ is the confined core area at levels of member with hoops and

is calculated as the area of core enclosed by the center lines of the internal perimeter hoops.

$A_{conf,min2} = 111441.00$ is the confined core area at midway between the levels of hoops and

is calculated by reducing all the dimensions of the area $A_{conf,max2}$ by a length equal to half the clear spacing between internal hoops.

$A_{noConf2} = 110709.333$ is the unconfined internal core area which is equal to $b_i^2/6$ as defined at (A.2).

$psh_{min} * F_{ywe} = \text{Min}(psh_x * F_{ywe}, psh_y * F_{ywe}) = 2.724$

Expression (5.4d) for $psh_{min} * F_{ywe}$ has been multiplied by 0.3 according to 15.7.1.3 for members without earthquake detailing (90° closed stirrups)

 $psh_x * F_{ywe} = psh1 * F_{ywe1} + ps2 * F_{ywe2} = 2.724$

$psh1$ ((5.4d), TBDY) = $L_{stir1} * A_{stir1} / (A_{sec} * s1) = 0.00301593$

L_{stir1} (Length of stirrups along Y) = 2160.00

A_{stir1} (stirrups area) = 78.53982

$psh2$ ((5.4d)) = $L_{stir2} * A_{stir2} / (A_{sec} * s2) = 0.00056047$

L_{stir2} (Length of stirrups along Y) = 1568.00

A_{stir2} (stirrups area) = 50.26548

 $psh_y * F_{ywe} = psh1 * F_{ywe1} + ps2 * F_{ywe2} = 3.25416$

$psh1$ ((5.4d), TBDY) = $L_{stir1} * A_{stir1} / (A_{sec} * s1) = 0.00357443$

L_{stir1} (Length of stirrups along X) = 2560.00

A_{stir1} (stirrups area) = 78.53982

$psh2$ ((5.4d), TBDY) = $L_{stir2} * A_{stir2} / (A_{sec} * s2) = 0.00070345$

L_{stir2} (Length of stirrups along X) = 1968.00

A_{stir2} (stirrups area) = 50.26548

 $A_{sec} = 562500.00$

$s1 = 100.00$

$s2 = 250.00$

$f_{ywe1} = 781.25$

$f_{ywe2} = 656.25$

$f_{ce} = 30.00$

From ((5.A5), TBDY), TBDY: $cc = 0.002$

c = confinement factor = 1.00

$y1 = 0.0025$

$sh1 = 0.008$

$ft1 = 907.50$

$fy1 = 756.25$

$su1 = 0.032$

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor

and also multiplied by the shear_factor according to 15.7.1.4, with

Shear_factor = 1.00

$lo/lo_{u,min} = l_b/l_d = 1.00$

$su1 = 0.4 * esu1_{nominal}$ ((5.5), TBDY) = 0.032

From table 5A.1, TBDY: $esu1_{nominal} = 0.08$,

For calculation of $esu1_{nominal}$ and $y1$, $sh1$, $ft1$, $fy1$, it is considered

characteristic value $fsy1 = fs1/1.2$, from table 5.1, TBDY.

$y1$, $sh1$, $ft1$, $fy1$, are also multiplied by $\text{Min}(1, 1.25 * (l_b/l_d)^{2/3})$, from 10.3.5, ASCE 41-17.

with $fs1 = (f_{s,jacket} * A_{s,ten,jacket} + f_{s,core} * A_{s,ten,core}) / A_{s,ten} = 756.25$

with $Es1 = (E_{s,jacket} * A_{s,ten,jacket} + E_{s,core} * A_{s,ten,core}) / A_{s,ten} = 200000.00$

$y2 = 0.0025$

```

sh2 = 0.008
ft2 = 907.50
fy2 = 756.25
su2 = 0.032
    using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
    and also multiplied by the shear_factor according to 15.7.1.4, with
    Shear_factor = 1.00
    lo/lo,min = lb/lb,min = 1.00
    su2 = 0.4*esu2_nominal ((5.5), TBDY) = 0.032
    From table 5A.1, TBDY: esu2_nominal = 0.08,
    For calculation of esu2_nominal and y2, sh2,ft2,fy2, it is considered
    characteristic value fsy2 = fs2/1.2, from table 5.1, TBDY.
    y1, sh1,ft1,fy1, are also multiplied by Min(1,1.25*(lb/lb)^ 2/3), from 10.3.5, ASCE 41-17.
    with fs2 = (fs,jacket*Asl,com,jacket + fs,core*Asl,com,core)/Asl,com = 756.25
    with Es2 = (Es,jacket*Asl,com,jacket + Es,core*Asl,com,core)/Asl,com = 200000.00
yv = 0.0025
shv = 0.008
ftv = 899.1522
fyv = 749.2935
suv = 0.032
    using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
    and also multiplied by the shear_factor according to 15.7.1.4, with
    Shear_factor = 1.00
    lo/lo,min = lb/lb = 1.00
    suv = 0.4*esuv_nominal ((5.5), TBDY) = 0.032
    From table 5A.1, TBDY: esuv_nominal = 0.08,
    considering characteristic value fsyv = fsv/1.2, from table 5.1, TBDY
    For calculation of esuv_nominal and yv, shv,ftv,fyv, it is considered
    characteristic value fsyv = fsv/1.2, from table 5.1, TBDY.
    y1, sh1,ft1,fy1, are also multiplied by Min(1,1.25*(lb/lb)^ 2/3), from 10.3.5, ASCE 41-17.
    with fsv = (fs,jacket*Asl,mid,jacket + fs,mid*Asl,mid,core)/Asl,mid = 749.2935
    with Esv = (Es,jacket*Asl,mid,jacket + Es,mid*Asl,mid,core)/Asl,mid = 200000.00
1 = Asl,ten/(b*d)*(fs1/fc) = 0.09507586
2 = Asl,com/(b*d)*(fs2/fc) = 0.09507586
v = Asl,mid/(b*d)*(fsv/fc) = 0.22108466
and confined core properties:
b = 390.00
d = 877.00
d' = 13.00
fcc (5A.2, TBDY) = 30.00
cc (5A.5, TBDY) = 0.002
c = confinement factor = 1.00
1 = Asl,ten/(b*d)*(fs1/fc) = 0.11345559
2 = Asl,com/(b*d)*(fs2/fc) = 0.11345559
v = Asl,mid/(b*d)*(fsv/fc) = 0.26382395
Case/Assumption: Unconfined full section - Steel rupture
' satisfies Eq. (4.3)
---->
v < vs,y2 - LHS eq.(4.5) is not satisfied
---->
v < vs,c - RHS eq.(4.5) is satisfied
---->
su (4.8) = 0.28399348
Mu = MRc (4.15) = 2.6730E+009
u = su (4.1) = 4.9274896E-005

```

Calculation of ratio lb/lb

Adequate Lap Length: lb/lb >= 1

Calculation of Mu2-

Calculation of ultimate curvature ϕ_u according to 4.1, Biskinis/Fardis 2013:

$$\phi_u = 4.9274896E-005$$

$$\mu = 2.6730E+009$$

with full section properties:

$$b = 450.00$$

$$d = 907.00$$

$$d' = 43.00$$

$$v = 0.00169807$$

$$N = 20792.05$$

$$f_c = 30.00$$

$$\phi_{co} (5A.5, TBDY) = 0.002$$

$$\text{Final value of } \phi_u: \phi_u^* = \text{shear_factor} * \text{Max}(\phi_u, \phi_{co}) = 0.00832321$$

The Shear_factor is considered equal to 1 (pure moment strength)

$$\text{From (5.4b), TBDY: } \phi_u = 0.00832321$$

$$\phi_{we} (5.4c) = 0.01453958$$

$$\phi_{ase} ((5.4d), TBDY) = (\phi_{ase1} * A_{ext} + \phi_{ase2} * A_{int}) / A_{sec} = 0.53375773$$

$$\phi_{ase1} = \text{Max}(((A_{conf,max1} - A_{noConf1}) / A_{conf,max1}) * (A_{conf,min1} / A_{conf,max1}), 0) = 0.53375773$$

The definitions of A_{noConf} , $A_{conf,min}$ and $A_{conf,max}$ are derived from generalization of the rectangular sections confinement, which is expressed by (5.4d).

The generalization is done according to Mander, J., Priestley, M., and Park, R. (1988)

"Theoretical Stress-Strain Model for Confined Concrete."

J. Struct. Eng., 10.1061/(ASCE)0733-9445(1988)114:8(1804), 1804-1826.

$A_{conf,max1} = 464100.00$ is the confined core area at levels of member with hoops and

is calculated as the area of core enclosed by the center lines of the external perimeter hoops.

$A_{conf,min1} = 395025.00$ is the confined core area at midway between the levels of hoops and

is calculated by reducing all the dimensions of the area $A_{conf,max1}$ by a length equal to half the clear spacing between external hoops.

$A_{noConf1} = 173066.667$ is the unconfined external core area which is equal to $b_i d_i / 6$ as defined at (A.2).

$$\phi_{ase2} (> \phi_{ase1}) = \text{Max}(((A_{conf,max2} - A_{noConf2}) / A_{conf,max2}) * (A_{conf,min2} / A_{conf,max2}), 0) = 0.53375773$$

The definitions of A_{noConf} , $A_{conf,min}$ and $A_{conf,max}$ are derived from generalization of the rectangular sections confinement, which is expressed by (5.4d).

The generalization is done according to Mander, J., Priestley, M., and Park, R. (1988)

"Theoretical Stress-Strain Model for Confined Concrete."

J. Struct. Eng., 10.1061/(ASCE)0733-9445(1988)114:8(1804), 1804-1826.

$A_{conf,max2} = 252164.00$ is the confined core area at levels of member with hoops and

is calculated as the area of core enclosed by the center lines of the internal perimeter hoops.

$A_{conf,min2} = 111441.00$ is the confined core area at midway between the levels of hoops and

is calculated by reducing all the dimensions of the area $A_{conf,max2}$ by a length equal to half the clear spacing between internal hoops.

$A_{noConf2} = 110709.333$ is the unconfined internal core area which is equal to $b_i d_i / 6$ as defined at (A.2).

$$\phi_{psh,min} * F_{ywe} = \text{Min}(\phi_{psh,x} * F_{ywe}, \phi_{psh,y} * F_{ywe}) = 2.724$$

Expression (5.4d) for $\phi_{psh,min} * F_{ywe}$ has been multiplied by 0.3 according to 15.7.1.3 for members without earthquake detailing (90° closed stirrups)

$$\phi_{psh,x} * F_{ywe} = \phi_{psh1} * F_{ywe1} + \phi_{psh2} * F_{ywe2} = 2.724$$

$$\phi_{psh1} ((5.4d), TBDY) = L_{stir1} * A_{stir1} / (A_{sec} * s1) = 0.00301593$$

$$L_{stir1} \text{ (Length of stirrups along Y)} = 2160.00$$

$$A_{stir1} \text{ (stirrups area)} = 78.53982$$

$$\phi_{psh2} (5.4d) = L_{stir2} * A_{stir2} / (A_{sec} * s2) = 0.00056047$$

$$L_{stir2} \text{ (Length of stirrups along Y)} = 1568.00$$

$$A_{stir2} \text{ (stirrups area)} = 50.26548$$

$$\phi_{psh,y} * F_{ywe} = \phi_{psh1} * F_{ywe1} + \phi_{psh2} * F_{ywe2} = 3.25416$$

$$\phi_{psh1} ((5.4d), TBDY) = L_{stir1} * A_{stir1} / (A_{sec} * s1) = 0.00357443$$

$$L_{stir1} \text{ (Length of stirrups along X)} = 2560.00$$

$$A_{stir1} \text{ (stirrups area)} = 78.53982$$

$$\phi_{psh2} ((5.4d), TBDY) = L_{stir2} * A_{stir2} / (A_{sec} * s2) = 0.00070345$$

$$L_{stir2} \text{ (Length of stirrups along X)} = 1968.00$$

$$A_{stir2} \text{ (stirrups area)} = 50.26548$$

$$A_{sec} = 562500.00$$

$$s1 = 100.00$$

$$s2 = 250.00$$

$$f_{ywe1} = 781.25$$

$$f_{ywe2} = 656.25$$

$$f_{ce} = 30.00$$

From ((5.A.5), TBDY), TBDY: $cc = 0.002$
 $c = \text{confinement factor} = 1.00$
 $y1 = 0.0025$
 $sh1 = 0.008$
 $ft1 = 907.50$
 $fy1 = 756.25$
 $su1 = 0.032$
 using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
 and also multiplied by the shear_factor according to 15.7.1.4, with
 $\text{Shear_factor} = 1.00$
 $lo/lou,min = lb/ld = 1.00$
 $su1 = 0.4*esu1_nominal ((5.5), TBDY) = 0.032$
 From table 5A.1, TBDY: $esu1_nominal = 0.08$,
 For calculation of $esu1_nominal$ and $y1, sh1, ft1, fy1$, it is considered
 characteristic value $fsy1 = fs1/1.2$, from table 5.1, TBDY.
 $y1, sh1, ft1, fy1$, are also multiplied by $\text{Min}(1, 1.25*(lb/ld)^{2/3})$, from 10.3.5, ASCE 41-17.
 with $fs1 = (fs,jacket*Asl,ten,jacket + fs,core*Asl,ten,core)/Asl,ten = 756.25$
 with $Es1 = (Es,jacket*Asl,ten,jacket + Es,core*Asl,ten,core)/Asl,ten = 200000.00$
 $y2 = 0.0025$
 $sh2 = 0.008$
 $ft2 = 907.50$
 $fy2 = 756.25$
 $su2 = 0.032$
 using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
 and also multiplied by the shear_factor according to 15.7.1.4, with
 $\text{Shear_factor} = 1.00$
 $lo/lou,min = lb/lb,min = 1.00$
 $su2 = 0.4*esu2_nominal ((5.5), TBDY) = 0.032$
 From table 5A.1, TBDY: $esu2_nominal = 0.08$,
 For calculation of $esu2_nominal$ and $y2, sh2, ft2, fy2$, it is considered
 characteristic value $fsy2 = fs2/1.2$, from table 5.1, TBDY.
 $y1, sh1, ft1, fy1$, are also multiplied by $\text{Min}(1, 1.25*(lb/ld)^{2/3})$, from 10.3.5, ASCE 41-17.
 with $fs2 = (fs,jacket*Asl,com,jacket + fs,core*Asl,com,core)/Asl,com = 756.25$
 with $Es2 = (Es,jacket*Asl,com,jacket + Es,core*Asl,com,core)/Asl,com = 200000.00$
 $yv = 0.0025$
 $shv = 0.008$
 $ftv = 899.1522$
 $fyv = 749.2935$
 $suv = 0.032$
 using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
 and also multiplied by the shear_factor according to 15.7.1.4, with
 $\text{Shear_factor} = 1.00$
 $lo/lou,min = lb/ld = 1.00$
 $suv = 0.4*esuv_nominal ((5.5), TBDY) = 0.032$
 From table 5A.1, TBDY: $esuv_nominal = 0.08$,
 considering characteristic value $fsyv = fsv/1.2$, from table 5.1, TBDY
 For calculation of $esuv_nominal$ and yv, shv, ftv, fyv , it is considered
 characteristic value $fsyv = fsv/1.2$, from table 5.1, TBDY.
 $y1, sh1, ft1, fy1$, are also multiplied by $\text{Min}(1, 1.25*(lb/ld)^{2/3})$, from 10.3.5, ASCE 41-17.
 with $fsv = (fs,jacket*Asl,mid,jacket + fs,mid*Asl,mid,core)/Asl,mid = 749.2935$
 with $Es_v = (Es,jacket*Asl,mid,jacket + Es,mid*Asl,mid,core)/Asl,mid = 200000.00$
 $1 = Asl,ten/(b*d)*(fs1/fc) = 0.09507586$
 $2 = Asl,com/(b*d)*(fs2/fc) = 0.09507586$
 $v = Asl,mid/(b*d)*(fsv/fc) = 0.22108466$
 and confined core properties:
 $b = 390.00$
 $d = 877.00$
 $d' = 13.00$
 $fcc (5A.2, TBDY) = 30.00$
 $cc (5A.5, TBDY) = 0.002$
 $c = \text{confinement factor} = 1.00$
 $1 = Asl,ten/(b*d)*(fs1/fc) = 0.11345559$
 $2 = Asl,com/(b*d)*(fs2/fc) = 0.11345559$
 $v = Asl,mid/(b*d)*(fsv/fc) = 0.26382395$
 Case/Assumption: Unconfined full section - Steel rupture
 ' satisfies Eq. (4.3)

--->

$v < v_{s,y2}$ - LHS eq.(4.5) is not satisfied

--->

$v < v_{s,c}$ - RHS eq.(4.5) is satisfied

--->

$$s_u(4.8) = 0.28399348$$

$$M_u = M_{Rc}(4.15) = 2.6730E+009$$

$$u = s_u(4.1) = 4.9274896E-005$$

Calculation of ratio l_b/l_d

Adequate Lap Length: $l_b/l_d \geq 1$

Calculation of Shear Strength $V_r = \min(V_{r1}, V_{r2}) = 1.6349E+006$

Calculation of Shear Strength at edge 1, $V_{r1} = 1.6349E+006$

$$V_{r1} = V_{Col}((10.3), ASCE 41-17) = k_n l^* V_{ColO}$$

$$V_{ColO} = 1.6349E+006$$

$$k_n l = 1 \text{ (zero step-static loading)}$$

NOTE: In expression (10-3) ' $V_s = A_v f_y d/s$ ' is replaced by ' $V_{s+} + f^* V_f$ ' where V_f is the contribution of FRPs (11.3), ACI 440).

= 1 (normal-weight concrete)

Mean concrete strength: $f'_c = (f'_{c,jacket} \cdot Area_{jacket} + f'_{c,core} \cdot Area_{core}) / Area_{section} = 27.20$, but $f'_c^{0.5} \leq 8.3$ MPa (22.5.3.1, ACI 318-14)

$$M/Vd = 2.00$$

$$M_u = 4.16869$$

$$V_u = 5.2099631E-036$$

$$d = 0.8 \cdot h = 760.00$$

$$N_u = 20792.05$$

$$A_g = 427500.00$$

$$\text{From (11.5.4.8), ACI 318-14: } V_s = V_{s,jacket} + V_{s,core} = 1.2262E+006$$

where:

$$V_{s,jacket} = V_{s,j1} + V_{s,j2} = 1.0996E+006$$

$V_{s,j1} = 353429.174$ is calculated for section web jacket, with:

$$d = 360.00$$

$$A_v = 157079.633$$

$$f_y = 625.00$$

$$s = 100.00$$

$$V_{s,j1} \text{ is multiplied by } Col,j1 = 1.00$$

$$s/d = 0.27777778$$

$V_{s,j2} = 746128.255$ is calculated for section flange jacket, with:

$$d = 760.00$$

$$A_v = 157079.633$$

$$f_y = 625.00$$

$$s = 100.00$$

$$V_{s,j2} \text{ is multiplied by } Col,j2 = 1.00$$

$$s/d = 0.13157895$$

$$V_{s,core} = V_{s,c1} + V_{s,c2} = 126669.016$$

$V_{s,c1} = 0.00$ is calculated for section web core, with:

$$d = 200.00$$

$$A_v = 100530.965$$

$$f_y = 525.00$$

$$s = 250.00$$

$$V_{s,c1} \text{ is multiplied by } Col,c1 = 0.00$$

$$s/d = 1.25$$

$V_{s,c2} = 126669.016$ is calculated for section flange core, with:

$$d = 600.00$$

$$A_v = 100530.965$$

$$f_y = 525.00$$

$$s = 250.00$$

$$V_{s,c2} \text{ is multiplied by } Col,c2 = 1.00$$

$$s/d = 0.41666667$$

Vf ((11-3)-(11.4), ACI 440) = 0.00
From (11-11), ACI 440: $V_s + V_f \leq 1.1849E+006$
bw = 450.00

Calculation of Shear Strength at edge 2, $V_{r2} = 1.6349E+006$
 $V_{r2} = V_{Col} ((10.3), ASCE 41-17) = knl * V_{Col0}$
 $V_{Col0} = 1.6349E+006$
knl = 1 (zero step-static loading)

NOTE: In expression (10-3) ' $V_s = A_v * f_y * d / s$ ' is replaced by ' $V_s + f * V_f$ '
where V_f is the contribution of FRPs (11.3), ACI 440).

= 1 (normal-weight concrete)
Mean concrete strength: $f_c' = (f_c'_{jacket} * Area_{jacket} + f_c'_{core} * Area_{core}) / Area_{section} = 27.20$, but $f_c'^{0.5} \leq 8.3$
MPa (22.5.3.1, ACI 318-14)
 $M/Vd = 2.00$
 $\mu_u = 4.16869$
 $V_u = 5.2099631E-036$
 $d = 0.8 * h = 760.00$
 $N_u = 20792.05$
 $A_g = 427500.00$
From (11.5.4.8), ACI 318-14: $V_s = V_{sjacket} + V_{s,core} = 1.2262E+006$
where:
 $V_{sjacket} = V_{sj1} + V_{sj2} = 1.0996E+006$
 $V_{sj1} = 353429.174$ is calculated for section web jacket, with:
 $d = 360.00$
 $A_v = 157079.633$
 $f_y = 625.00$
 $s = 100.00$
 V_{sj1} is multiplied by $Col,j1 = 1.00$
 $s/d = 0.27777778$
 $V_{sj2} = 746128.255$ is calculated for section flange jacket, with:
 $d = 760.00$
 $A_v = 157079.633$
 $f_y = 625.00$
 $s = 100.00$
 V_{sj2} is multiplied by $Col,j2 = 1.00$
 $s/d = 0.13157895$
 $V_{s,core} = V_{s,c1} + V_{s,c2} = 126669.016$
 $V_{s,c1} = 0.00$ is calculated for section web core, with:
 $d = 200.00$
 $A_v = 100530.965$
 $f_y = 525.00$
 $s = 250.00$
 $V_{s,c1}$ is multiplied by $Col,c1 = 0.00$
 $s/d = 1.25$
 $V_{s,c2} = 126669.016$ is calculated for section flange core, with:
 $d = 600.00$
 $A_v = 100530.965$
 $f_y = 525.00$
 $s = 250.00$
 $V_{s,c2}$ is multiplied by $Col,c2 = 1.00$
 $s/d = 0.41666667$
 $V_f ((11-3)-(11.4), ACI 440) = 0.00$
From (11-11), ACI 440: $V_s + V_f \leq 1.1849E+006$
bw = 450.00

End Of Calculation of Shear Capacity ratio for element: column JTC1 of floor 1
At local axis: 2

Start Of Calculation of Chord Rotation Capacity for element: column JTC1 of floor 1
At local axis: 3

Integration Section: (a)

Section Type: rcjtcs

Constant Properties

Knowledge Factor, $\gamma = 0.80$

Chord Rotation is generally considered as Deformation-Controlled Action according to Table C7-1, ASCE 41-17.

Mean strengths are used for Deformation-Controlled Actions according to 7.5.1.3, ASCE 41-17

Consequently:

Jacket

New material of Secondary Member: Concrete Strength, $f_c = f_{cm} = 30.00$

New material of Secondary Member: Steel Strength, $f_s = f_{sm} = 625.00$

Concrete Elasticity, $E_c = 25742.96$

Steel Elasticity, $E_s = 200000.00$

Existing Column

Existing material of Secondary Member: Concrete Strength, $f_c = f_{cm} = 24.00$

Existing material of Secondary Member: Steel Strength, $f_s = f_{sm} = 525.00$

Concrete Elasticity, $E_c = 23025.204$

Steel Elasticity, $E_s = 200000.00$

Max Height, $H_{max} = 750.00$

Min Height, $H_{min} = 450.00$

Max Width, $W_{max} = 950.00$

Min Width, $W_{min} = 450.00$

Eccentricity, $Ecc = 250.00$

Jacket Thickness, $t_j = 100.00$

Cover Thickness, $c = 25.00$

Element Length, $L = 3000.00$

Secondary Member

Smooth Bars

Ductile Steel

Without Detailing for Earthquake Resistance (including stirrups not closed at 135°)

Longitudinal Bars With Ends Lapped Starting at the End Sections

Adequate Lap Length ($l_b/d \geq 1$)

No FRP Wrapping

Stepwise Properties

Bending Moment, $M = -1.6657E+007$

Shear Force, $V_2 = -5479.017$

Shear Force, $V_3 = -1.3008$

Axial Force, $F = -21838.055$

Longitudinal Reinforcement Area Distribution (in 2 divisions)

-Tension: $As_t = 0.00$

-Compression: $As_c = 6691.592$

Longitudinal Reinforcement Area Distribution (in 3 divisions)

-Tension: $As_{t,ten} = 1539.38$

-Compression: $As_{c,com} = 1539.38$

-Middle: $As_{mid} = 3612.832$

Longitudinal External Reinforcement Area Distribution (in 3 divisions)

-Tension: $As_{t,ten,jacket} = 1231.504$

-Compression: $As_{c,com,jacket} = 1231.504$

-Middle: $As_{mid,jacket} = 2689.203$

Longitudinal Internal Reinforcement Area Distribution (in 3 divisions)

-Tension: $As_{t,ten,core} = 307.8761$

-Compression: $As_{c,com,core} = 307.8761$

-Middle: $As_{mid,core} = 923.6282$

Mean Diameter of Tension Reinforcement, $Db_L = 16.57143$

Existing component: From table 7-7, ASCE 41_17: Final chord rotation Capacity $u_{R} = \gamma \cdot u = 0.0058986$

$u = \gamma \cdot y + p = 0.00737325$

- Calculation of γ -

$y = (M_y * L_s / 3) / E_{eff} = 0.00507429 \text{ ((4.29), Biskinis Phd)}$
 $M_y = 1.2939E+009$
 $L_s = M/V \text{ (with } L_s > 0.1 * L \text{ and } L_s < 2 * L) = 3040.138$
 From table 10.5, ASCE 41_17: $E_{eff} = \text{factor} * E_c * I_g = 2.5841E+014$
 $\text{factor} = 0.30$
 $A_g = 562500.00$
 Mean concrete strength: $f_c' = (f_c'_{\text{jacket}} * A_{\text{jacket}} + f_c'_{\text{core}} * A_{\text{core}}) / A_{\text{section}} = 27.20$
 $N = 21838.055$
 $E_c * I_g = E_{c_jacket} * I_{g_jacket} + E_{c_core} * I_{g_core} = 8.6137E+014$

Calculation of Yielding Moment M_y

Calculation of y and M_y according to Annex 7 -

$y = \text{Min}(y_{\text{ten}}, y_{\text{com}})$
 $y_{\text{ten}} = 4.4892910E-006$
 with $f_y = 601.9953$
 $d = 907.00$
 $y = 0.26077258$
 $A = 0.01648381$
 $B = 0.00867498$
 with $p_t = 0.0037716$
 $p_c = 0.0037716$
 $p_v = 0.00885172$
 $N = 21838.055$
 $b = 450.00$
 $" = 0.04740904$
 $y_{\text{comp}} = 8.8910413E-006$
 with $f_c = 30.00$
 $E_c = 25742.96$
 $y = 0.26012097$
 $A = 0.0162674$
 $B = 0.0085861$
 with $E_s = 200000.00$

Calculation of ratio I_b/I_d

Adequate Lap Length: $I_b/I_d \geq 1$

- Calculation of p -

From table 10-8: $p = 0.00229896$

with:

- Columns not controlled by inadequate development or splicing along the clear height because $I_b/I_d \geq 1$

shear control ratio $V_y E / V_{col} E = 1.08994$

$d = d_{\text{external}} = 907.00$

$s = s_{\text{external}} = 0.00$

- $t = s_1 + s_2 + 2 * t_f / b_w * (f_{fe} / f_s) = 0.00427788$

jacket: $s_1 = A_{v1} * L_{\text{stir1}} / (s_1 * A_g) = 0.00357443$

$A_{v1} = 78.53982$, is the area of every stirrup parallel to loading (shear) direction

$L_{\text{stir1}} = 2560.00$, is the total Length of all stirrups parallel to loading (shear) direction

$s_1 = 100.00$

core: $s_2 = A_{v2} * L_{\text{stir2}} / (s_2 * A_g) = 0.00070345$

$A_{v2} = 50.26548$, is the area of every stirrup parallel to loading (shear) direction

$L_{\text{stir2}} = 1968.00$, is the total Length of all stirrups parallel to loading (shear) direction

$s_2 = 250.00$

The term $2 * t_f / b_w * (f_{fe} / f_s)$ is implemented to account for FRP contribution

where $f = 2 * t_f / b_w$ is FRP ratio (EC8 - 3, A.4.4.3(6)) and f_{fe} / f_s normalises f to steel strength

All these variables have already been given in Shear control ratio calculation.

For the normalisation f_s of jacket is used.

$N_{UD} = 21838.055$


$A_g = 562500.00$

$f_{cE} = (f_{c_jacket} \cdot Area_jacket + f_{c_core} \cdot Area_core) / section_area = 27.20$
 $f_{yIE} = (f_{y_ext_Long_Reinf} \cdot Area_ext_Long_Reinf + f_{y_int_Long_Reinf} \cdot Area_int_Long_Reinf) / Area_Tot_Long_Rein = 601.9953$
 $f_{yIE} = (f_{y_ext_Trans_Reinf} \cdot s1 + f_{y_int_Trans_Reinf} \cdot s2) / (s1 + s2) = 608.5561$
 $\rho_l = Area_Tot_Long_Rein / (b \cdot d) = 0.01639493$
 $b = 450.00$
 $d = 907.00$
 $f_{cE} = 27.20$

 End Of Calculation of Chord Rotation Capacity for element: column JTC1 of floor 1
 At local axis: 3
 Integration Section: (a)

Calculation No. 5

column C1, Floor 1
 Limit State: Operational Level (data interpolation between analysis steps 1 and 2)
 Analysis: Uniform +X
 Check: Shear capacity VR_d
 Edge: End
 Local Axis: (2)



Start Of Calculation of Shear Capacity for element: column JTC1 of floor 1
 At local axis: 2
 Integration Section: (b)
 Section Type: rcjtcs

Constant Properties

 Knowledge Factor, $\gamma = 0.80$
 Member Shear Force is generally considered as Force-Controlled Action according to Table C7-1, ASCE 41-17.
 Lower-bound strengths are used for Force-Controlled Actions according to 7.5.1.3, ASCE 41-17
 Consequently:
 Jacket
 New material of Secondary Member: Concrete Strength, $f_c = f_{c_lower_bound} = 20.00$

New material of Secondary Member: Steel Strength, $f_s = f_{s_lower_bound} = 500.00$
 Concrete Elasticity, $E_c = 25742.96$
 Steel Elasticity, $E_s = 200000.00$
 Existing Column
 Existing material of Secondary Member: Concrete Strength, $f_c = f_{c_lower_bound} = 16.00$
 Existing material of Secondary Member: Steel Strength, $f_s = f_{s_lower_bound} = 420.00$
 Concrete Elasticity, $E_c = 23025.204$
 Steel Elasticity, $E_s = 200000.00$
 #####
 Note: Especially for the calculation of γ for displacement ductility demand,
 the expected (mean value) strengths are used (7.5.1.3, ASCE 41-17) because bending is considered as
 Deformation-Controlled Action (Table C7-1, ASCE 41-17).
 Jacket
 New material: Concrete Strength, $f_c = f_{cm} = 30.00$
 New material: Steel Strength, $f_s = f_{sm} = 625.00$
 Existing Column
 Existing material: Concrete Strength, $f_c = f_{cm} = 24.00$
 Existing material: Steel Strength, $f_s = f_{sm} = 525.00$
 #####
 Max Height, $H_{max} = 750.00$
 Min Height, $H_{min} = 450.00$
 Max Width, $W_{max} = 950.00$
 Min Width, $W_{min} = 450.00$
 Eccentricity, $Ecc = 250.00$
 Jacket Thickness, $t_j = 100.00$
 Cover Thickness, $c = 25.00$
 Element Length, $L = 3000.00$
 Secondary Member
 Smooth Bars
 Ductile Steel
 Without Detailing for Earthquake Resistance (including stirrups not closed at 135°)
 Longitudinal Bars With Ends Lapped Starting at the End Sections
 Adequate Lap Length ($l_o/l_{ou,min} = l_b/l_d \geq 1$)
 No FRP Wrapping

Stepwise Properties

EDGE -A-
 Bending Moment, $M_a = -1.6657E+007$
 Shear Force, $V_a = -5479.017$
 EDGE -B-
 Bending Moment, $M_b = 215890.77$
 Shear Force, $V_b = 5479.017$
 BOTH EDGES
 Axial Force, $F = -21838.055$
 Longitudinal Reinforcement Area Distribution (in 2 divisions)
 -Tension: $A_{sl,t} = 0.00$
 -Compression: $A_{sl,c} = 6691.592$
 Longitudinal Reinforcement Area Distribution (in 3 divisions)
 -Tension: $A_{sl,ten} = 1539.38$
 -Compression: $A_{sl,com} = 1539.38$
 -Middle: $A_{sl,mid} = 3612.832$
 Mean Diameter of Tension Reinforcement, $Db_{L,ten} = 16.57143$

Existing component: From table 7-7, ASCE 41_17: Final Shear Capacity $V_R = \phi V_n = 1.0687E+006$
 V_n ((10.3), ASCE 41-17) = $k_n l^* V_{CoI0} = 1.3359E+006$
 $V_{CoI} = 1.3359E+006$
 $k_n l = 1.00$
 $displacement_ductility_demand = 0.01978423$

NOTE: In expression (10-3) ' $V_s = A_v f_y d/s$ ' is replaced by ' $V_s + \phi V_f$ '
 where V_f is the contribution of FRPs (11.3), ACI 440).

= 1 (normal-weight concrete)
Mean concrete strength: $fc' = (fc'_{jacket} \cdot Area_{jacket} + fc'_{core} \cdot Area_{core}) / Area_{section} = 18.13333$, but $fc'^{0.5} \leq 8.3$ MPa (22.5.3.1, ACI 318-14)
 $M/Vd = 2.00$
 $\mu_u = 215890.77$
 $V_u = 5479.017$
 $d = 0.8 \cdot h = 760.00$
 $N_u = 21838.055$
 $A_g = 427500.00$
From (11.5.4.8), ACI 318-14: $V_s = V_{sjacket} + V_{s,core} = 980981.156$
where:
 $V_{sjacket} = V_{sj1} + V_{sj2} = 879645.943$
 $V_{sj1} = 282743.339$ is calculated for section web jacket, with:
 $d = 360.00$
 $A_v = 157079.633$
 $f_y = 500.00$
 $s = 100.00$
 V_{sj1} is multiplied by $Col,j1 = 1.00$
 $s/d = 0.27777778$
 $V_{sj2} = 596902.604$ is calculated for section flange jacket, with:
 $d = 760.00$
 $A_v = 157079.633$
 $f_y = 500.00$
 $s = 100.00$
 V_{sj2} is multiplied by $Col,j2 = 1.00$
 $s/d = 0.13157895$
 $V_{s,core} = V_{s,c1} + V_{s,c2} = 101335.213$
 $V_{s,c1} = 0.00$ is calculated for section web core, with:
 $d = 200.00$
 $A_v = 100530.965$
 $f_y = 420.00$
 $s = 250.00$
 $V_{s,c1}$ is multiplied by $Col,c1 = 0.00$
 $s/d = 1.25$
 $V_{s,c2} = 101335.213$ is calculated for section flange core, with:
 $d = 600.00$
 $A_v = 100530.965$
 $f_y = 420.00$
 $s = 250.00$
 $V_{s,c2}$ is multiplied by $Col,c2 = 1.00$
 $s/d = 0.41666667$
 $V_f ((11-3)-(11.4), ACI 440) = 0.00$
From (11-11), ACI 440: $V_s + V_f \leq 967457.029$
 $bw = 450.00$

displacement ductility demand is calculated as δ_u / y

- Calculation of δ_u / y for END B -
for rotation axis 3 and integ. section (b)

From analysis, chord rotation $\theta = 9.9065471E-006$
 $y = (M_y \cdot L_s / 3) / E_{eff} = 0.00050073$ ((4.29), Biskinis Phd))
 $M_y = 1.2939E+009$
 $L_s = M/V$ (with $L_s > 0.1 \cdot L$ and $L_s < 2 \cdot L$) = 300.00
From table 10.5, ASCE 41_17: $E_{eff} = factor \cdot E_c \cdot I_g = 2.5841E+014$
 $factor = 0.30$
 $A_g = 562500.00$
Mean concrete strength: $fc' = (fc'_{jacket} \cdot Area_{jacket} + fc'_{core} \cdot Area_{core}) / Area_{section} = 27.20$
 $N = 21838.055$
 $E_c \cdot I_g = E_{c,jacket} \cdot I_{g,jacket} + E_{c,core} \cdot I_{g,core} = 8.6137E+014$

Calculation of Yielding Moment M_y

Calculation of y and M_y according to Annex 7 -

```
y = Min( y_ten, y_com)
y_ten = 4.4892910E-006
with fy = 601.9953
d = 907.00
y = 0.26077258
A = 0.01648381
B = 0.00867498
with pt = 0.0037716
pc = 0.0037716
pv = 0.00885172
N = 21838.055
b = 450.00
" = 0.04740904
y_comp = 8.8910413E-006
with fc = 30.00
Ec = 25742.96
y = 0.26012097
A = 0.0162674
B = 0.0085861
with Es = 200000.00
```

Calculation of ratio I_b/I_d

Adequate Lap Length: $I_b/I_d \geq 1$

End Of Calculation of Shear Capacity for element: column JTC1 of floor 1

At local axis: 2

Integration Section: (b)

Calculation No. 6

column C1, Floor 1



Limit State: Operational Level (data interpolation between analysis steps 1 and 2)

Analysis: Uniform +X

Check: Chord rotation capacity (ϕ_r)

Edge: End

Local Axis: (2)



Start Of Calculation of Shear Capacity ratio for element: column JTC1 of floor 1

At Shear local axis: 3

(Bending local axis: 2)

Section Type: rcjtcs

Constant Properties

Knowledge Factor, $\gamma = 0.80$

Mean strength values are used for both shear and moment calculations.

Consequently:

Jacket

New material of Secondary Member: Concrete Strength, $f_c = f_{cm} = 30.00$

New material of Secondary Member: Steel Strength, $f_s = f_{sm} = 625.00$

Concrete Elasticity, $E_c = 25742.96$

Steel Elasticity, $E_s = 200000.00$

Existing Column

Existing material of Secondary Member: Concrete Strength, $f_c = f_{cm} = 24.00$

Existing material of Secondary Member: Steel Strength, $f_s = f_{sm} = 525.00$

Concrete Elasticity, $E_c = 23025.204$

Steel Elasticity, $E_s = 200000.00$

#####

Note: Especially for the calculation of moment strengths,

the above steel re-bar strengths are multiplied by 1.25 according to R18.6.5, ACI 318-14

Jacket

New material: Steel Strength, $f_s = 1.25 \cdot f_{sm} = 781.25$

Existing Column

Existing material: Steel Strength, $f_s = 1.25 \cdot f_{sm} = 656.25$

#####

Max Height, $H_{max} = 750.00$

Min Height, $H_{min} = 450.00$

Max Width, $W_{max} = 950.00$

Min Width, $W_{min} = 450.00$

Eccentricity, $E_{cc} = 250.00$

Jacket Thickness, $t_j = 100.00$

Cover Thickness, $c = 25.00$

Mean Confinement Factor overall section = 1.00

Element Length, $L = 3000.00$

Secondary Member

Smooth Bars

Ductile Steel

Without Detailing for Earthquake Resistance (including stirrups not closed at 135°)

Longitudinal Bars With Ends Lapped Starting at the End Sections

Adequate Lap Length ($l_o/l_{o,u,min} \geq 1$)

No FRP Wrapping

Stepwise Properties

At local axis: 3

EDGE -A-

Shear Force, $V_a = -8.5087964E-020$

EDGE -B-

Shear Force, $V_b = 8.5087964E-020$
 BOTH EDGES
 Axial Force, $F = -20792.05$
 Longitudinal Reinforcement Area Distribution (in 2 divisions)
 -Tension: $As_t = 0.00$
 -Compression: $As_c = 6691.592$
 Longitudinal Reinforcement Area Distribution (in 3 divisions)
 -Tension: $As_{t,ten} = 1539.38$
 -Compression: $As_{c,com} = 2475.575$
 -Middle: $As_{mid} = 2676.637$

Calculation of Shear Capacity ratio, $V_e/V_r = 1.11674$
 Member Controlled by Shear ($V_e/V_r > 1$)
 Calculation of Shear Demand from fig. R18.6.5, ACI 318-14 $V_e = (M_{pr1} + M_{pr2})/l_n = 1.4424E+006$
 with
 $M_{pr1} = \text{Max}(\mu_{u1+}, \mu_{u1-}) = 2.1636E+009$
 $\mu_{u1+} = 2.0419E+009$, is the ultimate moment strength at the edge 1 of the member in the actual moment direction which is defined for the static loading combination
 $\mu_{u1-} = 2.1636E+009$, is the ultimate moment strength at the edge 1 of the member in the opposite moment direction which is defined for the static loading combination
 $M_{pr2} = \text{Max}(\mu_{u2+}, \mu_{u2-}) = 2.1636E+009$
 $\mu_{u2+} = 2.0419E+009$, is the ultimate moment strength at the edge 2 of the member in the actual moment direction which is defined for the static loading combination
 $\mu_{u2-} = 2.1636E+009$, is the ultimate moment strength at the edge 2 of the member in the opposite moment direction which is defined for the static loading combination

Calculation of μ_{u1+}

Calculation of ultimate curvature ϕ_u according to 4.1, Biskinis/Fardis 2013:
 $\phi_u = 5.3321191E-005$
 $\mu_u = 2.0419E+009$

with full section properties:

$b = 950.00$
 $d = 707.00$
 $d' = 43.00$
 $v = 0.00103189$
 $N = 20792.05$
 $f_c = 30.00$
 $\phi_{co} (5A.5, TBDY) = 0.002$

Final value of ϕ_{cu} : $\phi_{cu}^* = \text{shear_factor} * \text{Max}(\phi_{cu}, \phi_{cc}) = 0.00832321$

The Shear_factor is considered equal to 1 (pure moment strength)

From (5.4b), TBDY: $\phi_{cu} = 0.00832321$

we (5.4c) = 0.01453958

$\phi_{ase} ((5.4d), TBDY) = (\phi_{ase1} * A_{ext} + \phi_{ase2} * A_{int}) / A_{sec} = 0.53375773$

$\phi_{ase1} = \text{Max}(((A_{conf,max1} - A_{noConf1}) / A_{conf,max1}) * (A_{conf,min1} / A_{conf,max1}), 0) = 0.53375773$

The definitions of A_{noConf} , $A_{conf,min}$ and $A_{conf,max}$ are derived from generalization of the rectangular sections confinement, which is expressed by (5.4d).

The generalization is done according to Mander, J., Priestley, M., and Park, R. (1988)

"Theoretical Stress-Strain Model for Confined Concrete."

J. Struct. Eng., 10.1061/(ASCE)0733-9445(1988)114:8(1804), 1804-1826.

$A_{conf,max1} = 464100.00$ is the confined core area at levels of member with hoops and is calculated as the area of core enclosed by the center lines of the external perimeter hoops.

$A_{conf,min1} = 395025.00$ is the confined core area at midway between the levels of hoops and is calculated by reducing all the dimensions of the area $A_{conf,max1}$ by a length equal to half the clear spacing between external hoops.

$A_{noConf1} = 173066.667$ is the unconfined external core area which is equal to $b_i^2/6$ as defined at (A.2).

$\phi_{ase2} (>= \phi_{ase1}) = \text{Max}(((A_{conf,max2} - A_{noConf2}) / A_{conf,max2}) * (A_{conf,min2} / A_{conf,max2}), 0) = 0.53375773$

The definitions of A_{noConf} , $A_{conf,min}$ and $A_{conf,max}$ are derived from generalization of the rectangular sections confinement, which is expressed by (5.4d).

The generalization is done according to Mander, J., Priestley, M., and Park, R. (1988)

"Theoretical Stress-Strain Model for Confined Concrete."

J. Struct. Eng., 10.1061/(ASCE)0733-9445(1988)114:8(1804), 1804-1826.

$A_{conf,max2} = 252164.00$ is the confined core area at levels of member with hoops and is calculated as the area of core enclosed by the center lines of the internal perimeter hoops.
 $A_{conf,min2} = 111441.00$ is the confined core area at midway between the levels of hoops and is calculated by reducing all the dimensions of the area $A_{conf,max2}$ by a length equal to half the clear spacing between internal hoops.

$A_{noConf2} = 110709.333$ is the unconfined internal core area which is equal to $b_i^2/6$ as defined at (A.2).

$p_{sh,min} \cdot F_{ywe} = \text{Min}(p_{sh,x} \cdot F_{ywe}, p_{sh,y} \cdot F_{ywe}) = 2.724$

Expression (5.4d) for $p_{sh,min} \cdot F_{ywe}$ has been multiplied by 0.3 according to 15.7.1.3 for members without earthquake detailing (90° closed stirrups)

$p_{sh,x} \cdot F_{ywe} = p_{sh1} \cdot F_{ywe1} + p_{s2} \cdot F_{ywe2} = 2.724$

p_{sh1} ((5.4d), TBDY) = $L_{stir1} \cdot A_{stir1} / (A_{sec} \cdot s1) = 0.00301593$

L_{stir1} (Length of stirrups along Y) = 2160.00

A_{stir1} (stirrups area) = 78.53982

p_{s2} (5.4d) = $L_{stir2} \cdot A_{stir2} / (A_{sec} \cdot s2) = 0.00056047$

L_{stir2} (Length of stirrups along Y) = 1568.00

A_{stir2} (stirrups area) = 50.26548

$p_{sh,y} \cdot F_{ywe} = p_{sh1} \cdot F_{ywe1} + p_{s2} \cdot F_{ywe2} = 3.25416$

p_{sh1} ((5.4d), TBDY) = $L_{stir1} \cdot A_{stir1} / (A_{sec} \cdot s1) = 0.00357443$

L_{stir1} (Length of stirrups along X) = 2560.00

A_{stir1} (stirrups area) = 78.53982

p_{s2} ((5.4d), TBDY) = $L_{stir2} \cdot A_{stir2} / (A_{sec} \cdot s2) = 0.00070345$

L_{stir2} (Length of stirrups along X) = 1968.00

A_{stir2} (stirrups area) = 50.26548

$A_{sec} = 562500.00$

$s1 = 100.00$

$s2 = 250.00$

$f_{ywe1} = 781.25$

$f_{ywe2} = 656.25$

$f_{ce} = 30.00$

From ((5.A5), TBDY), TBDY: $cc = 0.002$

c = confinement factor = 1.00

$y1 = 0.0025$

$sh1 = 0.008$

$ft1 = 907.50$

$fy1 = 756.25$

$su1 = 0.032$

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor and also multiplied by the shear_factor according to 15.7.1.4, with Shear_factor = 1.00

$l_o/l_{ou,min} = l_b/l_d = 1.00$

$su1 = 0.4 \cdot esu1_{nominal}$ ((5.5), TBDY) = 0.032

From table 5A.1, TBDY: $esu1_{nominal} = 0.08$,

For calculation of $esu1_{nominal}$ and $y1, sh1, ft1, fy1$, it is considered characteristic value $fsy1 = fs1/1.2$, from table 5.1, TBDY.

$y1, sh1, ft1, fy1$, are also multiplied by $\text{Min}(1, 1.25 \cdot (l_b/l_d)^{2/3})$, from 10.3.5, ASCE 41-17.

with $fs1 = (f_{s,jacket} \cdot A_{sl,ten,jacket} + f_{s,core} \cdot A_{sl,ten,core}) / A_{sl,ten} = 756.25$

with $Es1 = (E_{s,jacket} \cdot A_{sl,ten,jacket} + E_{s,core} \cdot A_{sl,ten,core}) / A_{sl,ten} = 200000.00$

$y2 = 0.0025$

$sh2 = 0.008$

$ft2 = 900.1904$

$fy2 = 750.1586$

$su2 = 0.032$

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor and also multiplied by the shear_factor according to 15.7.1.4, with Shear_factor = 1.00

$l_o/l_{ou,min} = l_b/l_{b,min} = 1.00$

$su2 = 0.4 \cdot esu2_{nominal}$ ((5.5), TBDY) = 0.032

From table 5A.1, TBDY: $esu2_{nominal} = 0.08$,

For calculation of $esu2_{nominal}$ and $y2, sh2, ft2, fy2$, it is considered characteristic value $fsy2 = fs2/1.2$, from table 5.1, TBDY.

$y1, sh1, ft1, fy1$, are also multiplied by $\text{Min}(1, 1.25 \cdot (l_b/l_d)^{2/3})$, from 10.3.5, ASCE 41-17.

with $fs2 = (f_{s,jacket} \cdot A_{sl,com,jacket} + f_{s,core} \cdot A_{sl,com,core}) / A_{sl,com} = 750.1586$

```

with Es2 = (Es,jacket*Asl,com,jacket + Es,core*Asl,com,core)/Asl,com = 200000.00
yv = 0.0025
shv = 0.008
ftv = 902.993
fyv = 752.4941
suv = 0.032
using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00
lo/lou,min = lb/d = 1.00
suv = 0.4*esuv_nominal ((5.5), TBDY) = 0.032
From table 5A.1, TBDY: esuv_nominal = 0.08,
considering characteristic value fsyv = fsv/1.2, from table 5.1, TBDY
For calculation of esuv_nominal and yv, shv,ftv,fyv, it is considered
characteristic value fsyv = fsv/1.2, from table 5.1, TBDY.
y1, sh1,ft1,fy1, are also multiplied by Min(1,1.25*(lb/d)^2/3), from 10.3.5, ASCE 41-17.
with fsv = (fs,jacket*Asl,mid,jacket + fs,mid*Asl,mid,core)/Asl,mid = 752.4941
with Esv = (Es,jacket*Asl,mid,jacket + Es,mid*Asl,mid,core)/Asl,mid = 200000.00
1 = Asl,ten/(b*d)*(fs1/fc) = 0.05777595
2 = Asl,com/(b*d)*(fs2/fc) = 0.09216477
v = Asl,mid/(b*d)*(fsv/fc) = 0.09996047
and confined core properties:
b = 890.00
d = 677.00
d' = 13.00
fcc (5A.2, TBDY) = 30.00
cc (5A.5, TBDY) = 0.002
c = confinement factor = 1.00
1 = Asl,ten/(b*d)*(fs1/fc) = 0.06440379
2 = Asl,com/(b*d)*(fs2/fc) = 0.10273757
v = Asl,mid/(b*d)*(fsv/fc) = 0.11142757
Case/Assumption: Unconfined full section - Steel rupture
'satisfies Eq. (4.3)
--->
v < vs,y2 - LHS eq.(4.5) is not satisfied
--->
v < vs,c - RHS eq.(4.5) is satisfied
--->
su (4.8) = 0.15115045
Mu = MRc (4.15) = 2.0419E+009
u = su (4.1) = 5.3321191E-005

```

Calculation of ratio lb/d

Adequate Lap Length: lb/d >= 1

Calculation of Mu1-

Calculation of ultimate curvature u according to 4.1, Biskinis/Fardis 2013:

u = 6.8287974E-005
Mu = 2.1636E+009

with full section properties:

b = 450.00
d = 707.00
d' = 43.00
v = 0.00217843
N = 20792.05
fc = 30.00
co (5A.5, TBDY) = 0.002
Final value of cu: cu* = shear_factor * Max(cu, cc) = 0.00832321
The Shear_factor is considered equal to 1 (pure moment strength)

From (5.4b), TBDY: $c_u = 0.00832321$

w_e (5.4c) = 0.01453958

a_{se} ((5.4d), TBDY) = $(a_{se1} \cdot A_{ext} + a_{se2} \cdot A_{int}) / A_{sec} = 0.53375773$

$a_{se1} = \text{Max}(((A_{conf,max1} - A_{noConf1}) / A_{conf,max1}) \cdot (A_{conf,min1} / A_{conf,max1}), 0) = 0.53375773$

The definitions of A_{noConf} , $A_{conf,min}$ and $A_{conf,max}$ are derived from generalization of the rectangular sections confinement, which is expressed by (5.4d).

The generalization is done according to Mander, J., Priestley, M., and Park, R. (1988)

"Theoretical Stress-Strain Model for Confined Concrete."

J. Struct. Eng., 10.1061/(ASCE)0733-9445(1988)114:8(1804), 1804-1826.

$A_{conf,max1} = 464100.00$ is the confined core area at levels of member with hoops and

is calculated as the area of core enclosed by the center lines of the external perimeter hoops.

$A_{conf,min1} = 395025.00$ is the confined core area at midway between the levels of hoops and

is calculated by reducing all the dimensions of the area $A_{conf,max1}$ by a length

equal to half the clear spacing between external hoops.

$A_{noConf1} = 173066.667$ is the unconfined external core area which is equal to $b_i^2/6$ as defined at (A.2).

$a_{se2} (>= a_{se1}) = \text{Max}(((A_{conf,max2} - A_{noConf2}) / A_{conf,max2}) \cdot (A_{conf,min2} / A_{conf,max2}), 0) = 0.53375773$

The definitions of A_{noConf} , $A_{conf,min}$ and $A_{conf,max}$ are derived from generalization of the rectangular sections confinement, which is expressed by (5.4d).

The generalization is done according to Mander, J., Priestley, M., and Park, R. (1988)

"Theoretical Stress-Strain Model for Confined Concrete."

J. Struct. Eng., 10.1061/(ASCE)0733-9445(1988)114:8(1804), 1804-1826.

$A_{conf,max2} = 252164.00$ is the confined core area at levels of member with hoops and

is calculated as the area of core enclosed by the center lines of the internal perimeter hoops.

$A_{conf,min2} = 111441.00$ is the confined core area at midway between the levels of hoops and

is calculated by reducing all the dimensions of the area $A_{conf,max2}$ by a length

equal to half the clear spacing between internal hoops.

$A_{noConf2} = 110709.333$ is the unconfined internal core area which is equal to $b_i^2/6$ as defined at (A.2).

$p_{sh,min} \cdot F_{ywe} = \text{Min}(p_{sh,x} \cdot F_{ywe}, p_{sh,y} \cdot F_{ywe}) = 2.724$

Expression (5.4d) for $p_{sh,min} \cdot F_{ywe}$ has been multiplied by 0.3 according to 15.7.1.3 for members without earthquake detailing (90° closed stirrups)

$p_{sh,x} \cdot F_{ywe} = p_{sh1} \cdot F_{ywe1} + p_{s2} \cdot F_{ywe2} = 2.724$

p_{sh1} ((5.4d), TBDY) = $L_{stir1} \cdot A_{stir1} / (A_{sec} \cdot s_1) = 0.00301593$

L_{stir1} (Length of stirrups along Y) = 2160.00

A_{stir1} (stirrups area) = 78.53982

p_{sh2} (5.4d) = $L_{stir2} \cdot A_{stir2} / (A_{sec} \cdot s_2) = 0.00056047$

L_{stir2} (Length of stirrups along Y) = 1568.00

A_{stir2} (stirrups area) = 50.26548

$p_{sh,y} \cdot F_{ywe} = p_{sh1} \cdot F_{ywe1} + p_{s2} \cdot F_{ywe2} = 3.25416$

p_{sh1} ((5.4d), TBDY) = $L_{stir1} \cdot A_{stir1} / (A_{sec} \cdot s_1) = 0.00357443$

L_{stir1} (Length of stirrups along X) = 2560.00

A_{stir1} (stirrups area) = 78.53982

p_{sh2} ((5.4d), TBDY) = $L_{stir2} \cdot A_{stir2} / (A_{sec} \cdot s_2) = 0.00070345$

L_{stir2} (Length of stirrups along X) = 1968.00

A_{stir2} (stirrups area) = 50.26548

$A_{sec} = 562500.00$

$s_1 = 100.00$

$s_2 = 250.00$

$f_{ywe1} = 781.25$

$f_{ywe2} = 656.25$

$f_{ce} = 30.00$

From ((5.A5), TBDY), TBDY: $c_c = 0.002$

c = confinement factor = 1.00

$y_1 = 0.0025$

$sh_1 = 0.008$

$ft_1 = 900.1904$

$fy_1 = 750.1586$

$su_1 = 0.032$

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor

and also multiplied by the shear_factor according to 15.7.1.4, with

Shear_factor = 1.00

$l_o/l_{ou,min} = l_b/l_d = 1.00$

$su_1 = 0.4 \cdot esu_{1,nominal}$ ((5.5), TBDY) = 0.032

From table 5A.1, TBDY: $esu_{1,nominal} = 0.08$,

For calculation of $esu_{1,nominal}$ and y_1, sh_1, ft_1, fy_1 , it is considered

characteristic value $f_{sy1} = f_{s1}/1.2$, from table 5.1, TBDY.
 $y1, sh1, ft1, fy1$, are also multiplied by $\text{Min}(1, 1.25 \cdot (l_b/l_d)^{2/3})$, from 10.3.5, ASCE 41-17.
with $f_{s1} = (f_{sjacket} \cdot A_{s,ten,jacket} + f_{s,core} \cdot A_{s,ten,core})/A_{s,ten} = 750.1586$
with $E_{s1} = (E_{sjacket} \cdot A_{s,ten,jacket} + E_{s,core} \cdot A_{s,ten,core})/A_{s,ten} = 200000.00$
 $y2 = 0.0025$
 $sh2 = 0.008$
 $ft2 = 907.50$
 $fy2 = 756.25$
 $su2 = 0.032$
using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00
 $l_o/l_{o,min} = l_b/l_{b,min} = 1.00$
 $su2 = 0.4 \cdot esu2_nominal \text{ ((5.5), TBDY)} = 0.032$
From table 5A.1, TBDY: $esu2_nominal = 0.08$,
For calculation of $esu2_nominal$ and $y2, sh2, ft2, fy2$, it is considered
characteristic value $f_{sy2} = f_{s2}/1.2$, from table 5.1, TBDY.
 $y1, sh1, ft1, fy1$, are also multiplied by $\text{Min}(1, 1.25 \cdot (l_b/l_d)^{2/3})$, from 10.3.5, ASCE 41-17.
with $f_{s2} = (f_{sjacket} \cdot A_{s,com,jacket} + f_{s,core} \cdot A_{s,com,core})/A_{s,com} = 756.25$
with $E_{s2} = (E_{sjacket} \cdot A_{s,com,jacket} + E_{s,core} \cdot A_{s,com,core})/A_{s,com} = 200000.00$
 $yv = 0.0025$
 $shv = 0.008$
 $ftv = 902.993$
 $fyv = 752.4941$
 $suv = 0.032$
using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00
 $l_o/l_{o,min} = l_b/l_d = 1.00$
 $suv = 0.4 \cdot esuv_nominal \text{ ((5.5), TBDY)} = 0.032$
From table 5A.1, TBDY: $esuv_nominal = 0.08$,
considering characteristic value $f_{syv} = f_{sv}/1.2$, from table 5.1, TBDY
For calculation of $esuv_nominal$ and yv, shv, ftv, fyv , it is considered
characteristic value $f_{syv} = f_{sv}/1.2$, from table 5.1, TBDY.
 $y1, sh1, ft1, fy1$, are also multiplied by $\text{Min}(1, 1.25 \cdot (l_b/l_d)^{2/3})$, from 10.3.5, ASCE 41-17.
with $f_{sv} = (f_{sjacket} \cdot A_{s,mid,jacket} + f_{s,mid} \cdot A_{s,mid,core})/A_{s,mid} = 752.4941$
with $E_{sv} = (E_{sjacket} \cdot A_{s,mid,jacket} + E_{s,mid} \cdot A_{s,mid,core})/A_{s,mid} = 200000.00$
 $1 = A_{s,ten}/(b \cdot d) \cdot (f_{s1}/f_c) = 0.19457006$
 $2 = A_{s,com}/(b \cdot d) \cdot (f_{s2}/f_c) = 0.12197144$
 $v = A_{s,mid}/(b \cdot d) \cdot (f_{sv}/f_c) = 0.21102767$

and confined core properties:

$b = 390.00$
 $d = 677.00$
 $d' = 13.00$
 $f_{cc} \text{ (5A.2, TBDY)} = 30.00$
 $cc \text{ (5A.5, TBDY)} = 0.002$
 $c = \text{confinement factor} = 1.00$
 $1 = A_{s,ten}/(b \cdot d) \cdot (f_{s1}/f_c) = 0.23445239$
 $2 = A_{s,com}/(b \cdot d) \cdot (f_{s2}/f_c) = 0.14697275$
 $v = A_{s,mid}/(b \cdot d) \cdot (f_{sv}/f_c) = 0.25428343$

Case/Assumption: Unconfined full section - Steel rupture

' satisfies Eq. (4.3)

--->

$v < v_{s,y2}$ - LHS eq.(4.5) is not satisfied

--->

$v < v_{s,c}$ - RHS eq.(4.5) is satisfied

--->

$su \text{ (4.8)} = 0.33719414$

$Mu = MRc \text{ (4.15)} = 2.1636E+009$

$u = su \text{ (4.1)} = 6.8287974E-005$

Calculation of ratio l_b/l_d

Adequate Lap Length: $l_b/l_d \geq 1$

Calculation of Mu2+

Calculation of ultimate curvature μ according to 4.1, Biskinis/Fardis 2013:

$$\mu = 5.3321191E-005$$

$$Mu = 2.0419E+009$$

with full section properties:

$$b = 950.00$$

$$d = 707.00$$

$$d' = 43.00$$

$$v = 0.00103189$$

$$N = 20792.05$$

$$f_c = 30.00$$

$$co(5A.5, TBDY) = 0.002$$

$$\text{Final value of } \mu: \mu^* = \text{shear_factor} * \text{Max}(\mu, co) = 0.00832321$$

The Shear_factor is considered equal to 1 (pure moment strength)

$$\text{From (5.4b), TBDY: } \mu = 0.00832321$$

$$\mu_e(5.4c) = 0.01453958$$

$$ase((5.4d), TBDY) = (ase1 * A_{ext} + ase2 * A_{int}) / A_{sec} = 0.53375773$$

$$ase1 = \text{Max}(((A_{conf,max1} - A_{noConf1}) / A_{conf,max1}) * (A_{conf,min1} / A_{conf,max1}), 0) = 0.53375773$$

The definitions of A_{noConf} , $A_{conf,min}$ and $A_{conf,max}$ are derived from generalization of the rectangular sections confinement, which is expressed by (5.4d).

The generalization is done according to Mander, J., Priestley, M., and Park, R. (1988)

"Theoretical Stress-Strain Model for Confined Concrete."

J. Struct. Eng., 10.1061/(ASCE)0733-9445(1988)114:8(1804), 1804-1826.

$A_{conf,max1} = 464100.00$ is the confined core area at levels of member with hoops and is calculated as the area of core enclosed by the center lines of the external perimeter hoops.

$A_{conf,min1} = 395025.00$ is the confined core area at midway between the levels of hoops and is calculated by reducing all the dimensions of the area $A_{conf,max1}$ by a length equal to half the clear spacing between external hoops.

$A_{noConf1} = 173066.667$ is the unconfined external core area which is equal to $b_i^2/6$ as defined at (A.2).

$$ase2 (>= ase1) = \text{Max}(((A_{conf,max2} - A_{noConf2}) / A_{conf,max2}) * (A_{conf,min2} / A_{conf,max2}), 0) = 0.53375773$$

The definitions of A_{noConf} , $A_{conf,min}$ and $A_{conf,max}$ are derived from generalization of the rectangular sections confinement, which is expressed by (5.4d).

The generalization is done according to Mander, J., Priestley, M., and Park, R. (1988)

"Theoretical Stress-Strain Model for Confined Concrete."

J. Struct. Eng., 10.1061/(ASCE)0733-9445(1988)114:8(1804), 1804-1826.

$A_{conf,max2} = 252164.00$ is the confined core area at levels of member with hoops and is calculated as the area of core enclosed by the center lines of the internal perimeter hoops.

$A_{conf,min2} = 111441.00$ is the confined core area at midway between the levels of hoops and is calculated by reducing all the dimensions of the area $A_{conf,max2}$ by a length equal to half the clear spacing between internal hoops.

$A_{noConf2} = 110709.333$ is the unconfined internal core area which is equal to $b_i^2/6$ as defined at (A.2).

$$psh_{min} * F_{ywe} = \text{Min}(psh_x * F_{ywe}, psh_y * F_{ywe}) = 2.724$$

Expression (5.4d) for $psh_{min} * F_{ywe}$ has been multiplied by 0.3 according to 15.7.1.3 for members without earthquake detailing (90° closed stirrups)

$$psh_x * F_{ywe} = psh1 * F_{ywe1} + ps2 * F_{ywe2} = 2.724$$

$$psh1((5.4d), TBDY) = L_{stir1} * A_{stir1} / (A_{sec} * s1) = 0.00301593$$

$$L_{stir1} \text{ (Length of stirrups along Y)} = 2160.00$$

$$A_{stir1} \text{ (stirrups area)} = 78.53982$$

$$psh2(5.4d) = L_{stir2} * A_{stir2} / (A_{sec} * s2) = 0.00056047$$

$$L_{stir2} \text{ (Length of stirrups along Y)} = 1568.00$$

$$A_{stir2} \text{ (stirrups area)} = 50.26548$$

$$psh_y * F_{ywe} = psh1 * F_{ywe1} + ps2 * F_{ywe2} = 3.25416$$

$$psh1((5.4d), TBDY) = L_{stir1} * A_{stir1} / (A_{sec} * s1) = 0.00357443$$

$$L_{stir1} \text{ (Length of stirrups along X)} = 2560.00$$

$$A_{stir1} \text{ (stirrups area)} = 78.53982$$

$$psh2((5.4d), TBDY) = L_{stir2} * A_{stir2} / (A_{sec} * s2) = 0.00070345$$

$$L_{stir2} \text{ (Length of stirrups along X)} = 1968.00$$

$$A_{stir2} \text{ (stirrups area)} = 50.26548$$

$$A_{sec} = 562500.00$$

$s1 = 100.00$
 $s2 = 250.00$
 $fyw1 = 781.25$
 $fyw2 = 656.25$
 $fce = 30.00$
 From ((5.A.5), TBDY), TBDY: $cc = 0.002$
 $c = \text{confinement factor} = 1.00$
 $y1 = 0.0025$
 $sh1 = 0.008$
 $ft1 = 907.50$
 $fy1 = 756.25$
 $su1 = 0.032$
 using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
 and also multiplied by the shear_factor according to 15.7.1.4, with
 $\text{Shear_factor} = 1.00$
 $lo/lou, \min = lb/ld = 1.00$
 $su1 = 0.4 * esu1_nominal ((5.5), TBDY) = 0.032$
 From table 5A.1, TBDY: $esu1_nominal = 0.08$,
 For calculation of $esu1_nominal$ and $y1, sh1, ft1, fy1$, it is considered
 characteristic value $fsy1 = fs1/1.2$, from table 5.1, TBDY.
 $y1, sh1, ft1, fy1$, are also multiplied by $\text{Min}(1, 1.25 * (lb/ld)^{2/3})$, from 10.3.5, ASCE 41-17.
 with $fs1 = (fs_jacket * Asl, \text{ten}, \text{jacket} + fs_core * Asl, \text{ten}, \text{core}) / Asl, \text{ten} = 756.25$
 with $Es1 = (Es_jacket * Asl, \text{ten}, \text{jacket} + Es_core * Asl, \text{ten}, \text{core}) / Asl, \text{ten} = 200000.00$
 $y2 = 0.0025$
 $sh2 = 0.008$
 $ft2 = 900.1904$
 $fy2 = 750.1586$
 $su2 = 0.032$
 using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
 and also multiplied by the shear_factor according to 15.7.1.4, with
 $\text{Shear_factor} = 1.00$
 $lo/lou, \min = lb/lb, \min = 1.00$
 $su2 = 0.4 * esu2_nominal ((5.5), TBDY) = 0.032$
 From table 5A.1, TBDY: $esu2_nominal = 0.08$,
 For calculation of $esu2_nominal$ and $y2, sh2, ft2, fy2$, it is considered
 characteristic value $fsy2 = fs2/1.2$, from table 5.1, TBDY.
 $y1, sh1, ft1, fy1$, are also multiplied by $\text{Min}(1, 1.25 * (lb/ld)^{2/3})$, from 10.3.5, ASCE 41-17.
 with $fs2 = (fs_jacket * Asl, \text{com}, \text{jacket} + fs_core * Asl, \text{com}, \text{core}) / Asl, \text{com} = 750.1586$
 with $Es2 = (Es_jacket * Asl, \text{com}, \text{jacket} + Es_core * Asl, \text{com}, \text{core}) / Asl, \text{com} = 200000.00$
 $yv = 0.0025$
 $shv = 0.008$
 $ftv = 902.993$
 $fyv = 752.4941$
 $suv = 0.032$
 using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
 and also multiplied by the shear_factor according to 15.7.1.4, with
 $\text{Shear_factor} = 1.00$
 $lo/lou, \min = lb/ld = 1.00$
 $suv = 0.4 * esuv_nominal ((5.5), TBDY) = 0.032$
 From table 5A.1, TBDY: $esuv_nominal = 0.08$,
 considering characteristic value $fsyv = fsv/1.2$, from table 5.1, TBDY
 For calculation of $esuv_nominal$ and yv, shv, ftv, fyv , it is considered
 characteristic value $fsyv = fsv/1.2$, from table 5.1, TBDY.
 $y1, sh1, ft1, fy1$, are also multiplied by $\text{Min}(1, 1.25 * (lb/ld)^{2/3})$, from 10.3.5, ASCE 41-17.
 with $fsv = (fs_jacket * Asl, \text{mid}, \text{jacket} + fs_mid * Asl, \text{mid}, \text{core}) / Asl, \text{mid} = 752.4941$
 with $Es_v = (Es_jacket * Asl, \text{mid}, \text{jacket} + Es_mid * Asl, \text{mid}, \text{core}) / Asl, \text{mid} = 200000.00$
 $1 = Asl, \text{ten} / (b * d) * (fs1 / fc) = 0.05777595$
 $2 = Asl, \text{com} / (b * d) * (fs2 / fc) = 0.09216477$
 $v = Asl, \text{mid} / (b * d) * (fsv / fc) = 0.09996047$
 and confined core properties:
 $b = 890.00$
 $d = 677.00$
 $d' = 13.00$
 $fcc (5A.2, TBDY) = 30.00$
 $cc (5A.5, TBDY) = 0.002$
 $c = \text{confinement factor} = 1.00$
 $1 = Asl, \text{ten} / (b * d) * (fs1 / fc) = 0.06440379$

$$2 = A_{sl,com}/(b*d)*(f_{s2}/f_c) = 0.10273757$$

$$v = A_{sl,mid}/(b*d)*(f_{sv}/f_c) = 0.11142757$$

Case/Assumption: Unconfined full section - Steel rupture

' satisfies Eq. (4.3)

---->

$v < v_{s,y2}$ - LHS eq.(4.5) is not satisfied

---->

$v < v_{s,c}$ - RHS eq.(4.5) is satisfied

---->

$$s_u(4.8) = 0.15115045$$

$$\mu_u = M_{Rc}(4.15) = 2.0419E+009$$

$$u = s_u(4.1) = 5.3321191E-005$$

Calculation of ratio l_b/d

Adequate Lap Length: $l_b/d \geq 1$

Calculation of μ_{u2} -

Calculation of ultimate curvature μ_u according to 4.1, Biskinis/Fardis 2013:

$$u = 6.8287974E-005$$

$$\mu_u = 2.1636E+009$$

with full section properties:

$$b = 450.00$$

$$d = 707.00$$

$$d' = 43.00$$

$$v = 0.00217843$$

$$N = 20792.05$$

$$f_c = 30.00$$

$$\alpha_{co}(5A.5, TBDY) = 0.002$$

$$\text{Final value of } \alpha_{cu}: \alpha_{cu}^* = \text{shear_factor} * \text{Max}(\alpha_{cu}, \alpha_{cc}) = 0.00832321$$

The Shear_factor is considered equal to 1 (pure moment strength)

$$\text{From (5.4b), TBDY: } \alpha_{cu} = 0.00832321$$

$$\alpha_{we}(5.4c) = 0.01453958$$

$$\alpha_{ase}((5.4d), TBDY) = (\alpha_{ase1} * A_{ext} + \alpha_{ase2} * A_{int}) / A_{sec} = 0.53375773$$

$$\alpha_{ase1} = \text{Max}(((A_{conf,max1} - A_{noConf1}) / A_{conf,max1}) * (A_{conf,min1} / A_{conf,max1}), 0) = 0.53375773$$

The definitions of A_{noConf} , $A_{conf,min}$ and $A_{conf,max}$ are derived from generalization of the rectangular sections confinement, which is expressed by (5.4d).

The generalization is done according to Mander, J., Priestley, M., and Park, R. (1988)

"Theoretical Stress-Strain Model for Confined Concrete."

J. Struct. Eng., 10.1061/(ASCE)0733-9445(1988)114:8(1804), 1804-1826.

$A_{conf,max1} = 464100.00$ is the confined core area at levels of member with hoops and is calculated as the area of core enclosed by the center lines of the external perimeter hoops.

$A_{conf,min1} = 395025.00$ is the confined core area at midway between the levels of hoops and is calculated by reducing all the dimensions of the area $A_{conf,max1}$ by a length equal to half the clear spacing between external hoops.

$A_{noConf1} = 173066.667$ is the unconfined external core area which is equal to $b_i^2/6$ as defined at (A.2).

$$\alpha_{ase2}(\geq \alpha_{ase1}) = \text{Max}(((A_{conf,max2} - A_{noConf2}) / A_{conf,max2}) * (A_{conf,min2} / A_{conf,max2}), 0) = 0.53375773$$

The definitions of A_{noConf} , $A_{conf,min}$ and $A_{conf,max}$ are derived from generalization of the rectangular sections confinement, which is expressed by (5.4d).

The generalization is done according to Mander, J., Priestley, M., and Park, R. (1988)

"Theoretical Stress-Strain Model for Confined Concrete."

J. Struct. Eng., 10.1061/(ASCE)0733-9445(1988)114:8(1804), 1804-1826.

$A_{conf,max2} = 252164.00$ is the confined core area at levels of member with hoops and is calculated as the area of core enclosed by the center lines of the internal perimeter hoops.

$A_{conf,min2} = 111441.00$ is the confined core area at midway between the levels of hoops and is calculated by reducing all the dimensions of the area $A_{conf,max2}$ by a length equal to half the clear spacing between internal hoops.

$A_{noConf2} = 110709.333$ is the unconfined internal core area which is equal to $b_i^2/6$ as defined at (A.2).

$$p_{sh,min} * F_{ywe} = \text{Min}(p_{sh,x} * F_{ywe}, p_{sh,y} * F_{ywe}) = 2.724$$

Expression (5.4d) for $p_{sh,min} * F_{ywe}$ has been multiplied by 0.3 according to 15.7.1.3 for members without

earthquake detailing (90° closed stirrups)

psh_x*Fywe = psh1*Fywe1+ps2*Fywe2 = 2.724
psh1 ((5.4d), TBDY) = Lstir1*Astir1/(Asec*s1) = 0.00301593
Lstir1 (Length of stirrups along Y) = 2160.00
Astir1 (stirrups area) = 78.53982
psh2 (5.4d) = Lstir2*Astir2/(Asec*s2) = 0.00056047
Lstir2 (Length of stirrups along Y) = 1568.00
Astir2 (stirrups area) = 50.26548

psh_y*Fywe = psh1*Fywe1+ps2*Fywe2 = 3.25416
psh1 ((5.4d), TBDY) = Lstir1*Astir1/(Asec*s1) = 0.00357443
Lstir1 (Length of stirrups along X) = 2560.00
Astir1 (stirrups area) = 78.53982
psh2 ((5.4d), TBDY) = Lstir2*Astir2/(Asec*s2) = 0.00070345
Lstir2 (Length of stirrups along X) = 1968.00
Astir2 (stirrups area) = 50.26548

Asec = 562500.00

s1 = 100.00

s2 = 250.00

fywe1 = 781.25

fywe2 = 656.25

fce = 30.00

From ((5.A5), TBDY), TBDY: cc = 0.002

c = confinement factor = 1.00

y1 = 0.0025

sh1 = 0.008

ft1 = 900.1904

fy1 = 750.1586

su1 = 0.032

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00

lo/lou,min = lb/d = 1.00

su1 = 0.4*esu1_nominal ((5.5), TBDY) = 0.032

From table 5A.1, TBDY: esu1_nominal = 0.08,

For calculation of esu1_nominal and y1, sh1,ft1,fy1, it is considered
characteristic value fsy1 = fs1/1.2, from table 5.1, TBDY.

y1, sh1,ft1,fy1, are also multiplied by $\text{Min}(1, 1.25 \cdot (lb/d)^{2/3})$, from 10.3.5, ASCE 41-17.

with fs1 = (fs,jacket*Asl,ten,jacket + fs,core*Asl,ten,core)/Asl,ten = 750.1586

with Es1 = (Es,jacket*Asl,ten,jacket + Es,core*Asl,ten,core)/Asl,ten = 200000.00

y2 = 0.0025

sh2 = 0.008

ft2 = 907.50

fy2 = 756.25

su2 = 0.032

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00

lo/lou,min = lb/lb,min = 1.00

su2 = 0.4*esu2_nominal ((5.5), TBDY) = 0.032

From table 5A.1, TBDY: esu2_nominal = 0.08,

For calculation of esu2_nominal and y2, sh2,ft2,fy2, it is considered
characteristic value fsy2 = fs2/1.2, from table 5.1, TBDY.

y1, sh1,ft1,fy1, are also multiplied by $\text{Min}(1, 1.25 \cdot (lb/d)^{2/3})$, from 10.3.5, ASCE 41-17.

with fs2 = (fs,jacket*Asl,com,jacket + fs,core*Asl,com,core)/Asl,com = 756.25

with Es2 = (Es,jacket*Asl,com,jacket + Es,core*Asl,com,core)/Asl,com = 200000.00

yv = 0.0025

shv = 0.008

ftv = 902.993

fyv = 752.4941

suv = 0.032

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00

lo/lou,min = lb/d = 1.00

$suv = 0.4 * esuv_nominal ((5.5), TBDY) = 0.032$
 From table 5A.1, TBDY: $esuv_nominal = 0.08$,
 considering characteristic value $fsyv = fsv/1.2$, from table 5.1, TBDY
 For calculation of $esuv_nominal$ and yv , shv , ftv , fyv , it is considered
 characteristic value $fsyv = fsv/1.2$, from table 5.1, TBDY.
 $y1$, $sh1$, $ft1$, $fy1$, are also multiplied by $Min(1, 1.25 * (lb/ld)^{2/3})$, from 10.3.5, ASCE 41-17.
 with $fsv = (fs_jacket * Asl_mid_jacket + fs_mid * Asl_mid_core) / Asl_mid = 752.4941$
 with $Esv = (Es_jacket * Asl_mid_jacket + Es_mid * Asl_mid_core) / Asl_mid = 200000.00$
 $1 = Asl_ten / (b * d) * (fs1 / fc) = 0.19457006$
 $2 = Asl_com / (b * d) * (fs2 / fc) = 0.12197144$
 $v = Asl_mid / (b * d) * (fsv / fc) = 0.21102767$

and confined core properties:

$b = 390.00$
 $d = 677.00$
 $d' = 13.00$
 $fcc (5A.2, TBDY) = 30.00$
 $cc (5A.5, TBDY) = 0.002$
 $c = \text{confinement factor} = 1.00$
 $1 = Asl_ten / (b * d) * (fs1 / fc) = 0.23445239$
 $2 = Asl_com / (b * d) * (fs2 / fc) = 0.14697275$
 $v = Asl_mid / (b * d) * (fsv / fc) = 0.25428343$

Case/Assumption: Unconfined full section - Steel rupture
 ' satisfies Eq. (4.3)

--->
 $v < vs_y2$ - LHS eq.(4.5) is not satisfied
 --->

$v < vs_c$ - RHS eq.(4.5) is satisfied
 --->

$su (4.8) = 0.33719414$
 $Mu = MRc (4.15) = 2.1636E+009$
 $u = su (4.1) = 6.8287974E-005$

Calculation of ratio lb/ld

Adequate Lap Length: $lb/ld \geq 1$

Calculation of Shear Strength $Vr = Min(Vr1, Vr2) = 1.2916E+006$

Calculation of Shear Strength at edge 1, $Vr1 = 1.2916E+006$

$Vr1 = VCol ((10.3), ASCE 41-17) = knl * VColO$

$VColO = 1.2916E+006$

$knl = 1$ (zero step-static loading)

NOTE: In expression (10-3) ' $Vs = Av * fy * d / s$ ' is replaced by ' $Vs + f * Vf$ '
 where Vf is the contribution of FRPs (11.3), ACI 440).

$= 1$ (normal-weight concrete)
 Mean concrete strength: $fc' = (fc'_jacket * Area_jacket + fc'_core * Area_core) / Area_section = 27.20$, but $fc'^{0.5} \leq 8.3$
 MPa (22.5.3.1, ACI 318-14)

$M/Vd = 2.00$

$Mu = 5174.584$

$Vu = 8.5087964E-020$

$d = 0.8 * h = 600.00$

$Nu = 20792.05$

$Ag = 337500.00$

From (11.5.4.8), ACI 318-14: $Vs = Vs_jacket + Vs_core = 1.0354E+006$

where:

$Vs_jacket = Vs_j1 + Vs_j2 = 942477.796$

$Vs_j1 = 589048.623$ is calculated for section web jacket, with:

$d = 600.00$

$Av = 157079.633$

$fy = 625.00$

$s = 100.00$

$V_{s,j1}$ is multiplied by $Col,j1 = 1.00$
 $s/d = 0.16666667$
 $V_{s,j2} = 353429.174$ is calculated for section flange jacket, with:
 $d = 360.00$
 $A_v = 157079.633$
 $f_y = 625.00$
 $s = 100.00$
 $V_{s,j2}$ is multiplied by $Col,j2 = 1.00$
 $s/d = 0.27777778$
 $V_{s,core} = V_{s,c1} + V_{s,c2} = 92890.612$
 $V_{s,c1} = 92890.612$ is calculated for section web core, with:
 $d = 440.00$
 $A_v = 100530.965$
 $f_y = 525.00$
 $s = 250.00$
 $V_{s,c1}$ is multiplied by $Col,c1 = 1.00$
 $s/d = 0.56818182$
 $V_{s,c2} = 0.00$ is calculated for section flange core, with:
 $d = 200.00$
 $A_v = 100530.965$
 $f_y = 525.00$
 $s = 250.00$
 $V_{s,c2}$ is multiplied by $Col,c2 = 0.00$
 $s/d = 1.25$
 $V_f ((11-3)-(11.4), ACI 440) = 0.00$
 From (11-11), ACI 440: $V_s + V_f \leq 935437.922$
 $bw = 450.00$

Calculation of Shear Strength at edge 2, $V_{r2} = 1.2916E+006$
 $V_{r2} = V_{Col} ((10.3), ASCE 41-17) = knl * V_{Col0}$
 $V_{Col0} = 1.2916E+006$
 $knl = 1$ (zero step-static loading)

NOTE: In expression (10-3) ' $V_s = A_v * f_y * d / s$ ' is replaced by ' $V_s + f * V_f$ '
 where V_f is the contribution of FRPs (11.3), ACI 440).

$= 1$ (normal-weight concrete)
 Mean concrete strength: $f'_c = (f'_{c,jacket} * Area_{jacket} + f'_{c,core} * Area_{core}) / Area_{section} = 27.20$, but $f'_c^{0.5} \leq 8.3$
 MPa (22.5.3.1, ACI 318-14)
 $M/Vd = 2.00$
 $\mu_u = 5174.584$
 $V_u = 8.5087964E+020$
 $d = 0.8 * h = 600.00$
 $N_u = 20792.05$
 $A_g = 337500.00$
 From (11.5.4.8), ACI 318-14: $V_s = V_{s,jacket} + V_{s,core} = 1.0354E+006$
 where:
 $V_{s,jacket} = V_{s,j1} + V_{s,j2} = 942477.796$
 $V_{s,j1} = 589048.623$ is calculated for section web jacket, with:
 $d = 600.00$
 $A_v = 157079.633$
 $f_y = 625.00$
 $s = 100.00$
 $V_{s,j1}$ is multiplied by $Col,j1 = 1.00$
 $s/d = 0.16666667$
 $V_{s,j2} = 353429.174$ is calculated for section flange jacket, with:
 $d = 360.00$
 $A_v = 157079.633$
 $f_y = 625.00$
 $s = 100.00$
 $V_{s,j2}$ is multiplied by $Col,j2 = 1.00$
 $s/d = 0.27777778$
 $V_{s,core} = V_{s,c1} + V_{s,c2} = 92890.612$
 $V_{s,c1} = 92890.612$ is calculated for section web core, with:
 $d = 440.00$
 $A_v = 100530.965$

$f_y = 525.00$
 $s = 250.00$
 $V_{s,c1}$ is multiplied by $Col,c1 = 1.00$
 $s/d = 0.56818182$
 $V_{s,c2} = 0.00$ is calculated for section flange core, with:
 $d = 200.00$
 $A_v = 100530.965$
 $f_y = 525.00$
 $s = 250.00$
 $V_{s,c2}$ is multiplied by $Col,c2 = 0.00$
 $s/d = 1.25$
 $V_f ((11-3)-(11.4), ACI 440) = 0.00$
 From (11-11), ACI 440: $V_s + V_f \leq 935437.922$
 $bw = 450.00$

End Of Calculation of Shear Capacity ratio for element: column JTC1 of floor 1
 At local axis: 3

Start Of Calculation of Shear Capacity ratio for element: column JTC1 of floor 1
 At Shear local axis: 2
 (Bending local axis: 3)
 Section Type: rcjtcs

Constant Properties

Knowledge Factor, $\phi = 0.80$
 Mean strength values are used for both shear and moment calculations.
 Consequently:
 Jacket
 New material of Secondary Member: Concrete Strength, $f_c = f_{cm} = 30.00$
 New material of Secondary Member: Steel Strength, $f_s = f_{sm} = 625.00$
 Concrete Elasticity, $E_c = 25742.96$
 Steel Elasticity, $E_s = 200000.00$
 Existing Column
 Existing material of Secondary Member: Concrete Strength, $f_c = f_{cm} = 24.00$
 Existing material of Secondary Member: Steel Strength, $f_s = f_{sm} = 525.00$
 Concrete Elasticity, $E_c = 23025.204$
 Steel Elasticity, $E_s = 200000.00$
 #####
 Note: Especially for the calculation of moment strengths,
 the above steel re-bar strengths are multiplied by 1.25 according to R18.6.5, ACI 318-14
 Jacket
 New material: Steel Strength, $f_s = 1.25 \cdot f_{sm} = 781.25$
 Existing Column
 Existing material: Steel Strength, $f_s = 1.25 \cdot f_{sm} = 656.25$
 #####
 Max Height, $H_{max} = 750.00$
 Min Height, $H_{min} = 450.00$
 Max Width, $W_{max} = 950.00$
 Min Width, $W_{min} = 450.00$
 Eccentricity, $Ecc = 250.00$
 Jacket Thickness, $t_j = 100.00$
 Cover Thickness, $c = 25.00$
 Mean Confinement Factor overall section = 1.00
 Element Length, $L = 3000.00$
 Secondary Member
 Smooth Bars
 Ductile Steel
 Without Detailing for Earthquake Resistance (including stirrups not closed at 135°)
 Longitudinal Bars With Ends Lapped Starting at the End Sections
 Adequate Lap Length ($l_o/l_{ou,min} \geq 1$)
 No FRP Wrapping

Stepwise Properties

At local axis: 2

EDGE -A-

Shear Force, $V_a = 5.2099631E-036$

EDGE -B-

Shear Force, $V_b = -5.2099631E-036$

BOTH EDGES

Axial Force, $F = -20792.05$

Longitudinal Reinforcement Area Distribution (in 2 divisions)

-Tension: $As_t = 0.00$

-Compression: $As_c = 6691.592$

Longitudinal Reinforcement Area Distribution (in 3 divisions)

-Tension: $As_{t,ten} = 1539.38$

-Compression: $As_{c,com} = 1539.38$

-Middle: $As_{l,mid} = 3612.832$

Calculation of Shear Capacity ratio, $V_e/V_r = 1.08994$

Member Controlled by Shear ($V_e/V_r > 1$)

Calculation of Shear Demand from fig. R18.6.5, ACI 318-14 $V_e = (M_{pr1} + M_{pr2})/l_n = 1.7820E+006$ with

$M_{pr1} = \text{Max}(\mu_{1+}, \mu_{1-}) = 2.6730E+009$

$\mu_{1+} = 2.6730E+009$, is the ultimate moment strength at the edge 1 of the member in the actual moment direction which is defined for the static loading combination

$\mu_{1-} = 2.6730E+009$, is the ultimate moment strength at the edge 1 of the member in the opposite moment direction which is defined for the static loading combination

$M_{pr2} = \text{Max}(\mu_{2+}, \mu_{2-}) = 2.6730E+009$

$\mu_{2+} = 2.6730E+009$, is the ultimate moment strength at the edge 2 of the member in the actual moment direction which is defined for the static loading combination

$\mu_{2-} = 2.6730E+009$, is the ultimate moment strength at the edge 2 of the member in the opposite moment direction which is defined for the static loading combination

Calculation of μ_{1+}

Calculation of ultimate curvature μ according to 4.1, Biskinis/Fardis 2013:

$\mu = 4.9274896E-005$

$M_u = 2.6730E+009$

with full section properties:

$b = 450.00$

$d = 907.00$

$d' = 43.00$

$v = 0.00169807$

$N = 20792.05$

$f_c = 30.00$

ϕ (5A.5, TBDY) = 0.002

Final value of ϕ : $\phi^* = \text{shear_factor} * \text{Max}(\phi_c, \phi_s) = 0.00832321$

The Shear_factor is considered equal to 1 (pure moment strength)

From (5.4b), TBDY: $\phi_c = 0.00832321$

we (5.4c) = 0.01453958

ϕ_{se} ((5.4d), TBDY) = $(\phi_{se1} * A_{ext} + \phi_{se2} * A_{int}) / A_{sec} = 0.53375773$

$\phi_{se1} = \text{Max}(((A_{conf,max1} - A_{noConf1}) / A_{conf,max1}) * (A_{conf,min1} / A_{conf,max1}), 0) = 0.53375773$

The definitions of A_{noConf} , $A_{conf,min}$ and $A_{conf,max}$ are derived from generalization of the rectangular sections confinement, which is expressed by (5.4d).

The generalization is done according to Mander, J., Priestley, M., and Park, R. (1988)

"Theoretical Stress-Strain Model for Confined Concrete."

J. Struct. Eng., 10.1061/(ASCE)0733-9445(1988)114:8(1804), 1804-1826.

$A_{conf,max1} = 464100.00$ is the confined core area at levels of member with hoops and

is calculated as the area of core enclosed by the center lines of the external perimeter hoops.

$A_{conf,min1} = 395025.00$ is the confined core area at midway between the levels of hoops and

is calculated by reducing all the dimensions of the area $A_{conf,max1}$ by a length equal to half the clear spacing between external hoops.

$A_{noConf1} = 173066.667$ is the unconfined external core area which is equal to $b_i/6$ as defined at (A.2).
 $ase2 (>=ase1) = \text{Max}(((A_{conf,max2}-A_{noConf2})/A_{conf,max2})*(A_{conf,min2}/A_{conf,max2}),0) = 0.53375773$

The definitions of A_{noConf} , $A_{conf,min}$ and $A_{conf,max}$ are derived from generalization of the rectangular sections confinement, which is expressed by (5.4d).

The generalization is done according to Mander, J., Priestley, M., and Park, R. (1988) "Theoretical Stress-Strain Model for Confined Concrete."

J. Struct. Eng., 10.1061/(ASCE)0733-9445(1988)114:8(1804), 1804-1826.

$A_{conf,max2} = 252164.00$ is the confined core area at levels of member with hoops and is calculated as the area of core enclosed by the center lines of the internal perimeter hoops.

$A_{conf,min2} = 111441.00$ is the confined core area at midway between the levels of hoops and is calculated by reducing all the dimensions of the area $A_{conf,max2}$ by a length equal to half the clear spacing between internal hoops.

$A_{noConf2} = 110709.333$ is the unconfined internal core area which is equal to $b_i/6$ as defined at (A.2).
 $psh_{min}*F_{ywe} = \text{Min}(psh_x*F_{ywe}, psh_y*F_{ywe}) = 2.724$

Expression (5.4d) for $psh_{min}*F_{ywe}$ has been multiplied by 0.3 according to 15.7.1.3 for members without earthquake detailing (90° closed stirrups)

 $psh_x*F_{ywe} = psh1*F_{ywe1} + ps2*F_{ywe2} = 2.724$
 $psh1 ((5.4d), TBDY) = L_{stir1}*A_{stir1}/(A_{sec}*s1) = 0.00301593$
 L_{stir1} (Length of stirrups along Y) = 2160.00
 A_{stir1} (stirrups area) = 78.53982
 $psh2 ((5.4d)) = L_{stir2}*A_{stir2}/(A_{sec}*s2) = 0.00056047$
 L_{stir2} (Length of stirrups along Y) = 1568.00
 A_{stir2} (stirrups area) = 50.26548

 $psh_y*F_{ywe} = psh1*F_{ywe1} + ps2*F_{ywe2} = 3.25416$
 $psh1 ((5.4d), TBDY) = L_{stir1}*A_{stir1}/(A_{sec}*s1) = 0.00357443$
 L_{stir1} (Length of stirrups along X) = 2560.00
 A_{stir1} (stirrups area) = 78.53982
 $psh2 ((5.4d), TBDY) = L_{stir2}*A_{stir2}/(A_{sec}*s2) = 0.00070345$
 L_{stir2} (Length of stirrups along X) = 1968.00
 A_{stir2} (stirrups area) = 50.26548

 $A_{sec} = 562500.00$

$s1 = 100.00$

$s2 = 250.00$

$f_{ywe1} = 781.25$

$f_{ywe2} = 656.25$

$f_{ce} = 30.00$

From ((5.A5), TBDY), TBDY: $cc = 0.002$

c = confinement factor = 1.00

$y1 = 0.0025$

$sh1 = 0.008$

$ft1 = 907.50$

$fy1 = 756.25$

$su1 = 0.032$

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor and also multiplied by the shear_factor according to 15.7.1.4, with Shear_factor = 1.00

$l_o/l_{ou,min} = l_b/l_d = 1.00$

$su1 = 0.4*es_{u1,nominal} ((5.5), TBDY) = 0.032$

From table 5A.1, TBDY: $es_{u1,nominal} = 0.08$,

For calculation of $es_{u1,nominal}$ and $y1, sh1, ft1, fy1$, it is considered characteristic value $fs_{y1} = fs_{y1}/1.2$, from table 5.1, TBDY.

$y1, sh1, ft1, fy1$, are also multiplied by $\text{Min}(1, 1.25*(l_b/l_d)^{2/3})$, from 10.3.5, ASCE 41-17.

with $fs_1 = (f_{s,jacket}*A_{s,ten,jacket} + f_{s,core}*A_{s,ten,core})/A_{s,ten} = 756.25$

with $Es_1 = (E_{s,jacket}*A_{s,ten,jacket} + E_{s,core}*A_{s,ten,core})/A_{s,ten} = 200000.00$

$y2 = 0.0025$

$sh2 = 0.008$

$ft2 = 907.50$

$fy2 = 756.25$

$su2 = 0.032$

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor and also multiplied by the shear_factor according to 15.7.1.4, with Shear_factor = 1.00


```

lo/lou,min = lb/lbmin = 1.00
su2 = 0.4*esu2,nominal ((5.5), TBDY) = 0.032
From table 5A.1, TBDY: esu2,nominal = 0.08,
For calculation of esu2,nominal and y2, sh2,ft2,fy2, it is considered
characteristic value fsy2 = fs2/1.2, from table 5.1, TBDY.
y1, sh1,ft1,fy1, are also multiplied by Min(1,1.25*(lb/ld)2/3), from 10.3.5, ASCE 41-17.
with fs2 = (fsjacket*Aslcom,jacket + fscore*Aslcom,core)/Aslcom = 756.25
with Es2 = (Esjacket*Aslcom,jacket + Escore*Aslcom,core)/Aslcom = 200000.00
yv = 0.0025
shv = 0.008
ftv = 899.1522
fyv = 749.2935
suv = 0.032
using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00
lo/lou,min = lb/ld = 1.00
suv = 0.4*esuvnominal ((5.5), TBDY) = 0.032
From table 5A.1, TBDY: esuvnominal = 0.08,
considering characteristic value fsyv = fsv/1.2, from table 5.1, TBDY
For calculation of esuvnominal and yv, shv,ftv,fyv, it is considered
characteristic value fsyv = fsv/1.2, from table 5.1, TBDY.
y1, sh1,ft1,fy1, are also multiplied by Min(1,1.25*(lb/ld)2/3), from 10.3.5, ASCE 41-17.
with fsv = (fsjacket*Aslmid,jacket + fsmid*Aslmid,core)/Aslmid = 749.2935
with Esv = (Esjacket*Aslmid,jacket + Esmid*Aslmid,core)/Aslmid = 200000.00
1 = Aslten/(b*d)*(fs1/fc) = 0.09507586
2 = Aslcom/(b*d)*(fs2/fc) = 0.09507586
v = Aslmid/(b*d)*(fsv/fc) = 0.22108466
and confined core properties:
b = 390.00
d = 877.00
d' = 13.00
fcc (5A.2, TBDY) = 30.00
cc (5A.5, TBDY) = 0.002
c = confinement factor = 1.00
1 = Aslten/(b*d)*(fs1/fc) = 0.11345559
2 = Aslcom/(b*d)*(fs2/fc) = 0.11345559
v = Aslmid/(b*d)*(fsv/fc) = 0.26382395
Case/Assumption: Unconfined full section - Steel rupture
'satisfies Eq. (4.3)
---->
v < vsy2 - LHS eq.(4.5) is not satisfied
---->
v < vsc - RHS eq.(4.5) is satisfied
---->
su (4.8) = 0.28399348
Mu = MRc (4.15) = 2.6730E+009
u = su (4.1) = 4.9274896E-005

```

Calculation of ratio lb/l_d

Adequate Lap Length: lb/l_d >= 1

Calculation of Mu1-

Calculation of ultimate curvature u according to 4.1, Biskinis/Fardis 2013:

u = 4.9274896E-005

Mu = 2.6730E+009

with full section properties:

b = 450.00

d = 907.00

$d' = 43.00$
 $v = 0.00169807$
 $N = 20792.05$
 $f_c = 30.00$
 $co (5A.5, TBDY) = 0.002$
 Final value of cu : $cu^* = shear_factor * Max(cu, cc) = 0.00832321$
 The Shear_factor is considered equal to 1 (pure moment strength)
 From (5.4b), TBDY: $cu = 0.00832321$
 $we (5.4c) = 0.01453958$
 $ase ((5.4d), TBDY) = (ase1 * A_{ext} + ase2 * A_{int}) / A_{sec} = 0.53375773$
 $ase1 = Max(((A_{conf,max1} - A_{noConf1}) / A_{conf,max1}) * (A_{conf,min1} / A_{conf,max1}), 0) = 0.53375773$
 The definitions of A_{noConf} , $A_{conf,min}$ and $A_{conf,max}$ are derived from generalization of the rectangular sections confinement, which is expressed by (5.4d).
 The generalization is done according to Mander, J., Priestley, M., and Park, R. (1988) "Theoretical Stress-Strain Model for Confined Concrete."
 J. Struct. Eng., 10.1061/(ASCE)0733-9445(1988)114:8(1804), 1804-1826.
 $A_{conf,max1} = 464100.00$ is the confined core area at levels of member with hoops and is calculated as the area of core enclosed by the center lines of the external perimeter hoops.
 $A_{conf,min1} = 395025.00$ is the confined core area at midway between the levels of hoops and is calculated by reducing all the dimensions of the area $A_{conf,max1}$ by a length equal to half the clear spacing between external hoops.
 $A_{noConf1} = 173066.667$ is the unconfined external core area which is equal to $b_i^2/6$ as defined at (A.2).
 $ase2 (>= ase1) = Max(((A_{conf,max2} - A_{noConf2}) / A_{conf,max2}) * (A_{conf,min2} / A_{conf,max2}), 0) = 0.53375773$
 The definitions of A_{noConf} , $A_{conf,min}$ and $A_{conf,max}$ are derived from generalization of the rectangular sections confinement, which is expressed by (5.4d).
 The generalization is done according to Mander, J., Priestley, M., and Park, R. (1988) "Theoretical Stress-Strain Model for Confined Concrete."
 J. Struct. Eng., 10.1061/(ASCE)0733-9445(1988)114:8(1804), 1804-1826.
 $A_{conf,max2} = 252164.00$ is the confined core area at levels of member with hoops and is calculated as the area of core enclosed by the center lines of the internal perimeter hoops.
 $A_{conf,min2} = 111441.00$ is the confined core area at midway between the levels of hoops and is calculated by reducing all the dimensions of the area $A_{conf,max2}$ by a length equal to half the clear spacing between internal hoops.
 $A_{noConf2} = 110709.333$ is the unconfined internal core area which is equal to $b_i^2/6$ as defined at (A.2).
 $psh,min * F_{ywe} = Min(psh,x * F_{ywe}, psh,y * F_{ywe}) = 2.724$
 Expression (5.4d) for $psh,min * F_{ywe}$ has been multiplied by 0.3 according to 15.7.1.3 for members without earthquake detailing (90° closed stirrups)

$psh,x * F_{ywe} = psh1 * F_{ywe1} + ps2 * F_{ywe2} = 2.724$
 $psh1 ((5.4d), TBDY) = L_{stir1} * A_{stir1} / (A_{sec} * s1) = 0.00301593$
 L_{stir1} (Length of stirrups along Y) = 2160.00
 A_{stir1} (stirrups area) = 78.53982
 $psh2 (5.4d) = L_{stir2} * A_{stir2} / (A_{sec} * s2) = 0.00056047$
 L_{stir2} (Length of stirrups along Y) = 1568.00
 A_{stir2} (stirrups area) = 50.26548

$psh,y * F_{ywe} = psh1 * F_{ywe1} + ps2 * F_{ywe2} = 3.25416$
 $psh1 ((5.4d), TBDY) = L_{stir1} * A_{stir1} / (A_{sec} * s1) = 0.00357443$
 L_{stir1} (Length of stirrups along X) = 2560.00
 A_{stir1} (stirrups area) = 78.53982
 $psh2 ((5.4d), TBDY) = L_{stir2} * A_{stir2} / (A_{sec} * s2) = 0.00070345$
 L_{stir2} (Length of stirrups along X) = 1968.00
 A_{stir2} (stirrups area) = 50.26548

$A_{sec} = 562500.00$
 $s1 = 100.00$
 $s2 = 250.00$
 $f_{ywe1} = 781.25$
 $f_{ywe2} = 656.25$
 $f_{ce} = 30.00$
 From ((5.A5), TBDY), TBDY: $cc = 0.002$
 $c =$ confinement factor = 1.00
 $y1 = 0.0025$
 $sh1 = 0.008$
 $ft1 = 907.50$
 $fy1 = 756.25$
 $su1 = 0.032$

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
 and also multiplied by the shear_factor according to 15.7.1.4, with
 Shear_factor = 1.00
 $l_o/l_{ou,min} = l_b/l_d = 1.00$
 $su_1 = 0.4 * esu_{1,nominal} ((5.5), TBDY) = 0.032$
 From table 5A.1, TBDY: $esu_{1,nominal} = 0.08$,
 For calculation of $esu_{1,nominal}$ and y_1, sh_1, ft_1, fy_1 , it is considered
 characteristic value $fsy_1 = fs_1/1.2$, from table 5.1, TBDY.
 y_1, sh_1, ft_1, fy_1 , are also multiplied by $Min(1, 1.25 * (l_b/l_d)^{2/3})$, from 10.3.5, ASCE 41-17.
 with $fs_1 = (fs_{jacket} * A_{s,ten,jacket} + fs_{core} * A_{s,ten,core}) / A_{s,ten} = 756.25$
 with $Es_1 = (Es_{jacket} * A_{s,ten,jacket} + Es_{core} * A_{s,ten,core}) / A_{s,ten} = 200000.00$
 $y_2 = 0.0025$
 $sh_2 = 0.008$
 $ft_2 = 907.50$
 $fy_2 = 756.25$
 $su_2 = 0.032$
 using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
 and also multiplied by the shear_factor according to 15.7.1.4, with
 Shear_factor = 1.00
 $l_o/l_{ou,min} = l_b/l_{b,min} = 1.00$
 $su_2 = 0.4 * esu_{2,nominal} ((5.5), TBDY) = 0.032$
 From table 5A.1, TBDY: $esu_{2,nominal} = 0.08$,
 For calculation of $esu_{2,nominal}$ and y_2, sh_2, ft_2, fy_2 , it is considered
 characteristic value $fsy_2 = fs_2/1.2$, from table 5.1, TBDY.
 y_1, sh_1, ft_1, fy_1 , are also multiplied by $Min(1, 1.25 * (l_b/l_d)^{2/3})$, from 10.3.5, ASCE 41-17.
 with $fs_2 = (fs_{jacket} * A_{s,com,jacket} + fs_{core} * A_{s,com,core}) / A_{s,com} = 756.25$
 with $Es_2 = (Es_{jacket} * A_{s,com,jacket} + Es_{core} * A_{s,com,core}) / A_{s,com} = 200000.00$
 $y_v = 0.0025$
 $sh_v = 0.008$
 $ft_v = 899.1522$
 $fy_v = 749.2935$
 $suv = 0.032$
 using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
 and also multiplied by the shear_factor according to 15.7.1.4, with
 Shear_factor = 1.00
 $l_o/l_{ou,min} = l_b/l_d = 1.00$
 $suv = 0.4 * esuv_{nominal} ((5.5), TBDY) = 0.032$
 From table 5A.1, TBDY: $esuv_{nominal} = 0.08$,
 considering characteristic value $fsyv = fsv/1.2$, from table 5.1, TBDY
 For calculation of $esuv_{nominal}$ and y_v, sh_v, ft_v, fy_v , it is considered
 characteristic value $fsyv = fsv/1.2$, from table 5.1, TBDY.
 y_1, sh_1, ft_1, fy_1 , are also multiplied by $Min(1, 1.25 * (l_b/l_d)^{2/3})$, from 10.3.5, ASCE 41-17.
 with $fsv = (fs_{jacket} * A_{s,mid,jacket} + fs_{mid} * A_{s,mid,core}) / A_{s,mid} = 749.2935$
 with $Esv = (Es_{jacket} * A_{s,mid,jacket} + Es_{mid} * A_{s,mid,core}) / A_{s,mid} = 200000.00$
 $1 = A_{s,ten} / (b * d) * (fs_1 / fc) = 0.09507586$
 $2 = A_{s,com} / (b * d) * (fs_2 / fc) = 0.09507586$
 $v = A_{s,mid} / (b * d) * (fsv / fc) = 0.22108466$
 and confined core properties:
 $b = 390.00$
 $d = 877.00$
 $d' = 13.00$
 $f_{cc} (5A.2, TBDY) = 30.00$
 $cc (5A.5, TBDY) = 0.002$
 $c = \text{confinement factor} = 1.00$
 $1 = A_{s,ten} / (b * d) * (fs_1 / fc) = 0.11345559$
 $2 = A_{s,com} / (b * d) * (fs_2 / fc) = 0.11345559$
 $v = A_{s,mid} / (b * d) * (fsv / fc) = 0.26382395$
 Case/Assumption: Unconfined full section - Steel rupture
 ' satisfies Eq. (4.3)
 --->
 $v < v_{s,y2}$ - LHS eq.(4.5) is not satisfied
 --->
 $v < v_{s,c}$ - RHS eq.(4.5) is satisfied
 --->
 $su (4.8) = 0.28399348$
 $Mu = MRc (4.15) = 2.6730E+009$
 $u = su (4.1) = 4.9274896E-005$

Calculation of ratio l_b/d

Adequate Lap Length: $l_b/d \geq 1$

Calculation of μ_{2+}

Calculation of ultimate curvature μ according to 4.1, Biskinis/Fardis 2013:

$$\mu = 4.9274896E-005$$

$$\mu_u = 2.6730E+009$$

with full section properties:

$$b = 450.00$$

$$d = 907.00$$

$$d' = 43.00$$

$$\nu = 0.00169807$$

$$N = 20792.05$$

$$f_c = 30.00$$

$$\omega (5A.5, TBDY) = 0.002$$

$$\text{Final value of } \mu_u: \mu_u^* = \text{shear_factor} * \text{Max}(\mu_u, \mu_c) = 0.00832321$$

The Shear_factor is considered equal to 1 (pure moment strength)

$$\text{From (5.4b), TBDY: } \mu_u = 0.00832321$$

$$\mu_{ue} (5.4c) = 0.01453958$$

$$\mu_{ase} ((5.4d), TBDY) = (\mu_{ase1} * A_{ext} + \mu_{ase2} * A_{int}) / A_{sec} = 0.53375773$$

$$\mu_{ase1} = \text{Max}(((A_{conf,max1} - A_{noConf1}) / A_{conf,max1}) * (A_{conf,min1} / A_{conf,max1}), 0) = 0.53375773$$

The definitions of A_{noConf} , $A_{conf,min}$ and $A_{conf,max}$ are derived from generalization of the rectangular sections confinement, which is expressed by (5.4d).

The generalization is done according to Mander, J., Priestley, M., and Park, R. (1988)

"Theoretical Stress-Strain Model for Confined Concrete."

J. Struct. Eng., 10.1061/(ASCE)0733-9445(1988)114:8(1804), 1804-1826.

$A_{conf,max1} = 464100.00$ is the confined core area at levels of member with hoops and is calculated as the area of core enclosed by the center lines of the external perimeter hoops.

$A_{conf,min1} = 395025.00$ is the confined core area at midway between the levels of hoops and is calculated by reducing all the dimensions of the area $A_{conf,max1}$ by a length equal to half the clear spacing between external hoops.

$A_{noConf1} = 173066.667$ is the unconfined external core area which is equal to $b_i^2/6$ as defined at (A.2).

$$\mu_{ase2} (\geq \mu_{ase1}) = \text{Max}(((A_{conf,max2} - A_{noConf2}) / A_{conf,max2}) * (A_{conf,min2} / A_{conf,max2}), 0) = 0.53375773$$

The definitions of A_{noConf} , $A_{conf,min}$ and $A_{conf,max}$ are derived from generalization of the rectangular sections confinement, which is expressed by (5.4d).

The generalization is done according to Mander, J., Priestley, M., and Park, R. (1988)

"Theoretical Stress-Strain Model for Confined Concrete."

J. Struct. Eng., 10.1061/(ASCE)0733-9445(1988)114:8(1804), 1804-1826.

$A_{conf,max2} = 252164.00$ is the confined core area at levels of member with hoops and is calculated as the area of core enclosed by the center lines of the internal perimeter hoops.

$A_{conf,min2} = 111441.00$ is the confined core area at midway between the levels of hoops and is calculated by reducing all the dimensions of the area $A_{conf,max2}$ by a length equal to half the clear spacing between internal hoops.

$A_{noConf2} = 110709.333$ is the unconfined internal core area which is equal to $b_i^2/6$ as defined at (A.2).

$$p_{sh,min} * F_{ywe} = \text{Min}(p_{sh,x} * F_{ywe}, p_{sh,y} * F_{ywe}) = 2.724$$

Expression (5.4d) for $p_{sh,min} * F_{ywe}$ has been multiplied by 0.3 according to 15.7.1.3 for members without earthquake detailing (90° closed stirrups)

$$p_{sh,x} * F_{ywe} = p_{sh1} * F_{ywe1} + p_{sh2} * F_{ywe2} = 2.724$$

$$p_{sh1} ((5.4d), TBDY) = L_{stir1} * A_{stir1} / (A_{sec} * s_1) = 0.00301593$$

$$L_{stir1} \text{ (Length of stirrups along Y)} = 2160.00$$

$$A_{stir1} \text{ (stirrups area)} = 78.53982$$

$$p_{sh2} (5.4d) = L_{stir2} * A_{stir2} / (A_{sec} * s_2) = 0.00056047$$

$$L_{stir2} \text{ (Length of stirrups along Y)} = 1568.00$$

$$A_{stir2} \text{ (stirrups area)} = 50.26548$$

$$p_{sh,y} * F_{ywe} = p_{sh1} * F_{ywe1} + p_{sh2} * F_{ywe2} = 3.25416$$

$$p_{sh1} ((5.4d), TBDY) = L_{stir1} * A_{stir1} / (A_{sec} * s_1) = 0.00357443$$

Lstir1 (Length of stirrups along X) = 2560.00
 Astir1 (stirrups area) = 78.53982
 $psh2 ((5.4d), TBDY) = Lstir2 * Astir2 / (Asec * s2) = 0.00070345$
 Lstir2 (Length of stirrups along X) = 1968.00
 Astir2 (stirrups area) = 50.26548

Asec = 562500.00

s1 = 100.00

s2 = 250.00

fywe1 = 781.25

fywe2 = 656.25

fce = 30.00

From ((5.45), TBDY), TBDY: cc = 0.002

c = confinement factor = 1.00

y1 = 0.0025

sh1 = 0.008

ft1 = 907.50

fy1 = 756.25

su1 = 0.032

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
 and also multiplied by the shear_factor according to 15.7.1.4, with
 Shear_factor = 1.00

lo/lou,min = lb/ld = 1.00

su1 = 0.4*esu1_nominal ((5.5), TBDY) = 0.032

From table 5A.1, TBDY: esu1_nominal = 0.08,

For calculation of esu1_nominal and y1, sh1,ft1,fy1, it is considered
 characteristic value fsy1 = fs1/1.2, from table 5.1, TBDY.

y1, sh1,ft1,fy1, are also multiplied by $\text{Min}(1, 1.25 * (lb/ld)^{2/3})$, from 10.3.5, ASCE 41-17.

with fs1 = (fs,jacket*Asl,ten,jacket + fs,core*Asl,ten,core)/Asl,ten = 756.25

with Es1 = (Es,jacket*Asl,ten,jacket + Es,core*Asl,ten,core)/Asl,ten = 200000.00

y2 = 0.0025

sh2 = 0.008

ft2 = 907.50

fy2 = 756.25

su2 = 0.032

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
 and also multiplied by the shear_factor according to 15.7.1.4, with
 Shear_factor = 1.00

lo/lou,min = lb/lb,min = 1.00

su2 = 0.4*esu2_nominal ((5.5), TBDY) = 0.032

From table 5A.1, TBDY: esu2_nominal = 0.08,

For calculation of esu2_nominal and y2, sh2,ft2,fy2, it is considered
 characteristic value fsy2 = fs2/1.2, from table 5.1, TBDY.

y1, sh1,ft1,fy1, are also multiplied by $\text{Min}(1, 1.25 * (lb/ld)^{2/3})$, from 10.3.5, ASCE 41-17.

with fs2 = (fs,jacket*Asl,com,jacket + fs,core*Asl,com,core)/Asl,com = 756.25

with Es2 = (Es,jacket*Asl,com,jacket + Es,core*Asl,com,core)/Asl,com = 200000.00

yv = 0.0025

shv = 0.008

ftv = 899.1522

fyv = 749.2935

suv = 0.032

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
 and also multiplied by the shear_factor according to 15.7.1.4, with
 Shear_factor = 1.00

lo/lou,min = lb/ld = 1.00

suv = 0.4*esuv_nominal ((5.5), TBDY) = 0.032

From table 5A.1, TBDY: esuv_nominal = 0.08,

considering characteristic value fsyv = fsv/1.2, from table 5.1, TBDY

For calculation of esuv_nominal and yv, shv,ftv,fyv, it is considered
 characteristic value fsyv = fsv/1.2, from table 5.1, TBDY.

y1, sh1,ft1,fy1, are also multiplied by $\text{Min}(1, 1.25 * (lb/ld)^{2/3})$, from 10.3.5, ASCE 41-17.

with fsv = (fs,jacket*Asl,mid,jacket + fs,mid*Asl,mid,core)/Asl,mid = 749.2935

with Esv = (Es,jacket*Asl,mid,jacket + Es,mid*Asl,mid,core)/Asl,mid = 200000.00

1 = Asl,ten/(b*d)*(fs1/fc) = 0.09507586

2 = Asl,com/(b*d)*(fs2/fc) = 0.09507586

v = Asl,mid/(b*d)*(fsv/fc) = 0.22108466

and confined core properties:

$b = 390.00$
 $d = 877.00$
 $d' = 13.00$
 $f_{cc} (5A.2, TBDY) = 30.00$
 $cc (5A.5, TBDY) = 0.002$
 $c = \text{confinement factor} = 1.00$
 $1 = A_{sl,ten}/(b*d)*(f_{s1}/f_c) = 0.11345559$
 $2 = A_{sl,com}/(b*d)*(f_{s2}/f_c) = 0.11345559$
 $v = A_{sl,mid}/(b*d)*(f_{sv}/f_c) = 0.26382395$

Case/Assumption: Unconfined full section - Steel rupture
 ' satisfies Eq. (4.3)

---->
 $v < v_{s,y2}$ - LHS eq.(4.5) is not satisfied

---->
 $v < v_{s,c}$ - RHS eq.(4.5) is satisfied

---->
 $\mu_u (4.8) = 0.28399348$
 $\mu_u = M_{Rc} (4.15) = 2.6730E+009$
 $u = \mu_u (4.1) = 4.9274896E-005$

Calculation of ratio l_b/d

Adequate Lap Length: $l_b/d \geq 1$

Calculation of μ_{u2} -

Calculation of ultimate curvature μ_u according to 4.1, Biskinis/Fardis 2013:

$u = 4.9274896E-005$
 $\mu_u = 2.6730E+009$

with full section properties:

$b = 450.00$
 $d = 907.00$
 $d' = 43.00$
 $v = 0.00169807$
 $N = 20792.05$
 $f_c = 30.00$
 $cc (5A.5, TBDY) = 0.002$

Final value of μ_u : $\mu_u^* = \text{shear_factor} * \text{Max}(\mu_u, cc) = 0.00832321$

The Shear_factor is considered equal to 1 (pure moment strength)

From (5.4b), TBDY: $\mu_u = 0.00832321$

we (5.4c) = 0.01453958

ase ((5.4d), TBDY) = (ase1*Aext+ase2*Aint)/Asec = 0.53375773

ase1 = Max(((Aconf,max1-AnoConf1)/Aconf,max1)*(Aconf,min1/Aconf,max1),0) = 0.53375773

The definitions of AnoConf, Aconf,min and Aconf,max are derived from generalization of the rectangular sections confinement, which is expressed by (5.4d).

The generalization is done according to Mander, J., Priestley, M., and Park, R. (1988)

"Theoretical Stress-Strain Model for Confined Concrete."

J. Struct. Eng., 10.1061/(ASCE)0733-9445(1988)114:8(1804), 1804-1826.

Aconf,max1 = 464100.00 is the confined core area at levels of member with hoops and is calculated as the area of core enclosed by the center lines of the external perimeter hoops.

Aconf,min1 = 395025.00 is the confined core area at midway between the levels of hoops and is calculated by reducing all the dimensions of the area Aconf,max1 by a length

equal to half the clear spacing between external hoops.

AnoConf1 = 173066.667 is the unconfined external core area which is equal to $b_i^2/6$ as defined at (A.2).

ase2 ($\geq \text{ase1}$) = Max(((Aconf,max2-AnoConf2)/Aconf,max2)*(Aconf,min2/Aconf,max2),0) = 0.53375773

The definitions of AnoConf, Aconf,min and Aconf,max are derived from generalization of the rectangular sections confinement, which is expressed by (5.4d).

The generalization is done according to Mander, J., Priestley, M., and Park, R. (1988)

"Theoretical Stress-Strain Model for Confined Concrete."

J. Struct. Eng., 10.1061/(ASCE)0733-9445(1988)114:8(1804), 1804-1826.

Aconf,max2 = 252164.00 is the confined core area at levels of member with hoops and

is calculated as the area of core enclosed by the center lines of the internal perimeter hoops.

$A_{conf,min2} = 111441.00$ is the confined core area at midway between the levels of hoops and

is calculated by reducing all the dimensions of the area $A_{conf,max2}$ by a length

equal to half the clear spacing between internal hoops.

$A_{noConf2} = 110709.333$ is the unconfined internal core area which is equal to $b_i^2/6$ as defined at (A.2).

$psh_{min} \cdot F_{ywe} = \min(psh_x \cdot F_{ywe}, psh_y \cdot F_{ywe}) = 2.724$

Expression (5.4d) for $psh_{min} \cdot F_{ywe}$ has been multiplied by 0.3 according to 15.7.1.3 for members without earthquake detailing (90° closed stirrups)

$psh_x \cdot F_{ywe} = psh1 \cdot F_{ywe1} + ps2 \cdot F_{ywe2} = 2.724$

$psh1$ ((5.4d), TBDY) = $L_{stir1} \cdot A_{stir1} / (A_{sec} \cdot s1) = 0.00301593$

L_{stir1} (Length of stirrups along Y) = 2160.00

A_{stir1} (stirrups area) = 78.53982

$psh2$ ((5.4d)) = $L_{stir2} \cdot A_{stir2} / (A_{sec} \cdot s2) = 0.00056047$

L_{stir2} (Length of stirrups along Y) = 1568.00

A_{stir2} (stirrups area) = 50.26548

$psh_y \cdot F_{ywe} = psh1 \cdot F_{ywe1} + ps2 \cdot F_{ywe2} = 3.25416$

$psh1$ ((5.4d), TBDY) = $L_{stir1} \cdot A_{stir1} / (A_{sec} \cdot s1) = 0.00357443$

L_{stir1} (Length of stirrups along X) = 2560.00

A_{stir1} (stirrups area) = 78.53982

$psh2$ ((5.4d), TBDY) = $L_{stir2} \cdot A_{stir2} / (A_{sec} \cdot s2) = 0.00070345$

L_{stir2} (Length of stirrups along X) = 1968.00

A_{stir2} (stirrups area) = 50.26548

$A_{sec} = 562500.00$

$s1 = 100.00$

$s2 = 250.00$

$f_{ywe1} = 781.25$

$f_{ywe2} = 656.25$

$f_{ce} = 30.00$

From ((5.A5), TBDY), TBDY: $cc = 0.002$

c = confinement factor = 1.00

$y1 = 0.0025$

$sh1 = 0.008$

$ft1 = 907.50$

$fy1 = 756.25$

$su1 = 0.032$

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor

and also multiplied by the shear_factor according to 15.7.1.4, with

Shear_factor = 1.00

$lo/lo_{min} = lb/lb_{min} = 1.00$

$su1 = 0.4 \cdot esu1_{nominal}$ ((5.5), TBDY) = 0.032

From table 5A.1, TBDY: $esu1_{nominal} = 0.08$,

For calculation of $esu1_{nominal}$ and $y1, sh1, ft1, fy1$, it is considered

characteristic value $fsy1 = fs1/1.2$, from table 5.1, TBDY.

$y1, sh1, ft1, fy1$, are also multiplied by $\min(1, 1.25 \cdot (lb/lb_{min})^{2/3})$, from 10.3.5, ASCE 41-17.

with $fs1 = (fs_{jacket} \cdot A_{sl,ten,jacket} + fs_{core} \cdot A_{sl,ten,core}) / A_{sl,ten} = 756.25$

with $Es1 = (Es_{jacket} \cdot A_{sl,ten,jacket} + Es_{core} \cdot A_{sl,ten,core}) / A_{sl,ten} = 200000.00$

$y2 = 0.0025$

$sh2 = 0.008$

$ft2 = 907.50$

$fy2 = 756.25$

$su2 = 0.032$

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor

and also multiplied by the shear_factor according to 15.7.1.4, with

Shear_factor = 1.00

$lo/lo_{min} = lb/lb_{min} = 1.00$

$su2 = 0.4 \cdot esu2_{nominal}$ ((5.5), TBDY) = 0.032

From table 5A.1, TBDY: $esu2_{nominal} = 0.08$,

For calculation of $esu2_{nominal}$ and $y2, sh2, ft2, fy2$, it is considered

characteristic value $fsy2 = fs2/1.2$, from table 5.1, TBDY.

$y1, sh1, ft1, fy1$, are also multiplied by $\min(1, 1.25 \cdot (lb/lb_{min})^{2/3})$, from 10.3.5, ASCE 41-17.

with $fs2 = (fs_{jacket} \cdot A_{sl,com,jacket} + fs_{core} \cdot A_{sl,com,core}) / A_{sl,com} = 756.25$

with $Es2 = (Es_{jacket} \cdot A_{sl,com,jacket} + Es_{core} \cdot A_{sl,com,core}) / A_{sl,com} = 200000.00$

$yv = 0.0025$

$shv = 0.008$

```

ftv = 899.1522
fyv = 749.2935
suv = 0.032
    using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
    and also multiplied by the shear_factor according to 15.7.1.4, with
    Shear_factor = 1.00
    lo/lo,min = lb/ld = 1.00
    suv = 0.4*esuv_nominal ((5.5), TBDY) = 0.032
    From table 5A.1, TBDY: esuv_nominal = 0.08,
    considering characteristic value fsyv = fsv/1.2, from table 5.1, TBDY
    For calculation of esuv_nominal and yv, shv,ftv,fyv, it is considered
    characteristic value fsyv = fsv/1.2, from table 5.1, TBDY.
    y1, sh1,ft1,fy1, are also multiplied by Min(1,1.25*(lb/ld)^2/3), from 10.3.5, ASCE 41-17.
    with fsv = (fsjacket*Asl,mid,jacket + fs,mid*Asl,mid,core)/Asl,mid = 749.2935
    with Esv = (Es,jacket*Asl,mid,jacket + Es,mid*Asl,mid,core)/Asl,mid = 200000.00
    1 = Asl,ten/(b*d)*(fs1/fc) = 0.09507586
    2 = Asl,com/(b*d)*(fs2/fc) = 0.09507586
    v = Asl,mid/(b*d)*(fsv/fc) = 0.22108466
and confined core properties:
b = 390.00
d = 877.00
d' = 13.00
fcc (5A.2, TBDY) = 30.00
cc (5A.5, TBDY) = 0.002
    c = confinement factor = 1.00
    1 = Asl,ten/(b*d)*(fs1/fc) = 0.11345559
    2 = Asl,com/(b*d)*(fs2/fc) = 0.11345559
    v = Asl,mid/(b*d)*(fsv/fc) = 0.26382395
Case/Assumption: Unconfined full section - Steel rupture
' satisfies Eq. (4.3)
--->
v < vs,y2 - LHS eq.(4.5) is not satisfied
--->
v < vs,c - RHS eq.(4.5) is satisfied
--->
su (4.8) = 0.28399348
Mu = MRc (4.15) = 2.6730E+009
u = su (4.1) = 4.9274896E-005
-----

Calculation of ratio lb/ld
-----
Adequate Lap Length: lb/ld >= 1
-----
-----
-----
Calculation of Shear Strength Vr = Min(Vr1,Vr2) = 1.6349E+006
-----
Calculation of Shear Strength at edge 1, Vr1 = 1.6349E+006
Vr1 = VCol ((10.3), ASCE 41-17) = knl*VCol0
VCol0 = 1.6349E+006
knl = 1 (zero step-static loading)
-----
NOTE: In expression (10-3) 'Vs = Av*fy*d/s' is replaced by 'Vs+ f*Vf'
where Vf is the contribution of FRPs (11.3), ACI 440).
-----
= 1 (normal-weight concrete)
Mean concrete strength: fc' = (fc'_jacket*Area_jacket + fc'_core*Area_core)/Area_section = 27.20, but fc'^0.5 <= 8.3
MPa (22.5.3.1, ACI 318-14)
M/Vd = 2.00
Mu = 4.16869
Vu = 5.2099631E-036
d = 0.8*h = 760.00
Nu = 20792.05
Ag = 427500.00
From (11.5.4.8), ACI 318-14: Vs = Vs,jacket + Vs,core = 1.2262E+006

```


where:

$$V_{sj,jacket} = V_{sj,1} + V_{sj,2} = 1.0996E+006$$

$V_{sj,1} = 353429.174$ is calculated for section web jacket, with:

$$d = 360.00$$

$$A_v = 157079.633$$

$$f_y = 625.00$$

$$s = 100.00$$

$V_{sj,1}$ is multiplied by $Col,j1 = 1.00$

$$s/d = 0.27777778$$

$V_{sj,2} = 746128.255$ is calculated for section flange jacket, with:

$$d = 760.00$$

$$A_v = 157079.633$$

$$f_y = 625.00$$

$$s = 100.00$$

$V_{sj,2}$ is multiplied by $Col,j2 = 1.00$

$$s/d = 0.13157895$$

$$V_{s,core} = V_{s,c1} + V_{s,c2} = 126669.016$$

$V_{s,c1} = 0.00$ is calculated for section web core, with:

$$d = 200.00$$

$$A_v = 100530.965$$

$$f_y = 525.00$$

$$s = 250.00$$

$V_{s,c1}$ is multiplied by $Col,c1 = 0.00$

$$s/d = 1.25$$

$V_{s,c2} = 126669.016$ is calculated for section flange core, with:

$$d = 600.00$$

$$A_v = 100530.965$$

$$f_y = 525.00$$

$$s = 250.00$$

$V_{s,c2}$ is multiplied by $Col,c2 = 1.00$

$$s/d = 0.41666667$$

$V_f ((11-3)-(11.4), ACI 440) = 0.00$

From (11-11), ACI 440: $V_s + V_f \leq 1.1849E+006$

$$bw = 450.00$$

Calculation of Shear Strength at edge 2, $V_{r2} = 1.6349E+006$

$$V_{r2} = V_{Col} ((10.3), ASCE 41-17) = knl * V_{Col0}$$

$$V_{Col0} = 1.6349E+006$$

$knl = 1$ (zero step-static loading)

NOTE: In expression (10-3) ' $V_s = A_v * f_y * d / s$ ' is replaced by ' $V_s + f * V_f$ ' where V_f is the contribution of FRPs (11.3), ACI 440).

= 1 (normal-weight concrete)

Mean concrete strength: $f'_c = (f'_c_{jacket} * Area_{jacket} + f'_c_{core} * Area_{core}) / Area_{section} = 27.20$, but $f'_c^{0.5} \leq 8.3$ MPa (22.5.3.1, ACI 318-14)

$$M/Vd = 2.00$$

$$\mu_u = 4.16869$$

$$V_u = 5.2099631E-036$$

$$d = 0.8 * h = 760.00$$

$$N_u = 20792.05$$

$$A_g = 427500.00$$

From (11.5.4.8), ACI 318-14: $V_s = V_{sj,jacket} + V_{s,core} = 1.2262E+006$

where:

$$V_{sj,jacket} = V_{sj,1} + V_{sj,2} = 1.0996E+006$$

$V_{sj,1} = 353429.174$ is calculated for section web jacket, with:

$$d = 360.00$$

$$A_v = 157079.633$$

$$f_y = 625.00$$

$$s = 100.00$$

$V_{sj,1}$ is multiplied by $Col,j1 = 1.00$

$$s/d = 0.27777778$$

$V_{sj,2} = 746128.255$ is calculated for section flange jacket, with:

$$d = 760.00$$

$$A_v = 157079.633$$

$$f_y = 625.00$$

$s = 100.00$
 $V_{s,j2}$ is multiplied by $Col,j2 = 1.00$
 $s/d = 0.13157895$
 $V_{s,core} = V_{s,c1} + V_{s,c2} = 126669.016$
 $V_{s,c1} = 0.00$ is calculated for section web core, with:
 $d = 200.00$
 $A_v = 100530.965$
 $f_y = 525.00$
 $s = 250.00$
 $V_{s,c1}$ is multiplied by $Col,c1 = 0.00$
 $s/d = 1.25$
 $V_{s,c2} = 126669.016$ is calculated for section flange core, with:
 $d = 600.00$
 $A_v = 100530.965$
 $f_y = 525.00$
 $s = 250.00$
 $V_{s,c2}$ is multiplied by $Col,c2 = 1.00$
 $s/d = 0.41666667$
 $V_f ((11-3)-(11.4), ACI 440) = 0.00$
 From (11-11), ACI 440: $V_s + V_f \leq 1.1849E+006$
 $bw = 450.00$

 End Of Calculation of Shear Capacity ratio for element: column JTC1 of floor 1
 At local axis: 2

 Start Of Calculation of Chord Rotation Capacity for element: column JTC1 of floor 1
 At local axis: 2
 Integration Section: (b)
 Section Type: rcjtcs

Constant Properties

 Knowledge Factor, $\phi = 0.80$
 Chord Rotation is generally considered as Deformation-Controlled Action according to Table C7-1, ASCE 41-17.
 Mean strengths are used for Deformation-Controlled Actions according to 7.5.1.3, ASCE 41-17
 Consequently:
 Jacket
 New material of Secondary Member: Concrete Strength, $f_c = f_{cm} = 30.00$
 New material of Secondary Member: Steel Strength, $f_s = f_{sm} = 625.00$
 Concrete Elasticity, $E_c = 25742.96$
 Steel Elasticity, $E_s = 200000.00$
 Existing Column
 Existing material of Secondary Member: Concrete Strength, $f_c = f_{cm} = 24.00$
 Existing material of Secondary Member: Steel Strength, $f_s = f_{sm} = 525.00$
 Concrete Elasticity, $E_c = 23025.204$
 Steel Elasticity, $E_s = 200000.00$
 Max Height, $H_{max} = 750.00$
 Min Height, $H_{min} = 450.00$
 Max Width, $W_{max} = 950.00$
 Min Width, $W_{min} = 450.00$
 Eccentricity, $E_{cc} = 250.00$
 Jacket Thickness, $t_j = 100.00$
 Cover Thickness, $c = 25.00$
 Element Length, $L = 3000.00$
 Secondary Member
 Smooth Bars
 Ductile Steel
 Without Detailing for Earthquake Resistance (including stirrups not closed at 135°)
 Longitudinal Bars With Ends Lapped Starting at the End Sections
 Adequate Lap Length ($l_b/d \geq 1$)
 No FRP Wrapping

Stepwise Properties

Bending Moment, $M = -3480.992$

Shear Force, $V2 = 5479.017$

Shear Force, $V3 = 1.3008$

Axial Force, $F = -21838.055$

Longitudinal Reinforcement Area Distribution (in 2 divisions)

-Tension: $As_t = 0.00$

-Compression: $As_c = 6691.592$

Longitudinal Reinforcement Area Distribution (in 3 divisions)

-Tension: $As_{t,ten} = 1539.38$

-Compression: $As_{c,com} = 2475.575$

-Middle: $As_{mid} = 2676.637$

Longitudinal External Reinforcement Area Distribution (in 3 divisions)

-Tension: $As_{t,ten,jacket} = 1231.504$

-Compression: $As_{c,com,jacket} = 1859.823$

-Middle: $As_{mid,jacket} = 2060.885$

Longitudinal Internal Reinforcement Area Distribution (in 3 divisions)

-Tension: $As_{t,ten,core} = 307.8761$

-Compression: $As_{c,com,core} = 615.7522$

-Middle: $As_{mid,core} = 615.7522$

Mean Diameter of Tension Reinforcement, $DbL = 16.57143$

Existing component: From table 7-7, ASCE 41_17: Final chord rotation Capacity $u_R = u = 0.00565326$
 $u = y + p = 0.00706657$

- Calculation of y -

$y = (M_y * L_s / 3) / E_{eff} = 0.00492635$ ((4.29), Biskinis Phd))

$M_y = 9.4092E+008$

$L_s = M/V$ (with $L_s > 0.1 * L$ and $L_s < 2 * L$) = 2676.049

From table 10.5, ASCE 41_17: $E_{eff} = factor * E_c * I_g = 1.7037E+014$

factor = 0.30

$A_g = 562500.00$

Mean concrete strength: $fc' = (fc'_{jacket} * Area_{jacket} + fc'_{core} * Area_{core}) / Area_{section} = 27.20$

$N = 21838.055$

$E_c * I_g = E_{c,jacket} * I_{g,jacket} + E_{c,core} * I_{g,core} = 5.6791E+014$

Calculation of Yielding Moment M_y

Calculation of y and M_y according to Annex 7 -

Assuming neutral axis within flange ($y < t/d$, compression zone rectangular) with:

flange width, $b = 950.00$

web width, $b_w = 450.00$

flange thickness, $t = 450.00$

$y = \text{Min}(y_{ten}, y_{com})$

$y_{ten} = 5.3414671E-006$

with $f_y = 601.9953$

$d = 707.00$

$y = 0.20295445$

$A = 0.01001693$

$B = 0.00468389$

with $pt = 0.00229194$

$pc = 0.00368581$

$pv = 0.00398517$

$N = 21838.055$

$b = 950.00$

$" = 0.06082037$

$y_{comp} = 1.4673916E-005$

with $f_c = 30.00$
 $E_c = 25742.96$
 $y = 0.20219473$
 $A = 0.00988542$
 $B = 0.00462988$
with $E_s = 200000.00$
CONFIRMATION: $y = 0.20295445 < t/d$

Calculation of ratio I_b/I_d

Adequate Lap Length: $I_b/I_d \geq 1$

- Calculation of p -

From table 10-8: $p = 0.00214022$

with:

- Columns not controlled by inadequate development or splicing along the clear height because $I_b/I_d \geq 1$

shear control ratio $V_y E / V_{col} E = 1.11674$

$d = d_{external} = 707.00$

$s = s_{external} = 0.00$

- $t = s_1 + s_2 + 2 \cdot t_f / b_w \cdot (f_{fe} / f_s) = 0.0035764$

jacket: $s_1 = A_{v1} \cdot L_{stir1} / (s_1 \cdot A_g) = 0.00301593$

$A_{v1} = 78.53982$, is the area of every stirrup parallel to loading (shear) direction

$L_{stir1} = 2160.00$, is the total Length of all stirrups parallel to loading (shear) direction

$s_1 = 100.00$

core: $s_2 = A_{v2} \cdot L_{stir2} / (s_2 \cdot A_g) = 0.00056047$

$A_{v2} = 50.26548$, is the area of every stirrup parallel to loading (shear) direction

$L_{stir2} = 1568.00$, is the total Length of all stirrups parallel to loading (shear) direction

$s_2 = 250.00$

The term $2 \cdot t_f / b_w \cdot (f_{fe} / f_s)$ is implemented to account for FRP contribution

where $f = 2 \cdot t_f / b_w$ is FRP ratio (EC8 - 3, A.4.4.3(6)) and f_{fe} / f_s normalises f to steel strength

All these variables have already been given in Shear control ratio calculation.

For the normalisation f_s of jacket is used.

$NUD = 21838.055$

$A_g = 562500.00$

$f_{cE} = (f_{c,jacket} \cdot Area_{jacket} + f_{c,core} \cdot Area_{core}) / section_area = 27.20$

$f_{yE} = (f_{y,ext_Long_Reinf} \cdot Area_{ext_Long_Reinf} + f_{y,int_Long_Reinf} \cdot Area_{int_Long_Reinf}) / Area_{Tot_Long_Rein} =$

601.9953

$f_{yE} = (f_{y,ext_Trans_Reinf} \cdot s_1 + f_{y,int_Trans_Reinf} \cdot s_2) / (s_1 + s_2) = 609.3286$

$p_l = Area_{Tot_Long_Rein} / (b \cdot d) = 0.00996292$

$b = 950.00$

$d = 707.00$

$f_{cE} = 27.20$


End Of Calculation of Chord Rotation Capacity for element: column JTC1 of floor 1

At local axis: 2

Integration Section: (b)

Calculation No. 7

column C1, Floor 1
 Limit State: Operational Level (data interpolation between analysis steps 1 and 2)
 Analysis: Uniform +X
 Check: Shear capacity VR_d
 Edge: End
 Local Axis: (3)



Start Of Calculation of Shear Capacity for element: column JTC1 of floor 1
 At local axis: 3
 Integration Section: (b)
 Section Type: rcjtcs

Constant Properties

Knowledge Factor, $\gamma = 0.80$
 Member Shear Force is generally considered as Force-Controlled Action according to Table C7-1, ASCE 41-17.
 Lower-bound strengths are used for Force-Controlled Actions according to 7.5.1.3, ASCE 41-17
 Consequently:
 Jacket
 New material of Secondary Member: Concrete Strength, $f_c = f_{c_lower_bound} = 20.00$
 New material of Secondary Member: Steel Strength, $f_s = f_{s_lower_bound} = 500.00$
 Concrete Elasticity, $E_c = 25742.96$
 Steel Elasticity, $E_s = 200000.00$
 Existing Column
 Existing material of Secondary Member: Concrete Strength, $f_c = f_{c_lower_bound} = 16.00$
 Existing material of Secondary Member: Steel Strength, $f_s = f_{s_lower_bound} = 420.00$
 Concrete Elasticity, $E_c = 23025.204$
 Steel Elasticity, $E_s = 200000.00$
 #####
 Note: Especially for the calculation of γ for displacement ductility demand,
 the expected (mean value) strengths are used (7.5.1.3, ASCE 41-17) because bending is considered as
 Deformation-Controlled Action (Table C7-1, ASCE 41-17).
 Jacket
 New material: Concrete Strength, $f_c = f_{cm} = 30.00$
 New material: Steel Strength, $f_s = f_{sm} = 625.00$
 Existing Column
 Existing material: Concrete Strength, $f_c = f_{cm} = 24.00$
 Existing material: Steel Strength, $f_s = f_{sm} = 525.00$
 #####
 Max Height, $H_{max} = 750.00$
 Min Height, $H_{min} = 450.00$
 Max Width, $W_{max} = 950.00$
 Min Width, $W_{min} = 450.00$
 Eccentricity, $E_{cc} = 250.00$
 Jacket Thickness, $t_j = 100.00$
 Cover Thickness, $c = 25.00$

Element Length, L = 3000.00
 Secondary Member
 Smooth Bars
 Ductile Steel
 Without Detailing for Earthquake Resistance (including stirrups not closed at 135°)
 Longitudinal Bars With Ends Lapped Starting at the End Sections
 Adequate Lap Length ($l_o/l_{ou,min} = l_b/l_d \geq 1$)
 No FRP Wrapping

Stepwise Properties

EDGE -A-
 Bending Moment, $M_a = 8159.13$
 Shear Force, $V_a = -1.3008$
 EDGE -B-
 Bending Moment, $M_b = -3480.992$
 Shear Force, $V_b = 1.3008$
 BOTH EDGES
 Axial Force, $F = -21838.055$
 Longitudinal Reinforcement Area Distribution (in 2 divisions)
 -Tension: $A_{st} = 0.00$
 -Compression: $A_{sc} = 6691.592$
 Longitudinal Reinforcement Area Distribution (in 3 divisions)
 -Tension: $A_{st,ten} = 1539.38$
 -Compression: $A_{sc,com} = 2475.575$
 -Middle: $A_{st,mid} = 2676.637$
 Mean Diameter of Tension Reinforcement, $Db_{L,ten} = 16.57143$

Existing component: From table 7-7, ASCE 41_17: Final Shear Capacity $V_R = V_n = 727734.241$
 V_n ((10.3), ASCE 41-17) = $k_n l V_{CoI} = 909667.801$
 $V_{CoI} = 909667.801$
 $k_n l = 1.00$
 displacement_ductility_demand = 1.5259160E-007

NOTE: In expression (10-3) ' $V_s = A_v f_y d/s$ ' is replaced by ' $V_s + f V_f$ '
 where V_f is the contribution of FRPs (11.3), ACI 440).

= 1 (normal-weight concrete)
 Mean concrete strength: $f'_c = (f'_{c,jacket} \text{Area}_{jacket} + f'_{c,core} \text{Area}_{core}) / \text{Area}_{section} = 18.13333$, but $f'_c^{0.5} \leq 8.3 \text{ MPa}$ (22.5.3.1, ACI 318-14)
 $M/Vd = 4.00$
 $M_u = 3480.992$
 $V_u = 1.3008$
 $d = 0.8 \cdot h = 600.00$
 $N_u = 21838.055$
 $A_g = 337500.00$
 From (11.5.4.8), ACI 318-14: $V_s = V_{sjacket} + V_{s,core} = 828294.726$
 where:
 $V_{sjacket} = V_{sj1} + V_{sj2} = 753982.237$
 $V_{sj1} = 471238.898$ is calculated for section web jacket, with:
 $d = 600.00$
 $A_v = 157079.633$
 $f_y = 500.00$
 $s = 100.00$
 V_{sj1} is multiplied by $Col_{j1} = 1.00$
 $s/d = 0.16666667$
 $V_{sj2} = 282743.339$ is calculated for section flange jacket, with:
 $d = 360.00$
 $A_v = 157079.633$
 $f_y = 500.00$
 $s = 100.00$
 V_{sj2} is multiplied by $Col_{j2} = 1.00$
 $s/d = 0.27777778$

$$V_{s,core} = V_{s,c1} + V_{s,c2} = 74312.489$$

$V_{s,c1} = 74312.489$ is calculated for section web core, with:

$$d = 440.00$$

$$A_v = 100530.965$$

$$f_y = 420.00$$

$$s = 250.00$$

$V_{s,c1}$ is multiplied by $Col,c1 = 1.00$

$$s/d = 0.56818182$$

$V_{s,c2} = 0.00$ is calculated for section flange core, with:

$$d = 200.00$$

$$A_v = 100530.965$$

$$f_y = 420.00$$

$$s = 250.00$$

$V_{s,c2}$ is multiplied by $Col,c2 = 0.00$

$$s/d = 1.25$$

$V_f ((11-3)-(11.4), ACI 440) = 0.00$

From (11-11), ACI 440: $V_s + V_f \leq 763781.865$

$$bw = 450.00$$

displacement ductility demand is calculated as δ / y

- Calculation of δ / y for END B -
for rotation axis 2 and integ. section (b)

From analysis, chord rotation $\theta = 7.5171959E-010$

$$y = (M_y * L_s / 3) / E_{eff} = 0.00492635 ((4.29), Biskinis Phd)$$

$$M_y = 9.4092E+008$$

$$L_s = M/V \text{ (with } L_s > 0.1 * L \text{ and } L_s < 2 * L) = 2676.049$$

From table 10.5, ASCE 41_17: $E_{eff} = factor * E_c * I_g = 1.7037E+014$

$$factor = 0.30$$

$$A_g = 562500.00$$

$$\text{Mean concrete strength: } f'_c = (f'_c_{jacket} * Area_{jacket} + f'_c_{core} * Area_{core}) / Area_{section} = 27.20$$

$$N = 21838.055$$

$$E_c * I_g = E_{c,jacket} * I_{g,jacket} + E_{c,core} * I_{g,core} = 5.6791E+014$$

Calculation of Yielding Moment M_y

Calculation of δ / y and M_y according to Annex 7 -

Assuming neutral axis within flange ($y < t/d$, compression zone rectangular) with:

flange width, $b = 950.00$

web width, $bw = 450.00$

flange thickness, $t = 450.00$

$$y = \text{Min}(y_{ten}, y_{com})$$

$$y_{ten} = 5.3414671E-006$$

with $f_y = 601.9953$

$$d = 707.00$$

$$y = 0.20295445$$

$$A = 0.01001693$$

$$B = 0.00468389$$

with $p_t = 0.00229194$

$$p_c = 0.00368581$$

$$p_v = 0.00398517$$

$$N = 21838.055$$

$$b = 950.00$$

$$\rho = 0.06082037$$

$$y_{comp} = 1.4673916E-005$$

with $f_c = 30.00$

$$E_c = 25742.96$$

$$y = 0.20219473$$

$$A = 0.00988542$$

$$B = 0.00462988$$

with $E_s = 200000.00$
CONFIRMATION: $y = 0.20295445 < t/d$

Calculation of ratio I_b/I_d

Adequate Lap Length: $I_b/I_d \geq 1$

End Of Calculation of Shear Capacity for element: column JTC1 of floor 1

At local axis: 3

Integration Section: (b)

Calculation No. 8

column C1, Floor 1


Limit State: Operational Level (data interpolation between analysis steps 1 and 2)

Analysis: Uniform +X

Check: Chord rotation capacity (ϕ)

Edge: End

Local Axis: (3)



Start Of Calculation of Shear Capacity ratio for element: column JTC1 of floor 1

At Shear local axis: 3

(Bending local axis: 2)

Section Type: rcjtcs

Constant Properties

Knowledge Factor, $\gamma = 0.80$

Mean strength values are used for both shear and moment calculations.

Consequently:

Jacket

New material of Secondary Member: Concrete Strength, $f_c = f_{cm} = 30.00$

New material of Secondary Member: Steel Strength, $f_s = f_{sm} = 625.00$

Concrete Elasticity, $E_c = 25742.96$

Steel Elasticity, $E_s = 200000.00$

Existing Column

Existing material of Secondary Member: Concrete Strength, $f_c = f_{cm} = 24.00$
 Existing material of Secondary Member: Steel Strength, $f_s = f_{sm} = 525.00$
 Concrete Elasticity, $E_c = 23025.204$
 Steel Elasticity, $E_s = 200000.00$
 #####
 Note: Especially for the calculation of moment strengths,
 the above steel re-bar strengths are multiplied by 1.25 according to R18.6.5, ACI 318-14
 Jacket
 New material: Steel Strength, $f_s = 1.25 \cdot f_{sm} = 781.25$
 Existing Column
 Existing material: Steel Strength, $f_s = 1.25 \cdot f_{sm} = 656.25$
 #####
 Max Height, $H_{max} = 750.00$
 Min Height, $H_{min} = 450.00$
 Max Width, $W_{max} = 950.00$
 Min Width, $W_{min} = 450.00$
 Eccentricity, $Ecc = 250.00$
 Jacket Thickness, $t_j = 100.00$
 Cover Thickness, $c = 25.00$
 Mean Confinement Factor overall section = 1.00
 Element Length, $L = 3000.00$
 Secondary Member
 Smooth Bars
 Ductile Steel
 Without Detailing for Earthquake Resistance (including stirrups not closed at 135°)
 Longitudinal Bars With Ends Lapped Starting at the End Sections
 Adequate Lap Length ($l_o/l_{ou,min} > 1$)
 No FRP Wrapping

Stepwise Properties

At local axis: 3
 EDGE -A-
 Shear Force, $V_a = -8.5087964E-020$
 EDGE -B-
 Shear Force, $V_b = 8.5087964E-020$
 BOTH EDGES
 Axial Force, $F = -20792.05$
 Longitudinal Reinforcement Area Distribution (in 2 divisions)
 -Tension: $As_t = 0.00$
 -Compression: $As_c = 6691.592$
 Longitudinal Reinforcement Area Distribution (in 3 divisions)
 -Tension: $As_{t,ten} = 1539.38$
 -Compression: $As_{l,com} = 2475.575$
 -Middle: $As_{l,mid} = 2676.637$

Calculation of Shear Capacity ratio, $V_e/V_r = 1.11674$
 Member Controlled by Shear ($V_e/V_r > 1$)
 Calculation of Shear Demand from fig. R18.6.5, ACI 318-14 $V_e = (M_{pr1} + M_{pr2})/l_n = 1.4424E+006$
 with
 $M_{pr1} = \text{Max}(\mu_{u1+}, \mu_{u1-}) = 2.1636E+009$
 $\mu_{u1+} = 2.0419E+009$, is the ultimate moment strength at the edge 1 of the member in the actual moment direction
 which is defined for the static loading combination
 $\mu_{u1-} = 2.1636E+009$, is the ultimate moment strength at the edge 1 of the member in the opposite moment
 direction which is defined for the static loading combination
 $M_{pr2} = \text{Max}(\mu_{u2+}, \mu_{u2-}) = 2.1636E+009$
 $\mu_{u2+} = 2.0419E+009$, is the ultimate moment strength at the edge 2 of the member in the actual moment direction
 which is defined for the the static loading combination
 $\mu_{u2-} = 2.1636E+009$, is the ultimate moment strength at the edge 2 of the member in the opposite moment
 direction which is defined for the the static loading combination

Calculation of μ_{u1+}

Calculation of ultimate curvature ϕ_u according to 4.1, Biskinis/Fardis 2013:

$$u = 5.3321191E-005$$

$$\mu = 2.0419E+009$$

with full section properties:

$$b = 950.00$$

$$d = 707.00$$

$$d' = 43.00$$

$$v = 0.00103189$$

$$N = 20792.05$$

$$f_c = 30.00$$

$$\alpha (5A.5, \text{TBDY}) = 0.002$$

$$\text{Final value of } \phi_u: \phi_u^* = \text{shear_factor} * \text{Max}(\phi_u, \phi_c) = 0.00832321$$

The Shear_factor is considered equal to 1 (pure moment strength)

$$\text{From (5.4b), TBDY: } \phi_u = 0.00832321$$

$$\phi_{ue} (5.4c) = 0.01453958$$

$$\alpha_{se} ((5.4d), \text{TBDY}) = (\alpha_{se1} * A_{ext} + \alpha_{se2} * A_{int}) / A_{sec} = 0.53375773$$

$$\alpha_{se1} = \text{Max}(((A_{conf,max1} - A_{noConf1}) / A_{conf,max1}) * (A_{conf,min1} / A_{conf,max1}), 0) = 0.53375773$$

The definitions of A_{noConf} , $A_{conf,min}$ and $A_{conf,max}$ are derived from generalization of the rectangular sections confinement, which is expressed by (5.4d).

The generalization is done according to Mander, J., Priestley, M., and Park, R. (1988)

"Theoretical Stress-Strain Model for Confined Concrete."

J. Struct. Eng., 10.1061/(ASCE)0733-9445(1988)114:8(1804), 1804-1826.

$A_{conf,max1} = 464100.00$ is the confined core area at levels of member with hoops and is calculated as the area of core enclosed by the center lines of the external perimeter hoops.

$A_{conf,min1} = 395025.00$ is the confined core area at midway between the levels of hoops and is calculated by reducing all the dimensions of the area $A_{conf,max1}$ by a length equal to half the clear spacing between external hoops.

$A_{noConf1} = 173066.667$ is the unconfined external core area which is equal to $b_i d_i / 6$ as defined at (A.2).

$$\alpha_{se2} (> \alpha_{se1}) = \text{Max}(((A_{conf,max2} - A_{noConf2}) / A_{conf,max2}) * (A_{conf,min2} / A_{conf,max2}), 0) = 0.53375773$$

The definitions of A_{noConf} , $A_{conf,min}$ and $A_{conf,max}$ are derived from generalization of the rectangular sections confinement, which is expressed by (5.4d).

The generalization is done according to Mander, J., Priestley, M., and Park, R. (1988)

"Theoretical Stress-Strain Model for Confined Concrete."

J. Struct. Eng., 10.1061/(ASCE)0733-9445(1988)114:8(1804), 1804-1826.

$A_{conf,max2} = 252164.00$ is the confined core area at levels of member with hoops and is calculated as the area of core enclosed by the center lines of the internal perimeter hoops.

$A_{conf,min2} = 111441.00$ is the confined core area at midway between the levels of hoops and is calculated by reducing all the dimensions of the area $A_{conf,max2}$ by a length equal to half the clear spacing between internal hoops.

$A_{noConf2} = 110709.333$ is the unconfined internal core area which is equal to $b_i d_i / 6$ as defined at (A.2).

$$p_{sh,min} * F_{ywe} = \text{Min}(p_{sh,x} * F_{ywe}, p_{sh,y} * F_{ywe}) = 2.724$$

Expression (5.4d) for $p_{sh,min} * F_{ywe}$ has been multiplied by 0.3 according to 15.7.1.3 for members without earthquake detailing (90° closed stirrups)

$$p_{sh,x} * F_{ywe} = p_{sh1} * F_{ywe1} + p_{sh2} * F_{ywe2} = 2.724$$

$$p_{sh1} ((5.4d), \text{TBDY}) = L_{stir1} * A_{stir1} / (A_{sec} * s_1) = 0.00301593$$

$$L_{stir1} (\text{Length of stirrups along Y}) = 2160.00$$

$$A_{stir1} (\text{stirrups area}) = 78.53982$$

$$p_{sh2} (5.4d) = L_{stir2} * A_{stir2} / (A_{sec} * s_2) = 0.00056047$$

$$L_{stir2} (\text{Length of stirrups along Y}) = 1568.00$$

$$A_{stir2} (\text{stirrups area}) = 50.26548$$

$$p_{sh,y} * F_{ywe} = p_{sh1} * F_{ywe1} + p_{sh2} * F_{ywe2} = 3.25416$$

$$p_{sh1} ((5.4d), \text{TBDY}) = L_{stir1} * A_{stir1} / (A_{sec} * s_1) = 0.00357443$$

$$L_{stir1} (\text{Length of stirrups along X}) = 2560.00$$

$$A_{stir1} (\text{stirrups area}) = 78.53982$$

$$p_{sh2} ((5.4d), \text{TBDY}) = L_{stir2} * A_{stir2} / (A_{sec} * s_2) = 0.00070345$$

$$L_{stir2} (\text{Length of stirrups along X}) = 1968.00$$

$$A_{stir2} (\text{stirrups area}) = 50.26548$$

$$A_{sec} = 562500.00$$

$$s_1 = 100.00$$

$$s_2 = 250.00$$

$fy_{we1} = 781.25$
 $fy_{we2} = 656.25$
 $f_{ce} = 30.00$
 From ((5.A.5), TBDY), TBDY: $cc = 0.002$
 $c = \text{confinement factor} = 1.00$
 $y_1 = 0.0025$
 $sh_1 = 0.008$
 $ft_1 = 907.50$
 $fy_1 = 756.25$
 $su_1 = 0.032$
 using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
 and also multiplied by the shear_factor according to 15.7.1.4, with
 $Shear_factor = 1.00$
 $lo/lou, min = lb/ld = 1.00$
 $su_1 = 0.4 * esu_1_nominal ((5.5), TBDY) = 0.032$
 From table 5A.1, TBDY: $esu_1_nominal = 0.08$,
 For calculation of $esu_1_nominal$ and y_1, sh_1, ft_1, fy_1 , it is considered
 characteristic value $fsy_1 = fs_1/1.2$, from table 5.1, TBDY.
 y_1, sh_1, ft_1, fy_1 , are also multiplied by $Min(1, 1.25 * (lb/ld)^{2/3})$, from 10.3.5, ASCE 41-17.
 with $fs_1 = (fs_{jacket} * Asl_{ten, jacket} + fs_{core} * Asl_{ten, core}) / Asl_{ten} = 756.25$
 with $Es_1 = (Es_{jacket} * Asl_{ten, jacket} + Es_{core} * Asl_{ten, core}) / Asl_{ten} = 200000.00$
 $y_2 = 0.0025$
 $sh_2 = 0.008$
 $ft_2 = 900.1904$
 $fy_2 = 750.1586$
 $su_2 = 0.032$
 using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
 and also multiplied by the shear_factor according to 15.7.1.4, with
 $Shear_factor = 1.00$
 $lo/lou, min = lb/lb, min = 1.00$
 $su_2 = 0.4 * esu_2_nominal ((5.5), TBDY) = 0.032$
 From table 5A.1, TBDY: $esu_2_nominal = 0.08$,
 For calculation of $esu_2_nominal$ and y_2, sh_2, ft_2, fy_2 , it is considered
 characteristic value $fsy_2 = fs_2/1.2$, from table 5.1, TBDY.
 y_1, sh_1, ft_1, fy_1 , are also multiplied by $Min(1, 1.25 * (lb/ld)^{2/3})$, from 10.3.5, ASCE 41-17.
 with $fs_2 = (fs_{jacket} * Asl_{com, jacket} + fs_{core} * Asl_{com, core}) / Asl_{com} = 750.1586$
 with $Es_2 = (Es_{jacket} * Asl_{com, jacket} + Es_{core} * Asl_{com, core}) / Asl_{com} = 200000.00$
 $y_v = 0.0025$
 $sh_v = 0.008$
 $ft_v = 902.993$
 $fy_v = 752.4941$
 $suv = 0.032$
 using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
 and also multiplied by the shear_factor according to 15.7.1.4, with
 $Shear_factor = 1.00$
 $lo/lou, min = lb/ld = 1.00$
 $suv = 0.4 * esuv_nominal ((5.5), TBDY) = 0.032$
 From table 5A.1, TBDY: $esuv_nominal = 0.08$,
 considering characteristic value $fsyv = fs_v/1.2$, from table 5.1, TBDY
 For calculation of $esuv_nominal$ and y_v, sh_v, ft_v, fy_v , it is considered
 characteristic value $fsyv = fs_v/1.2$, from table 5.1, TBDY.
 y_1, sh_1, ft_1, fy_1 , are also multiplied by $Min(1, 1.25 * (lb/ld)^{2/3})$, from 10.3.5, ASCE 41-17.
 with $fs_v = (fs_{jacket} * Asl_{mid, jacket} + fs_{mid} * Asl_{mid, core}) / Asl_{mid} = 752.4941$
 with $Es_v = (Es_{jacket} * Asl_{mid, jacket} + Es_{mid} * Asl_{mid, core}) / Asl_{mid} = 200000.00$
 $1 = Asl_{ten} / (b * d) * (fs_1 / f_c) = 0.05777595$
 $2 = Asl_{com} / (b * d) * (fs_2 / f_c) = 0.09216477$
 $v = Asl_{mid} / (b * d) * (fs_v / f_c) = 0.09996047$
 and confined core properties:
 $b = 890.00$
 $d = 677.00$
 $d' = 13.00$
 $f_{cc} (5A.2, TBDY) = 30.00$
 $cc (5A.5, TBDY) = 0.002$
 $c = \text{confinement factor} = 1.00$
 $1 = Asl_{ten} / (b * d) * (fs_1 / f_c) = 0.06440379$
 $2 = Asl_{com} / (b * d) * (fs_2 / f_c) = 0.10273757$
 $v = Asl_{mid} / (b * d) * (fs_v / f_c) = 0.11142757$

Case/Assumption: Unconfined full section - Steel rupture
' satisfies Eq. (4.3)

--->
 $v < v_{s,y2}$ - LHS eq.(4.5) is not satisfied
--->
 $v < v_{s,c}$ - RHS eq.(4.5) is satisfied
--->
 $s_u(4.8) = 0.15115045$
 $M_u = M_{Rc}(4.15) = 2.0419E+009$
 $u = s_u(4.1) = 5.3321191E-005$

Calculation of ratio I_b/I_d

Adequate Lap Length: $I_b/I_d \geq 1$

Calculation of M_{u1} -

Calculation of ultimate curvature u according to 4.1, Biskinis/Fardis 2013:
 $u = 6.8287974E-005$
 $M_u = 2.1636E+009$

with full section properties:

$b = 450.00$
 $d = 707.00$
 $d' = 43.00$
 $v = 0.00217843$
 $N = 20792.05$
 $f_c = 30.00$
 $\alpha(5A.5, TBDY) = 0.002$
Final value of α : $\alpha^* = \text{shear_factor} * \text{Max}(\alpha_c, \alpha) = 0.00832321$
The Shear_factor is considered equal to 1 (pure moment strength)
From (5.4b), TBDY: $\alpha_c = 0.00832321$
 $w_e(5.4c) = 0.01453958$
 $\alpha_{se}((5.4d), TBDY) = (\alpha_{se1} * A_{ext} + \alpha_{se2} * A_{int}) / A_{sec} = 0.53375773$
 $\alpha_{se1} = \text{Max}(((A_{conf,max1} - A_{noConf1}) / A_{conf,max1}) * (A_{conf,min1} / A_{conf,max1}), 0) = 0.53375773$
The definitions of A_{noConf} , $A_{conf,min}$ and $A_{conf,max}$ are derived from generalization of the rectangular sections confinement, which is expressed by (5.4d).
The generalization is done according to Mander, J., Priestley, M., and Park, R. (1988) "Theoretical Stress-Strain Model for Confined Concrete."
J. Struct. Eng., 10.1061/(ASCE)0733-9445(1988)114:8(1804), 1804-1826.
 $A_{conf,max1} = 464100.00$ is the confined core area at levels of member with hoops and is calculated as the area of core enclosed by the center lines of the external perimeter hoops.
 $A_{conf,min1} = 395025.00$ is the confined core area at midway between the levels of hoops and is calculated by reducing all the dimensions of the area $A_{conf,max1}$ by a length equal to half the clear spacing between external hoops.
 $A_{noConf1} = 173066.667$ is the unconfined external core area which is equal to $b_i^2/6$ as defined at (A.2).
 $\alpha_{se2} (\geq \alpha_{se1}) = \text{Max}(((A_{conf,max2} - A_{noConf2}) / A_{conf,max2}) * (A_{conf,min2} / A_{conf,max2}), 0) = 0.53375773$
The definitions of A_{noConf} , $A_{conf,min}$ and $A_{conf,max}$ are derived from generalization of the rectangular sections confinement, which is expressed by (5.4d).
The generalization is done according to Mander, J., Priestley, M., and Park, R. (1988) "Theoretical Stress-Strain Model for Confined Concrete."
J. Struct. Eng., 10.1061/(ASCE)0733-9445(1988)114:8(1804), 1804-1826.
 $A_{conf,max2} = 252164.00$ is the confined core area at levels of member with hoops and is calculated as the area of core enclosed by the center lines of the internal perimeter hoops.
 $A_{conf,min2} = 111441.00$ is the confined core area at midway between the levels of hoops and is calculated by reducing all the dimensions of the area $A_{conf,max2}$ by a length equal to half the clear spacing between internal hoops.
 $A_{noConf2} = 110709.333$ is the unconfined internal core area which is equal to $b_i^2/6$ as defined at (A.2).
 $p_{sh,min} * F_{ywe} = \text{Min}(p_{sh,x} * F_{ywe}, p_{sh,y} * F_{ywe}) = 2.724$
Expression (5.4d) for $p_{sh,min} * F_{ywe}$ has been multiplied by 0.3 according to 15.7.1.3 for members without earthquake detailing (90° closed stirrups)

$psh_x * Fywe = psh1 * Fywe1 + ps2 * Fywe2 = 2.724$
 $psh1 \text{ ((5.4d), TBDY)} = Lstir1 * Astir1 / (Asec * s1) = 0.00301593$
 $Lstir1 \text{ (Length of stirrups along Y)} = 2160.00$
 $Astir1 \text{ (stirrups area)} = 78.53982$
 $psh2 \text{ (5.4d)} = Lstir2 * Astir2 / (Asec * s2) = 0.00056047$
 $Lstir2 \text{ (Length of stirrups along Y)} = 1568.00$
 $Astir2 \text{ (stirrups area)} = 50.26548$

$psh_y * Fywe = psh1 * Fywe1 + ps2 * Fywe2 = 3.25416$
 $psh1 \text{ ((5.4d), TBDY)} = Lstir1 * Astir1 / (Asec * s1) = 0.00357443$
 $Lstir1 \text{ (Length of stirrups along X)} = 2560.00$
 $Astir1 \text{ (stirrups area)} = 78.53982$
 $psh2 \text{ ((5.4d), TBDY)} = Lstir2 * Astir2 / (Asec * s2) = 0.00070345$
 $Lstir2 \text{ (Length of stirrups along X)} = 1968.00$
 $Astir2 \text{ (stirrups area)} = 50.26548$

$Asec = 562500.00$
 $s1 = 100.00$
 $s2 = 250.00$
 $fywe1 = 781.25$
 $fywe2 = 656.25$
 $fce = 30.00$

From ((5.A5), TBDY), TBDY: $cc = 0.002$
 $c = \text{confinement factor} = 1.00$

$y1 = 0.0025$
 $sh1 = 0.008$
 $ft1 = 900.1904$
 $fy1 = 750.1586$
 $su1 = 0.032$

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
 and also multiplied by the shear_factor according to 15.7.1.4, with
 $Shear_factor = 1.00$
 $lo/lou, min = lb/ld = 1.00$

$su1 = 0.4 * esu1_nominal \text{ ((5.5), TBDY)} = 0.032$

From table 5A.1, TBDY: $esu1_nominal = 0.08$,

For calculation of $esu1_nominal$ and $y1, sh1, ft1, fy1$, it is considered
 characteristic value $fsy1 = fs1/1.2$, from table 5.1, TBDY.

$y1, sh1, ft1, fy1$, are also multiplied by $\text{Min}(1, 1.25 * (lb/ld)^{2/3})$, from 10.3.5, ASCE 41-17.

with $fs1 = (fs_jacket * Asl, ten, jacket + fs_core * Asl, ten, core) / Asl, ten = 750.1586$

with $Es1 = (Es_jacket * Asl, ten, jacket + Es_core * Asl, ten, core) / Asl, ten = 200000.00$

$y2 = 0.0025$
 $sh2 = 0.008$
 $ft2 = 907.50$
 $fy2 = 756.25$
 $su2 = 0.032$

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
 and also multiplied by the shear_factor according to 15.7.1.4, with
 $Shear_factor = 1.00$

$lo/lou, min = lb/lb, min = 1.00$

$su2 = 0.4 * esu2_nominal \text{ ((5.5), TBDY)} = 0.032$

From table 5A.1, TBDY: $esu2_nominal = 0.08$,

For calculation of $esu2_nominal$ and $y2, sh2, ft2, fy2$, it is considered
 characteristic value $fsy2 = fs2/1.2$, from table 5.1, TBDY.

$y2, sh2, ft2, fy2$, are also multiplied by $\text{Min}(1, 1.25 * (lb/ld)^{2/3})$, from 10.3.5, ASCE 41-17.

with $fs2 = (fs_jacket * Asl, com, jacket + fs_core * Asl, com, core) / Asl, com = 756.25$

with $Es2 = (Es_jacket * Asl, com, jacket + Es_core * Asl, com, core) / Asl, com = 200000.00$

$yv = 0.0025$
 $shv = 0.008$
 $ftv = 902.993$
 $fyv = 752.4941$
 $suv = 0.032$

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
 and also multiplied by the shear_factor according to 15.7.1.4, with
 $Shear_factor = 1.00$

$lo/lou, min = lb/ld = 1.00$

$suv = 0.4 * esuv_nominal \text{ ((5.5), TBDY)} = 0.032$

From table 5A.1, TBDY: $esuv_nominal = 0.08$,

considering characteristic value $f_{syv} = f_{sv}/1.2$, from table 5.1, TBDY

For calculation of $e_{suv_nominal}$ and y_v , sh_v , ft_v , fy_v , it is considered characteristic value $f_{syv} = f_{sv}/1.2$, from table 5.1, TBDY.

y_1 , sh_1 , ft_1 , fy_1 , are also multiplied by $\text{Min}(1, 1.25 \cdot (l_b/l_d)^{2/3})$, from 10.3.5, ASCE 41-17.

with $f_{sv} = (f_{s,jacket} \cdot A_{sl,mid,jacket} + f_{s,mid} \cdot A_{sl,mid,core}) / A_{sl,mid} = 752.4941$

with $E_{sv} = (E_{s,jacket} \cdot A_{sl,mid,jacket} + E_{s,mid} \cdot A_{sl,mid,core}) / A_{sl,mid} = 200000.00$

$1 = A_{sl,ten} / (b \cdot d) \cdot (f_{s1} / f_c) = 0.19457006$

$2 = A_{sl,com} / (b \cdot d) \cdot (f_{s2} / f_c) = 0.12197144$

$v = A_{sl,mid} / (b \cdot d) \cdot (f_{sv} / f_c) = 0.21102767$

and confined core properties:

$b = 390.00$

$d = 677.00$

$d' = 13.00$

f_{cc} (5A.2, TBDY) = 30.00

cc (5A.5, TBDY) = 0.002

c = confinement factor = 1.00

$1 = A_{sl,ten} / (b \cdot d) \cdot (f_{s1} / f_c) = 0.23445239$

$2 = A_{sl,com} / (b \cdot d) \cdot (f_{s2} / f_c) = 0.14697275$

$v = A_{sl,mid} / (b \cdot d) \cdot (f_{sv} / f_c) = 0.25428343$

Case/Assumption: Unconfined full section - Steel rupture

' satisfies Eq. (4.3)

---->

$v < v_{s,y2}$ - LHS eq.(4.5) is not satisfied

---->

$v < v_{s,c}$ - RHS eq.(4.5) is satisfied

---->

su (4.8) = 0.33719414

$Mu = MR_c$ (4.15) = 2.1636E+009

$u = su$ (4.1) = 6.8287974E-005

Calculation of ratio l_b/l_d

Adequate Lap Length: $l_b/l_d \geq 1$

Calculation of Mu_{2+}

Calculation of ultimate curvature u according to 4.1, Biskinis/Fardis 2013:

$u = 5.3321191E-005$

$Mu = 2.0419E+009$

with full section properties:

$b = 950.00$

$d = 707.00$

$d' = 43.00$

$v = 0.00103189$

$N = 20792.05$

$f_c = 30.00$

co (5A.5, TBDY) = 0.002

Final value of cu : $cu^* = \text{shear_factor} \cdot \text{Max}(cu, cc) = 0.00832321$

The Shear_factor is considered equal to 1 (pure moment strength)

From (5.4b), TBDY: $cu = 0.00832321$

we (5.4c) = 0.01453958

ase ((5.4d), TBDY) = $(ase1 \cdot A_{ext} + ase2 \cdot A_{int}) / A_{sec} = 0.53375773$

$ase1 = \text{Max}(((A_{conf,max1} - A_{noConf1}) / A_{conf,max1}) \cdot (A_{conf,min1} / A_{conf,max1}), 0) = 0.53375773$

The definitions of A_{noConf} , $A_{conf,min}$ and $A_{conf,max}$ are derived from generalization of the rectangular sections confinement, which is expressed by (5.4d).

The generalization is done according to Mander, J., Priestley, M., and Park, R. (1988)

"Theoretical Stress-Strain Model for Confined Concrete."

J. Struct. Eng., 10.1061/(ASCE)0733-9445(1988)114:8(1804), 1804-1826.

$A_{conf,max1} = 464100.00$ is the confined core area at levels of member with hoops and

is calculated as the area of core enclosed by the center lines of the external perimeter hoops.

$A_{conf,min1} = 395025.00$ is the confined core area at midway between the levels of hoops and

is calculated by reducing all the dimensions of the area $A_{conf,max1}$ by a length equal to half the clear spacing between external hoops.

$A_{noConf1} = 173066.667$ is the unconfined external core area which is equal to $b_i/6$ as defined at (A.2).
 $ase2 (>=ase1) = \text{Max}(((A_{conf,max2}-A_{noConf2})/A_{conf,max2})*(A_{conf,min2}/A_{conf,max2}),0) = 0.53375773$

The definitions of A_{noConf} , $A_{conf,min}$ and $A_{conf,max}$ are derived from generalization of the rectangular sections confinement, which is expressed by (5.4d).

The generalization is done according to Mander, J., Priestley, M., and Park, R. (1988) "Theoretical Stress-Strain Model for Confined Concrete."

J. Struct. Eng., 10.1061/(ASCE)0733-9445(1988)114:8(1804), 1804-1826.

$A_{conf,max2} = 252164.00$ is the confined core area at levels of member with hoops and is calculated as the area of core enclosed by the center lines of the internal perimeter hoops.

$A_{conf,min2} = 111441.00$ is the confined core area at midway between the levels of hoops and is calculated by reducing all the dimensions of the area $A_{conf,max2}$ by a length equal to half the clear spacing between internal hoops.

$A_{noConf2} = 110709.333$ is the unconfined internal core area which is equal to $b_i/6$ as defined at (A.2).
 $psh,min*F_{ywe} = \text{Min}(psh,x*F_{ywe}, psh,y*F_{ywe}) = 2.724$

Expression (5.4d) for $psh,min*F_{ywe}$ has been multiplied by 0.3 according to 15.7.1.3 for members without earthquake detailing (90° closed stirrups)

 $psh,x*F_{ywe} = psh1*F_{ywe1} + ps2*F_{ywe2} = 2.724$
 $psh1 ((5.4d), TBDY) = L_{stir1}*A_{stir1}/(A_{sec}*s1) = 0.00301593$
 L_{stir1} (Length of stirrups along Y) = 2160.00
 A_{stir1} (stirrups area) = 78.53982
 $psh2 ((5.4d)) = L_{stir2}*A_{stir2}/(A_{sec}*s2) = 0.00056047$
 L_{stir2} (Length of stirrups along Y) = 1568.00
 A_{stir2} (stirrups area) = 50.26548

 $psh,y*F_{ywe} = psh1*F_{ywe1} + ps2*F_{ywe2} = 3.25416$
 $psh1 ((5.4d), TBDY) = L_{stir1}*A_{stir1}/(A_{sec}*s1) = 0.00357443$
 L_{stir1} (Length of stirrups along X) = 2560.00
 A_{stir1} (stirrups area) = 78.53982
 $psh2 ((5.4d), TBDY) = L_{stir2}*A_{stir2}/(A_{sec}*s2) = 0.00070345$
 L_{stir2} (Length of stirrups along X) = 1968.00
 A_{stir2} (stirrups area) = 50.26548

 $A_{sec} = 562500.00$

$s1 = 100.00$

$s2 = 250.00$

$f_{ywe1} = 781.25$

$f_{ywe2} = 656.25$

$f_{ce} = 30.00$

From ((5.A5), TBDY), TBDY: $cc = 0.002$

c = confinement factor = 1.00

$y1 = 0.0025$

$sh1 = 0.008$

$ft1 = 907.50$

$fy1 = 756.25$

$su1 = 0.032$

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor and also multiplied by the shear_factor according to 15.7.1.4, with Shear_factor = 1.00

$l_o/l_{ou,min} = l_b/l_d = 1.00$

$su1 = 0.4*es_{u1,nominal} ((5.5), TBDY) = 0.032$

From table 5A.1, TBDY: $es_{u1,nominal} = 0.08$,

For calculation of $es_{u1,nominal}$ and $y1, sh1, ft1, fy1$, it is considered characteristic value $fs_{y1} = fs_{y1}/1.2$, from table 5.1, TBDY.

$y1, sh1, ft1, fy1$, are also multiplied by $\text{Min}(1, 1.25*(l_b/l_d)^{2/3})$, from 10.3.5, ASCE 41-17.

with $fs_1 = (f_{s,jacket}*A_{s1,ten,jacket} + f_{s,core}*A_{s1,ten,core})/A_{s1,ten} = 756.25$

with $Es_1 = (E_{s,jacket}*A_{s1,ten,jacket} + E_{s,core}*A_{s1,ten,core})/A_{s1,ten} = 200000.00$

$y2 = 0.0025$

$sh2 = 0.008$

$ft2 = 900.1904$

$fy2 = 750.1586$

$su2 = 0.032$

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor and also multiplied by the shear_factor according to 15.7.1.4, with Shear_factor = 1.00

```

lo/lou,min = lb/lbmin = 1.00
su2 = 0.4*esu2,nominal ((5.5), TBDY) = 0.032
From table 5A.1, TBDY: esu2,nominal = 0.08,
For calculation of esu2,nominal and y2, sh2,ft2,fy2, it is considered
characteristic value fsy2 = fs2/1.2, from table 5.1, TBDY.
y1, sh1,ft1,fy1, are also multiplied by Min(1,1.25*(lb/ld)2/3), from 10.3.5, ASCE 41-17.
with fs2 = (fsjacket*Aslcom,jacket + fscore*Aslcom,core)/Aslcom = 750.1586
with Es2 = (Esjacket*Aslcom,jacket + Escore*Aslcom,core)/Aslcom = 200000.00
yv = 0.0025
shv = 0.008
ftv = 902.993
fyv = 752.4941
suv = 0.032
using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00
lo/lou,min = lb/ld = 1.00
suv = 0.4*esuvnominal ((5.5), TBDY) = 0.032
From table 5A.1, TBDY: esuvnominal = 0.08,
considering characteristic value fsyv = fsv/1.2, from table 5.1, TBDY
For calculation of esuvnominal and yv, shv,ftv,fyv, it is considered
characteristic value fsyv = fsv/1.2, from table 5.1, TBDY.
y1, sh1,ft1,fy1, are also multiplied by Min(1,1.25*(lb/ld)2/3), from 10.3.5, ASCE 41-17.
with fsv = (fsjacket*Aslmid,jacket + fsmid*Aslmid,core)/Aslmid = 752.4941
with Esv = (Esjacket*Aslmid,jacket + Esmid*Aslmid,core)/Aslmid = 200000.00
1 = Aslten/(b*d)*(fs1/fc) = 0.05777595
2 = Aslcom/(b*d)*(fs2/fc) = 0.09216477
v = Aslmid/(b*d)*(fsv/fc) = 0.09996047
and confined core properties:
b = 890.00
d = 677.00
d' = 13.00
fcc (5A.2, TBDY) = 30.00
cc (5A.5, TBDY) = 0.002
c = confinement factor = 1.00
1 = Aslten/(b*d)*(fs1/fc) = 0.06440379
2 = Aslcom/(b*d)*(fs2/fc) = 0.10273757
v = Aslmid/(b*d)*(fsv/fc) = 0.11142757
Case/Assumption: Unconfined full section - Steel rupture
'satisfies Eq. (4.3)
---->
v < vsy2 - LHS eq.(4.5) is not satisfied
---->
v < vsc - RHS eq.(4.5) is satisfied
---->
su (4.8) = 0.15115045
Mu = MRc (4.15) = 2.0419E+009
u = su (4.1) = 5.3321191E-005

```

Calculation of ratio lb/l_d

Adequate Lap Length: lb/l_d >= 1

Calculation of Mu₂-

Calculation of ultimate curvature u according to 4.1, Biskinis/Fardis 2013:

$$u = 6.8287974E-005$$

$$Mu = 2.1636E+009$$

with full section properties:

$$b = 450.00$$

$$d = 707.00$$

$d' = 43.00$
 $v = 0.00217843$
 $N = 20792.05$
 $f_c = 30.00$
 $co (5A.5, TBDY) = 0.002$
 Final value of cu : $cu^* = shear_factor * Max(cu, cc) = 0.00832321$
 The Shear_factor is considered equal to 1 (pure moment strength)
 From (5.4b), TBDY: $cu = 0.00832321$
 $we (5.4c) = 0.01453958$
 $ase ((5.4d), TBDY) = (ase1 * A_{ext} + ase2 * A_{int}) / A_{sec} = 0.53375773$
 $ase1 = Max(((A_{conf,max1} - A_{noConf1}) / A_{conf,max1}) * (A_{conf,min1} / A_{conf,max1}), 0) = 0.53375773$
 The definitions of A_{noConf} , $A_{conf,min}$ and $A_{conf,max}$ are derived from generalization of the rectangular sections confinement, which is expressed by (5.4d).
 The generalization is done according to Mander, J., Priestley, M., and Park, R. (1988) "Theoretical Stress-Strain Model for Confined Concrete."
 J. Struct. Eng., 10.1061/(ASCE)0733-9445(1988)114:8(1804), 1804-1826.
 $A_{conf,max1} = 464100.00$ is the confined core area at levels of member with hoops and is calculated as the area of core enclosed by the center lines of the external perimeter hoops.
 $A_{conf,min1} = 395025.00$ is the confined core area at midway between the levels of hoops and is calculated by reducing all the dimensions of the area $A_{conf,max1}$ by a length equal to half the clear spacing between external hoops.
 $A_{noConf1} = 173066.667$ is the unconfined external core area which is equal to $b_i^2/6$ as defined at (A.2).
 $ase2 (>= ase1) = Max(((A_{conf,max2} - A_{noConf2}) / A_{conf,max2}) * (A_{conf,min2} / A_{conf,max2}), 0) = 0.53375773$
 The definitions of A_{noConf} , $A_{conf,min}$ and $A_{conf,max}$ are derived from generalization of the rectangular sections confinement, which is expressed by (5.4d).
 The generalization is done according to Mander, J., Priestley, M., and Park, R. (1988) "Theoretical Stress-Strain Model for Confined Concrete."
 J. Struct. Eng., 10.1061/(ASCE)0733-9445(1988)114:8(1804), 1804-1826.
 $A_{conf,max2} = 252164.00$ is the confined core area at levels of member with hoops and is calculated as the area of core enclosed by the center lines of the internal perimeter hoops.
 $A_{conf,min2} = 111441.00$ is the confined core area at midway between the levels of hoops and is calculated by reducing all the dimensions of the area $A_{conf,max2}$ by a length equal to half the clear spacing between internal hoops.
 $A_{noConf2} = 110709.333$ is the unconfined internal core area which is equal to $b_i^2/6$ as defined at (A.2).
 $psh,min * F_{ywe} = Min(psh,x * F_{ywe}, psh,y * F_{ywe}) = 2.724$
 Expression (5.4d) for $psh,min * F_{ywe}$ has been multiplied by 0.3 according to 15.7.1.3 for members without earthquake detailing (90° closed stirrups)

$psh,x * F_{ywe} = psh1 * F_{ywe1} + ps2 * F_{ywe2} = 2.724$
 $psh1 ((5.4d), TBDY) = L_{stir1} * A_{stir1} / (A_{sec} * s1) = 0.00301593$
 L_{stir1} (Length of stirrups along Y) = 2160.00
 A_{stir1} (stirrups area) = 78.53982
 $psh2 (5.4d) = L_{stir2} * A_{stir2} / (A_{sec} * s2) = 0.00056047$
 L_{stir2} (Length of stirrups along Y) = 1568.00
 A_{stir2} (stirrups area) = 50.26548

$psh,y * F_{ywe} = psh1 * F_{ywe1} + ps2 * F_{ywe2} = 3.25416$
 $psh1 ((5.4d), TBDY) = L_{stir1} * A_{stir1} / (A_{sec} * s1) = 0.00357443$
 L_{stir1} (Length of stirrups along X) = 2560.00
 A_{stir1} (stirrups area) = 78.53982
 $psh2 ((5.4d), TBDY) = L_{stir2} * A_{stir2} / (A_{sec} * s2) = 0.00070345$
 L_{stir2} (Length of stirrups along X) = 1968.00
 A_{stir2} (stirrups area) = 50.26548

$A_{sec} = 562500.00$
 $s1 = 100.00$
 $s2 = 250.00$
 $f_{ywe1} = 781.25$
 $f_{ywe2} = 656.25$
 $f_{ce} = 30.00$
 From ((5.A5), TBDY), TBDY: $cc = 0.002$
 $c =$ confinement factor = 1.00
 $y1 = 0.0025$
 $sh1 = 0.008$
 $ft1 = 900.1904$
 $fy1 = 750.1586$
 $su1 = 0.032$

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
 and also multiplied by the shear_factor according to 15.7.1.4, with
 Shear_factor = 1.00
 $l_o/l_{ou,min} = l_b/l_d = 1.00$
 $su_1 = 0.4 * esu_{1,nominal} ((5.5), TBDY) = 0.032$
 From table 5A.1, TBDY: $esu_{1,nominal} = 0.08$,
 For calculation of $esu_{1,nominal}$ and y_1, sh_1, ft_1, fy_1 , it is considered
 characteristic value $fsy_1 = fs_1/1.2$, from table 5.1, TBDY.
 y_1, sh_1, ft_1, fy_1 , are also multiplied by $Min(1, 1.25 * (l_b/l_d)^{2/3})$, from 10.3.5, ASCE 41-17.
 with $fs_1 = (fs_{jacket} * A_{sl,ten,jacket} + fs_{core} * A_{sl,ten,core}) / A_{sl,ten} = 750.1586$
 with $Es_1 = (Es_{jacket} * A_{sl,ten,jacket} + Es_{core} * A_{sl,ten,core}) / A_{sl,ten} = 200000.00$
 $y_2 = 0.0025$
 $sh_2 = 0.008$
 $ft_2 = 907.50$
 $fy_2 = 756.25$
 $su_2 = 0.032$
 using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
 and also multiplied by the shear_factor according to 15.7.1.4, with
 Shear_factor = 1.00
 $l_o/l_{ou,min} = l_b/l_{b,min} = 1.00$
 $su_2 = 0.4 * esu_{2,nominal} ((5.5), TBDY) = 0.032$
 From table 5A.1, TBDY: $esu_{2,nominal} = 0.08$,
 For calculation of $esu_{2,nominal}$ and y_2, sh_2, ft_2, fy_2 , it is considered
 characteristic value $fsy_2 = fs_2/1.2$, from table 5.1, TBDY.
 y_2, sh_2, ft_2, fy_2 , are also multiplied by $Min(1, 1.25 * (l_b/l_d)^{2/3})$, from 10.3.5, ASCE 41-17.
 with $fs_2 = (fs_{jacket} * A_{sl,com,jacket} + fs_{core} * A_{sl,com,core}) / A_{sl,com} = 756.25$
 with $Es_2 = (Es_{jacket} * A_{sl,com,jacket} + Es_{core} * A_{sl,com,core}) / A_{sl,com} = 200000.00$
 $y_v = 0.0025$
 $sh_v = 0.008$
 $ft_v = 902.993$
 $fy_v = 752.4941$
 $suv = 0.032$
 using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
 and also multiplied by the shear_factor according to 15.7.1.4, with
 Shear_factor = 1.00
 $l_o/l_{ou,min} = l_b/l_d = 1.00$
 $suv = 0.4 * esuv_{nominal} ((5.5), TBDY) = 0.032$
 From table 5A.1, TBDY: $esuv_{nominal} = 0.08$,
 considering characteristic value $fsyv = fsv/1.2$, from table 5.1, TBDY
 For calculation of $esuv_{nominal}$ and y_v, sh_v, ft_v, fy_v , it is considered
 characteristic value $fsyv = fsv/1.2$, from table 5.1, TBDY.
 y_1, sh_1, ft_1, fy_1 , are also multiplied by $Min(1, 1.25 * (l_b/l_d)^{2/3})$, from 10.3.5, ASCE 41-17.
 with $fsv = (fs_{jacket} * A_{sl,mid,jacket} + fs_{mid} * A_{sl,mid,core}) / A_{sl,mid} = 752.4941$
 with $Esv = (Es_{jacket} * A_{sl,mid,jacket} + Es_{mid} * A_{sl,mid,core}) / A_{sl,mid} = 200000.00$
 $1 = A_{sl,ten} / (b * d) * (fs_1 / fc) = 0.19457006$
 $2 = A_{sl,com} / (b * d) * (fs_2 / fc) = 0.12197144$
 $v = A_{sl,mid} / (b * d) * (fsv / fc) = 0.21102767$
 and confined core properties:
 $b = 390.00$
 $d = 677.00$
 $d' = 13.00$
 $f_{cc} (5A.2, TBDY) = 30.00$
 $cc (5A.5, TBDY) = 0.002$
 $c = \text{confinement factor} = 1.00$
 $1 = A_{sl,ten} / (b * d) * (fs_1 / fc) = 0.23445239$
 $2 = A_{sl,com} / (b * d) * (fs_2 / fc) = 0.14697275$
 $v = A_{sl,mid} / (b * d) * (fsv / fc) = 0.25428343$
 Case/Assumption: Unconfined full section - Steel rupture
 ' satisfies Eq. (4.3)
 --->
 $v < v_{s,y2}$ - LHS eq.(4.5) is not satisfied
 --->
 $v < v_{s,c}$ - RHS eq.(4.5) is satisfied
 --->
 $su (4.8) = 0.33719414$
 $Mu = MRc (4.15) = 2.1636E+009$
 $u = su (4.1) = 6.8287974E-005$

Calculation of ratio l_b/d

Adequate Lap Length: $l_b/d \geq 1$

Calculation of Shear Strength $V_r = \text{Min}(V_{r1}, V_{r2}) = 1.2916\text{E}+006$

Calculation of Shear Strength at edge 1, $V_{r1} = 1.2916\text{E}+006$

$V_{r1} = V_{\text{Col}} ((10.3), \text{ASCE } 41-17) = k_n l V_{\text{ColO}}$

$V_{\text{ColO}} = 1.2916\text{E}+006$

$k_n l = 1$ (zero step-static loading)

NOTE: In expression (10-3) ' $V_s = A_v f_y d/s$ ' is replaced by ' $V_s + f V_f$ ' where V_f is the contribution of FRPs (11.3), ACI 440).

$= 1$ (normal-weight concrete)

Mean concrete strength: $f_c' = (f_c'_{\text{jacket}} \text{Area}_{\text{jacket}} + f_c'_{\text{core}} \text{Area}_{\text{core}}) / \text{Area}_{\text{section}} = 27.20$, but $f_c'^{0.5} \leq 8.3$ MPa (22.5.3.1, ACI 318-14)

$M/V_d = 2.00$

$\mu_u = 5174.584$

$V_u = 8.5087964\text{E}-020$

$d = 0.8 \cdot h = 600.00$

$N_u = 20792.05$

$A_g = 337500.00$

From (11.5.4.8), ACI 318-14: $V_s = V_{s,\text{jacket}} + V_{s,\text{core}} = 1.0354\text{E}+006$

where:

$V_{s,\text{jacket}} = V_{s,j1} + V_{s,j2} = 942477.796$

$V_{s,j1} = 589048.623$ is calculated for section web jacket, with:

$d = 600.00$

$A_v = 157079.633$

$f_y = 625.00$

$s = 100.00$

$V_{s,j1}$ is multiplied by $\text{Col},j1 = 1.00$

$s/d = 0.16666667$

$V_{s,j2} = 353429.174$ is calculated for section flange jacket, with:

$d = 360.00$

$A_v = 157079.633$

$f_y = 625.00$

$s = 100.00$

$V_{s,j2}$ is multiplied by $\text{Col},j2 = 1.00$

$s/d = 0.27777778$

$V_{s,\text{core}} = V_{s,c1} + V_{s,c2} = 92890.612$

$V_{s,c1} = 92890.612$ is calculated for section web core, with:

$d = 440.00$

$A_v = 100530.965$

$f_y = 525.00$

$s = 250.00$

$V_{s,c1}$ is multiplied by $\text{Col},c1 = 1.00$

$s/d = 0.56818182$

$V_{s,c2} = 0.00$ is calculated for section flange core, with:

$d = 200.00$

$A_v = 100530.965$

$f_y = 525.00$

$s = 250.00$

$V_{s,c2}$ is multiplied by $\text{Col},c2 = 0.00$

$s/d = 1.25$

$V_f ((11-3)-(11.4), \text{ACI } 440) = 0.00$

From (11-11), ACI 440: $V_s + V_f \leq 935437.922$

$b_w = 450.00$

Calculation of Shear Strength at edge 2, $V_{r2} = 1.2916\text{E}+006$

$V_{r2} = V_{\text{Col}} ((10.3), \text{ASCE } 41-17) = k_n l V_{\text{ColO}}$

VColO = 1.2916E+006
knl = 1 (zero step-static loading)

NOTE: In expression (10-3) ' $V_s = A_v \cdot f_y \cdot d / s$ ' is replaced by ' $V_s + f \cdot V_f$ '
where V_f is the contribution of FRPs (11.3), ACI 440).

= 1 (normal-weight concrete)
Mean concrete strength: $f_c' = (f_c'_{\text{jacket}} \cdot \text{Area}_{\text{jacket}} + f_c'_{\text{core}} \cdot \text{Area}_{\text{core}}) / \text{Area}_{\text{section}} = 27.20$, but $f_c'^{0.5} \leq 8.3$
MPa (22.5.3.1, ACI 318-14)
 $M/Vd = 2.00$
 $\mu_u = 5174.584$
 $V_u = 8.5087964E-020$
 $d = 0.8 \cdot h = 600.00$
 $N_u = 20792.05$
 $A_g = 337500.00$
From (11.5.4.8), ACI 318-14: $V_s = V_{s,\text{jacket}} + V_{s,\text{core}} = 1.0354E+006$
where:
 $V_{s,\text{jacket}} = V_{s,j1} + V_{s,j2} = 942477.796$
 $V_{s,j1} = 589048.623$ is calculated for section web jacket, with:
 $d = 600.00$
 $A_v = 157079.633$
 $f_y = 625.00$
 $s = 100.00$
 $V_{s,j1}$ is multiplied by $\text{Col},j1 = 1.00$
 $s/d = 0.16666667$
 $V_{s,j2} = 353429.174$ is calculated for section flange jacket, with:
 $d = 360.00$
 $A_v = 157079.633$
 $f_y = 625.00$
 $s = 100.00$
 $V_{s,j2}$ is multiplied by $\text{Col},j2 = 1.00$
 $s/d = 0.27777778$
 $V_{s,\text{core}} = V_{s,c1} + V_{s,c2} = 92890.612$
 $V_{s,c1} = 92890.612$ is calculated for section web core, with:
 $d = 440.00$
 $A_v = 100530.965$
 $f_y = 525.00$
 $s = 250.00$
 $V_{s,c1}$ is multiplied by $\text{Col},c1 = 1.00$
 $s/d = 0.56818182$
 $V_{s,c2} = 0.00$ is calculated for section flange core, with:
 $d = 200.00$
 $A_v = 100530.965$
 $f_y = 525.00$
 $s = 250.00$
 $V_{s,c2}$ is multiplied by $\text{Col},c2 = 0.00$
 $s/d = 1.25$
 $V_f ((11-3)-(11.4), \text{ACI } 440) = 0.00$
From (11-11), ACI 440: $V_s + V_f \leq 935437.922$
 $b_w = 450.00$

End Of Calculation of Shear Capacity ratio for element: column JTC1 of floor 1
At local axis: 3

Start Of Calculation of Shear Capacity ratio for element: column JTC1 of floor 1
At Shear local axis: 2
(Bending local axis: 3)
Section Type: rcjtcs

Constant Properties

Knowledge Factor, $\phi = 0.80$
Mean strength values are used for both shear and moment calculations.

Consequently:

Jacket

New material of Secondary Member: Concrete Strength, $f_c = f_{cm} = 30.00$

New material of Secondary Member: Steel Strength, $f_s = f_{sm} = 625.00$

Concrete Elasticity, $E_c = 25742.96$

Steel Elasticity, $E_s = 200000.00$

Existing Column

Existing material of Secondary Member: Concrete Strength, $f_c = f_{cm} = 24.00$

Existing material of Secondary Member: Steel Strength, $f_s = f_{sm} = 525.00$

Concrete Elasticity, $E_c = 23025.204$

Steel Elasticity, $E_s = 200000.00$

#####

Note: Especially for the calculation of moment strengths,
the above steel re-bar strengths are multiplied by 1.25 according to R18.6.5, ACI 318-14

Jacket

New material: Steel Strength, $f_s = 1.25 \cdot f_{sm} = 781.25$

Existing Column

Existing material: Steel Strength, $f_s = 1.25 \cdot f_{sm} = 656.25$

#####

Max Height, $H_{max} = 750.00$

Min Height, $H_{min} = 450.00$

Max Width, $W_{max} = 950.00$

Min Width, $W_{min} = 450.00$

Eccentricity, $Ecc = 250.00$

Jacket Thickness, $t_j = 100.00$

Cover Thickness, $c = 25.00$

Mean Confinement Factor overall section = 1.00

Element Length, $L = 3000.00$

Secondary Member

Smooth Bars

Ductile Steel

Without Detailing for Earthquake Resistance (including stirrups not closed at 135°)

Longitudinal Bars With Ends Lapped Starting at the End Sections

Adequate Lap Length ($l_o/l_{ou,min} \geq 1$)

No FRP Wrapping

Stepwise Properties

At local axis: 2

EDGE -A-

Shear Force, $V_a = 5.2099631E-036$

EDGE -B-

Shear Force, $V_b = -5.2099631E-036$

BOTH EDGES

Axial Force, $F = -20792.05$

Longitudinal Reinforcement Area Distribution (in 2 divisions)

-Tension: $As_t = 0.00$

-Compression: $As_c = 6691.592$

Longitudinal Reinforcement Area Distribution (in 3 divisions)

-Tension: $As_{t,ten} = 1539.38$

-Compression: $As_{c,com} = 1539.38$

-Middle: $As_{l,mid} = 3612.832$

Calculation of Shear Capacity ratio, $V_e/V_r = 1.08994$

Member Controlled by Shear ($V_e/V_r > 1$)

Calculation of Shear Demand from fig. R18.6.5, ACI 318-14 $V_e = (M_{pr1} + M_{pr2})/l_n = 1.7820E+006$

with

$M_{pr1} = \text{Max}(Mu_{1+}, Mu_{1-}) = 2.6730E+009$

$Mu_{1+} = 2.6730E+009$, is the ultimate moment strength at the edge 1 of the member in the actual moment direction which is defined for the static loading combination

$Mu_{1-} = 2.6730E+009$, is the ultimate moment strength at the edge 1 of the member in the opposite moment direction which is defined for the static loading combination

$M_{pr2} = \text{Max}(Mu_{2+}, Mu_{2-}) = 2.6730E+009$

Mu2+ = 2.6730E+009, is the ultimate moment strength at the edge 2 of the member in the actual moment direction which is defined for the the static loading combination

Mu2- = 2.6730E+009, is the ultimate moment strength at the edge 2 of the member in the opposite moment direction which is defined for the the static loading combination

Calculation of Mu1+

Calculation of ultimate curvature ϕ_u according to 4.1, Biskinis/Fardis 2013:

$$\phi_u = 4.9274896E-005$$

$$\mu_u = 2.6730E+009$$

with full section properties:

$$b = 450.00$$

$$d = 907.00$$

$$d' = 43.00$$

$$\nu = 0.00169807$$

$$N = 20792.05$$

$$f_c = 30.00$$

$$\phi_{co} (5A.5, TBDY) = 0.002$$

$$\text{Final value of } \phi_u: \phi_u^* = \text{shear_factor} * \text{Max}(\phi_u, \phi_{co}) = 0.00832321$$

The Shear_factor is considered equal to 1 (pure moment strength)

$$\text{From (5.4b), TBDY: } \phi_u = 0.00832321$$

$$\phi_{we} (5.4c) = 0.01453958$$

$$\phi_{ase} ((5.4d), TBDY) = (\phi_{ase1} * A_{ext} + \phi_{ase2} * A_{int}) / A_{sec} = 0.53375773$$

$$\phi_{ase1} = \text{Max}(((A_{conf,max1} - A_{noConf1}) / A_{conf,max1}) * (\phi_{conf,min1} / A_{conf,max1}), 0) = 0.53375773$$

The definitions of A_{noConf} , $A_{conf,min}$ and $A_{conf,max}$ are derived from generalization of the rectangular sections confinement, which is expressed by (5.4d).

The generalization is done according to Mander, J., Priestley, M., and Park, R. (1988)

"Theoretical Stress-Strain Model for Confined Concrete."

J. Struct. Eng., 10.1061/(ASCE)0733-9445(1988)114:8(1804), 1804-1826.

$A_{conf,max1} = 464100.00$ is the confined core area at levels of member with hoops and

is calculated as the area of core enclosed by the center lines of the external perimeter hoops.

$A_{conf,min1} = 395025.00$ is the confined core area at midway between the levels of hoops and

is calculated by reducing all the dimensions of the area $A_{conf,max1}$ by a length

equal to half the clear spacing between external hoops.

$A_{noConf1} = 173066.667$ is the unconfined external core area which is equal to $b_i^2/6$ as defined at (A.2).

$$\phi_{ase2} (> \phi_{ase1}) = \text{Max}(((A_{conf,max2} - A_{noConf2}) / A_{conf,max2}) * (\phi_{conf,min2} / A_{conf,max2}), 0) = 0.53375773$$

The definitions of A_{noConf} , $A_{conf,min}$ and $A_{conf,max}$ are derived from generalization of the rectangular sections confinement, which is expressed by (5.4d).

The generalization is done according to Mander, J., Priestley, M., and Park, R. (1988)

"Theoretical Stress-Strain Model for Confined Concrete."

J. Struct. Eng., 10.1061/(ASCE)0733-9445(1988)114:8(1804), 1804-1826.

$A_{conf,max2} = 252164.00$ is the confined core area at levels of member with hoops and

is calculated as the area of core enclosed by the center lines of the internal perimeter hoops.

$A_{conf,min2} = 111441.00$ is the confined core area at midway between the levels of hoops and

is calculated by reducing all the dimensions of the area $A_{conf,max2}$ by a length

equal to half the clear spacing between internal hoops.

$A_{noConf2} = 110709.333$ is the unconfined internal core area which is equal to $b_i^2/6$ as defined at (A.2).

$$\phi_{psh,min} * F_{ywe} = \text{Min}(\phi_{psh,x} * F_{ywe}, \phi_{psh,y} * F_{ywe}) = 2.724$$

Expression (5.4d) for $\phi_{psh,min} * F_{ywe}$ has been multiplied by 0.3 according to 15.7.1.3 for members without earthquake detailing (90° closed stirrups)

$$\phi_{psh,x} * F_{ywe} = \phi_{psh1} * F_{ywe1} + \phi_{psh2} * F_{ywe2} = 2.724$$

$$\phi_{psh1} ((5.4d), TBDY) = L_{stir1} * A_{stir1} / (A_{sec} * s_1) = 0.00301593$$

$$L_{stir1} (\text{Length of stirrups along Y}) = 2160.00$$

$$A_{stir1} (\text{stirrups area}) = 78.53982$$

$$\phi_{psh2} (5.4d) = L_{stir2} * A_{stir2} / (A_{sec} * s_2) = 0.00056047$$

$$L_{stir2} (\text{Length of stirrups along Y}) = 1568.00$$

$$A_{stir2} (\text{stirrups area}) = 50.26548$$

$$\phi_{psh,y} * F_{ywe} = \phi_{psh1} * F_{ywe1} + \phi_{psh2} * F_{ywe2} = 3.25416$$

$$\phi_{psh1} ((5.4d), TBDY) = L_{stir1} * A_{stir1} / (A_{sec} * s_1) = 0.00357443$$

$$L_{stir1} (\text{Length of stirrups along X}) = 2560.00$$

$$A_{stir1} (\text{stirrups area}) = 78.53982$$

$psh2 ((5.4d), TBDY) = Lstir2 * Astir2 / (Asec * s2) = 0.00070345$
 $Lstir2$ (Length of stirrups along X) = 1968.00
 $Astir2$ (stirrups area) = 50.26548

Asec = 562500.00

s1 = 100.00

s2 = 250.00

fywe1 = 781.25

fywe2 = 656.25

fce = 30.00

From ((5.A5), TBDY), TBDY: cc = 0.002

c = confinement factor = 1.00

y1 = 0.0025

sh1 = 0.008

ft1 = 907.50

fy1 = 756.25

su1 = 0.032

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00

lo/lou,min = lb/ld = 1.00

su1 = 0.4*esu1_nominal ((5.5), TBDY) = 0.032

From table 5A.1, TBDY: esu1_nominal = 0.08,

For calculation of esu1_nominal and y1, sh1,ft1,fy1, it is considered
characteristic value fsy1 = fs1/1.2, from table 5.1, TBDY.

y1, sh1,ft1,fy1, are also multiplied by $\text{Min}(1, 1.25 * (lb/ld)^{2/3})$, from 10.3.5, ASCE 41-17.

with fs1 = (fs,jacket*Asl,ten,jacket + fs,core*Asl,ten,core)/Asl,ten = 756.25

with Es1 = (Es,jacket*Asl,ten,jacket + Es,core*Asl,ten,core)/Asl,ten = 200000.00

y2 = 0.0025

sh2 = 0.008

ft2 = 907.50

fy2 = 756.25

su2 = 0.032

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00

lo/lou,min = lb/lb,min = 1.00

su2 = 0.4*esu2_nominal ((5.5), TBDY) = 0.032

From table 5A.1, TBDY: esu2_nominal = 0.08,

For calculation of esu2_nominal and y2, sh2,ft2,fy2, it is considered
characteristic value fsy2 = fs2/1.2, from table 5.1, TBDY.

y1, sh1,ft1,fy1, are also multiplied by $\text{Min}(1, 1.25 * (lb/ld)^{2/3})$, from 10.3.5, ASCE 41-17.

with fs2 = (fs,jacket*Asl,com,jacket + fs,core*Asl,com,core)/Asl,com = 756.25

with Es2 = (Es,jacket*Asl,com,jacket + Es,core*Asl,com,core)/Asl,com = 200000.00

yv = 0.0025

shv = 0.008

ftv = 899.1522

fyv = 749.2935

suv = 0.032

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00

lo/lou,min = lb/ld = 1.00

suv = 0.4*esuv_nominal ((5.5), TBDY) = 0.032

From table 5A.1, TBDY: esuv_nominal = 0.08,

considering characteristic value fsyv = fsv/1.2, from table 5.1, TBDY
For calculation of esuv_nominal and yv, shv,ftv,fyv, it is considered

characteristic value fsyv = fsv/1.2, from table 5.1, TBDY.

y1, sh1,ft1,fy1, are also multiplied by $\text{Min}(1, 1.25 * (lb/ld)^{2/3})$, from 10.3.5, ASCE 41-17.

with fsv = (fs,jacket*Asl,mid,jacket + fs,mid*Asl,mid,core)/Asl,mid = 749.2935

with Esv = (Es,jacket*Asl,mid,jacket + Es,mid*Asl,mid,core)/Asl,mid = 200000.00

1 = Asl,ten/(b*d)*(fs1/fc) = 0.09507586

2 = Asl,com/(b*d)*(fs2/fc) = 0.09507586

v = Asl,mid/(b*d)*(fsv/fc) = 0.22108466

and confined core properties:

b = 390.00

d = 877.00

```

d' = 13.00
fcc (5A.2, TBDY) = 30.00
cc (5A.5, TBDY) = 0.002
c = confinement factor = 1.00
1 = Asl,ten/(b*d)*(fs1/fc) = 0.11345559
2 = Asl,com/(b*d)*(fs2/fc) = 0.11345559
v = Asl,mid/(b*d)*(fsv/fc) = 0.26382395
Case/Assumption: Unconfined full section - Steel rupture
'satisfies Eq. (4.3)
--->
v < vs,y2 - LHS eq.(4.5) is not satisfied
--->
v < vs,c - RHS eq.(4.5) is satisfied
--->
su (4.8) = 0.28399348
Mu = MRc (4.15) = 2.6730E+009
u = su (4.1) = 4.9274896E-005

```

Calculation of ratio lb/d

Adequate Lap Length: lb/d >= 1

Calculation of Mu1-

Calculation of ultimate curvature u according to 4.1, Biskinis/Fardis 2013:

```

u = 4.9274896E-005
Mu = 2.6730E+009

```

with full section properties:

```

b = 450.00
d = 907.00
d' = 43.00
v = 0.00169807
N = 20792.05
fc = 30.00
co (5A.5, TBDY) = 0.002
Final value of cu: cu* = shear_factor * Max( cu, cc) = 0.00832321
The Shear_factor is considered equal to 1 (pure moment strength)
From (5.4b), TBDY: cu = 0.00832321
we (5.4c) = 0.01453958
ase ((5.4d), TBDY) = (ase1*Aext+ase2*Aint)/Asec = 0.53375773
ase1 = Max(((Aconf,max1-AnoConf1)/Aconf,max1)*(Aconf,min1/Aconf,max1),0) = 0.53375773
The definitions of AnoConf, Aconf,min and Aconf,max are derived from generalization
of the rectangular sections confinement, which is expressed by (5.4d).
The generalization is done according to Mander, J., Priestley, M., and Park, R. (1988)
"Theoretical Stress-Strain Model for Confined Concrete."
J. Struct. Eng., 10.1061/(ASCE)0733-9445(1988)114:8(1804), 1804-1826.
Aconf,max1 = 464100.00 is the confined core area at levels of member with hoops and
is calculated as the area of core enclosed by the center lines of the external perimeter hoops.
Aconf,min1 = 395025.00 is the confined core area at midway between the levels of hoops and
is calculated by reducing all the dimensions of the area Aconf,max1 by a length
equal to half the clear spacing between external hoops.
AnoConf1 = 173066.667 is the unconfined external core area which is equal to bi2/6 as defined at (A.2).
ase2 (>=ase1) = Max(((Aconf,max2-AnoConf2)/Aconf,max2)*(Aconf,min2/Aconf,max2),0) = 0.53375773
The definitions of AnoConf, Aconf,min and Aconf,max are derived from generalization
of the rectangular sections confinement, which is expressed by (5.4d).
The generalization is done according to Mander, J., Priestley, M., and Park, R. (1988)
"Theoretical Stress-Strain Model for Confined Concrete."
J. Struct. Eng., 10.1061/(ASCE)0733-9445(1988)114:8(1804), 1804-1826.
Aconf,max2 = 252164.00 is the confined core area at levels of member with hoops and
is calculated as the area of core enclosed by the center lines of the internal perimeter hoops.
Aconf,min2 = 111441.00 is the confined core area at midway between the levels of hoops and

```


is calculated by reducing all the dimensions of the area Aconf,max2 by a length equal to half the clear spacing between internal hoops.

AnoConf2 = 110709.333 is the unconfined internal core area which is equal to $b_i^2/6$ as defined at (A.2).

$$psh_{min} \cdot F_{ywe} = \min(psh_x \cdot F_{ywe}, psh_y \cdot F_{ywe}) = 2.724$$

Expression (5.4d) for $psh_{min} \cdot F_{ywe}$ has been multiplied by 0.3 according to 15.7.1.3 for members without earthquake detailing (90° closed stirrups)

$$psh_x \cdot F_{ywe} = psh1 \cdot F_{ywe1} + ps2 \cdot F_{ywe2} = 2.724$$

$$psh1 \text{ ((5.4d), TBDY)} = Lstir1 \cdot Astir1 / (Asec \cdot s1) = 0.00301593$$

$$Lstir1 \text{ (Length of stirrups along Y)} = 2160.00$$

$$Astir1 \text{ (stirrups area)} = 78.53982$$

$$psh2 \text{ (5.4d)} = Lstir2 \cdot Astir2 / (Asec \cdot s2) = 0.00056047$$

$$Lstir2 \text{ (Length of stirrups along Y)} = 1568.00$$

$$Astir2 \text{ (stirrups area)} = 50.26548$$

$$psh_y \cdot F_{ywe} = psh1 \cdot F_{ywe1} + ps2 \cdot F_{ywe2} = 3.25416$$

$$psh1 \text{ ((5.4d), TBDY)} = Lstir1 \cdot Astir1 / (Asec \cdot s1) = 0.00357443$$

$$Lstir1 \text{ (Length of stirrups along X)} = 2560.00$$

$$Astir1 \text{ (stirrups area)} = 78.53982$$

$$psh2 \text{ ((5.4d), TBDY)} = Lstir2 \cdot Astir2 / (Asec \cdot s2) = 0.00070345$$

$$Lstir2 \text{ (Length of stirrups along X)} = 1968.00$$

$$Astir2 \text{ (stirrups area)} = 50.26548$$

$$Asec = 562500.00$$

$$s1 = 100.00$$

$$s2 = 250.00$$

$$fywe1 = 781.25$$

$$fywe2 = 656.25$$

$$fce = 30.00$$

$$\text{From ((5.A5), TBDY), TBDY: } cc = 0.002$$

$$c = \text{confinement factor} = 1.00$$

$$y1 = 0.0025$$

$$sh1 = 0.008$$

$$ft1 = 907.50$$

$$fy1 = 756.25$$

$$su1 = 0.032$$

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor and also multiplied by the shear_factor according to 15.7.1.4, with Shear_factor = 1.00

$$lo/lo_{min} = lb/lb_{min} = 1.00$$

$$su1 = 0.4 \cdot esu1_{nominal} \text{ ((5.5), TBDY)} = 0.032$$

From table 5A.1, TBDY: $esu1_{nominal} = 0.08$,

For calculation of $esu1_{nominal}$ and $y1$, $sh1$, $ft1$, $fy1$, it is considered characteristic value $fsy1 = fs1/1.2$, from table 5.1, TBDY.

$y1$, $sh1$, $ft1$, $fy1$, are also multiplied by $\min(1, 1.25 \cdot (lb/lb_{min})^{2/3})$, from 10.3.5, ASCE 41-17.

$$\text{with } fs1 = (fs_{jacket} \cdot Asl_{ten,jacket} + fs_{core} \cdot Asl_{ten,core}) / Asl_{ten} = 756.25$$

$$\text{with } Es1 = (Es_{jacket} \cdot Asl_{ten,jacket} + Es_{core} \cdot Asl_{ten,core}) / Asl_{ten} = 200000.00$$

$$y2 = 0.0025$$

$$sh2 = 0.008$$

$$ft2 = 907.50$$

$$fy2 = 756.25$$

$$su2 = 0.032$$

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor and also multiplied by the shear_factor according to 15.7.1.4, with Shear_factor = 1.00

$$lo/lo_{min} = lb/lb_{min} = 1.00$$

$$su2 = 0.4 \cdot esu2_{nominal} \text{ ((5.5), TBDY)} = 0.032$$

From table 5A.1, TBDY: $esu2_{nominal} = 0.08$,

For calculation of $esu2_{nominal}$ and $y2$, $sh2$, $ft2$, $fy2$, it is considered characteristic value $fsy2 = fs2/1.2$, from table 5.1, TBDY.

$y1$, $sh1$, $ft1$, $fy1$, are also multiplied by $\min(1, 1.25 \cdot (lb/lb_{min})^{2/3})$, from 10.3.5, ASCE 41-17.

$$\text{with } fs2 = (fs_{jacket} \cdot Asl_{com,jacket} + fs_{core} \cdot Asl_{com,core}) / Asl_{com} = 756.25$$

$$\text{with } Es2 = (Es_{jacket} \cdot Asl_{com,jacket} + Es_{core} \cdot Asl_{com,core}) / Asl_{com} = 200000.00$$

$$yv = 0.0025$$

$$shv = 0.008$$

$$ftv = 899.1522$$

$$fyv = 749.2935$$

```

suv = 0.032
using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00
lo/lou,min = lb/ld = 1.00
suv = 0.4*esuvnominal ((5.5), TBDY) = 0.032
From table 5A.1, TBDY: esuvnominal = 0.08,
considering characteristic value fsyv = fsv/1.2, from table 5.1, TBDY
For calculation of esuvnominal and yv, shv, ftv, fyv, it is considered
characteristic value fsyv = fsv/1.2, from table 5.1, TBDY.
y1, sh1, ft1, fy1, are also multiplied by Min(1, 1.25*(lb/ld)2/3), from 10.3.5, ASCE 41-17.
with fsv = (fsjacket*Aslmid,jacket + fsmid*Aslmid,core)/Aslmid = 749.2935
with Esv = (Esjacket*Aslmid,jacket + Esmid*Aslmid,core)/Aslmid = 200000.00
1 = Aslten/(b*d)*(fs1/fc) = 0.09507586
2 = Aslcom/(b*d)*(fs2/fc) = 0.09507586
v = Aslmid/(b*d)*(fsv/fc) = 0.22108466
and confined core properties:
b = 390.00
d = 877.00
d' = 13.00
fcc (5A.2, TBDY) = 30.00
cc (5A.5, TBDY) = 0.002
c = confinement factor = 1.00
1 = Aslten/(b*d)*(fs1/fc) = 0.11345559
2 = Aslcom/(b*d)*(fs2/fc) = 0.11345559
v = Aslmid/(b*d)*(fsv/fc) = 0.26382395
Case/Assumption: Unconfined full section - Steel rupture
'satisfies Eq. (4.3)
--->
v < vs,y2 - LHS eq.(4.5) is not satisfied
--->
v < vs,c - RHS eq.(4.5) is satisfied
--->
su (4.8) = 0.28399348
Mu = MRc (4.15) = 2.6730E+009
u = su (4.1) = 4.9274896E-005
-----

Calculation of ratio lb/ld
-----
Adequate Lap Length: lb/ld >= 1
-----
-----
Calculation of Mu2+
-----
-----
Calculation of ultimate curvature u according to 4.1, Biskinis/Fardis 2013:
u = 4.9274896E-005
Mu = 2.6730E+009
-----
with full section properties:
b = 450.00
d = 907.00
d' = 43.00
v = 0.00169807
N = 20792.05
fc = 30.00
co (5A.5, TBDY) = 0.002
Final value of cu: cu* = shear_factor * Max( cu, cc) = 0.00832321
The Shear_factor is considered equal to 1 (pure moment strength)
From (5.4b), TBDY: cu = 0.00832321
we (5.4c) = 0.01453958
ase ((5.4d), TBDY) = (ase1*Aext+ase2*Aint)/Asec = 0.53375773
ase1 = Max(((Aconf,max1-AnoConf1)/Aconf,max1)*(Aconf,min1/Aconf,max1),0) = 0.53375773
The definitions of AnoConf, Aconf,min and Aconf,max are derived from generalization

```

of the rectangular sections confinement, which is expressed by (5.4d).

The generalization is done according to Mander, J., Priestley, M., and Park, R. (1988)

"Theoretical Stress-Strain Model for Confined Concrete."

J. Struct. Eng., 10.1061/(ASCE)0733-9445(1988)114:8(1804), 1804-1826.

$A_{conf,max1} = 464100.00$ is the confined core area at levels of member with hoops and

is calculated as the area of core enclosed by the center lines of the external perimeter hoops.

$A_{conf,min1} = 395025.00$ is the confined core area at midway between the levels of hoops and

is calculated by reducing all the dimensions of the area $A_{conf,max1}$ by a length equal to half the clear spacing between external hoops.

$A_{noConf1} = 173066.667$ is the unconfined external core area which is equal to $b_i^2/6$ as defined at (A.2).

$ase2 (>= ase1) = \text{Max}(((A_{conf,max2} - A_{noConf2})/A_{conf,max2}) * (A_{conf,min2}/A_{conf,max2}), 0) = 0.53375773$

The definitions of A_{noConf} , $A_{conf,min}$ and $A_{conf,max}$ are derived from generalization of the rectangular sections confinement, which is expressed by (5.4d).

The generalization is done according to Mander, J., Priestley, M., and Park, R. (1988)

"Theoretical Stress-Strain Model for Confined Concrete."

J. Struct. Eng., 10.1061/(ASCE)0733-9445(1988)114:8(1804), 1804-1826.

$A_{conf,max2} = 252164.00$ is the confined core area at levels of member with hoops and

is calculated as the area of core enclosed by the center lines of the internal perimeter hoops.

$A_{conf,min2} = 111441.00$ is the confined core area at midway between the levels of hoops and

is calculated by reducing all the dimensions of the area $A_{conf,max2}$ by a length equal to half the clear spacing between internal hoops.

$A_{noConf2} = 110709.333$ is the unconfined internal core area which is equal to $b_i^2/6$ as defined at (A.2).

$psh_{min} * F_{ywe} = \text{Min}(psh_x * F_{ywe}, psh_y * F_{ywe}) = 2.724$

Expression (5.4d) for $psh_{min} * F_{ywe}$ has been multiplied by 0.3 according to 15.7.1.3 for members without earthquake detailing (90° closed stirrups)

 $psh_x * F_{ywe} = psh1 * F_{ywe1} + ps2 * F_{ywe2} = 2.724$

$psh1$ ((5.4d), TBDY) = $L_{stir1} * A_{stir1} / (A_{sec} * s1) = 0.00301593$

L_{stir1} (Length of stirrups along Y) = 2160.00

A_{stir1} (stirrups area) = 78.53982

$psh2$ ((5.4d)) = $L_{stir2} * A_{stir2} / (A_{sec} * s2) = 0.00056047$

L_{stir2} (Length of stirrups along Y) = 1568.00

A_{stir2} (stirrups area) = 50.26548

 $psh_y * F_{ywe} = psh1 * F_{ywe1} + ps2 * F_{ywe2} = 3.25416$

$psh1$ ((5.4d), TBDY) = $L_{stir1} * A_{stir1} / (A_{sec} * s1) = 0.00357443$

L_{stir1} (Length of stirrups along X) = 2560.00

A_{stir1} (stirrups area) = 78.53982

$psh2$ ((5.4d), TBDY) = $L_{stir2} * A_{stir2} / (A_{sec} * s2) = 0.00070345$

L_{stir2} (Length of stirrups along X) = 1968.00

A_{stir2} (stirrups area) = 50.26548

 $A_{sec} = 562500.00$

$s1 = 100.00$

$s2 = 250.00$

$f_{ywe1} = 781.25$

$f_{ywe2} = 656.25$

$f_{ce} = 30.00$

From ((5.A5), TBDY), TBDY: $cc = 0.002$

c = confinement factor = 1.00

$y1 = 0.0025$

$sh1 = 0.008$

$ft1 = 907.50$

$fy1 = 756.25$

$su1 = 0.032$

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor

and also multiplied by the shear_factor according to 15.7.1.4, with

Shear_factor = 1.00

$lo/lo_{u,min} = l_b/l_d = 1.00$

$su1 = 0.4 * esu1_{nominal}$ ((5.5), TBDY) = 0.032

From table 5A.1, TBDY: $esu1_{nominal} = 0.08$,

For calculation of $esu1_{nominal}$ and $y1$, $sh1$, $ft1$, $fy1$, it is considered

characteristic value $fsy1 = fs1/1.2$, from table 5.1, TBDY.

$y1$, $sh1$, $ft1$, $fy1$, are also multiplied by $\text{Min}(1, 1.25 * (l_b/l_d)^{2/3})$, from 10.3.5, ASCE 41-17.

with $fs1 = (f_{s,jacket} * A_{s,ten,jacket} + f_{s,core} * A_{s,ten,core}) / A_{s,ten} = 756.25$

with $Es1 = (E_{s,jacket} * A_{s,ten,jacket} + E_{s,core} * A_{s,ten,core}) / A_{s,ten} = 200000.00$

$y2 = 0.0025$

```

sh2 = 0.008
ft2 = 907.50
fy2 = 756.25
su2 = 0.032
    using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
    and also multiplied by the shear_factor according to 15.7.1.4, with
    Shear_factor = 1.00
    lo/lo,min = lb/lb,min = 1.00
    su2 = 0.4*esu2_nominal ((5.5), TBDY) = 0.032
    From table 5A.1, TBDY: esu2_nominal = 0.08,
    For calculation of esu2_nominal and y2, sh2,ft2,fy2, it is considered
    characteristic value fsy2 = fs2/1.2, from table 5.1, TBDY.
    y1, sh1,ft1,fy1, are also multiplied by Min(1,1.25*(lb/lb)^ 2/3), from 10.3.5, ASCE 41-17.
    with fs2 = (fs,jacket*Asl,com,jacket + fs,core*Asl,com,core)/Asl,com = 756.25
    with Es2 = (Es,jacket*Asl,com,jacket + Es,core*Asl,com,core)/Asl,com = 200000.00
yv = 0.0025
shv = 0.008
ftv = 899.1522
fyv = 749.2935
suv = 0.032
    using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
    and also multiplied by the shear_factor according to 15.7.1.4, with
    Shear_factor = 1.00
    lo/lo,min = lb/lb = 1.00
    suv = 0.4*esuv_nominal ((5.5), TBDY) = 0.032
    From table 5A.1, TBDY: esuv_nominal = 0.08,
    considering characteristic value fsyv = fsv/1.2, from table 5.1, TBDY
    For calculation of esuv_nominal and yv, shv,ftv,fyv, it is considered
    characteristic value fsyv = fsv/1.2, from table 5.1, TBDY.
    y1, sh1,ft1,fy1, are also multiplied by Min(1,1.25*(lb/lb)^ 2/3), from 10.3.5, ASCE 41-17.
    with fsv = (fs,jacket*Asl,mid,jacket + fs,mid*Asl,mid,core)/Asl,mid = 749.2935
    with Esv = (Es,jacket*Asl,mid,jacket + Es,mid*Asl,mid,core)/Asl,mid = 200000.00
1 = Asl,ten/(b*d)*(fs1/fc) = 0.09507586
2 = Asl,com/(b*d)*(fs2/fc) = 0.09507586
v = Asl,mid/(b*d)*(fsv/fc) = 0.22108466
and confined core properties:
b = 390.00
d = 877.00
d' = 13.00
fcc (5A.2, TBDY) = 30.00
cc (5A.5, TBDY) = 0.002
c = confinement factor = 1.00
1 = Asl,ten/(b*d)*(fs1/fc) = 0.11345559
2 = Asl,com/(b*d)*(fs2/fc) = 0.11345559
v = Asl,mid/(b*d)*(fsv/fc) = 0.26382395
Case/Assumption: Unconfined full section - Steel rupture
' satisfies Eq. (4.3)
--->
v < vs,y2 - LHS eq.(4.5) is not satisfied
--->
v < vs,c - RHS eq.(4.5) is satisfied
--->
su (4.8) = 0.28399348
Mu = MRc (4.15) = 2.6730E+009
u = su (4.1) = 4.9274896E-005

```

Calculation of ratio lb/lb

Adequate Lap Length: lb/lb >= 1

Calculation of Mu2-

Calculation of ultimate curvature ϕ_u according to 4.1, Biskinis/Fardis 2013:

$$\phi_u = 4.9274896E-005$$

$$\mu = 2.6730E+009$$

with full section properties:

$$b = 450.00$$

$$d = 907.00$$

$$d' = 43.00$$

$$v = 0.00169807$$

$$N = 20792.05$$

$$f_c = 30.00$$

$$\phi_{co} (5A.5, TBDY) = 0.002$$

$$\text{Final value of } \phi_u: \phi_u^* = \text{shear_factor} * \text{Max}(\phi_u, \phi_{co}) = 0.00832321$$

The Shear_factor is considered equal to 1 (pure moment strength)

$$\text{From (5.4b), TBDY: } \phi_u = 0.00832321$$

$$\phi_{we} (5.4c) = 0.01453958$$

$$\phi_{ase} ((5.4d), TBDY) = (\phi_{ase1} * A_{ext} + \phi_{ase2} * A_{int}) / A_{sec} = 0.53375773$$

$$\phi_{ase1} = \text{Max}(((A_{conf,max1} - A_{noConf1}) / A_{conf,max1}) * (A_{conf,min1} / A_{conf,max1}), 0) = 0.53375773$$

The definitions of A_{noConf} , $A_{conf,min}$ and $A_{conf,max}$ are derived from generalization of the rectangular sections confinement, which is expressed by (5.4d).

The generalization is done according to Mander, J., Priestley, M., and Park, R. (1988)

"Theoretical Stress-Strain Model for Confined Concrete."

J. Struct. Eng., 10.1061/(ASCE)0733-9445(1988)114:8(1804), 1804-1826.

$A_{conf,max1} = 464100.00$ is the confined core area at levels of member with hoops and

is calculated as the area of core enclosed by the center lines of the external perimeter hoops.

$A_{conf,min1} = 395025.00$ is the confined core area at midway between the levels of hoops and

is calculated by reducing all the dimensions of the area $A_{conf,max1}$ by a length equal to half the clear spacing between external hoops.

$A_{noConf1} = 173066.667$ is the unconfined external core area which is equal to $b_i d_i / 6$ as defined at (A.2).

$$\phi_{ase2} (> \phi_{ase1}) = \text{Max}(((A_{conf,max2} - A_{noConf2}) / A_{conf,max2}) * (A_{conf,min2} / A_{conf,max2}), 0) = 0.53375773$$

The definitions of A_{noConf} , $A_{conf,min}$ and $A_{conf,max}$ are derived from generalization of the rectangular sections confinement, which is expressed by (5.4d).

The generalization is done according to Mander, J., Priestley, M., and Park, R. (1988)

"Theoretical Stress-Strain Model for Confined Concrete."

J. Struct. Eng., 10.1061/(ASCE)0733-9445(1988)114:8(1804), 1804-1826.

$A_{conf,max2} = 252164.00$ is the confined core area at levels of member with hoops and

is calculated as the area of core enclosed by the center lines of the internal perimeter hoops.

$A_{conf,min2} = 111441.00$ is the confined core area at midway between the levels of hoops and

is calculated by reducing all the dimensions of the area $A_{conf,max2}$ by a length equal to half the clear spacing between internal hoops.

$A_{noConf2} = 110709.333$ is the unconfined internal core area which is equal to $b_i d_i / 6$ as defined at (A.2).

$$\phi_{psh,min} * F_{ywe} = \text{Min}(\phi_{psh,x} * F_{ywe}, \phi_{psh,y} * F_{ywe}) = 2.724$$

Expression (5.4d) for $\phi_{psh,min} * F_{ywe}$ has been multiplied by 0.3 according to 15.7.1.3 for members without earthquake detailing (90° closed stirrups)

$$\phi_{psh,x} * F_{ywe} = \phi_{psh1} * F_{ywe1} + \phi_{ps2} * F_{ywe2} = 2.724$$

$$\phi_{psh1} ((5.4d), TBDY) = L_{stir1} * A_{stir1} / (A_{sec} * s1) = 0.00301593$$

$$L_{stir1} \text{ (Length of stirrups along Y)} = 2160.00$$

$$A_{stir1} \text{ (stirrups area)} = 78.53982$$

$$\phi_{ps2} (5.4d) = L_{stir2} * A_{stir2} / (A_{sec} * s2) = 0.00056047$$

$$L_{stir2} \text{ (Length of stirrups along Y)} = 1568.00$$

$$A_{stir2} \text{ (stirrups area)} = 50.26548$$

$$\phi_{psh,y} * F_{ywe} = \phi_{psh1} * F_{ywe1} + \phi_{ps2} * F_{ywe2} = 3.25416$$

$$\phi_{psh1} ((5.4d), TBDY) = L_{stir1} * A_{stir1} / (A_{sec} * s1) = 0.00357443$$

$$L_{stir1} \text{ (Length of stirrups along X)} = 2560.00$$

$$A_{stir1} \text{ (stirrups area)} = 78.53982$$

$$\phi_{ps2} ((5.4d), TBDY) = L_{stir2} * A_{stir2} / (A_{sec} * s2) = 0.00070345$$

$$L_{stir2} \text{ (Length of stirrups along X)} = 1968.00$$

$$A_{stir2} \text{ (stirrups area)} = 50.26548$$

$$A_{sec} = 562500.00$$

$$s1 = 100.00$$

$$s2 = 250.00$$

$$f_{ywe1} = 781.25$$

$$f_{ywe2} = 656.25$$

$$f_{ce} = 30.00$$

From ((5A.5), TBDY), TBDY: $cc = 0.002$
 $c = \text{confinement factor} = 1.00$
 $y1 = 0.0025$
 $sh1 = 0.008$
 $ft1 = 907.50$
 $fy1 = 756.25$
 $su1 = 0.032$
 using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
 and also multiplied by the shear_factor according to 15.7.1.4, with
 $\text{Shear_factor} = 1.00$
 $lo/lou,min = lb/ld = 1.00$
 $su1 = 0.4*esu1_nominal ((5.5), TBDY) = 0.032$
 From table 5A.1, TBDY: $esu1_nominal = 0.08$,
 For calculation of $esu1_nominal$ and $y1, sh1, ft1, fy1$, it is considered
 characteristic value $fsy1 = fs1/1.2$, from table 5.1, TBDY.
 $y1, sh1, ft1, fy1$, are also multiplied by $\text{Min}(1, 1.25*(lb/ld)^{2/3})$, from 10.3.5, ASCE 41-17.
 with $fs1 = (fs,jacket*Asl,ten,jacket + fs,core*Asl,ten,core)/Asl,ten = 756.25$
 with $Es1 = (Es,jacket*Asl,ten,jacket + Es,core*Asl,ten,core)/Asl,ten = 200000.00$
 $y2 = 0.0025$
 $sh2 = 0.008$
 $ft2 = 907.50$
 $fy2 = 756.25$
 $su2 = 0.032$
 using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
 and also multiplied by the shear_factor according to 15.7.1.4, with
 $\text{Shear_factor} = 1.00$
 $lo/lou,min = lb/lb,min = 1.00$
 $su2 = 0.4*esu2_nominal ((5.5), TBDY) = 0.032$
 From table 5A.1, TBDY: $esu2_nominal = 0.08$,
 For calculation of $esu2_nominal$ and $y2, sh2, ft2, fy2$, it is considered
 characteristic value $fsy2 = fs2/1.2$, from table 5.1, TBDY.
 $y1, sh1, ft1, fy1$, are also multiplied by $\text{Min}(1, 1.25*(lb/ld)^{2/3})$, from 10.3.5, ASCE 41-17.
 with $fs2 = (fs,jacket*Asl,com,jacket + fs,core*Asl,com,core)/Asl,com = 756.25$
 with $Es2 = (Es,jacket*Asl,com,jacket + Es,core*Asl,com,core)/Asl,com = 200000.00$
 $yv = 0.0025$
 $shv = 0.008$
 $ftv = 899.1522$
 $fyv = 749.2935$
 $suv = 0.032$
 using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
 and also multiplied by the shear_factor according to 15.7.1.4, with
 $\text{Shear_factor} = 1.00$
 $lo/lou,min = lb/ld = 1.00$
 $suv = 0.4*esuv_nominal ((5.5), TBDY) = 0.032$
 From table 5A.1, TBDY: $esuv_nominal = 0.08$,
 considering characteristic value $fsyv = fsv/1.2$, from table 5.1, TBDY
 For calculation of $esuv_nominal$ and yv, shv, ftv, fyv , it is considered
 characteristic value $fsyv = fsv/1.2$, from table 5.1, TBDY.
 $y1, sh1, ft1, fy1$, are also multiplied by $\text{Min}(1, 1.25*(lb/ld)^{2/3})$, from 10.3.5, ASCE 41-17.
 with $fsv = (fs,jacket*Asl,mid,jacket + fs,mid*Asl,mid,core)/Asl,mid = 749.2935$
 with $Es_v = (Es,jacket*Asl,mid,jacket + Es,mid*Asl,mid,core)/Asl,mid = 200000.00$
 $1 = Asl,ten/(b*d)*(fs1/fc) = 0.09507586$
 $2 = Asl,com/(b*d)*(fs2/fc) = 0.09507586$
 $v = Asl,mid/(b*d)*(fsv/fc) = 0.22108466$
 and confined core properties:
 $b = 390.00$
 $d = 877.00$
 $d' = 13.00$
 $fcc (5A.2, TBDY) = 30.00$
 $cc (5A.5, TBDY) = 0.002$
 $c = \text{confinement factor} = 1.00$
 $1 = Asl,ten/(b*d)*(fs1/fc) = 0.11345559$
 $2 = Asl,com/(b*d)*(fs2/fc) = 0.11345559$
 $v = Asl,mid/(b*d)*(fsv/fc) = 0.26382395$
 Case/Assumption: Unconfined full section - Steel rupture
 ' satisfies Eq. (4.3)

--->

$v < v_{s,y2}$ - LHS eq.(4.5) is not satisfied

---->

$v < v_{s,c}$ - RHS eq.(4.5) is satisfied

---->

$$s_u(4.8) = 0.28399348$$

$$M_u = M_{Rc}(4.15) = 2.6730E+009$$

$$u = s_u(4.1) = 4.9274896E-005$$

Calculation of ratio l_b/l_d

Adequate Lap Length: $l_b/l_d \geq 1$

Calculation of Shear Strength $V_r = \text{Min}(V_{r1}, V_{r2}) = 1.6349E+006$

Calculation of Shear Strength at edge 1, $V_{r1} = 1.6349E+006$

$$V_{r1} = V_{Col}((10.3), ASCE 41-17) = k_n l^* V_{ColO}$$

$$V_{ColO} = 1.6349E+006$$

$$k_n l = 1 \text{ (zero step-static loading)}$$

NOTE: In expression (10-3) ' $V_s = A_v f_y d/s$ ' is replaced by ' $V_{s+} f^* V_f$ ' where V_f is the contribution of FRPs (11.3), ACI 440).

$$= 1 \text{ (normal-weight concrete)}$$

Mean concrete strength: $f'_c = (f'_{c,jacket} \cdot \text{Area}_{jacket} + f'_{c,core} \cdot \text{Area}_{core}) / \text{Area}_{section} = 27.20$, but $f'_c^{0.5} \leq 8.3$ MPa (22.5.3.1, ACI 318-14)

$$M/Vd = 2.00$$

$$M_u = 4.16869$$

$$V_u = 5.2099631E-036$$

$$d = 0.8 \cdot h = 760.00$$

$$N_u = 20792.05$$

$$A_g = 427500.00$$

$$\text{From (11.5.4.8), ACI 318-14: } V_s = V_{s,jacket} + V_{s,core} = 1.2262E+006$$

where:

$$V_{s,jacket} = V_{s,j1} + V_{s,j2} = 1.0996E+006$$

$V_{s,j1} = 353429.174$ is calculated for section web jacket, with:

$$d = 360.00$$

$$A_v = 157079.633$$

$$f_y = 625.00$$

$$s = 100.00$$

$$V_{s,j1} \text{ is multiplied by } Col,j1 = 1.00$$

$$s/d = 0.27777778$$

$V_{s,j2} = 746128.255$ is calculated for section flange jacket, with:

$$d = 760.00$$

$$A_v = 157079.633$$

$$f_y = 625.00$$

$$s = 100.00$$

$$V_{s,j2} \text{ is multiplied by } Col,j2 = 1.00$$

$$s/d = 0.13157895$$

$$V_{s,core} = V_{s,c1} + V_{s,c2} = 126669.016$$

$V_{s,c1} = 0.00$ is calculated for section web core, with:

$$d = 200.00$$

$$A_v = 100530.965$$

$$f_y = 525.00$$

$$s = 250.00$$

$$V_{s,c1} \text{ is multiplied by } Col,c1 = 0.00$$

$$s/d = 1.25$$

$V_{s,c2} = 126669.016$ is calculated for section flange core, with:

$$d = 600.00$$

$$A_v = 100530.965$$

$$f_y = 525.00$$

$$s = 250.00$$

$$V_{s,c2} \text{ is multiplied by } Col,c2 = 1.00$$

$$s/d = 0.41666667$$

Vf ((11-3)-(11.4), ACI 440) = 0.00
From (11-11), ACI 440: $V_s + V_f \leq 1.1849E+006$
bw = 450.00

Calculation of Shear Strength at edge 2, $V_{r2} = 1.6349E+006$
 $V_{r2} = V_{Col} ((10.3), ASCE 41-17) = knl * V_{Col0}$
 $V_{Col0} = 1.6349E+006$
knl = 1 (zero step-static loading)

NOTE: In expression (10-3) ' $V_s = A_v * f_y * d / s$ ' is replaced by ' $V_s + f * V_f$ '
where V_f is the contribution of FRPs (11.3), ACI 440).

= 1 (normal-weight concrete)
Mean concrete strength: $f_c' = (f_c'_{jacket} * Area_{jacket} + f_c'_{core} * Area_{core}) / Area_{section} = 27.20$, but $f_c'^{0.5} \leq 8.3$
MPa (22.5.3.1, ACI 318-14)
 $M/Vd = 2.00$
 $\mu_u = 4.16869$
 $V_u = 5.2099631E-036$
 $d = 0.8 * h = 760.00$
 $N_u = 20792.05$
 $A_g = 427500.00$
From (11.5.4.8), ACI 318-14: $V_s = V_{sjacket} + V_{s,core} = 1.2262E+006$
where:
 $V_{sjacket} = V_{sj1} + V_{sj2} = 1.0996E+006$
 $V_{sj1} = 353429.174$ is calculated for section web jacket, with:
 $d = 360.00$
 $A_v = 157079.633$
 $f_y = 625.00$
 $s = 100.00$
 V_{sj1} is multiplied by $Col,j1 = 1.00$
 $s/d = 0.27777778$
 $V_{sj2} = 746128.255$ is calculated for section flange jacket, with:
 $d = 760.00$
 $A_v = 157079.633$
 $f_y = 625.00$
 $s = 100.00$
 V_{sj2} is multiplied by $Col,j2 = 1.00$
 $s/d = 0.13157895$
 $V_{s,core} = V_{s,c1} + V_{s,c2} = 126669.016$
 $V_{s,c1} = 0.00$ is calculated for section web core, with:
 $d = 200.00$
 $A_v = 100530.965$
 $f_y = 525.00$
 $s = 250.00$
 $V_{s,c1}$ is multiplied by $Col,c1 = 0.00$
 $s/d = 1.25$
 $V_{s,c2} = 126669.016$ is calculated for section flange core, with:
 $d = 600.00$
 $A_v = 100530.965$
 $f_y = 525.00$
 $s = 250.00$
 $V_{s,c2}$ is multiplied by $Col,c2 = 1.00$
 $s/d = 0.41666667$
 $V_f ((11-3)-(11.4), ACI 440) = 0.00$
From (11-11), ACI 440: $V_s + V_f \leq 1.1849E+006$
bw = 450.00

End Of Calculation of Shear Capacity ratio for element: column JTC1 of floor 1
At local axis: 2

Start Of Calculation of Chord Rotation Capacity for element: column JTC1 of floor 1
At local axis: 3

Integration Section: (b)

Section Type: rcjtcs

Constant Properties

Knowledge Factor, $\gamma = 0.80$

Chord Rotation is generally considered as Deformation-Controlled Action according to Table C7-1, ASCE 41-17.

Mean strengths are used for Deformation-Controlled Actions according to 7.5.1.3, ASCE 41-17

Consequently:

Jacket

New material of Secondary Member: Concrete Strength, $f_c = f_{cm} = 30.00$

New material of Secondary Member: Steel Strength, $f_s = f_{sm} = 625.00$

Concrete Elasticity, $E_c = 25742.96$

Steel Elasticity, $E_s = 200000.00$

Existing Column

Existing material of Secondary Member: Concrete Strength, $f_c = f_{cm} = 24.00$

Existing material of Secondary Member: Steel Strength, $f_s = f_{sm} = 525.00$

Concrete Elasticity, $E_c = 23025.204$

Steel Elasticity, $E_s = 200000.00$

Max Height, $H_{max} = 750.00$

Min Height, $H_{min} = 450.00$

Max Width, $W_{max} = 950.00$

Min Width, $W_{min} = 450.00$

Eccentricity, $Ecc = 250.00$

Jacket Thickness, $t_j = 100.00$

Cover Thickness, $c = 25.00$

Element Length, $L = 3000.00$

Secondary Member

Smooth Bars

Ductile Steel

Without Detailing for Earthquake Resistance (including stirrups not closed at 135°)

Longitudinal Bars With Ends Lapped Starting at the End Sections

Adequate Lap Length ($l_b/d \geq 1$)

No FRP Wrapping

Stepwise Properties

Bending Moment, $M = 215890.77$

Shear Force, $V_2 = 5479.017$

Shear Force, $V_3 = 1.3008$

Axial Force, $F = -21838.055$

Longitudinal Reinforcement Area Distribution (in 2 divisions)

-Tension: $As_t = 0.00$

-Compression: $As_c = 6691.592$

Longitudinal Reinforcement Area Distribution (in 3 divisions)

-Tension: $As_{t,ten} = 1539.38$

-Compression: $As_{c,com} = 1539.38$

-Middle: $As_{mid} = 3612.832$

Longitudinal External Reinforcement Area Distribution (in 3 divisions)

-Tension: $As_{t,ten,jacket} = 1231.504$

-Compression: $As_{c,com,jacket} = 1231.504$

-Middle: $As_{mid,jacket} = 2689.203$

Longitudinal Internal Reinforcement Area Distribution (in 3 divisions)

-Tension: $As_{t,ten,core} = 307.8761$

-Compression: $As_{c,com,core} = 307.8761$

-Middle: $As_{mid,core} = 923.6282$

Mean Diameter of Tension Reinforcement, $Db_L = 16.57143$

Existing component: From table 7-7, ASCE 41_17: Final chord rotation Capacity $u_{R} = \gamma \cdot u = 0.00223975$

$u = \gamma \cdot y + p = 0.00279969$

- Calculation of γ -

$y = (M_y * L_s / 3) / E_{eff} = 0.00050073 \text{ ((4.29), Biskinis Phd)}$
 $M_y = 1.2939E+009$
 $L_s = M/V \text{ (with } L_s > 0.1 * L \text{ and } L_s < 2 * L) = 300.00$
 From table 10.5, ASCE 41_17: $E_{eff} = \text{factor} * E_c * I_g = 2.5841E+014$
 $\text{factor} = 0.30$
 $A_g = 562500.00$
 Mean concrete strength: $f_c' = (f_c'_{\text{jacket}} * A_{\text{jacket}} + f_c'_{\text{core}} * A_{\text{core}}) / A_{\text{section}} = 27.20$
 $N = 21838.055$
 $E_c * I_g = E_{c_jacket} * I_{g_jacket} + E_{c_core} * I_{g_core} = 8.6137E+014$

Calculation of Yielding Moment M_y

Calculation of y and M_y according to Annex 7 -

$y = \text{Min}(y_{\text{ten}}, y_{\text{com}})$
 $y_{\text{ten}} = 4.4892910E-006$
 with $f_y = 601.9953$
 $d = 907.00$
 $y = 0.26077258$
 $A = 0.01648381$
 $B = 0.00867498$
 with $p_t = 0.0037716$
 $p_c = 0.0037716$
 $p_v = 0.00885172$
 $N = 21838.055$
 $b = 450.00$
 $" = 0.04740904$
 $y_{\text{comp}} = 8.8910413E-006$
 with $f_c = 30.00$
 $E_c = 25742.96$
 $y = 0.26012097$
 $A = 0.0162674$
 $B = 0.0085861$
 with $E_s = 200000.00$

Calculation of ratio I_b/I_d

Adequate Lap Length: $I_b/I_d \geq 1$

- Calculation of p -

From table 10-8: $p = 0.00229896$

with:

- Columns not controlled by inadequate development or splicing along the clear height because $I_b/I_d \geq 1$

shear control ratio $V_y E / V_{col} E = 1.08994$

$d = d_{\text{external}} = 907.00$

$s = s_{\text{external}} = 0.00$

- $t = s_1 + s_2 + 2 * t_f / b_w * (f_{fe} / f_s) = 0.00427788$

jacket: $s_1 = A_{v1} * L_{\text{stir1}} / (s_1 * A_g) = 0.00357443$

$A_{v1} = 78.53982$, is the area of every stirrup parallel to loading (shear) direction

$L_{\text{stir1}} = 2560.00$, is the total Length of all stirrups parallel to loading (shear) direction

$s_1 = 100.00$

core: $s_2 = A_{v2} * L_{\text{stir2}} / (s_2 * A_g) = 0.00070345$

$A_{v2} = 50.26548$, is the area of every stirrup parallel to loading (shear) direction

$L_{\text{stir2}} = 1968.00$, is the total Length of all stirrups parallel to loading (shear) direction

$s_2 = 250.00$

The term $2 * t_f / b_w * (f_{fe} / f_s)$ is implemented to account for FRP contribution

where $f = 2 * t_f / b_w$ is FRP ratio (EC8 - 3, A.4.4.3(6)) and f_{fe} / f_s normalises f to steel strength

All these variables have already been given in Shear control ratio calculation.

For the normalisation f_s of jacket is used.

$N_{UD} = 21838.055$


$A_g = 562500.00$

$f_{cE} = (f_{c_jacket} \cdot Area_jacket + f_{c_core} \cdot Area_core) / section_area = 27.20$
 $f_{yIE} = (f_{y_ext_Long_Reinf} \cdot Area_ext_Long_Reinf + f_{y_int_Long_Reinf} \cdot Area_int_Long_Reinf) / Area_Tot_Long_Rein = 601.9953$
 $f_{yIE} = (f_{y_ext_Trans_Reinf} \cdot s1 + f_{y_int_Trans_Reinf} \cdot s2) / (s1 + s2) = 608.5561$
 $\rho_l = Area_Tot_Long_Rein / (b \cdot d) = 0.01639493$
 $b = 450.00$
 $d = 907.00$
 $f_{cE} = 27.20$

 End Of Calculation of Chord Rotation Capacity for element: column JTC1 of floor 1
 At local axis: 3
 Integration Section: (b)

Calculation No. 9

column C1, Floor 1
 Limit State: Life Safety (data interpolation between analysis steps 1 and 2)
 Analysis: Uniform +X
 Check: Shear capacity V_{Rd}
 Edge: Start
 Local Axis: (2)



Start Of Calculation of Shear Capacity for element: column JTC1 of floor 1
 At local axis: 2
 Integration Section: (a)
 Section Type: rcjtcs

Constant Properties

 Knowledge Factor, $\gamma = 0.80$
 Member Shear Force is generally considered as Force-Controlled Action according to Table C7-1, ASCE 41-17.
 Lower-bound strengths are used for Force-Controlled Actions according to 7.5.1.3, ASCE 41-17
 Consequently:
 Jacket
 New material of Secondary Member: Concrete Strength, $f_c = f_{c_lower_bound} = 20.00$

New material of Secondary Member: Steel Strength, $f_s = f_{s_lower_bound} = 500.00$
 Concrete Elasticity, $E_c = 25742.96$
 Steel Elasticity, $E_s = 200000.00$
 Existing Column
 Existing material of Secondary Member: Concrete Strength, $f_c = f_{c_lower_bound} = 16.00$
 Existing material of Secondary Member: Steel Strength, $f_s = f_{s_lower_bound} = 420.00$
 Concrete Elasticity, $E_c = 23025.204$
 Steel Elasticity, $E_s = 200000.00$
 #####
 Note: Especially for the calculation of γ for displacement ductility demand,
 the expected (mean value) strengths are used (7.5.1.3, ASCE 41-17) because bending is considered as
 Deformation-Controlled Action (Table C7-1, ASCE 41-17).
 Jacket
 New material: Concrete Strength, $f_c = f_{cm} = 30.00$
 New material: Steel Strength, $f_s = f_{sm} = 625.00$
 Existing Column
 Existing material: Concrete Strength, $f_c = f_{cm} = 24.00$
 Existing material: Steel Strength, $f_s = f_{sm} = 525.00$
 #####
 Max Height, $H_{max} = 750.00$
 Min Height, $H_{min} = 450.00$
 Max Width, $W_{max} = 950.00$
 Min Width, $W_{min} = 450.00$
 Eccentricity, $Ecc = 250.00$
 Jacket Thickness, $t_j = 100.00$
 Cover Thickness, $c = 25.00$
 Element Length, $L = 3000.00$
 Secondary Member
 Smooth Bars
 Ductile Steel
 Without Detailing for Earthquake Resistance (including stirrups not closed at 135°)
 Longitudinal Bars With Ends Lapped Starting at the End Sections
 Adequate Lap Length ($l_o/l_{ou,min} = l_b/l_d \geq 1$)
 No FRP Wrapping

----- Stepwise Properties -----

EDGE -A-
 Bending Moment, $M_a = -2.5217E+007$
 Shear Force, $V_a = -8294.64$
 EDGE -B-
 Bending Moment, $M_b = 326833.199$
 Shear Force, $V_b = 8294.64$
 BOTH EDGES
 Axial Force, $F = -22375.589$
 Longitudinal Reinforcement Area Distribution (in 2 divisions)
 -Tension: $As_t = 0.00$
 -Compression: $As_c = 6691.592$
 Longitudinal Reinforcement Area Distribution (in 3 divisions)
 -Tension: $As_{l,ten} = 1539.38$
 -Compression: $As_{l,com} = 1539.38$
 -Middle: $As_{l,mid} = 3612.832$
 Mean Diameter of Tension Reinforcement, $Db_{L,ten} = 16.57143$

 Existing component: From table 7-7, ASCE 41_17: Final Shear Capacity $V_R = \phi V_n = 921379.524$
 V_n ((10.3), ASCE 41-17) = $k_n l \cdot V_{CoI} = 1.1517E+006$
 $V_{CoI} = 1.1517E+006$
 $k_n l = 1.00$
 displacement_ductility_demand = 0.01202712

 NOTE: In expression (10-3) ' $V_s = A_v \cdot f_y \cdot d/s$ ' is replaced by ' $V_s + \phi \cdot V_f$ '
 where V_f is the contribution of FRPs (11.3), ACI 440).

= 1 (normal-weight concrete)
Mean concrete strength: $fc' = (fc'_{jacket} \cdot Area_{jacket} + fc'_{core} \cdot Area_{core}) / Area_{section} = 18.13333$, but $fc'^{0.5} \leq 8.3$ MPa (22.5.3.1, ACI 318-14)
 $M/Vd = 4.00$
 $\mu_u = 2.5217E+007$
 $V_u = 8294.64$
 $d = 0.8 \cdot h = 760.00$
 $N_u = 22375.589$
 $A_g = 427500.00$
From (11.5.4.8), ACI 318-14: $V_s = V_{sjacket} + V_{s,core} = 980981.156$
where:
 $V_{sjacket} = V_{sj1} + V_{sj2} = 879645.943$
 $V_{sj1} = 282743.339$ is calculated for section web jacket, with:
 $d = 360.00$
 $A_v = 157079.633$
 $f_y = 500.00$
 $s = 100.00$
 V_{sj1} is multiplied by $Col,j1 = 1.00$
 $s/d = 0.27777778$
 $V_{sj2} = 596902.604$ is calculated for section flange jacket, with:
 $d = 760.00$
 $A_v = 157079.633$
 $f_y = 500.00$
 $s = 100.00$
 V_{sj2} is multiplied by $Col,j2 = 1.00$
 $s/d = 0.13157895$
 $V_{s,core} = V_{s,c1} + V_{s,c2} = 101335.213$
 $V_{s,c1} = 0.00$ is calculated for section web core, with:
 $d = 200.00$
 $A_v = 100530.965$
 $f_y = 420.00$
 $s = 250.00$
 $V_{s,c1}$ is multiplied by $Col,c1 = 0.00$
 $s/d = 1.25$
 $V_{s,c2} = 101335.213$ is calculated for section flange core, with:
 $d = 600.00$
 $A_v = 100530.965$
 $f_y = 420.00$
 $s = 250.00$
 $V_{s,c2}$ is multiplied by $Col,c2 = 1.00$
 $s/d = 0.41666667$
 $V_f ((11-3)-(11.4), ACI 440) = 0.00$
From (11-11), ACI 440: $V_s + V_f \leq 967457.029$
 $bw = 450.00$

displacement_ductility_demand is calculated as ϕ_y

- Calculation of ϕ_y for END A -
for rotation axis 3 and integ. section (a)

From analysis, chord rotation $\theta = 6.1037811E-005$
 $y = (M_y \cdot L_s / 3) / E_{eff} = 0.00507501$ ((4.29), Biskinis Phd))
 $M_y = 1.2941E+009$
 $L_s = M/V$ (with $L_s > 0.1 \cdot L$ and $L_s < 2 \cdot L$) = 3040.138
From table 10.5, ASCE 41_17: $E_{eff} = factor \cdot E_c \cdot I_g = 2.5841E+014$
 $factor = 0.30$
 $A_g = 562500.00$
Mean concrete strength: $fc' = (fc'_{jacket} \cdot Area_{jacket} + fc'_{core} \cdot Area_{core}) / Area_{section} = 27.20$
 $N = 22375.589$
 $E_c \cdot I_g = E_{c,jacket} \cdot I_{g,jacket} + E_{c,core} \cdot I_{g,core} = 8.6137E+014$

Calculation of Yielding Moment M_y

Calculation of y and M_y according to Annex 7 -

$y = \text{Min}(y_{\text{ten}}, y_{\text{com}})$
 $y_{\text{ten}} = 4.4894872\text{E-}006$
with $f_y = 601.9953$
 $d = 907.00$
 $y = 0.26080489$
 $A = 0.016486$
 $B = 0.00867717$
with $p_t = 0.0037716$
 $p_c = 0.0037716$
 $p_v = 0.00885172$
 $N = 22375.589$
 $b = 450.00$
 $" = 0.04740904$
 $y_{\text{comp}} = 8.8904803\text{E-}006$
with $f_c = 30.00$
 $E_c = 25742.96$
 $y = 0.26013738$
 $A = 0.01626426$
 $B = 0.0085861$
with $E_s = 200000.00$

Calculation of ratio I_b/I_d

Adequate Lap Length: $I_b/I_d \geq 1$

End Of Calculation of Shear Capacity for element: column JTC1 of floor 1

At local axis: 2

Integration Section: (a)

Calculation No. 10

column C1, Floor 1



Limit State: Life Safety (data interpolation between analysis steps 1 and 2)

Analysis: Uniform +X

Check: Chord rotation capacity (ϕ_r)

Edge: Start

Local Axis: (2)



Start Of Calculation of Shear Capacity ratio for element: column JTC1 of floor 1

At Shear local axis: 3

(Bending local axis: 2)

Section Type: rcjtcs

Constant Properties

Knowledge Factor, $\gamma = 0.80$

Mean strength values are used for both shear and moment calculations.

Consequently:

Jacket

New material of Secondary Member: Concrete Strength, $f_c = f_{cm} = 30.00$

New material of Secondary Member: Steel Strength, $f_s = f_{sm} = 625.00$

Concrete Elasticity, $E_c = 25742.96$

Steel Elasticity, $E_s = 200000.00$

Existing Column

Existing material of Secondary Member: Concrete Strength, $f_c = f_{cm} = 24.00$

Existing material of Secondary Member: Steel Strength, $f_s = f_{sm} = 525.00$

Concrete Elasticity, $E_c = 23025.204$

Steel Elasticity, $E_s = 200000.00$

#####

Note: Especially for the calculation of moment strengths,

the above steel re-bar strengths are multiplied by 1.25 according to R18.6.5, ACI 318-14

Jacket

New material: Steel Strength, $f_s = 1.25 \cdot f_{sm} = 781.25$

Existing Column

Existing material: Steel Strength, $f_s = 1.25 \cdot f_{sm} = 656.25$

#####

Max Height, $H_{max} = 750.00$

Min Height, $H_{min} = 450.00$

Max Width, $W_{max} = 950.00$

Min Width, $W_{min} = 450.00$

Eccentricity, $E_{cc} = 250.00$

Jacket Thickness, $t_j = 100.00$

Cover Thickness, $c = 25.00$

Mean Confinement Factor overall section = 1.00

Element Length, $L = 3000.00$

Secondary Member

Smooth Bars

Ductile Steel

Without Detailing for Earthquake Resistance (including stirrups not closed at 135°)

Longitudinal Bars With Ends Lapped Starting at the End Sections

Adequate Lap Length ($l_o/l_{o,min} \geq 1$)

No FRP Wrapping

Stepwise Properties

At local axis: 3

EDGE -A-

Shear Force, $V_a = -8.5087964E-020$

EDGE -B-

Shear Force, $V_b = 8.5087964E-020$
 BOTH EDGES
 Axial Force, $F = -20792.05$
 Longitudinal Reinforcement Area Distribution (in 2 divisions)
 -Tension: $As_t = 0.00$
 -Compression: $As_c = 6691.592$
 Longitudinal Reinforcement Area Distribution (in 3 divisions)
 -Tension: $As_{t,ten} = 1539.38$
 -Compression: $As_{c,com} = 2475.575$
 -Middle: $As_{mid} = 2676.637$

Calculation of Shear Capacity ratio, $V_e/V_r = 1.11674$
 Member Controlled by Shear ($V_e/V_r > 1$)
 Calculation of Shear Demand from fig. R18.6.5, ACI 318-14 $V_e = (M_{pr1} + M_{pr2})/l_n = 1.4424E+006$
 with
 $M_{pr1} = \text{Max}(\mu_{u1+}, \mu_{u1-}) = 2.1636E+009$
 $\mu_{u1+} = 2.0419E+009$, is the ultimate moment strength at the edge 1 of the member in the actual moment direction which is defined for the static loading combination
 $\mu_{u1-} = 2.1636E+009$, is the ultimate moment strength at the edge 1 of the member in the opposite moment direction which is defined for the static loading combination
 $M_{pr2} = \text{Max}(\mu_{u2+}, \mu_{u2-}) = 2.1636E+009$
 $\mu_{u2+} = 2.0419E+009$, is the ultimate moment strength at the edge 2 of the member in the actual moment direction which is defined for the static loading combination
 $\mu_{u2-} = 2.1636E+009$, is the ultimate moment strength at the edge 2 of the member in the opposite moment direction which is defined for the static loading combination

Calculation of μ_{u1+}

Calculation of ultimate curvature ϕ_u according to 4.1, Biskinis/Fardis 2013:
 $\phi_u = 5.3321191E-005$
 $\mu_u = 2.0419E+009$

with full section properties:

$b = 950.00$
 $d = 707.00$
 $d' = 43.00$
 $v = 0.00103189$
 $N = 20792.05$
 $f_c = 30.00$
 $\phi_c (5A.5, TBDY) = 0.002$

Final value of ϕ_u : $\phi_u^* = \text{shear_factor} * \text{Max}(\phi_u, \phi_c) = 0.00832321$

The Shear_factor is considered equal to 1 (pure moment strength)

From (5.4b), TBDY: $\phi_u = 0.00832321$

we (5.4c) = 0.01453958

$\phi_{se} ((5.4d), TBDY) = (\phi_{se1} * A_{ext} + \phi_{se2} * A_{int}) / A_{sec} = 0.53375773$

$\phi_{se1} = \text{Max}(((A_{conf,max1} - A_{noConf1}) / A_{conf,max1}) * (A_{conf,min1} / A_{conf,max1}), 0) = 0.53375773$

The definitions of A_{noConf} , $A_{conf,min}$ and $A_{conf,max}$ are derived from generalization of the rectangular sections confinement, which is expressed by (5.4d).

The generalization is done according to Mander, J., Priestley, M., and Park, R. (1988)

"Theoretical Stress-Strain Model for Confined Concrete."

J. Struct. Eng., 10.1061/(ASCE)0733-9445(1988)114:8(1804), 1804-1826.

$A_{conf,max1} = 464100.00$ is the confined core area at levels of member with hoops and is calculated as the area of core enclosed by the center lines of the external perimeter hoops.

$A_{conf,min1} = 395025.00$ is the confined core area at midway between the levels of hoops and is calculated by reducing all the dimensions of the area $A_{conf,max1}$ by a length equal to half the clear spacing between external hoops.

$A_{noConf1} = 173066.667$ is the unconfined external core area which is equal to $b_i^2/6$ as defined at (A.2).

$\phi_{se2} (> \phi_{se1}) = \text{Max}(((A_{conf,max2} - A_{noConf2}) / A_{conf,max2}) * (A_{conf,min2} / A_{conf,max2}), 0) = 0.53375773$

The definitions of A_{noConf} , $A_{conf,min}$ and $A_{conf,max}$ are derived from generalization of the rectangular sections confinement, which is expressed by (5.4d).

The generalization is done according to Mander, J., Priestley, M., and Park, R. (1988)

"Theoretical Stress-Strain Model for Confined Concrete."

J. Struct. Eng., 10.1061/(ASCE)0733-9445(1988)114:8(1804), 1804-1826.

$A_{conf,max2} = 252164.00$ is the confined core area at levels of member with hoops and is calculated as the area of core enclosed by the center lines of the internal perimeter hoops.
 $A_{conf,min2} = 111441.00$ is the confined core area at midway between the levels of hoops and is calculated by reducing all the dimensions of the area $A_{conf,max2}$ by a length equal to half the clear spacing between internal hoops.

$A_{noConf2} = 110709.333$ is the unconfined internal core area which is equal to $b_i^2/6$ as defined at (A.2).

$p_{sh,min} \cdot F_{ywe} = \text{Min}(p_{sh,x} \cdot F_{ywe}, p_{sh,y} \cdot F_{ywe}) = 2.724$

Expression (5.4d) for $p_{sh,min} \cdot F_{ywe}$ has been multiplied by 0.3 according to 15.7.1.3 for members without earthquake detailing (90° closed stirrups)

$p_{sh,x} \cdot F_{ywe} = p_{sh1} \cdot F_{ywe1} + p_{s2} \cdot F_{ywe2} = 2.724$

p_{sh1} ((5.4d), TBDY) = $L_{stir1} \cdot A_{stir1} / (A_{sec} \cdot s_1) = 0.00301593$

L_{stir1} (Length of stirrups along Y) = 2160.00

A_{stir1} (stirrups area) = 78.53982

p_{s2} (5.4d) = $L_{stir2} \cdot A_{stir2} / (A_{sec} \cdot s_2) = 0.00056047$

L_{stir2} (Length of stirrups along Y) = 1568.00

A_{stir2} (stirrups area) = 50.26548

$p_{sh,y} \cdot F_{ywe} = p_{sh1} \cdot F_{ywe1} + p_{s2} \cdot F_{ywe2} = 3.25416$

p_{sh1} ((5.4d), TBDY) = $L_{stir1} \cdot A_{stir1} / (A_{sec} \cdot s_1) = 0.00357443$

L_{stir1} (Length of stirrups along X) = 2560.00

A_{stir1} (stirrups area) = 78.53982

p_{s2} ((5.4d), TBDY) = $L_{stir2} \cdot A_{stir2} / (A_{sec} \cdot s_2) = 0.00070345$

L_{stir2} (Length of stirrups along X) = 1968.00

A_{stir2} (stirrups area) = 50.26548

$A_{sec} = 562500.00$

$s_1 = 100.00$

$s_2 = 250.00$

$f_{ywe1} = 781.25$

$f_{ywe2} = 656.25$

$f_{ce} = 30.00$

From ((5.A5), TBDY), TBDY: $cc = 0.002$

c = confinement factor = 1.00

$y_1 = 0.0025$

$sh_1 = 0.008$

$ft_1 = 907.50$

$fy_1 = 756.25$

$su_1 = 0.032$

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor and also multiplied by the shear_factor according to 15.7.1.4, with Shear_factor = 1.00

$l_o/l_{ou,min} = l_b/l_d = 1.00$

$su_1 = 0.4 \cdot esu1_{nominal}$ ((5.5), TBDY) = 0.032

From table 5A.1, TBDY: $esu1_{nominal} = 0.08$,

For calculation of $esu1_{nominal}$ and y_1, sh_1, ft_1, fy_1 , it is considered characteristic value $fsy_1 = fs_1/1.2$, from table 5.1, TBDY.

y_1, sh_1, ft_1, fy_1 , are also multiplied by $\text{Min}(1, 1.25 \cdot (l_b/l_d)^{2/3})$, from 10.3.5, ASCE 41-17.

with $fs_1 = (f_{s,jacket} \cdot A_{sl,ten,jacket} + f_{s,core} \cdot A_{sl,ten,core}) / A_{sl,ten} = 756.25$

with $Es_1 = (E_{s,jacket} \cdot A_{sl,ten,jacket} + E_{s,core} \cdot A_{sl,ten,core}) / A_{sl,ten} = 200000.00$

$y_2 = 0.0025$

$sh_2 = 0.008$

$ft_2 = 900.1904$

$fy_2 = 750.1586$

$su_2 = 0.032$

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor and also multiplied by the shear_factor according to 15.7.1.4, with Shear_factor = 1.00

$l_o/l_{ou,min} = l_b/l_{b,min} = 1.00$

$su_2 = 0.4 \cdot esu2_{nominal}$ ((5.5), TBDY) = 0.032

From table 5A.1, TBDY: $esu2_{nominal} = 0.08$,

For calculation of $esu2_{nominal}$ and y_2, sh_2, ft_2, fy_2 , it is considered characteristic value $fsy_2 = fs_2/1.2$, from table 5.1, TBDY.

y_1, sh_1, ft_1, fy_1 , are also multiplied by $\text{Min}(1, 1.25 \cdot (l_b/l_d)^{2/3})$, from 10.3.5, ASCE 41-17.

with $fs_2 = (f_{s,jacket} \cdot A_{sl,com,jacket} + f_{s,core} \cdot A_{sl,com,core}) / A_{sl,com} = 750.1586$

```

with Es2 = (Es,jacket*Asl,com,jacket + Es,core*Asl,com,core)/Asl,com = 200000.00
yv = 0.0025
shv = 0.008
ftv = 902.993
fyv = 752.4941
suv = 0.032
using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00
lo/lou,min = lb/d = 1.00
suv = 0.4*esuv_nominal ((5.5), TBDY) = 0.032
From table 5A.1, TBDY: esuv_nominal = 0.08,
considering characteristic value fsyv = fsv/1.2, from table 5.1, TBDY
For calculation of esuv_nominal and yv, shv,ftv,fyv, it is considered
characteristic value fsyv = fsv/1.2, from table 5.1, TBDY.
y1, sh1,ft1,fy1, are also multiplied by Min(1,1.25*(lb/d)^2/3), from 10.3.5, ASCE 41-17.
with fsv = (fs,jacket*Asl,mid,jacket + fs,mid*Asl,mid,core)/Asl,mid = 752.4941
with Esv = (Es,jacket*Asl,mid,jacket + Es,mid*Asl,mid,core)/Asl,mid = 200000.00
1 = Asl,ten/(b*d)*(fs1/fc) = 0.05777595
2 = Asl,com/(b*d)*(fs2/fc) = 0.09216477
v = Asl,mid/(b*d)*(fsv/fc) = 0.09996047
and confined core properties:
b = 890.00
d = 677.00
d' = 13.00
fcc (5A.2, TBDY) = 30.00
cc (5A.5, TBDY) = 0.002
c = confinement factor = 1.00
1 = Asl,ten/(b*d)*(fs1/fc) = 0.06440379
2 = Asl,com/(b*d)*(fs2/fc) = 0.10273757
v = Asl,mid/(b*d)*(fsv/fc) = 0.11142757
Case/Assumption: Unconfined full section - Steel rupture
'satisfies Eq. (4.3)
--->
v < vs,y2 - LHS eq.(4.5) is not satisfied
--->
v < vs,c - RHS eq.(4.5) is satisfied
--->
su (4.8) = 0.15115045
Mu = MRc (4.15) = 2.0419E+009
u = su (4.1) = 5.3321191E-005

```

Calculation of ratio lb/d

Adequate Lap Length: lb/d >= 1

Calculation of Mu1-

Calculation of ultimate curvature u according to 4.1, Biskinis/Fardis 2013:

u = 6.8287974E-005
Mu = 2.1636E+009

with full section properties:

b = 450.00
d = 707.00
d' = 43.00
v = 0.00217843
N = 20792.05
fc = 30.00
co (5A.5, TBDY) = 0.002
Final value of cu: cu* = shear_factor * Max(cu, cc) = 0.00832321
The Shear_factor is considered equal to 1 (pure moment strength)

From (5.4b), TBDY: $c_u = 0.00832321$

w_e (5.4c) = 0.01453958

a_{se} ((5.4d), TBDY) = $(a_{se1} \cdot A_{ext} + a_{se2} \cdot A_{int}) / A_{sec} = 0.53375773$

$a_{se1} = \text{Max}(((A_{conf,max1} - A_{noConf1}) / A_{conf,max1}) \cdot (A_{conf,min1} / A_{conf,max1}), 0) = 0.53375773$

The definitions of A_{noConf} , $A_{conf,min}$ and $A_{conf,max}$ are derived from generalization of the rectangular sections confinement, which is expressed by (5.4d).

The generalization is done according to Mander, J., Priestley, M., and Park, R. (1988)

"Theoretical Stress-Strain Model for Confined Concrete."

J. Struct. Eng., 10.1061/(ASCE)0733-9445(1988)114:8(1804), 1804-1826.

$A_{conf,max1} = 464100.00$ is the confined core area at levels of member with hoops and

is calculated as the area of core enclosed by the center lines of the external perimeter hoops.

$A_{conf,min1} = 395025.00$ is the confined core area at midway between the levels of hoops and

is calculated by reducing all the dimensions of the area $A_{conf,max1}$ by a length equal to half the clear spacing between external hoops.

$A_{noConf1} = 173066.667$ is the unconfined external core area which is equal to $b_i^2/6$ as defined at (A.2).

$a_{se2} (>= a_{se1}) = \text{Max}(((A_{conf,max2} - A_{noConf2}) / A_{conf,max2}) \cdot (A_{conf,min2} / A_{conf,max2}), 0) = 0.53375773$

The definitions of A_{noConf} , $A_{conf,min}$ and $A_{conf,max}$ are derived from generalization of the rectangular sections confinement, which is expressed by (5.4d).

The generalization is done according to Mander, J., Priestley, M., and Park, R. (1988)

"Theoretical Stress-Strain Model for Confined Concrete."

J. Struct. Eng., 10.1061/(ASCE)0733-9445(1988)114:8(1804), 1804-1826.

$A_{conf,max2} = 252164.00$ is the confined core area at levels of member with hoops and

is calculated as the area of core enclosed by the center lines of the internal perimeter hoops.

$A_{conf,min2} = 111441.00$ is the confined core area at midway between the levels of hoops and

is calculated by reducing all the dimensions of the area $A_{conf,max2}$ by a length equal to half the clear spacing between internal hoops.

$A_{noConf2} = 110709.333$ is the unconfined internal core area which is equal to $b_i^2/6$ as defined at (A.2).

$p_{sh,min} \cdot F_{ywe} = \text{Min}(p_{sh,x} \cdot F_{ywe}, p_{sh,y} \cdot F_{ywe}) = 2.724$

Expression (5.4d) for $p_{sh,min} \cdot F_{ywe}$ has been multiplied by 0.3 according to 15.7.1.3 for members without earthquake detailing (90° closed stirrups)

$p_{sh,x} \cdot F_{ywe} = p_{sh1} \cdot F_{ywe1} + p_{sh2} \cdot F_{ywe2} = 2.724$

p_{sh1} ((5.4d), TBDY) = $L_{stir1} \cdot A_{stir1} / (A_{sec} \cdot s_1) = 0.00301593$

L_{stir1} (Length of stirrups along Y) = 2160.00

A_{stir1} (stirrups area) = 78.53982

p_{sh2} (5.4d) = $L_{stir2} \cdot A_{stir2} / (A_{sec} \cdot s_2) = 0.00056047$

L_{stir2} (Length of stirrups along Y) = 1568.00

A_{stir2} (stirrups area) = 50.26548

$p_{sh,y} \cdot F_{ywe} = p_{sh1} \cdot F_{ywe1} + p_{sh2} \cdot F_{ywe2} = 3.25416$

p_{sh1} ((5.4d), TBDY) = $L_{stir1} \cdot A_{stir1} / (A_{sec} \cdot s_1) = 0.00357443$

L_{stir1} (Length of stirrups along X) = 2560.00

A_{stir1} (stirrups area) = 78.53982

p_{sh2} ((5.4d), TBDY) = $L_{stir2} \cdot A_{stir2} / (A_{sec} \cdot s_2) = 0.00070345$

L_{stir2} (Length of stirrups along X) = 1968.00

A_{stir2} (stirrups area) = 50.26548

$A_{sec} = 562500.00$

$s_1 = 100.00$

$s_2 = 250.00$

$f_{ywe1} = 781.25$

$f_{ywe2} = 656.25$

$f_{ce} = 30.00$

From ((5.A5), TBDY), TBDY: $c_c = 0.002$

c = confinement factor = 1.00

$y_1 = 0.0025$

$sh_1 = 0.008$

$ft_1 = 900.1904$

$fy_1 = 750.1586$

$su_1 = 0.032$

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor

and also multiplied by the shear_factor according to 15.7.1.4, with

Shear_factor = 1.00

$l_o/l_{ou,min} = l_b/l_d = 1.00$

$su_1 = 0.4 \cdot esu_{1,nominal}$ ((5.5), TBDY) = 0.032

From table 5A.1, TBDY: $esu_{1,nominal} = 0.08$,

For calculation of $esu_{1,nominal}$ and y_1, sh_1, ft_1, fy_1 , it is considered

characteristic value $f_{sy1} = f_{s1}/1.2$, from table 5.1, TBDY.
 $y1, sh1, ft1, fy1$, are also multiplied by $\text{Min}(1, 1.25 \cdot (l_b/l_d)^{2/3})$, from 10.3.5, ASCE 41-17.
with $f_{s1} = (f_{sjacket} \cdot A_{s,ten,jacket} + f_{s,core} \cdot A_{s,ten,core})/A_{s,ten} = 750.1586$
with $E_{s1} = (E_{sjacket} \cdot A_{s,ten,jacket} + E_{s,core} \cdot A_{s,ten,core})/A_{s,ten} = 200000.00$
 $y2 = 0.0025$
 $sh2 = 0.008$
 $ft2 = 907.50$
 $fy2 = 756.25$
 $su2 = 0.032$
using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00
 $l_o/l_{ou,min} = l_b/l_{b,min} = 1.00$
 $su2 = 0.4 \cdot esu2_nominal \text{ ((5.5), TBDY)} = 0.032$
From table 5A.1, TBDY: $esu2_nominal = 0.08$,
For calculation of $esu2_nominal$ and $y2, sh2, ft2, fy2$, it is considered
characteristic value $f_{sy2} = f_{s2}/1.2$, from table 5.1, TBDY.
 $y1, sh1, ft1, fy1$, are also multiplied by $\text{Min}(1, 1.25 \cdot (l_b/l_d)^{2/3})$, from 10.3.5, ASCE 41-17.
with $f_{s2} = (f_{sjacket} \cdot A_{s,com,jacket} + f_{s,core} \cdot A_{s,com,core})/A_{s,com} = 756.25$
with $E_{s2} = (E_{sjacket} \cdot A_{s,com,jacket} + E_{s,core} \cdot A_{s,com,core})/A_{s,com} = 200000.00$
 $yv = 0.0025$
 $shv = 0.008$
 $ftv = 902.993$
 $fyv = 752.4941$
 $suv = 0.032$
using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00
 $l_o/l_{ou,min} = l_b/l_d = 1.00$
 $suv = 0.4 \cdot esuv_nominal \text{ ((5.5), TBDY)} = 0.032$
From table 5A.1, TBDY: $esuv_nominal = 0.08$,
considering characteristic value $f_{syv} = f_{sv}/1.2$, from table 5.1, TBDY
For calculation of $esuv_nominal$ and yv, shv, ftv, fyv , it is considered
characteristic value $f_{syv} = f_{sv}/1.2$, from table 5.1, TBDY.
 $y1, sh1, ft1, fy1$, are also multiplied by $\text{Min}(1, 1.25 \cdot (l_b/l_d)^{2/3})$, from 10.3.5, ASCE 41-17.
with $f_{sv} = (f_{sjacket} \cdot A_{s,mid,jacket} + f_{s,mid} \cdot A_{s,mid,core})/A_{s,mid} = 752.4941$
with $E_{sv} = (E_{sjacket} \cdot A_{s,mid,jacket} + E_{s,mid} \cdot A_{s,mid,core})/A_{s,mid} = 200000.00$
 $1 = A_{s,ten}/(b \cdot d) \cdot (f_{s1}/f_c) = 0.19457006$
 $2 = A_{s,com}/(b \cdot d) \cdot (f_{s2}/f_c) = 0.12197144$
 $v = A_{s,mid}/(b \cdot d) \cdot (f_{sv}/f_c) = 0.21102767$

and confined core properties:

$b = 390.00$
 $d = 677.00$
 $d' = 13.00$
 $f_{cc} \text{ (5A.2, TBDY)} = 30.00$
 $cc \text{ (5A.5, TBDY)} = 0.002$
 $c = \text{confinement factor} = 1.00$
 $1 = A_{s,ten}/(b \cdot d) \cdot (f_{s1}/f_c) = 0.23445239$
 $2 = A_{s,com}/(b \cdot d) \cdot (f_{s2}/f_c) = 0.14697275$
 $v = A_{s,mid}/(b \cdot d) \cdot (f_{sv}/f_c) = 0.25428343$

Case/Assumption: Unconfined full section - Steel rupture

' satisfies Eq. (4.3)

---->

$v < v_{s,y2}$ - LHS eq.(4.5) is not satisfied

---->

$v < v_{s,c}$ - RHS eq.(4.5) is satisfied

---->

$su \text{ (4.8)} = 0.33719414$

$Mu = MRc \text{ (4.15)} = 2.1636E+009$

$u = su \text{ (4.1)} = 6.8287974E-005$

Calculation of ratio l_b/l_d

Adequate Lap Length: $l_b/l_d \geq 1$

Calculation of Mu2+

Calculation of ultimate curvature μ according to 4.1, Biskinis/Fardis 2013:

$$\mu = 5.3321191E-005$$

$$Mu = 2.0419E+009$$

with full section properties:

$$b = 950.00$$

$$d = 707.00$$

$$d' = 43.00$$

$$v = 0.00103189$$

$$N = 20792.05$$

$$f_c = 30.00$$

$$co(5A.5, TBDY) = 0.002$$

$$\text{Final value of } \mu: \mu^* = \text{shear_factor} * \text{Max}(\mu, \mu_c) = 0.00832321$$

The Shear_factor is considered equal to 1 (pure moment strength)

$$\text{From (5.4b), TBDY: } \mu_c = 0.00832321$$

$$\mu_{we}(5.4c) = 0.01453958$$

$$\mu_{ase}((5.4d), TBDY) = (\mu_{ase1} * A_{ext} + \mu_{ase2} * A_{int}) / A_{sec} = 0.53375773$$

$$\mu_{ase1} = \text{Max}(((A_{conf,max1} - A_{noConf1}) / A_{conf,max1}) * (A_{conf,min1} / A_{conf,max1}), 0) = 0.53375773$$

The definitions of A_{noConf} , $A_{conf,min}$ and $A_{conf,max}$ are derived from generalization of the rectangular sections confinement, which is expressed by (5.4d).

The generalization is done according to Mander, J., Priestley, M., and Park, R. (1988)

"Theoretical Stress-Strain Model for Confined Concrete."

J. Struct. Eng., 10.1061/(ASCE)0733-9445(1988)114:8(1804), 1804-1826.

$A_{conf,max1} = 464100.00$ is the confined core area at levels of member with hoops and is calculated as the area of core enclosed by the center lines of the external perimeter hoops.

$A_{conf,min1} = 395025.00$ is the confined core area at midway between the levels of hoops and is calculated by reducing all the dimensions of the area $A_{conf,max1}$ by a length equal to half the clear spacing between external hoops.

$A_{noConf1} = 173066.667$ is the unconfined external core area which is equal to $b_i^2/6$ as defined at (A.2).

$$\mu_{ase2}(>= \mu_{ase1}) = \text{Max}(((A_{conf,max2} - A_{noConf2}) / A_{conf,max2}) * (A_{conf,min2} / A_{conf,max2}), 0) = 0.53375773$$

The definitions of A_{noConf} , $A_{conf,min}$ and $A_{conf,max}$ are derived from generalization of the rectangular sections confinement, which is expressed by (5.4d).

The generalization is done according to Mander, J., Priestley, M., and Park, R. (1988)

"Theoretical Stress-Strain Model for Confined Concrete."

J. Struct. Eng., 10.1061/(ASCE)0733-9445(1988)114:8(1804), 1804-1826.

$A_{conf,max2} = 252164.00$ is the confined core area at levels of member with hoops and is calculated as the area of core enclosed by the center lines of the internal perimeter hoops.

$A_{conf,min2} = 111441.00$ is the confined core area at midway between the levels of hoops and is calculated by reducing all the dimensions of the area $A_{conf,max2}$ by a length equal to half the clear spacing between internal hoops.

$A_{noConf2} = 110709.333$ is the unconfined internal core area which is equal to $b_i^2/6$ as defined at (A.2).

$$\mu_{psh,min} * F_{ywe} = \text{Min}(\mu_{psh,x} * F_{ywe}, \mu_{psh,y} * F_{ywe}) = 2.724$$

Expression (5.4d) for $\mu_{psh,min} * F_{ywe}$ has been multiplied by 0.3 according to 15.7.1.3 for members without earthquake detailing (90° closed stirrups)

$$\mu_{psh,x} * F_{ywe} = \mu_{psh1} * F_{ywe1} + \mu_{psh2} * F_{ywe2} = 2.724$$

$$\mu_{psh1}((5.4d), TBDY) = L_{stir1} * A_{stir1} / (A_{sec} * s_1) = 0.00301593$$

$$L_{stir1} \text{ (Length of stirrups along Y)} = 2160.00$$

$$A_{stir1} \text{ (stirrups area)} = 78.53982$$

$$\mu_{psh2}((5.4d)) = L_{stir2} * A_{stir2} / (A_{sec} * s_2) = 0.00056047$$

$$L_{stir2} \text{ (Length of stirrups along Y)} = 1568.00$$

$$A_{stir2} \text{ (stirrups area)} = 50.26548$$

$$\mu_{psh,y} * F_{ywe} = \mu_{psh1} * F_{ywe1} + \mu_{psh2} * F_{ywe2} = 3.25416$$

$$\mu_{psh1}((5.4d), TBDY) = L_{stir1} * A_{stir1} / (A_{sec} * s_1) = 0.00357443$$

$$L_{stir1} \text{ (Length of stirrups along X)} = 2560.00$$

$$A_{stir1} \text{ (stirrups area)} = 78.53982$$

$$\mu_{psh2}((5.4d), TBDY) = L_{stir2} * A_{stir2} / (A_{sec} * s_2) = 0.00070345$$

$$L_{stir2} \text{ (Length of stirrups along X)} = 1968.00$$

$$A_{stir2} \text{ (stirrups area)} = 50.26548$$

$$A_{sec} = 562500.00$$

```

s1 = 100.00
s2 = 250.00
fywe1 = 781.25
fywe2 = 656.25
fce = 30.00
From ((5A5), TBDY), TBDY: cc = 0.002
c = confinement factor = 1.00
y1 = 0.0025
sh1 = 0.008
ft1 = 907.50
fy1 = 756.25
su1 = 0.032
using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00
lo/lou,min = lb/lb = 1.00
su1 = 0.4*esu1_nominal ((5.5), TBDY) = 0.032
From table 5A.1, TBDY: esu1_nominal = 0.08,
For calculation of esu1_nominal and y1, sh1,ft1,fy1, it is considered
characteristic value fsy1 = fs1/1.2, from table 5.1, TBDY.
y1, sh1,ft1,fy1, are also multiplied by Min(1,1.25*(lb/lb)^2/3), from 10.3.5, ASCE 41-17.
with fs1 = (fs,jacket*Asl,ten,jacket + fs,core*Asl,ten,core)/Asl,ten = 756.25
with Es1 = (Es,jacket*Asl,ten,jacket + Es,core*Asl,ten,core)/Asl,ten = 200000.00
y2 = 0.0025
sh2 = 0.008
ft2 = 900.1904
fy2 = 750.1586
su2 = 0.032
using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00
lo/lou,min = lb/lb,min = 1.00
su2 = 0.4*esu2_nominal ((5.5), TBDY) = 0.032
From table 5A.1, TBDY: esu2_nominal = 0.08,
For calculation of esu2_nominal and y2, sh2,ft2,fy2, it is considered
characteristic value fsy2 = fs2/1.2, from table 5.1, TBDY.
y1, sh1,ft1,fy1, are also multiplied by Min(1,1.25*(lb/lb)^2/3), from 10.3.5, ASCE 41-17.
with fs2 = (fs,jacket*Asl,com,jacket + fs,core*Asl,com,core)/Asl,com = 750.1586
with Es2 = (Es,jacket*Asl,com,jacket + Es,core*Asl,com,core)/Asl,com = 200000.00
yv = 0.0025
shv = 0.008
ftv = 902.993
fyv = 752.4941
suv = 0.032
using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00
lo/lou,min = lb/lb = 1.00
suv = 0.4*esuv_nominal ((5.5), TBDY) = 0.032
From table 5A.1, TBDY: esuv_nominal = 0.08,
considering characteristic value fsyv = fsv/1.2, from table 5.1, TBDY
For calculation of esuv_nominal and yv, shv,ftv,fyv, it is considered
characteristic value fsyv = fsv/1.2, from table 5.1, TBDY.
y1, sh1,ft1,fy1, are also multiplied by Min(1,1.25*(lb/lb)^2/3), from 10.3.5, ASCE 41-17.
with fsv = (fs,jacket*Asl,mid,jacket + fs,mid*Asl,mid,core)/Asl,mid = 752.4941
with Esv = (Es,jacket*Asl,mid,jacket + Es,mid*Asl,mid,core)/Asl,mid = 200000.00
1 = Asl,ten/(b*d)*(fs1/fc) = 0.05777595
2 = Asl,com/(b*d)*(fs2/fc) = 0.09216477
v = Asl,mid/(b*d)*(fsv/fc) = 0.09996047
and confined core properties:
b = 890.00
d = 677.00
d' = 13.00
fcc (5A.2, TBDY) = 30.00
cc (5A.5, TBDY) = 0.002
c = confinement factor = 1.00
1 = Asl,ten/(b*d)*(fs1/fc) = 0.06440379

```

$$2 = A_{sl,com}/(b*d)*(f_{s2}/f_c) = 0.10273757$$

$$v = A_{sl,mid}/(b*d)*(f_{sv}/f_c) = 0.11142757$$

Case/Assumption: Unconfined full section - Steel rupture

' satisfies Eq. (4.3)

---->

$v < v_{s,y2}$ - LHS eq.(4.5) is not satisfied

---->

$v < v_{s,c}$ - RHS eq.(4.5) is satisfied

---->

$$s_u(4.8) = 0.15115045$$

$$\mu_u = M_{Rc}(4.15) = 2.0419E+009$$

$$u = s_u(4.1) = 5.3321191E-005$$

Calculation of ratio l_b/d

Adequate Lap Length: $l_b/d \geq 1$

Calculation of μ_{u2} -

Calculation of ultimate curvature μ_u according to 4.1, Biskinis/Fardis 2013:

$$u = 6.8287974E-005$$

$$\mu_u = 2.1636E+009$$

with full section properties:

$$b = 450.00$$

$$d = 707.00$$

$$d' = 43.00$$

$$v = 0.00217843$$

$$N = 20792.05$$

$$f_c = 30.00$$

$$\alpha_{co}(5A.5, TBDY) = 0.002$$

$$\text{Final value of } \alpha_{cu}: \alpha_{cu} = \text{shear_factor} * \text{Max}(\alpha_{cu}, \alpha_{cc}) = 0.00832321$$

The Shear_factor is considered equal to 1 (pure moment strength)

$$\text{From (5.4b), TBDY: } \alpha_{cu} = 0.00832321$$

$$\alpha_{we}(5.4c) = 0.01453958$$

$$\alpha_{ase}((5.4d), TBDY) = (\alpha_{ase1} * A_{ext} + \alpha_{ase2} * A_{int}) / A_{sec} = 0.53375773$$

$$\alpha_{ase1} = \text{Max}(((A_{conf,max1} - A_{noConf1}) / A_{conf,max1}) * (A_{conf,min1} / A_{conf,max1}), 0) = 0.53375773$$

The definitions of A_{noConf} , $A_{conf,min}$ and $A_{conf,max}$ are derived from generalization of the rectangular sections confinement, which is expressed by (5.4d).

The generalization is done according to Mander, J., Priestley, M., and Park, R. (1988)

"Theoretical Stress-Strain Model for Confined Concrete."

J. Struct. Eng., 10.1061/(ASCE)0733-9445(1988)114:8(1804), 1804-1826.

$A_{conf,max1} = 464100.00$ is the confined core area at levels of member with hoops and

is calculated as the area of core enclosed by the center lines of the external perimeter hoops.

$A_{conf,min1} = 395025.00$ is the confined core area at midway between the levels of hoops and

is calculated by reducing all the dimensions of the area $A_{conf,max1}$ by a length equal to half the clear spacing between external hoops.

$A_{noConf1} = 173066.667$ is the unconfined external core area which is equal to $b_i^2/6$ as defined at (A.2).

$$\alpha_{ase2}(\geq \alpha_{ase1}) = \text{Max}(((A_{conf,max2} - A_{noConf2}) / A_{conf,max2}) * (A_{conf,min2} / A_{conf,max2}), 0) = 0.53375773$$

The definitions of A_{noConf} , $A_{conf,min}$ and $A_{conf,max}$ are derived from generalization of the rectangular sections confinement, which is expressed by (5.4d).

The generalization is done according to Mander, J., Priestley, M., and Park, R. (1988)

"Theoretical Stress-Strain Model for Confined Concrete."

J. Struct. Eng., 10.1061/(ASCE)0733-9445(1988)114:8(1804), 1804-1826.

$A_{conf,max2} = 252164.00$ is the confined core area at levels of member with hoops and

is calculated as the area of core enclosed by the center lines of the internal perimeter hoops.

$A_{conf,min2} = 111441.00$ is the confined core area at midway between the levels of hoops and

is calculated by reducing all the dimensions of the area $A_{conf,max2}$ by a length equal to half the clear spacing between internal hoops.

$A_{noConf2} = 110709.333$ is the unconfined internal core area which is equal to $b_i^2/6$ as defined at (A.2).

$$p_{sh,min} * F_{ywe} = \text{Min}(p_{sh,x} * F_{ywe}, p_{sh,y} * F_{ywe}) = 2.724$$

Expression (5.4d) for $p_{sh,min} * F_{ywe}$ has been multiplied by 0.3 according to 15.7.1.3 for members without

earthquake detailing (90° closed stirrups)

psh_x*Fywe = psh1*Fywe1+ps2*Fywe2 = 2.724
psh1 ((5.4d), TBDY) = Lstir1*Astir1/(Asec*s1) = 0.00301593
Lstir1 (Length of stirrups along Y) = 2160.00
Astir1 (stirrups area) = 78.53982
psh2 (5.4d) = Lstir2*Astir2/(Asec*s2) = 0.00056047
Lstir2 (Length of stirrups along Y) = 1568.00
Astir2 (stirrups area) = 50.26548

psh_y*Fywe = psh1*Fywe1+ps2*Fywe2 = 3.25416
psh1 ((5.4d), TBDY) = Lstir1*Astir1/(Asec*s1) = 0.00357443
Lstir1 (Length of stirrups along X) = 2560.00
Astir1 (stirrups area) = 78.53982
psh2 ((5.4d), TBDY) = Lstir2*Astir2/(Asec*s2) = 0.00070345
Lstir2 (Length of stirrups along X) = 1968.00
Astir2 (stirrups area) = 50.26548

Asec = 562500.00

s1 = 100.00

s2 = 250.00

fywe1 = 781.25

fywe2 = 656.25

fce = 30.00

From ((5.A5), TBDY), TBDY: cc = 0.002

c = confinement factor = 1.00

y1 = 0.0025

sh1 = 0.008

ft1 = 900.1904

fy1 = 750.1586

su1 = 0.032

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00

lo/lou,min = lb/ld = 1.00

su1 = 0.4*esu1_nominal ((5.5), TBDY) = 0.032

From table 5A.1, TBDY: esu1_nominal = 0.08,

For calculation of esu1_nominal and y1, sh1,ft1,fy1, it is considered
characteristic value fsy1 = fs1/1.2, from table 5.1, TBDY.

y1, sh1,ft1,fy1, are also multiplied by $\text{Min}(1, 1.25 \cdot (lb/ld)^{2/3})$, from 10.3.5, ASCE 41-17.

with fs1 = (fs,jacket*Asl,ten,jacket + fs,core*Asl,ten,core)/Asl,ten = 750.1586

with Es1 = (Es,jacket*Asl,ten,jacket + Es,core*Asl,ten,core)/Asl,ten = 200000.00

y2 = 0.0025

sh2 = 0.008

ft2 = 907.50

fy2 = 756.25

su2 = 0.032

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00

lo/lou,min = lb/lb,min = 1.00

su2 = 0.4*esu2_nominal ((5.5), TBDY) = 0.032

From table 5A.1, TBDY: esu2_nominal = 0.08,

For calculation of esu2_nominal and y2, sh2,ft2,fy2, it is considered
characteristic value fsy2 = fs2/1.2, from table 5.1, TBDY.

y1, sh1,ft1,fy1, are also multiplied by $\text{Min}(1, 1.25 \cdot (lb/ld)^{2/3})$, from 10.3.5, ASCE 41-17.

with fs2 = (fs,jacket*Asl,com,jacket + fs,core*Asl,com,core)/Asl,com = 756.25

with Es2 = (Es,jacket*Asl,com,jacket + Es,core*Asl,com,core)/Asl,com = 200000.00

yv = 0.0025

shv = 0.008

ftv = 902.993

fyv = 752.4941

suv = 0.032

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00

lo/lou,min = lb/ld = 1.00

$suv = 0.4 * esuv_nominal ((5.5), TBDY) = 0.032$
 From table 5A.1, TBDY: $esuv_nominal = 0.08$,
 considering characteristic value $fsyv = fsv/1.2$, from table 5.1, TBDY
 For calculation of $esuv_nominal$ and yv , shv , ftv , fyv , it is considered
 characteristic value $fsyv = fsv/1.2$, from table 5.1, TBDY.
 $y1$, $sh1$, $ft1$, $fy1$, are also multiplied by $Min(1, 1.25 * (lb/ld)^{2/3})$, from 10.3.5, ASCE 41-17.
 with $fsv = (fs_jacket * Asl_mid_jacket + fs_mid * Asl_mid_core) / Asl_mid = 752.4941$
 with $Esv = (Es_jacket * Asl_mid_jacket + Es_mid * Asl_mid_core) / Asl_mid = 200000.00$
 $1 = Asl_ten / (b * d) * (fs1 / fc) = 0.19457006$
 $2 = Asl_com / (b * d) * (fs2 / fc) = 0.12197144$
 $v = Asl_mid / (b * d) * (fsv / fc) = 0.21102767$

and confined core properties:

$b = 390.00$
 $d = 677.00$
 $d' = 13.00$
 $fcc (5A.2, TBDY) = 30.00$
 $cc (5A.5, TBDY) = 0.002$
 $c = \text{confinement factor} = 1.00$
 $1 = Asl_ten / (b * d) * (fs1 / fc) = 0.23445239$
 $2 = Asl_com / (b * d) * (fs2 / fc) = 0.14697275$
 $v = Asl_mid / (b * d) * (fsv / fc) = 0.25428343$

Case/Assumption: Unconfined full section - Steel rupture
 ' satisfies Eq. (4.3)

--->
 $v < vs_y2$ - LHS eq.(4.5) is not satisfied
 --->

$v < vs_c$ - RHS eq.(4.5) is satisfied
 --->

$su (4.8) = 0.33719414$
 $Mu = MRc (4.15) = 2.1636E+009$
 $u = su (4.1) = 6.8287974E-005$

Calculation of ratio lb/ld

Adequate Lap Length: $lb/ld \geq 1$

Calculation of Shear Strength $Vr = Min(Vr1, Vr2) = 1.2916E+006$

Calculation of Shear Strength at edge 1, $Vr1 = 1.2916E+006$

$Vr1 = VCol ((10.3), ASCE 41-17) = knl * VColO$

$VColO = 1.2916E+006$

$knl = 1$ (zero step-static loading)

NOTE: In expression (10-3) ' $Vs = Av * fy * d / s$ ' is replaced by ' $Vs + f * Vf$ '
 where Vf is the contribution of FRPs (11.3), ACI 440).

$= 1$ (normal-weight concrete)
 Mean concrete strength: $fc' = (fc'_jacket * Area_jacket + fc'_core * Area_core) / Area_section = 27.20$, but $fc'^{0.5} \leq 8.3$
 MPa (22.5.3.1, ACI 318-14)

$M/Vd = 2.00$

$Mu = 5174.584$

$Vu = 8.5087964E-020$

$d = 0.8 * h = 600.00$

$Nu = 20792.05$

$Ag = 337500.00$

From (11.5.4.8), ACI 318-14: $Vs = Vs_jacket + Vs_core = 1.0354E+006$

where:

$Vs_jacket = Vs_j1 + Vs_j2 = 942477.796$

$Vs_j1 = 589048.623$ is calculated for section web jacket, with:

$d = 600.00$

$Av = 157079.633$

$fy = 625.00$

$s = 100.00$

$V_{s,j1}$ is multiplied by $Col,j1 = 1.00$
 $s/d = 0.16666667$
 $V_{s,j2} = 353429.174$ is calculated for section flange jacket, with:
 $d = 360.00$
 $A_v = 157079.633$
 $f_y = 625.00$
 $s = 100.00$
 $V_{s,j2}$ is multiplied by $Col,j2 = 1.00$
 $s/d = 0.27777778$
 $V_{s,core} = V_{s,c1} + V_{s,c2} = 92890.612$
 $V_{s,c1} = 92890.612$ is calculated for section web core, with:
 $d = 440.00$
 $A_v = 100530.965$
 $f_y = 525.00$
 $s = 250.00$
 $V_{s,c1}$ is multiplied by $Col,c1 = 1.00$
 $s/d = 0.56818182$
 $V_{s,c2} = 0.00$ is calculated for section flange core, with:
 $d = 200.00$
 $A_v = 100530.965$
 $f_y = 525.00$
 $s = 250.00$
 $V_{s,c2}$ is multiplied by $Col,c2 = 0.00$
 $s/d = 1.25$
 $V_f ((11-3)-(11.4), ACI 440) = 0.00$
 From (11-11), ACI 440: $V_s + V_f \leq 935437.922$
 $bw = 450.00$

Calculation of Shear Strength at edge 2, $V_{r2} = 1.2916E+006$
 $V_{r2} = V_{Col} ((10.3), ASCE 41-17) = knl * V_{Col0}$
 $V_{Col0} = 1.2916E+006$
 $knl = 1$ (zero step-static loading)

NOTE: In expression (10-3) ' $V_s = A_v * f_y * d / s$ ' is replaced by ' $V_s + f * V_f$ '
 where V_f is the contribution of FRPs (11.3), ACI 440).

$= 1$ (normal-weight concrete)
 Mean concrete strength: $f'_c = (f'_{c,jacket} * Area_{jacket} + f'_{c,core} * Area_{core}) / Area_{section} = 27.20$, but $f'_c^{0.5} \leq 8.3$
 MPa (22.5.3.1, ACI 318-14)
 $M/Vd = 2.00$
 $M_u = 5174.584$
 $V_u = 8.5087964E-020$
 $d = 0.8 * h = 600.00$
 $N_u = 20792.05$
 $A_g = 337500.00$
 From (11.5.4.8), ACI 318-14: $V_s = V_{s,jacket} + V_{s,core} = 1.0354E+006$
 where:
 $V_{s,jacket} = V_{s,j1} + V_{s,j2} = 942477.796$
 $V_{s,j1} = 589048.623$ is calculated for section web jacket, with:
 $d = 600.00$
 $A_v = 157079.633$
 $f_y = 625.00$
 $s = 100.00$
 $V_{s,j1}$ is multiplied by $Col,j1 = 1.00$
 $s/d = 0.16666667$
 $V_{s,j2} = 353429.174$ is calculated for section flange jacket, with:
 $d = 360.00$
 $A_v = 157079.633$
 $f_y = 625.00$
 $s = 100.00$
 $V_{s,j2}$ is multiplied by $Col,j2 = 1.00$
 $s/d = 0.27777778$
 $V_{s,core} = V_{s,c1} + V_{s,c2} = 92890.612$
 $V_{s,c1} = 92890.612$ is calculated for section web core, with:
 $d = 440.00$
 $A_v = 100530.965$

```

fy = 525.00
s = 250.00
Vs,c1 is multiplied by Col,c1 = 1.00
s/d = 0.56818182
Vs,c2 = 0.00 is calculated for section flange core, with:
d = 200.00
Av = 100530.965
fy = 525.00
s = 250.00
Vs,c2 is multiplied by Col,c2 = 0.00
s/d = 1.25
Vf ((11-3)-(11.4), ACI 440) = 0.00
From (11-11), ACI 440: Vs + Vf <= 935437.922
bw = 450.00
-----
End Of Calculation of Shear Capacity ratio for element: column JTC1 of floor 1
At local axis: 3
-----

Start Of Calculation of Shear Capacity ratio for element: column JTC1 of floor 1
At Shear local axis: 2
(Bending local axis: 3)
Section Type: rcjctcs

Constant Properties
-----
Knowledge Factor,   = 0.80
Mean strength values are used for both shear and moment calculations.
Consequently:
Jacket
New material of Secondary Member: Concrete Strength, fc = fcm = 30.00
New material of Secondary Member: Steel Strength, fs = fsm = 625.00
Concrete Elasticity, Ec = 25742.96
Steel Elasticity, Es = 200000.00
Existing Column
Existing material of Secondary Member: Concrete Strength, fc = fcm = 24.00
Existing material of Secondary Member: Steel Strength, fs = fsm = 525.00
Concrete Elasticity, Ec = 23025.204
Steel Elasticity, Es = 200000.00
#####
Note: Especially for the calculation of moment strengths,
the above steel re-bar strengths are multiplied by 1.25 according to R18.6.5, ACI 318-14
Jacket
New material: Steel Strength, fs = 1.25*fsm = 781.25
Existing Column
Existing material: Steel Strength, fs = 1.25*fsm = 656.25
#####
Max Height, Hmax = 750.00
Min Height, Hmin = 450.00
Max Width, Wmax = 950.00
Min Width, Wmin = 450.00
Eccentricity, Ecc = 250.00
Jacket Thickness, tj = 100.00
Cover Thickness, c = 25.00
Mean Confinement Factor overall section = 1.00
Element Length, L = 3000.00
Secondary Member
Smooth Bars
Ductile Steel
Without Detailing for Earthquake Resistance (including stirrups not closed at 135°)
Longitudinal Bars With Ends Lapped Starting at the End Sections
Adequate Lap Length (lo/lo,min>=1)
No FRP Wrapping
-----

```

Stepwise Properties

At local axis: 2

EDGE -A-

Shear Force, $V_a = 5.2099631E-036$

EDGE -B-

Shear Force, $V_b = -5.2099631E-036$

BOTH EDGES

Axial Force, $F = -20792.05$

Longitudinal Reinforcement Area Distribution (in 2 divisions)

-Tension: $A_{st} = 0.00$

-Compression: $A_{sc} = 6691.592$

Longitudinal Reinforcement Area Distribution (in 3 divisions)

-Tension: $A_{st,ten} = 1539.38$

-Compression: $A_{sc,com} = 1539.38$

-Middle: $A_{sl,mid} = 3612.832$

Calculation of Shear Capacity ratio, $V_e/V_r = 1.08994$

Member Controlled by Shear ($V_e/V_r > 1$)

Calculation of Shear Demand from fig. R18.6.5, ACI 318-14 $V_e = (M_{pr1} + M_{pr2})/l_n = 1.7820E+006$ with

$M_{pr1} = \text{Max}(\mu_{1+}, \mu_{1-}) = 2.6730E+009$

$\mu_{1+} = 2.6730E+009$, is the ultimate moment strength at the edge 1 of the member in the actual moment direction which is defined for the static loading combination

$\mu_{1-} = 2.6730E+009$, is the ultimate moment strength at the edge 1 of the member in the opposite moment direction which is defined for the static loading combination

$M_{pr2} = \text{Max}(\mu_{2+}, \mu_{2-}) = 2.6730E+009$

$\mu_{2+} = 2.6730E+009$, is the ultimate moment strength at the edge 2 of the member in the actual moment direction which is defined for the static loading combination

$\mu_{2-} = 2.6730E+009$, is the ultimate moment strength at the edge 2 of the member in the opposite moment direction which is defined for the static loading combination

Calculation of μ_{1+}

Calculation of ultimate curvature ϕ_u according to 4.1, Biskinis/Fardis 2013:

$\phi_u = 4.9274896E-005$

$M_u = 2.6730E+009$

with full section properties:

$b = 450.00$

$d = 907.00$

$d' = 43.00$

$v = 0.00169807$

$N = 20792.05$

$f_c = 30.00$

ϕ_c (5A.5, TBDY) = 0.002

Final value of ϕ_u : $\phi_u^* = \text{shear_factor} * \text{Max}(\phi_{cu}, \phi_{cc}) = 0.00832321$

The Shear_factor is considered equal to 1 (pure moment strength)

From (5.4b), TBDY: $\phi_{cu} = 0.00832321$

we (5.4c) = 0.01453958

ϕ_{ase} ((5.4d), TBDY) = $(\phi_{ase1} * A_{ext} + \phi_{ase2} * A_{int}) / A_{sec} = 0.53375773$

$\phi_{ase1} = \text{Max}(((A_{conf,max1} - A_{noConf1}) / A_{conf,max1}) * (A_{conf,min1} / A_{conf,max1}), 0) = 0.53375773$

The definitions of A_{noConf} , $A_{conf,min}$ and $A_{conf,max}$ are derived from generalization of the rectangular sections confinement, which is expressed by (5.4d).

The generalization is done according to Mander, J., Priestley, M., and Park, R. (1988)

"Theoretical Stress-Strain Model for Confined Concrete."

J. Struct. Eng., 10.1061/(ASCE)0733-9445(1988)114:8(1804), 1804-1826.

$A_{conf,max1} = 464100.00$ is the confined core area at levels of member with hoops and

is calculated as the area of core enclosed by the center lines of the external perimeter hoops.

$A_{conf,min1} = 395025.00$ is the confined core area at midway between the levels of hoops and

is calculated by reducing all the dimensions of the area Aconf,max1 by a length equal to half the clear spacing between external hoops.

AnoConf1 = 173066.667 is the unconfined external core area which is equal to $b_i^2/6$ as defined at (A.2).
ase2 (\geq ase1) = $\text{Max}(((A_{\text{conf,max2}} - A_{\text{noConf2}})/A_{\text{conf,max2}}) * (A_{\text{conf,min2}}/A_{\text{conf,max2}}), 0) = 0.53375773$

The definitions of AnoConf, Aconf,min and Aconf,max are derived from generalization of the rectangular sections confinement, which is expressed by (5.4d).

The generalization is done according to Mander, J., Priestley, M., and Park, R. (1988) "Theoretical Stress-Strain Model for Confined Concrete."

J. Struct. Eng., 10.1061/(ASCE)0733-9445(1988)114:8(1804), 1804-1826.

Aconf,max2 = 252164.00 is the confined core area at levels of member with hoops and is calculated as the area of core enclosed by the center lines of the internal perimeter hoops.

Aconf,min2 = 111441.00 is the confined core area at midway between the levels of hoops and is calculated by reducing all the dimensions of the area Aconf,max2 by a length equal to half the clear spacing between internal hoops.

AnoConf2 = 110709.333 is the unconfined internal core area which is equal to $b_i^2/6$ as defined at (A.2).
psh,min*Fywe = $\text{Min}(psh_x * Fywe, psh_y * Fywe) = 2.724$

Expression (5.4d) for psh,min*Fywe has been multiplied by 0.3 according to 15.7.1.3 for members without earthquake detailing (90° closed stirrups)

psh_x*Fywe = psh1*Fywe1 + ps2*Fywe2 = 2.724
psh1 ((5.4d), TBDY) = $L_{\text{stir1}} * A_{\text{stir1}} / (A_{\text{sec}} * s_1) = 0.00301593$
Lstir1 (Length of stirrups along Y) = 2160.00
Astir1 (stirrups area) = 78.53982
psh2 ((5.4d)) = $L_{\text{stir2}} * A_{\text{stir2}} / (A_{\text{sec}} * s_2) = 0.00056047$
Lstir2 (Length of stirrups along Y) = 1568.00
Astir2 (stirrups area) = 50.26548

psh_y*Fywe = psh1*Fywe1 + ps2*Fywe2 = 3.25416
psh1 ((5.4d), TBDY) = $L_{\text{stir1}} * A_{\text{stir1}} / (A_{\text{sec}} * s_1) = 0.00357443$
Lstir1 (Length of stirrups along X) = 2560.00
Astir1 (stirrups area) = 78.53982
psh2 ((5.4d), TBDY) = $L_{\text{stir2}} * A_{\text{stir2}} / (A_{\text{sec}} * s_2) = 0.00070345$
Lstir2 (Length of stirrups along X) = 1968.00
Astir2 (stirrups area) = 50.26548

Asec = 562500.00

s1 = 100.00

s2 = 250.00

fywe1 = 781.25

fywe2 = 656.25

fce = 30.00

From ((5.A5), TBDY), TBDY: cc = 0.002

c = confinement factor = 1.00

y1 = 0.0025

sh1 = 0.008

ft1 = 907.50

fy1 = 756.25

su1 = 0.032

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor and also multiplied by the shear_factor according to 15.7.1.4, with Shear_factor = 1.00

lo/lou,min = lb/ld = 1.00

su1 = $0.4 * esu1_{\text{nominal}} ((5.5), \text{TBDY}) = 0.032$

From table 5A.1, TBDY: esu1_nominal = 0.08,

For calculation of esu1_nominal and y1, sh1, ft1, fy1, it is considered characteristic value fsy1 = fs1/1.2, from table 5.1, TBDY.

y1, sh1, ft1, fy1, are also multiplied by $\text{Min}(1, 1.25 * (lb/ld)^{2/3})$, from 10.3.5, ASCE 41-17.

with fs1 = $(f_{s,jacket} * A_{s1,ten,jacket} + f_{s,core} * A_{s1,ten,core}) / A_{s1,ten} = 756.25$

with Es1 = $(E_{s,jacket} * A_{s1,ten,jacket} + E_{s,core} * A_{s1,ten,core}) / A_{s1,ten} = 200000.00$

y2 = 0.0025

sh2 = 0.008

ft2 = 907.50

fy2 = 756.25

su2 = 0.032

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor and also multiplied by the shear_factor according to 15.7.1.4, with Shear_factor = 1.00

```

lo/lou,min = lb/lbmin = 1.00
su2 = 0.4*esu2,nominal ((5.5), TBDY) = 0.032
From table 5A.1, TBDY: esu2,nominal = 0.08,
For calculation of esu2,nominal and y2, sh2,ft2,fy2, it is considered
characteristic value fsy2 = fs2/1.2, from table 5.1, TBDY.
y1, sh1,ft1,fy1, are also multiplied by Min(1,1.25*(lb/ld)2/3), from 10.3.5, ASCE 41-17.
with fs2 = (fsjacket*Aslcom,jacket + fscore*Aslcom,core)/Aslcom = 756.25
with Es2 = (Esjacket*Aslcom,jacket + Escore*Aslcom,core)/Aslcom = 200000.00
yv = 0.0025
shv = 0.008
ftv = 899.1522
fyv = 749.2935
suv = 0.032
using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00
lo/lou,min = lb/ld = 1.00
suv = 0.4*esuvnominal ((5.5), TBDY) = 0.032
From table 5A.1, TBDY: esuvnominal = 0.08,
considering characteristic value fsyv = fsv/1.2, from table 5.1, TBDY
For calculation of esuvnominal and yv, shv,ftv,fyv, it is considered
characteristic value fsyv = fsv/1.2, from table 5.1, TBDY.
y1, sh1,ft1,fy1, are also multiplied by Min(1,1.25*(lb/ld)2/3), from 10.3.5, ASCE 41-17.
with fsv = (fsjacket*Aslmid,jacket + fsmid*Aslmid,core)/Aslmid = 749.2935
with Esv = (Esjacket*Aslmid,jacket + Esmid*Aslmid,core)/Aslmid = 200000.00
1 = Aslten/(b*d)*(fs1/fc) = 0.09507586
2 = Aslcom/(b*d)*(fs2/fc) = 0.09507586
v = Aslmid/(b*d)*(fsv/fc) = 0.22108466
and confined core properties:
b = 390.00
d = 877.00
d' = 13.00
fcc (5A.2, TBDY) = 30.00
cc (5A.5, TBDY) = 0.002
c = confinement factor = 1.00
1 = Aslten/(b*d)*(fs1/fc) = 0.11345559
2 = Aslcom/(b*d)*(fs2/fc) = 0.11345559
v = Aslmid/(b*d)*(fsv/fc) = 0.26382395
Case/Assumption: Unconfined full section - Steel rupture
'satisfies Eq. (4.3)
---->
v < vsy2 - LHS eq.(4.5) is not satisfied
---->
v < vsc - RHS eq.(4.5) is satisfied
---->
su (4.8) = 0.28399348
Mu = MRc (4.15) = 2.6730E+009
u = su (4.1) = 4.9274896E-005

```

Calculation of ratio lb/l_d

Adequate Lap Length: lb/l_d >= 1

Calculation of Mu₁-

Calculation of ultimate curvature u according to 4.1, Biskinis/Fardis 2013:

u = 4.9274896E-005

Mu = 2.6730E+009

with full section properties:

b = 450.00

d = 907.00

$d' = 43.00$
 $v = 0.00169807$
 $N = 20792.05$
 $f_c = 30.00$
 $co(5A.5, TBDY) = 0.002$
 Final value of cu : $cu^* = shear_factor * Max(cu, cc) = 0.00832321$
 The Shear_factor is considered equal to 1 (pure moment strength)
 From (5.4b), TBDY: $cu = 0.00832321$
 $we(5.4c) = 0.01453958$
 $ase((5.4d), TBDY) = (ase1 * A_{ext} + ase2 * A_{int}) / A_{sec} = 0.53375773$
 $ase1 = Max(((A_{conf,max1} - A_{noConf1}) / A_{conf,max1}) * (A_{conf,min1} / A_{conf,max1}), 0) = 0.53375773$
 The definitions of A_{noConf} , $A_{conf,min}$ and $A_{conf,max}$ are derived from generalization of the rectangular sections confinement, which is expressed by (5.4d).
 The generalization is done according to Mander, J., Priestley, M., and Park, R. (1988) "Theoretical Stress-Strain Model for Confined Concrete."
 J. Struct. Eng., 10.1061/(ASCE)0733-9445(1988)114:8(1804), 1804-1826.
 $A_{conf,max1} = 464100.00$ is the confined core area at levels of member with hoops and is calculated as the area of core enclosed by the center lines of the external perimeter hoops.
 $A_{conf,min1} = 395025.00$ is the confined core area at midway between the levels of hoops and is calculated by reducing all the dimensions of the area $A_{conf,max1}$ by a length equal to half the clear spacing between external hoops.
 $A_{noConf1} = 173066.667$ is the unconfined external core area which is equal to $b_i^2/6$ as defined at (A.2).
 $ase2 (>= ase1) = Max(((A_{conf,max2} - A_{noConf2}) / A_{conf,max2}) * (A_{conf,min2} / A_{conf,max2}), 0) = 0.53375773$
 The definitions of A_{noConf} , $A_{conf,min}$ and $A_{conf,max}$ are derived from generalization of the rectangular sections confinement, which is expressed by (5.4d).
 The generalization is done according to Mander, J., Priestley, M., and Park, R. (1988) "Theoretical Stress-Strain Model for Confined Concrete."
 J. Struct. Eng., 10.1061/(ASCE)0733-9445(1988)114:8(1804), 1804-1826.
 $A_{conf,max2} = 252164.00$ is the confined core area at levels of member with hoops and is calculated as the area of core enclosed by the center lines of the internal perimeter hoops.
 $A_{conf,min2} = 111441.00$ is the confined core area at midway between the levels of hoops and is calculated by reducing all the dimensions of the area $A_{conf,max2}$ by a length equal to half the clear spacing between internal hoops.
 $A_{noConf2} = 110709.333$ is the unconfined internal core area which is equal to $b_i^2/6$ as defined at (A.2).
 $psh,min * F_{ywe} = Min(psh,x * F_{ywe}, psh,y * F_{ywe}) = 2.724$
 Expression (5.4d) for $psh,min * F_{ywe}$ has been multiplied by 0.3 according to 15.7.1.3 for members without earthquake detailing (90° closed stirrups)

$psh,x * F_{ywe} = psh1 * F_{ywe1} + ps2 * F_{ywe2} = 2.724$
 $psh1((5.4d), TBDY) = L_{stir1} * A_{stir1} / (A_{sec} * s1) = 0.00301593$
 L_{stir1} (Length of stirrups along Y) = 2160.00
 A_{stir1} (stirrups area) = 78.53982
 $psh2(5.4d) = L_{stir2} * A_{stir2} / (A_{sec} * s2) = 0.00056047$
 L_{stir2} (Length of stirrups along Y) = 1568.00
 A_{stir2} (stirrups area) = 50.26548

$psh,y * F_{ywe} = psh1 * F_{ywe1} + ps2 * F_{ywe2} = 3.25416$
 $psh1((5.4d), TBDY) = L_{stir1} * A_{stir1} / (A_{sec} * s1) = 0.00357443$
 L_{stir1} (Length of stirrups along X) = 2560.00
 A_{stir1} (stirrups area) = 78.53982
 $psh2((5.4d), TBDY) = L_{stir2} * A_{stir2} / (A_{sec} * s2) = 0.00070345$
 L_{stir2} (Length of stirrups along X) = 1968.00
 A_{stir2} (stirrups area) = 50.26548

$A_{sec} = 562500.00$
 $s1 = 100.00$
 $s2 = 250.00$
 $f_{ywe1} = 781.25$
 $f_{ywe2} = 656.25$
 $f_{ce} = 30.00$
 From ((5.A5), TBDY), TBDY: $cc = 0.002$
 c = confinement factor = 1.00
 $y1 = 0.0025$
 $sh1 = 0.008$
 $ft1 = 907.50$
 $fy1 = 756.25$
 $su1 = 0.032$

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
 and also multiplied by the shear_factor according to 15.7.1.4, with
 Shear_factor = 1.00
 $l_o/l_{ou,min} = l_b/l_d = 1.00$
 $su_1 = 0.4 * esu_{1,nominal} ((5.5), TBDY) = 0.032$
 From table 5A.1, TBDY: $esu_{1,nominal} = 0.08$,
 For calculation of $esu_{1,nominal}$ and y_1, sh_1, ft_1, fy_1 , it is considered
 characteristic value $fsy_1 = fs_1/1.2$, from table 5.1, TBDY.
 y_1, sh_1, ft_1, fy_1 , are also multiplied by $Min(1, 1.25 * (l_b/l_d)^{2/3})$, from 10.3.5, ASCE 41-17.
 with $fs_1 = (fs_{jacket} * A_{sl,ten,jacket} + fs_{core} * A_{sl,ten,core}) / A_{sl,ten} = 756.25$
 with $Es_1 = (Es_{jacket} * A_{sl,ten,jacket} + Es_{core} * A_{sl,ten,core}) / A_{sl,ten} = 200000.00$
 $y_2 = 0.0025$
 $sh_2 = 0.008$
 $ft_2 = 907.50$
 $fy_2 = 756.25$
 $su_2 = 0.032$
 using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
 and also multiplied by the shear_factor according to 15.7.1.4, with
 Shear_factor = 1.00
 $l_o/l_{ou,min} = l_b/l_{b,min} = 1.00$
 $su_2 = 0.4 * esu_{2,nominal} ((5.5), TBDY) = 0.032$
 From table 5A.1, TBDY: $esu_{2,nominal} = 0.08$,
 For calculation of $esu_{2,nominal}$ and y_2, sh_2, ft_2, fy_2 , it is considered
 characteristic value $fsy_2 = fs_2/1.2$, from table 5.1, TBDY.
 y_1, sh_1, ft_1, fy_1 , are also multiplied by $Min(1, 1.25 * (l_b/l_d)^{2/3})$, from 10.3.5, ASCE 41-17.
 with $fs_2 = (fs_{jacket} * A_{sl,com,jacket} + fs_{core} * A_{sl,com,core}) / A_{sl,com} = 756.25$
 with $Es_2 = (Es_{jacket} * A_{sl,com,jacket} + Es_{core} * A_{sl,com,core}) / A_{sl,com} = 200000.00$
 $y_v = 0.0025$
 $sh_v = 0.008$
 $ft_v = 899.1522$
 $fy_v = 749.2935$
 $suv = 0.032$
 using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
 and also multiplied by the shear_factor according to 15.7.1.4, with
 Shear_factor = 1.00
 $l_o/l_{ou,min} = l_b/l_d = 1.00$
 $suv = 0.4 * esuv_{nominal} ((5.5), TBDY) = 0.032$
 From table 5A.1, TBDY: $esuv_{nominal} = 0.08$,
 considering characteristic value $fsyv = fsv/1.2$, from table 5.1, TBDY
 For calculation of $esuv_{nominal}$ and y_v, sh_v, ft_v, fy_v , it is considered
 characteristic value $fsyv = fsv/1.2$, from table 5.1, TBDY.
 y_1, sh_1, ft_1, fy_1 , are also multiplied by $Min(1, 1.25 * (l_b/l_d)^{2/3})$, from 10.3.5, ASCE 41-17.
 with $fsv = (fs_{jacket} * A_{sl,mid,jacket} + fs_{mid} * A_{sl,mid,core}) / A_{sl,mid} = 749.2935$
 with $Esv = (Es_{jacket} * A_{sl,mid,jacket} + Es_{mid} * A_{sl,mid,core}) / A_{sl,mid} = 200000.00$
 $1 = A_{sl,ten} / (b * d) * (fs_1 / fc) = 0.09507586$
 $2 = A_{sl,com} / (b * d) * (fs_2 / fc) = 0.09507586$
 $v = A_{sl,mid} / (b * d) * (fsv / fc) = 0.22108466$
 and confined core properties:
 $b = 390.00$
 $d = 877.00$
 $d' = 13.00$
 $f_{cc} (5A.2, TBDY) = 30.00$
 $cc (5A.5, TBDY) = 0.002$
 $c = \text{confinement factor} = 1.00$
 $1 = A_{sl,ten} / (b * d) * (fs_1 / fc) = 0.11345559$
 $2 = A_{sl,com} / (b * d) * (fs_2 / fc) = 0.11345559$
 $v = A_{sl,mid} / (b * d) * (fsv / fc) = 0.26382395$
 Case/Assumption: Unconfined full section - Steel rupture
 ' satisfies Eq. (4.3)
 --->
 $v < v_{s,y2}$ - LHS eq.(4.5) is not satisfied
 --->
 $v < v_{s,c}$ - RHS eq.(4.5) is satisfied
 --->
 $su (4.8) = 0.28399348$
 $Mu = MRc (4.15) = 2.6730E+009$
 $u = su (4.1) = 4.9274896E-005$

Calculation of ratio l_b/d

Adequate Lap Length: $l_b/d \geq 1$

Calculation of μ_{2+}

Calculation of ultimate curvature μ according to 4.1, Biskinis/Fardis 2013:

$$\mu = 4.9274896E-005$$

$$\mu_u = 2.6730E+009$$

with full section properties:

$$b = 450.00$$

$$d = 907.00$$

$$d' = 43.00$$

$$\nu = 0.00169807$$

$$N = 20792.05$$

$$f_c = 30.00$$

$$\omega (5A.5, TBDY) = 0.002$$

$$\text{Final value of } \mu_u: \mu_u^* = \text{shear_factor} * \text{Max}(\mu_u, \mu_c) = 0.00832321$$

The Shear_factor is considered equal to 1 (pure moment strength)

$$\text{From (5.4b), TBDY: } \mu_u = 0.00832321$$

$$\mu_{ue} (5.4c) = 0.01453958$$

$$\mu_{ase} ((5.4d), TBDY) = (\mu_{ase1} * A_{ext} + \mu_{ase2} * A_{int}) / A_{sec} = 0.53375773$$

$$\mu_{ase1} = \text{Max}(((A_{conf,max1} - A_{noConf1}) / A_{conf,max1}) * (A_{conf,min1} / A_{conf,max1}), 0) = 0.53375773$$

The definitions of A_{noConf} , $A_{conf,min}$ and $A_{conf,max}$ are derived from generalization of the rectangular sections confinement, which is expressed by (5.4d).

The generalization is done according to Mander, J., Priestley, M., and Park, R. (1988)

"Theoretical Stress-Strain Model for Confined Concrete."

J. Struct. Eng., 10.1061/(ASCE)0733-9445(1988)114:8(1804), 1804-1826.

$A_{conf,max1} = 464100.00$ is the confined core area at levels of member with hoops and is calculated as the area of core enclosed by the center lines of the external perimeter hoops.

$A_{conf,min1} = 395025.00$ is the confined core area at midway between the levels of hoops and is calculated by reducing all the dimensions of the area $A_{conf,max1}$ by a length equal to half the clear spacing between external hoops.

$A_{noConf1} = 173066.667$ is the unconfined external core area which is equal to $b_i^2/6$ as defined at (A.2).

$$\mu_{ase2} (\geq \mu_{ase1}) = \text{Max}(((A_{conf,max2} - A_{noConf2}) / A_{conf,max2}) * (A_{conf,min2} / A_{conf,max2}), 0) = 0.53375773$$

The definitions of A_{noConf} , $A_{conf,min}$ and $A_{conf,max}$ are derived from generalization of the rectangular sections confinement, which is expressed by (5.4d).

The generalization is done according to Mander, J., Priestley, M., and Park, R. (1988)

"Theoretical Stress-Strain Model for Confined Concrete."

J. Struct. Eng., 10.1061/(ASCE)0733-9445(1988)114:8(1804), 1804-1826.

$A_{conf,max2} = 252164.00$ is the confined core area at levels of member with hoops and is calculated as the area of core enclosed by the center lines of the internal perimeter hoops.

$A_{conf,min2} = 111441.00$ is the confined core area at midway between the levels of hoops and is calculated by reducing all the dimensions of the area $A_{conf,max2}$ by a length equal to half the clear spacing between internal hoops.

$A_{noConf2} = 110709.333$ is the unconfined internal core area which is equal to $b_i^2/6$ as defined at (A.2).

$$p_{sh,min} * F_{ywe} = \text{Min}(p_{sh,x} * F_{ywe}, p_{sh,y} * F_{ywe}) = 2.724$$

Expression (5.4d) for $p_{sh,min} * F_{ywe}$ has been multiplied by 0.3 according to 15.7.1.3 for members without earthquake detailing (90° closed stirrups)

$$p_{sh,x} * F_{ywe} = p_{sh1} * F_{ywe1} + p_{sh2} * F_{ywe2} = 2.724$$

$$p_{sh1} ((5.4d), TBDY) = L_{stir1} * A_{stir1} / (A_{sec} * s_1) = 0.00301593$$

$$L_{stir1} \text{ (Length of stirrups along Y)} = 2160.00$$

$$A_{stir1} \text{ (stirrups area)} = 78.53982$$

$$p_{sh2} (5.4d) = L_{stir2} * A_{stir2} / (A_{sec} * s_2) = 0.00056047$$

$$L_{stir2} \text{ (Length of stirrups along Y)} = 1568.00$$

$$A_{stir2} \text{ (stirrups area)} = 50.26548$$

$$p_{sh,y} * F_{ywe} = p_{sh1} * F_{ywe1} + p_{sh2} * F_{ywe2} = 3.25416$$

$$p_{sh1} ((5.4d), TBDY) = L_{stir1} * A_{stir1} / (A_{sec} * s_1) = 0.00357443$$

Lstir1 (Length of stirrups along X) = 2560.00
 Astir1 (stirrups area) = 78.53982
 $psh2 ((5.4d), TBDY) = Lstir2 * Astir2 / (Asec * s2) = 0.00070345$
 Lstir2 (Length of stirrups along X) = 1968.00
 Astir2 (stirrups area) = 50.26548

Asec = 562500.00

s1 = 100.00

s2 = 250.00

fywe1 = 781.25

fywe2 = 656.25

fce = 30.00

From ((5.45), TBDY), TBDY: cc = 0.002

c = confinement factor = 1.00

y1 = 0.0025

sh1 = 0.008

ft1 = 907.50

fy1 = 756.25

su1 = 0.032

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
 and also multiplied by the shear_factor according to 15.7.1.4, with
 Shear_factor = 1.00

lo/lou,min = lb/ld = 1.00

su1 = 0.4*esu1_nominal ((5.5), TBDY) = 0.032

From table 5A.1, TBDY: esu1_nominal = 0.08,

For calculation of esu1_nominal and y1, sh1,ft1,fy1, it is considered
 characteristic value fsy1 = fs1/1.2, from table 5.1, TBDY.

y1, sh1,ft1,fy1, are also multiplied by $\text{Min}(1, 1.25 * (lb/ld)^{2/3})$, from 10.3.5, ASCE 41-17.

with fs1 = (fs,jacket*Asl,ten,jacket + fs,core*Asl,ten,core)/Asl,ten = 756.25

with Es1 = (Es,jacket*Asl,ten,jacket + Es,core*Asl,ten,core)/Asl,ten = 200000.00

y2 = 0.0025

sh2 = 0.008

ft2 = 907.50

fy2 = 756.25

su2 = 0.032

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
 and also multiplied by the shear_factor according to 15.7.1.4, with
 Shear_factor = 1.00

lo/lou,min = lb/lb,min = 1.00

su2 = 0.4*esu2_nominal ((5.5), TBDY) = 0.032

From table 5A.1, TBDY: esu2_nominal = 0.08,

For calculation of esu2_nominal and y2, sh2,ft2,fy2, it is considered
 characteristic value fsy2 = fs2/1.2, from table 5.1, TBDY.

y1, sh1,ft1,fy1, are also multiplied by $\text{Min}(1, 1.25 * (lb/ld)^{2/3})$, from 10.3.5, ASCE 41-17.

with fs2 = (fs,jacket*Asl,com,jacket + fs,core*Asl,com,core)/Asl,com = 756.25

with Es2 = (Es,jacket*Asl,com,jacket + Es,core*Asl,com,core)/Asl,com = 200000.00

yv = 0.0025

shv = 0.008

ftv = 899.1522

fyv = 749.2935

suv = 0.032

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
 and also multiplied by the shear_factor according to 15.7.1.4, with
 Shear_factor = 1.00

lo/lou,min = lb/ld = 1.00

suv = 0.4*esuv_nominal ((5.5), TBDY) = 0.032

From table 5A.1, TBDY: esuv_nominal = 0.08,

considering characteristic value fsyv = fsv/1.2, from table 5.1, TBDY

For calculation of esuv_nominal and yv, shv,ftv,fyv, it is considered
 characteristic value fsyv = fsv/1.2, from table 5.1, TBDY.

y1, sh1,ft1,fy1, are also multiplied by $\text{Min}(1, 1.25 * (lb/ld)^{2/3})$, from 10.3.5, ASCE 41-17.

with fsv = (fs,jacket*Asl,mid,jacket + fs,mid*Asl,mid,core)/Asl,mid = 749.2935

with Esv = (Es,jacket*Asl,mid,jacket + Es,mid*Asl,mid,core)/Asl,mid = 200000.00

1 = Asl,ten/(b*d)*(fs1/fc) = 0.09507586

2 = Asl,com/(b*d)*(fs2/fc) = 0.09507586

v = Asl,mid/(b*d)*(fsv/fc) = 0.22108466

and confined core properties:

```

b = 390.00
d = 877.00
d' = 13.00
fcc (5A.2, TBDY) = 30.00
cc (5A.5, TBDY) = 0.002
c = confinement factor = 1.00
1 = Asl,ten/(b*d)*(fs1/fc) = 0.11345559
2 = Asl,com/(b*d)*(fs2/fc) = 0.11345559
v = Asl,mid/(b*d)*(fsv/fc) = 0.26382395

```

Case/Assumption: Unconfined full section - Steel rupture
 ' satisfies Eq. (4.3)

---->
 v < vs,y2 - LHS eq.(4.5) is not satisfied

---->
 v < vs,c - RHS eq.(4.5) is satisfied

---->
 su (4.8) = 0.28399348
 Mu = MRc (4.15) = 2.6730E+009
 u = su (4.1) = 4.9274896E-005

 Calculation of ratio lb/d

 Adequate Lap Length: lb/d >= 1

 Calculation of Mu2-

 Calculation of ultimate curvature u according to 4.1, Biskinis/Fardis 2013:
 u = 4.9274896E-005
 Mu = 2.6730E+009

 with full section properties:

```

b = 450.00
d = 907.00
d' = 43.00
v = 0.00169807
N = 20792.05
fc = 30.00
co (5A.5, TBDY) = 0.002
Final value of cu: cu* = shear_factor * Max( cu, cc) = 0.00832321
The Shear_factor is considered equal to 1 (pure moment strength)
From (5.4b), TBDY: cu = 0.00832321
we (5.4c) = 0.01453958

```

```

ase ((5.4d), TBDY) = (ase1*Aext+ase2*Aint)/Asec = 0.53375773

```

```

ase1 = Max(((Aconf,max1-AnoConf1)/Aconf,max1)*(Aconf,min1/Aconf,max1),0) = 0.53375773

```

The definitions of AnoConf, Aconf,min and Aconf,max are derived from generalization of the rectangular sections confinement, which is expressed by (5.4d).

The generalization is done according to Mander, J., Priestley, M., and Park, R. (1988) "Theoretical Stress-Strain Model for Confined Concrete."

J. Struct. Eng., 10.1061/(ASCE)0733-9445(1988)114:8(1804), 1804-1826.

Aconf,max1 = 464100.00 is the confined core area at levels of member with hoops and is calculated as the area of core enclosed by the center lines of the external perimeter hoops.

Aconf,min1 = 395025.00 is the confined core area at midway between the levels of hoops and is calculated by reducing all the dimensions of the area Aconf,max1 by a length equal to half the clear spacing between external hoops.

AnoConf1 = 173066.667 is the unconfined external core area which is equal to bi2/6 as defined at (A.2).

```

ase2 (>=ase1) = Max(((Aconf,max2-AnoConf2)/Aconf,max2)*(Aconf,min2/Aconf,max2),0) = 0.53375773

```

The definitions of AnoConf, Aconf,min and Aconf,max are derived from generalization of the rectangular sections confinement, which is expressed by (5.4d).

The generalization is done according to Mander, J., Priestley, M., and Park, R. (1988) "Theoretical Stress-Strain Model for Confined Concrete."

J. Struct. Eng., 10.1061/(ASCE)0733-9445(1988)114:8(1804), 1804-1826.

Aconf,max2 = 252164.00 is the confined core area at levels of member with hoops and

is calculated as the area of core enclosed by the center lines of the internal perimeter hoops.

$A_{conf,min2} = 111441.00$ is the confined core area at midway between the levels of hoops and

is calculated by reducing all the dimensions of the area $A_{conf,max2}$ by a length

equal to half the clear spacing between internal hoops.

$A_{noConf2} = 110709.333$ is the unconfined internal core area which is equal to $b_i^2/6$ as defined at (A.2).

$psh_{min} \cdot F_{ywe} = \min(psh_x \cdot F_{ywe}, psh_y \cdot F_{ywe}) = 2.724$

Expression (5.4d) for $psh_{min} \cdot F_{ywe}$ has been multiplied by 0.3 according to 15.7.1.3 for members without earthquake detailing (90° closed stirrups)

$psh_x \cdot F_{ywe} = psh1 \cdot F_{ywe1} + ps2 \cdot F_{ywe2} = 2.724$

$psh1$ ((5.4d), TBDY) = $L_{stir1} \cdot A_{stir1} / (A_{sec} \cdot s1) = 0.00301593$

L_{stir1} (Length of stirrups along Y) = 2160.00

A_{stir1} (stirrups area) = 78.53982

$psh2$ ((5.4d)) = $L_{stir2} \cdot A_{stir2} / (A_{sec} \cdot s2) = 0.00056047$

L_{stir2} (Length of stirrups along Y) = 1568.00

A_{stir2} (stirrups area) = 50.26548

$psh_y \cdot F_{ywe} = psh1 \cdot F_{ywe1} + ps2 \cdot F_{ywe2} = 3.25416$

$psh1$ ((5.4d), TBDY) = $L_{stir1} \cdot A_{stir1} / (A_{sec} \cdot s1) = 0.00357443$

L_{stir1} (Length of stirrups along X) = 2560.00

A_{stir1} (stirrups area) = 78.53982

$psh2$ ((5.4d), TBDY) = $L_{stir2} \cdot A_{stir2} / (A_{sec} \cdot s2) = 0.00070345$

L_{stir2} (Length of stirrups along X) = 1968.00

A_{stir2} (stirrups area) = 50.26548

$A_{sec} = 562500.00$

$s1 = 100.00$

$s2 = 250.00$

$f_{ywe1} = 781.25$

$f_{ywe2} = 656.25$

$f_{ce} = 30.00$

From ((5.A5), TBDY), TBDY: $cc = 0.002$

c = confinement factor = 1.00

$y1 = 0.0025$

$sh1 = 0.008$

$ft1 = 907.50$

$fy1 = 756.25$

$su1 = 0.032$

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor

and also multiplied by the shear_factor according to 15.7.1.4, with

Shear_factor = 1.00

$lo/lou,min = lb/ld = 1.00$

$su1 = 0.4 \cdot esu1_{nominal}$ ((5.5), TBDY) = 0.032

From table 5A.1, TBDY: $esu1_{nominal} = 0.08$,

For calculation of $esu1_{nominal}$ and $y1$, $sh1$, $ft1$, $fy1$, it is considered

characteristic value $fsy1 = fs1/1.2$, from table 5.1, TBDY.

$y1$, $sh1$, $ft1$, $fy1$, are also multiplied by $\min(1, 1.25 \cdot (lb/ld)^{2/3})$, from 10.3.5, ASCE 41-17.

with $fs1 = (fs_{jacket} \cdot A_{sl,ten,jacket} + fs_{core} \cdot A_{sl,ten,core}) / A_{sl,ten} = 756.25$

with $Es1 = (Es_{jacket} \cdot A_{sl,ten,jacket} + Es_{core} \cdot A_{sl,ten,core}) / A_{sl,ten} = 200000.00$

$y2 = 0.0025$

$sh2 = 0.008$

$ft2 = 907.50$

$fy2 = 756.25$

$su2 = 0.032$

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor

and also multiplied by the shear_factor according to 15.7.1.4, with

Shear_factor = 1.00

$lo/lou,min = lb/lb,min = 1.00$

$su2 = 0.4 \cdot esu2_{nominal}$ ((5.5), TBDY) = 0.032

From table 5A.1, TBDY: $esu2_{nominal} = 0.08$,

For calculation of $esu2_{nominal}$ and $y2$, $sh2$, $ft2$, $fy2$, it is considered

characteristic value $fsy2 = fs2/1.2$, from table 5.1, TBDY.

$y1$, $sh1$, $ft1$, $fy1$, are also multiplied by $\min(1, 1.25 \cdot (lb/ld)^{2/3})$, from 10.3.5, ASCE 41-17.

with $fs2 = (fs_{jacket} \cdot A_{sl,com,jacket} + fs_{core} \cdot A_{sl,com,core}) / A_{sl,com} = 756.25$

with $Es2 = (Es_{jacket} \cdot A_{sl,com,jacket} + Es_{core} \cdot A_{sl,com,core}) / A_{sl,com} = 200000.00$

$yv = 0.0025$

$shv = 0.008$

```

ftv = 899.1522
fyv = 749.2935
suv = 0.032
    using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
    and also multiplied by the shear_factor according to 15.7.1.4, with
    Shear_factor = 1.00
    lo/lo,min = lb/ld = 1.00
    suv = 0.4*esuv_nominal ((5.5), TBDY) = 0.032
    From table 5A.1, TBDY: esuv_nominal = 0.08,
    considering characteristic value fsyv = fsv/1.2, from table 5.1, TBDY
    For calculation of esuv_nominal and yv, shv,ftv,fyv, it is considered
    characteristic value fsyv = fsv/1.2, from table 5.1, TBDY.
    y1, sh1,ft1,fy1, are also multiplied by Min(1,1.25*(lb/ld)^2/3), from 10.3.5, ASCE 41-17.
    with fsv = (fsjacket*Asl,mid,jacket + fs,mid*Asl,mid,core)/Asl,mid = 749.2935
    with Esv = (Es,jacket*Asl,mid,jacket + Es,mid*Asl,mid,core)/Asl,mid = 200000.00
    1 = Asl,ten/(b*d)*(fs1/fc) = 0.09507586
    2 = Asl,com/(b*d)*(fs2/fc) = 0.09507586
    v = Asl,mid/(b*d)*(fsv/fc) = 0.22108466
and confined core properties:
b = 390.00
d = 877.00
d' = 13.00
fcc (5A.2, TBDY) = 30.00
cc (5A.5, TBDY) = 0.002
    c = confinement factor = 1.00
    1 = Asl,ten/(b*d)*(fs1/fc) = 0.11345559
    2 = Asl,com/(b*d)*(fs2/fc) = 0.11345559
    v = Asl,mid/(b*d)*(fsv/fc) = 0.26382395
Case/Assumption: Unconfined full section - Steel rupture
' satisfies Eq. (4.3)
--->
v < vs,y2 - LHS eq.(4.5) is not satisfied
--->
v < vs,c - RHS eq.(4.5) is satisfied
--->
su (4.8) = 0.28399348
Mu = MRc (4.15) = 2.6730E+009
u = su (4.1) = 4.9274896E-005
-----

Calculation of ratio lb/ld
-----
Adequate Lap Length: lb/ld >= 1
-----
-----
-----
Calculation of Shear Strength Vr = Min(Vr1,Vr2) = 1.6349E+006
-----
Calculation of Shear Strength at edge 1, Vr1 = 1.6349E+006
Vr1 = VCol ((10.3), ASCE 41-17) = knl*VCol0
VCol0 = 1.6349E+006
knl = 1 (zero step-static loading)
-----
NOTE: In expression (10-3) 'Vs = Av*fy*d/s' is replaced by 'Vs+ f*Vf'
where Vf is the contribution of FRPs (11.3), ACI 440).
-----
= 1 (normal-weight concrete)
Mean concrete strength: fc' = (fc'_jacket*Area_jacket + fc'_core*Area_core)/Area_section = 27.20, but fc'^0.5 <= 8.3
MPa (22.5.3.1, ACI 318-14)
M/Vd = 2.00
Mu = 4.16869
Vu = 5.2099631E-036
d = 0.8*h = 760.00
Nu = 20792.05
Ag = 427500.00
From (11.5.4.8), ACI 318-14: Vs = Vs,jacket + Vs,core = 1.2262E+006

```

where:

$$V_{sj,jacket} = V_{sj,1} + V_{sj,2} = 1.0996E+006$$

$V_{sj,1} = 353429.174$ is calculated for section web jacket, with:

$$d = 360.00$$

$$A_v = 157079.633$$

$$f_y = 625.00$$

$$s = 100.00$$

$V_{sj,1}$ is multiplied by $Col,j1 = 1.00$

$$s/d = 0.27777778$$

$V_{sj,2} = 746128.255$ is calculated for section flange jacket, with:

$$d = 760.00$$

$$A_v = 157079.633$$

$$f_y = 625.00$$

$$s = 100.00$$

$V_{sj,2}$ is multiplied by $Col,j2 = 1.00$

$$s/d = 0.13157895$$

$$V_{s,core} = V_{s,c1} + V_{s,c2} = 126669.016$$

$V_{s,c1} = 0.00$ is calculated for section web core, with:

$$d = 200.00$$

$$A_v = 100530.965$$

$$f_y = 525.00$$

$$s = 250.00$$

$V_{s,c1}$ is multiplied by $Col,c1 = 0.00$

$$s/d = 1.25$$

$V_{s,c2} = 126669.016$ is calculated for section flange core, with:

$$d = 600.00$$

$$A_v = 100530.965$$

$$f_y = 525.00$$

$$s = 250.00$$

$V_{s,c2}$ is multiplied by $Col,c2 = 1.00$

$$s/d = 0.41666667$$

$$V_f ((11-3)-(11.4), \text{ACI } 440) = 0.00$$

$$\text{From } (11-11), \text{ACI } 440: V_s + V_f \leq 1.1849E+006$$

$$bw = 450.00$$

Calculation of Shear Strength at edge 2, $V_{r2} = 1.6349E+006$

$$V_{r2} = V_{Col} ((10.3), \text{ASCE } 41-17) = knl * V_{Col0}$$

$$V_{Col0} = 1.6349E+006$$

$$knl = 1 \text{ (zero step-static loading)}$$

NOTE: In expression (10-3) ' $V_s = A_v * f_y * d / s$ ' is replaced by ' $V_s + f * V_f$ ' where V_f is the contribution of FRPs (11.3), ACI 440).

$$= 1 \text{ (normal-weight concrete)}$$

$$\text{Mean concrete strength: } f'_c = (f'_c_{jacket} * Area_{jacket} + f'_c_{core} * Area_{core}) / Area_{section} = 27.20, \text{ but } f'_c^{0.5} \leq 8.3 \text{ MPa (22.5.3.1, ACI 318-14)}$$

$$M/Vd = 2.00$$

$$\mu_u = 4.16869$$

$$V_u = 5.2099631E-036$$

$$d = 0.8 * h = 760.00$$

$$N_u = 20792.05$$

$$A_g = 427500.00$$

$$\text{From (11.5.4.8), ACI 318-14: } V_s = V_{sj,jacket} + V_{s,core} = 1.2262E+006$$

where:

$$V_{sj,jacket} = V_{sj,1} + V_{sj,2} = 1.0996E+006$$

$V_{sj,1} = 353429.174$ is calculated for section web jacket, with:

$$d = 360.00$$

$$A_v = 157079.633$$

$$f_y = 625.00$$

$$s = 100.00$$

$V_{sj,1}$ is multiplied by $Col,j1 = 1.00$

$$s/d = 0.27777778$$

$V_{sj,2} = 746128.255$ is calculated for section flange jacket, with:

$$d = 760.00$$

$$A_v = 157079.633$$

$$f_y = 625.00$$

$s = 100.00$
 $V_{s,j2}$ is multiplied by $Col,j2 = 1.00$
 $s/d = 0.13157895$
 $V_{s,core} = V_{s,c1} + V_{s,c2} = 126669.016$
 $V_{s,c1} = 0.00$ is calculated for section web core, with:
 $d = 200.00$
 $A_v = 100530.965$
 $f_y = 525.00$
 $s = 250.00$
 $V_{s,c1}$ is multiplied by $Col,c1 = 0.00$
 $s/d = 1.25$
 $V_{s,c2} = 126669.016$ is calculated for section flange core, with:
 $d = 600.00$
 $A_v = 100530.965$
 $f_y = 525.00$
 $s = 250.00$
 $V_{s,c2}$ is multiplied by $Col,c2 = 1.00$
 $s/d = 0.41666667$
 $V_f ((11-3)-(11.4), ACI 440) = 0.00$
 From (11-11), ACI 440: $V_s + V_f \leq 1.1849E+006$
 $bw = 450.00$

 End Of Calculation of Shear Capacity ratio for element: column JTC1 of floor 1
 At local axis: 2

 Start Of Calculation of Chord Rotation Capacity for element: column JTC1 of floor 1
 At local axis: 2
 Integration Section: (a)
 Section Type: rcjtcs

Constant Properties

 Knowledge Factor, $\phi = 0.80$
 Chord Rotation is generally considered as Deformation-Controlled Action according to Table C7-1, ASCE 41-17.
 Mean strengths are used for Deformation-Controlled Actions according to 7.5.1.3, ASCE 41-17
 Consequently:
 Jacket
 New material of Secondary Member: Concrete Strength, $f_c = f_{cm} = 30.00$
 New material of Secondary Member: Steel Strength, $f_s = f_{sm} = 625.00$
 Concrete Elasticity, $E_c = 25742.96$
 Steel Elasticity, $E_s = 200000.00$
 Existing Column
 Existing material of Secondary Member: Concrete Strength, $f_c = f_{cm} = 24.00$
 Existing material of Secondary Member: Steel Strength, $f_s = f_{sm} = 525.00$
 Concrete Elasticity, $E_c = 23025.204$
 Steel Elasticity, $E_s = 200000.00$
 Max Height, $H_{max} = 750.00$
 Min Height, $H_{min} = 450.00$
 Max Width, $W_{max} = 950.00$
 Min Width, $W_{min} = 450.00$
 Eccentricity, $E_{cc} = 250.00$
 Jacket Thickness, $t_j = 100.00$
 Cover Thickness, $c = 25.00$
 Element Length, $L = 3000.00$
 Secondary Member
 Smooth Bars
 Ductile Steel
 Without Detailing for Earthquake Resistance (including stirrups not closed at 135°)
 Longitudinal Bars With Ends Lapped Starting at the End Sections
 Adequate Lap Length ($l_b/d \geq 1$)
 No FRP Wrapping

Stepwise Properties

Bending Moment, $M = 9692.864$

Shear Force, $V2 = -8294.64$

Shear Force, $V3 = -1.96926$

Axial Force, $F = -22375.589$

Longitudinal Reinforcement Area Distribution (in 2 divisions)

-Tension: $As_{lt} = 0.00$

-Compression: $As_{lc} = 6691.592$

Longitudinal Reinforcement Area Distribution (in 3 divisions)

-Tension: $As_{l,ten} = 1539.38$

-Compression: $As_{l,com} = 2475.575$

-Middle: $As_{l,mid} = 2676.637$

Longitudinal External Reinforcement Area Distribution (in 3 divisions)

-Tension: $As_{l,ten,jacket} = 1231.504$

-Compression: $As_{l,com,jacket} = 1859.823$

-Middle: $As_{l,mid,jacket} = 2060.885$

Longitudinal Internal Reinforcement Area Distribution (in 3 divisions)

-Tension: $As_{l,ten,core} = 307.8761$

-Compression: $As_{l,com,core} = 615.7522$

-Middle: $As_{l,mid,core} = 615.7522$

Mean Diameter of Tension Reinforcement, $DbL = 16.57143$

Existing component: From table 7-7, ASCE 41_17: Final chord rotation Capacity $u_R = u = 0.03373694$
 $u = y + p = 0.04217118$

- Calculation of y -

$y = (M_y * L_s / 3) / E_{eff} = 0.0090626$ ((4.29), Biskinis Phd))

$M_y = 9.4108E+008$

$L_s = M/V$ (with $L_s > 0.1 * L$ and $L_s < 2 * L$) = 4922.076

From table 10.5, ASCE 41_17: $E_{eff} = factor * E_c * I_g = 1.7037E+014$

factor = 0.30

$A_g = 562500.00$

Mean concrete strength: $fc' = (fc'_{jacket} * Area_{jacket} + fc'_{core} * Area_{core}) / Area_{section} = 27.20$

$N = 22375.589$

$E_c * I_g = E_{c,jacket} * I_{g,jacket} + E_{c,core} * I_{g,core} = 5.6791E+014$

Calculation of Yielding Moment M_y

Calculation of y and M_y according to Annex 7 -

Assuming neutral axis within flange ($y < t/d$, compression zone rectangular) with:

flange width, $b = 950.00$

web width, $b_w = 450.00$

flange thickness, $t = 450.00$

$y = \min(y_{ten}, y_{com})$

$y_{ten} = 5.3416636E-006$

with $f_y = 601.9953$

$d = 707.00$

$y = 0.20298377$

$A = 0.01001826$

$B = 0.00468522$

with $pt = 0.00229194$

$pc = 0.00368581$

$pv = 0.00398517$

$N = 22375.589$

$b = 950.00$

$\alpha = 0.06082037$

$y_{comp} = 1.4673137E-005$

with $f_c = 30.00$
 $E_c = 25742.96$
 $y = 0.20220547$
 $A = 0.00988351$
 $B = 0.00462988$
with $E_s = 200000.00$
CONFIRMATION: $y = 0.20298377 < t/d$

Calculation of ratio I_b/I_d

Adequate Lap Length: $I_b/I_d \geq 1$

- Calculation of p -

From table 10-8: $p = 0.03310857$

with:

- Columns not controlled by inadequate development or splicing along the clear height because $I_b/I_d \geq 1$

shear control ratio $V_y E / V_{col} E = 1.11674$

$d = d_{external} = 707.00$

$s = s_{external} = 0.00$

- $t = s_1 + s_2 + 2 * t_f / b_w * (f_{fe} / f_s) = 0.0035764$

jacket: $s_1 = A_{v1} * L_{stir1} / (s_1 * A_g) = 0.00301593$

$A_{v1} = 78.53982$, is the area of every stirrup parallel to loading (shear) direction

$L_{stir1} = 2160.00$, is the total Length of all stirrups parallel to loading (shear) direction

$s_1 = 100.00$

core: $s_2 = A_{v2} * L_{stir2} / (s_2 * A_g) = 0.00056047$

$A_{v2} = 50.26548$, is the area of every stirrup parallel to loading (shear) direction

$L_{stir2} = 1568.00$, is the total Length of all stirrups parallel to loading (shear) direction

$s_2 = 250.00$

The term $2 * t_f / b_w * (f_{fe} / f_s)$ is implemented to account for FRP contribution

where $f = 2 * t_f / b_w$ is FRP ratio (EC8 - 3, A.4.4.3(6)) and f_{fe} / f_s normalises f to steel strength

All these variables have already been given in Shear control ratio calculation.

For the normalisation f_s of jacket is used.

$NUD = 22375.589$

$A_g = 562500.00$

$f_{cE} = (f_{c,jacket} * Area_{jacket} + f_{c,core} * Area_{core}) / section_area = 27.20$

$f_{yIE} = (f_{y,ext_Long_Reinf} * Area_{ext_Long_Reinf} + f_{y,int_Long_Reinf} * Area_{int_Long_Reinf}) / Area_{Tot_Long_Rein} =$

601.9953

$f_{yIE} = (f_{y,ext_Trans_Reinf} * s_1 + f_{y,int_Trans_Reinf} * s_2) / (s_1 + s_2) = 609.3286$

$pI = Area_{Tot_Long_Rein} / (b * d) = 0.00996292$

$b = 950.00$

$d = 707.00$

$f_{cE} = 27.20$

End Of Calculation of Chord Rotation Capacity for element: column JTC1 of floor 1

At local axis: 2

Integration Section: (a)

Calculation No. 11

column C1, Floor 1


Limit State: Life Safety (data interpolation between analysis steps 1 and 2)

Analysis: Uniform +X

Check: Shear capacity VRd

Edge: Start

Local Axis: (3)



Start Of Calculation of Shear Capacity for element: column JTC1 of floor 1

At local axis: 3

Integration Section: (a)

Section Type: rcjtcs

Constant Properties

Knowledge Factor, $\gamma = 0.80$

Member Shear Force is generally considered as Force-Controlled Action according to Table C7-1, ASCE 41-17.

Lower-bound strengths are used for Force-Controlled Actions according to 7.5.1.3, ASCE 41-17

Consequently:

Jacket

New material of Secondary Member: Concrete Strength, $f_c = f_{c_lower_bound} = 20.00$

New material of Secondary Member: Steel Strength, $f_s = f_{s_lower_bound} = 500.00$

Concrete Elasticity, $E_c = 25742.96$

Steel Elasticity, $E_s = 200000.00$

Existing Column

Existing material of Secondary Member: Concrete Strength, $f_c = f_{c_lower_bound} = 16.00$

Existing material of Secondary Member: Steel Strength, $f_s = f_{s_lower_bound} = 420.00$

Concrete Elasticity, $E_c = 23025.204$

Steel Elasticity, $E_s = 200000.00$

#####

Note: Especially for the calculation of γ for displacement ductility demand, the expected (mean value) strengths are used (7.5.1.3, ASCE 41-17) because bending is considered as Deformation-Controlled Action (Table C7-1, ASCE 41-17).

Jacket

New material: Concrete Strength, $f_c = f_{cm} = 30.00$

New material: Steel Strength, $f_s = f_{sm} = 625.00$

Existing Column

Existing material: Concrete Strength, $f_c = f_{cm} = 24.00$

Existing material: Steel Strength, $f_s = f_{sm} = 525.00$

#####

Max Height, $H_{max} = 750.00$

Min Height, $H_{min} = 450.00$

Max Width, $W_{max} = 950.00$

Min Width, $W_{min} = 450.00$

Eccentricity, $E_{cc} = 250.00$

Jacket Thickness, $t_j = 100.00$

Cover Thickness, $c = 25.00$

Element Length, L = 3000.00
 Secondary Member
 Smooth Bars
 Ductile Steel
 Without Detailing for Earthquake Resistance (including stirrups not closed at 135°)
 Longitudinal Bars With Ends Lapped Starting at the End Sections
 Adequate Lap Length ($l_o/l_{ou,min} = l_b/l_d \geq 1$)
 No FRP Wrapping

Stepwise Properties

EDGE -A-
 Bending Moment, $M_a = 9692.864$
 Shear Force, $V_a = -1.96926$
 EDGE -B-
 Bending Moment, $M_b = -2610.668$
 Shear Force, $V_b = 1.96926$
 BOTH EDGES
 Axial Force, $F = -22375.589$
 Longitudinal Reinforcement Area Distribution (in 2 divisions)
 -Tension: $A_{st} = 0.00$
 -Compression: $A_{sc} = 6691.592$
 Longitudinal Reinforcement Area Distribution (in 3 divisions)
 -Tension: $A_{st,ten} = 1539.38$
 -Compression: $A_{sc,com} = 2475.575$
 -Middle: $A_{st,mid} = 2676.637$
 Mean Diameter of Tension Reinforcement, $Db_{L,ten} = 16.57143$

Existing component: From table 7-7, ASCE 41_17: Final Shear Capacity $V_R = V_n = 727776.597$
 V_n ((10.3), ASCE 41-17) = $k_n l V_{CoI} = 909720.747$
 $V_{CoI} = 909720.747$
 $k_n l = 1.00$
 displacement_ductility_demand = 0.00138508

NOTE: In expression (10-3) ' $V_s = A_v f_y d/s$ ' is replaced by ' $V_s + f^* V_f$ '
 where V_f is the contribution of FRPs (11.3), ACI 440).

= 1 (normal-weight concrete)
 Mean concrete strength: $f'_c = (f'_{c,jacket} \text{Area}_{jacket} + f'_{c,core} \text{Area}_{core}) / \text{Area}_{section} = 18.13333$, but $f'_c^{0.5} \leq 8.3 \text{ MPa}$ (22.5.3.1, ACI 318-14)
 $M/Vd = 4.00$
 $M_u = 9692.864$
 $V_u = 1.96926$
 $d = 0.8 \cdot h = 600.00$
 $N_u = 22375.589$
 $A_g = 337500.00$
 From (11.5.4.8), ACI 318-14: $V_s = V_{sjacket} + V_{s,core} = 828294.726$
 where:
 $V_{sjacket} = V_{sj1} + V_{sj2} = 753982.237$
 $V_{sj1} = 471238.898$ is calculated for section web jacket, with:
 $d = 600.00$
 $A_v = 157079.633$
 $f_y = 500.00$
 $s = 100.00$
 V_{sj1} is multiplied by $Col_{j1} = 1.00$
 $s/d = 0.16666667$
 $V_{sj2} = 282743.339$ is calculated for section flange jacket, with:
 $d = 360.00$
 $A_v = 157079.633$
 $f_y = 500.00$
 $s = 100.00$
 V_{sj2} is multiplied by $Col_{j2} = 1.00$
 $s/d = 0.27777778$

$V_{s,core} = V_{s,c1} + V_{s,c2} = 74312.489$
 $V_{s,c1} = 74312.489$ is calculated for section web core, with:
 $d = 440.00$
 $A_v = 100530.965$
 $f_y = 420.00$
 $s = 250.00$
 $V_{s,c1}$ is multiplied by $Col,c1 = 1.00$
 $s/d = 0.56818182$
 $V_{s,c2} = 0.00$ is calculated for section flange core, with:
 $d = 200.00$
 $A_v = 100530.965$
 $f_y = 420.00$
 $s = 250.00$
 $V_{s,c2}$ is multiplied by $Col,c2 = 0.00$
 $s/d = 1.25$
 $V_f ((11-3)-(11.4), ACI 440) = 0.00$
 From (11-11), ACI 440: $V_s + V_f \leq 763781.865$
 $bw = 450.00$

displacement_ductility_demand is calculated as ϕ / y

- Calculation of ϕ / y for END A -
for rotation axis 2 and integ. section (a)

From analysis, chord rotation $\theta = 1.2552399E-005$
 $y = (M_y * L_s / 3) / E_{eff} = 0.0090626 ((4.29), Biskinis Phd)$
 $M_y = 9.4108E+008$
 $L_s = M/V$ (with $L_s > 0.1 * L$ and $L_s < 2 * L$) = 4922.076
 From table 10.5, ASCE 41_17: $E_{eff} = factor * E_c * I_g = 1.7037E+014$
 $factor = 0.30$
 $A_g = 562500.00$
 Mean concrete strength: $f_c' = (f_c'_{jacket} * Area_{jacket} + f_c'_{core} * Area_{core}) / Area_{section} = 27.20$
 $N = 22375.589$
 $E_c * I_g = E_c * I_{g,jacket} + E_c * I_{g,core} = 5.6791E+014$

Calculation of Yielding Moment M_y

Calculation of ϕ and M_y according to Annex 7 -

Assuming neutral axis within flange ($y < t/d$, compression zone rectangular) with:
 flange width, $b = 950.00$
 web width, $bw = 450.00$
 flange thickness, $t = 450.00$

$y = \text{Min}(y_{ten}, y_{com})$
 $y_{ten} = 5.3416636E-006$
 with $f_y = 601.9953$
 $d = 707.00$
 $y = 0.20298377$
 $A = 0.01001826$
 $B = 0.00468522$
 with $p_t = 0.00229194$
 $p_c = 0.00368581$
 $p_v = 0.00398517$
 $N = 22375.589$
 $b = 950.00$
 $" = 0.06082037$
 $y_{comp} = 1.4673137E-005$
 with $f_c = 30.00$
 $E_c = 25742.96$
 $y = 0.20220547$
 $A = 0.00988351$
 $B = 0.00462988$

with $E_s = 200000.00$
CONFIRMATION: $y = 0.20298377 < t/d$

Calculation of ratio I_b/I_d

Adequate Lap Length: $I_b/I_d \geq 1$

End Of Calculation of Shear Capacity for element: column JTC1 of floor 1

At local axis: 3

Integration Section: (a)

Calculation No. 12

column C1, Floor 1


Limit State: Life Safety (data interpolation between analysis steps 1 and 2)

Analysis: Uniform +X

Check: Chord rotation capacity (ϕ)

Edge: Start

Local Axis: (3)



Start Of Calculation of Shear Capacity ratio for element: column JTC1 of floor 1

At Shear local axis: 3

(Bending local axis: 2)

Section Type: rcjtcs

Constant Properties

Knowledge Factor, $\gamma = 0.80$

Mean strength values are used for both shear and moment calculations.

Consequently:

Jacket

New material of Secondary Member: Concrete Strength, $f_c = f_{cm} = 30.00$

New material of Secondary Member: Steel Strength, $f_s = f_{sm} = 625.00$

Concrete Elasticity, $E_c = 25742.96$

Steel Elasticity, $E_s = 200000.00$

Existing Column

Existing material of Secondary Member: Concrete Strength, $f_c = f_{cm} = 24.00$
 Existing material of Secondary Member: Steel Strength, $f_s = f_{sm} = 525.00$
 Concrete Elasticity, $E_c = 23025.204$
 Steel Elasticity, $E_s = 200000.00$
 #####
 Note: Especially for the calculation of moment strengths,
 the above steel re-bar strengths are multiplied by 1.25 according to R18.6.5, ACI 318-14
 Jacket
 New material: Steel Strength, $f_s = 1.25 \cdot f_{sm} = 781.25$
 Existing Column
 Existing material: Steel Strength, $f_s = 1.25 \cdot f_{sm} = 656.25$
 #####
 Max Height, $H_{max} = 750.00$
 Min Height, $H_{min} = 450.00$
 Max Width, $W_{max} = 950.00$
 Min Width, $W_{min} = 450.00$
 Eccentricity, $E_{cc} = 250.00$
 Jacket Thickness, $t_j = 100.00$
 Cover Thickness, $c = 25.00$
 Mean Confinement Factor overall section = 1.00
 Element Length, $L = 3000.00$
 Secondary Member
 Smooth Bars
 Ductile Steel
 Without Detailing for Earthquake Resistance (including stirrups not closed at 135°)
 Longitudinal Bars With Ends Lapped Starting at the End Sections
 Adequate Lap Length ($l_o/l_{ou,min} > 1$)
 No FRP Wrapping

Stepwise Properties

At local axis: 3
 EDGE -A-
 Shear Force, $V_a = -8.5087964E-020$
 EDGE -B-
 Shear Force, $V_b = 8.5087964E-020$
 BOTH EDGES
 Axial Force, $F = -20792.05$
 Longitudinal Reinforcement Area Distribution (in 2 divisions)
 -Tension: $A_{sl,t} = 0.00$
 -Compression: $A_{sl,c} = 6691.592$
 Longitudinal Reinforcement Area Distribution (in 3 divisions)
 -Tension: $A_{sl,ten} = 1539.38$
 -Compression: $A_{sl,com} = 2475.575$
 -Middle: $A_{sl,mid} = 2676.637$

Calculation of Shear Capacity ratio, $V_e/V_r = 1.11674$
 Member Controlled by Shear ($V_e/V_r > 1$)
 Calculation of Shear Demand from fig. R18.6.5, ACI 318-14 $V_e = (M_{pr1} + M_{pr2})/l_n = 1.4424E+006$
 with
 $M_{pr1} = \max(\mu_{u1+}, \mu_{u1-}) = 2.1636E+009$
 $\mu_{u1+} = 2.0419E+009$, is the ultimate moment strength at the edge 1 of the member in the actual moment direction
 which is defined for the static loading combination
 $\mu_{u1-} = 2.1636E+009$, is the ultimate moment strength at the edge 1 of the member in the opposite moment
 direction which is defined for the static loading combination
 $M_{pr2} = \max(\mu_{u2+}, \mu_{u2-}) = 2.1636E+009$
 $\mu_{u2+} = 2.0419E+009$, is the ultimate moment strength at the edge 2 of the member in the actual moment direction
 which is defined for the the static loading combination
 $\mu_{u2-} = 2.1636E+009$, is the ultimate moment strength at the edge 2 of the member in the opposite moment
 direction which is defined for the the static loading combination

Calculation of μ_{u1+}

Calculation of ultimate curvature ϕ_u according to 4.1, Biskinis/Fardis 2013:

$$u = 5.3321191E-005$$

$$\mu = 2.0419E+009$$

with full section properties:

$$b = 950.00$$

$$d = 707.00$$

$$d' = 43.00$$

$$v = 0.00103189$$

$$N = 20792.05$$

$$f_c = 30.00$$

$$\alpha (5A.5, \text{TBDY}) = 0.002$$

$$\text{Final value of } \phi_u: \phi_u^* = \text{shear_factor} * \text{Max}(\phi_u, \phi_c) = 0.00832321$$

The Shear_factor is considered equal to 1 (pure moment strength)

$$\text{From (5.4b), TBDY: } \phi_u = 0.00832321$$

$$\phi_{ue} (5.4c) = 0.01453958$$

$$\alpha_{se} ((5.4d), \text{TBDY}) = (\alpha_{se1} * A_{ext} + \alpha_{se2} * A_{int}) / A_{sec} = 0.53375773$$

$$\alpha_{se1} = \text{Max}(((A_{conf,max1} - A_{noConf1}) / A_{conf,max1}) * (A_{conf,min1} / A_{conf,max1}), 0) = 0.53375773$$

The definitions of A_{noConf} , $A_{conf,min}$ and $A_{conf,max}$ are derived from generalization of the rectangular sections confinement, which is expressed by (5.4d).

The generalization is done according to Mander, J., Priestley, M., and Park, R. (1988)

"Theoretical Stress-Strain Model for Confined Concrete."

J. Struct. Eng., 10.1061/(ASCE)0733-9445(1988)114:8(1804), 1804-1826.

$A_{conf,max1} = 464100.00$ is the confined core area at levels of member with hoops and is calculated as the area of core enclosed by the center lines of the external perimeter hoops.

$A_{conf,min1} = 395025.00$ is the confined core area at midway between the levels of hoops and is calculated by reducing all the dimensions of the area $A_{conf,max1}$ by a length equal to half the clear spacing between external hoops.

$A_{noConf1} = 173066.667$ is the unconfined external core area which is equal to $b_i d_i / 6$ as defined at (A.2).

$$\alpha_{se2} (> \alpha_{se1}) = \text{Max}(((A_{conf,max2} - A_{noConf2}) / A_{conf,max2}) * (A_{conf,min2} / A_{conf,max2}), 0) = 0.53375773$$

The definitions of A_{noConf} , $A_{conf,min}$ and $A_{conf,max}$ are derived from generalization of the rectangular sections confinement, which is expressed by (5.4d).

The generalization is done according to Mander, J., Priestley, M., and Park, R. (1988)

"Theoretical Stress-Strain Model for Confined Concrete."

J. Struct. Eng., 10.1061/(ASCE)0733-9445(1988)114:8(1804), 1804-1826.

$A_{conf,max2} = 252164.00$ is the confined core area at levels of member with hoops and is calculated as the area of core enclosed by the center lines of the internal perimeter hoops.

$A_{conf,min2} = 111441.00$ is the confined core area at midway between the levels of hoops and is calculated by reducing all the dimensions of the area $A_{conf,max2}$ by a length equal to half the clear spacing between internal hoops.

$A_{noConf2} = 110709.333$ is the unconfined internal core area which is equal to $b_i d_i / 6$ as defined at (A.2).

$$\phi_{sh,min} * F_{ywe} = \text{Min}(\phi_{sh,x} * F_{ywe}, \phi_{sh,y} * F_{ywe}) = 2.724$$

Expression (5.4d) for $\phi_{sh,min} * F_{ywe}$ has been multiplied by 0.3 according to 15.7.1.3 for members without earthquake detailing (90° closed stirrups)

$$\phi_{sh,x} * F_{ywe} = \phi_{sh1} * F_{ywe1} + \phi_{sh2} * F_{ywe2} = 2.724$$

$$\phi_{sh1} ((5.4d), \text{TBDY}) = L_{stir1} * A_{stir1} / (A_{sec} * s_1) = 0.00301593$$

$$L_{stir1} \text{ (Length of stirrups along Y)} = 2160.00$$

$$A_{stir1} \text{ (stirrups area)} = 78.53982$$

$$\phi_{sh2} (5.4d) = L_{stir2} * A_{stir2} / (A_{sec} * s_2) = 0.00056047$$

$$L_{stir2} \text{ (Length of stirrups along Y)} = 1568.00$$

$$A_{stir2} \text{ (stirrups area)} = 50.26548$$

$$\phi_{sh,y} * F_{ywe} = \phi_{sh1} * F_{ywe1} + \phi_{sh2} * F_{ywe2} = 3.25416$$

$$\phi_{sh1} ((5.4d), \text{TBDY}) = L_{stir1} * A_{stir1} / (A_{sec} * s_1) = 0.00357443$$

$$L_{stir1} \text{ (Length of stirrups along X)} = 2560.00$$

$$A_{stir1} \text{ (stirrups area)} = 78.53982$$

$$\phi_{sh2} ((5.4d), \text{TBDY}) = L_{stir2} * A_{stir2} / (A_{sec} * s_2) = 0.00070345$$

$$L_{stir2} \text{ (Length of stirrups along X)} = 1968.00$$

$$A_{stir2} \text{ (stirrups area)} = 50.26548$$

$$A_{sec} = 562500.00$$

$$s_1 = 100.00$$

$$s_2 = 250.00$$

```

fywe1 = 781.25
fywe2 = 656.25
fce = 30.00
From ((5.A.5), TBDY), TBDY: cc = 0.002
c = confinement factor = 1.00
y1 = 0.0025
sh1 = 0.008
ft1 = 907.50
fy1 = 756.25
su1 = 0.032
using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00
lo/lou,min = lb/lb = 1.00
su1 = 0.4*esu1_nominal ((5.5), TBDY) = 0.032
From table 5A.1, TBDY: esu1_nominal = 0.08,
For calculation of esu1_nominal and y1, sh1,ft1,fy1, it is considered
characteristic value fsy1 = fs1/1.2, from table 5.1, TBDY.
y1, sh1,ft1,fy1, are also multiplied by  $\text{Min}(1, 1.25 \cdot (lb/ld)^{2/3})$ , from 10.3.5, ASCE 41-17.
with fs1 = (fs,jacket*Asl,ten,jacket + fs,core*Asl,ten,core)/Asl,ten = 756.25
with Es1 = (Es,jacket*Asl,ten,jacket + Es,core*Asl,ten,core)/Asl,ten = 200000.00
y2 = 0.0025
sh2 = 0.008
ft2 = 900.1904
fy2 = 750.1586
su2 = 0.032
using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00
lo/lou,min = lb/lb,min = 1.00
su2 = 0.4*esu2_nominal ((5.5), TBDY) = 0.032
From table 5A.1, TBDY: esu2_nominal = 0.08,
For calculation of esu2_nominal and y2, sh2,ft2,fy2, it is considered
characteristic value fsy2 = fs2/1.2, from table 5.1, TBDY.
y1, sh1,ft1,fy1, are also multiplied by  $\text{Min}(1, 1.25 \cdot (lb/ld)^{2/3})$ , from 10.3.5, ASCE 41-17.
with fs2 = (fs,jacket*Asl,com,jacket + fs,core*Asl,com,core)/Asl,com = 750.1586
with Es2 = (Es,jacket*Asl,com,jacket + Es,core*Asl,com,core)/Asl,com = 200000.00
yv = 0.0025
shv = 0.008
ftv = 902.993
fyv = 752.4941
suv = 0.032
using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00
lo/lou,min = lb/lb = 1.00
suv = 0.4*esuv_nominal ((5.5), TBDY) = 0.032
From table 5A.1, TBDY: esuv_nominal = 0.08,
considering characteristic value fsyv = fsv/1.2, from table 5.1, TBDY
For calculation of esuv_nominal and yv, shv,ftv,fyv, it is considered
characteristic value fsyv = fsv/1.2, from table 5.1, TBDY.
y1, sh1,ft1,fy1, are also multiplied by  $\text{Min}(1, 1.25 \cdot (lb/ld)^{2/3})$ , from 10.3.5, ASCE 41-17.
with fsv = (fs,jacket*Asl,mid,jacket + fs,mid*Asl,mid,core)/Asl,mid = 752.4941
with Esv = (Es,jacket*Asl,mid,jacket + Es,mid*Asl,mid,core)/Asl,mid = 200000.00
1 = Asl,ten/(b*d)*(fs1/fc) = 0.05777595
2 = Asl,com/(b*d)*(fs2/fc) = 0.09216477
v = Asl,mid/(b*d)*(fsv/fc) = 0.09996047
and confined core properties:
b = 890.00
d = 677.00
d' = 13.00
fcc (5A.2, TBDY) = 30.00
cc (5A.5, TBDY) = 0.002
c = confinement factor = 1.00
1 = Asl,ten/(b*d)*(fs1/fc) = 0.06440379
2 = Asl,com/(b*d)*(fs2/fc) = 0.10273757
v = Asl,mid/(b*d)*(fsv/fc) = 0.11142757

```


Case/Assumption: Unconfined full section - Steel rupture
' satisfies Eq. (4.3)

--->
 $v < v_{s,y2}$ - LHS eq.(4.5) is not satisfied
--->
 $v < v_{s,c}$ - RHS eq.(4.5) is satisfied
--->
 $s_u(4.8) = 0.15115045$
 $M_u = M_{Rc}(4.15) = 2.0419E+009$
 $u = s_u(4.1) = 5.3321191E-005$

Calculation of ratio I_b/I_d

Adequate Lap Length: $I_b/I_d \geq 1$

Calculation of M_{u1} -

Calculation of ultimate curvature u according to 4.1, Biskinis/Fardis 2013:
 $u = 6.8287974E-005$
 $M_u = 2.1636E+009$

with full section properties:

$b = 450.00$
 $d = 707.00$
 $d' = 43.00$
 $v = 0.00217843$
 $N = 20792.05$
 $f_c = 30.00$
 $\alpha(5A.5, TBDY) = 0.002$
Final value of α : $\alpha^* = \text{shear_factor} * \text{Max}(\alpha_c, \alpha) = 0.00832321$
The Shear_factor is considered equal to 1 (pure moment strength)
From (5.4b), TBDY: $\alpha_c = 0.00832321$
 $w_e(5.4c) = 0.01453958$
 $\alpha_{se}((5.4d), TBDY) = (\alpha_{se1} * A_{ext} + \alpha_{se2} * A_{int}) / A_{sec} = 0.53375773$
 $\alpha_{se1} = \text{Max}(((A_{conf,max1} - A_{noConf1}) / A_{conf,max1}) * (A_{conf,min1} / A_{conf,max1}), 0) = 0.53375773$
The definitions of A_{noConf} , $A_{conf,min}$ and $A_{conf,max}$ are derived from generalization of the rectangular sections confinement, which is expressed by (5.4d).
The generalization is done according to Mander, J., Priestley, M., and Park, R. (1988) "Theoretical Stress-Strain Model for Confined Concrete."
J. Struct. Eng., 10.1061/(ASCE)0733-9445(1988)114:8(1804), 1804-1826.
 $A_{conf,max1} = 464100.00$ is the confined core area at levels of member with hoops and is calculated as the area of core enclosed by the center lines of the external perimeter hoops.
 $A_{conf,min1} = 395025.00$ is the confined core area at midway between the levels of hoops and is calculated by reducing all the dimensions of the area $A_{conf,max1}$ by a length equal to half the clear spacing between external hoops.
 $A_{noConf1} = 173066.667$ is the unconfined external core area which is equal to $b_i^2/6$ as defined at (A.2).
 $\alpha_{se2} (\geq \alpha_{se1}) = \text{Max}(((A_{conf,max2} - A_{noConf2}) / A_{conf,max2}) * (A_{conf,min2} / A_{conf,max2}), 0) = 0.53375773$
The definitions of A_{noConf} , $A_{conf,min}$ and $A_{conf,max}$ are derived from generalization of the rectangular sections confinement, which is expressed by (5.4d).
The generalization is done according to Mander, J., Priestley, M., and Park, R. (1988) "Theoretical Stress-Strain Model for Confined Concrete."
J. Struct. Eng., 10.1061/(ASCE)0733-9445(1988)114:8(1804), 1804-1826.
 $A_{conf,max2} = 252164.00$ is the confined core area at levels of member with hoops and is calculated as the area of core enclosed by the center lines of the internal perimeter hoops.
 $A_{conf,min2} = 111441.00$ is the confined core area at midway between the levels of hoops and is calculated by reducing all the dimensions of the area $A_{conf,max2}$ by a length equal to half the clear spacing between internal hoops.
 $A_{noConf2} = 110709.333$ is the unconfined internal core area which is equal to $b_i^2/6$ as defined at (A.2).
 $p_{sh,min} * F_{ywe} = \text{Min}(p_{sh,x} * F_{ywe}, p_{sh,y} * F_{ywe}) = 2.724$
Expression (5.4d) for $p_{sh,min} * F_{ywe}$ has been multiplied by 0.3 according to 15.7.1.3 for members without earthquake detailing (90° closed stirrups)

$psh_x * Fywe = psh1 * Fywe1 + ps2 * Fywe2 = 2.724$
 $psh1 \text{ ((5.4d), TBDY)} = Lstir1 * Astir1 / (Asec * s1) = 0.00301593$
 $Lstir1 \text{ (Length of stirrups along Y)} = 2160.00$
 $Astir1 \text{ (stirrups area)} = 78.53982$
 $psh2 \text{ (5.4d)} = Lstir2 * Astir2 / (Asec * s2) = 0.00056047$
 $Lstir2 \text{ (Length of stirrups along Y)} = 1568.00$
 $Astir2 \text{ (stirrups area)} = 50.26548$

$psh_y * Fywe = psh1 * Fywe1 + ps2 * Fywe2 = 3.25416$
 $psh1 \text{ ((5.4d), TBDY)} = Lstir1 * Astir1 / (Asec * s1) = 0.00357443$
 $Lstir1 \text{ (Length of stirrups along X)} = 2560.00$
 $Astir1 \text{ (stirrups area)} = 78.53982$
 $psh2 \text{ ((5.4d), TBDY)} = Lstir2 * Astir2 / (Asec * s2) = 0.00070345$
 $Lstir2 \text{ (Length of stirrups along X)} = 1968.00$
 $Astir2 \text{ (stirrups area)} = 50.26548$

$Asec = 562500.00$
 $s1 = 100.00$
 $s2 = 250.00$
 $fywe1 = 781.25$
 $fywe2 = 656.25$
 $fce = 30.00$

From ((5.A5), TBDY), TBDY: $cc = 0.002$
 $c = \text{confinement factor} = 1.00$

$y1 = 0.0025$
 $sh1 = 0.008$
 $ft1 = 900.1904$
 $fy1 = 750.1586$
 $su1 = 0.032$

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
 and also multiplied by the shear_factor according to 15.7.1.4, with
 $Shear_factor = 1.00$
 $lo/lou, min = lb/ld = 1.00$

$su1 = 0.4 * esu1_nominal \text{ ((5.5), TBDY)} = 0.032$

From table 5A.1, TBDY: $esu1_nominal = 0.08$,

For calculation of $esu1_nominal$ and $y1, sh1, ft1, fy1$, it is considered
 characteristic value $fsy1 = fs1/1.2$, from table 5.1, TBDY.

$y1, sh1, ft1, fy1$, are also multiplied by $\text{Min}(1, 1.25 * (lb/ld)^{2/3})$, from 10.3.5, ASCE 41-17.

with $fs1 = (fs_jacket * Asl, ten, jacket + fs_core * Asl, ten, core) / Asl, ten = 750.1586$

with $Es1 = (Es_jacket * Asl, ten, jacket + Es_core * Asl, ten, core) / Asl, ten = 200000.00$

$y2 = 0.0025$
 $sh2 = 0.008$
 $ft2 = 907.50$
 $fy2 = 756.25$
 $su2 = 0.032$

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
 and also multiplied by the shear_factor according to 15.7.1.4, with
 $Shear_factor = 1.00$

$lo/lou, min = lb/lb, min = 1.00$

$su2 = 0.4 * esu2_nominal \text{ ((5.5), TBDY)} = 0.032$

From table 5A.1, TBDY: $esu2_nominal = 0.08$,

For calculation of $esu2_nominal$ and $y2, sh2, ft2, fy2$, it is considered
 characteristic value $fsy2 = fs2/1.2$, from table 5.1, TBDY.

$y1, sh1, ft1, fy1$, are also multiplied by $\text{Min}(1, 1.25 * (lb/ld)^{2/3})$, from 10.3.5, ASCE 41-17.

with $fs2 = (fs_jacket * Asl, com, jacket + fs_core * Asl, com, core) / Asl, com = 756.25$

with $Es2 = (Es_jacket * Asl, com, jacket + Es_core * Asl, com, core) / Asl, com = 200000.00$

$yv = 0.0025$
 $shv = 0.008$
 $ftv = 902.993$
 $fyv = 752.4941$
 $suv = 0.032$

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
 and also multiplied by the shear_factor according to 15.7.1.4, with
 $Shear_factor = 1.00$

$lo/lou, min = lb/ld = 1.00$

$suv = 0.4 * esuv_nominal \text{ ((5.5), TBDY)} = 0.032$

From table 5A.1, TBDY: $esuv_nominal = 0.08$,

considering characteristic value $f_{syv} = f_{sv}/1.2$, from table 5.1, TBDY

For calculation of $e_{suv_nominal}$ and y_v , sh_v , ft_v , f_{yv} , it is considered characteristic value $f_{syv} = f_{sv}/1.2$, from table 5.1, TBDY.

y_1 , sh_1 , ft_1 , f_{y1} , are also multiplied by $\text{Min}(1, 1.25 \cdot (l_b/l_d)^{2/3})$, from 10.3.5, ASCE 41-17.

with $f_{sv} = (f_{s,jacket} \cdot A_{sl,mid,jacket} + f_{s,mid} \cdot A_{sl,mid,core}) / A_{sl,mid} = 752.4941$

with $E_{sv} = (E_{s,jacket} \cdot A_{sl,mid,jacket} + E_{s,mid} \cdot A_{sl,mid,core}) / A_{sl,mid} = 200000.00$

$1 = A_{sl,ten} / (b \cdot d) \cdot (f_{s1} / f_c) = 0.19457006$

$2 = A_{sl,com} / (b \cdot d) \cdot (f_{s2} / f_c) = 0.12197144$

$v = A_{sl,mid} / (b \cdot d) \cdot (f_{sv} / f_c) = 0.21102767$

and confined core properties:

$b = 390.00$

$d = 677.00$

$d' = 13.00$

f_{cc} (5A.2, TBDY) = 30.00

cc (5A.5, TBDY) = 0.002

c = confinement factor = 1.00

$1 = A_{sl,ten} / (b \cdot d) \cdot (f_{s1} / f_c) = 0.23445239$

$2 = A_{sl,com} / (b \cdot d) \cdot (f_{s2} / f_c) = 0.14697275$

$v = A_{sl,mid} / (b \cdot d) \cdot (f_{sv} / f_c) = 0.25428343$

Case/Assumption: Unconfined full section - Steel rupture

' satisfies Eq. (4.3)

---->

$v < v_{s,y2}$ - LHS eq.(4.5) is not satisfied

---->

$v < v_{s,c}$ - RHS eq.(4.5) is satisfied

---->

su (4.8) = 0.33719414

$Mu = MR_c$ (4.15) = 2.1636E+009

$u = su$ (4.1) = 6.8287974E-005

Calculation of ratio l_b/l_d

Adequate Lap Length: $l_b/l_d \geq 1$

Calculation of Mu_{2+}

Calculation of ultimate curvature u according to 4.1, Biskinis/Fardis 2013:

$u = 5.3321191E-005$

$Mu = 2.0419E+009$

with full section properties:

$b = 950.00$

$d = 707.00$

$d' = 43.00$

$v = 0.00103189$

$N = 20792.05$

$f_c = 30.00$

co (5A.5, TBDY) = 0.002

Final value of cu : $cu^* = \text{shear_factor} \cdot \text{Max}(cu, cc) = 0.00832321$

The Shear_factor is considered equal to 1 (pure moment strength)

From (5.4b), TBDY: $cu = 0.00832321$

we (5.4c) = 0.01453958

ase ((5.4d), TBDY) = $(ase1 \cdot A_{ext} + ase2 \cdot A_{int}) / A_{sec} = 0.53375773$

$ase1 = \text{Max}(((A_{conf,max1} - A_{noConf1}) / A_{conf,max1}) \cdot (A_{conf,min1} / A_{conf,max1}), 0) = 0.53375773$

The definitions of A_{noConf} , $A_{conf,min}$ and $A_{conf,max}$ are derived from generalization of the rectangular sections confinement, which is expressed by (5.4d).

The generalization is done according to Mander, J., Priestley, M., and Park, R. (1988)

"Theoretical Stress-Strain Model for Confined Concrete."

J. Struct. Eng., 10.1061/(ASCE)0733-9445(1988)114:8(1804), 1804-1826.

$A_{conf,max1} = 464100.00$ is the confined core area at levels of member with hoops and

is calculated as the area of core enclosed by the center lines of the external perimeter hoops.

$A_{conf,min1} = 395025.00$ is the confined core area at midway between the levels of hoops and

is calculated by reducing all the dimensions of the area Aconf,max1 by a length equal to half the clear spacing between external hoops.

AnoConf1 = 173066.667 is the unconfined external core area which is equal to $b_i^2/6$ as defined at (A.2).
 $ase2 (>=ase1) = \text{Max}(((Aconf,max2-AnoConf2)/Aconf,max2)*(Aconf,min2/Aconf,max2),0) = 0.53375773$

The definitions of AnoConf, Aconf,min and Aconf,max are derived from generalization of the rectangular sections confinement, which is expressed by (5.4d).

The generalization is done according to Mander, J., Priestley, M., and Park, R. (1988)

"Theoretical Stress-Strain Model for Confined Concrete."

J. Struct. Eng., 10.1061/(ASCE)0733-9445(1988)114:8(1804), 1804-1826.

Aconf,max2 = 252164.00 is the confined core area at levels of member with hoops and

is calculated as the area of core enclosed by the center lines of the internal perimeter hoops.

Aconf,min2 = 111441.00 is the confined core area at midway between the levels of hoops and

is calculated by reducing all the dimensions of the area Aconf,max2 by a length equal to half the clear spacing between internal hoops.

AnoConf2 = 110709.333 is the unconfined internal core area which is equal to $b_i^2/6$ as defined at (A.2).

$psh,min*Fywe = \text{Min}(psh,x*Fywe, psh,y*Fywe) = 2.724$

Expression (5.4d) for $psh,min*Fywe$ has been multiplied by 0.3 according to 15.7.1.3 for members without earthquake detailing (90° closed stirrups)

$psh_x*Fywe = psh1*Fywe1 + ps2*Fywe2 = 2.724$

$psh1 ((5.4d), TBDY) = Lstir1*Astir1/(Asec*s1) = 0.00301593$

Lstir1 (Length of stirrups along Y) = 2160.00

Astir1 (stirrups area) = 78.53982

$psh2 ((5.4d)) = Lstir2*Astir2/(Asec*s2) = 0.00056047$

Lstir2 (Length of stirrups along Y) = 1568.00

Astir2 (stirrups area) = 50.26548

$psh_y*Fywe = psh1*Fywe1 + ps2*Fywe2 = 3.25416$

$psh1 ((5.4d), TBDY) = Lstir1*Astir1/(Asec*s1) = 0.00357443$

Lstir1 (Length of stirrups along X) = 2560.00

Astir1 (stirrups area) = 78.53982

$psh2 ((5.4d), TBDY) = Lstir2*Astir2/(Asec*s2) = 0.00070345$

Lstir2 (Length of stirrups along X) = 1968.00

Astir2 (stirrups area) = 50.26548

Asec = 562500.00

s1 = 100.00

s2 = 250.00

fywe1 = 781.25

fywe2 = 656.25

fce = 30.00

From ((5.A5), TBDY), TBDY: cc = 0.002

c = confinement factor = 1.00

y1 = 0.0025

sh1 = 0.008

ft1 = 907.50

fy1 = 756.25

su1 = 0.032

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor and also multiplied by the shear_factor according to 15.7.1.4, with Shear_factor = 1.00

$lo/lou,min = lb/ld = 1.00$

$su1 = 0.4*esu1_nominal ((5.5), TBDY) = 0.032$

From table 5A.1, TBDY: esu1_nominal = 0.08,

For calculation of esu1_nominal and y1, sh1, ft1, fy1, it is considered characteristic value $fsy1 = fs1/1.2$, from table 5.1, TBDY.

y1, sh1, ft1, fy1, are also multiplied by $\text{Min}(1, 1.25*(lb/ld)^{2/3})$, from 10.3.5, ASCE 41-17.

with $fs1 = (fs,jacket*Asl,ten,jacket + fs,core*Asl,ten,core)/Asl,ten = 756.25$

with $Es1 = (Es,jacket*Asl,ten,jacket + Es,core*Asl,ten,core)/Asl,ten = 200000.00$

y2 = 0.0025

sh2 = 0.008

ft2 = 900.1904

fy2 = 750.1586

su2 = 0.032

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor and also multiplied by the shear_factor according to 15.7.1.4, with Shear_factor = 1.00

```

lo/lou,min = lb/lbmin = 1.00
su2 = 0.4*esu2,nominal ((5.5), TBDY) = 0.032
From table 5A.1, TBDY: esu2,nominal = 0.08,
For calculation of esu2,nominal and y2, sh2,ft2,fy2, it is considered
characteristic value fsy2 = fs2/1.2, from table 5.1, TBDY.
y1, sh1,ft1,fy1, are also multiplied by Min(1,1.25*(lb/ld)2/3), from 10.3.5, ASCE 41-17.
with fs2 = (fsjacket*Aslcom,jacket + fscore*Aslcom,core)/Aslcom = 750.1586
with Es2 = (Esjacket*Aslcom,jacket + Escore*Aslcom,core)/Aslcom = 200000.00
yv = 0.0025
shv = 0.008
ftv = 902.993
fyv = 752.4941
suv = 0.032
using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00
lo/lou,min = lb/ld = 1.00
suv = 0.4*esuvnominal ((5.5), TBDY) = 0.032
From table 5A.1, TBDY: esuvnominal = 0.08,
considering characteristic value fsyv = fsv/1.2, from table 5.1, TBDY
For calculation of esuvnominal and yv, shv,ftv,fyv, it is considered
characteristic value fsyv = fsv/1.2, from table 5.1, TBDY.
y1, sh1,ft1,fy1, are also multiplied by Min(1,1.25*(lb/ld)2/3), from 10.3.5, ASCE 41-17.
with fsv = (fsjacket*Aslmid,jacket + fsmid*Aslmid,core)/Aslmid = 752.4941
with Esv = (Esjacket*Aslmid,jacket + Esmid*Aslmid,core)/Aslmid = 200000.00
1 = Aslten/(b*d)*(fs1/fc) = 0.05777595
2 = Aslcom/(b*d)*(fs2/fc) = 0.09216477
v = Aslmid/(b*d)*(fsv/fc) = 0.09996047
and confined core properties:
b = 890.00
d = 677.00
d' = 13.00
fcc (5A.2, TBDY) = 30.00
cc (5A.5, TBDY) = 0.002
c = confinement factor = 1.00
1 = Aslten/(b*d)*(fs1/fc) = 0.06440379
2 = Aslcom/(b*d)*(fs2/fc) = 0.10273757
v = Aslmid/(b*d)*(fsv/fc) = 0.11142757
Case/Assumption: Unconfined full section - Steel rupture
' satisfies Eq. (4.3)
---->
v < vsy2 - LHS eq.(4.5) is not satisfied
---->
v < vsc - RHS eq.(4.5) is satisfied
---->
su (4.8) = 0.15115045
Mu = MRc (4.15) = 2.0419E+009
u = su (4.1) = 5.3321191E-005

```

Calculation of ratio lb/l_d

Adequate Lap Length: lb/l_d >= 1

Calculation of Mu₂-

Calculation of ultimate curvature u according to 4.1, Biskinis/Fardis 2013:

$$u = 6.8287974E-005$$

$$Mu = 2.1636E+009$$

with full section properties:

$$b = 450.00$$

$$d = 707.00$$

$d' = 43.00$
 $v = 0.00217843$
 $N = 20792.05$
 $f_c = 30.00$
 $co(5A.5, TBDY) = 0.002$
 Final value of cu : $cu^* = shear_factor * Max(cu, cc) = 0.00832321$
 The Shear_factor is considered equal to 1 (pure moment strength)
 From (5.4b), TBDY: $cu = 0.00832321$
 $we(5.4c) = 0.01453958$
 $ase((5.4d), TBDY) = (ase1 * A_{ext} + ase2 * A_{int}) / A_{sec} = 0.53375773$
 $ase1 = Max(((A_{conf,max1} - A_{noConf1}) / A_{conf,max1}) * (A_{conf,min1} / A_{conf,max1}), 0) = 0.53375773$
 The definitions of A_{noConf} , $A_{conf,min}$ and $A_{conf,max}$ are derived from generalization of the rectangular sections confinement, which is expressed by (5.4d).
 The generalization is done according to Mander, J., Priestley, M., and Park, R. (1988) "Theoretical Stress-Strain Model for Confined Concrete."
 J. Struct. Eng., 10.1061/(ASCE)0733-9445(1988)114:8(1804), 1804-1826.
 $A_{conf,max1} = 464100.00$ is the confined core area at levels of member with hoops and is calculated as the area of core enclosed by the center lines of the external perimeter hoops.
 $A_{conf,min1} = 395025.00$ is the confined core area at midway between the levels of hoops and is calculated by reducing all the dimensions of the area $A_{conf,max1}$ by a length equal to half the clear spacing between external hoops.
 $A_{noConf1} = 173066.667$ is the unconfined external core area which is equal to $b_i^2/6$ as defined at (A.2).
 $ase2 (>= ase1) = Max(((A_{conf,max2} - A_{noConf2}) / A_{conf,max2}) * (A_{conf,min2} / A_{conf,max2}), 0) = 0.53375773$
 The definitions of A_{noConf} , $A_{conf,min}$ and $A_{conf,max}$ are derived from generalization of the rectangular sections confinement, which is expressed by (5.4d).
 The generalization is done according to Mander, J., Priestley, M., and Park, R. (1988) "Theoretical Stress-Strain Model for Confined Concrete."
 J. Struct. Eng., 10.1061/(ASCE)0733-9445(1988)114:8(1804), 1804-1826.
 $A_{conf,max2} = 252164.00$ is the confined core area at levels of member with hoops and is calculated as the area of core enclosed by the center lines of the internal perimeter hoops.
 $A_{conf,min2} = 111441.00$ is the confined core area at midway between the levels of hoops and is calculated by reducing all the dimensions of the area $A_{conf,max2}$ by a length equal to half the clear spacing between internal hoops.
 $A_{noConf2} = 110709.333$ is the unconfined internal core area which is equal to $b_i^2/6$ as defined at (A.2).
 $psh,min * F_{ywe} = Min(psh,x * F_{ywe}, psh,y * F_{ywe}) = 2.724$
 Expression (5.4d) for $psh,min * F_{ywe}$ has been multiplied by 0.3 according to 15.7.1.3 for members without earthquake detailing (90° closed stirrups)

$psh,x * F_{ywe} = psh1 * F_{ywe1} + ps2 * F_{ywe2} = 2.724$
 $psh1((5.4d), TBDY) = L_{stir1} * A_{stir1} / (A_{sec} * s1) = 0.00301593$
 L_{stir1} (Length of stirrups along Y) = 2160.00
 A_{stir1} (stirrups area) = 78.53982
 $psh2(5.4d) = L_{stir2} * A_{stir2} / (A_{sec} * s2) = 0.00056047$
 L_{stir2} (Length of stirrups along Y) = 1568.00
 A_{stir2} (stirrups area) = 50.26548

$psh,y * F_{ywe} = psh1 * F_{ywe1} + ps2 * F_{ywe2} = 3.25416$
 $psh1((5.4d), TBDY) = L_{stir1} * A_{stir1} / (A_{sec} * s1) = 0.00357443$
 L_{stir1} (Length of stirrups along X) = 2560.00
 A_{stir1} (stirrups area) = 78.53982
 $psh2((5.4d), TBDY) = L_{stir2} * A_{stir2} / (A_{sec} * s2) = 0.00070345$
 L_{stir2} (Length of stirrups along X) = 1968.00
 A_{stir2} (stirrups area) = 50.26548

$A_{sec} = 562500.00$
 $s1 = 100.00$
 $s2 = 250.00$
 $f_{ywe1} = 781.25$
 $f_{ywe2} = 656.25$
 $f_{ce} = 30.00$
 From ((5.A5), TBDY), TBDY: $cc = 0.002$
 c = confinement factor = 1.00
 $y1 = 0.0025$
 $sh1 = 0.008$
 $ft1 = 900.1904$
 $fy1 = 750.1586$
 $su1 = 0.032$

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
 and also multiplied by the shear_factor according to 15.7.1.4, with
 Shear_factor = 1.00
 $l_o/l_{ou,min} = l_b/l_d = 1.00$
 $su_1 = 0.4 * esu_{1,nominal} ((5.5), TBDY) = 0.032$
 From table 5A.1, TBDY: $esu_{1,nominal} = 0.08$,
 For calculation of $esu_{1,nominal}$ and y_1, sh_1, ft_1, fy_1 , it is considered
 characteristic value $fsy_1 = fs_1/1.2$, from table 5.1, TBDY.
 y_1, sh_1, ft_1, fy_1 , are also multiplied by $Min(1, 1.25 * (l_b/l_d)^{2/3})$, from 10.3.5, ASCE 41-17.
 with $fs_1 = (fs_{jacket} * A_{sl,ten,jacket} + fs_{core} * A_{sl,ten,core}) / A_{sl,ten} = 750.1586$
 with $Es_1 = (Es_{jacket} * A_{sl,ten,jacket} + Es_{core} * A_{sl,ten,core}) / A_{sl,ten} = 200000.00$
 $y_2 = 0.0025$
 $sh_2 = 0.008$
 $ft_2 = 907.50$
 $fy_2 = 756.25$
 $su_2 = 0.032$
 using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
 and also multiplied by the shear_factor according to 15.7.1.4, with
 Shear_factor = 1.00
 $l_o/l_{ou,min} = l_b/l_{b,min} = 1.00$
 $su_2 = 0.4 * esu_{2,nominal} ((5.5), TBDY) = 0.032$
 From table 5A.1, TBDY: $esu_{2,nominal} = 0.08$,
 For calculation of $esu_{2,nominal}$ and y_2, sh_2, ft_2, fy_2 , it is considered
 characteristic value $fsy_2 = fs_2/1.2$, from table 5.1, TBDY.
 y_2, sh_2, ft_2, fy_2 , are also multiplied by $Min(1, 1.25 * (l_b/l_d)^{2/3})$, from 10.3.5, ASCE 41-17.
 with $fs_2 = (fs_{jacket} * A_{sl,com,jacket} + fs_{core} * A_{sl,com,core}) / A_{sl,com} = 756.25$
 with $Es_2 = (Es_{jacket} * A_{sl,com,jacket} + Es_{core} * A_{sl,com,core}) / A_{sl,com} = 200000.00$
 $y_v = 0.0025$
 $sh_v = 0.008$
 $ft_v = 902.993$
 $fy_v = 752.4941$
 $suv = 0.032$
 using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
 and also multiplied by the shear_factor according to 15.7.1.4, with
 Shear_factor = 1.00
 $l_o/l_{ou,min} = l_b/l_d = 1.00$
 $suv = 0.4 * esuv_{nominal} ((5.5), TBDY) = 0.032$
 From table 5A.1, TBDY: $esuv_{nominal} = 0.08$,
 considering characteristic value $fsyv = fsv/1.2$, from table 5.1, TBDY
 For calculation of $esuv_{nominal}$ and y_v, sh_v, ft_v, fy_v , it is considered
 characteristic value $fsyv = fsv/1.2$, from table 5.1, TBDY.
 y_1, sh_1, ft_1, fy_1 , are also multiplied by $Min(1, 1.25 * (l_b/l_d)^{2/3})$, from 10.3.5, ASCE 41-17.
 with $fsv = (fs_{jacket} * A_{sl,mid,jacket} + fs_{mid} * A_{sl,mid,core}) / A_{sl,mid} = 752.4941$
 with $Esv = (Es_{jacket} * A_{sl,mid,jacket} + Es_{mid} * A_{sl,mid,core}) / A_{sl,mid} = 200000.00$
 $1 = A_{sl,ten} / (b * d) * (fs_1 / fc) = 0.19457006$
 $2 = A_{sl,com} / (b * d) * (fs_2 / fc) = 0.12197144$
 $v = A_{sl,mid} / (b * d) * (fsv / fc) = 0.21102767$
 and confined core properties:
 $b = 390.00$
 $d = 677.00$
 $d' = 13.00$
 $f_{cc} (5A.2, TBDY) = 30.00$
 $cc (5A.5, TBDY) = 0.002$
 $c = \text{confinement factor} = 1.00$
 $1 = A_{sl,ten} / (b * d) * (fs_1 / fc) = 0.23445239$
 $2 = A_{sl,com} / (b * d) * (fs_2 / fc) = 0.14697275$
 $v = A_{sl,mid} / (b * d) * (fsv / fc) = 0.25428343$
 Case/Assumption: Unconfined full section - Steel rupture
 ' satisfies Eq. (4.3)
 --->
 $v < v_{s,y2}$ - LHS eq.(4.5) is not satisfied
 --->
 $v < v_{s,c}$ - RHS eq.(4.5) is satisfied
 --->
 $su (4.8) = 0.33719414$
 $Mu = MRc (4.15) = 2.1636E+009$
 $u = su (4.1) = 6.8287974E-005$

Calculation of ratio l_b/d

Adequate Lap Length: $l_b/d \geq 1$

Calculation of Shear Strength $V_r = \text{Min}(V_{r1}, V_{r2}) = 1.2916\text{E}+006$

Calculation of Shear Strength at edge 1, $V_{r1} = 1.2916\text{E}+006$

$V_{r1} = V_{\text{Col}} ((10.3), \text{ASCE } 41-17) = k_n l V_{\text{ColO}}$

$V_{\text{ColO}} = 1.2916\text{E}+006$

$k_n l = 1$ (zero step-static loading)

NOTE: In expression (10-3) ' $V_s = A_v f_y d/s$ ' is replaced by ' $V_s + f V_f$ ' where V_f is the contribution of FRPs (11.3), ACI 440).

$= 1$ (normal-weight concrete)

Mean concrete strength: $f_c' = (f_c'_{\text{jacket}} \text{Area}_{\text{jacket}} + f_c'_{\text{core}} \text{Area}_{\text{core}}) / \text{Area}_{\text{section}} = 27.20$, but $f_c'^{0.5} \leq 8.3$ MPa (22.5.3.1, ACI 318-14)

$M/V_d = 2.00$

$\mu_u = 5174.584$

$V_u = 8.5087964\text{E}-020$

$d = 0.8 \cdot h = 600.00$

$N_u = 20792.05$

$A_g = 337500.00$

From (11.5.4.8), ACI 318-14: $V_s = V_{s,\text{jacket}} + V_{s,\text{core}} = 1.0354\text{E}+006$

where:

$V_{s,\text{jacket}} = V_{s,j1} + V_{s,j2} = 942477.796$

$V_{s,j1} = 589048.623$ is calculated for section web jacket, with:

$d = 600.00$

$A_v = 157079.633$

$f_y = 625.00$

$s = 100.00$

$V_{s,j1}$ is multiplied by $\text{Col},j1 = 1.00$

$s/d = 0.16666667$

$V_{s,j2} = 353429.174$ is calculated for section flange jacket, with:

$d = 360.00$

$A_v = 157079.633$

$f_y = 625.00$

$s = 100.00$

$V_{s,j2}$ is multiplied by $\text{Col},j2 = 1.00$

$s/d = 0.27777778$

$V_{s,\text{core}} = V_{s,c1} + V_{s,c2} = 92890.612$

$V_{s,c1} = 92890.612$ is calculated for section web core, with:

$d = 440.00$

$A_v = 100530.965$

$f_y = 525.00$

$s = 250.00$

$V_{s,c1}$ is multiplied by $\text{Col},c1 = 1.00$

$s/d = 0.56818182$

$V_{s,c2} = 0.00$ is calculated for section flange core, with:

$d = 200.00$

$A_v = 100530.965$

$f_y = 525.00$

$s = 250.00$

$V_{s,c2}$ is multiplied by $\text{Col},c2 = 0.00$

$s/d = 1.25$

$V_f ((11-3)-(11.4), \text{ACI } 440) = 0.00$

From (11-11), ACI 440: $V_s + V_f \leq 935437.922$

$b_w = 450.00$

Calculation of Shear Strength at edge 2, $V_{r2} = 1.2916\text{E}+006$

$V_{r2} = V_{\text{Col}} ((10.3), \text{ASCE } 41-17) = k_n l V_{\text{ColO}}$

VColO = 1.2916E+006
knl = 1 (zero step-static loading)

NOTE: In expression (10-3) ' $V_s = A_v \cdot f_y \cdot d / s$ ' is replaced by ' $V_s + f \cdot V_f$ '
where V_f is the contribution of FRPs (11.3), ACI 440).

= 1 (normal-weight concrete)
Mean concrete strength: $f_c' = (f_c'_{\text{jacket}} \cdot \text{Area}_{\text{jacket}} + f_c'_{\text{core}} \cdot \text{Area}_{\text{core}}) / \text{Area}_{\text{section}} = 27.20$, but $f_c'^{0.5} \leq 8.3$
MPa (22.5.3.1, ACI 318-14)
 $M/Vd = 2.00$
 $\mu_u = 5174.584$
 $V_u = 8.5087964E-020$
 $d = 0.8 \cdot h = 600.00$
 $N_u = 20792.05$
 $A_g = 337500.00$
From (11.5.4.8), ACI 318-14: $V_s = V_{s,\text{jacket}} + V_{s,\text{core}} = 1.0354E+006$
where:
 $V_{s,\text{jacket}} = V_{s,j1} + V_{s,j2} = 942477.796$
 $V_{s,j1} = 589048.623$ is calculated for section web jacket, with:
 $d = 600.00$
 $A_v = 157079.633$
 $f_y = 625.00$
 $s = 100.00$
 $V_{s,j1}$ is multiplied by $\text{Col},j1 = 1.00$
 $s/d = 0.16666667$
 $V_{s,j2} = 353429.174$ is calculated for section flange jacket, with:
 $d = 360.00$
 $A_v = 157079.633$
 $f_y = 625.00$
 $s = 100.00$
 $V_{s,j2}$ is multiplied by $\text{Col},j2 = 1.00$
 $s/d = 0.27777778$
 $V_{s,\text{core}} = V_{s,c1} + V_{s,c2} = 92890.612$
 $V_{s,c1} = 92890.612$ is calculated for section web core, with:
 $d = 440.00$
 $A_v = 100530.965$
 $f_y = 525.00$
 $s = 250.00$
 $V_{s,c1}$ is multiplied by $\text{Col},c1 = 1.00$
 $s/d = 0.56818182$
 $V_{s,c2} = 0.00$ is calculated for section flange core, with:
 $d = 200.00$
 $A_v = 100530.965$
 $f_y = 525.00$
 $s = 250.00$
 $V_{s,c2}$ is multiplied by $\text{Col},c2 = 0.00$
 $s/d = 1.25$
 $V_f ((11-3)-(11.4), \text{ACI } 440) = 0.00$
From (11-11), ACI 440: $V_s + V_f \leq 935437.922$
 $b_w = 450.00$

End Of Calculation of Shear Capacity ratio for element: column JTC1 of floor 1
At local axis: 3

Start Of Calculation of Shear Capacity ratio for element: column JTC1 of floor 1
At Shear local axis: 2
(Bending local axis: 3)
Section Type: rcjtcs

Constant Properties

Knowledge Factor, $\phi = 0.80$
Mean strength values are used for both shear and moment calculations.

Consequently:

Jacket

New material of Secondary Member: Concrete Strength, $f_c = f_{cm} = 30.00$

New material of Secondary Member: Steel Strength, $f_s = f_{sm} = 625.00$

Concrete Elasticity, $E_c = 25742.96$

Steel Elasticity, $E_s = 200000.00$

Existing Column

Existing material of Secondary Member: Concrete Strength, $f_c = f_{cm} = 24.00$

Existing material of Secondary Member: Steel Strength, $f_s = f_{sm} = 525.00$

Concrete Elasticity, $E_c = 23025.204$

Steel Elasticity, $E_s = 200000.00$

#####

Note: Especially for the calculation of moment strengths,
the above steel re-bar strengths are multiplied by 1.25 according to R18.6.5, ACI 318-14

Jacket

New material: Steel Strength, $f_s = 1.25 \cdot f_{sm} = 781.25$

Existing Column

Existing material: Steel Strength, $f_s = 1.25 \cdot f_{sm} = 656.25$

#####

Max Height, $H_{max} = 750.00$

Min Height, $H_{min} = 450.00$

Max Width, $W_{max} = 950.00$

Min Width, $W_{min} = 450.00$

Eccentricity, $Ecc = 250.00$

Jacket Thickness, $t_j = 100.00$

Cover Thickness, $c = 25.00$

Mean Confinement Factor overall section = 1.00

Element Length, $L = 3000.00$

Secondary Member

Smooth Bars

Ductile Steel

Without Detailing for Earthquake Resistance (including stirrups not closed at 135°)

Longitudinal Bars With Ends Lapped Starting at the End Sections

Adequate Lap Length ($l_o/l_{ou,min} \geq 1$)

No FRP Wrapping

Stepwise Properties

At local axis: 2

EDGE -A-

Shear Force, $V_a = 5.2099631E-036$

EDGE -B-

Shear Force, $V_b = -5.2099631E-036$

BOTH EDGES

Axial Force, $F = -20792.05$

Longitudinal Reinforcement Area Distribution (in 2 divisions)

-Tension: $As_t = 0.00$

-Compression: $As_c = 6691.592$

Longitudinal Reinforcement Area Distribution (in 3 divisions)

-Tension: $As_{t,ten} = 1539.38$

-Compression: $As_{c,com} = 1539.38$

-Middle: $As_{l,mid} = 3612.832$

Calculation of Shear Capacity ratio, $V_e/V_r = 1.08994$

Member Controlled by Shear ($V_e/V_r > 1$)

Calculation of Shear Demand from fig. R18.6.5, ACI 318-14 $V_e = (M_{pr1} + M_{pr2})/l_n = 1.7820E+006$

with

$M_{pr1} = \text{Max}(Mu_{1+}, Mu_{1-}) = 2.6730E+009$

$Mu_{1+} = 2.6730E+009$, is the ultimate moment strength at the edge 1 of the member in the actual moment direction which is defined for the static loading combination

$Mu_{1-} = 2.6730E+009$, is the ultimate moment strength at the edge 1 of the member in the opposite moment direction which is defined for the static loading combination

$M_{pr2} = \text{Max}(Mu_{2+}, Mu_{2-}) = 2.6730E+009$

Mu2+ = 2.6730E+009, is the ultimate moment strength at the edge 2 of the member in the actual moment direction which is defined for the the static loading combination

Mu2- = 2.6730E+009, is the ultimate moment strength at the edge 2 of the member in the opposite moment direction which is defined for the the static loading combination

Calculation of Mu1+

Calculation of ultimate curvature ϕ_u according to 4.1, Biskinis/Fardis 2013:

$$\phi_u = 4.9274896E-005$$

$$M_u = 2.6730E+009$$

with full section properties:

$$b = 450.00$$

$$d = 907.00$$

$$d' = 43.00$$

$$\nu = 0.00169807$$

$$N = 20792.05$$

$$f_c = 30.00$$

$$\phi_{co} (5A.5, TBDY) = 0.002$$

$$\text{Final value of } \phi_u: \phi_u^* = \text{shear_factor} * \text{Max}(\phi_u, \phi_{co}) = 0.00832321$$

The Shear_factor is considered equal to 1 (pure moment strength)

$$\text{From (5.4b), TBDY: } \phi_u = 0.00832321$$

$$\phi_{we} (5.4c) = 0.01453958$$

$$\phi_{ase} ((5.4d), TBDY) = (\phi_{ase1} * A_{ext} + \phi_{ase2} * A_{int}) / A_{sec} = 0.53375773$$

$$\phi_{ase1} = \text{Max}(((A_{conf,max1} - A_{noConf1}) / A_{conf,max1}) * (A_{conf,min1} / A_{conf,max1}), 0) = 0.53375773$$

The definitions of A_{noConf} , $A_{conf,min}$ and $A_{conf,max}$ are derived from generalization of the rectangular sections confinement, which is expressed by (5.4d).

The generalization is done according to Mander, J., Priestley, M., and Park, R. (1988)

"Theoretical Stress-Strain Model for Confined Concrete."

J. Struct. Eng., 10.1061/(ASCE)0733-9445(1988)114:8(1804), 1804-1826.

$A_{conf,max1} = 464100.00$ is the confined core area at levels of member with hoops and

is calculated as the area of core enclosed by the center lines of the external perimeter hoops.

$A_{conf,min1} = 395025.00$ is the confined core area at midway between the levels of hoops and

is calculated by reducing all the dimensions of the area $A_{conf,max1}$ by a length

equal to half the clear spacing between external hoops.

$A_{noConf1} = 173066.667$ is the unconfined external core area which is equal to $b_i^2/6$ as defined at (A.2).

$$\phi_{ase2} (> \phi_{ase1}) = \text{Max}(((A_{conf,max2} - A_{noConf2}) / A_{conf,max2}) * (A_{conf,min2} / A_{conf,max2}), 0) = 0.53375773$$

The definitions of A_{noConf} , $A_{conf,min}$ and $A_{conf,max}$ are derived from generalization of the rectangular sections confinement, which is expressed by (5.4d).

The generalization is done according to Mander, J., Priestley, M., and Park, R. (1988)

"Theoretical Stress-Strain Model for Confined Concrete."

J. Struct. Eng., 10.1061/(ASCE)0733-9445(1988)114:8(1804), 1804-1826.

$A_{conf,max2} = 252164.00$ is the confined core area at levels of member with hoops and

is calculated as the area of core enclosed by the center lines of the internal perimeter hoops.

$A_{conf,min2} = 111441.00$ is the confined core area at midway between the levels of hoops and

is calculated by reducing all the dimensions of the area $A_{conf,max2}$ by a length

equal to half the clear spacing between internal hoops.

$A_{noConf2} = 110709.333$ is the unconfined internal core area which is equal to $b_i^2/6$ as defined at (A.2).

$$\phi_{psh,min} * F_{ywe} = \text{Min}(\phi_{psh,x} * F_{ywe}, \phi_{psh,y} * F_{ywe}) = 2.724$$

Expression (5.4d) for $\phi_{psh,min} * F_{ywe}$ has been multiplied by 0.3 according to 15.7.1.3 for members without earthquake detailing (90° closed stirrups)

$$\phi_{psh,x} * F_{ywe} = \phi_{psh1} * F_{ywe1} + \phi_{psh2} * F_{ywe2} = 2.724$$

$$\phi_{psh1} ((5.4d), TBDY) = L_{stir1} * A_{stir1} / (A_{sec} * s_1) = 0.00301593$$

$$L_{stir1} (\text{Length of stirrups along Y}) = 2160.00$$

$$A_{stir1} (\text{stirrups area}) = 78.53982$$

$$\phi_{psh2} (5.4d) = L_{stir2} * A_{stir2} / (A_{sec} * s_2) = 0.00056047$$

$$L_{stir2} (\text{Length of stirrups along Y}) = 1568.00$$

$$A_{stir2} (\text{stirrups area}) = 50.26548$$

$$\phi_{psh,y} * F_{ywe} = \phi_{psh1} * F_{ywe1} + \phi_{psh2} * F_{ywe2} = 3.25416$$

$$\phi_{psh1} ((5.4d), TBDY) = L_{stir1} * A_{stir1} / (A_{sec} * s_1) = 0.00357443$$

$$L_{stir1} (\text{Length of stirrups along X}) = 2560.00$$

$$A_{stir1} (\text{stirrups area}) = 78.53982$$

$psh2 ((5.4d), TBDY) = Lstir2 * Astir2 / (Asec * s2) = 0.00070345$
 $Lstir2 (\text{Length of stirrups along X}) = 1968.00$
 $Astir2 (\text{stirrups area}) = 50.26548$

Asec = 562500.00

s1 = 100.00

s2 = 250.00

fywe1 = 781.25

fywe2 = 656.25

fce = 30.00

From ((5.A5), TBDY), TBDY: cc = 0.002

c = confinement factor = 1.00

y1 = 0.0025

sh1 = 0.008

ft1 = 907.50

fy1 = 756.25

su1 = 0.032

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00

lo/lou,min = lb/ld = 1.00

su1 = 0.4*esu1_nominal ((5.5), TBDY) = 0.032

From table 5A.1, TBDY: esu1_nominal = 0.08,

For calculation of esu1_nominal and y1, sh1,ft1,fy1, it is considered
characteristic value fsy1 = fs1/1.2, from table 5.1, TBDY.

y1, sh1,ft1,fy1, are also multiplied by $\text{Min}(1, 1.25 * (lb/ld)^{2/3})$, from 10.3.5, ASCE 41-17.

with fs1 = (fs,jacket*Asl,ten,jacket + fs,core*Asl,ten,core)/Asl,ten = 756.25

with Es1 = (Es,jacket*Asl,ten,jacket + Es,core*Asl,ten,core)/Asl,ten = 200000.00

y2 = 0.0025

sh2 = 0.008

ft2 = 907.50

fy2 = 756.25

su2 = 0.032

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00

lo/lou,min = lb/lb,min = 1.00

su2 = 0.4*esu2_nominal ((5.5), TBDY) = 0.032

From table 5A.1, TBDY: esu2_nominal = 0.08,

For calculation of esu2_nominal and y2, sh2,ft2,fy2, it is considered
characteristic value fsy2 = fs2/1.2, from table 5.1, TBDY.

y1, sh1,ft1,fy1, are also multiplied by $\text{Min}(1, 1.25 * (lb/ld)^{2/3})$, from 10.3.5, ASCE 41-17.

with fs2 = (fs,jacket*Asl,com,jacket + fs,core*Asl,com,core)/Asl,com = 756.25

with Es2 = (Es,jacket*Asl,com,jacket + Es,core*Asl,com,core)/Asl,com = 200000.00

yv = 0.0025

shv = 0.008

ftv = 899.1522

fyv = 749.2935

suv = 0.032

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00

lo/lou,min = lb/ld = 1.00

suv = 0.4*esuv_nominal ((5.5), TBDY) = 0.032

From table 5A.1, TBDY: esuv_nominal = 0.08,

considering characteristic value fsyv = fsv/1.2, from table 5.1, TBDY
For calculation of esuv_nominal and yv, shv,ftv,fyv, it is considered

characteristic value fsyv = fsv/1.2, from table 5.1, TBDY.

y1, sh1,ft1,fy1, are also multiplied by $\text{Min}(1, 1.25 * (lb/ld)^{2/3})$, from 10.3.5, ASCE 41-17.

with fsv = (fs,jacket*Asl,mid,jacket + fs,mid*Asl,mid,core)/Asl,mid = 749.2935

with Esv = (Es,jacket*Asl,mid,jacket + Es,mid*Asl,mid,core)/Asl,mid = 200000.00

1 = Asl,ten/(b*d)*(fs1/fc) = 0.09507586

2 = Asl,com/(b*d)*(fs2/fc) = 0.09507586

v = Asl,mid/(b*d)*(fsv/fc) = 0.22108466

and confined core properties:

b = 390.00

d = 877.00

```

d' = 13.00
fcc (5A.2, TBDY) = 30.00
cc (5A.5, TBDY) = 0.002
c = confinement factor = 1.00
1 = Asl,ten/(b*d)*(fs1/fc) = 0.11345559
2 = Asl,com/(b*d)*(fs2/fc) = 0.11345559
v = Asl,mid/(b*d)*(fsv/fc) = 0.26382395
Case/Assumption: Unconfined full section - Steel rupture
'satisfies Eq. (4.3)
--->
v < vs,y2 - LHS eq.(4.5) is not satisfied
--->
v < vs,c - RHS eq.(4.5) is satisfied
--->
su (4.8) = 0.28399348
Mu = MRc (4.15) = 2.6730E+009
u = su (4.1) = 4.9274896E-005

```

Calculation of ratio lb/ld

Adequate Lap Length: lb/ld >= 1

Calculation of Mu1-

Calculation of ultimate curvature u according to 4.1, Biskinis/Fardis 2013:

```

u = 4.9274896E-005
Mu = 2.6730E+009

```

with full section properties:

```

b = 450.00
d = 907.00
d' = 43.00
v = 0.00169807
N = 20792.05
fc = 30.00
co (5A.5, TBDY) = 0.002
Final value of cu: cu* = shear_factor * Max( cu, cc) = 0.00832321
The Shear_factor is considered equal to 1 (pure moment strength)
From (5.4b), TBDY: cu = 0.00832321
we (5.4c) = 0.01453958
ase ((5.4d), TBDY) = (ase1*Aext+ase2*Aint)/Asec = 0.53375773
ase1 = Max(((Aconf,max1-AnoConf1)/Aconf,max1)*(Aconf,min1/Aconf,max1),0) = 0.53375773
The definitions of AnoConf, Aconf,min and Aconf,max are derived from generalization
of the rectangular sections confinement, which is expressed by (5.4d).
The generalization is done according to Mander, J., Priestley, M., and Park, R. (1988)
"Theoretical Stress-Strain Model for Confined Concrete."
J. Struct. Eng., 10.1061/(ASCE)0733-9445(1988)114:8(1804), 1804-1826.
Aconf,max1 = 464100.00 is the confined core area at levels of member with hoops and
is calculated as the area of core enclosed by the center lines of the external perimeter hoops.
Aconf,min1 = 395025.00 is the confined core area at midway between the levels of hoops and
is calculated by reducing all the dimensions of the area Aconf,max1 by a length
equal to half the clear spacing between external hoops.
AnoConf1 = 173066.667 is the unconfined external core area which is equal to bi2/6 as defined at (A.2).
ase2 (>=ase1) = Max(((Aconf,max2-AnoConf2)/Aconf,max2)*(Aconf,min2/Aconf,max2),0) = 0.53375773
The definitions of AnoConf, Aconf,min and Aconf,max are derived from generalization
of the rectangular sections confinement, which is expressed by (5.4d).
The generalization is done according to Mander, J., Priestley, M., and Park, R. (1988)
"Theoretical Stress-Strain Model for Confined Concrete."
J. Struct. Eng., 10.1061/(ASCE)0733-9445(1988)114:8(1804), 1804-1826.
Aconf,max2 = 252164.00 is the confined core area at levels of member with hoops and
is calculated as the area of core enclosed by the center lines of the internal perimeter hoops.
Aconf,min2 = 111441.00 is the confined core area at midway between the levels of hoops and

```

is calculated by reducing all the dimensions of the area Aconf,max2 by a length equal to half the clear spacing between internal hoops.

AnoConf2 = 110709.333 is the unconfined internal core area which is equal to $b_i^2/6$ as defined at (A.2).

$$psh_{min} \cdot F_{ywe} = \min(psh_x \cdot F_{ywe}, psh_y \cdot F_{ywe}) = 2.724$$

Expression (5.4d) for $psh_{min} \cdot F_{ywe}$ has been multiplied by 0.3 according to 15.7.1.3 for members without earthquake detailing (90° closed stirrups)

$$\begin{aligned} psh_x \cdot F_{ywe} &= psh1 \cdot F_{ywe1} + ps2 \cdot F_{ywe2} = 2.724 \\ psh1 \text{ ((5.4d), TBDY)} &= Lstir1 \cdot Astir1 / (Asec \cdot s1) = 0.00301593 \\ Lstir1 \text{ (Length of stirrups along Y)} &= 2160.00 \\ Astir1 \text{ (stirrups area)} &= 78.53982 \\ psh2 \text{ (5.4d)} &= Lstir2 \cdot Astir2 / (Asec \cdot s2) = 0.00056047 \\ Lstir2 \text{ (Length of stirrups along Y)} &= 1568.00 \\ Astir2 \text{ (stirrups area)} &= 50.26548 \end{aligned}$$

$$\begin{aligned} psh_y \cdot F_{ywe} &= psh1 \cdot F_{ywe1} + ps2 \cdot F_{ywe2} = 3.25416 \\ psh1 \text{ ((5.4d), TBDY)} &= Lstir1 \cdot Astir1 / (Asec \cdot s1) = 0.00357443 \\ Lstir1 \text{ (Length of stirrups along X)} &= 2560.00 \\ Astir1 \text{ (stirrups area)} &= 78.53982 \\ psh2 \text{ ((5.4d), TBDY)} &= Lstir2 \cdot Astir2 / (Asec \cdot s2) = 0.00070345 \\ Lstir2 \text{ (Length of stirrups along X)} &= 1968.00 \\ Astir2 \text{ (stirrups area)} &= 50.26548 \end{aligned}$$

$$Asec = 562500.00$$

$$s1 = 100.00$$

$$s2 = 250.00$$

$$fywe1 = 781.25$$

$$fywe2 = 656.25$$

$$fce = 30.00$$

$$\text{From ((5.A5), TBDY), TBDY: } cc = 0.002$$

$$c = \text{confinement factor} = 1.00$$

$$y1 = 0.0025$$

$$sh1 = 0.008$$

$$ft1 = 907.50$$

$$fy1 = 756.25$$

$$su1 = 0.032$$

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor and also multiplied by the shear_factor according to 15.7.1.4, with Shear_factor = 1.00

$$lo/lo_{min} = lb/lb_{min} = 1.00$$

$$su1 = 0.4 \cdot esu1_{nominal} \text{ ((5.5), TBDY)} = 0.032$$

From table 5A.1, TBDY: $esu1_{nominal} = 0.08$,

For calculation of $esu1_{nominal}$ and $y1, sh1, ft1, fy1$, it is considered characteristic value $fsy1 = fs1/1.2$, from table 5.1, TBDY.

$y1, sh1, ft1, fy1$, are also multiplied by $\min(1, 1.25 \cdot (lb/lb_{min})^{2/3})$, from 10.3.5, ASCE 41-17.

$$\text{with } fs1 = (fs_{jacket} \cdot Asl_{ten,jacket} + fs_{core} \cdot Asl_{ten,core}) / Asl_{ten} = 756.25$$

$$\text{with } Es1 = (Es_{jacket} \cdot Asl_{ten,jacket} + Es_{core} \cdot Asl_{ten,core}) / Asl_{ten} = 200000.00$$

$$y2 = 0.0025$$

$$sh2 = 0.008$$

$$ft2 = 907.50$$

$$fy2 = 756.25$$

$$su2 = 0.032$$

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor and also multiplied by the shear_factor according to 15.7.1.4, with Shear_factor = 1.00

$$lo/lo_{min} = lb/lb_{min} = 1.00$$

$$su2 = 0.4 \cdot esu2_{nominal} \text{ ((5.5), TBDY)} = 0.032$$

From table 5A.1, TBDY: $esu2_{nominal} = 0.08$,

For calculation of $esu2_{nominal}$ and $y2, sh2, ft2, fy2$, it is considered characteristic value $fsy2 = fs2/1.2$, from table 5.1, TBDY.

$y1, sh1, ft1, fy1$, are also multiplied by $\min(1, 1.25 \cdot (lb/lb_{min})^{2/3})$, from 10.3.5, ASCE 41-17.

$$\text{with } fs2 = (fs_{jacket} \cdot Asl_{com,jacket} + fs_{core} \cdot Asl_{com,core}) / Asl_{com} = 756.25$$

$$\text{with } Es2 = (Es_{jacket} \cdot Asl_{com,jacket} + Es_{core} \cdot Asl_{com,core}) / Asl_{com} = 200000.00$$

$$yv = 0.0025$$

$$shv = 0.008$$

$$ftv = 899.1522$$

$$fyv = 749.2935$$

```

suv = 0.032
using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00
lo/lou,min = lb/ld = 1.00
suv = 0.4*esuvnominal ((5.5), TBDY) = 0.032
From table 5A.1, TBDY: esuvnominal = 0.08,
considering characteristic value fsyv = fsv/1.2, from table 5.1, TBDY
For calculation of esuvnominal and yv, shv,ftv,fyv, it is considered
characteristic value fsyv = fsv/1.2, from table 5.1, TBDY.
y1, sh1,ft1,fy1, are also multiplied by Min(1,1.25*(lb/ld)^2/3), from 10.3.5, ASCE 41-17.
with fsv = (fsjacket*Aslmid,jacket + fsmid*Aslmid,core)/Aslmid = 749.2935
with Esv = (Esjacket*Aslmid,jacket + Esmid*Aslmid,core)/Aslmid = 200000.00
1 = Aslten/(b*d)*(fs1/fc) = 0.09507586
2 = Aslcom/(b*d)*(fs2/fc) = 0.09507586
v = Aslmid/(b*d)*(fsv/fc) = 0.22108466
and confined core properties:
b = 390.00
d = 877.00
d' = 13.00
fcc (5A.2, TBDY) = 30.00
cc (5A.5, TBDY) = 0.002
c = confinement factor = 1.00
1 = Aslten/(b*d)*(fs1/fc) = 0.11345559
2 = Aslcom/(b*d)*(fs2/fc) = 0.11345559
v = Aslmid/(b*d)*(fsv/fc) = 0.26382395
Case/Assumption: Unconfined full section - Steel rupture
'satisfies Eq. (4.3)
--->
v < vs,y2 - LHS eq.(4.5) is not satisfied
--->
v < vs,c - RHS eq.(4.5) is satisfied
--->
su (4.8) = 0.28399348
Mu = MRc (4.15) = 2.6730E+009
u = su (4.1) = 4.9274896E-005
-----

Calculation of ratio lb/ld
-----
Adequate Lap Length: lb/ld >= 1
-----
-----
Calculation of Mu2+
-----
-----
Calculation of ultimate curvature u according to 4.1, Biskinis/Fardis 2013:
u = 4.9274896E-005
Mu = 2.6730E+009
-----
with full section properties:
b = 450.00
d = 907.00
d' = 43.00
v = 0.00169807
N = 20792.05
fc = 30.00
co (5A.5, TBDY) = 0.002
Final value of cu: cu* = shear_factor * Max( cu, cc) = 0.00832321
The Shear_factor is considered equal to 1 (pure moment strength)
From (5.4b), TBDY: cu = 0.00832321
we (5.4c) = 0.01453958
ase ((5.4d), TBDY) = (ase1*Aext+ase2*Aint)/Asec = 0.53375773
ase1 = Max(((Aconf,max1-AnoConf1)/Aconf,max1)*(Aconf,min1/Aconf,max1),0) = 0.53375773
The definitions of AnoConf, Aconf,min and Aconf,max are derived from generalization

```

of the rectangular sections confinement, which is expressed by (5.4d).

The generalization is done according to Mander, J., Priestley, M., and Park, R. (1988)

"Theoretical Stress-Strain Model for Confined Concrete."

J. Struct. Eng., 10.1061/(ASCE)0733-9445(1988)114:8(1804), 1804-1826.

Aconf,max1 = 464100.00 is the confined core area at levels of member with hoops and

is calculated as the area of core enclosed by the center lines of the external perimeter hoops.

Aconf,min1 = 395025.00 is the confined core area at midway between the levels of hoops and

is calculated by reducing all the dimensions of the area Aconf,max1 by a length equal to half the clear spacing between external hoops.

AnoConf1 = 173066.667 is the unconfined external core area which is equal to $b_i^2/6$ as defined at (A.2).

ase2 (\geq ase1) = $\text{Max}(((A_{\text{conf,max2}} - A_{\text{noConf2}})/A_{\text{conf,max2}}) * (A_{\text{conf,min2}}/A_{\text{conf,max2}}), 0) = 0.53375773$

The definitions of AnoConf, Aconf,min and Aconf,max are derived from generalization of the rectangular sections confinement, which is expressed by (5.4d).

The generalization is done according to Mander, J., Priestley, M., and Park, R. (1988)

"Theoretical Stress-Strain Model for Confined Concrete."

J. Struct. Eng., 10.1061/(ASCE)0733-9445(1988)114:8(1804), 1804-1826.

Aconf,max2 = 252164.00 is the confined core area at levels of member with hoops and

is calculated as the area of core enclosed by the center lines of the internal perimeter hoops.

Aconf,min2 = 111441.00 is the confined core area at midway between the levels of hoops and

is calculated by reducing all the dimensions of the area Aconf,max2 by a length equal to half the clear spacing between internal hoops.

AnoConf2 = 110709.333 is the unconfined internal core area which is equal to $b_i^2/6$ as defined at (A.2).

psh,min*Fywe = $\text{Min}(psh_x * Fywe, psh_y * Fywe) = 2.724$

Expression (5.4d) for psh,min*Fywe has been multiplied by 0.3 according to 15.7.1.3 for members without earthquake detailing (90° closed stirrups)

psh_x*Fywe = psh1*Fywe1 + ps2*Fywe2 = 2.724

psh1 ((5.4d), TBDY) = $L_{\text{stir1}} * A_{\text{stir1}} / (A_{\text{sec}} * s_1) = 0.00301593$

Lstir1 (Length of stirrups along Y) = 2160.00

Astir1 (stirrups area) = 78.53982

psh2 ((5.4d)) = $L_{\text{stir2}} * A_{\text{stir2}} / (A_{\text{sec}} * s_2) = 0.00056047$

Lstir2 (Length of stirrups along Y) = 1568.00

Astir2 (stirrups area) = 50.26548

psh_y*Fywe = psh1*Fywe1 + ps2*Fywe2 = 3.25416

psh1 ((5.4d), TBDY) = $L_{\text{stir1}} * A_{\text{stir1}} / (A_{\text{sec}} * s_1) = 0.00357443$

Lstir1 (Length of stirrups along X) = 2560.00

Astir1 (stirrups area) = 78.53982

psh2 ((5.4d), TBDY) = $L_{\text{stir2}} * A_{\text{stir2}} / (A_{\text{sec}} * s_2) = 0.00070345$

Lstir2 (Length of stirrups along X) = 1968.00

Astir2 (stirrups area) = 50.26548

Asec = 562500.00

s1 = 100.00

s2 = 250.00

fywe1 = 781.25

fywe2 = 656.25

fce = 30.00

From ((5.A5), TBDY), TBDY: cc = 0.002

c = confinement factor = 1.00

y1 = 0.0025

sh1 = 0.008

ft1 = 907.50

fy1 = 756.25

su1 = 0.032

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor

and also multiplied by the shear_factor according to 15.7.1.4, with

Shear_factor = 1.00

lo/lo,min = lb/lb = 1.00

su1 = $0.4 * esu1_{\text{nominal}} ((5.5), \text{TBDY}) = 0.032$

From table 5A.1, TBDY: esu1_nominal = 0.08,

For calculation of esu1_nominal and y1, sh1, ft1, fy1, it is considered

characteristic value fsy1 = fs1/1.2, from table 5.1, TBDY.

y1, sh1, ft1, fy1, are also multiplied by $\text{Min}(1, 1.25 * (lb/lb)^{2/3})$, from 10.3.5, ASCE 41-17.

with fs1 = $(f_{s,jacket} * A_{s,ten,jacket} + f_{s,core} * A_{s,ten,core}) / A_{s,ten} = 756.25$

with Es1 = $(E_{s,jacket} * A_{s,ten,jacket} + E_{s,core} * A_{s,ten,core}) / A_{s,ten} = 200000.00$

y2 = 0.0025


```

sh2 = 0.008
ft2 = 907.50
fy2 = 756.25
su2 = 0.032
    using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
    and also multiplied by the shear_factor according to 15.7.1.4, with
    Shear_factor = 1.00
    lo/lo,min = lb/lb,min = 1.00
    su2 = 0.4*esu2_nominal ((5.5), TBDY) = 0.032
    From table 5A.1, TBDY: esu2_nominal = 0.08,
    For calculation of esu2_nominal and y2, sh2,ft2,fy2, it is considered
    characteristic value fsy2 = fs2/1.2, from table 5.1, TBDY.
    y1, sh1,ft1,fy1, are also multiplied by Min(1,1.25*(lb/lb)^ 2/3), from 10.3.5, ASCE 41-17.
    with fs2 = (fs,jacket*Asl,com,jacket + fs,core*Asl,com,core)/Asl,com = 756.25
    with Es2 = (Es,jacket*Asl,com,jacket + Es,core*Asl,com,core)/Asl,com = 200000.00
yv = 0.0025
shv = 0.008
ftv = 899.1522
fyv = 749.2935
suv = 0.032
    using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
    and also multiplied by the shear_factor according to 15.7.1.4, with
    Shear_factor = 1.00
    lo/lo,min = lb/lb = 1.00
    suv = 0.4*esuv_nominal ((5.5), TBDY) = 0.032
    From table 5A.1, TBDY: esuv_nominal = 0.08,
    considering characteristic value fsyv = fsv/1.2, from table 5.1, TBDY
    For calculation of esuv_nominal and yv, shv,ftv,fyv, it is considered
    characteristic value fsyv = fsv/1.2, from table 5.1, TBDY.
    y1, sh1,ft1,fy1, are also multiplied by Min(1,1.25*(lb/lb)^ 2/3), from 10.3.5, ASCE 41-17.
    with fsv = (fs,jacket*Asl,mid,jacket + fs,mid*Asl,mid,core)/Asl,mid = 749.2935
    with Esv = (Es,jacket*Asl,mid,jacket + Es,mid*Asl,mid,core)/Asl,mid = 200000.00
1 = Asl,ten/(b*d)*(fs1/fc) = 0.09507586
2 = Asl,com/(b*d)*(fs2/fc) = 0.09507586
v = Asl,mid/(b*d)*(fsv/fc) = 0.22108466
and confined core properties:
b = 390.00
d = 877.00
d' = 13.00
fcc (5A.2, TBDY) = 30.00
cc (5A.5, TBDY) = 0.002
c = confinement factor = 1.00
1 = Asl,ten/(b*d)*(fs1/fc) = 0.11345559
2 = Asl,com/(b*d)*(fs2/fc) = 0.11345559
v = Asl,mid/(b*d)*(fsv/fc) = 0.26382395
Case/Assumption: Unconfined full section - Steel rupture
' satisfies Eq. (4.3)
--->
v < vs,y2 - LHS eq.(4.5) is not satisfied
--->
v < vs,c - RHS eq.(4.5) is satisfied
--->
su (4.8) = 0.28399348
Mu = MRc (4.15) = 2.6730E+009
u = su (4.1) = 4.9274896E-005

```

Calculation of ratio lb/lb

Adequate Lap Length: lb/lb >= 1

Calculation of Mu2-

Calculation of ultimate curvature ϕ_u according to 4.1, Biskinis/Fardis 2013:

$$\phi_u = 4.9274896E-005$$

$$\mu = 2.6730E+009$$

with full section properties:

$$b = 450.00$$

$$d = 907.00$$

$$d' = 43.00$$

$$v = 0.00169807$$

$$N = 20792.05$$

$$f_c = 30.00$$

$$\phi_{co} (5A.5, TBDY) = 0.002$$

$$\text{Final value of } \phi_u: \phi_u^* = \text{shear_factor} * \text{Max}(\phi_u, \phi_{co}) = 0.00832321$$

The Shear_factor is considered equal to 1 (pure moment strength)

$$\text{From (5.4b), TBDY: } \phi_u = 0.00832321$$

$$\phi_{we} (5.4c) = 0.01453958$$

$$\phi_{ase} ((5.4d), TBDY) = (\phi_{ase1} * A_{ext} + \phi_{ase2} * A_{int}) / A_{sec} = 0.53375773$$

$$\phi_{ase1} = \text{Max}(((A_{conf,max1} - A_{noConf1}) / A_{conf,max1}) * (A_{conf,min1} / A_{conf,max1}), 0) = 0.53375773$$

The definitions of A_{noConf} , $A_{conf,min}$ and $A_{conf,max}$ are derived from generalization of the rectangular sections confinement, which is expressed by (5.4d).

The generalization is done according to Mander, J., Priestley, M., and Park, R. (1988)

"Theoretical Stress-Strain Model for Confined Concrete."

J. Struct. Eng., 10.1061/(ASCE)0733-9445(1988)114:8(1804), 1804-1826.

$A_{conf,max1} = 464100.00$ is the confined core area at levels of member with hoops and

is calculated as the area of core enclosed by the center lines of the external perimeter hoops.

$A_{conf,min1} = 395025.00$ is the confined core area at midway between the levels of hoops and

is calculated by reducing all the dimensions of the area $A_{conf,max1}$ by a length equal to half the clear spacing between external hoops.

$A_{noConf1} = 173066.667$ is the unconfined external core area which is equal to $b_i d_i / 6$ as defined at (A.2).

$$\phi_{ase2} (> \phi_{ase1}) = \text{Max}(((A_{conf,max2} - A_{noConf2}) / A_{conf,max2}) * (A_{conf,min2} / A_{conf,max2}), 0) = 0.53375773$$

The definitions of A_{noConf} , $A_{conf,min}$ and $A_{conf,max}$ are derived from generalization of the rectangular sections confinement, which is expressed by (5.4d).

The generalization is done according to Mander, J., Priestley, M., and Park, R. (1988)

"Theoretical Stress-Strain Model for Confined Concrete."

J. Struct. Eng., 10.1061/(ASCE)0733-9445(1988)114:8(1804), 1804-1826.

$A_{conf,max2} = 252164.00$ is the confined core area at levels of member with hoops and

is calculated as the area of core enclosed by the center lines of the internal perimeter hoops.

$A_{conf,min2} = 111441.00$ is the confined core area at midway between the levels of hoops and

is calculated by reducing all the dimensions of the area $A_{conf,max2}$ by a length equal to half the clear spacing between internal hoops.

$A_{noConf2} = 110709.333$ is the unconfined internal core area which is equal to $b_i d_i / 6$ as defined at (A.2).

$$\phi_{psh,min} * F_{ywe} = \text{Min}(\phi_{psh,x} * F_{ywe}, \phi_{psh,y} * F_{ywe}) = 2.724$$

Expression (5.4d) for $\phi_{psh,min} * F_{ywe}$ has been multiplied by 0.3 according to 15.7.1.3 for members without earthquake detailing (90° closed stirrups)

$$\phi_{psh,x} * F_{ywe} = \phi_{psh1} * F_{ywe1} + \phi_{psh2} * F_{ywe2} = 2.724$$

$$\phi_{psh1} ((5.4d), TBDY) = L_{stir1} * A_{stir1} / (A_{sec} * s1) = 0.00301593$$

$$L_{stir1} \text{ (Length of stirrups along Y)} = 2160.00$$

$$A_{stir1} \text{ (stirrups area)} = 78.53982$$

$$\phi_{psh2} (5.4d) = L_{stir2} * A_{stir2} / (A_{sec} * s2) = 0.00056047$$

$$L_{stir2} \text{ (Length of stirrups along Y)} = 1568.00$$

$$A_{stir2} \text{ (stirrups area)} = 50.26548$$

$$\phi_{psh,y} * F_{ywe} = \phi_{psh1} * F_{ywe1} + \phi_{psh2} * F_{ywe2} = 3.25416$$

$$\phi_{psh1} ((5.4d), TBDY) = L_{stir1} * A_{stir1} / (A_{sec} * s1) = 0.00357443$$

$$L_{stir1} \text{ (Length of stirrups along X)} = 2560.00$$

$$A_{stir1} \text{ (stirrups area)} = 78.53982$$

$$\phi_{psh2} ((5.4d), TBDY) = L_{stir2} * A_{stir2} / (A_{sec} * s2) = 0.00070345$$

$$L_{stir2} \text{ (Length of stirrups along X)} = 1968.00$$

$$A_{stir2} \text{ (stirrups area)} = 50.26548$$

$$A_{sec} = 562500.00$$

$$s1 = 100.00$$

$$s2 = 250.00$$

$$f_{ywe1} = 781.25$$

$$f_{ywe2} = 656.25$$

$$f_{ce} = 30.00$$

From ((5.A.5), TBDY), TBDY: $cc = 0.002$
 $c = \text{confinement factor} = 1.00$
 $y1 = 0.0025$
 $sh1 = 0.008$
 $ft1 = 907.50$
 $fy1 = 756.25$
 $su1 = 0.032$
 using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
 and also multiplied by the shear_factor according to 15.7.1.4, with
 $\text{Shear_factor} = 1.00$
 $lo/lou, \min = lb/ld = 1.00$
 $su1 = 0.4 * esu1_nominal ((5.5), TBDY) = 0.032$
 From table 5A.1, TBDY: $esu1_nominal = 0.08$,
 For calculation of $esu1_nominal$ and $y1, sh1, ft1, fy1$, it is considered
 characteristic value $fsy1 = fs1/1.2$, from table 5.1, TBDY.
 $y1, sh1, ft1, fy1$, are also multiplied by $\text{Min}(1, 1.25 * (lb/ld)^{2/3})$, from 10.3.5, ASCE 41-17.
 with $fs1 = (fs_jacket * Asl, \text{ten}, \text{jacket} + fs_core * Asl, \text{ten}, \text{core}) / Asl, \text{ten} = 756.25$
 with $Es1 = (Es_jacket * Asl, \text{ten}, \text{jacket} + Es_core * Asl, \text{ten}, \text{core}) / Asl, \text{ten} = 200000.00$
 $y2 = 0.0025$
 $sh2 = 0.008$
 $ft2 = 907.50$
 $fy2 = 756.25$
 $su2 = 0.032$
 using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
 and also multiplied by the shear_factor according to 15.7.1.4, with
 $\text{Shear_factor} = 1.00$
 $lo/lou, \min = lb/lb, \min = 1.00$
 $su2 = 0.4 * esu2_nominal ((5.5), TBDY) = 0.032$
 From table 5A.1, TBDY: $esu2_nominal = 0.08$,
 For calculation of $esu2_nominal$ and $y2, sh2, ft2, fy2$, it is considered
 characteristic value $fsy2 = fs2/1.2$, from table 5.1, TBDY.
 $y1, sh1, ft1, fy1$, are also multiplied by $\text{Min}(1, 1.25 * (lb/ld)^{2/3})$, from 10.3.5, ASCE 41-17.
 with $fs2 = (fs_jacket * Asl, \text{com}, \text{jacket} + fs_core * Asl, \text{com}, \text{core}) / Asl, \text{com} = 756.25$
 with $Es2 = (Es_jacket * Asl, \text{com}, \text{jacket} + Es_core * Asl, \text{com}, \text{core}) / Asl, \text{com} = 200000.00$
 $yv = 0.0025$
 $shv = 0.008$
 $ftv = 899.1522$
 $fyv = 749.2935$
 $suv = 0.032$
 using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
 and also multiplied by the shear_factor according to 15.7.1.4, with
 $\text{Shear_factor} = 1.00$
 $lo/lou, \min = lb/ld = 1.00$
 $suv = 0.4 * esuv_nominal ((5.5), TBDY) = 0.032$
 From table 5A.1, TBDY: $esuv_nominal = 0.08$,
 considering characteristic value $fsyv = fsv/1.2$, from table 5.1, TBDY
 For calculation of $esuv_nominal$ and yv, shv, ftv, fyv , it is considered
 characteristic value $fsyv = fsv/1.2$, from table 5.1, TBDY.
 $y1, sh1, ft1, fy1$, are also multiplied by $\text{Min}(1, 1.25 * (lb/ld)^{2/3})$, from 10.3.5, ASCE 41-17.
 with $fsv = (fs_jacket * Asl, \text{mid}, \text{jacket} + fs_mid * Asl, \text{mid}, \text{core}) / Asl, \text{mid} = 749.2935$
 with $Es_v = (Es_jacket * Asl, \text{mid}, \text{jacket} + Es_mid * Asl, \text{mid}, \text{core}) / Asl, \text{mid} = 200000.00$
 $1 = Asl, \text{ten} / (b * d) * (fs1 / fc) = 0.09507586$
 $2 = Asl, \text{com} / (b * d) * (fs2 / fc) = 0.09507586$
 $v = Asl, \text{mid} / (b * d) * (fsv / fc) = 0.22108466$
 and confined core properties:
 $b = 390.00$
 $d = 877.00$
 $d' = 13.00$
 $fcc (5A.2, TBDY) = 30.00$
 $cc (5A.5, TBDY) = 0.002$
 $c = \text{confinement factor} = 1.00$
 $1 = Asl, \text{ten} / (b * d) * (fs1 / fc) = 0.11345559$
 $2 = Asl, \text{com} / (b * d) * (fs2 / fc) = 0.11345559$
 $v = Asl, \text{mid} / (b * d) * (fsv / fc) = 0.26382395$
 Case/Assumption: Unconfined full section - Steel rupture
 ' satisfies Eq. (4.3)

--->

$v < v_{s,y2}$ - LHS eq.(4.5) is not satisfied

--->

$v < v_{s,c}$ - RHS eq.(4.5) is satisfied

--->

$$s_u(4.8) = 0.28399348$$

$$M_u = M_{Rc}(4.15) = 2.6730E+009$$

$$u = s_u(4.1) = 4.9274896E-005$$

Calculation of ratio l_b/l_d

Adequate Lap Length: $l_b/l_d \geq 1$

Calculation of Shear Strength $V_r = \min(V_{r1}, V_{r2}) = 1.6349E+006$

Calculation of Shear Strength at edge 1, $V_{r1} = 1.6349E+006$

$$V_{r1} = V_{Col}((10.3), ASCE 41-17) = k_n l^* V_{Col0}$$

$$V_{Col0} = 1.6349E+006$$

$$k_n l = 1 \text{ (zero step-static loading)}$$

NOTE: In expression (10-3) ' $V_s = A_v f_y d/s$ ' is replaced by ' $V_{s+} + f^* V_f$ ' where V_f is the contribution of FRPs (11.3), ACI 440).

= 1 (normal-weight concrete)

Mean concrete strength: $f'_c = (f'_{c,jacket} \cdot Area_{jacket} + f'_{c,core} \cdot Area_{core}) / Area_{section} = 27.20$, but $f'_c^{0.5} \leq 8.3$ MPa (22.5.3.1, ACI 318-14)

$$M/Vd = 2.00$$

$$M_u = 4.16869$$

$$V_u = 5.2099631E-036$$

$$d = 0.8 \cdot h = 760.00$$

$$N_u = 20792.05$$

$$A_g = 427500.00$$

$$\text{From (11.5.4.8), ACI 318-14: } V_s = V_{s,jacket} + V_{s,core} = 1.2262E+006$$

where:

$$V_{s,jacket} = V_{s,j1} + V_{s,j2} = 1.0996E+006$$

$V_{s,j1} = 353429.174$ is calculated for section web jacket, with:

$$d = 360.00$$

$$A_v = 157079.633$$

$$f_y = 625.00$$

$$s = 100.00$$

$$V_{s,j1} \text{ is multiplied by } Col,j1 = 1.00$$

$$s/d = 0.27777778$$

$V_{s,j2} = 746128.255$ is calculated for section flange jacket, with:

$$d = 760.00$$

$$A_v = 157079.633$$

$$f_y = 625.00$$

$$s = 100.00$$

$$V_{s,j2} \text{ is multiplied by } Col,j2 = 1.00$$

$$s/d = 0.13157895$$

$$V_{s,core} = V_{s,c1} + V_{s,c2} = 126669.016$$

$V_{s,c1} = 0.00$ is calculated for section web core, with:

$$d = 200.00$$

$$A_v = 100530.965$$

$$f_y = 525.00$$

$$s = 250.00$$

$$V_{s,c1} \text{ is multiplied by } Col,c1 = 0.00$$

$$s/d = 1.25$$

$V_{s,c2} = 126669.016$ is calculated for section flange core, with:

$$d = 600.00$$

$$A_v = 100530.965$$

$$f_y = 525.00$$

$$s = 250.00$$

$$V_{s,c2} \text{ is multiplied by } Col,c2 = 1.00$$

$$s/d = 0.41666667$$

Vf ((11-3)-(11.4), ACI 440) = 0.00
From (11-11), ACI 440: $V_s + V_f \leq 1.1849E+006$
bw = 450.00

Calculation of Shear Strength at edge 2, $V_{r2} = 1.6349E+006$
 $V_{r2} = V_{Col} ((10.3), ASCE 41-17) = knl * V_{Col0}$
 $V_{Col0} = 1.6349E+006$
knl = 1 (zero step-static loading)

NOTE: In expression (10-3) ' $V_s = A_v * f_y * d / s$ ' is replaced by ' $V_s + f * V_f$ '
where V_f is the contribution of FRPs (11.3), ACI 440).

= 1 (normal-weight concrete)
Mean concrete strength: $f_c' = (f_c'_{jacket} * Area_{jacket} + f_c'_{core} * Area_{core}) / Area_{section} = 27.20$, but $f_c'^{0.5} \leq 8.3$
MPa (22.5.3.1, ACI 318-14)
 $M/Vd = 2.00$
 $\mu_u = 4.16869$
 $V_u = 5.2099631E-036$
 $d = 0.8 * h = 760.00$
 $N_u = 20792.05$
 $A_g = 427500.00$
From (11.5.4.8), ACI 318-14: $V_s = V_{sjacket} + V_{s,core} = 1.2262E+006$
where:
 $V_{sjacket} = V_{sj1} + V_{sj2} = 1.0996E+006$
 $V_{sj1} = 353429.174$ is calculated for section web jacket, with:
 $d = 360.00$
 $A_v = 157079.633$
 $f_y = 625.00$
 $s = 100.00$
 V_{sj1} is multiplied by $Col,j1 = 1.00$
 $s/d = 0.27777778$
 $V_{sj2} = 746128.255$ is calculated for section flange jacket, with:
 $d = 760.00$
 $A_v = 157079.633$
 $f_y = 625.00$
 $s = 100.00$
 V_{sj2} is multiplied by $Col,j2 = 1.00$
 $s/d = 0.13157895$
 $V_{s,core} = V_{s,c1} + V_{s,c2} = 126669.016$
 $V_{s,c1} = 0.00$ is calculated for section web core, with:
 $d = 200.00$
 $A_v = 100530.965$
 $f_y = 525.00$
 $s = 250.00$
 $V_{s,c1}$ is multiplied by $Col,c1 = 0.00$
 $s/d = 1.25$
 $V_{s,c2} = 126669.016$ is calculated for section flange core, with:
 $d = 600.00$
 $A_v = 100530.965$
 $f_y = 525.00$
 $s = 250.00$
 $V_{s,c2}$ is multiplied by $Col,c2 = 1.00$
 $s/d = 0.41666667$
 $V_f ((11-3)-(11.4), ACI 440) = 0.00$
From (11-11), ACI 440: $V_s + V_f \leq 1.1849E+006$
bw = 450.00

End Of Calculation of Shear Capacity ratio for element: column JTC1 of floor 1
At local axis: 2

Start Of Calculation of Chord Rotation Capacity for element: column JTC1 of floor 1
At local axis: 3

Integration Section: (a)

Section Type: rcjtcs

Constant Properties

Knowledge Factor, $\gamma = 0.80$

Chord Rotation is generally considered as Deformation-Controlled Action according to Table C7-1, ASCE 41-17.

Mean strengths are used for Deformation-Controlled Actions according to 7.5.1.3, ASCE 41-17

Consequently:

Jacket

New material of Secondary Member: Concrete Strength, $f_c = f_{cm} = 30.00$

New material of Secondary Member: Steel Strength, $f_s = f_{sm} = 625.00$

Concrete Elasticity, $E_c = 25742.96$

Steel Elasticity, $E_s = 200000.00$

Existing Column

Existing material of Secondary Member: Concrete Strength, $f_c = f_{cm} = 24.00$

Existing material of Secondary Member: Steel Strength, $f_s = f_{sm} = 525.00$

Concrete Elasticity, $E_c = 23025.204$

Steel Elasticity, $E_s = 200000.00$

Max Height, $H_{max} = 750.00$

Min Height, $H_{min} = 450.00$

Max Width, $W_{max} = 950.00$

Min Width, $W_{min} = 450.00$

Eccentricity, $Ecc = 250.00$

Jacket Thickness, $t_j = 100.00$

Cover Thickness, $c = 25.00$

Element Length, $L = 3000.00$

Secondary Member

Smooth Bars

Ductile Steel

Without Detailing for Earthquake Resistance (including stirrups not closed at 135°)

Longitudinal Bars With Ends Lapped Starting at the End Sections

Adequate Lap Length ($l_b/d \geq 1$)

No FRP Wrapping

Stepwise Properties

Bending Moment, $M = -2.5217E+007$

Shear Force, $V_2 = -8294.64$

Shear Force, $V_3 = -1.96926$

Axial Force, $F = -22375.589$

Longitudinal Reinforcement Area Distribution (in 2 divisions)

-Tension: $As_t = 0.00$

-Compression: $As_c = 6691.592$

Longitudinal Reinforcement Area Distribution (in 3 divisions)

-Tension: $As_{t,ten} = 1539.38$

-Compression: $As_{c,com} = 1539.38$

-Middle: $As_{mid} = 3612.832$

Longitudinal External Reinforcement Area Distribution (in 3 divisions)

-Tension: $As_{t,ten,jacket} = 1231.504$

-Compression: $As_{c,com,jacket} = 1231.504$

-Middle: $As_{mid,jacket} = 2689.203$

Longitudinal Internal Reinforcement Area Distribution (in 3 divisions)

-Tension: $As_{t,ten,core} = 307.8761$

-Compression: $As_{c,com,core} = 307.8761$

-Middle: $As_{mid,core} = 923.6282$

Mean Diameter of Tension Reinforcement, $Db_L = 16.57143$

Existing component: From table 7-7, ASCE 41_17: Final chord rotation Capacity $u_{R} = \gamma \cdot u = 0.03177574$

$u = \gamma \cdot y + p = 0.03971968$

- Calculation of γ -

$y = (M_y * L_s / 3) / E_{eff} = 0.00507501$ ((4.29), Biskinis Phd))
 $M_y = 1.2941E+009$
 $L_s = M/V$ (with $L_s > 0.1 * L$ and $L_s < 2 * L$) = 3040.138
 From table 10.5, ASCE 41_17: $E_{eff} = factor * E_c * I_g = 2.5841E+014$
 $factor = 0.30$
 $A_g = 562500.00$
 Mean concrete strength: $f_c' = (f_c'_{jacket} * Area_{jacket} + f_c'_{core} * Area_{core}) / Area_{section} = 27.20$
 $N = 22375.589$
 $E_c * I_g = E_{c,jacket} * I_{g,jacket} + E_{c,core} * I_{g,core} = 8.6137E+014$

Calculation of Yielding Moment M_y

Calculation of y and M_y according to Annex 7 -

$y = \text{Min}(y_{ten}, y_{com})$
 $y_{ten} = 4.4894872E-006$
 with $f_y = 601.9953$
 $d = 907.00$
 $y = 0.26080489$
 $A = 0.016486$
 $B = 0.00867717$
 with $p_t = 0.0037716$
 $p_c = 0.0037716$
 $p_v = 0.00885172$
 $N = 22375.589$
 $b = 450.00$
 $" = 0.04740904$
 $y_{comp} = 8.8904803E-006$
 with $f_c = 30.00$
 $E_c = 25742.96$
 $y = 0.26013738$
 $A = 0.01626426$
 $B = 0.0085861$
 with $E_s = 200000.00$

Calculation of ratio I_b/I_d

Adequate Lap Length: $I_b/I_d \geq 1$

- Calculation of p -

From table 10-8: $p = 0.03464467$

with:

- Columns not controlled by inadequate development or splicing along the clear height because $I_b/I_d \geq 1$

shear control ratio $V_y E / V_{col} E = 1.08994$

$d = d_{external} = 907.00$

$s = s_{external} = 0.00$

- $t = s_1 + s_2 + 2 * t_f / b_w * (f_{fe} / f_s) = 0.00427788$

jacket: $s_1 = A_{v1} * L_{stir1} / (s_1 * A_g) = 0.00357443$

$A_{v1} = 78.53982$, is the area of every stirrup parallel to loading (shear) direction

$L_{stir1} = 2560.00$, is the total Length of all stirrups parallel to loading (shear) direction

$s_1 = 100.00$

core: $s_2 = A_{v2} * L_{stir2} / (s_2 * A_g) = 0.00070345$

$A_{v2} = 50.26548$, is the area of every stirrup parallel to loading (shear) direction

$L_{stir2} = 1968.00$, is the total Length of all stirrups parallel to loading (shear) direction

$s_2 = 250.00$

The term $2 * t_f / b_w * (f_{fe} / f_s)$ is implemented to account for FRP contribution

where $f = 2 * t_f / b_w$ is FRP ratio (EC8 - 3, A.4.4.3(6)) and f_{fe} / f_s normalises f to steel strength

All these variables have already been given in Shear control ratio calculation.

For the normalisation f_s of jacket is used.

$NUD = 22375.589$


$A_g = 562500.00$

$f_{cE} = (f_{c_jacket} \cdot Area_jacket + f_{c_core} \cdot Area_core) / section_area = 27.20$
 $f_{yIE} = (f_{y_ext_Long_Reinf} \cdot Area_ext_Long_Reinf + f_{y_int_Long_Reinf} \cdot Area_int_Long_Reinf) / Area_Tot_Long_Rein = 601.9953$
 $f_{yIE} = (f_{y_ext_Trans_Reinf} \cdot s1 + f_{y_int_Trans_Reinf} \cdot s2) / (s1 + s2) = 608.5561$
 $\rho_l = Area_Tot_Long_Rein / (b \cdot d) = 0.01639493$
 $b = 450.00$
 $d = 907.00$
 $f_{cE} = 27.20$

 End Of Calculation of Chord Rotation Capacity for element: column JTC1 of floor 1
 At local axis: 3
 Integration Section: (a)

Calculation No. 13

column C1, Floor 1
 Limit State: Life Safety (data interpolation between analysis steps 1 and 2)
 Analysis: Uniform +X
 Check: Shear capacity V_{Rd}
 Edge: End
 Local Axis: (2)



Start Of Calculation of Shear Capacity for element: column JTC1 of floor 1
 At local axis: 2
 Integration Section: (b)
 Section Type: rcjtcs

Constant Properties

 Knowledge Factor, $\gamma = 0.80$
 Member Shear Force is generally considered as Force-Controlled Action according to Table C7-1, ASCE 41-17.
 Lower-bound strengths are used for Force-Controlled Actions according to 7.5.1.3, ASCE 41-17
 Consequently:
 Jacket
 New material of Secondary Member: Concrete Strength, $f_c = f_{c_lower_bound} = 20.00$

New material of Secondary Member: Steel Strength, $f_s = f_{s_lower_bound} = 500.00$
Concrete Elasticity, $E_c = 25742.96$
Steel Elasticity, $E_s = 200000.00$
Existing Column
Existing material of Secondary Member: Concrete Strength, $f_c = f_{c_lower_bound} = 16.00$
Existing material of Secondary Member: Steel Strength, $f_s = f_{s_lower_bound} = 420.00$
Concrete Elasticity, $E_c = 23025.204$
Steel Elasticity, $E_s = 200000.00$

Note: Especially for the calculation of γ for displacement ductility demand,
the expected (mean value) strengths are used (7.5.1.3, ASCE 41-17) because bending is considered as
Deformation-Controlled Action (Table C7-1, ASCE 41-17).
Jacket
New material: Concrete Strength, $f_c = f_{cm} = 30.00$
New material: Steel Strength, $f_s = f_{sm} = 625.00$
Existing Column
Existing material: Concrete Strength, $f_c = f_{cm} = 24.00$
Existing material: Steel Strength, $f_s = f_{sm} = 525.00$

Max Height, $H_{max} = 750.00$
Min Height, $H_{min} = 450.00$
Max Width, $W_{max} = 950.00$
Min Width, $W_{min} = 450.00$
Eccentricity, $Ecc = 250.00$
Jacket Thickness, $t_j = 100.00$
Cover Thickness, $c = 25.00$
Element Length, $L = 3000.00$
Secondary Member
Smooth Bars
Ductile Steel
Without Detailing for Earthquake Resistance (including stirrups not closed at 135°)
Longitudinal Bars With Ends Lapped Starting at the End Sections
Adequate Lap Length ($l_o/l_{ou,min} = l_b/l_d \geq 1$)
No FRP Wrapping

Stepwise Properties

EDGE -A-
Bending Moment, $M_a = -2.5217E+007$
Shear Force, $V_a = -8294.64$
EDGE -B-
Bending Moment, $M_b = 326833.199$
Shear Force, $V_b = 8294.64$
BOTH EDGES
Axial Force, $F = -22375.589$
Longitudinal Reinforcement Area Distribution (in 2 divisions)
-Tension: $A_{sl,t} = 0.00$
-Compression: $A_{sl,c} = 6691.592$
Longitudinal Reinforcement Area Distribution (in 3 divisions)
-Tension: $A_{sl,ten} = 1539.38$
-Compression: $A_{sl,com} = 1539.38$
-Middle: $A_{sl,mid} = 3612.832$
Mean Diameter of Tension Reinforcement, $Db_{L,ten} = 16.57143$

Existing component: From table 7-7, ASCE 41_17: Final Shear Capacity $V_R = \phi V_n = 1.0688E+006$
 V_n ((10.3), ASCE 41-17) = $k_n l \cdot V_{CoI} = 1.3360E+006$
 $V_{CoI} = 1.3360E+006$
 $k_n l = 1.00$
displacement_ductility_demand = 0.0299469

NOTE: In expression (10-3) ' $V_s = A_v \cdot f_y \cdot d/s$ ' is replaced by ' $V_s + \phi \cdot V_f$ '
where V_f is the contribution of FRPs (11.3), ACI 440).

= 1 (normal-weight concrete)
Mean concrete strength: $fc' = (fc'_{jacket} \cdot Area_{jacket} + fc'_{core} \cdot Area_{core}) / Area_{section} = 18.13333$, but $fc'^{0.5} \leq 8.3$ MPa (22.5.3.1, ACI 318-14)
 $M/Vd = 2.00$
 $\mu_u = 326833.199$
 $V_u = 8294.64$
 $d = 0.8 \cdot h = 760.00$
 $N_u = 22375.589$
 $A_g = 427500.00$
From (11.5.4.8), ACI 318-14: $V_s = V_{sjacket} + V_{s,core} = 980981.156$
where:
 $V_{sjacket} = V_{sj1} + V_{sj2} = 879645.943$
 $V_{sj1} = 282743.339$ is calculated for section web jacket, with:
 $d = 360.00$
 $A_v = 157079.633$
 $f_y = 500.00$
 $s = 100.00$
 V_{sj1} is multiplied by $Col,j1 = 1.00$
 $s/d = 0.27777778$
 $V_{sj2} = 596902.604$ is calculated for section flange jacket, with:
 $d = 760.00$
 $A_v = 157079.633$
 $f_y = 500.00$
 $s = 100.00$
 V_{sj2} is multiplied by $Col,j2 = 1.00$
 $s/d = 0.13157895$
 $V_{s,core} = V_{s,c1} + V_{s,c2} = 101335.213$
 $V_{s,c1} = 0.00$ is calculated for section web core, with:
 $d = 200.00$
 $A_v = 100530.965$
 $f_y = 420.00$
 $s = 250.00$
 $V_{s,c1}$ is multiplied by $Col,c1 = 0.00$
 $s/d = 1.25$
 $V_{s,c2} = 101335.213$ is calculated for section flange core, with:
 $d = 600.00$
 $A_v = 100530.965$
 $f_y = 420.00$
 $s = 250.00$
 $V_{s,c2}$ is multiplied by $Col,c2 = 1.00$
 $s/d = 0.41666667$
 $V_f ((11-3)-(11.4), ACI 440) = 0.00$
From (11-11), ACI 440: $V_s + V_f \leq 967457.029$
 $bw = 450.00$

displacement ductility demand is calculated as δ_u / y

- Calculation of δ_u / y for END B -
for rotation axis 3 and integ. section (b)

From analysis, chord rotation $\theta = 1.4997444E-005$
 $y = (M_y \cdot L_s / 3) / E_{eff} = 0.0005008$ ((4.29), Biskinis Phd))
 $M_y = 1.2941E+009$
 $L_s = M/V$ (with $L_s > 0.1 \cdot L$ and $L_s < 2 \cdot L$) = 300.00
From table 10.5, ASCE 41_17: $E_{eff} = factor \cdot E_c \cdot I_g = 2.5841E+014$
 $factor = 0.30$
 $A_g = 562500.00$
Mean concrete strength: $fc' = (fc'_{jacket} \cdot Area_{jacket} + fc'_{core} \cdot Area_{core}) / Area_{section} = 27.20$
 $N = 22375.589$
 $E_c \cdot I_g = E_{c,jacket} \cdot I_{g,jacket} + E_{c,core} \cdot I_{g,core} = 8.6137E+014$

Calculation of Yielding Moment M_y

Calculation of y and M_y according to Annex 7 -

$y = \text{Min}(y_{\text{ten}}, y_{\text{com}})$
 $y_{\text{ten}} = 4.4894872\text{E-}006$
with $f_y = 601.9953$
 $d = 907.00$
 $y = 0.26080489$
 $A = 0.016486$
 $B = 0.00867717$
with $p_t = 0.0037716$
 $p_c = 0.0037716$
 $p_v = 0.00885172$
 $N = 22375.589$
 $b = 450.00$
 $" = 0.04740904$
 $y_{\text{comp}} = 8.8904803\text{E-}006$
with $f_c = 30.00$
 $E_c = 25742.96$
 $y = 0.26013738$
 $A = 0.01626426$
 $B = 0.0085861$
with $E_s = 200000.00$

Calculation of ratio I_b/I_d

Adequate Lap Length: $I_b/I_d \geq 1$

End Of Calculation of Shear Capacity for element: column JTC1 of floor 1

At local axis: 2

Integration Section: (b)

Calculation No. 14

column C1, Floor 1



Limit State: Life Safety (data interpolation between analysis steps 1 and 2)

Analysis: Uniform +X

Check: Chord rotation capacity (ϕ_r)

Edge: End

Local Axis: (2)



Start Of Calculation of Shear Capacity ratio for element: column JTC1 of floor 1

At Shear local axis: 3

(Bending local axis: 2)

Section Type: rcjtcs

Constant Properties

Knowledge Factor, $\gamma = 0.80$

Mean strength values are used for both shear and moment calculations.

Consequently:

Jacket

New material of Secondary Member: Concrete Strength, $f_c = f_{cm} = 30.00$

New material of Secondary Member: Steel Strength, $f_s = f_{sm} = 625.00$

Concrete Elasticity, $E_c = 25742.96$

Steel Elasticity, $E_s = 200000.00$

Existing Column

Existing material of Secondary Member: Concrete Strength, $f_c = f_{cm} = 24.00$

Existing material of Secondary Member: Steel Strength, $f_s = f_{sm} = 525.00$

Concrete Elasticity, $E_c = 23025.204$

Steel Elasticity, $E_s = 200000.00$

#####

Note: Especially for the calculation of moment strengths,

the above steel re-bar strengths are multiplied by 1.25 according to R18.6.5, ACI 318-14

Jacket

New material: Steel Strength, $f_s = 1.25 \cdot f_{sm} = 781.25$

Existing Column

Existing material: Steel Strength, $f_s = 1.25 \cdot f_{sm} = 656.25$

#####

Max Height, $H_{max} = 750.00$

Min Height, $H_{min} = 450.00$

Max Width, $W_{max} = 950.00$

Min Width, $W_{min} = 450.00$

Eccentricity, $E_{cc} = 250.00$

Jacket Thickness, $t_j = 100.00$

Cover Thickness, $c = 25.00$

Mean Confinement Factor overall section = 1.00

Element Length, $L = 3000.00$

Secondary Member

Smooth Bars

Ductile Steel

Without Detailing for Earthquake Resistance (including stirrups not closed at 135°)

Longitudinal Bars With Ends Lapped Starting at the End Sections

Adequate Lap Length ($l_o/l_{o,u,min} \geq 1$)

No FRP Wrapping

Stepwise Properties

At local axis: 3

EDGE -A-

Shear Force, $V_a = -8.5087964E-020$

EDGE -B-

Shear Force, $V_b = 8.5087964E-020$

BOTH EDGES

Axial Force, $F = -20792.05$

Longitudinal Reinforcement Area Distribution (in 2 divisions)

-Tension: $As_t = 0.00$

-Compression: $As_c = 6691.592$

Longitudinal Reinforcement Area Distribution (in 3 divisions)

-Tension: $As_{t,ten} = 1539.38$

-Compression: $As_{c,com} = 2475.575$

-Middle: $As_{mid} = 2676.637$

Calculation of Shear Capacity ratio, $V_e/V_r = 1.11674$

Member Controlled by Shear ($V_e/V_r > 1$)

Calculation of Shear Demand from fig. R18.6.5, ACI 318-14 $V_e = (M_{pr1} + M_{pr2})/l_n = 1.4424E+006$ with

$M_{pr1} = \text{Max}(Mu_{1+}, Mu_{1-}) = 2.1636E+009$

$Mu_{1+} = 2.0419E+009$, is the ultimate moment strength at the edge 1 of the member in the actual moment direction which is defined for the static loading combination

$Mu_{1-} = 2.1636E+009$, is the ultimate moment strength at the edge 1 of the member in the opposite moment direction which is defined for the static loading combination

$M_{pr2} = \text{Max}(Mu_{2+}, Mu_{2-}) = 2.1636E+009$

$Mu_{2+} = 2.0419E+009$, is the ultimate moment strength at the edge 2 of the member in the actual moment direction which is defined for the static loading combination

$Mu_{2-} = 2.1636E+009$, is the ultimate moment strength at the edge 2 of the member in the opposite moment direction which is defined for the static loading combination

Calculation of Mu_{1+}

Calculation of ultimate curvature ϕ_u according to 4.1, Biskinis/Fardis 2013:

$\phi_u = 5.3321191E-005$

$M_u = 2.0419E+009$

with full section properties:

$b = 950.00$

$d = 707.00$

$d' = 43.00$

$v = 0.00103189$

$N = 20792.05$

$f_c = 30.00$

ϕ_c (5A.5, TBDY) = 0.002

Final value of ϕ_u : $\phi_u^* = \text{shear_factor} * \text{Max}(\phi_u, \phi_c) = 0.00832321$

The Shear_factor is considered equal to 1 (pure moment strength)

From (5.4b), TBDY: $\phi_u = 0.00832321$

we (5.4c) = 0.01453958

ϕ_{se} ((5.4d), TBDY) = $(\phi_{se1} * A_{ext} + \phi_{se2} * A_{int}) / A_{sec} = 0.53375773$

$\phi_{se1} = \text{Max}(((A_{conf,max1} - A_{noConf1}) / A_{conf,max1}) * (A_{conf,min1} / A_{conf,max1}), 0) = 0.53375773$

The definitions of A_{noConf} , $A_{conf,min}$ and $A_{conf,max}$ are derived from generalization of the rectangular sections confinement, which is expressed by (5.4d).

The generalization is done according to Mander, J., Priestley, M., and Park, R. (1988)

"Theoretical Stress-Strain Model for Confined Concrete."

J. Struct. Eng., 10.1061/(ASCE)0733-9445(1988)114:8(1804), 1804-1826.

$A_{conf,max1} = 464100.00$ is the confined core area at levels of member with hoops and is calculated as the area of core enclosed by the center lines of the external perimeter hoops.

$A_{conf,min1} = 395025.00$ is the confined core area at midway between the levels of hoops and is calculated by reducing all the dimensions of the area $A_{conf,max1}$ by a length equal to half the clear spacing between external hoops.

$A_{noConf1} = 173066.667$ is the unconfined external core area which is equal to $b_i^2/6$ as defined at (A.2).

$\phi_{se2} (>= \phi_{se1}) = \text{Max}(((A_{conf,max2} - A_{noConf2}) / A_{conf,max2}) * (A_{conf,min2} / A_{conf,max2}), 0) = 0.53375773$

The definitions of A_{noConf} , $A_{conf,min}$ and $A_{conf,max}$ are derived from generalization of the rectangular sections confinement, which is expressed by (5.4d).

The generalization is done according to Mander, J., Priestley, M., and Park, R. (1988)

"Theoretical Stress-Strain Model for Confined Concrete."

J. Struct. Eng., 10.1061/(ASCE)0733-9445(1988)114:8(1804), 1804-1826.

$A_{conf,max2} = 252164.00$ is the confined core area at levels of member with hoops and is calculated as the area of core enclosed by the center lines of the internal perimeter hoops.
 $A_{conf,min2} = 111441.00$ is the confined core area at midway between the levels of hoops and is calculated by reducing all the dimensions of the area $A_{conf,max2}$ by a length equal to half the clear spacing between internal hoops.

$A_{noConf2} = 110709.333$ is the unconfined internal core area which is equal to $b_i^2/6$ as defined at (A.2).

$p_{sh,min} \cdot F_{ywe} = \text{Min}(p_{sh,x} \cdot F_{ywe}, p_{sh,y} \cdot F_{ywe}) = 2.724$

Expression (5.4d) for $p_{sh,min} \cdot F_{ywe}$ has been multiplied by 0.3 according to 15.7.1.3 for members without earthquake detailing (90° closed stirrups)

$p_{sh,x} \cdot F_{ywe} = p_{sh1} \cdot F_{ywe1} + p_{s2} \cdot F_{ywe2} = 2.724$

p_{sh1} ((5.4d), TBDY) = $L_{stir1} \cdot A_{stir1} / (A_{sec} \cdot s1) = 0.00301593$

L_{stir1} (Length of stirrups along Y) = 2160.00

A_{stir1} (stirrups area) = 78.53982

p_{s2} (5.4d) = $L_{stir2} \cdot A_{stir2} / (A_{sec} \cdot s2) = 0.00056047$

L_{stir2} (Length of stirrups along Y) = 1568.00

A_{stir2} (stirrups area) = 50.26548

$p_{sh,y} \cdot F_{ywe} = p_{sh1} \cdot F_{ywe1} + p_{s2} \cdot F_{ywe2} = 3.25416$

p_{sh1} ((5.4d), TBDY) = $L_{stir1} \cdot A_{stir1} / (A_{sec} \cdot s1) = 0.00357443$

L_{stir1} (Length of stirrups along X) = 2560.00

A_{stir1} (stirrups area) = 78.53982

p_{s2} ((5.4d), TBDY) = $L_{stir2} \cdot A_{stir2} / (A_{sec} \cdot s2) = 0.00070345$

L_{stir2} (Length of stirrups along X) = 1968.00

A_{stir2} (stirrups area) = 50.26548

$A_{sec} = 562500.00$

$s1 = 100.00$

$s2 = 250.00$

$f_{ywe1} = 781.25$

$f_{ywe2} = 656.25$

$f_{ce} = 30.00$

From ((5.A5), TBDY), TBDY: $cc = 0.002$

c = confinement factor = 1.00

$y1 = 0.0025$

$sh1 = 0.008$

$ft1 = 907.50$

$fy1 = 756.25$

$su1 = 0.032$

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor and also multiplied by the shear_factor according to 15.7.1.4, with Shear_factor = 1.00

$l_o/l_{ou,min} = l_b/l_d = 1.00$

$su1 = 0.4 \cdot esu1_{nominal}$ ((5.5), TBDY) = 0.032

From table 5A.1, TBDY: $esu1_{nominal} = 0.08$,

For calculation of $esu1_{nominal}$ and $y1, sh1, ft1, fy1$, it is considered characteristic value $fsy1 = fs1/1.2$, from table 5.1, TBDY.

$y1, sh1, ft1, fy1$, are also multiplied by $\text{Min}(1, 1.25 \cdot (l_b/l_d)^{2/3})$, from 10.3.5, ASCE 41-17.

with $fs1 = (f_{s,jacket} \cdot A_{sl,ten,jacket} + f_{s,core} \cdot A_{sl,ten,core}) / A_{sl,ten} = 756.25$

with $Es1 = (E_{s,jacket} \cdot A_{sl,ten,jacket} + E_{s,core} \cdot A_{sl,ten,core}) / A_{sl,ten} = 200000.00$

$y2 = 0.0025$

$sh2 = 0.008$

$ft2 = 900.1904$

$fy2 = 750.1586$

$su2 = 0.032$

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor and also multiplied by the shear_factor according to 15.7.1.4, with Shear_factor = 1.00

$l_o/l_{ou,min} = l_b/l_{b,min} = 1.00$

$su2 = 0.4 \cdot esu2_{nominal}$ ((5.5), TBDY) = 0.032

From table 5A.1, TBDY: $esu2_{nominal} = 0.08$,

For calculation of $esu2_{nominal}$ and $y2, sh2, ft2, fy2$, it is considered characteristic value $fsy2 = fs2/1.2$, from table 5.1, TBDY.

$y1, sh1, ft1, fy1$, are also multiplied by $\text{Min}(1, 1.25 \cdot (l_b/l_d)^{2/3})$, from 10.3.5, ASCE 41-17.

with $fs2 = (f_{s,jacket} \cdot A_{sl,com,jacket} + f_{s,core} \cdot A_{sl,com,core}) / A_{sl,com} = 750.1586$

```

with Es2 = (Es,jacket*Asl,com,jacket + Es,core*Asl,com,core)/Asl,com = 200000.00
yv = 0.0025
shv = 0.008
ftv = 902.993
fyv = 752.4941
suv = 0.032
using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00
lo/lou,min = lb/d = 1.00
suv = 0.4*esuv_nominal ((5.5), TBDY) = 0.032
From table 5A.1, TBDY: esuv_nominal = 0.08,
considering characteristic value fsyv = fsv/1.2, from table 5.1, TBDY
For calculation of esuv_nominal and yv, shv,ftv,fyv, it is considered
characteristic value fsyv = fsv/1.2, from table 5.1, TBDY.
y1, sh1,ft1,fy1, are also multiplied by Min(1,1.25*(lb/d)^2/3), from 10.3.5, ASCE 41-17.
with fsv = (fs,jacket*Asl,mid,jacket + fs,mid*Asl,mid,core)/Asl,mid = 752.4941
with Esv = (Es,jacket*Asl,mid,jacket + Es,mid*Asl,mid,core)/Asl,mid = 200000.00
1 = Asl,ten/(b*d)*(fs1/fc) = 0.05777595
2 = Asl,com/(b*d)*(fs2/fc) = 0.09216477
v = Asl,mid/(b*d)*(fsv/fc) = 0.09996047
and confined core properties:
b = 890.00
d = 677.00
d' = 13.00
fcc (5A.2, TBDY) = 30.00
cc (5A.5, TBDY) = 0.002
c = confinement factor = 1.00
1 = Asl,ten/(b*d)*(fs1/fc) = 0.06440379
2 = Asl,com/(b*d)*(fs2/fc) = 0.10273757
v = Asl,mid/(b*d)*(fsv/fc) = 0.11142757
Case/Assumption: Unconfined full section - Steel rupture
'satisfies Eq. (4.3)
--->
v < vs,y2 - LHS eq.(4.5) is not satisfied
--->
v < vs,c - RHS eq.(4.5) is satisfied
--->
su (4.8) = 0.15115045
Mu = MRc (4.15) = 2.0419E+009
u = su (4.1) = 5.3321191E-005

```

Calculation of ratio lb/d

Adequate Lap Length: lb/d >= 1

Calculation of Mu1-

Calculation of ultimate curvature u according to 4.1, Biskinis/Fardis 2013:

u = 6.8287974E-005
Mu = 2.1636E+009

with full section properties:

b = 450.00
d = 707.00
d' = 43.00
v = 0.00217843
N = 20792.05
fc = 30.00
co (5A.5, TBDY) = 0.002
Final value of cu: cu* = shear_factor * Max(cu, cc) = 0.00832321
The Shear_factor is considered equal to 1 (pure moment strength)

From (5.4b), TBDY: $c_u = 0.00832321$

w_e (5.4c) = 0.01453958

a_{se} ((5.4d), TBDY) = $(a_{se1} \cdot A_{ext} + a_{se2} \cdot A_{int}) / A_{sec} = 0.53375773$

$a_{se1} = \text{Max}(((A_{conf,max1} - A_{noConf1}) / A_{conf,max1}) \cdot (A_{conf,min1} / A_{conf,max1}), 0) = 0.53375773$

The definitions of A_{noConf} , $A_{conf,min}$ and $A_{conf,max}$ are derived from generalization of the rectangular sections confinement, which is expressed by (5.4d).

The generalization is done according to Mander, J., Priestley, M., and Park, R. (1988)

"Theoretical Stress-Strain Model for Confined Concrete."

J. Struct. Eng., 10.1061/(ASCE)0733-9445(1988)114:8(1804), 1804-1826.

$A_{conf,max1} = 464100.00$ is the confined core area at levels of member with hoops and

is calculated as the area of core enclosed by the center lines of the external perimeter hoops.

$A_{conf,min1} = 395025.00$ is the confined core area at midway between the levels of hoops and

is calculated by reducing all the dimensions of the area $A_{conf,max1}$ by a length equal to half the clear spacing between external hoops.

$A_{noConf1} = 173066.667$ is the unconfined external core area which is equal to $b_i^2/6$ as defined at (A.2).

$a_{se2} (>= a_{se1}) = \text{Max}(((A_{conf,max2} - A_{noConf2}) / A_{conf,max2}) \cdot (A_{conf,min2} / A_{conf,max2}), 0) = 0.53375773$

The definitions of A_{noConf} , $A_{conf,min}$ and $A_{conf,max}$ are derived from generalization of the rectangular sections confinement, which is expressed by (5.4d).

The generalization is done according to Mander, J., Priestley, M., and Park, R. (1988)

"Theoretical Stress-Strain Model for Confined Concrete."

J. Struct. Eng., 10.1061/(ASCE)0733-9445(1988)114:8(1804), 1804-1826.

$A_{conf,max2} = 252164.00$ is the confined core area at levels of member with hoops and

is calculated as the area of core enclosed by the center lines of the internal perimeter hoops.

$A_{conf,min2} = 111441.00$ is the confined core area at midway between the levels of hoops and

is calculated by reducing all the dimensions of the area $A_{conf,max2}$ by a length equal to half the clear spacing between internal hoops.

$A_{noConf2} = 110709.333$ is the unconfined internal core area which is equal to $b_i^2/6$ as defined at (A.2).

$p_{sh,min} \cdot F_{ywe} = \text{Min}(p_{sh,x} \cdot F_{ywe}, p_{sh,y} \cdot F_{ywe}) = 2.724$

Expression (5.4d) for $p_{sh,min} \cdot F_{ywe}$ has been multiplied by 0.3 according to 15.7.1.3 for members without earthquake detailing (90° closed stirrups)

$p_{sh,x} \cdot F_{ywe} = p_{sh1} \cdot F_{ywe1} + p_{s2} \cdot F_{ywe2} = 2.724$

p_{sh1} ((5.4d), TBDY) = $L_{stir1} \cdot A_{stir1} / (A_{sec} \cdot s_1) = 0.00301593$

L_{stir1} (Length of stirrups along Y) = 2160.00

A_{stir1} (stirrups area) = 78.53982

p_{sh2} (5.4d) = $L_{stir2} \cdot A_{stir2} / (A_{sec} \cdot s_2) = 0.00056047$

L_{stir2} (Length of stirrups along Y) = 1568.00

A_{stir2} (stirrups area) = 50.26548

$p_{sh,y} \cdot F_{ywe} = p_{sh1} \cdot F_{ywe1} + p_{s2} \cdot F_{ywe2} = 3.25416$

p_{sh1} ((5.4d), TBDY) = $L_{stir1} \cdot A_{stir1} / (A_{sec} \cdot s_1) = 0.00357443$

L_{stir1} (Length of stirrups along X) = 2560.00

A_{stir1} (stirrups area) = 78.53982

p_{sh2} ((5.4d), TBDY) = $L_{stir2} \cdot A_{stir2} / (A_{sec} \cdot s_2) = 0.00070345$

L_{stir2} (Length of stirrups along X) = 1968.00

A_{stir2} (stirrups area) = 50.26548

$A_{sec} = 562500.00$

$s_1 = 100.00$

$s_2 = 250.00$

$f_{ywe1} = 781.25$

$f_{ywe2} = 656.25$

$f_{ce} = 30.00$

From ((5.A5), TBDY), TBDY: $c_c = 0.002$

c = confinement factor = 1.00

$y_1 = 0.0025$

$sh_1 = 0.008$

$ft_1 = 900.1904$

$fy_1 = 750.1586$

$su_1 = 0.032$

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor

and also multiplied by the shear_factor according to 15.7.1.4, with

Shear_factor = 1.00

$l_o/l_{ou,min} = l_b/l_d = 1.00$

$su_1 = 0.4 \cdot esu_{1,nominal}$ ((5.5), TBDY) = 0.032

From table 5A.1, TBDY: $esu_{1,nominal} = 0.08$,

For calculation of $esu_{1,nominal}$ and y_1, sh_1, ft_1, fy_1 , it is considered

characteristic value $f_{sy1} = f_{s1}/1.2$, from table 5.1, TBDY.
 $y1, sh1, ft1, fy1$, are also multiplied by $\text{Min}(1, 1.25 \cdot (l_b/l_d)^{2/3})$, from 10.3.5, ASCE 41-17.
 with $f_{s1} = (f_{sjacket} \cdot A_{s,ten,jacket} + f_{s,core} \cdot A_{s,ten,core})/A_{s,ten} = 750.1586$
 with $E_{s1} = (E_{sjacket} \cdot A_{s,ten,jacket} + E_{s,core} \cdot A_{s,ten,core})/A_{s,ten} = 200000.00$
 $y2 = 0.0025$
 $sh2 = 0.008$
 $ft2 = 907.50$
 $fy2 = 756.25$
 $su2 = 0.032$
 using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
 and also multiplied by the shear_factor according to 15.7.1.4, with
 Shear_factor = 1.00
 $l_o/l_{ou,min} = l_b/l_{b,min} = 1.00$
 $su2 = 0.4 \cdot esu2_nominal \text{ ((5.5), TBDY)} = 0.032$
 From table 5A.1, TBDY: $esu2_nominal = 0.08$,
 For calculation of $esu2_nominal$ and $y2, sh2, ft2, fy2$, it is considered
 characteristic value $f_{sy2} = f_{s2}/1.2$, from table 5.1, TBDY.
 $y1, sh1, ft1, fy1$, are also multiplied by $\text{Min}(1, 1.25 \cdot (l_b/l_d)^{2/3})$, from 10.3.5, ASCE 41-17.
 with $f_{s2} = (f_{sjacket} \cdot A_{s,com,jacket} + f_{s,core} \cdot A_{s,com,core})/A_{s,com} = 756.25$
 with $E_{s2} = (E_{sjacket} \cdot A_{s,com,jacket} + E_{s,core} \cdot A_{s,com,core})/A_{s,com} = 200000.00$
 $yv = 0.0025$
 $shv = 0.008$
 $ftv = 902.993$
 $fyv = 752.4941$
 $suv = 0.032$
 using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
 and also multiplied by the shear_factor according to 15.7.1.4, with
 Shear_factor = 1.00
 $l_o/l_{ou,min} = l_b/l_d = 1.00$
 $suv = 0.4 \cdot esuv_nominal \text{ ((5.5), TBDY)} = 0.032$
 From table 5A.1, TBDY: $esuv_nominal = 0.08$,
 considering characteristic value $f_{syv} = f_{sv}/1.2$, from table 5.1, TBDY
 For calculation of $esuv_nominal$ and yv, shv, ftv, fyv , it is considered
 characteristic value $f_{syv} = f_{sv}/1.2$, from table 5.1, TBDY.
 $y1, sh1, ft1, fy1$, are also multiplied by $\text{Min}(1, 1.25 \cdot (l_b/l_d)^{2/3})$, from 10.3.5, ASCE 41-17.
 with $f_{sv} = (f_{sjacket} \cdot A_{s,mid,jacket} + f_{s,mid} \cdot A_{s,mid,core})/A_{s,mid} = 752.4941$
 with $E_{sv} = (E_{sjacket} \cdot A_{s,mid,jacket} + E_{s,mid} \cdot A_{s,mid,core})/A_{s,mid} = 200000.00$
 $1 = A_{s,ten}/(b \cdot d) \cdot (f_{s1}/f_c) = 0.19457006$
 $2 = A_{s,com}/(b \cdot d) \cdot (f_{s2}/f_c) = 0.12197144$
 $v = A_{s,mid}/(b \cdot d) \cdot (f_{sv}/f_c) = 0.21102767$

and confined core properties:

$b = 390.00$
 $d = 677.00$
 $d' = 13.00$
 $f_{cc} \text{ (5A.2, TBDY)} = 30.00$
 $cc \text{ (5A.5, TBDY)} = 0.002$
 $c = \text{confinement factor} = 1.00$
 $1 = A_{s,ten}/(b \cdot d) \cdot (f_{s1}/f_c) = 0.23445239$
 $2 = A_{s,com}/(b \cdot d) \cdot (f_{s2}/f_c) = 0.14697275$
 $v = A_{s,mid}/(b \cdot d) \cdot (f_{sv}/f_c) = 0.25428343$

Case/Assumption: Unconfined full section - Steel rupture

' satisfies Eq. (4.3)

---->

$v < v_{s,y2}$ - LHS eq.(4.5) is not satisfied

---->

$v < v_{s,c}$ - RHS eq.(4.5) is satisfied

---->

$su \text{ (4.8)} = 0.33719414$

$Mu = MR_c \text{ (4.15)} = 2.1636E+009$

$u = su \text{ (4.1)} = 6.8287974E-005$

Calculation of ratio l_b/l_d

Adequate Lap Length: $l_b/l_d \geq 1$

Calculation of Mu2+

Calculation of ultimate curvature ϕ_u according to 4.1, Biskinis/Fardis 2013:

$$u = 5.3321191E-005$$

$$Mu = 2.0419E+009$$

with full section properties:

$$b = 950.00$$

$$d = 707.00$$

$$d' = 43.00$$

$$v = 0.00103189$$

$$N = 20792.05$$

$$f_c = 30.00$$

$$c_o(5A.5, TBDY) = 0.002$$

$$\text{Final value of } c_u: c_u^* = \text{shear_factor} * \text{Max}(c_u, c_c) = 0.00832321$$

The Shear_factor is considered equal to 1 (pure moment strength)

$$\text{From (5.4b), TBDY: } c_u = 0.00832321$$

$$w_e(5.4c) = 0.01453958$$

$$a_{se}((5.4d), TBDY) = (a_{se1} * A_{ext} + a_{se2} * A_{int}) / A_{sec} = 0.53375773$$

$$a_{se1} = \text{Max}(((A_{conf,max1} - A_{noConf1}) / A_{conf,max1}) * (A_{conf,min1} / A_{conf,max1}), 0) = 0.53375773$$

The definitions of A_{noConf} , $A_{conf,min}$ and $A_{conf,max}$ are derived from generalization of the rectangular sections confinement, which is expressed by (5.4d).

The generalization is done according to Mander, J., Priestley, M., and Park, R. (1988)

"Theoretical Stress-Strain Model for Confined Concrete."

J. Struct. Eng., 10.1061/(ASCE)0733-9445(1988)114:8(1804), 1804-1826.

$A_{conf,max1} = 464100.00$ is the confined core area at levels of member with hoops and is calculated as the area of core enclosed by the center lines of the external perimeter hoops.

$A_{conf,min1} = 395025.00$ is the confined core area at midway between the levels of hoops and is calculated by reducing all the dimensions of the area $A_{conf,max1}$ by a length equal to half the clear spacing between external hoops.

$A_{noConf1} = 173066.667$ is the unconfined external core area which is equal to $b_i^2/6$ as defined at (A.2).

$$a_{se2}(>=a_{se1}) = \text{Max}(((A_{conf,max2} - A_{noConf2}) / A_{conf,max2}) * (A_{conf,min2} / A_{conf,max2}), 0) = 0.53375773$$

The definitions of A_{noConf} , $A_{conf,min}$ and $A_{conf,max}$ are derived from generalization of the rectangular sections confinement, which is expressed by (5.4d).

The generalization is done according to Mander, J., Priestley, M., and Park, R. (1988)

"Theoretical Stress-Strain Model for Confined Concrete."

J. Struct. Eng., 10.1061/(ASCE)0733-9445(1988)114:8(1804), 1804-1826.

$A_{conf,max2} = 252164.00$ is the confined core area at levels of member with hoops and is calculated as the area of core enclosed by the center lines of the internal perimeter hoops.

$A_{conf,min2} = 111441.00$ is the confined core area at midway between the levels of hoops and is calculated by reducing all the dimensions of the area $A_{conf,max2}$ by a length equal to half the clear spacing between internal hoops.

$A_{noConf2} = 110709.333$ is the unconfined internal core area which is equal to $b_i^2/6$ as defined at (A.2).

$$p_{sh,min} * F_{ywe} = \text{Min}(p_{sh,x} * F_{ywe}, p_{sh,y} * F_{ywe}) = 2.724$$

Expression (5.4d) for $p_{sh,min} * F_{ywe}$ has been multiplied by 0.3 according to 15.7.1.3 for members without earthquake detailing (90° closed stirrups)

$$p_{sh,x} * F_{ywe} = p_{sh1} * F_{ywe1} + p_{sh2} * F_{ywe2} = 2.724$$

$$p_{sh1}((5.4d), TBDY) = L_{stir1} * A_{stir1} / (A_{sec} * s_1) = 0.00301593$$

$$L_{stir1} \text{ (Length of stirrups along Y)} = 2160.00$$

$$A_{stir1} \text{ (stirrups area)} = 78.53982$$

$$p_{sh2}((5.4d)) = L_{stir2} * A_{stir2} / (A_{sec} * s_2) = 0.00056047$$

$$L_{stir2} \text{ (Length of stirrups along Y)} = 1568.00$$

$$A_{stir2} \text{ (stirrups area)} = 50.26548$$

$$p_{sh,y} * F_{ywe} = p_{sh1} * F_{ywe1} + p_{sh2} * F_{ywe2} = 3.25416$$

$$p_{sh1}((5.4d), TBDY) = L_{stir1} * A_{stir1} / (A_{sec} * s_1) = 0.00357443$$

$$L_{stir1} \text{ (Length of stirrups along X)} = 2560.00$$

$$A_{stir1} \text{ (stirrups area)} = 78.53982$$

$$p_{sh2}((5.4d), TBDY) = L_{stir2} * A_{stir2} / (A_{sec} * s_2) = 0.00070345$$

$$L_{stir2} \text{ (Length of stirrups along X)} = 1968.00$$

$$A_{stir2} \text{ (stirrups area)} = 50.26548$$

$$A_{sec} = 562500.00$$

$s1 = 100.00$
 $s2 = 250.00$
 $fyw1 = 781.25$
 $fyw2 = 656.25$
 $fce = 30.00$
 From ((5.A.5), TBDY), TBDY: $cc = 0.002$
 $c = \text{confinement factor} = 1.00$
 $y1 = 0.0025$
 $sh1 = 0.008$
 $ft1 = 907.50$
 $fy1 = 756.25$
 $su1 = 0.032$
 using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
 and also multiplied by the shear_factor according to 15.7.1.4, with
 $\text{Shear_factor} = 1.00$
 $lo/lou, \min = lb/ld = 1.00$
 $su1 = 0.4 * esu1_nominal ((5.5), TBDY) = 0.032$
 From table 5A.1, TBDY: $esu1_nominal = 0.08$,
 For calculation of $esu1_nominal$ and $y1, sh1, ft1, fy1$, it is considered
 characteristic value $fsy1 = fs1/1.2$, from table 5.1, TBDY.
 $y1, sh1, ft1, fy1$, are also multiplied by $\text{Min}(1, 1.25 * (lb/ld)^{2/3})$, from 10.3.5, ASCE 41-17.
 with $fs1 = (fs_jacket * Asl, \text{ten}, \text{jacket} + fs_core * Asl, \text{ten}, \text{core}) / Asl, \text{ten} = 756.25$
 with $Es1 = (Es_jacket * Asl, \text{ten}, \text{jacket} + Es_core * Asl, \text{ten}, \text{core}) / Asl, \text{ten} = 200000.00$
 $y2 = 0.0025$
 $sh2 = 0.008$
 $ft2 = 900.1904$
 $fy2 = 750.1586$
 $su2 = 0.032$
 using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
 and also multiplied by the shear_factor according to 15.7.1.4, with
 $\text{Shear_factor} = 1.00$
 $lo/lou, \min = lb/lb, \min = 1.00$
 $su2 = 0.4 * esu2_nominal ((5.5), TBDY) = 0.032$
 From table 5A.1, TBDY: $esu2_nominal = 0.08$,
 For calculation of $esu2_nominal$ and $y2, sh2, ft2, fy2$, it is considered
 characteristic value $fsy2 = fs2/1.2$, from table 5.1, TBDY.
 $y1, sh1, ft1, fy1$, are also multiplied by $\text{Min}(1, 1.25 * (lb/ld)^{2/3})$, from 10.3.5, ASCE 41-17.
 with $fs2 = (fs_jacket * Asl, \text{com}, \text{jacket} + fs_core * Asl, \text{com}, \text{core}) / Asl, \text{com} = 750.1586$
 with $Es2 = (Es_jacket * Asl, \text{com}, \text{jacket} + Es_core * Asl, \text{com}, \text{core}) / Asl, \text{com} = 200000.00$
 $yv = 0.0025$
 $shv = 0.008$
 $ftv = 902.993$
 $fyv = 752.4941$
 $suv = 0.032$
 using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
 and also multiplied by the shear_factor according to 15.7.1.4, with
 $\text{Shear_factor} = 1.00$
 $lo/lou, \min = lb/ld = 1.00$
 $suv = 0.4 * esuv_nominal ((5.5), TBDY) = 0.032$
 From table 5A.1, TBDY: $esuv_nominal = 0.08$,
 considering characteristic value $fsyv = fsv/1.2$, from table 5.1, TBDY
 For calculation of $esuv_nominal$ and yv, shv, ftv, fyv , it is considered
 characteristic value $fsyv = fsv/1.2$, from table 5.1, TBDY.
 $y1, sh1, ft1, fy1$, are also multiplied by $\text{Min}(1, 1.25 * (lb/ld)^{2/3})$, from 10.3.5, ASCE 41-17.
 with $fsv = (fs_jacket * Asl, \text{mid}, \text{jacket} + fs_mid * Asl, \text{mid}, \text{core}) / Asl, \text{mid} = 752.4941$
 with $Es_v = (Es_jacket * Asl, \text{mid}, \text{jacket} + Es_mid * Asl, \text{mid}, \text{core}) / Asl, \text{mid} = 200000.00$
 $1 = Asl, \text{ten} / (b * d) * (fs1 / fc) = 0.05777595$
 $2 = Asl, \text{com} / (b * d) * (fs2 / fc) = 0.09216477$
 $v = Asl, \text{mid} / (b * d) * (fsv / fc) = 0.09996047$
 and confined core properties:
 $b = 890.00$
 $d = 677.00$
 $d' = 13.00$
 $fcc (5A.2, TBDY) = 30.00$
 $cc (5A.5, TBDY) = 0.002$
 $c = \text{confinement factor} = 1.00$
 $1 = Asl, \text{ten} / (b * d) * (fs1 / fc) = 0.06440379$

$$2 = A_{sl,com}/(b*d)*(f_{s2}/f_c) = 0.10273757$$

$$v = A_{sl,mid}/(b*d)*(f_{sv}/f_c) = 0.11142757$$

Case/Assumption: Unconfined full section - Steel rupture

' satisfies Eq. (4.3)

---->

$v < v_{s,y2}$ - LHS eq.(4.5) is not satisfied

---->

$v < v_{s,c}$ - RHS eq.(4.5) is satisfied

---->

$$s_u(4.8) = 0.15115045$$

$$\mu_u = M_{Rc}(4.15) = 2.0419E+009$$

$$u = s_u(4.1) = 5.3321191E-005$$

Calculation of ratio l_b/l_d

Adequate Lap Length: $l_b/l_d \geq 1$

Calculation of μ_{u2} -

Calculation of ultimate curvature μ_u according to 4.1, Biskinis/Fardis 2013:

$$u = 6.8287974E-005$$

$$\mu_u = 2.1636E+009$$

with full section properties:

$$b = 450.00$$

$$d = 707.00$$

$$d' = 43.00$$

$$v = 0.00217843$$

$$N = 20792.05$$

$$f_c = 30.00$$

$$\alpha_{co}(5A.5, TBDY) = 0.002$$

$$\text{Final value of } \alpha_{cu}: \alpha_{cu}^* = \text{shear_factor} * \text{Max}(\alpha_{cu}, \alpha_{cc}) = 0.00832321$$

The Shear_factor is considered equal to 1 (pure moment strength)

$$\text{From (5.4b), TBDY: } \alpha_{cu} = 0.00832321$$

$$\alpha_{we}(5.4c) = 0.01453958$$

$$\alpha_{ase}((5.4d), TBDY) = (\alpha_{ase1} * A_{ext} + \alpha_{ase2} * A_{int}) / A_{sec} = 0.53375773$$

$$\alpha_{ase1} = \text{Max}(((A_{conf,max1} - A_{noConf1}) / A_{conf,max1}) * (A_{conf,min1} / A_{conf,max1}), 0) = 0.53375773$$

The definitions of A_{noConf} , $A_{conf,min}$ and $A_{conf,max}$ are derived from generalization of the rectangular sections confinement, which is expressed by (5.4d).

The generalization is done according to Mander, J., Priestley, M., and Park, R. (1988)

"Theoretical Stress-Strain Model for Confined Concrete."

J. Struct. Eng., 10.1061/(ASCE)0733-9445(1988)114:8(1804), 1804-1826.

$A_{conf,max1} = 464100.00$ is the confined core area at levels of member with hoops and

is calculated as the area of core enclosed by the center lines of the external perimeter hoops.

$A_{conf,min1} = 395025.00$ is the confined core area at midway between the levels of hoops and

is calculated by reducing all the dimensions of the area $A_{conf,max1}$ by a length equal to half the clear spacing between external hoops.

$A_{noConf1} = 173066.667$ is the unconfined external core area which is equal to $b_i^2/6$ as defined at (A.2).

$$\alpha_{ase2}(\geq \alpha_{ase1}) = \text{Max}(((A_{conf,max2} - A_{noConf2}) / A_{conf,max2}) * (A_{conf,min2} / A_{conf,max2}), 0) = 0.53375773$$

The definitions of A_{noConf} , $A_{conf,min}$ and $A_{conf,max}$ are derived from generalization of the rectangular sections confinement, which is expressed by (5.4d).

The generalization is done according to Mander, J., Priestley, M., and Park, R. (1988)

"Theoretical Stress-Strain Model for Confined Concrete."

J. Struct. Eng., 10.1061/(ASCE)0733-9445(1988)114:8(1804), 1804-1826.

$A_{conf,max2} = 252164.00$ is the confined core area at levels of member with hoops and

is calculated as the area of core enclosed by the center lines of the internal perimeter hoops.

$A_{conf,min2} = 111441.00$ is the confined core area at midway between the levels of hoops and

is calculated by reducing all the dimensions of the area $A_{conf,max2}$ by a length equal to half the clear spacing between internal hoops.

$A_{noConf2} = 110709.333$ is the unconfined internal core area which is equal to $b_i^2/6$ as defined at (A.2).

$$p_{sh,min} * F_{ywe} = \text{Min}(p_{sh,x} * F_{ywe}, p_{sh,y} * F_{ywe}) = 2.724$$

Expression (5.4d) for $p_{sh,min} * F_{ywe}$ has been multiplied by 0.3 according to 15.7.1.3 for members without

earthquake detailing (90° closed stirrups)

psh_x*Fywe = psh1*Fywe1+ps2*Fywe2 = 2.724
psh1 ((5.4d), TBDY) = Lstir1*Astir1/(Asec*s1) = 0.00301593
Lstir1 (Length of stirrups along Y) = 2160.00
Astir1 (stirrups area) = 78.53982
psh2 (5.4d) = Lstir2*Astir2/(Asec*s2) = 0.00056047
Lstir2 (Length of stirrups along Y) = 1568.00
Astir2 (stirrups area) = 50.26548

psh_y*Fywe = psh1*Fywe1+ps2*Fywe2 = 3.25416
psh1 ((5.4d), TBDY) = Lstir1*Astir1/(Asec*s1) = 0.00357443
Lstir1 (Length of stirrups along X) = 2560.00
Astir1 (stirrups area) = 78.53982
psh2 ((5.4d), TBDY) = Lstir2*Astir2/(Asec*s2) = 0.00070345
Lstir2 (Length of stirrups along X) = 1968.00
Astir2 (stirrups area) = 50.26548

Asec = 562500.00

s1 = 100.00

s2 = 250.00

fywe1 = 781.25

fywe2 = 656.25

fce = 30.00

From ((5.A5), TBDY), TBDY: cc = 0.002

c = confinement factor = 1.00

y1 = 0.0025

sh1 = 0.008

ft1 = 900.1904

fy1 = 750.1586

su1 = 0.032

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00

lo/lou,min = lb/lb = 1.00

su1 = 0.4*esu1_nominal ((5.5), TBDY) = 0.032

From table 5A.1, TBDY: esu1_nominal = 0.08,

For calculation of esu1_nominal and y1, sh1,ft1,fy1, it is considered
characteristic value fsy1 = fs1/1.2, from table 5.1, TBDY.

y1, sh1,ft1,fy1, are also multiplied by $\text{Min}(1, 1.25 \cdot (lb/lb)^{2/3})$, from 10.3.5, ASCE 41-17.

with fs1 = (fs,jacket*Asl,ten,jacket + fs,core*Asl,ten,core)/Asl,ten = 750.1586

with Es1 = (Es,jacket*Asl,ten,jacket + Es,core*Asl,ten,core)/Asl,ten = 200000.00

y2 = 0.0025

sh2 = 0.008

ft2 = 907.50

fy2 = 756.25

su2 = 0.032

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00

lo/lou,min = lb/lb,min = 1.00

su2 = 0.4*esu2_nominal ((5.5), TBDY) = 0.032

From table 5A.1, TBDY: esu2_nominal = 0.08,

For calculation of esu2_nominal and y2, sh2,ft2,fy2, it is considered
characteristic value fsy2 = fs2/1.2, from table 5.1, TBDY.

y1, sh1,ft1,fy1, are also multiplied by $\text{Min}(1, 1.25 \cdot (lb/lb)^{2/3})$, from 10.3.5, ASCE 41-17.

with fs2 = (fs,jacket*Asl,com,jacket + fs,core*Asl,com,core)/Asl,com = 756.25

with Es2 = (Es,jacket*Asl,com,jacket + Es,core*Asl,com,core)/Asl,com = 200000.00

yv = 0.0025

shv = 0.008

ftv = 902.993

fyv = 752.4941

suv = 0.032

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00

lo/lou,min = lb/lb = 1.00

$suv = 0.4 * esuv_nominal ((5.5), TBDY) = 0.032$
 From table 5A.1, TBDY: $esuv_nominal = 0.08$,
 considering characteristic value $fsyv = fsv/1.2$, from table 5.1, TBDY
 For calculation of $esuv_nominal$ and yv , shv , ftv , fyv , it is considered
 characteristic value $fsyv = fsv/1.2$, from table 5.1, TBDY.
 $y1$, $sh1$, $ft1$, $fy1$, are also multiplied by $Min(1, 1.25 * (lb/ld)^{2/3})$, from 10.3.5, ASCE 41-17.
 with $fsv = (fs_jacket * Asl_mid_jacket + fs_mid * Asl_mid_core) / Asl_mid = 752.4941$
 with $Esv = (Es_jacket * Asl_mid_jacket + Es_mid * Asl_mid_core) / Asl_mid = 200000.00$
 $1 = Asl_ten / (b * d) * (fs1 / fc) = 0.19457006$
 $2 = Asl_com / (b * d) * (fs2 / fc) = 0.12197144$
 $v = Asl_mid / (b * d) * (fsv / fc) = 0.21102767$

and confined core properties:

$b = 390.00$
 $d = 677.00$
 $d' = 13.00$
 $fcc (5A.2, TBDY) = 30.00$
 $cc (5A.5, TBDY) = 0.002$
 $c = \text{confinement factor} = 1.00$
 $1 = Asl_ten / (b * d) * (fs1 / fc) = 0.23445239$
 $2 = Asl_com / (b * d) * (fs2 / fc) = 0.14697275$
 $v = Asl_mid / (b * d) * (fsv / fc) = 0.25428343$

Case/Assumption: Unconfined full section - Steel rupture
 ' satisfies Eq. (4.3)

--->
 $v < vs_y2$ - LHS eq.(4.5) is not satisfied

--->
 $v < vs_c$ - RHS eq.(4.5) is satisfied
 --->

$su (4.8) = 0.33719414$
 $Mu = MRc (4.15) = 2.1636E+009$
 $u = su (4.1) = 6.8287974E-005$

Calculation of ratio lb/ld

Adequate Lap Length: $lb/ld \geq 1$

Calculation of Shear Strength $Vr = Min(Vr1, Vr2) = 1.2916E+006$

Calculation of Shear Strength at edge 1, $Vr1 = 1.2916E+006$

$Vr1 = VCol ((10.3), ASCE 41-17) = knl * VColO$

$VColO = 1.2916E+006$

$knl = 1$ (zero step-static loading)

NOTE: In expression (10-3) ' $Vs = Av * fy * d / s$ ' is replaced by ' $Vs + f * Vf$ '
 where Vf is the contribution of FRPs (11.3), ACI 440).

$= 1$ (normal-weight concrete)
 Mean concrete strength: $fc' = (fc'_jacket * Area_jacket + fc'_core * Area_core) / Area_section = 27.20$, but $fc'^{0.5} \leq 8.3$
 MPa (22.5.3.1, ACI 318-14)

$M/Vd = 2.00$

$Mu = 5174.584$

$Vu = 8.5087964E-020$

$d = 0.8 * h = 600.00$

$Nu = 20792.05$

$Ag = 337500.00$

From (11.5.4.8), ACI 318-14: $Vs = Vs_jacket + Vs_core = 1.0354E+006$

where:

$Vs_jacket = Vs_j1 + Vs_j2 = 942477.796$

$Vs_j1 = 589048.623$ is calculated for section web jacket, with:

$d = 600.00$

$Av = 157079.633$

$fy = 625.00$

$s = 100.00$

$V_{s,j1}$ is multiplied by $Col,j1 = 1.00$
 $s/d = 0.16666667$
 $V_{s,j2} = 353429.174$ is calculated for section flange jacket, with:
 $d = 360.00$
 $A_v = 157079.633$
 $f_y = 625.00$
 $s = 100.00$
 $V_{s,j2}$ is multiplied by $Col,j2 = 1.00$
 $s/d = 0.27777778$
 $V_{s,core} = V_{s,c1} + V_{s,c2} = 92890.612$
 $V_{s,c1} = 92890.612$ is calculated for section web core, with:
 $d = 440.00$
 $A_v = 100530.965$
 $f_y = 525.00$
 $s = 250.00$
 $V_{s,c1}$ is multiplied by $Col,c1 = 1.00$
 $s/d = 0.56818182$
 $V_{s,c2} = 0.00$ is calculated for section flange core, with:
 $d = 200.00$
 $A_v = 100530.965$
 $f_y = 525.00$
 $s = 250.00$
 $V_{s,c2}$ is multiplied by $Col,c2 = 0.00$
 $s/d = 1.25$
 $V_f ((11-3)-(11.4), ACI 440) = 0.00$
 From (11-11), ACI 440: $V_s + V_f \leq 935437.922$
 $bw = 450.00$

Calculation of Shear Strength at edge 2, $V_{r2} = 1.2916E+006$
 $V_{r2} = V_{Col} ((10.3), ASCE 41-17) = knl * V_{Col0}$
 $V_{Col0} = 1.2916E+006$
 $knl = 1$ (zero step-static loading)

NOTE: In expression (10-3) ' $V_s = A_v * f_y * d / s$ ' is replaced by ' $V_s + f * V_f$ '
 where V_f is the contribution of FRPs (11.3), ACI 440).

$= 1$ (normal-weight concrete)
 Mean concrete strength: $f'_c = (f'_{c,jacket} * Area_{jacket} + f'_{c,core} * Area_{core}) / Area_{section} = 27.20$, but $f'_c^{0.5} \leq 8.3$
 MPa (22.5.3.1, ACI 318-14)
 $M/Vd = 2.00$
 $M_u = 5174.584$
 $V_u = 8.5087964E-020$
 $d = 0.8 * h = 600.00$
 $N_u = 20792.05$
 $A_g = 337500.00$
 From (11.5.4.8), ACI 318-14: $V_s = V_{s,jacket} + V_{s,core} = 1.0354E+006$
 where:
 $V_{s,jacket} = V_{s,j1} + V_{s,j2} = 942477.796$
 $V_{s,j1} = 589048.623$ is calculated for section web jacket, with:
 $d = 600.00$
 $A_v = 157079.633$
 $f_y = 625.00$
 $s = 100.00$
 $V_{s,j1}$ is multiplied by $Col,j1 = 1.00$
 $s/d = 0.16666667$
 $V_{s,j2} = 353429.174$ is calculated for section flange jacket, with:
 $d = 360.00$
 $A_v = 157079.633$
 $f_y = 625.00$
 $s = 100.00$
 $V_{s,j2}$ is multiplied by $Col,j2 = 1.00$
 $s/d = 0.27777778$
 $V_{s,core} = V_{s,c1} + V_{s,c2} = 92890.612$
 $V_{s,c1} = 92890.612$ is calculated for section web core, with:
 $d = 440.00$
 $A_v = 100530.965$

$f_y = 525.00$
 $s = 250.00$
 $V_{s,c1}$ is multiplied by $Col,c1 = 1.00$
 $s/d = 0.56818182$
 $V_{s,c2} = 0.00$ is calculated for section flange core, with:
 $d = 200.00$
 $A_v = 100530.965$
 $f_y = 525.00$
 $s = 250.00$
 $V_{s,c2}$ is multiplied by $Col,c2 = 0.00$
 $s/d = 1.25$
 $V_f ((11-3)-(11.4), ACI 440) = 0.00$
 From (11-11), ACI 440: $V_s + V_f \leq 935437.922$
 $bw = 450.00$

End Of Calculation of Shear Capacity ratio for element: column JTC1 of floor 1
 At local axis: 3

Start Of Calculation of Shear Capacity ratio for element: column JTC1 of floor 1
 At Shear local axis: 2
 (Bending local axis: 3)
 Section Type: rcjtcs

Constant Properties

Knowledge Factor, $\phi = 0.80$
 Mean strength values are used for both shear and moment calculations.
 Consequently:
 Jacket
 New material of Secondary Member: Concrete Strength, $f_c = f_{cm} = 30.00$
 New material of Secondary Member: Steel Strength, $f_s = f_{sm} = 625.00$
 Concrete Elasticity, $E_c = 25742.96$
 Steel Elasticity, $E_s = 200000.00$
 Existing Column
 Existing material of Secondary Member: Concrete Strength, $f_c = f_{cm} = 24.00$
 Existing material of Secondary Member: Steel Strength, $f_s = f_{sm} = 525.00$
 Concrete Elasticity, $E_c = 23025.204$
 Steel Elasticity, $E_s = 200000.00$
 #####
 Note: Especially for the calculation of moment strengths,
 the above steel re-bar strengths are multiplied by 1.25 according to R18.6.5, ACI 318-14
 Jacket
 New material: Steel Strength, $f_s = 1.25 \cdot f_{sm} = 781.25$
 Existing Column
 Existing material: Steel Strength, $f_s = 1.25 \cdot f_{sm} = 656.25$
 #####
 Max Height, $H_{max} = 750.00$
 Min Height, $H_{min} = 450.00$
 Max Width, $W_{max} = 950.00$
 Min Width, $W_{min} = 450.00$
 Eccentricity, $Ecc = 250.00$
 Jacket Thickness, $t_j = 100.00$
 Cover Thickness, $c = 25.00$
 Mean Confinement Factor overall section = 1.00
 Element Length, $L = 3000.00$
 Secondary Member
 Smooth Bars
 Ductile Steel
 Without Detailing for Earthquake Resistance (including stirrups not closed at 135°)
 Longitudinal Bars With Ends Lapped Starting at the End Sections
 Adequate Lap Length ($l_o/l_{ou,min} \geq 1$)
 No FRP Wrapping

Stepwise Properties

At local axis: 2

EDGE -A-

Shear Force, $V_a = 5.2099631E-036$

EDGE -B-

Shear Force, $V_b = -5.2099631E-036$

BOTH EDGES

Axial Force, $F = -20792.05$

Longitudinal Reinforcement Area Distribution (in 2 divisions)

-Tension: $A_{st} = 0.00$

-Compression: $A_{sc} = 6691.592$

Longitudinal Reinforcement Area Distribution (in 3 divisions)

-Tension: $A_{st,ten} = 1539.38$

-Compression: $A_{sc,com} = 1539.38$

-Middle: $A_{sl,mid} = 3612.832$

Calculation of Shear Capacity ratio, $V_e/V_r = 1.08994$

Member Controlled by Shear ($V_e/V_r > 1$)

Calculation of Shear Demand from fig. R18.6.5, ACI 318-14 $V_e = (M_{pr1} + M_{pr2})/l_n = 1.7820E+006$ with

$M_{pr1} = \text{Max}(\mu_{1+}, \mu_{1-}) = 2.6730E+009$

$\mu_{1+} = 2.6730E+009$, is the ultimate moment strength at the edge 1 of the member in the actual moment direction which is defined for the static loading combination

$\mu_{1-} = 2.6730E+009$, is the ultimate moment strength at the edge 1 of the member in the opposite moment direction which is defined for the static loading combination

$M_{pr2} = \text{Max}(\mu_{2+}, \mu_{2-}) = 2.6730E+009$

$\mu_{2+} = 2.6730E+009$, is the ultimate moment strength at the edge 2 of the member in the actual moment direction which is defined for the static loading combination

$\mu_{2-} = 2.6730E+009$, is the ultimate moment strength at the edge 2 of the member in the opposite moment direction which is defined for the static loading combination

Calculation of μ_{1+}

Calculation of ultimate curvature μ according to 4.1, Biskinis/Fardis 2013:

$\mu = 4.9274896E-005$

$M_u = 2.6730E+009$

with full section properties:

$b = 450.00$

$d = 907.00$

$d' = 43.00$

$v = 0.00169807$

$N = 20792.05$

$f_c = 30.00$

α_0 (5A.5, TBDY) = 0.002

Final value of μ : $\mu^* = \text{shear_factor} * \text{Max}(\mu_c, \mu_{cc}) = 0.00832321$

The Shear_factor is considered equal to 1 (pure moment strength)

From (5.4b), TBDY: $\mu_c = 0.00832321$

we (5.4c) = 0.01453958

α_{se} ((5.4d), TBDY) = $(\alpha_{se1} * A_{ext} + \alpha_{se2} * A_{int}) / A_{sec} = 0.53375773$

$\alpha_{se1} = \text{Max}(((A_{conf,max1} - A_{noConf1}) / A_{conf,max1}) * (A_{conf,min1} / A_{conf,max1}), 0) = 0.53375773$

The definitions of A_{noConf} , $A_{conf,min}$ and $A_{conf,max}$ are derived from generalization of the rectangular sections confinement, which is expressed by (5.4d).

The generalization is done according to Mander, J., Priestley, M., and Park, R. (1988)

"Theoretical Stress-Strain Model for Confined Concrete."

J. Struct. Eng., 10.1061/(ASCE)0733-9445(1988)114:8(1804), 1804-1826.

$A_{conf,max1} = 464100.00$ is the confined core area at levels of member with hoops and

is calculated as the area of core enclosed by the center lines of the external perimeter hoops.

$A_{conf,min1} = 395025.00$ is the confined core area at midway between the levels of hoops and

is calculated by reducing all the dimensions of the area $A_{conf,max1}$ by a length equal to half the clear spacing between external hoops.

$A_{noConf1} = 173066.667$ is the unconfined external core area which is equal to $b_i^2/6$ as defined at (A.2).
 $ase2 (>=ase1) = \text{Max}(((A_{conf,max2}-A_{noConf2})/A_{conf,max2})*(A_{conf,min2}/A_{conf,max2}),0) = 0.53375773$

The definitions of A_{noConf} , $A_{conf,min}$ and $A_{conf,max}$ are derived from generalization of the rectangular sections confinement, which is expressed by (5.4d).

The generalization is done according to Mander, J., Priestley, M., and Park, R. (1988) "Theoretical Stress-Strain Model for Confined Concrete."

J. Struct. Eng., 10.1061/(ASCE)0733-9445(1988)114:8(1804), 1804-1826.

$A_{conf,max2} = 252164.00$ is the confined core area at levels of member with hoops and is calculated as the area of core enclosed by the center lines of the internal perimeter hoops.

$A_{conf,min2} = 111441.00$ is the confined core area at midway between the levels of hoops and is calculated by reducing all the dimensions of the area $A_{conf,max2}$ by a length equal to half the clear spacing between internal hoops.

$A_{noConf2} = 110709.333$ is the unconfined internal core area which is equal to $b_i^2/6$ as defined at (A.2).
 $psh,min*F_{ywe} = \text{Min}(psh,x*F_{ywe}, psh,y*F_{ywe}) = 2.724$

Expression (5.4d) for $psh,min*F_{ywe}$ has been multiplied by 0.3 according to 15.7.1.3 for members without earthquake detailing (90° closed stirrups)

 $psh_x*F_{ywe} = psh1*F_{ywe1} + ps2*F_{ywe2} = 2.724$
 $psh1 ((5.4d), TBDY) = L_{stir1}*A_{stir1}/(A_{sec}*s1) = 0.00301593$
 L_{stir1} (Length of stirrups along Y) = 2160.00
 A_{stir1} (stirrups area) = 78.53982
 $psh2 ((5.4d)) = L_{stir2}*A_{stir2}/(A_{sec}*s2) = 0.00056047$
 L_{stir2} (Length of stirrups along Y) = 1568.00
 A_{stir2} (stirrups area) = 50.26548

 $psh_y*F_{ywe} = psh1*F_{ywe1} + ps2*F_{ywe2} = 3.25416$
 $psh1 ((5.4d), TBDY) = L_{stir1}*A_{stir1}/(A_{sec}*s1) = 0.00357443$
 L_{stir1} (Length of stirrups along X) = 2560.00
 A_{stir1} (stirrups area) = 78.53982
 $psh2 ((5.4d), TBDY) = L_{stir2}*A_{stir2}/(A_{sec}*s2) = 0.00070345$
 L_{stir2} (Length of stirrups along X) = 1968.00
 A_{stir2} (stirrups area) = 50.26548

 $A_{sec} = 562500.00$

$s1 = 100.00$

$s2 = 250.00$

$f_{ywe1} = 781.25$

$f_{ywe2} = 656.25$

$f_{ce} = 30.00$

From ((5.A5), TBDY), TBDY: $cc = 0.002$

c = confinement factor = 1.00

$y1 = 0.0025$

$sh1 = 0.008$

$ft1 = 907.50$

$fy1 = 756.25$

$su1 = 0.032$

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor and also multiplied by the shear_factor according to 15.7.1.4, with Shear_factor = 1.00

$l_o/l_{ou,min} = l_b/l_d = 1.00$

$su1 = 0.4*es_{u1,nominal} ((5.5), TBDY) = 0.032$

From table 5A.1, TBDY: $es_{u1,nominal} = 0.08$,

For calculation of $es_{u1,nominal}$ and $y1, sh1, ft1, fy1$, it is considered characteristic value $fs_{y1} = fs_{y1}/1.2$, from table 5.1, TBDY.

$y1, sh1, ft1, fy1$, are also multiplied by $\text{Min}(1, 1.25*(l_b/l_d)^{2/3})$, from 10.3.5, ASCE 41-17.

with $fs_1 = (f_{s,jacket}*A_{s,ten,jacket} + f_{s,core}*A_{s,ten,core})/A_{s,ten} = 756.25$

with $Es_1 = (E_{s,jacket}*A_{s,ten,jacket} + E_{s,core}*A_{s,ten,core})/A_{s,ten} = 200000.00$

$y2 = 0.0025$

$sh2 = 0.008$

$ft2 = 907.50$

$fy2 = 756.25$

$su2 = 0.032$

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor and also multiplied by the shear_factor according to 15.7.1.4, with Shear_factor = 1.00

```

lo/lou,min = lb/lbmin = 1.00
su2 = 0.4*esu2,nominal ((5.5), TBDY) = 0.032
From table 5A.1, TBDY: esu2,nominal = 0.08,
For calculation of esu2,nominal and y2, sh2,ft2,fy2, it is considered
characteristic value fsy2 = fs2/1.2, from table 5.1, TBDY.
y1, sh1,ft1,fy1, are also multiplied by Min(1,1.25*(lb/ld)2/3), from 10.3.5, ASCE 41-17.
with fs2 = (fsjacket*Aslcom,jacket + fscore*Aslcom,core)/Aslcom = 756.25
with Es2 = (Esjacket*Aslcom,jacket + Escore*Aslcom,core)/Aslcom = 200000.00
yv = 0.0025
shv = 0.008
ftv = 899.1522
fyv = 749.2935
suv = 0.032
using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00
lo/lou,min = lb/ld = 1.00
suv = 0.4*esuvnominal ((5.5), TBDY) = 0.032
From table 5A.1, TBDY: esuvnominal = 0.08,
considering characteristic value fsyv = fsv/1.2, from table 5.1, TBDY
For calculation of esuvnominal and yv, shv,ftv,fyv, it is considered
characteristic value fsyv = fsv/1.2, from table 5.1, TBDY.
y1, sh1,ft1,fy1, are also multiplied by Min(1,1.25*(lb/ld)2/3), from 10.3.5, ASCE 41-17.
with fsv = (fsjacket*Aslmid,jacket + fsmid*Aslmid,core)/Aslmid = 749.2935
with Esv = (Esjacket*Aslmid,jacket + Esmid*Aslmid,core)/Aslmid = 200000.00
1 = Aslten/(b*d)*(fs1/fc) = 0.09507586
2 = Aslcom/(b*d)*(fs2/fc) = 0.09507586
v = Aslmid/(b*d)*(fsv/fc) = 0.22108466
and confined core properties:
b = 390.00
d = 877.00
d' = 13.00
fcc (5A.2, TBDY) = 30.00
cc (5A.5, TBDY) = 0.002
c = confinement factor = 1.00
1 = Aslten/(b*d)*(fs1/fc) = 0.11345559
2 = Aslcom/(b*d)*(fs2/fc) = 0.11345559
v = Aslmid/(b*d)*(fsv/fc) = 0.26382395
Case/Assumption: Unconfined full section - Steel rupture
'satisfies Eq. (4.3)
---->
v < vs,y2 - LHS eq.(4.5) is not satisfied
---->
v < vs,c - RHS eq.(4.5) is satisfied
---->
su (4.8) = 0.28399348
Mu = MRc (4.15) = 2.6730E+009
u = su (4.1) = 4.9274896E-005

```

Calculation of ratio lb/l_d

Adequate Lap Length: lb/l_d >= 1

Calculation of Mu1-

Calculation of ultimate curvature u according to 4.1, Biskinis/Fardis 2013:

u = 4.9274896E-005

Mu = 2.6730E+009

with full section properties:

b = 450.00

d = 907.00

$d' = 43.00$
 $v = 0.00169807$
 $N = 20792.05$
 $f_c = 30.00$
 $co(5A.5, TBDY) = 0.002$
 Final value of cu : $cu^* = shear_factor * Max(cu, cc) = 0.00832321$
 The Shear_factor is considered equal to 1 (pure moment strength)
 From (5.4b), TBDY: $cu = 0.00832321$
 $we(5.4c) = 0.01453958$
 $ase((5.4d), TBDY) = (ase1 * A_{ext} + ase2 * A_{int}) / A_{sec} = 0.53375773$
 $ase1 = Max(((A_{conf,max1} - A_{noConf1}) / A_{conf,max1}) * (A_{conf,min1} / A_{conf,max1}), 0) = 0.53375773$
 The definitions of A_{noConf} , $A_{conf,min}$ and $A_{conf,max}$ are derived from generalization of the rectangular sections confinement, which is expressed by (5.4d).
 The generalization is done according to Mander, J., Priestley, M., and Park, R. (1988) "Theoretical Stress-Strain Model for Confined Concrete."
 J. Struct. Eng., 10.1061/(ASCE)0733-9445(1988)114:8(1804), 1804-1826.
 $A_{conf,max1} = 464100.00$ is the confined core area at levels of member with hoops and is calculated as the area of core enclosed by the center lines of the external perimeter hoops.
 $A_{conf,min1} = 395025.00$ is the confined core area at midway between the levels of hoops and is calculated by reducing all the dimensions of the area $A_{conf,max1}$ by a length equal to half the clear spacing between external hoops.
 $A_{noConf1} = 173066.667$ is the unconfined external core area which is equal to $b_i^2/6$ as defined at (A.2).
 $ase2 (>= ase1) = Max(((A_{conf,max2} - A_{noConf2}) / A_{conf,max2}) * (A_{conf,min2} / A_{conf,max2}), 0) = 0.53375773$
 The definitions of A_{noConf} , $A_{conf,min}$ and $A_{conf,max}$ are derived from generalization of the rectangular sections confinement, which is expressed by (5.4d).
 The generalization is done according to Mander, J., Priestley, M., and Park, R. (1988) "Theoretical Stress-Strain Model for Confined Concrete."
 J. Struct. Eng., 10.1061/(ASCE)0733-9445(1988)114:8(1804), 1804-1826.
 $A_{conf,max2} = 252164.00$ is the confined core area at levels of member with hoops and is calculated as the area of core enclosed by the center lines of the internal perimeter hoops.
 $A_{conf,min2} = 111441.00$ is the confined core area at midway between the levels of hoops and is calculated by reducing all the dimensions of the area $A_{conf,max2}$ by a length equal to half the clear spacing between internal hoops.
 $A_{noConf2} = 110709.333$ is the unconfined internal core area which is equal to $b_i^2/6$ as defined at (A.2).
 $psh,min * F_{ywe} = Min(psh,x * F_{ywe}, psh,y * F_{ywe}) = 2.724$
 Expression (5.4d) for $psh,min * F_{ywe}$ has been multiplied by 0.3 according to 15.7.1.3 for members without earthquake detailing (90° closed stirrups)

$psh,x * F_{ywe} = psh1 * F_{ywe1} + ps2 * F_{ywe2} = 2.724$
 $psh1((5.4d), TBDY) = L_{stir1} * A_{stir1} / (A_{sec} * s1) = 0.00301593$
 L_{stir1} (Length of stirrups along Y) = 2160.00
 A_{stir1} (stirrups area) = 78.53982
 $psh2(5.4d) = L_{stir2} * A_{stir2} / (A_{sec} * s2) = 0.00056047$
 L_{stir2} (Length of stirrups along Y) = 1568.00
 A_{stir2} (stirrups area) = 50.26548

$psh,y * F_{ywe} = psh1 * F_{ywe1} + ps2 * F_{ywe2} = 3.25416$
 $psh1((5.4d), TBDY) = L_{stir1} * A_{stir1} / (A_{sec} * s1) = 0.00357443$
 L_{stir1} (Length of stirrups along X) = 2560.00
 A_{stir1} (stirrups area) = 78.53982
 $psh2((5.4d), TBDY) = L_{stir2} * A_{stir2} / (A_{sec} * s2) = 0.00070345$
 L_{stir2} (Length of stirrups along X) = 1968.00
 A_{stir2} (stirrups area) = 50.26548

$A_{sec} = 562500.00$
 $s1 = 100.00$
 $s2 = 250.00$
 $f_{ywe1} = 781.25$
 $f_{ywe2} = 656.25$
 $f_{ce} = 30.00$
 From ((5.A5), TBDY), TBDY: $cc = 0.002$
 c = confinement factor = 1.00
 $y1 = 0.0025$
 $sh1 = 0.008$
 $ft1 = 907.50$
 $fy1 = 756.25$
 $su1 = 0.032$

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
 and also multiplied by the shear_factor according to 15.7.1.4, with
 Shear_factor = 1.00
 $l_o/l_{ou,min} = l_b/l_d = 1.00$
 $su_1 = 0.4 * esu_{1,nominal} ((5.5), TBDY) = 0.032$
 From table 5A.1, TBDY: $esu_{1,nominal} = 0.08$,
 For calculation of $esu_{1,nominal}$ and y_1, sh_1, ft_1, fy_1 , it is considered
 characteristic value $fsy_1 = fs_1/1.2$, from table 5.1, TBDY.
 y_1, sh_1, ft_1, fy_1 , are also multiplied by $Min(1, 1.25 * (l_b/l_d)^{2/3})$, from 10.3.5, ASCE 41-17.
 with $fs_1 = (fs_{jacket} * A_{sl,ten,jacket} + fs_{core} * A_{sl,ten,core}) / A_{sl,ten} = 756.25$
 with $Es_1 = (Es_{jacket} * A_{sl,ten,jacket} + Es_{core} * A_{sl,ten,core}) / A_{sl,ten} = 200000.00$
 $y_2 = 0.0025$
 $sh_2 = 0.008$
 $ft_2 = 907.50$
 $fy_2 = 756.25$
 $su_2 = 0.032$
 using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
 and also multiplied by the shear_factor according to 15.7.1.4, with
 Shear_factor = 1.00
 $l_o/l_{ou,min} = l_b/l_{b,min} = 1.00$
 $su_2 = 0.4 * esu_{2,nominal} ((5.5), TBDY) = 0.032$
 From table 5A.1, TBDY: $esu_{2,nominal} = 0.08$,
 For calculation of $esu_{2,nominal}$ and y_2, sh_2, ft_2, fy_2 , it is considered
 characteristic value $fsy_2 = fs_2/1.2$, from table 5.1, TBDY.
 y_1, sh_1, ft_1, fy_1 , are also multiplied by $Min(1, 1.25 * (l_b/l_d)^{2/3})$, from 10.3.5, ASCE 41-17.
 with $fs_2 = (fs_{jacket} * A_{sl,com,jacket} + fs_{core} * A_{sl,com,core}) / A_{sl,com} = 756.25$
 with $Es_2 = (Es_{jacket} * A_{sl,com,jacket} + Es_{core} * A_{sl,com,core}) / A_{sl,com} = 200000.00$
 $y_v = 0.0025$
 $sh_v = 0.008$
 $ft_v = 899.1522$
 $fy_v = 749.2935$
 $suv = 0.032$
 using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
 and also multiplied by the shear_factor according to 15.7.1.4, with
 Shear_factor = 1.00
 $l_o/l_{ou,min} = l_b/l_d = 1.00$
 $suv = 0.4 * esuv_{nominal} ((5.5), TBDY) = 0.032$
 From table 5A.1, TBDY: $esuv_{nominal} = 0.08$,
 considering characteristic value $fsyv = fsv/1.2$, from table 5.1, TBDY
 For calculation of $esuv_{nominal}$ and y_v, sh_v, ft_v, fy_v , it is considered
 characteristic value $fsyv = fsv/1.2$, from table 5.1, TBDY.
 y_1, sh_1, ft_1, fy_1 , are also multiplied by $Min(1, 1.25 * (l_b/l_d)^{2/3})$, from 10.3.5, ASCE 41-17.
 with $fsv = (fs_{jacket} * A_{sl,mid,jacket} + fs_{mid} * A_{sl,mid,core}) / A_{sl,mid} = 749.2935$
 with $Esv = (Es_{jacket} * A_{sl,mid,jacket} + Es_{mid} * A_{sl,mid,core}) / A_{sl,mid} = 200000.00$
 $1 = A_{sl,ten} / (b * d) * (fs_1 / fc) = 0.09507586$
 $2 = A_{sl,com} / (b * d) * (fs_2 / fc) = 0.09507586$
 $v = A_{sl,mid} / (b * d) * (fsv / fc) = 0.22108466$
 and confined core properties:
 $b = 390.00$
 $d = 877.00$
 $d' = 13.00$
 $f_{cc} (5A.2, TBDY) = 30.00$
 $cc (5A.5, TBDY) = 0.002$
 $c = \text{confinement factor} = 1.00$
 $1 = A_{sl,ten} / (b * d) * (fs_1 / fc) = 0.11345559$
 $2 = A_{sl,com} / (b * d) * (fs_2 / fc) = 0.11345559$
 $v = A_{sl,mid} / (b * d) * (fsv / fc) = 0.26382395$
 Case/Assumption: Unconfined full section - Steel rupture
 ' satisfies Eq. (4.3)
 --->
 $v < v_{s,y2}$ - LHS eq.(4.5) is not satisfied
 --->
 $v < v_{s,c}$ - RHS eq.(4.5) is satisfied
 --->
 $su (4.8) = 0.28399348$
 $Mu = MRc (4.15) = 2.6730E+009$
 $u = su (4.1) = 4.9274896E-005$

Calculation of ratio l_b/d

Adequate Lap Length: $l_b/d \geq 1$

Calculation of μ_{2+}

Calculation of ultimate curvature μ according to 4.1, Biskinis/Fardis 2013:

$$\mu = 4.9274896E-005$$

$$\mu_u = 2.6730E+009$$

with full section properties:

$$b = 450.00$$

$$d = 907.00$$

$$d' = 43.00$$

$$\nu = 0.00169807$$

$$N = 20792.05$$

$$f_c = 30.00$$

$$\omega (5A.5, TBDY) = 0.002$$

$$\text{Final value of } \mu_u: \mu_u^* = \text{shear_factor} * \text{Max}(\mu_u, \mu_c) = 0.00832321$$

The Shear_factor is considered equal to 1 (pure moment strength)

$$\text{From (5.4b), TBDY: } \mu_u = 0.00832321$$

$$\mu_w (5.4c) = 0.01453958$$

$$\mu_{ase} ((5.4d), TBDY) = (\mu_{ase1} * A_{ext} + \mu_{ase2} * A_{int}) / A_{sec} = 0.53375773$$

$$\mu_{ase1} = \text{Max}(((A_{conf,max1} - A_{noConf1}) / A_{conf,max1}) * (A_{conf,min1} / A_{conf,max1}), 0) = 0.53375773$$

The definitions of A_{noConf} , $A_{conf,min}$ and $A_{conf,max}$ are derived from generalization of the rectangular sections confinement, which is expressed by (5.4d).

The generalization is done according to Mander, J., Priestley, M., and Park, R. (1988)

"Theoretical Stress-Strain Model for Confined Concrete."

J. Struct. Eng., 10.1061/(ASCE)0733-9445(1988)114:8(1804), 1804-1826.

$A_{conf,max1} = 464100.00$ is the confined core area at levels of member with hoops and is calculated as the area of core enclosed by the center lines of the external perimeter hoops.

$A_{conf,min1} = 395025.00$ is the confined core area at midway between the levels of hoops and is calculated by reducing all the dimensions of the area $A_{conf,max1}$ by a length equal to half the clear spacing between external hoops.

$A_{noConf1} = 173066.667$ is the unconfined external core area which is equal to $b_i^2/6$ as defined at (A.2).

$$\mu_{ase2} (\geq \mu_{ase1}) = \text{Max}(((A_{conf,max2} - A_{noConf2}) / A_{conf,max2}) * (A_{conf,min2} / A_{conf,max2}), 0) = 0.53375773$$

The definitions of A_{noConf} , $A_{conf,min}$ and $A_{conf,max}$ are derived from generalization of the rectangular sections confinement, which is expressed by (5.4d).

The generalization is done according to Mander, J., Priestley, M., and Park, R. (1988)

"Theoretical Stress-Strain Model for Confined Concrete."

J. Struct. Eng., 10.1061/(ASCE)0733-9445(1988)114:8(1804), 1804-1826.

$A_{conf,max2} = 252164.00$ is the confined core area at levels of member with hoops and is calculated as the area of core enclosed by the center lines of the internal perimeter hoops.

$A_{conf,min2} = 111441.00$ is the confined core area at midway between the levels of hoops and is calculated by reducing all the dimensions of the area $A_{conf,max2}$ by a length equal to half the clear spacing between internal hoops.

$A_{noConf2} = 110709.333$ is the unconfined internal core area which is equal to $b_i^2/6$ as defined at (A.2).

$$p_{sh,min} * F_{ywe} = \text{Min}(p_{sh,x} * F_{ywe}, p_{sh,y} * F_{ywe}) = 2.724$$

Expression (5.4d) for $p_{sh,min} * F_{ywe}$ has been multiplied by 0.3 according to 15.7.1.3 for members without earthquake detailing (90° closed stirrups)

$$p_{sh,x} * F_{ywe} = p_{sh1} * F_{ywe1} + p_{sh2} * F_{ywe2} = 2.724$$

$$p_{sh1} ((5.4d), TBDY) = L_{stir1} * A_{stir1} / (A_{sec} * s_1) = 0.00301593$$

$$L_{stir1} \text{ (Length of stirrups along Y)} = 2160.00$$

$$A_{stir1} \text{ (stirrups area)} = 78.53982$$

$$p_{sh2} (5.4d) = L_{stir2} * A_{stir2} / (A_{sec} * s_2) = 0.00056047$$

$$L_{stir2} \text{ (Length of stirrups along Y)} = 1568.00$$

$$A_{stir2} \text{ (stirrups area)} = 50.26548$$

$$p_{sh,y} * F_{ywe} = p_{sh1} * F_{ywe1} + p_{sh2} * F_{ywe2} = 3.25416$$

$$p_{sh1} ((5.4d), TBDY) = L_{stir1} * A_{stir1} / (A_{sec} * s_1) = 0.00357443$$

Lstir1 (Length of stirrups along X) = 2560.00
 Astir1 (stirrups area) = 78.53982
 $psh2 ((5.4d), TBDY) = Lstir2 * Astir2 / (Asec * s2) = 0.00070345$
 Lstir2 (Length of stirrups along X) = 1968.00
 Astir2 (stirrups area) = 50.26548

Asec = 562500.00

s1 = 100.00

s2 = 250.00

fywe1 = 781.25

fywe2 = 656.25

fce = 30.00

From ((5.45), TBDY), TBDY: cc = 0.002

c = confinement factor = 1.00

y1 = 0.0025

sh1 = 0.008

ft1 = 907.50

fy1 = 756.25

su1 = 0.032

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
 and also multiplied by the shear_factor according to 15.7.1.4, with
 Shear_factor = 1.00

lo/lou,min = lb/ld = 1.00

su1 = 0.4*esu1_nominal ((5.5), TBDY) = 0.032

From table 5A.1, TBDY: esu1_nominal = 0.08,

For calculation of esu1_nominal and y1, sh1,ft1,fy1, it is considered
 characteristic value fsy1 = fs1/1.2, from table 5.1, TBDY.

y1, sh1,ft1,fy1, are also multiplied by $\text{Min}(1, 1.25 * (lb/ld)^{2/3})$, from 10.3.5, ASCE 41-17.

with fs1 = (fs,jacket*Asl,ten,jacket + fs,core*Asl,ten,core)/Asl,ten = 756.25

with Es1 = (Es,jacket*Asl,ten,jacket + Es,core*Asl,ten,core)/Asl,ten = 200000.00

y2 = 0.0025

sh2 = 0.008

ft2 = 907.50

fy2 = 756.25

su2 = 0.032

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
 and also multiplied by the shear_factor according to 15.7.1.4, with
 Shear_factor = 1.00

lo/lou,min = lb/lb,min = 1.00

su2 = 0.4*esu2_nominal ((5.5), TBDY) = 0.032

From table 5A.1, TBDY: esu2_nominal = 0.08,

For calculation of esu2_nominal and y2, sh2,ft2,fy2, it is considered
 characteristic value fsy2 = fs2/1.2, from table 5.1, TBDY.

y1, sh1,ft1,fy1, are also multiplied by $\text{Min}(1, 1.25 * (lb/ld)^{2/3})$, from 10.3.5, ASCE 41-17.

with fs2 = (fs,jacket*Asl,com,jacket + fs,core*Asl,com,core)/Asl,com = 756.25

with Es2 = (Es,jacket*Asl,com,jacket + Es,core*Asl,com,core)/Asl,com = 200000.00

yv = 0.0025

shv = 0.008

ftv = 899.1522

fyv = 749.2935

suv = 0.032

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
 and also multiplied by the shear_factor according to 15.7.1.4, with
 Shear_factor = 1.00

lo/lou,min = lb/ld = 1.00

suv = 0.4*esuv_nominal ((5.5), TBDY) = 0.032

From table 5A.1, TBDY: esuv_nominal = 0.08,

considering characteristic value fsyv = fsv/1.2, from table 5.1, TBDY

For calculation of esuv_nominal and yv, shv,ftv,fyv, it is considered
 characteristic value fsyv = fsv/1.2, from table 5.1, TBDY.

y1, sh1,ft1,fy1, are also multiplied by $\text{Min}(1, 1.25 * (lb/ld)^{2/3})$, from 10.3.5, ASCE 41-17.

with fsv = (fs,jacket*Asl,mid,jacket + fs,mid*Asl,mid,core)/Asl,mid = 749.2935

with Esv = (Es,jacket*Asl,mid,jacket + Es,mid*Asl,mid,core)/Asl,mid = 200000.00

1 = Asl,ten/(b*d)*(fs1/fc) = 0.09507586

2 = Asl,com/(b*d)*(fs2/fc) = 0.09507586

v = Asl,mid/(b*d)*(fsv/fc) = 0.22108466

and confined core properties:

```

b = 390.00
d = 877.00
d' = 13.00
fcc (5A.2, TBDY) = 30.00
cc (5A.5, TBDY) = 0.002
c = confinement factor = 1.00
1 = Asl,ten/(b*d)*(fs1/fc) = 0.11345559
2 = Asl,com/(b*d)*(fs2/fc) = 0.11345559
v = Asl,mid/(b*d)*(fsv/fc) = 0.26382395

```

Case/Assumption: Unconfined full section - Steel rupture
 ' satisfies Eq. (4.3)

```

---->
v < vs,y2 - LHS eq.(4.5) is not satisfied
---->
v < vs,c - RHS eq.(4.5) is satisfied
---->
su (4.8) = 0.28399348
Mu = MRc (4.15) = 2.6730E+009
u = su (4.1) = 4.9274896E-005

```

Calculation of ratio lb/d

Adequate Lap Length: lb/d >= 1

Calculation of Mu2-

Calculation of ultimate curvature u according to 4.1, Biskinis/Fardis 2013:
 u = 4.9274896E-005
 Mu = 2.6730E+009

with full section properties:

```

b = 450.00
d = 907.00
d' = 43.00
v = 0.00169807
N = 20792.05
fc = 30.00
co (5A.5, TBDY) = 0.002
Final value of cu: cu* = shear_factor * Max( cu, cc) = 0.00832321
The Shear_factor is considered equal to 1 (pure moment strength)
From (5.4b), TBDY: cu = 0.00832321
we (5.4c) = 0.01453958
ase ((5.4d), TBDY) = (ase1*Aext+ase2*Aint)/Asec = 0.53375773
ase1 = Max(((Aconf,max1-AnoConf1)/Aconf,max1)*(Aconf,min1/Aconf,max1),0) = 0.53375773
The definitions of AnoConf, Aconf,min and Aconf,max are derived from generalization
of the rectangular sections confinement, which is expressed by (5.4d).
The generalization is done according to Mander, J., Priestley, M., and Park, R. (1988)
"Theoretical Stress-Strain Model for Confined Concrete."
J. Struct. Eng., 10.1061/(ASCE)0733-9445(1988)114:8(1804), 1804-1826.
Aconf,max1 = 464100.00 is the confined core area at levels of member with hoops and
is calculated as the area of core enclosed by the center lines of the external perimeter hoops.
Aconf,min1 = 395025.00 is the confined core area at midway between the levels of hoops and
is calculated by reducing all the dimensions of the area Aconf,max1 by a length
equal to half the clear spacing between external hoops.
AnoConf1 = 173066.667 is the unconfined external core area which is equal to bi2/6 as defined at (A.2).
ase2 (>=ase1) = Max(((Aconf,max2-AnoConf2)/Aconf,max2)*(Aconf,min2/Aconf,max2),0) = 0.53375773
The definitions of AnoConf, Aconf,min and Aconf,max are derived from generalization
of the rectangular sections confinement, which is expressed by (5.4d).
The generalization is done according to Mander, J., Priestley, M., and Park, R. (1988)
"Theoretical Stress-Strain Model for Confined Concrete."
J. Struct. Eng., 10.1061/(ASCE)0733-9445(1988)114:8(1804), 1804-1826.
Aconf,max2 = 252164.00 is the confined core area at levels of member with hoops and

```


is calculated as the area of core enclosed by the center lines of the internal perimeter hoops.

$A_{conf,min2} = 111441.00$ is the confined core area at midway between the levels of hoops and

is calculated by reducing all the dimensions of the area $A_{conf,max2}$ by a length

equal to half the clear spacing between internal hoops.

$A_{noConf2} = 110709.333$ is the unconfined internal core area which is equal to $b_i^2/6$ as defined at (A.2).

$psh_{min} \cdot F_{ywe} = \min(psh_x \cdot F_{ywe}, psh_y \cdot F_{ywe}) = 2.724$

Expression (5.4d) for $psh_{min} \cdot F_{ywe}$ has been multiplied by 0.3 according to 15.7.1.3 for members without earthquake detailing (90° closed stirrups)

$psh_x \cdot F_{ywe} = psh1 \cdot F_{ywe1} + ps2 \cdot F_{ywe2} = 2.724$

$psh1$ ((5.4d), TBDY) = $L_{stir1} \cdot A_{stir1} / (A_{sec} \cdot s1) = 0.00301593$

L_{stir1} (Length of stirrups along Y) = 2160.00

A_{stir1} (stirrups area) = 78.53982

$psh2$ (5.4d) = $L_{stir2} \cdot A_{stir2} / (A_{sec} \cdot s2) = 0.00056047$

L_{stir2} (Length of stirrups along Y) = 1568.00

A_{stir2} (stirrups area) = 50.26548

$psh_y \cdot F_{ywe} = psh1 \cdot F_{ywe1} + ps2 \cdot F_{ywe2} = 3.25416$

$psh1$ ((5.4d), TBDY) = $L_{stir1} \cdot A_{stir1} / (A_{sec} \cdot s1) = 0.00357443$

L_{stir1} (Length of stirrups along X) = 2560.00

A_{stir1} (stirrups area) = 78.53982

$psh2$ ((5.4d), TBDY) = $L_{stir2} \cdot A_{stir2} / (A_{sec} \cdot s2) = 0.00070345$

L_{stir2} (Length of stirrups along X) = 1968.00

A_{stir2} (stirrups area) = 50.26548

$A_{sec} = 562500.00$

$s1 = 100.00$

$s2 = 250.00$

$f_{ywe1} = 781.25$

$f_{ywe2} = 656.25$

$f_{ce} = 30.00$

From ((5.A5), TBDY), TBDY: $cc = 0.002$

c = confinement factor = 1.00

$y1 = 0.0025$

$sh1 = 0.008$

$ft1 = 907.50$

$fy1 = 756.25$

$su1 = 0.032$

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor

and also multiplied by the shear_factor according to 15.7.1.4, with

Shear_factor = 1.00

$lo/lou,min = lb/ld = 1.00$

$su1 = 0.4 \cdot esu1_{nominal}$ ((5.5), TBDY) = 0.032

From table 5A.1, TBDY: $esu1_{nominal} = 0.08$,

For calculation of $esu1_{nominal}$ and $y1$, $sh1$, $ft1$, $fy1$, it is considered

characteristic value $fsy1 = fs1/1.2$, from table 5.1, TBDY.

$y1$, $sh1$, $ft1$, $fy1$, are also multiplied by $\min(1, 1.25 \cdot (lb/ld)^{2/3})$, from 10.3.5, ASCE 41-17.

with $fs1 = (fs_{jacket} \cdot A_{sl,ten,jacket} + fs_{core} \cdot A_{sl,ten,core}) / A_{sl,ten} = 756.25$

with $Es1 = (Es_{jacket} \cdot A_{sl,ten,jacket} + Es_{core} \cdot A_{sl,ten,core}) / A_{sl,ten} = 200000.00$

$y2 = 0.0025$

$sh2 = 0.008$

$ft2 = 907.50$

$fy2 = 756.25$

$su2 = 0.032$

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor

and also multiplied by the shear_factor according to 15.7.1.4, with

Shear_factor = 1.00

$lo/lou,min = lb/lb,min = 1.00$

$su2 = 0.4 \cdot esu2_{nominal}$ ((5.5), TBDY) = 0.032

From table 5A.1, TBDY: $esu2_{nominal} = 0.08$,

For calculation of $esu2_{nominal}$ and $y2$, $sh2$, $ft2$, $fy2$, it is considered

characteristic value $fsy2 = fs2/1.2$, from table 5.1, TBDY.

$y1$, $sh1$, $ft1$, $fy1$, are also multiplied by $\min(1, 1.25 \cdot (lb/ld)^{2/3})$, from 10.3.5, ASCE 41-17.

with $fs2 = (fs_{jacket} \cdot A_{sl,com,jacket} + fs_{core} \cdot A_{sl,com,core}) / A_{sl,com} = 756.25$

with $Es2 = (Es_{jacket} \cdot A_{sl,com,jacket} + Es_{core} \cdot A_{sl,com,core}) / A_{sl,com} = 200000.00$

$yv = 0.0025$

$shv = 0.008$

```

ftv = 899.1522
fyv = 749.2935
suv = 0.032
    using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
    and also multiplied by the shear_factor according to 15.7.1.4, with
    Shear_factor = 1.00
    lo/lo,min = lb/ld = 1.00
    suv = 0.4*esuv_nominal ((5.5), TBDY) = 0.032
    From table 5A.1, TBDY: esuv_nominal = 0.08,
    considering characteristic value fsyv = fsv/1.2, from table 5.1, TBDY
    For calculation of esuv_nominal and yv, shv,ftv,fyv, it is considered
    characteristic value fsyv = fsv/1.2, from table 5.1, TBDY.
    y1, sh1,ft1,fy1, are also multiplied by Min(1,1.25*(lb/ld)^2/3), from 10.3.5, ASCE 41-17.
    with fsv = (fsjacket*Asl,mid,jacket + fs,mid*Asl,mid,core)/Asl,mid = 749.2935
    with Esv = (Es,jacket*Asl,mid,jacket + Es,mid*Asl,mid,core)/Asl,mid = 200000.00
    1 = Asl,ten/(b*d)*(fs1/fc) = 0.09507586
    2 = Asl,com/(b*d)*(fs2/fc) = 0.09507586
    v = Asl,mid/(b*d)*(fsv/fc) = 0.22108466
and confined core properties:
b = 390.00
d = 877.00
d' = 13.00
fcc (5A.2, TBDY) = 30.00
cc (5A.5, TBDY) = 0.002
    c = confinement factor = 1.00
    1 = Asl,ten/(b*d)*(fs1/fc) = 0.11345559
    2 = Asl,com/(b*d)*(fs2/fc) = 0.11345559
    v = Asl,mid/(b*d)*(fsv/fc) = 0.26382395
Case/Assumption: Unconfined full section - Steel rupture
' satisfies Eq. (4.3)
--->
v < vs,y2 - LHS eq.(4.5) is not satisfied
--->
v < vs,c - RHS eq.(4.5) is satisfied
--->
su (4.8) = 0.28399348
Mu = MRc (4.15) = 2.6730E+009
u = su (4.1) = 4.9274896E-005
-----

Calculation of ratio lb/ld
-----
Adequate Lap Length: lb/ld >= 1
-----
-----
-----
Calculation of Shear Strength Vr = Min(Vr1,Vr2) = 1.6349E+006
-----
Calculation of Shear Strength at edge 1, Vr1 = 1.6349E+006
Vr1 = VCol ((10.3), ASCE 41-17) = knl*VCol0
VCol0 = 1.6349E+006
knl = 1 (zero step-static loading)
-----
NOTE: In expression (10-3) 'Vs = Av*fy*d/s' is replaced by 'Vs+ f*Vf'
where Vf is the contribution of FRPs (11.3), ACI 440).
-----
= 1 (normal-weight concrete)
Mean concrete strength: fc' = (fc'_jacket*Area_jacket + fc'_core*Area_core)/Area_section = 27.20, but fc'^0.5 <= 8.3
MPa (22.5.3.1, ACI 318-14)
M/Vd = 2.00
Mu = 4.16869
Vu = 5.2099631E-036
d = 0.8*h = 760.00
Nu = 20792.05
Ag = 427500.00
From (11.5.4.8), ACI 318-14: Vs = Vs,jacket + Vs,core = 1.2262E+006

```

where:

$$V_{sj,jacket} = V_{sj,1} + V_{sj,2} = 1.0996E+006$$

$V_{sj,1} = 353429.174$ is calculated for section web jacket, with:

$$d = 360.00$$

$$A_v = 157079.633$$

$$f_y = 625.00$$

$$s = 100.00$$

$V_{sj,1}$ is multiplied by $Col,j1 = 1.00$

$$s/d = 0.27777778$$

$V_{sj,2} = 746128.255$ is calculated for section flange jacket, with:

$$d = 760.00$$

$$A_v = 157079.633$$

$$f_y = 625.00$$

$$s = 100.00$$

$V_{sj,2}$ is multiplied by $Col,j2 = 1.00$

$$s/d = 0.13157895$$

$$V_{s,core} = V_{s,c1} + V_{s,c2} = 126669.016$$

$V_{s,c1} = 0.00$ is calculated for section web core, with:

$$d = 200.00$$

$$A_v = 100530.965$$

$$f_y = 525.00$$

$$s = 250.00$$

$V_{s,c1}$ is multiplied by $Col,c1 = 0.00$

$$s/d = 1.25$$

$V_{s,c2} = 126669.016$ is calculated for section flange core, with:

$$d = 600.00$$

$$A_v = 100530.965$$

$$f_y = 525.00$$

$$s = 250.00$$

$V_{s,c2}$ is multiplied by $Col,c2 = 1.00$

$$s/d = 0.41666667$$

$$V_f ((11-3)-(11.4), \text{ACI } 440) = 0.00$$

$$\text{From } (11-11), \text{ACI } 440: V_s + V_f \leq 1.1849E+006$$

$$bw = 450.00$$

Calculation of Shear Strength at edge 2, $V_{r2} = 1.6349E+006$

$$V_{r2} = V_{Col} ((10.3), \text{ASCE } 41-17) = knl * V_{Col0}$$

$$V_{Col0} = 1.6349E+006$$

$$knl = 1 \text{ (zero step-static loading)}$$

NOTE: In expression (10-3) ' $V_s = A_v * f_y * d / s$ ' is replaced by ' $V_s + f * V_f$ ' where V_f is the contribution of FRPs (11.3), ACI 440).

$$= 1 \text{ (normal-weight concrete)}$$

$$\text{Mean concrete strength: } f'_c = (f'_c_{jacket} * Area_{jacket} + f'_c_{core} * Area_{core}) / Area_{section} = 27.20, \text{ but } f'_c^{0.5} \leq 8.3 \text{ MPa (22.5.3.1, ACI 318-14)}$$

$$M/Vd = 2.00$$

$$\mu_u = 4.16869$$

$$V_u = 5.2099631E-036$$

$$d = 0.8 * h = 760.00$$

$$N_u = 20792.05$$

$$A_g = 427500.00$$

$$\text{From (11.5.4.8), ACI 318-14: } V_s = V_{sj,jacket} + V_{s,core} = 1.2262E+006$$

where:

$$V_{sj,jacket} = V_{sj,1} + V_{sj,2} = 1.0996E+006$$

$V_{sj,1} = 353429.174$ is calculated for section web jacket, with:

$$d = 360.00$$

$$A_v = 157079.633$$

$$f_y = 625.00$$

$$s = 100.00$$

$V_{sj,1}$ is multiplied by $Col,j1 = 1.00$

$$s/d = 0.27777778$$

$V_{sj,2} = 746128.255$ is calculated for section flange jacket, with:

$$d = 760.00$$

$$A_v = 157079.633$$

$$f_y = 625.00$$

$s = 100.00$
 $V_{s,j2}$ is multiplied by $Col,j2 = 1.00$
 $s/d = 0.13157895$
 $V_{s,core} = V_{s,c1} + V_{s,c2} = 126669.016$
 $V_{s,c1} = 0.00$ is calculated for section web core, with:
 $d = 200.00$
 $A_v = 100530.965$
 $f_y = 525.00$
 $s = 250.00$
 $V_{s,c1}$ is multiplied by $Col,c1 = 0.00$
 $s/d = 1.25$
 $V_{s,c2} = 126669.016$ is calculated for section flange core, with:
 $d = 600.00$
 $A_v = 100530.965$
 $f_y = 525.00$
 $s = 250.00$
 $V_{s,c2}$ is multiplied by $Col,c2 = 1.00$
 $s/d = 0.41666667$
 $V_f ((11-3)-(11.4), ACI 440) = 0.00$
 From (11-11), ACI 440: $V_s + V_f \leq 1.1849E+006$
 $bw = 450.00$

 End Of Calculation of Shear Capacity ratio for element: column JTC1 of floor 1
 At local axis: 2

 Start Of Calculation of Chord Rotation Capacity for element: column JTC1 of floor 1
 At local axis: 2
 Integration Section: (b)
 Section Type: rcjtcs

Constant Properties

 Knowledge Factor, $\phi = 0.80$
 Chord Rotation is generally considered as Deformation-Controlled Action according to Table C7-1, ASCE 41-17.
 Mean strengths are used for Deformation-Controlled Actions according to 7.5.1.3, ASCE 41-17
 Consequently:
 Jacket
 New material of Secondary Member: Concrete Strength, $f_c = f_{cm} = 30.00$
 New material of Secondary Member: Steel Strength, $f_s = f_{sm} = 625.00$
 Concrete Elasticity, $E_c = 25742.96$
 Steel Elasticity, $E_s = 200000.00$
 Existing Column
 Existing material of Secondary Member: Concrete Strength, $f_c = f_{cm} = 24.00$
 Existing material of Secondary Member: Steel Strength, $f_s = f_{sm} = 525.00$
 Concrete Elasticity, $E_c = 23025.204$
 Steel Elasticity, $E_s = 200000.00$
 Max Height, $H_{max} = 750.00$
 Min Height, $H_{min} = 450.00$
 Max Width, $W_{max} = 950.00$
 Min Width, $W_{min} = 450.00$
 Eccentricity, $E_{cc} = 250.00$
 Jacket Thickness, $t_j = 100.00$
 Cover Thickness, $c = 25.00$
 Element Length, $L = 3000.00$
 Secondary Member
 Smooth Bars
 Ductile Steel
 Without Detailing for Earthquake Resistance (including stirrups not closed at 135°)
 Longitudinal Bars With Ends Lapped Starting at the End Sections
 Adequate Lap Length ($l_b/d \geq 1$)
 No FRP Wrapping

Stepwise Properties

Bending Moment, $M = -2610.668$

Shear Force, $V2 = 8294.64$

Shear Force, $V3 = 1.96926$

Axial Force, $F = -22375.589$

Longitudinal Reinforcement Area Distribution (in 2 divisions)

-Tension: $As_{lt} = 0.00$

-Compression: $As_{lc} = 6691.592$

Longitudinal Reinforcement Area Distribution (in 3 divisions)

-Tension: $As_{l,ten} = 1539.38$

-Compression: $As_{l,com} = 2475.575$

-Middle: $As_{l,mid} = 2676.637$

Longitudinal External Reinforcement Area Distribution (in 3 divisions)

-Tension: $As_{l,ten,jacket} = 1231.504$

-Compression: $As_{l,com,jacket} = 1859.823$

-Middle: $As_{l,mid,jacket} = 2060.885$

Longitudinal Internal Reinforcement Area Distribution (in 3 divisions)

-Tension: $As_{l,ten,core} = 307.8761$

-Compression: $As_{l,com,core} = 615.7522$

-Middle: $As_{l,mid,core} = 615.7522$

Mean Diameter of Tension Reinforcement, $DbL = 16.57143$

Existing component: From table 7-7, ASCE 41_17: Final chord rotation Capacity $u_R = u = 0.02843959$
 $u = y + p = 0.03554949$

- Calculation of y -

$y = (M_y * L_s / 3) / E_{eff} = 0.00244091$ ((4.29), Biskinis Phd))

$M_y = 9.4108E+008$

$L_s = M/V$ (with $L_s > 0.1 * L$ and $L_s < 2 * L$) = 1325.708

From table 10.5, ASCE 41_17: $E_{eff} = factor * E_c * I_g = 1.7037E+014$

factor = 0.30

$A_g = 562500.00$

Mean concrete strength: $fc' = (fc'_{jacket} * Area_{jacket} + fc'_{core} * Area_{core}) / Area_{section} = 27.20$

$N = 22375.589$

$E_c * I_g = E_{c,jacket} * I_{g,jacket} + E_{c,core} * I_{g,core} = 5.6791E+014$

Calculation of Yielding Moment M_y

Calculation of y and M_y according to Annex 7 -

Assuming neutral axis within flange ($y < t/d$, compression zone rectangular) with:

flange width, $b = 950.00$

web width, $b_w = 450.00$

flange thickness, $t = 450.00$

$y = \min(y_{ten}, y_{com})$

$y_{ten} = 5.3416636E-006$

with $f_y = 601.9953$

$d = 707.00$

$y = 0.20298377$

$A = 0.01001826$

$B = 0.00468522$

with $pt = 0.00229194$

$pc = 0.00368581$

$pv = 0.00398517$

$N = 22375.589$

$b = 950.00$

$" = 0.06082037$

$y_{comp} = 1.4673137E-005$

with $f_c = 30.00$
 $E_c = 25742.96$
 $y = 0.20220547$
 $A = 0.00988351$
 $B = 0.00462988$
with $E_s = 200000.00$
CONFIRMATION: $y = 0.20298377 < t/d$

Calculation of ratio I_b/I_d

Adequate Lap Length: $I_b/I_d \geq 1$

- Calculation of p -

From table 10-8: $p = 0.03310857$

with:

- Columns not controlled by inadequate development or splicing along the clear height because $I_b/I_d \geq 1$

shear control ratio $V_y E / V_{col} E = 1.11674$

$d = d_{external} = 707.00$

$s = s_{external} = 0.00$

- $t = s_1 + s_2 + 2 * t_f / b_w * (f_{fe} / f_s) = 0.0035764$

jacket: $s_1 = A_{v1} * L_{stir1} / (s_1 * A_g) = 0.00301593$

$A_{v1} = 78.53982$, is the area of every stirrup parallel to loading (shear) direction

$L_{stir1} = 2160.00$, is the total Length of all stirrups parallel to loading (shear) direction

$s_1 = 100.00$

core: $s_2 = A_{v2} * L_{stir2} / (s_2 * A_g) = 0.00056047$

$A_{v2} = 50.26548$, is the area of every stirrup parallel to loading (shear) direction

$L_{stir2} = 1568.00$, is the total Length of all stirrups parallel to loading (shear) direction

$s_2 = 250.00$

The term $2 * t_f / b_w * (f_{fe} / f_s)$ is implemented to account for FRP contribution

where $f = 2 * t_f / b_w$ is FRP ratio (EC8 - 3, A.4.4.3(6)) and f_{fe} / f_s normalises f to steel strength

All these variables have already been given in Shear control ratio calculation.

For the normalisation f_s of jacket is used.

$NUD = 22375.589$

$A_g = 562500.00$

$f_{cE} = (f_{c,jacket} * Area_{jacket} + f_{c,core} * Area_{core}) / section_area = 27.20$

$f_{yE} = (f_{y,ext_Long_Reinf} * Area_{ext_Long_Reinf} + f_{y,int_Long_Reinf} * Area_{int_Long_Reinf}) / Area_{Tot_Long_Rein} =$

601.9953

$f_{yE} = (f_{y,ext_Trans_Reinf} * s_1 + f_{y,int_Trans_Reinf} * s_2) / (s_1 + s_2) = 609.3286$

$p_l = Area_{Tot_Long_Rein} / (b * d) = 0.00996292$

$b = 950.00$

$d = 707.00$

$f_{cE} = 27.20$


End Of Calculation of Chord Rotation Capacity for element: column JTC1 of floor 1

At local axis: 2

Integration Section: (b)

Calculation No. 15

column C1, Floor 1
 Limit State: Life Safety (data interpolation between analysis steps 1 and 2)
 Analysis: Uniform +X
 Check: Shear capacity VRd
 Edge: End
 Local Axis: (3)



Start Of Calculation of Shear Capacity for element: column JTC1 of floor 1
 At local axis: 3
 Integration Section: (b)
 Section Type: rcjtcs

Constant Properties

Knowledge Factor, $\gamma = 0.80$
 Member Shear Force is generally considered as Force-Controlled Action according to Table C7-1, ASCE 41-17.
 Lower-bound strengths are used for Force-Controlled Actions according to 7.5.1.3, ASCE 41-17
 Consequently:
 Jacket
 New material of Secondary Member: Concrete Strength, $f_c = f_{c_lower_bound} = 20.00$
 New material of Secondary Member: Steel Strength, $f_s = f_{s_lower_bound} = 500.00$
 Concrete Elasticity, $E_c = 25742.96$
 Steel Elasticity, $E_s = 200000.00$
 Existing Column
 Existing material of Secondary Member: Concrete Strength, $f_c = f_{c_lower_bound} = 16.00$
 Existing material of Secondary Member: Steel Strength, $f_s = f_{s_lower_bound} = 420.00$
 Concrete Elasticity, $E_c = 23025.204$
 Steel Elasticity, $E_s = 200000.00$
 #####
 Note: Especially for the calculation of γ for displacement ductility demand,
 the expected (mean value) strengths are used (7.5.1.3, ASCE 41-17) because bending is considered as
 Deformation-Controlled Action (Table C7-1, ASCE 41-17).
 Jacket
 New material: Concrete Strength, $f_c = f_{cm} = 30.00$
 New material: Steel Strength, $f_s = f_{sm} = 625.00$
 Existing Column
 Existing material: Concrete Strength, $f_c = f_{cm} = 24.00$
 Existing material: Steel Strength, $f_s = f_{sm} = 525.00$
 #####
 Max Height, $H_{max} = 750.00$
 Min Height, $H_{min} = 450.00$
 Max Width, $W_{max} = 950.00$
 Min Width, $W_{min} = 450.00$
 Eccentricity, $Ecc = 250.00$
 Jacket Thickness, $t_j = 100.00$
 Cover Thickness, $c = 25.00$

Element Length, L = 3000.00
 Secondary Member
 Smooth Bars
 Ductile Steel
 Without Detailing for Earthquake Resistance (including stirrups not closed at 135°)
 Longitudinal Bars With Ends Lapped Starting at the End Sections
 Adequate Lap Length ($l_o/l_{ou,min} = l_b/l_d \geq 1$)
 No FRP Wrapping

Stepwise Properties

EDGE -A-
 Bending Moment, $M_a = 9692.864$
 Shear Force, $V_a = -1.96926$
 EDGE -B-
 Bending Moment, $M_b = -2610.668$
 Shear Force, $V_b = 1.96926$
 BOTH EDGES
 Axial Force, $F = -22375.589$
 Longitudinal Reinforcement Area Distribution (in 2 divisions)
 -Tension: $A_{st} = 0.00$
 -Compression: $A_{sc} = 6691.592$
 Longitudinal Reinforcement Area Distribution (in 3 divisions)
 -Tension: $A_{st,ten} = 1539.38$
 -Compression: $A_{sc,com} = 2475.575$
 -Middle: $A_{st,mid} = 2676.637$
 Mean Diameter of Tension Reinforcement, $Db_{L,ten} = 16.57143$

Existing component: From table 7-7, ASCE 41_17: Final Shear Capacity $V_R = V_n = 822386.268$
 V_n ((10.3), ASCE 41-17) = $k_n \cdot V_{CoI} = 1.0280E+006$
 $V_{CoI} = 1.0280E+006$
 $k_n = 1.00$
 displacement_ductility_demand = $4.6622796E-007$

NOTE: In expression (10-3) ' $V_s = A_v \cdot f_y \cdot d / s$ ' is replaced by ' $V_s + f \cdot V_f$ '
 where V_f is the contribution of FRPs (11.3), ACI 440).

= 1 (normal-weight concrete)
 Mean concrete strength: $f'_c = (f'_{c,jacket} \cdot Area_{jacket} + f'_{c,core} \cdot Area_{core}) / Area_{section} = 18.13333$, but $f'_c^{0.5} \leq 8.3$ MPa (22.5.3.1, ACI 318-14)
 $M/Vd = 2.20951$
 $\mu_u = 2610.668$
 $V_u = 1.96926$
 $d = 0.8 \cdot h = 600.00$
 $N_u = 22375.589$
 $A_g = 337500.00$
 From (11.5.4.8), ACI 318-14: $V_s = V_{sjacket} + V_{s,core} = 828294.726$
 where:
 $V_{sjacket} = V_{sj1} + V_{sj2} = 753982.237$
 $V_{sj1} = 471238.898$ is calculated for section web jacket, with:
 $d = 600.00$
 $A_v = 157079.633$
 $f_y = 500.00$
 $s = 100.00$
 V_{sj1} is multiplied by $Col_{j1} = 1.00$
 $s/d = 0.16666667$
 $V_{sj2} = 282743.339$ is calculated for section flange jacket, with:
 $d = 360.00$
 $A_v = 157079.633$
 $f_y = 500.00$
 $s = 100.00$
 V_{sj2} is multiplied by $Col_{j2} = 1.00$
 $s/d = 0.27777778$

$V_{s,core} = V_{s,c1} + V_{s,c2} = 74312.489$
 $V_{s,c1} = 74312.489$ is calculated for section web core, with:
 $d = 440.00$
 $A_v = 100530.965$
 $f_y = 420.00$
 $s = 250.00$
 $V_{s,c1}$ is multiplied by $Col,c1 = 1.00$
 $s/d = 0.56818182$
 $V_{s,c2} = 0.00$ is calculated for section flange core, with:
 $d = 200.00$
 $A_v = 100530.965$
 $f_y = 420.00$
 $s = 250.00$
 $V_{s,c2}$ is multiplied by $Col,c2 = 0.00$
 $s/d = 1.25$
 $V_f ((11-3)-(11.4), ACI 440) = 0.00$
 From (11-11), ACI 440: $V_s + V_f \leq 763781.865$
 $bw = 450.00$

displacement ductility demand is calculated as ϕ / y

- Calculation of ϕ / y for END B -
for rotation axis 2 and integ. section (b)

From analysis, chord rotation $\theta = 1.1380224E-009$
 $y = (M_y * L_s / 3) / E_{eff} = 0.00244091$ ((4.29), Biskinis Phd))
 $M_y = 9.4108E+008$
 $L_s = M/V$ (with $L_s > 0.1 * L$ and $L_s < 2 * L$) = 1325.708
 From table 10.5, ASCE 41_17: $E_{eff} = factor * E_c * I_g = 1.7037E+014$
 $factor = 0.30$
 $A_g = 562500.00$
 Mean concrete strength: $f'_c = (f'_c_{jacket} * Area_{jacket} + f'_c_{core} * Area_{core}) / Area_{section} = 27.20$
 $N = 22375.589$
 $E_c * I_g = E_{c,jacket} * I_{g,jacket} + E_{c,core} * I_{g,core} = 5.6791E+014$

Calculation of Yielding Moment M_y

Calculation of ϕ and M_y according to Annex 7 -

Assuming neutral axis within flange ($y < t/d$, compression zone rectangular) with:
 flange width, $b = 950.00$
 web width, $bw = 450.00$
 flange thickness, $t = 450.00$

$y = \text{Min}(y_{ten}, y_{com})$
 $y_{ten} = 5.3416636E-006$
 with $f_y = 601.9953$
 $d = 707.00$
 $y = 0.20298377$
 $A = 0.01001826$
 $B = 0.00468522$
 with $p_t = 0.00229194$
 $p_c = 0.00368581$
 $p_v = 0.00398517$
 $N = 22375.589$
 $b = 950.00$
 $\rho = 0.06082037$
 $y_{comp} = 1.4673137E-005$
 with $f_c = 30.00$
 $E_c = 25742.96$
 $y = 0.20220547$
 $A = 0.00988351$
 $B = 0.00462988$

with $E_s = 200000.00$
CONFIRMATION: $y = 0.20298377 < t/d$

Calculation of ratio I_b/I_d

Adequate Lap Length: $I_b/I_d \geq 1$

End Of Calculation of Shear Capacity for element: column JTC1 of floor 1

At local axis: 3

Integration Section: (b)

Calculation No. 16

column C1, Floor 1


Limit State: Life Safety (data interpolation between analysis steps 1 and 2)

Analysis: Uniform +X

Check: Chord rotation capacity (ϕ)

Edge: End

Local Axis: (3)



Start Of Calculation of Shear Capacity ratio for element: column JTC1 of floor 1

At Shear local axis: 3

(Bending local axis: 2)

Section Type: rcjtcs

Constant Properties

Knowledge Factor, $\gamma = 0.80$

Mean strength values are used for both shear and moment calculations.

Consequently:

Jacket

New material of Secondary Member: Concrete Strength, $f_c = f_{cm} = 30.00$

New material of Secondary Member: Steel Strength, $f_s = f_{sm} = 625.00$

Concrete Elasticity, $E_c = 25742.96$

Steel Elasticity, $E_s = 200000.00$

Existing Column

Existing material of Secondary Member: Concrete Strength, $f_c = f_{cm} = 24.00$
 Existing material of Secondary Member: Steel Strength, $f_s = f_{sm} = 525.00$
 Concrete Elasticity, $E_c = 23025.204$
 Steel Elasticity, $E_s = 200000.00$
 #####
 Note: Especially for the calculation of moment strengths,
 the above steel re-bar strengths are multiplied by 1.25 according to R18.6.5, ACI 318-14
 Jacket
 New material: Steel Strength, $f_s = 1.25 \cdot f_{sm} = 781.25$
 Existing Column
 Existing material: Steel Strength, $f_s = 1.25 \cdot f_{sm} = 656.25$
 #####
 Max Height, $H_{max} = 750.00$
 Min Height, $H_{min} = 450.00$
 Max Width, $W_{max} = 950.00$
 Min Width, $W_{min} = 450.00$
 Eccentricity, $Ecc = 250.00$
 Jacket Thickness, $t_j = 100.00$
 Cover Thickness, $c = 25.00$
 Mean Confinement Factor overall section = 1.00
 Element Length, $L = 3000.00$
 Secondary Member
 Smooth Bars
 Ductile Steel
 Without Detailing for Earthquake Resistance (including stirrups not closed at 135°)
 Longitudinal Bars With Ends Lapped Starting at the End Sections
 Adequate Lap Length ($l_o/l_{ou,min} > 1$)
 No FRP Wrapping

Stepwise Properties

At local axis: 3
 EDGE -A-
 Shear Force, $V_a = -8.5087964E-020$
 EDGE -B-
 Shear Force, $V_b = 8.5087964E-020$
 BOTH EDGES
 Axial Force, $F = -20792.05$
 Longitudinal Reinforcement Area Distribution (in 2 divisions)
 -Tension: $As_t = 0.00$
 -Compression: $As_c = 6691.592$
 Longitudinal Reinforcement Area Distribution (in 3 divisions)
 -Tension: $As_{t,ten} = 1539.38$
 -Compression: $As_{l,com} = 2475.575$
 -Middle: $As_{l,mid} = 2676.637$

Calculation of Shear Capacity ratio, $V_e/V_r = 1.11674$
 Member Controlled by Shear ($V_e/V_r > 1$)
 Calculation of Shear Demand from fig. R18.6.5, ACI 318-14 $V_e = (M_{pr1} + M_{pr2})/l_n = 1.4424E+006$
 with
 $M_{pr1} = \text{Max}(\mu_{u1+}, \mu_{u1-}) = 2.1636E+009$
 $\mu_{u1+} = 2.0419E+009$, is the ultimate moment strength at the edge 1 of the member in the actual moment direction
 which is defined for the static loading combination
 $\mu_{u1-} = 2.1636E+009$, is the ultimate moment strength at the edge 1 of the member in the opposite moment
 direction which is defined for the static loading combination
 $M_{pr2} = \text{Max}(\mu_{u2+}, \mu_{u2-}) = 2.1636E+009$
 $\mu_{u2+} = 2.0419E+009$, is the ultimate moment strength at the edge 2 of the member in the actual moment direction
 which is defined for the the static loading combination
 $\mu_{u2-} = 2.1636E+009$, is the ultimate moment strength at the edge 2 of the member in the opposite moment
 direction which is defined for the the static loading combination

Calculation of μ_{u1+}

Calculation of ultimate curvature ϕ_u according to 4.1, Biskinis/Fardis 2013:

$$u = 5.3321191E-005$$

$$\mu = 2.0419E+009$$

with full section properties:

$$b = 950.00$$

$$d = 707.00$$

$$d' = 43.00$$

$$v = 0.00103189$$

$$N = 20792.05$$

$$f_c = 30.00$$

$$\alpha (5A.5, \text{TBDY}) = 0.002$$

$$\text{Final value of } \phi_u: \phi_u^* = \text{shear_factor} * \text{Max}(\phi_u, \phi_c) = 0.00832321$$

The Shear_factor is considered equal to 1 (pure moment strength)

$$\text{From (5.4b), TBDY: } \phi_u = 0.00832321$$

$$\phi_{ue} (5.4c) = 0.01453958$$

$$\alpha_{se} ((5.4d), \text{TBDY}) = (\alpha_{se1} * A_{ext} + \alpha_{se2} * A_{int}) / A_{sec} = 0.53375773$$

$$\alpha_{se1} = \text{Max}(((A_{conf,max1} - A_{noConf1}) / A_{conf,max1}) * (A_{conf,min1} / A_{conf,max1}), 0) = 0.53375773$$

The definitions of A_{noConf} , $A_{conf,min}$ and $A_{conf,max}$ are derived from generalization of the rectangular sections confinement, which is expressed by (5.4d).

The generalization is done according to Mander, J., Priestley, M., and Park, R. (1988)

"Theoretical Stress-Strain Model for Confined Concrete."

J. Struct. Eng., 10.1061/(ASCE)0733-9445(1988)114:8(1804), 1804-1826.

$A_{conf,max1} = 464100.00$ is the confined core area at levels of member with hoops and is calculated as the area of core enclosed by the center lines of the external perimeter hoops.

$A_{conf,min1} = 395025.00$ is the confined core area at midway between the levels of hoops and is calculated by reducing all the dimensions of the area $A_{conf,max1}$ by a length equal to half the clear spacing between external hoops.

$A_{noConf1} = 173066.667$ is the unconfined external core area which is equal to $b_i d_i / 6$ as defined at (A.2).

$$\alpha_{se2} (> \alpha_{se1}) = \text{Max}(((A_{conf,max2} - A_{noConf2}) / A_{conf,max2}) * (A_{conf,min2} / A_{conf,max2}), 0) = 0.53375773$$

The definitions of A_{noConf} , $A_{conf,min}$ and $A_{conf,max}$ are derived from generalization of the rectangular sections confinement, which is expressed by (5.4d).

The generalization is done according to Mander, J., Priestley, M., and Park, R. (1988)

"Theoretical Stress-Strain Model for Confined Concrete."

J. Struct. Eng., 10.1061/(ASCE)0733-9445(1988)114:8(1804), 1804-1826.

$A_{conf,max2} = 252164.00$ is the confined core area at levels of member with hoops and is calculated as the area of core enclosed by the center lines of the internal perimeter hoops.

$A_{conf,min2} = 111441.00$ is the confined core area at midway between the levels of hoops and is calculated by reducing all the dimensions of the area $A_{conf,max2}$ by a length equal to half the clear spacing between internal hoops.

$A_{noConf2} = 110709.333$ is the unconfined internal core area which is equal to $b_i d_i / 6$ as defined at (A.2).

$$\phi_{sh,min} * F_{ywe} = \text{Min}(\phi_{sh,x} * F_{ywe}, \phi_{sh,y} * F_{ywe}) = 2.724$$

Expression (5.4d) for $\phi_{sh,min} * F_{ywe}$ has been multiplied by 0.3 according to 15.7.1.3 for members without earthquake detailing (90° closed stirrups)

$$\phi_{sh,x} * F_{ywe} = \phi_{sh1} * F_{ywe1} + \phi_{sh2} * F_{ywe2} = 2.724$$

$$\phi_{sh1} ((5.4d), \text{TBDY}) = L_{stir1} * A_{stir1} / (A_{sec} * s_1) = 0.00301593$$

$$L_{stir1} (\text{Length of stirrups along Y}) = 2160.00$$

$$A_{stir1} (\text{stirrups area}) = 78.53982$$

$$\phi_{sh2} (5.4d) = L_{stir2} * A_{stir2} / (A_{sec} * s_2) = 0.00056047$$

$$L_{stir2} (\text{Length of stirrups along Y}) = 1568.00$$

$$A_{stir2} (\text{stirrups area}) = 50.26548$$

$$\phi_{sh,y} * F_{ywe} = \phi_{sh1} * F_{ywe1} + \phi_{sh2} * F_{ywe2} = 3.25416$$

$$\phi_{sh1} ((5.4d), \text{TBDY}) = L_{stir1} * A_{stir1} / (A_{sec} * s_1) = 0.00357443$$

$$L_{stir1} (\text{Length of stirrups along X}) = 2560.00$$

$$A_{stir1} (\text{stirrups area}) = 78.53982$$

$$\phi_{sh2} ((5.4d), \text{TBDY}) = L_{stir2} * A_{stir2} / (A_{sec} * s_2) = 0.00070345$$

$$L_{stir2} (\text{Length of stirrups along X}) = 1968.00$$

$$A_{stir2} (\text{stirrups area}) = 50.26548$$

$$A_{sec} = 562500.00$$

$$s_1 = 100.00$$

$$s_2 = 250.00$$

$fy_{we1} = 781.25$
 $fy_{we2} = 656.25$
 $f_{ce} = 30.00$
 From ((5.A.5), TBDY), TBDY: $cc = 0.002$
 $c = \text{confinement factor} = 1.00$
 $y_1 = 0.0025$
 $sh_1 = 0.008$
 $ft_1 = 907.50$
 $fy_1 = 756.25$
 $su_1 = 0.032$
 using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
 and also multiplied by the shear_factor according to 15.7.1.4, with
 $Shear_factor = 1.00$
 $lo/lou, min = lb/ld = 1.00$
 $su_1 = 0.4 * esu_1_nominal ((5.5), TBDY) = 0.032$
 From table 5A.1, TBDY: $esu_1_nominal = 0.08$,
 For calculation of $esu_1_nominal$ and y_1, sh_1, ft_1, fy_1 , it is considered
 characteristic value $fsy_1 = fs_1/1.2$, from table 5.1, TBDY.
 y_1, sh_1, ft_1, fy_1 , are also multiplied by $Min(1, 1.25 * (lb/ld)^{2/3})$, from 10.3.5, ASCE 41-17.
 with $fs_1 = (fs_{jacket} * Asl_{ten, jacket} + fs_{core} * Asl_{ten, core}) / Asl_{ten} = 756.25$
 with $Es_1 = (Es_{jacket} * Asl_{ten, jacket} + Es_{core} * Asl_{ten, core}) / Asl_{ten} = 200000.00$
 $y_2 = 0.0025$
 $sh_2 = 0.008$
 $ft_2 = 900.1904$
 $fy_2 = 750.1586$
 $su_2 = 0.032$
 using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
 and also multiplied by the shear_factor according to 15.7.1.4, with
 $Shear_factor = 1.00$
 $lo/lou, min = lb/lb, min = 1.00$
 $su_2 = 0.4 * esu_2_nominal ((5.5), TBDY) = 0.032$
 From table 5A.1, TBDY: $esu_2_nominal = 0.08$,
 For calculation of $esu_2_nominal$ and y_2, sh_2, ft_2, fy_2 , it is considered
 characteristic value $fsy_2 = fs_2/1.2$, from table 5.1, TBDY.
 y_2, sh_2, ft_2, fy_2 , are also multiplied by $Min(1, 1.25 * (lb/ld)^{2/3})$, from 10.3.5, ASCE 41-17.
 with $fs_2 = (fs_{jacket} * Asl_{com, jacket} + fs_{core} * Asl_{com, core}) / Asl_{com} = 750.1586$
 with $Es_2 = (Es_{jacket} * Asl_{com, jacket} + Es_{core} * Asl_{com, core}) / Asl_{com} = 200000.00$
 $y_v = 0.0025$
 $sh_v = 0.008$
 $ft_v = 902.993$
 $fy_v = 752.4941$
 $suv = 0.032$
 using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
 and also multiplied by the shear_factor according to 15.7.1.4, with
 $Shear_factor = 1.00$
 $lo/lou, min = lb/ld = 1.00$
 $suv = 0.4 * esuv_nominal ((5.5), TBDY) = 0.032$
 From table 5A.1, TBDY: $esuv_nominal = 0.08$,
 considering characteristic value $fsyv = fsv/1.2$, from table 5.1, TBDY
 For calculation of $esuv_nominal$ and y_v, sh_v, ft_v, fy_v , it is considered
 characteristic value $fsyv = fsv/1.2$, from table 5.1, TBDY.
 y_v, sh_v, ft_v, fy_v , are also multiplied by $Min(1, 1.25 * (lb/ld)^{2/3})$, from 10.3.5, ASCE 41-17.
 with $fsv = (fs_{jacket} * Asl_{mid, jacket} + fs_{mid} * Asl_{mid, core}) / Asl_{mid} = 752.4941$
 with $Es_v = (Es_{jacket} * Asl_{mid, jacket} + Es_{mid} * Asl_{mid, core}) / Asl_{mid} = 200000.00$
 $1 = Asl_{ten} / (b * d) * (fs_1 / f_c) = 0.05777595$
 $2 = Asl_{com} / (b * d) * (fs_2 / f_c) = 0.09216477$
 $v = Asl_{mid} / (b * d) * (fsv / f_c) = 0.09996047$
 and confined core properties:
 $b = 890.00$
 $d = 677.00$
 $d' = 13.00$
 $f_{cc} (5A.2, TBDY) = 30.00$
 $cc (5A.5, TBDY) = 0.002$
 $c = \text{confinement factor} = 1.00$
 $1 = Asl_{ten} / (b * d) * (fs_1 / f_c) = 0.06440379$
 $2 = Asl_{com} / (b * d) * (fs_2 / f_c) = 0.10273757$
 $v = Asl_{mid} / (b * d) * (fsv / f_c) = 0.11142757$

Case/Assumption: Unconfined full section - Steel rupture
' satisfies Eq. (4.3)

--->
 $v < v_{s,y2}$ - LHS eq.(4.5) is not satisfied
--->
 $v < v_{s,c}$ - RHS eq.(4.5) is satisfied
--->
 $s_u(4.8) = 0.15115045$
 $M_u = M_{Rc}(4.15) = 2.0419E+009$
 $u = s_u(4.1) = 5.3321191E-005$

Calculation of ratio I_b/I_d

Adequate Lap Length: $I_b/I_d \geq 1$

Calculation of M_{u1} -

Calculation of ultimate curvature u according to 4.1, Biskinis/Fardis 2013:
 $u = 6.8287974E-005$
 $M_u = 2.1636E+009$

with full section properties:

$b = 450.00$
 $d = 707.00$
 $d' = 43.00$
 $v = 0.00217843$
 $N = 20792.05$
 $f_c = 30.00$
 $\alpha(5A.5, TBDY) = 0.002$
Final value of α : $\alpha^* = \text{shear_factor} * \text{Max}(\alpha_c, \alpha) = 0.00832321$
The Shear_factor is considered equal to 1 (pure moment strength)
From (5.4b), TBDY: $\alpha_c = 0.00832321$
 $w_e(5.4c) = 0.01453958$
 $\alpha_{se}((5.4d), TBDY) = (\alpha_{se1} * A_{ext} + \alpha_{se2} * A_{int}) / A_{sec} = 0.53375773$
 $\alpha_{se1} = \text{Max}(((A_{conf,max1} - A_{noConf1}) / A_{conf,max1}) * (A_{conf,min1} / A_{conf,max1}), 0) = 0.53375773$
The definitions of A_{noConf} , $A_{conf,min}$ and $A_{conf,max}$ are derived from generalization of the rectangular sections confinement, which is expressed by (5.4d).
The generalization is done according to Mander, J., Priestley, M., and Park, R. (1988) "Theoretical Stress-Strain Model for Confined Concrete."
J. Struct. Eng., 10.1061/(ASCE)0733-9445(1988)114:8(1804), 1804-1826.
 $A_{conf,max1} = 464100.00$ is the confined core area at levels of member with hoops and is calculated as the area of core enclosed by the center lines of the external perimeter hoops.
 $A_{conf,min1} = 395025.00$ is the confined core area at midway between the levels of hoops and is calculated by reducing all the dimensions of the area $A_{conf,max1}$ by a length equal to half the clear spacing between external hoops.
 $A_{noConf1} = 173066.667$ is the unconfined external core area which is equal to $b_i^2/6$ as defined at (A.2).
 $\alpha_{se2} (\geq \alpha_{se1}) = \text{Max}(((A_{conf,max2} - A_{noConf2}) / A_{conf,max2}) * (A_{conf,min2} / A_{conf,max2}), 0) = 0.53375773$
The definitions of A_{noConf} , $A_{conf,min}$ and $A_{conf,max}$ are derived from generalization of the rectangular sections confinement, which is expressed by (5.4d).
The generalization is done according to Mander, J., Priestley, M., and Park, R. (1988) "Theoretical Stress-Strain Model for Confined Concrete."
J. Struct. Eng., 10.1061/(ASCE)0733-9445(1988)114:8(1804), 1804-1826.
 $A_{conf,max2} = 252164.00$ is the confined core area at levels of member with hoops and is calculated as the area of core enclosed by the center lines of the internal perimeter hoops.
 $A_{conf,min2} = 111441.00$ is the confined core area at midway between the levels of hoops and is calculated by reducing all the dimensions of the area $A_{conf,max2}$ by a length equal to half the clear spacing between internal hoops.
 $A_{noConf2} = 110709.333$ is the unconfined internal core area which is equal to $b_i^2/6$ as defined at (A.2).
 $p_{sh,min} * F_{ywe} = \text{Min}(p_{sh,x} * F_{ywe}, p_{sh,y} * F_{ywe}) = 2.724$
Expression (5.4d) for $p_{sh,min} * F_{ywe}$ has been multiplied by 0.3 according to 15.7.1.3 for members without earthquake detailing (90° closed stirrups)

$psh_x * Fywe = psh1 * Fywe1 + ps2 * Fywe2 = 2.724$
 $psh1 ((5.4d), TBDY) = Lstir1 * Astir1 / (Asec * s1) = 0.00301593$
 $Lstir1 \text{ (Length of stirrups along Y)} = 2160.00$
 $Astir1 \text{ (stirrups area)} = 78.53982$
 $psh2 (5.4d) = Lstir2 * Astir2 / (Asec * s2) = 0.00056047$
 $Lstir2 \text{ (Length of stirrups along Y)} = 1568.00$
 $Astir2 \text{ (stirrups area)} = 50.26548$

$psh_y * Fywe = psh1 * Fywe1 + ps2 * Fywe2 = 3.25416$
 $psh1 ((5.4d), TBDY) = Lstir1 * Astir1 / (Asec * s1) = 0.00357443$
 $Lstir1 \text{ (Length of stirrups along X)} = 2560.00$
 $Astir1 \text{ (stirrups area)} = 78.53982$
 $psh2 ((5.4d), TBDY) = Lstir2 * Astir2 / (Asec * s2) = 0.00070345$
 $Lstir2 \text{ (Length of stirrups along X)} = 1968.00$
 $Astir2 \text{ (stirrups area)} = 50.26548$

$Asec = 562500.00$
 $s1 = 100.00$
 $s2 = 250.00$
 $fywe1 = 781.25$
 $fywe2 = 656.25$
 $fce = 30.00$

From ((5.A5), TBDY), TBDY: $cc = 0.002$
 $c = \text{confinement factor} = 1.00$

$y1 = 0.0025$
 $sh1 = 0.008$
 $ft1 = 900.1904$
 $fy1 = 750.1586$
 $su1 = 0.032$

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
 and also multiplied by the shear_factor according to 15.7.1.4, with
 $Shear_factor = 1.00$
 $lo/lou,min = lb/ld = 1.00$

$su1 = 0.4 * esu1_nominal ((5.5), TBDY) = 0.032$

From table 5A.1, TBDY: $esu1_nominal = 0.08$,

For calculation of $esu1_nominal$ and $y1, sh1, ft1, fy1$, it is considered
 characteristic value $fsy1 = fs1/1.2$, from table 5.1, TBDY.

$y1, sh1, ft1, fy1$, are also multiplied by $\text{Min}(1, 1.25 * (lb/ld)^{2/3})$, from 10.3.5, ASCE 41-17.

with $fs1 = (fs,jacket * Asl,ten,jacket + fs,core * Asl,ten,core) / Asl,ten = 750.1586$

with $Es1 = (Es,jacket * Asl,ten,jacket + Es,core * Asl,ten,core) / Asl,ten = 200000.00$

$y2 = 0.0025$
 $sh2 = 0.008$
 $ft2 = 907.50$
 $fy2 = 756.25$
 $su2 = 0.032$

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
 and also multiplied by the shear_factor according to 15.7.1.4, with
 $Shear_factor = 1.00$

$lo/lou,min = lb/lb,min = 1.00$

$su2 = 0.4 * esu2_nominal ((5.5), TBDY) = 0.032$

From table 5A.1, TBDY: $esu2_nominal = 0.08$,

For calculation of $esu2_nominal$ and $y2, sh2, ft2, fy2$, it is considered
 characteristic value $fsy2 = fs2/1.2$, from table 5.1, TBDY.

$y2, sh2, ft2, fy2$, are also multiplied by $\text{Min}(1, 1.25 * (lb/ld)^{2/3})$, from 10.3.5, ASCE 41-17.

with $fs2 = (fs,jacket * Asl,com,jacket + fs,core * Asl,com,core) / Asl,com = 756.25$

with $Es2 = (Es,jacket * Asl,com,jacket + Es,core * Asl,com,core) / Asl,com = 200000.00$

$yv = 0.0025$
 $shv = 0.008$
 $ftv = 902.993$
 $fyv = 752.4941$
 $suv = 0.032$

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
 and also multiplied by the shear_factor according to 15.7.1.4, with
 $Shear_factor = 1.00$

$lo/lou,min = lb/ld = 1.00$

$suv = 0.4 * esuv_nominal ((5.5), TBDY) = 0.032$

From table 5A.1, TBDY: $esuv_nominal = 0.08$,

considering characteristic value $f_{syv} = f_{sv}/1.2$, from table 5.1, TBDY

For calculation of $e_{suv_nominal}$ and y_v , sh_v , ft_v , f_{yv} , it is considered characteristic value $f_{syv} = f_{sv}/1.2$, from table 5.1, TBDY.

y_1 , sh_1 , ft_1 , f_{y1} , are also multiplied by $\text{Min}(1, 1.25 \cdot (l_b/l_d)^{2/3})$, from 10.3.5, ASCE 41-17.

with $f_{sv} = (f_{s,jacket} \cdot A_{sl,mid,jacket} + f_{s,mid} \cdot A_{sl,mid,core}) / A_{sl,mid} = 752.4941$

with $E_{sv} = (E_{s,jacket} \cdot A_{sl,mid,jacket} + E_{s,mid} \cdot A_{sl,mid,core}) / A_{sl,mid} = 200000.00$

$1 = A_{sl,ten} / (b \cdot d) \cdot (f_{s1} / f_c) = 0.19457006$

$2 = A_{sl,com} / (b \cdot d) \cdot (f_{s2} / f_c) = 0.12197144$

$v = A_{sl,mid} / (b \cdot d) \cdot (f_{sv} / f_c) = 0.21102767$

and confined core properties:

$b = 390.00$

$d = 677.00$

$d' = 13.00$

f_{cc} (5A.2, TBDY) = 30.00

cc (5A.5, TBDY) = 0.002

c = confinement factor = 1.00

$1 = A_{sl,ten} / (b \cdot d) \cdot (f_{s1} / f_c) = 0.23445239$

$2 = A_{sl,com} / (b \cdot d) \cdot (f_{s2} / f_c) = 0.14697275$

$v = A_{sl,mid} / (b \cdot d) \cdot (f_{sv} / f_c) = 0.25428343$

Case/Assumption: Unconfined full section - Steel rupture

' satisfies Eq. (4.3)

---->

$v < v_{s,y2}$ - LHS eq.(4.5) is not satisfied

---->

$v < v_{s,c}$ - RHS eq.(4.5) is satisfied

---->

su (4.8) = 0.33719414

$Mu = MR_c$ (4.15) = 2.1636E+009

$u = su$ (4.1) = 6.8287974E-005

Calculation of ratio l_b/l_d

Adequate Lap Length: $l_b/l_d \geq 1$

Calculation of Mu_{2+}

Calculation of ultimate curvature u according to 4.1, Biskinis/Fardis 2013:

$u = 5.3321191E-005$

$Mu = 2.0419E+009$

with full section properties:

$b = 950.00$

$d = 707.00$

$d' = 43.00$

$v = 0.00103189$

$N = 20792.05$

$f_c = 30.00$

co (5A.5, TBDY) = 0.002

Final value of cu^* = $shear_factor \cdot \text{Max}(cu, cc) = 0.00832321$

The $Shear_factor$ is considered equal to 1 (pure moment strength)

From (5.4b), TBDY: $cu = 0.00832321$

we (5.4c) = 0.01453958

ase ((5.4d), TBDY) = $(ase1 \cdot A_{ext} + ase2 \cdot A_{int}) / A_{sec} = 0.53375773$

$ase1 = \text{Max}(((A_{conf,max1} - A_{noConf1}) / A_{conf,max1}) \cdot (A_{conf,min1} / A_{conf,max1}), 0) = 0.53375773$

The definitions of A_{noConf} , $A_{conf,min}$ and $A_{conf,max}$ are derived from generalization of the rectangular sections confinement, which is expressed by (5.4d).

The generalization is done according to Mander, J., Priestley, M., and Park, R. (1988)

"Theoretical Stress-Strain Model for Confined Concrete."

J. Struct. Eng., 10.1061/(ASCE)0733-9445(1988)114:8(1804), 1804-1826.

$A_{conf,max1} = 464100.00$ is the confined core area at levels of member with hoops and

is calculated as the area of core enclosed by the center lines of the external perimeter hoops.

$A_{conf,min1} = 395025.00$ is the confined core area at midway between the levels of hoops and

is calculated by reducing all the dimensions of the area $A_{conf,max1}$ by a length equal to half the clear spacing between external hoops.

$A_{noConf1} = 173066.667$ is the unconfined external core area which is equal to $b_i/6$ as defined at (A.2).
 $ase2 (>=ase1) = \text{Max}(((A_{conf,max2}-A_{noConf2})/A_{conf,max2})*(A_{conf,min2}/A_{conf,max2}),0) = 0.53375773$

The definitions of A_{noConf} , $A_{conf,min}$ and $A_{conf,max}$ are derived from generalization of the rectangular sections confinement, which is expressed by (5.4d).

The generalization is done according to Mander, J., Priestley, M., and Park, R. (1988) "Theoretical Stress-Strain Model for Confined Concrete."

J. Struct. Eng., 10.1061/(ASCE)0733-9445(1988)114:8(1804), 1804-1826.

$A_{conf,max2} = 252164.00$ is the confined core area at levels of member with hoops and is calculated as the area of core enclosed by the center lines of the internal perimeter hoops.

$A_{conf,min2} = 111441.00$ is the confined core area at midway between the levels of hoops and is calculated by reducing all the dimensions of the area $A_{conf,max2}$ by a length equal to half the clear spacing between internal hoops.

$A_{noConf2} = 110709.333$ is the unconfined internal core area which is equal to $b_i/6$ as defined at (A.2).
 $psh_{min}*F_{ywe} = \text{Min}(psh_x*F_{ywe}, psh_y*F_{ywe}) = 2.724$

Expression (5.4d) for $psh_{min}*F_{ywe}$ has been multiplied by 0.3 according to 15.7.1.3 for members without earthquake detailing (90° closed stirrups)

 $psh_x*F_{ywe} = psh1*F_{ywe1} + ps2*F_{ywe2} = 2.724$
 $psh1 ((5.4d), TBDY) = L_{stir1}*A_{stir1}/(A_{sec}*s1) = 0.00301593$
 L_{stir1} (Length of stirrups along Y) = 2160.00
 A_{stir1} (stirrups area) = 78.53982
 $psh2 ((5.4d)) = L_{stir2}*A_{stir2}/(A_{sec}*s2) = 0.00056047$
 L_{stir2} (Length of stirrups along Y) = 1568.00
 A_{stir2} (stirrups area) = 50.26548

 $psh_y*F_{ywe} = psh1*F_{ywe1} + ps2*F_{ywe2} = 3.25416$
 $psh1 ((5.4d), TBDY) = L_{stir1}*A_{stir1}/(A_{sec}*s1) = 0.00357443$
 L_{stir1} (Length of stirrups along X) = 2560.00
 A_{stir1} (stirrups area) = 78.53982
 $psh2 ((5.4d), TBDY) = L_{stir2}*A_{stir2}/(A_{sec}*s2) = 0.00070345$
 L_{stir2} (Length of stirrups along X) = 1968.00
 A_{stir2} (stirrups area) = 50.26548

 $A_{sec} = 562500.00$

$s1 = 100.00$

$s2 = 250.00$

$f_{ywe1} = 781.25$

$f_{ywe2} = 656.25$

$f_{ce} = 30.00$

From ((5.A5), TBDY), TBDY: $cc = 0.002$

c = confinement factor = 1.00

$y1 = 0.0025$

$sh1 = 0.008$

$ft1 = 907.50$

$fy1 = 756.25$

$su1 = 0.032$

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor and also multiplied by the shear_factor according to 15.7.1.4, with Shear_factor = 1.00

$l_o/l_{ou,min} = l_b/l_d = 1.00$

$su1 = 0.4*es_{u1,nominal} ((5.5), TBDY) = 0.032$

From table 5A.1, TBDY: $es_{u1,nominal} = 0.08$,

For calculation of $es_{u1,nominal}$ and $y1, sh1, ft1, fy1$, it is considered characteristic value $fs_{y1} = fs_{y1}/1.2$, from table 5.1, TBDY.

$y1, sh1, ft1, fy1$, are also multiplied by $\text{Min}(1, 1.25*(l_b/l_d)^{2/3})$, from 10.3.5, ASCE 41-17.

with $fs_1 = (f_{s,jacket}*A_{s,t,jacket} + f_{s,core}*A_{s,t,core})/A_{s,t} = 756.25$

with $Es_1 = (E_{s,jacket}*A_{s,t,jacket} + E_{s,core}*A_{s,t,core})/A_{s,t} = 200000.00$

$y2 = 0.0025$

$sh2 = 0.008$

$ft2 = 900.1904$

$fy2 = 750.1586$

$su2 = 0.032$

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor and also multiplied by the shear_factor according to 15.7.1.4, with Shear_factor = 1.00

```

lo/lou,min = lb/lbmin = 1.00
su2 = 0.4*esu2,nominal ((5.5), TBDY) = 0.032
From table 5A.1, TBDY: esu2,nominal = 0.08,
For calculation of esu2,nominal and y2, sh2,ft2,fy2, it is considered
characteristic value fsy2 = fs2/1.2, from table 5.1, TBDY.
y1, sh1,ft1,fy1, are also multiplied by Min(1,1.25*(lb/ld)2/3), from 10.3.5, ASCE 41-17.
with fs2 = (fsjacket*Aslcom,jacket + fscore*Aslcom,core)/Aslcom = 750.1586
with Es2 = (Esjacket*Aslcom,jacket + Escore*Aslcom,core)/Aslcom = 200000.00
yv = 0.0025
shv = 0.008
ftv = 902.993
fyv = 752.4941
suv = 0.032
using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00
lo/lou,min = lb/ld = 1.00
suv = 0.4*esuvnominal ((5.5), TBDY) = 0.032
From table 5A.1, TBDY: esuvnominal = 0.08,
considering characteristic value fsyv = fsv/1.2, from table 5.1, TBDY
For calculation of esuvnominal and yv, shv,ftv,fyv, it is considered
characteristic value fsyv = fsv/1.2, from table 5.1, TBDY.
y1, sh1,ft1,fy1, are also multiplied by Min(1,1.25*(lb/ld)2/3), from 10.3.5, ASCE 41-17.
with fsv = (fsjacket*Aslmid,jacket + fsmid*Aslmid,core)/Aslmid = 752.4941
with Esv = (Esjacket*Aslmid,jacket + Esmid*Aslmid,core)/Aslmid = 200000.00
1 = Aslten/(b*d)*(fs1/fc) = 0.05777595
2 = Aslcom/(b*d)*(fs2/fc) = 0.09216477
v = Aslmid/(b*d)*(fsv/fc) = 0.09996047
and confined core properties:
b = 890.00
d = 677.00
d' = 13.00
fcc (5A.2, TBDY) = 30.00
cc (5A.5, TBDY) = 0.002
c = confinement factor = 1.00
1 = Aslten/(b*d)*(fs1/fc) = 0.06440379
2 = Aslcom/(b*d)*(fs2/fc) = 0.10273757
v = Aslmid/(b*d)*(fsv/fc) = 0.11142757
Case/Assumption: Unconfined full section - Steel rupture
' satisfies Eq. (4.3)
---->
v < vsy2 - LHS eq.(4.5) is not satisfied
---->
v < vsc - RHS eq.(4.5) is satisfied
---->
su (4.8) = 0.15115045
Mu = MRc (4.15) = 2.0419E+009
u = su (4.1) = 5.3321191E-005

```

Calculation of ratio lb/l_d

Adequate Lap Length: lb/l_d >= 1

Calculation of Mu₂-

Calculation of ultimate curvature u according to 4.1, Biskinis/Fardis 2013:

$$u = 6.8287974E-005$$

$$Mu = 2.1636E+009$$

with full section properties:

$$b = 450.00$$

$$d = 707.00$$

$d' = 43.00$
 $v = 0.00217843$
 $N = 20792.05$
 $f_c = 30.00$
 $co(5A.5, TBDY) = 0.002$
 Final value of cu : $cu^* = shear_factor * Max(cu, cc) = 0.00832321$
 The Shear_factor is considered equal to 1 (pure moment strength)
 From (5.4b), TBDY: $cu = 0.00832321$
 $we(5.4c) = 0.01453958$
 $ase((5.4d), TBDY) = (ase1 * A_{ext} + ase2 * A_{int}) / A_{sec} = 0.53375773$
 $ase1 = Max(((A_{conf,max1} - A_{noConf1}) / A_{conf,max1}) * (A_{conf,min1} / A_{conf,max1}), 0) = 0.53375773$
 The definitions of A_{noConf} , $A_{conf,min}$ and $A_{conf,max}$ are derived from generalization of the rectangular sections confinement, which is expressed by (5.4d).
 The generalization is done according to Mander, J., Priestley, M., and Park, R. (1988) "Theoretical Stress-Strain Model for Confined Concrete."
 J. Struct. Eng., 10.1061/(ASCE)0733-9445(1988)114:8(1804), 1804-1826.
 $A_{conf,max1} = 464100.00$ is the confined core area at levels of member with hoops and is calculated as the area of core enclosed by the center lines of the external perimeter hoops.
 $A_{conf,min1} = 395025.00$ is the confined core area at midway between the levels of hoops and is calculated by reducing all the dimensions of the area $A_{conf,max1}$ by a length equal to half the clear spacing between external hoops.
 $A_{noConf1} = 173066.667$ is the unconfined external core area which is equal to $b_i^2/6$ as defined at (A.2).
 $ase2 (>= ase1) = Max(((A_{conf,max2} - A_{noConf2}) / A_{conf,max2}) * (A_{conf,min2} / A_{conf,max2}), 0) = 0.53375773$
 The definitions of A_{noConf} , $A_{conf,min}$ and $A_{conf,max}$ are derived from generalization of the rectangular sections confinement, which is expressed by (5.4d).
 The generalization is done according to Mander, J., Priestley, M., and Park, R. (1988) "Theoretical Stress-Strain Model for Confined Concrete."
 J. Struct. Eng., 10.1061/(ASCE)0733-9445(1988)114:8(1804), 1804-1826.
 $A_{conf,max2} = 252164.00$ is the confined core area at levels of member with hoops and is calculated as the area of core enclosed by the center lines of the internal perimeter hoops.
 $A_{conf,min2} = 111441.00$ is the confined core area at midway between the levels of hoops and is calculated by reducing all the dimensions of the area $A_{conf,max2}$ by a length equal to half the clear spacing between internal hoops.
 $A_{noConf2} = 110709.333$ is the unconfined internal core area which is equal to $b_i^2/6$ as defined at (A.2).
 $psh,min * F_{ywe} = Min(psh,x * F_{ywe}, psh,y * F_{ywe}) = 2.724$
 Expression (5.4d) for $psh,min * F_{ywe}$ has been multiplied by 0.3 according to 15.7.1.3 for members without earthquake detailing (90° closed stirrups)

$psh,x * F_{ywe} = psh1 * F_{ywe1} + ps2 * F_{ywe2} = 2.724$
 $psh1((5.4d), TBDY) = L_{stir1} * A_{stir1} / (A_{sec} * s1) = 0.00301593$
 L_{stir1} (Length of stirrups along Y) = 2160.00
 A_{stir1} (stirrups area) = 78.53982
 $psh2(5.4d) = L_{stir2} * A_{stir2} / (A_{sec} * s2) = 0.00056047$
 L_{stir2} (Length of stirrups along Y) = 1568.00
 A_{stir2} (stirrups area) = 50.26548

$psh,y * F_{ywe} = psh1 * F_{ywe1} + ps2 * F_{ywe2} = 3.25416$
 $psh1((5.4d), TBDY) = L_{stir1} * A_{stir1} / (A_{sec} * s1) = 0.00357443$
 L_{stir1} (Length of stirrups along X) = 2560.00
 A_{stir1} (stirrups area) = 78.53982
 $psh2((5.4d), TBDY) = L_{stir2} * A_{stir2} / (A_{sec} * s2) = 0.00070345$
 L_{stir2} (Length of stirrups along X) = 1968.00
 A_{stir2} (stirrups area) = 50.26548

$A_{sec} = 562500.00$
 $s1 = 100.00$
 $s2 = 250.00$
 $f_{ywe1} = 781.25$
 $f_{ywe2} = 656.25$
 $f_{ce} = 30.00$
 From ((5.A5), TBDY), TBDY: $cc = 0.002$
 $c =$ confinement factor = 1.00
 $y1 = 0.0025$
 $sh1 = 0.008$
 $ft1 = 900.1904$
 $fy1 = 750.1586$
 $su1 = 0.032$

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
 and also multiplied by the shear_factor according to 15.7.1.4, with
 Shear_factor = 1.00
 $l_o/l_{ou,min} = l_b/l_d = 1.00$
 $su_1 = 0.4 * esu_{1,nominal} ((5.5), TBDY) = 0.032$
 From table 5A.1, TBDY: $esu_{1,nominal} = 0.08$,
 For calculation of $esu_{1,nominal}$ and y_1, sh_1, ft_1, fy_1 , it is considered
 characteristic value $fsy_1 = fs_1/1.2$, from table 5.1, TBDY.
 y_1, sh_1, ft_1, fy_1 , are also multiplied by $Min(1, 1.25 * (l_b/l_d)^{2/3})$, from 10.3.5, ASCE 41-17.
 with $fs_1 = (fs_{jacket} * A_{sl,ten,jacket} + fs_{core} * A_{sl,ten,core}) / A_{sl,ten} = 750.1586$
 with $Es_1 = (Es_{jacket} * A_{sl,ten,jacket} + Es_{core} * A_{sl,ten,core}) / A_{sl,ten} = 200000.00$
 $y_2 = 0.0025$
 $sh_2 = 0.008$
 $ft_2 = 907.50$
 $fy_2 = 756.25$
 $su_2 = 0.032$
 using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
 and also multiplied by the shear_factor according to 15.7.1.4, with
 Shear_factor = 1.00
 $l_o/l_{ou,min} = l_b/l_{b,min} = 1.00$
 $su_2 = 0.4 * esu_{2,nominal} ((5.5), TBDY) = 0.032$
 From table 5A.1, TBDY: $esu_{2,nominal} = 0.08$,
 For calculation of $esu_{2,nominal}$ and y_2, sh_2, ft_2, fy_2 , it is considered
 characteristic value $fsy_2 = fs_2/1.2$, from table 5.1, TBDY.
 y_2, sh_2, ft_2, fy_2 , are also multiplied by $Min(1, 1.25 * (l_b/l_d)^{2/3})$, from 10.3.5, ASCE 41-17.
 with $fs_2 = (fs_{jacket} * A_{sl,com,jacket} + fs_{core} * A_{sl,com,core}) / A_{sl,com} = 756.25$
 with $Es_2 = (Es_{jacket} * A_{sl,com,jacket} + Es_{core} * A_{sl,com,core}) / A_{sl,com} = 200000.00$
 $y_v = 0.0025$
 $sh_v = 0.008$
 $ft_v = 902.993$
 $fy_v = 752.4941$
 $suv = 0.032$
 using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
 and also multiplied by the shear_factor according to 15.7.1.4, with
 Shear_factor = 1.00
 $l_o/l_{ou,min} = l_b/l_d = 1.00$
 $suv = 0.4 * esuv_{nominal} ((5.5), TBDY) = 0.032$
 From table 5A.1, TBDY: $esuv_{nominal} = 0.08$,
 considering characteristic value $fsyv = fsv/1.2$, from table 5.1, TBDY
 For calculation of $esuv_{nominal}$ and y_v, sh_v, ft_v, fy_v , it is considered
 characteristic value $fsyv = fsv/1.2$, from table 5.1, TBDY.
 y_1, sh_1, ft_1, fy_1 , are also multiplied by $Min(1, 1.25 * (l_b/l_d)^{2/3})$, from 10.3.5, ASCE 41-17.
 with $fsv = (fs_{jacket} * A_{sl,mid,jacket} + fs_{mid} * A_{sl,mid,core}) / A_{sl,mid} = 752.4941$
 with $Esv = (Es_{jacket} * A_{sl,mid,jacket} + Es_{mid} * A_{sl,mid,core}) / A_{sl,mid} = 200000.00$
 $1 = A_{sl,ten} / (b * d) * (fs_1 / fc) = 0.19457006$
 $2 = A_{sl,com} / (b * d) * (fs_2 / fc) = 0.12197144$
 $v = A_{sl,mid} / (b * d) * (fsv / fc) = 0.21102767$
 and confined core properties:
 $b = 390.00$
 $d = 677.00$
 $d' = 13.00$
 $f_{cc} (5A.2, TBDY) = 30.00$
 $cc (5A.5, TBDY) = 0.002$
 $c = \text{confinement factor} = 1.00$
 $1 = A_{sl,ten} / (b * d) * (fs_1 / fc) = 0.23445239$
 $2 = A_{sl,com} / (b * d) * (fs_2 / fc) = 0.14697275$
 $v = A_{sl,mid} / (b * d) * (fsv / fc) = 0.25428343$
 Case/Assumption: Unconfined full section - Steel rupture
 ' satisfies Eq. (4.3)
 --->
 $v < v_{s,y2}$ - LHS eq.(4.5) is not satisfied
 --->
 $v < v_{s,c}$ - RHS eq.(4.5) is satisfied
 --->
 $su (4.8) = 0.33719414$
 $Mu = MRc (4.15) = 2.1636E+009$
 $u = su (4.1) = 6.8287974E-005$

Calculation of ratio l_b/d

Adequate Lap Length: $l_b/d \geq 1$

Calculation of Shear Strength $V_r = \text{Min}(V_{r1}, V_{r2}) = 1.2916\text{E}+006$

Calculation of Shear Strength at edge 1, $V_{r1} = 1.2916\text{E}+006$

$V_{r1} = V_{\text{Col}} ((10.3), \text{ASCE } 41-17) = k_n l V_{\text{ColO}}$

$V_{\text{ColO}} = 1.2916\text{E}+006$

$k_n l = 1$ (zero step-static loading)

NOTE: In expression (10-3) ' $V_s = A_v f_y d/s$ ' is replaced by ' $V_s + f V_f$ ' where V_f is the contribution of FRPs (11.3), ACI 440).

$= 1$ (normal-weight concrete)

Mean concrete strength: $f_c' = (f_c'_{\text{jacket}} \text{Area}_{\text{jacket}} + f_c'_{\text{core}} \text{Area}_{\text{core}}) / \text{Area}_{\text{section}} = 27.20$, but $f_c'^{0.5} \leq 8.3$ MPa (22.5.3.1, ACI 318-14)

$M/V_d = 2.00$

$\mu_u = 5174.584$

$V_u = 8.5087964\text{E}-020$

$d = 0.8 \cdot h = 600.00$

$N_u = 20792.05$

$A_g = 337500.00$

From (11.5.4.8), ACI 318-14: $V_s = V_{s\text{jacket}} + V_{s\text{core}} = 1.0354\text{E}+006$

where:

$V_{s\text{jacket}} = V_{s\text{j1}} + V_{s\text{j2}} = 942477.796$

$V_{s\text{j1}} = 589048.623$ is calculated for section web jacket, with:

$d = 600.00$

$A_v = 157079.633$

$f_y = 625.00$

$s = 100.00$

$V_{s\text{j1}}$ is multiplied by $\text{Col}_{\text{j1}} = 1.00$

$s/d = 0.16666667$

$V_{s\text{j2}} = 353429.174$ is calculated for section flange jacket, with:

$d = 360.00$

$A_v = 157079.633$

$f_y = 625.00$

$s = 100.00$

$V_{s\text{j2}}$ is multiplied by $\text{Col}_{\text{j2}} = 1.00$

$s/d = 0.27777778$

$V_{s\text{core}} = V_{s\text{c1}} + V_{s\text{c2}} = 92890.612$

$V_{s\text{c1}} = 92890.612$ is calculated for section web core, with:

$d = 440.00$

$A_v = 100530.965$

$f_y = 525.00$

$s = 250.00$

$V_{s\text{c1}}$ is multiplied by $\text{Col}_{\text{c1}} = 1.00$

$s/d = 0.56818182$

$V_{s\text{c2}} = 0.00$ is calculated for section flange core, with:

$d = 200.00$

$A_v = 100530.965$

$f_y = 525.00$

$s = 250.00$

$V_{s\text{c2}}$ is multiplied by $\text{Col}_{\text{c2}} = 0.00$

$s/d = 1.25$

$V_f ((11-3)-(11.4), \text{ACI } 440) = 0.00$

From (11-11), ACI 440: $V_s + V_f \leq 935437.922$

$b_w = 450.00$

Calculation of Shear Strength at edge 2, $V_{r2} = 1.2916\text{E}+006$

$V_{r2} = V_{\text{Col}} ((10.3), \text{ASCE } 41-17) = k_n l V_{\text{ColO}}$

VColO = 1.2916E+006
knl = 1 (zero step-static loading)

NOTE: In expression (10-3) ' $V_s = A_v \cdot f_y \cdot d / s$ ' is replaced by ' $V_s + f \cdot V_f$ '
where V_f is the contribution of FRPs (11.3), ACI 440).

= 1 (normal-weight concrete)
Mean concrete strength: $f_c' = (f_c'_{\text{jacket}} \cdot \text{Area}_{\text{jacket}} + f_c'_{\text{core}} \cdot \text{Area}_{\text{core}}) / \text{Area}_{\text{section}} = 27.20$, but $f_c'^{0.5} \leq 8.3$ MPa (22.5.3.1, ACI 318-14)
 $M/Vd = 2.00$
 $\mu_u = 5174.584$
 $V_u = 8.5087964E-020$
 $d = 0.8 \cdot h = 600.00$
 $N_u = 20792.05$
 $A_g = 337500.00$
From (11.5.4.8), ACI 318-14: $V_s = V_{s,\text{jacket}} + V_{s,\text{core}} = 1.0354E+006$
where:
 $V_{s,\text{jacket}} = V_{s,j1} + V_{s,j2} = 942477.796$
 $V_{s,j1} = 589048.623$ is calculated for section web jacket, with:
 $d = 600.00$
 $A_v = 157079.633$
 $f_y = 625.00$
 $s = 100.00$
 $V_{s,j1}$ is multiplied by $\text{Col},j1 = 1.00$
 $s/d = 0.16666667$
 $V_{s,j2} = 353429.174$ is calculated for section flange jacket, with:
 $d = 360.00$
 $A_v = 157079.633$
 $f_y = 625.00$
 $s = 100.00$
 $V_{s,j2}$ is multiplied by $\text{Col},j2 = 1.00$
 $s/d = 0.27777778$
 $V_{s,\text{core}} = V_{s,c1} + V_{s,c2} = 92890.612$
 $V_{s,c1} = 92890.612$ is calculated for section web core, with:
 $d = 440.00$
 $A_v = 100530.965$
 $f_y = 525.00$
 $s = 250.00$
 $V_{s,c1}$ is multiplied by $\text{Col},c1 = 1.00$
 $s/d = 0.56818182$
 $V_{s,c2} = 0.00$ is calculated for section flange core, with:
 $d = 200.00$
 $A_v = 100530.965$
 $f_y = 525.00$
 $s = 250.00$
 $V_{s,c2}$ is multiplied by $\text{Col},c2 = 0.00$
 $s/d = 1.25$
 $V_f ((11-3)-(11.4), \text{ACI } 440) = 0.00$
From (11-11), ACI 440: $V_s + V_f \leq 935437.922$
 $b_w = 450.00$

End Of Calculation of Shear Capacity ratio for element: column JTC1 of floor 1
At local axis: 3

Start Of Calculation of Shear Capacity ratio for element: column JTC1 of floor 1
At Shear local axis: 2
(Bending local axis: 3)
Section Type: rcjtcs

Constant Properties

Knowledge Factor, $\phi = 0.80$
Mean strength values are used for both shear and moment calculations.

Consequently:

Jacket

New material of Secondary Member: Concrete Strength, $f_c = f_{cm} = 30.00$

New material of Secondary Member: Steel Strength, $f_s = f_{sm} = 625.00$

Concrete Elasticity, $E_c = 25742.96$

Steel Elasticity, $E_s = 200000.00$

Existing Column

Existing material of Secondary Member: Concrete Strength, $f_c = f_{cm} = 24.00$

Existing material of Secondary Member: Steel Strength, $f_s = f_{sm} = 525.00$

Concrete Elasticity, $E_c = 23025.204$

Steel Elasticity, $E_s = 200000.00$

#####

Note: Especially for the calculation of moment strengths,
the above steel re-bar strengths are multiplied by 1.25 according to R18.6.5, ACI 318-14

Jacket

New material: Steel Strength, $f_s = 1.25 \cdot f_{sm} = 781.25$

Existing Column

Existing material: Steel Strength, $f_s = 1.25 \cdot f_{sm} = 656.25$

#####

Max Height, $H_{max} = 750.00$

Min Height, $H_{min} = 450.00$

Max Width, $W_{max} = 950.00$

Min Width, $W_{min} = 450.00$

Eccentricity, $Ecc = 250.00$

Jacket Thickness, $t_j = 100.00$

Cover Thickness, $c = 25.00$

Mean Confinement Factor overall section = 1.00

Element Length, $L = 3000.00$

Secondary Member

Smooth Bars

Ductile Steel

Without Detailing for Earthquake Resistance (including stirrups not closed at 135°)

Longitudinal Bars With Ends Lapped Starting at the End Sections

Adequate Lap Length ($l_o/l_{ou,min} \geq 1$)

No FRP Wrapping

Stepwise Properties

At local axis: 2

EDGE -A-

Shear Force, $V_a = 5.2099631E-036$

EDGE -B-

Shear Force, $V_b = -5.2099631E-036$

BOTH EDGES

Axial Force, $F = -20792.05$

Longitudinal Reinforcement Area Distribution (in 2 divisions)

-Tension: $As_t = 0.00$

-Compression: $As_c = 6691.592$

Longitudinal Reinforcement Area Distribution (in 3 divisions)

-Tension: $As_{t,ten} = 1539.38$

-Compression: $As_{c,com} = 1539.38$

-Middle: $As_{l,mid} = 3612.832$

Calculation of Shear Capacity ratio, $V_e/V_r = 1.08994$

Member Controlled by Shear ($V_e/V_r > 1$)

Calculation of Shear Demand from fig. R18.6.5, ACI 318-14 $V_e = (M_{pr1} + M_{pr2})/l_n = 1.7820E+006$

with

$M_{pr1} = \text{Max}(Mu_{1+}, Mu_{1-}) = 2.6730E+009$

$Mu_{1+} = 2.6730E+009$, is the ultimate moment strength at the edge 1 of the member in the actual moment direction which is defined for the static loading combination

$Mu_{1-} = 2.6730E+009$, is the ultimate moment strength at the edge 1 of the member in the opposite moment direction which is defined for the static loading combination

$M_{pr2} = \text{Max}(Mu_{2+}, Mu_{2-}) = 2.6730E+009$

Mu2+ = 2.6730E+009, is the ultimate moment strength at the edge 2 of the member in the actual moment direction which is defined for the the static loading combination

Mu2- = 2.6730E+009, is the ultimate moment strength at the edge 2 of the member in the opposite moment direction which is defined for the the static loading combination

Calculation of Mu1+

Calculation of ultimate curvature ϕ_u according to 4.1, Biskinis/Fardis 2013:

$$\phi_u = 4.9274896E-005$$

$$M_u = 2.6730E+009$$

with full section properties:

$$b = 450.00$$

$$d = 907.00$$

$$d' = 43.00$$

$$\nu = 0.00169807$$

$$N = 20792.05$$

$$f_c = 30.00$$

$$\phi_{co} (5A.5, TBDY) = 0.002$$

$$\text{Final value of } \phi_u: \phi_u^* = \text{shear_factor} * \text{Max}(\phi_u, \phi_{co}) = 0.00832321$$

The Shear_factor is considered equal to 1 (pure moment strength)

$$\text{From (5.4b), TBDY: } \phi_u = 0.00832321$$

$$\phi_{we} (5.4c) = 0.01453958$$

$$\phi_{ase} ((5.4d), TBDY) = (\phi_{ase1} * A_{ext} + \phi_{ase2} * A_{int}) / A_{sec} = 0.53375773$$

$$\phi_{ase1} = \text{Max}(((A_{conf,max1} - A_{noConf1}) / A_{conf,max1}) * (A_{conf,min1} / A_{conf,max1}), 0) = 0.53375773$$

The definitions of A_{noConf} , $A_{conf,min}$ and $A_{conf,max}$ are derived from generalization of the rectangular sections confinement, which is expressed by (5.4d).

The generalization is done according to Mander, J., Priestley, M., and Park, R. (1988)

"Theoretical Stress-Strain Model for Confined Concrete."

J. Struct. Eng., 10.1061/(ASCE)0733-9445(1988)114:8(1804), 1804-1826.

$A_{conf,max1} = 464100.00$ is the confined core area at levels of member with hoops and

is calculated as the area of core enclosed by the center lines of the external perimeter hoops.

$A_{conf,min1} = 395025.00$ is the confined core area at midway between the levels of hoops and

is calculated by reducing all the dimensions of the area $A_{conf,max1}$ by a length

equal to half the clear spacing between external hoops.

$A_{noConf1} = 173066.667$ is the unconfined external core area which is equal to $b_i^2/6$ as defined at (A.2).

$$\phi_{ase2} (>= \phi_{ase1}) = \text{Max}(((A_{conf,max2} - A_{noConf2}) / A_{conf,max2}) * (A_{conf,min2} / A_{conf,max2}), 0) = 0.53375773$$

The definitions of A_{noConf} , $A_{conf,min}$ and $A_{conf,max}$ are derived from generalization of the rectangular sections confinement, which is expressed by (5.4d).

The generalization is done according to Mander, J., Priestley, M., and Park, R. (1988)

"Theoretical Stress-Strain Model for Confined Concrete."

J. Struct. Eng., 10.1061/(ASCE)0733-9445(1988)114:8(1804), 1804-1826.

$A_{conf,max2} = 252164.00$ is the confined core area at levels of member with hoops and

is calculated as the area of core enclosed by the center lines of the internal perimeter hoops.

$A_{conf,min2} = 111441.00$ is the confined core area at midway between the levels of hoops and

is calculated by reducing all the dimensions of the area $A_{conf,max2}$ by a length

equal to half the clear spacing between internal hoops.

$A_{noConf2} = 110709.333$ is the unconfined internal core area which is equal to $b_i^2/6$ as defined at (A.2).

$$\phi_{psh,min} * F_{ywe} = \text{Min}(\phi_{psh,x} * F_{ywe}, \phi_{psh,y} * F_{ywe}) = 2.724$$

Expression (5.4d) for $\phi_{psh,min} * F_{ywe}$ has been multiplied by 0.3 according to 15.7.1.3 for members without earthquake detailing (90° closed stirrups)

$$\phi_{psh,x} * F_{ywe} = \phi_{psh1} * F_{ywe1} + \phi_{psh2} * F_{ywe2} = 2.724$$

$$\phi_{psh1} ((5.4d), TBDY) = L_{stir1} * A_{stir1} / (A_{sec} * s_1) = 0.00301593$$

$$L_{stir1} (\text{Length of stirrups along Y}) = 2160.00$$

$$A_{stir1} (\text{stirrups area}) = 78.53982$$

$$\phi_{psh2} (5.4d) = L_{stir2} * A_{stir2} / (A_{sec} * s_2) = 0.00056047$$

$$L_{stir2} (\text{Length of stirrups along Y}) = 1568.00$$

$$A_{stir2} (\text{stirrups area}) = 50.26548$$

$$\phi_{psh,y} * F_{ywe} = \phi_{psh1} * F_{ywe1} + \phi_{psh2} * F_{ywe2} = 3.25416$$

$$\phi_{psh1} ((5.4d), TBDY) = L_{stir1} * A_{stir1} / (A_{sec} * s_1) = 0.00357443$$

$$L_{stir1} (\text{Length of stirrups along X}) = 2560.00$$

$$A_{stir1} (\text{stirrups area}) = 78.53982$$

$psh2 ((5.4d), TBDY) = Lstir2 * Astir2 / (Asec * s2) = 0.00070345$
 $Lstir2 (\text{Length of stirrups along X}) = 1968.00$
 $Astir2 (\text{stirrups area}) = 50.26548$

Asec = 562500.00

s1 = 100.00

s2 = 250.00

fywe1 = 781.25

fywe2 = 656.25

fce = 30.00

From ((5.A5), TBDY), TBDY: cc = 0.002

c = confinement factor = 1.00

y1 = 0.0025

sh1 = 0.008

ft1 = 907.50

fy1 = 756.25

su1 = 0.032

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00

lo/lou,min = lb/lb,min = 1.00

su1 = 0.4*esu1_nominal ((5.5), TBDY) = 0.032

From table 5A.1, TBDY: esu1_nominal = 0.08,

For calculation of esu1_nominal and y1, sh1,ft1,fy1, it is considered
characteristic value fsy1 = fs1/1.2, from table 5.1, TBDY.

y1, sh1,ft1,fy1, are also multiplied by $\text{Min}(1, 1.25 * (lb/ld)^{2/3})$, from 10.3.5, ASCE 41-17.

with fs1 = (fs,jacket*Asl,ten,jacket + fs,core*Asl,ten,core)/Asl,ten = 756.25

with Es1 = (Es,jacket*Asl,ten,jacket + Es,core*Asl,ten,core)/Asl,ten = 200000.00

y2 = 0.0025

sh2 = 0.008

ft2 = 907.50

fy2 = 756.25

su2 = 0.032

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00

lo/lou,min = lb/lb,min = 1.00

su2 = 0.4*esu2_nominal ((5.5), TBDY) = 0.032

From table 5A.1, TBDY: esu2_nominal = 0.08,

For calculation of esu2_nominal and y2, sh2,ft2,fy2, it is considered
characteristic value fsy2 = fs2/1.2, from table 5.1, TBDY.

y1, sh1,ft1,fy1, are also multiplied by $\text{Min}(1, 1.25 * (lb/ld)^{2/3})$, from 10.3.5, ASCE 41-17.

with fs2 = (fs,jacket*Asl,com,jacket + fs,core*Asl,com,core)/Asl,com = 756.25

with Es2 = (Es,jacket*Asl,com,jacket + Es,core*Asl,com,core)/Asl,com = 200000.00

yv = 0.0025

shv = 0.008

ftv = 899.1522

fyv = 749.2935

suv = 0.032

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00

lo/lou,min = lb/ld = 1.00

suv = 0.4*esuv_nominal ((5.5), TBDY) = 0.032

From table 5A.1, TBDY: esuv_nominal = 0.08,

considering characteristic value fsyv = fsv/1.2, from table 5.1, TBDY
For calculation of esuv_nominal and yv, shv,ftv,fyv, it is considered
characteristic value fsyv = fsv/1.2, from table 5.1, TBDY.

y1, sh1,ft1,fy1, are also multiplied by $\text{Min}(1, 1.25 * (lb/ld)^{2/3})$, from 10.3.5, ASCE 41-17.

with fsv = (fs,jacket*Asl,mid,jacket + fs,mid*Asl,mid,core)/Asl,mid = 749.2935

with Esv = (Es,jacket*Asl,mid,jacket + Es,mid*Asl,mid,core)/Asl,mid = 200000.00

1 = Asl,ten/(b*d)*(fs1/fc) = 0.09507586

2 = Asl,com/(b*d)*(fs2/fc) = 0.09507586

v = Asl,mid/(b*d)*(fsv/fc) = 0.22108466

and confined core properties:

b = 390.00

d = 877.00

```

d' = 13.00
fcc (5A.2, TBDY) = 30.00
cc (5A.5, TBDY) = 0.002
c = confinement factor = 1.00
1 = Asl,ten/(b*d)*(fs1/fc) = 0.11345559
2 = Asl,com/(b*d)*(fs2/fc) = 0.11345559
v = Asl,mid/(b*d)*(fsv/fc) = 0.26382395
Case/Assumption: Unconfined full section - Steel rupture
'satisfies Eq. (4.3)
--->
v < vs,y2 - LHS eq.(4.5) is not satisfied
--->
v < vs,c - RHS eq.(4.5) is satisfied
--->
su (4.8) = 0.28399348
Mu = MRc (4.15) = 2.6730E+009
u = su (4.1) = 4.9274896E-005

```

Calculation of ratio lb/ld

Adequate Lap Length: lb/ld >= 1

Calculation of Mu1-

Calculation of ultimate curvature u according to 4.1, Biskinis/Fardis 2013:

```

u = 4.9274896E-005
Mu = 2.6730E+009

```

with full section properties:

```

b = 450.00
d = 907.00
d' = 43.00
v = 0.00169807
N = 20792.05
fc = 30.00
co (5A.5, TBDY) = 0.002
Final value of cu: cu* = shear_factor * Max( cu, cc) = 0.00832321
The Shear_factor is considered equal to 1 (pure moment strength)
From (5.4b), TBDY: cu = 0.00832321
we (5.4c) = 0.01453958
ase ((5.4d), TBDY) = (ase1*Aext+ase2*Aint)/Asec = 0.53375773
ase1 = Max(((Aconf,max1-AnoConf1)/Aconf,max1)*(Aconf,min1/Aconf,max1),0) = 0.53375773
The definitions of AnoConf, Aconf,min and Aconf,max are derived from generalization
of the rectangular sections confinement, which is expressed by (5.4d).
The generalization is done according to Mander, J., Priestley, M., and Park, R. (1988)
"Theoretical Stress-Strain Model for Confined Concrete."
J. Struct. Eng., 10.1061/(ASCE)0733-9445(1988)114:8(1804), 1804-1826.
Aconf,max1 = 464100.00 is the confined core area at levels of member with hoops and
is calculated as the area of core enclosed by the center lines of the external perimeter hoops.
Aconf,min1 = 395025.00 is the confined core area at midway between the levels of hoops and
is calculated by reducing all the dimensions of the area Aconf,max1 by a length
equal to half the clear spacing between external hoops.
AnoConf1 = 173066.667 is the unconfined external core area which is equal to bi2/6 as defined at (A.2).
ase2 (>=ase1) = Max(((Aconf,max2-AnoConf2)/Aconf,max2)*(Aconf,min2/Aconf,max2),0) = 0.53375773
The definitions of AnoConf, Aconf,min and Aconf,max are derived from generalization
of the rectangular sections confinement, which is expressed by (5.4d).
The generalization is done according to Mander, J., Priestley, M., and Park, R. (1988)
"Theoretical Stress-Strain Model for Confined Concrete."
J. Struct. Eng., 10.1061/(ASCE)0733-9445(1988)114:8(1804), 1804-1826.
Aconf,max2 = 252164.00 is the confined core area at levels of member with hoops and
is calculated as the area of core enclosed by the center lines of the internal perimeter hoops.
Aconf,min2 = 111441.00 is the confined core area at midway between the levels of hoops and

```

is calculated by reducing all the dimensions of the area Aconf,max2 by a length equal to half the clear spacing between internal hoops.

AnoConf2 = 110709.333 is the unconfined internal core area which is equal to $b_i^2/6$ as defined at (A.2).

$$psh_{min} \cdot F_{ywe} = \min(psh_x \cdot F_{ywe}, psh_y \cdot F_{ywe}) = 2.724$$

Expression (5.4d) for $psh_{min} \cdot F_{ywe}$ has been multiplied by 0.3 according to 15.7.1.3 for members without earthquake detailing (90° closed stirrups)

$$psh_x \cdot F_{ywe} = psh1 \cdot F_{ywe1} + ps2 \cdot F_{ywe2} = 2.724$$

$$psh1 \text{ ((5.4d), TBDY)} = Lstir1 \cdot Astir1 / (Asec \cdot s1) = 0.00301593$$

$$Lstir1 \text{ (Length of stirrups along Y)} = 2160.00$$

$$Astir1 \text{ (stirrups area)} = 78.53982$$

$$psh2 \text{ (5.4d)} = Lstir2 \cdot Astir2 / (Asec \cdot s2) = 0.00056047$$

$$Lstir2 \text{ (Length of stirrups along Y)} = 1568.00$$

$$Astir2 \text{ (stirrups area)} = 50.26548$$

$$psh_y \cdot F_{ywe} = psh1 \cdot F_{ywe1} + ps2 \cdot F_{ywe2} = 3.25416$$

$$psh1 \text{ ((5.4d), TBDY)} = Lstir1 \cdot Astir1 / (Asec \cdot s1) = 0.00357443$$

$$Lstir1 \text{ (Length of stirrups along X)} = 2560.00$$

$$Astir1 \text{ (stirrups area)} = 78.53982$$

$$psh2 \text{ ((5.4d), TBDY)} = Lstir2 \cdot Astir2 / (Asec \cdot s2) = 0.00070345$$

$$Lstir2 \text{ (Length of stirrups along X)} = 1968.00$$

$$Astir2 \text{ (stirrups area)} = 50.26548$$

$$Asec = 562500.00$$

$$s1 = 100.00$$

$$s2 = 250.00$$

$$fywe1 = 781.25$$

$$fywe2 = 656.25$$

$$fce = 30.00$$

$$\text{From ((5.A5), TBDY), TBDY: } cc = 0.002$$

$$c = \text{confinement factor} = 1.00$$

$$y1 = 0.0025$$

$$sh1 = 0.008$$

$$ft1 = 907.50$$

$$fy1 = 756.25$$

$$su1 = 0.032$$

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor and also multiplied by the shear_factor according to 15.7.1.4, with Shear_factor = 1.00

$$lo/lo_{min} = lb/lb_{min} = 1.00$$

$$su1 = 0.4 \cdot esu1_{nominal} \text{ ((5.5), TBDY)} = 0.032$$

From table 5A.1, TBDY: $esu1_{nominal} = 0.08$,

For calculation of $esu1_{nominal}$ and $y1, sh1, ft1, fy1$, it is considered characteristic value $fsy1 = fs1/1.2$, from table 5.1, TBDY.

$y1, sh1, ft1, fy1$, are also multiplied by $\min(1, 1.25 \cdot (lb/lb_{min})^{2/3})$, from 10.3.5, ASCE 41-17.

$$\text{with } fs1 = (fs_{jacket} \cdot Asl_{ten,jacket} + fs_{core} \cdot Asl_{ten,core}) / Asl_{ten} = 756.25$$

$$\text{with } Es1 = (Es_{jacket} \cdot Asl_{ten,jacket} + Es_{core} \cdot Asl_{ten,core}) / Asl_{ten} = 200000.00$$

$$y2 = 0.0025$$

$$sh2 = 0.008$$

$$ft2 = 907.50$$

$$fy2 = 756.25$$

$$su2 = 0.032$$

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor and also multiplied by the shear_factor according to 15.7.1.4, with Shear_factor = 1.00

$$lo/lo_{min} = lb/lb_{min} = 1.00$$

$$su2 = 0.4 \cdot esu2_{nominal} \text{ ((5.5), TBDY)} = 0.032$$

From table 5A.1, TBDY: $esu2_{nominal} = 0.08$,

For calculation of $esu2_{nominal}$ and $y2, sh2, ft2, fy2$, it is considered characteristic value $fsy2 = fs2/1.2$, from table 5.1, TBDY.

$y2, sh2, ft2, fy2$, are also multiplied by $\min(1, 1.25 \cdot (lb/lb_{min})^{2/3})$, from 10.3.5, ASCE 41-17.

$$\text{with } fs2 = (fs_{jacket} \cdot Asl_{com,jacket} + fs_{core} \cdot Asl_{com,core}) / Asl_{com} = 756.25$$

$$\text{with } Es2 = (Es_{jacket} \cdot Asl_{com,jacket} + Es_{core} \cdot Asl_{com,core}) / Asl_{com} = 200000.00$$

$$yv = 0.0025$$

$$shv = 0.008$$

$$ftv = 899.1522$$

$$fyv = 749.2935$$

```

suv = 0.032
using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00
lo/lou,min = lb/ld = 1.00
suv = 0.4*esuvnominal ((5.5), TBDY) = 0.032
From table 5A.1, TBDY: esuvnominal = 0.08,
considering characteristic value fsyv = fsv/1.2, from table 5.1, TBDY
For calculation of esuvnominal and yv, shv,ftv,fyv, it is considered
characteristic value fsyv = fsv/1.2, from table 5.1, TBDY.
y1, sh1,ft1,fy1, are also multiplied by Min(1,1.25*(lb/ld)^ 2/3), from 10.3.5, ASCE 41-17.
with fsv = (fsjacket*Aslmid,jacket + fsmid*Aslmid,core)/Aslmid = 749.2935
with Esv = (Esjacket*Aslmid,jacket + Esmid*Aslmid,core)/Aslmid = 200000.00
1 = Aslten/(b*d)*(fs1/fc) = 0.09507586
2 = Aslcom/(b*d)*(fs2/fc) = 0.09507586
v = Aslmid/(b*d)*(fsv/fc) = 0.22108466
and confined core properties:
b = 390.00
d = 877.00
d' = 13.00
fcc (5A.2, TBDY) = 30.00
cc (5A.5, TBDY) = 0.002
c = confinement factor = 1.00
1 = Aslten/(b*d)*(fs1/fc) = 0.11345559
2 = Aslcom/(b*d)*(fs2/fc) = 0.11345559
v = Aslmid/(b*d)*(fsv/fc) = 0.26382395
Case/Assumption: Unconfined full section - Steel rupture
'satisfies Eq. (4.3)
---->
v < vs,y2 - LHS eq.(4.5) is not satisfied
---->
v < vs,c - RHS eq.(4.5) is satisfied
---->
su (4.8) = 0.28399348
Mu = MRc (4.15) = 2.6730E+009
u = su (4.1) = 4.9274896E-005
-----

Calculation of ratio lb/ld
-----
Adequate Lap Length: lb/ld >= 1
-----
-----
Calculation of Mu2+
-----
-----
Calculation of ultimate curvature u according to 4.1, Biskinis/Fardis 2013:
u = 4.9274896E-005
Mu = 2.6730E+009
-----
with full section properties:
b = 450.00
d = 907.00
d' = 43.00
v = 0.00169807
N = 20792.05
fc = 30.00
co (5A.5, TBDY) = 0.002
Final value of cu: cu* = shear_factor * Max( cu, cc) = 0.00832321
The Shear_factor is considered equal to 1 (pure moment strength)
From (5.4b), TBDY: cu = 0.00832321
we (5.4c) = 0.01453958
ase ((5.4d), TBDY) = (ase1*Aext+ ase2*Aint)/Asec = 0.53375773
ase1 = Max(((Aconf,max1-AnoConf1)/Aconf,max1)*(Aconf,min1/Aconf,max1),0) = 0.53375773
The definitions of AnoConf, Aconf,min and Aconf,max are derived from generalization

```

of the rectangular sections confinement, which is expressed by (5.4d).

The generalization is done according to Mander, J., Priestley, M., and Park, R. (1988)

"Theoretical Stress-Strain Model for Confined Concrete."

J. Struct. Eng., 10.1061/(ASCE)0733-9445(1988)114:8(1804), 1804-1826.

$A_{conf,max1} = 464100.00$ is the confined core area at levels of member with hoops and

is calculated as the area of core enclosed by the center lines of the external perimeter hoops.

$A_{conf,min1} = 395025.00$ is the confined core area at midway between the levels of hoops and

is calculated by reducing all the dimensions of the area $A_{conf,max1}$ by a length equal to half the clear spacing between external hoops.

$A_{noConf1} = 173066.667$ is the unconfined external core area which is equal to $b_i^2/6$ as defined at (A.2).

$ase2 (>= ase1) = \text{Max}(((A_{conf,max2} - A_{noConf2})/A_{conf,max2}) * (A_{conf,min2}/A_{conf,max2}), 0) = 0.53375773$

The definitions of A_{noConf} , $A_{conf,min}$ and $A_{conf,max}$ are derived from generalization of the rectangular sections confinement, which is expressed by (5.4d).

The generalization is done according to Mander, J., Priestley, M., and Park, R. (1988)

"Theoretical Stress-Strain Model for Confined Concrete."

J. Struct. Eng., 10.1061/(ASCE)0733-9445(1988)114:8(1804), 1804-1826.

$A_{conf,max2} = 252164.00$ is the confined core area at levels of member with hoops and

is calculated as the area of core enclosed by the center lines of the internal perimeter hoops.

$A_{conf,min2} = 111441.00$ is the confined core area at midway between the levels of hoops and

is calculated by reducing all the dimensions of the area $A_{conf,max2}$ by a length equal to half the clear spacing between internal hoops.

$A_{noConf2} = 110709.333$ is the unconfined internal core area which is equal to $b_i^2/6$ as defined at (A.2).

$psh_{min} * F_{ywe} = \text{Min}(psh_x * F_{ywe}, psh_y * F_{ywe}) = 2.724$

Expression (5.4d) for $psh_{min} * F_{ywe}$ has been multiplied by 0.3 according to 15.7.1.3 for members without earthquake detailing (90° closed stirrups)

 $psh_x * F_{ywe} = psh1 * F_{ywe1} + ps2 * F_{ywe2} = 2.724$

$psh1 ((5.4d), TBDY) = L_{stir1} * A_{stir1} / (A_{sec} * s1) = 0.00301593$

L_{stir1} (Length of stirrups along Y) = 2160.00

A_{stir1} (stirrups area) = 78.53982

$psh2 ((5.4d)) = L_{stir2} * A_{stir2} / (A_{sec} * s2) = 0.00056047$

L_{stir2} (Length of stirrups along Y) = 1568.00

A_{stir2} (stirrups area) = 50.26548

 $psh_y * F_{ywe} = psh1 * F_{ywe1} + ps2 * F_{ywe2} = 3.25416$

$psh1 ((5.4d), TBDY) = L_{stir1} * A_{stir1} / (A_{sec} * s1) = 0.00357443$

L_{stir1} (Length of stirrups along X) = 2560.00

A_{stir1} (stirrups area) = 78.53982

$psh2 ((5.4d), TBDY) = L_{stir2} * A_{stir2} / (A_{sec} * s2) = 0.00070345$

L_{stir2} (Length of stirrups along X) = 1968.00

A_{stir2} (stirrups area) = 50.26548

 $A_{sec} = 562500.00$

$s1 = 100.00$

$s2 = 250.00$

$f_{ywe1} = 781.25$

$f_{ywe2} = 656.25$

$f_{ce} = 30.00$

From ((5.A5), TBDY), TBDY: $cc = 0.002$

c = confinement factor = 1.00

$y1 = 0.0025$

$sh1 = 0.008$

$ft1 = 907.50$

$fy1 = 756.25$

$su1 = 0.032$

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor

and also multiplied by the shear_factor according to 15.7.1.4, with

Shear_factor = 1.00

$lo/lo_{u,min} = l_b/l_d = 1.00$

$su1 = 0.4 * esu1_{nominal} ((5.5), TBDY) = 0.032$

From table 5A.1, TBDY: $esu1_{nominal} = 0.08$,

For calculation of $esu1_{nominal}$ and $y1$, $sh1$, $ft1$, $fy1$, it is considered

characteristic value $fsy1 = fs1/1.2$, from table 5.1, TBDY.

$y1$, $sh1$, $ft1$, $fy1$, are also multiplied by $\text{Min}(1, 1.25 * (l_b/l_d)^{2/3})$, from 10.3.5, ASCE 41-17.

with $fs1 = (f_{s,jacket} * A_{s,ten,jacket} + f_{s,core} * A_{s,ten,core}) / A_{s,ten} = 756.25$

with $Es1 = (E_{s,jacket} * A_{s,ten,jacket} + E_{s,core} * A_{s,ten,core}) / A_{s,ten} = 200000.00$

$y2 = 0.0025$

```

sh2 = 0.008
ft2 = 907.50
fy2 = 756.25
su2 = 0.032
    using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
    and also multiplied by the shear_factor according to 15.7.1.4, with
    Shear_factor = 1.00
    lo/lo,min = lb/lb,min = 1.00
    su2 = 0.4*esu2_nominal ((5.5), TBDY) = 0.032
    From table 5A.1, TBDY: esu2_nominal = 0.08,
    For calculation of esu2_nominal and y2, sh2,ft2,fy2, it is considered
    characteristic value fsy2 = fs2/1.2, from table 5.1, TBDY.
    y1, sh1,ft1,fy1, are also multiplied by Min(1,1.25*(lb/lb)^ 2/3), from 10.3.5, ASCE 41-17.
    with fs2 = (fs,jacket*Asl,com,jacket + fs,core*Asl,com,core)/Asl,com = 756.25
    with Es2 = (Es,jacket*Asl,com,jacket + Es,core*Asl,com,core)/Asl,com = 200000.00
yv = 0.0025
shv = 0.008
ftv = 899.1522
fyv = 749.2935
suv = 0.032
    using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
    and also multiplied by the shear_factor according to 15.7.1.4, with
    Shear_factor = 1.00
    lo/lo,min = lb/lb = 1.00
    suv = 0.4*esuv_nominal ((5.5), TBDY) = 0.032
    From table 5A.1, TBDY: esuv_nominal = 0.08,
    considering characteristic value fsyv = fsv/1.2, from table 5.1, TBDY
    For calculation of esuv_nominal and yv, shv,ftv,fyv, it is considered
    characteristic value fsyv = fsv/1.2, from table 5.1, TBDY.
    y1, sh1,ft1,fy1, are also multiplied by Min(1,1.25*(lb/lb)^ 2/3), from 10.3.5, ASCE 41-17.
    with fsv = (fs,jacket*Asl,mid,jacket + fs,mid*Asl,mid,core)/Asl,mid = 749.2935
    with Esv = (Es,jacket*Asl,mid,jacket + Es,mid*Asl,mid,core)/Asl,mid = 200000.00
1 = Asl,ten/(b*d)*(fs1/fc) = 0.09507586
2 = Asl,com/(b*d)*(fs2/fc) = 0.09507586
v = Asl,mid/(b*d)*(fsv/fc) = 0.22108466
and confined core properties:
b = 390.00
d = 877.00
d' = 13.00
fcc (5A.2, TBDY) = 30.00
cc (5A.5, TBDY) = 0.002
c = confinement factor = 1.00
1 = Asl,ten/(b*d)*(fs1/fc) = 0.11345559
2 = Asl,com/(b*d)*(fs2/fc) = 0.11345559
v = Asl,mid/(b*d)*(fsv/fc) = 0.26382395
Case/Assumption: Unconfined full section - Steel rupture
' satisfies Eq. (4.3)
--->
v < vs,y2 - LHS eq.(4.5) is not satisfied
--->
v < vs,c - RHS eq.(4.5) is satisfied
--->
su (4.8) = 0.28399348
Mu = MRc (4.15) = 2.6730E+009
u = su (4.1) = 4.9274896E-005

```

Calculation of ratio lb/lb

Adequate Lap Length: lb/lb >= 1

Calculation of Mu2-

Calculation of ultimate curvature ϕ_u according to 4.1, Biskinis/Fardis 2013:

$$\phi_u = 4.9274896E-005$$

$$\mu = 2.6730E+009$$

with full section properties:

$$b = 450.00$$

$$d = 907.00$$

$$d' = 43.00$$

$$v = 0.00169807$$

$$N = 20792.05$$

$$f_c = 30.00$$

$$\phi_{co}(5A.5, \text{TB DY}) = 0.002$$

$$\text{Final value of } \phi_{cu}: \phi_{cu}^* = \text{shear_factor} * \text{Max}(\phi_{cu}, \phi_{cc}) = 0.00832321$$

The Shear_factor is considered equal to 1 (pure moment strength)

$$\text{From (5.4b), TB DY: } \phi_{cu} = 0.00832321$$

$$\phi_{we}(5.4c) = 0.01453958$$

$$\phi_{ase}((5.4d), \text{TB DY}) = (\phi_{ase1} * A_{ext} + \phi_{ase2} * A_{int}) / A_{sec} = 0.53375773$$

$$\phi_{ase1} = \text{Max}(((A_{conf,max1} - A_{noConf1}) / A_{conf,max1}) * (A_{conf,min1} / A_{conf,max1}), 0) = 0.53375773$$

The definitions of A_{noConf} , $A_{conf,min}$ and $A_{conf,max}$ are derived from generalization of the rectangular sections confinement, which is expressed by (5.4d).

The generalization is done according to Mander, J., Priestley, M., and Park, R. (1988)

"Theoretical Stress-Strain Model for Confined Concrete."

J. Struct. Eng., 10.1061/(ASCE)0733-9445(1988)114:8(1804), 1804-1826.

$A_{conf,max1} = 464100.00$ is the confined core area at levels of member with hoops and

is calculated as the area of core enclosed by the center lines of the external perimeter hoops.

$A_{conf,min1} = 395025.00$ is the confined core area at midway between the levels of hoops and

is calculated by reducing all the dimensions of the area $A_{conf,max1}$ by a length equal to half the clear spacing between external hoops.

$A_{noConf1} = 173066.667$ is the unconfined external core area which is equal to $b_i d_i / 6$ as defined at (A.2).

$$\phi_{ase2} (\geq \phi_{ase1}) = \text{Max}(((A_{conf,max2} - A_{noConf2}) / A_{conf,max2}) * (A_{conf,min2} / A_{conf,max2}), 0) = 0.53375773$$

The definitions of A_{noConf} , $A_{conf,min}$ and $A_{conf,max}$ are derived from generalization of the rectangular sections confinement, which is expressed by (5.4d).

The generalization is done according to Mander, J., Priestley, M., and Park, R. (1988)

"Theoretical Stress-Strain Model for Confined Concrete."

J. Struct. Eng., 10.1061/(ASCE)0733-9445(1988)114:8(1804), 1804-1826.

$A_{conf,max2} = 252164.00$ is the confined core area at levels of member with hoops and

is calculated as the area of core enclosed by the center lines of the internal perimeter hoops.

$A_{conf,min2} = 111441.00$ is the confined core area at midway between the levels of hoops and

is calculated by reducing all the dimensions of the area $A_{conf,max2}$ by a length equal to half the clear spacing between internal hoops.

$A_{noConf2} = 110709.333$ is the unconfined internal core area which is equal to $b_i d_i / 6$ as defined at (A.2).

$$\phi_{psh,min} * F_{ywe} = \text{Min}(\phi_{psh,x} * F_{ywe}, \phi_{psh,y} * F_{ywe}) = 2.724$$

Expression (5.4d) for $\phi_{psh,min} * F_{ywe}$ has been multiplied by 0.3 according to 15.7.1.3 for members without earthquake detailing (90° closed stirrups)

$$\phi_{psh,x} * F_{ywe} = \phi_{psh1} * F_{ywe1} + \phi_{ps2} * F_{ywe2} = 2.724$$

$$\phi_{psh1}((5.4d), \text{TB DY}) = L_{stir1} * A_{stir1} / (A_{sec} * s1) = 0.00301593$$

$$L_{stir1} \text{ (Length of stirrups along Y)} = 2160.00$$

$$A_{stir1} \text{ (stirrups area)} = 78.53982$$

$$\phi_{psh2}(5.4d) = L_{stir2} * A_{stir2} / (A_{sec} * s2) = 0.00056047$$

$$L_{stir2} \text{ (Length of stirrups along Y)} = 1568.00$$

$$A_{stir2} \text{ (stirrups area)} = 50.26548$$

$$\phi_{psh,y} * F_{ywe} = \phi_{psh1} * F_{ywe1} + \phi_{ps2} * F_{ywe2} = 3.25416$$

$$\phi_{psh1}((5.4d), \text{TB DY}) = L_{stir1} * A_{stir1} / (A_{sec} * s1) = 0.00357443$$

$$L_{stir1} \text{ (Length of stirrups along X)} = 2560.00$$

$$A_{stir1} \text{ (stirrups area)} = 78.53982$$

$$\phi_{psh2}((5.4d), \text{TB DY}) = L_{stir2} * A_{stir2} / (A_{sec} * s2) = 0.00070345$$

$$L_{stir2} \text{ (Length of stirrups along X)} = 1968.00$$

$$A_{stir2} \text{ (stirrups area)} = 50.26548$$

$$A_{sec} = 562500.00$$

$$s1 = 100.00$$

$$s2 = 250.00$$

$$f_{ywe1} = 781.25$$

$$f_{ywe2} = 656.25$$

$$f_{ce} = 30.00$$

From ((5.A.5), TBDY), TBDY: $cc = 0.002$
 $c = \text{confinement factor} = 1.00$
 $y1 = 0.0025$
 $sh1 = 0.008$
 $ft1 = 907.50$
 $fy1 = 756.25$
 $su1 = 0.032$
 using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
 and also multiplied by the shear_factor according to 15.7.1.4, with
 $\text{Shear_factor} = 1.00$
 $lo/lou,min = lb/ld = 1.00$
 $su1 = 0.4 * esu1_nominal ((5.5), TBDY) = 0.032$
 From table 5A.1, TBDY: $esu1_nominal = 0.08$,
 For calculation of $esu1_nominal$ and $y1, sh1, ft1, fy1$, it is considered
 characteristic value $fsy1 = fs1/1.2$, from table 5.1, TBDY.
 $y1, sh1, ft1, fy1$, are also multiplied by $\text{Min}(1, 1.25 * (lb/ld)^{2/3})$, from 10.3.5, ASCE 41-17.
 with $fs1 = (fs_jacket * Asl,ten,jacket + fs_core * Asl,ten,core) / Asl,ten = 756.25$
 with $Es1 = (Es_jacket * Asl,ten,jacket + Es_core * Asl,ten,core) / Asl,ten = 200000.00$
 $y2 = 0.0025$
 $sh2 = 0.008$
 $ft2 = 907.50$
 $fy2 = 756.25$
 $su2 = 0.032$
 using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
 and also multiplied by the shear_factor according to 15.7.1.4, with
 $\text{Shear_factor} = 1.00$
 $lo/lou,min = lb/lb,min = 1.00$
 $su2 = 0.4 * esu2_nominal ((5.5), TBDY) = 0.032$
 From table 5A.1, TBDY: $esu2_nominal = 0.08$,
 For calculation of $esu2_nominal$ and $y2, sh2, ft2, fy2$, it is considered
 characteristic value $fsy2 = fs2/1.2$, from table 5.1, TBDY.
 $y1, sh1, ft1, fy1$, are also multiplied by $\text{Min}(1, 1.25 * (lb/ld)^{2/3})$, from 10.3.5, ASCE 41-17.
 with $fs2 = (fs_jacket * Asl,com,jacket + fs_core * Asl,com,core) / Asl,com = 756.25$
 with $Es2 = (Es_jacket * Asl,com,jacket + Es_core * Asl,com,core) / Asl,com = 200000.00$
 $yv = 0.0025$
 $shv = 0.008$
 $ftv = 899.1522$
 $fyv = 749.2935$
 $suv = 0.032$
 using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
 and also multiplied by the shear_factor according to 15.7.1.4, with
 $\text{Shear_factor} = 1.00$
 $lo/lou,min = lb/ld = 1.00$
 $suv = 0.4 * esuv_nominal ((5.5), TBDY) = 0.032$
 From table 5A.1, TBDY: $esuv_nominal = 0.08$,
 considering characteristic value $fsyv = fsv/1.2$, from table 5.1, TBDY
 For calculation of $esuv_nominal$ and yv, shv, ftv, fyv , it is considered
 characteristic value $fsyv = fsv/1.2$, from table 5.1, TBDY.
 $y1, sh1, ft1, fy1$, are also multiplied by $\text{Min}(1, 1.25 * (lb/ld)^{2/3})$, from 10.3.5, ASCE 41-17.
 with $fsv = (fs_jacket * Asl,mid,jacket + fs_mid * Asl,mid,core) / Asl,mid = 749.2935$
 with $Es_v = (Es_jacket * Asl,mid,jacket + Es_mid * Asl,mid,core) / Asl,mid = 200000.00$
 $1 = Asl,ten / (b * d) * (fs1 / fc) = 0.09507586$
 $2 = Asl,com / (b * d) * (fs2 / fc) = 0.09507586$
 $v = Asl,mid / (b * d) * (fsv / fc) = 0.22108466$
 and confined core properties:
 $b = 390.00$
 $d = 877.00$
 $d' = 13.00$
 $fcc (5A.2, TBDY) = 30.00$
 $cc (5A.5, TBDY) = 0.002$
 $c = \text{confinement factor} = 1.00$
 $1 = Asl,ten / (b * d) * (fs1 / fc) = 0.11345559$
 $2 = Asl,com / (b * d) * (fs2 / fc) = 0.11345559$
 $v = Asl,mid / (b * d) * (fsv / fc) = 0.26382395$
 Case/Assumption: Unconfined full section - Steel rupture
 ' satisfies Eq. (4.3)

--->

$v < v_{s,y2}$ - LHS eq.(4.5) is not satisfied

---->

$v < v_{s,c}$ - RHS eq.(4.5) is satisfied

---->

$$s_u(4.8) = 0.28399348$$

$$M_u = M_{Rc}(4.15) = 2.6730E+009$$

$$u = s_u(4.1) = 4.9274896E-005$$

Calculation of ratio l_b/l_d

Adequate Lap Length: $l_b/l_d \geq 1$

Calculation of Shear Strength $V_r = \text{Min}(V_{r1}, V_{r2}) = 1.6349E+006$

Calculation of Shear Strength at edge 1, $V_{r1} = 1.6349E+006$

$$V_{r1} = V_{Col}((10.3), ASCE 41-17) = k_n l^* V_{Col0}$$

$$V_{Col0} = 1.6349E+006$$

$$k_n l = 1 \text{ (zero step-static loading)}$$

NOTE: In expression (10-3) ' $V_s = A_v f_y d/s$ ' is replaced by ' $V_{s+} + f^* V_f$ ' where V_f is the contribution of FRPs (11.3), ACI 440).

= 1 (normal-weight concrete)

Mean concrete strength: $f'_c = (f'_{c,jacket} \cdot \text{Area}_{jacket} + f'_{c,core} \cdot \text{Area}_{core}) / \text{Area}_{section} = 27.20$, but $f'_c^{0.5} \leq 8.3$ MPa (22.5.3.1, ACI 318-14)

$$M/Vd = 2.00$$

$$M_u = 4.16869$$

$$V_u = 5.2099631E-036$$

$$d = 0.8 \cdot h = 760.00$$

$$N_u = 20792.05$$

$$A_g = 427500.00$$

$$\text{From (11.5.4.8), ACI 318-14: } V_s = V_{s,jacket} + V_{s,core} = 1.2262E+006$$

where:

$$V_{s,jacket} = V_{s,j1} + V_{s,j2} = 1.0996E+006$$

$V_{s,j1} = 353429.174$ is calculated for section web jacket, with:

$$d = 360.00$$

$$A_v = 157079.633$$

$$f_y = 625.00$$

$$s = 100.00$$

$$V_{s,j1} \text{ is multiplied by } Col,j1 = 1.00$$

$$s/d = 0.27777778$$

$V_{s,j2} = 746128.255$ is calculated for section flange jacket, with:

$$d = 760.00$$

$$A_v = 157079.633$$

$$f_y = 625.00$$

$$s = 100.00$$

$$V_{s,j2} \text{ is multiplied by } Col,j2 = 1.00$$

$$s/d = 0.13157895$$

$$V_{s,core} = V_{s,c1} + V_{s,c2} = 126669.016$$

$V_{s,c1} = 0.00$ is calculated for section web core, with:

$$d = 200.00$$

$$A_v = 100530.965$$

$$f_y = 525.00$$

$$s = 250.00$$

$$V_{s,c1} \text{ is multiplied by } Col,c1 = 0.00$$

$$s/d = 1.25$$

$V_{s,c2} = 126669.016$ is calculated for section flange core, with:

$$d = 600.00$$

$$A_v = 100530.965$$

$$f_y = 525.00$$

$$s = 250.00$$

$$V_{s,c2} \text{ is multiplied by } Col,c2 = 1.00$$

$$s/d = 0.41666667$$

Vf ((11-3)-(11.4), ACI 440) = 0.00
From (11-11), ACI 440: $V_s + V_f \leq 1.1849E+006$
bw = 450.00

Calculation of Shear Strength at edge 2, $V_{r2} = 1.6349E+006$
 $V_{r2} = V_{Col} ((10.3), ASCE 41-17) = knl * V_{Col0}$
 $V_{Col0} = 1.6349E+006$
knl = 1 (zero step-static loading)

NOTE: In expression (10-3) ' $V_s = A_v * f_y * d / s$ ' is replaced by ' $V_s + f * V_f$ '
where V_f is the contribution of FRPs (11.3), ACI 440).

= 1 (normal-weight concrete)
Mean concrete strength: $f_c' = (f_c'_{jacket} * Area_{jacket} + f_c'_{core} * Area_{core}) / Area_{section} = 27.20$, but $f_c'^{0.5} \leq 8.3$
MPa (22.5.3.1, ACI 318-14)
 $M/Vd = 2.00$
 $\mu_u = 4.16869$
 $V_u = 5.2099631E-036$
 $d = 0.8 * h = 760.00$
 $N_u = 20792.05$
 $A_g = 427500.00$
From (11.5.4.8), ACI 318-14: $V_s = V_{sjacket} + V_{s,core} = 1.2262E+006$
where:
 $V_{sjacket} = V_{sj1} + V_{sj2} = 1.0996E+006$
 $V_{sj1} = 353429.174$ is calculated for section web jacket, with:
 $d = 360.00$
 $A_v = 157079.633$
 $f_y = 625.00$
 $s = 100.00$
 V_{sj1} is multiplied by $Col,j1 = 1.00$
 $s/d = 0.27777778$
 $V_{sj2} = 746128.255$ is calculated for section flange jacket, with:
 $d = 760.00$
 $A_v = 157079.633$
 $f_y = 625.00$
 $s = 100.00$
 V_{sj2} is multiplied by $Col,j2 = 1.00$
 $s/d = 0.13157895$
 $V_{s,core} = V_{s,c1} + V_{s,c2} = 126669.016$
 $V_{s,c1} = 0.00$ is calculated for section web core, with:
 $d = 200.00$
 $A_v = 100530.965$
 $f_y = 525.00$
 $s = 250.00$
 $V_{s,c1}$ is multiplied by $Col,c1 = 0.00$
 $s/d = 1.25$
 $V_{s,c2} = 126669.016$ is calculated for section flange core, with:
 $d = 600.00$
 $A_v = 100530.965$
 $f_y = 525.00$
 $s = 250.00$
 $V_{s,c2}$ is multiplied by $Col,c2 = 1.00$
 $s/d = 0.41666667$
 $V_f ((11-3)-(11.4), ACI 440) = 0.00$
From (11-11), ACI 440: $V_s + V_f \leq 1.1849E+006$
bw = 450.00

End Of Calculation of Shear Capacity ratio for element: column JTC1 of floor 1
At local axis: 2

Start Of Calculation of Chord Rotation Capacity for element: column JTC1 of floor 1
At local axis: 3

Integration Section: (b)

Section Type: rcjtcs

Constant Properties

Knowledge Factor, $\gamma = 0.80$

Chord Rotation is generally considered as Deformation-Controlled Action according to Table C7-1, ASCE 41-17.

Mean strengths are used for Deformation-Controlled Actions according to 7.5.1.3, ASCE 41-17

Consequently:

Jacket

New material of Secondary Member: Concrete Strength, $f_c = f_{cm} = 30.00$

New material of Secondary Member: Steel Strength, $f_s = f_{sm} = 625.00$

Concrete Elasticity, $E_c = 25742.96$

Steel Elasticity, $E_s = 200000.00$

Existing Column

Existing material of Secondary Member: Concrete Strength, $f_c = f_{cm} = 24.00$

Existing material of Secondary Member: Steel Strength, $f_s = f_{sm} = 525.00$

Concrete Elasticity, $E_c = 23025.204$

Steel Elasticity, $E_s = 200000.00$

Max Height, $H_{max} = 750.00$

Min Height, $H_{min} = 450.00$

Max Width, $W_{max} = 950.00$

Min Width, $W_{min} = 450.00$

Eccentricity, $Ecc = 250.00$

Jacket Thickness, $t_j = 100.00$

Cover Thickness, $c = 25.00$

Element Length, $L = 3000.00$

Secondary Member

Smooth Bars

Ductile Steel

Without Detailing for Earthquake Resistance (including stirrups not closed at 135°)

Longitudinal Bars With Ends Lapped Starting at the End Sections

Adequate Lap Length ($l_b/d \geq 1$)

No FRP Wrapping

Stepwise Properties

Bending Moment, $M = 326833.199$

Shear Force, $V_2 = 8294.64$

Shear Force, $V_3 = 1.96926$

Axial Force, $F = -22375.589$

Longitudinal Reinforcement Area Distribution (in 2 divisions)

-Tension: $As_t = 0.00$

-Compression: $As_c = 6691.592$

Longitudinal Reinforcement Area Distribution (in 3 divisions)

-Tension: $As_{t,ten} = 1539.38$

-Compression: $As_{c,com} = 1539.38$

-Middle: $As_{mid} = 3612.832$

Longitudinal External Reinforcement Area Distribution (in 3 divisions)

-Tension: $As_{t,ten,jacket} = 1231.504$

-Compression: $As_{c,com,jacket} = 1231.504$

-Middle: $As_{mid,jacket} = 2689.203$

Longitudinal Internal Reinforcement Area Distribution (in 3 divisions)

-Tension: $As_{t,ten,core} = 307.8761$

-Compression: $As_{c,com,core} = 307.8761$

-Middle: $As_{mid,core} = 923.6282$

Mean Diameter of Tension Reinforcement, $Db_L = 16.57143$

Existing component: From table 7-7, ASCE 41_17: Final chord rotation Capacity $u_R = \gamma \cdot u = 0.02811637$

$u = \gamma \cdot y + p = 0.03514547$

- Calculation of γ -

$y = (M_y * L_s / 3) / E_{eff} = 0.0005008 \text{ ((4.29), Biskinis Phd)}$
 $M_y = 1.2941E+009$
 $L_s = M/V \text{ (with } L_s > 0.1 * L \text{ and } L_s < 2 * L) = 300.00$
 From table 10.5, ASCE 41_17: $E_{eff} = \text{factor} * E_c * I_g = 2.5841E+014$
 $\text{factor} = 0.30$
 $A_g = 562500.00$
 Mean concrete strength: $f_c' = (f_c'_{\text{jacket}} * \text{Area}_{\text{jacket}} + f_c'_{\text{core}} * \text{Area}_{\text{core}}) / \text{Area}_{\text{section}} = 27.20$
 $N = 22375.589$
 $E_c * I_g = E_{c_jacket} * I_{g_jacket} + E_{c_core} * I_{g_core} = 8.6137E+014$

Calculation of Yielding Moment M_y

Calculation of y and M_y according to Annex 7 -

$y = \text{Min}(y_{\text{ten}}, y_{\text{com}})$
 $y_{\text{ten}} = 4.4894872E-006$
 with $f_y = 601.9953$
 $d = 907.00$
 $y = 0.26080489$
 $A = 0.016486$
 $B = 0.00867717$
 with $p_t = 0.0037716$
 $p_c = 0.0037716$
 $p_v = 0.00885172$
 $N = 22375.589$
 $b = 450.00$
 $" = 0.04740904$
 $y_{\text{comp}} = 8.8904803E-006$
 with $f_c = 30.00$
 $E_c = 25742.96$
 $y = 0.26013738$
 $A = 0.01626426$
 $B = 0.0085861$
 with $E_s = 200000.00$

Calculation of ratio I_b/I_d

Adequate Lap Length: $I_b/I_d \geq 1$

- Calculation of p -

From table 10-8: $p = 0.03464467$

with:

- Columns not controlled by inadequate development or splicing along the clear height because $I_b/I_d \geq 1$

shear control ratio $V_y E / V_{col} E = 1.08994$

$d = d_{\text{external}} = 907.00$

$s = s_{\text{external}} = 0.00$

- $t = s_1 + s_2 + 2 * t_f / b_w * (f_{fe} / f_s) = 0.00427788$

jacket: $s_1 = A_{v1} * L_{\text{stir1}} / (s_1 * A_g) = 0.00357443$

$A_{v1} = 78.53982$, is the area of every stirrup parallel to loading (shear) direction

$L_{\text{stir1}} = 2560.00$, is the total Length of all stirrups parallel to loading (shear) direction

$s_1 = 100.00$

core: $s_2 = A_{v2} * L_{\text{stir2}} / (s_2 * A_g) = 0.00070345$

$A_{v2} = 50.26548$, is the area of every stirrup parallel to loading (shear) direction

$L_{\text{stir2}} = 1968.00$, is the total Length of all stirrups parallel to loading (shear) direction

$s_2 = 250.00$

The term $2 * t_f / b_w * (f_{fe} / f_s)$ is implemented to account for FRP contribution

where $f = 2 * t_f / b_w$ is FRP ratio (EC8 - 3, A.4.4.3(6)) and f_{fe} / f_s normalises f to steel strength

All these variables have already been given in Shear control ratio calculation.

For the normalisation f_s of jacket is used.

$N_{UD} = 22375.589$

$A_g = 562500.00$

$f_{cE} = (f_{c_jacket} \cdot Area_jacket + f_{c_core} \cdot Area_core) / section_area = 27.20$
 $f_{yE} = (f_{y_ext_Long_Reinf} \cdot Area_ext_Long_Reinf + f_{y_int_Long_Reinf} \cdot Area_int_Long_Reinf) / Area_Tot_Long_Rein = 601.9953$
 $f_{yE} = (f_{y_ext_Trans_Reinf} \cdot s1 + f_{y_int_Trans_Reinf} \cdot s2) / (s1 + s2) = 608.5561$
 $\rho_l = Area_Tot_Long_Rein / (b \cdot d) = 0.01639493$
 $b = 450.00$
 $d = 907.00$
 $f_{cE} = 27.20$

End Of Calculation of Chord Rotation Capacity for element: column JTC1 of floor 1
At local axis: 3
Integration Section: (b)
