

Detailed Member Calculations

Units: N&mm

Regulation: ASCE 41-17

Calculation No. 1

beam B1, Floor 1



Limit State: Operational Level (data interpolation between analysis steps 1 and 2)

Analysis: Uniform +X

Check: Shear capacity VR_d

Edge: Start

Local Axis: (2)



Start Of Calculation of Shear Capacity for element: beam B1 of floor 1

At local axis: 2

Integration Section: (a)

Section Type: rcars

Constant Properties

Knowledge Factor, $\gamma = 1.00$

Member Shear Force is generally considered as Force-Controlled Action according to Table C7-1, ASCE 41-17.

Lower-bound strengths are used for Force-Controlled Actions according to 7.5.1.3, ASCE 41-17

Consequently:

Existing material of Secondary Member: Concrete Strength, $f_c = f_{c_lower_bound} = 16.00$

Existing material of Secondary Member: Steel Strength, $f_s = f_{s_lower_bound} = 400.00$

Concrete Elasticity, $E_c = 21019.039$

Steel Elasticity, $E_s = 200000.00$
Section Height, $H = 400.00$
Section Width, $W = 300.00$
Cover Thickness, $c = 25.00$
Element Length, $L = 1850.00$
Secondary Member
Ribbed Bars
Ductile Steel
Without Detailing for Earthquake Resistance (including stirrups not closed at 135°)
Longitudinal Bars With Ends Lapped Starting at the End Sections
Inadequate Lap Length with $l_o/l_{ou,min} = l_b/l_d = 0.30$
No FRP Wrapping

Stepwise Properties

EDGE -A-
Bending Moment, $M_a = -5.3891561E-005$
Shear Force, $V_a = -6.2288147E-008$
EDGE -B-
Bending Moment, $M_b = -6.4263222E-005$
Shear Force, $V_b = 6.2288147E-008$
BOTH EDGES
Axial Force, $F = -1388.628$
Longitudinal Reinforcement Area Distribution (in 2 divisions)
-Tension: $A_{st} = 603.1858$
-Compression: $A_{sc} = 923.6282$
Longitudinal Reinforcement Area Distribution (in 3 divisions)
-Tension: $A_{st,ten} = 508.938$
-Compression: $A_{st,com} = 508.938$
-Middle: $A_{st,mid} = 508.938$
Mean Diameter of Tension Reinforcement, $Db_{L,ten} = 14.66667$

Existing component: From table 7-7, ASCE 41_17: Final Shear Capacity $V_R = *V_n = 139682.658$
 $V_n ((22.5.1.1), ACI 318-14) = 139682.658$

NOTE: In expression (22.5.1.1) 'Vw' is replaced by 'Vw+ f*Vf'
where Vf is the contribution of FRPs (11.3), ACI 440).

From Table (22.5.5.1), ACI 318-14: $V_c = 64284.434$
= 1 (normal-weight concrete)
 $f'_c = 16.00$, but $f'_c^{0.5} \leq 8.3$ MPa (22.5.3.1, ACI 318-14)
 $\rho_w = A_s/(b_w*d) = 0.00628319$
 A_s (tension reinf.) = 603.1858
 $b_w = 400.00$
 $d = 240.00$
 $V_u*d/M_u < 1 = 0.27739325$
 $M_u = 5.3891561E-005$
 $V_u = 6.2288147E-008$
From (11.5.4.8), ACI 318-14: $V_s = 75398.224$
 $A_v = 157079.633$
 $f_y = 400.00$
 $s = 150.00$
 V_s has been multiplied by $2(1-s/d)$ ($s > d/2$, according to ASCE 41-17, 10.3.4)
 $2(1-s/d) = 0.75$
 $V_f ((11-3)-(11.4), ACI 440) = 0.00$
From (11-11), ACI 440: $V_s + V_f \leq 255092.67$

End Of Calculation of Shear Capacity for element: beam B1 of floor 1
At local axis: 2
Integration Section: (a)

Calculation No. 2

beam B1, Floor 1



Limit State: Operational Level (data interpolation between analysis steps 1 and 2)

Analysis: Uniform +X

Check: Chord rotation capacity (ϕ)

Edge: Start

Local Axis: (2)



Start Of Calculation of Shear Capacity ratio for element: beam B1 of floor 1

At Shear local axis: 3

(Bending local axis: 2)

Section Type: rcars

Constant Properties

Knowledge Factor, $\gamma = 1.00$

Mean strength values are used for both shear and moment calculations.

Consequently:

Existing material of Secondary Member: Concrete Strength, $f_c = f_{cm} = 20.00$

Existing material of Secondary Member: Steel Strength, $f_s = f_{sm} = 444.44$

Concrete Elasticity, $E_c = 21019.039$

Steel Elasticity, $E_s = 200000.00$

#####

Note: Especially for the calculation of moment strengths,

the above steel re-bar strengths are multiplied by 1.25 according to R18.6.5, ACI 318-14

Existing material: Steel Strength, $f_s = 1.25 \cdot f_{sm} = 555.55$

#####

Section Height, $H = 400.00$

Section Width, $W = 300.00$

Cover Thickness, $c = 25.00$

Mean Confinement Factor overall section = 1.00

Element Length, $L = 1850.00$

Secondary Member

Ribbed Bars

Ductile Steel

Without Detailing for Earthquake Resistance (including stirrups not closed at 135°)

Longitudinal Bars With Ends Lapped Starting at the End Sections

Inadequate Lap Length with $l_o/l_{ou,min} = 0.30$

No FRP Wrapping

Stepwise Properties

At local axis: 3

EDGE -A-

Shear Force, $V_a = 4076.60$

EDGE -B-

Shear Force, $V_b = 4178.928$

BOTH EDGES

Axial Force, $F = -400.0832$

Longitudinal Reinforcement Area Distribution (in 2 divisions)

-Tension: $As_t = 603.1858$

-Compression: $As_c = 923.6282$

Longitudinal Reinforcement Area Distribution (in 3 divisions)

-Tension: $As_{t,ten} = 603.1858$

-Compression: $As_{l,com} = 615.7522$

-Middle: $As_{l,mid} = 307.8761$

Calculation of Shear Capacity ratio, $V_e/V_r = 0.40672566$

Member Controlled by Flexure ($V_e/V_r < 1$)

Calculation of Shear Demand from fig. R18.6.5, ACI 318-14 $V_e = (M_{pr1} + M_{pr2})/l_n \pm w_u \cdot l_n/2 = 92684.415$ with

$M_{pr1} = \text{Max}(Mu_{1+}, Mu_{1-}) = 8.1957E+007$

$Mu_{1+} = 8.0451E+007$, is the ultimate moment strength at the edge 1 of the member in the actual moment direction which is defined for the static loading combination

$Mu_{1-} = 8.1957E+007$, is the ultimate moment strength at the edge 1 of the member in the opposite moment direction which is defined for the static loading combination

$M_{pr2} = \text{Max}(Mu_{2+}, Mu_{2-}) = 8.1873E+007$

$Mu_{2+} = 8.0533E+007$, is the ultimate moment strength at the edge 2 of the member in the actual moment direction which is defined for the static loading combination

$Mu_{2-} = 8.1873E+007$, is the ultimate moment strength at the edge 2 of the member in the opposite moment direction which is defined for the static loading combination

and

$\pm w_u \cdot l_n = (|V_1| + |V_2|)/2$

with

$V_1 = 4076.60$, is the shear force acting at edge 1 for the static loading combination

$V_2 = 4178.928$, is the shear force acting at edge 2 for the static loading combination

Calculation of Mu_{1+}

Calculation of ultimate curvature ϕ_u according to 4.1, Biskinis/Fardis 2013:

$\phi_u = 1.7899831E-005$

$M_u = 8.0451E+007$

with full section properties:

$b = 300.00$

$d = 357.00$

$d' = 42.00$

$v = 0.00018678$

$N = 400.0832$

$f_c = 20.00$

ϕ_c (5A.5, TBDY) = 0.002

Final value of ϕ_u : $\phi_u^* = \text{shear_factor} \cdot \text{Max}(\phi_u, \phi_c) = 0.00583896$

The Shear_factor is considered equal to 1 (pure moment strength)

From (5.4b), TBDY: $\phi_u = 0.00583896$

w_e (5.4c) = 0.0034192

a_{se} ((5.4d), TBDY) = 0.15672608

$b_o = 240.00$

$h_o = 340.00$

$bi_2 = 346400.00$

psh,min = Min(psh,x , psh,y) = 0.00261799
Expression ((5.4d), TBDY) for psh,min has been multiplied by 0.3 according to 15.7.1.3 for members without earthquake detailing (90° closed stirrups)

psh,x (5.4d) = 0.00349066
Ash = Astir*ns = 78.53982
No stirups, ns = 2.00
bk = 300.00

psh,y (5.4d) = 0.00261799
Ash = Astir*ns = 78.53982
No stirups, ns = 2.00
bk = 400.00

s = 150.00
fywe = 555.55
fce = 20.00
From ((5.A5), TBDY), TBDY: cc = 0.002
c = confinement factor = 1.00
y1 = 0.00129669
sh1 = 0.0044814
ft1 = 373.4467
fy1 = 311.2056
su1 = 0.00512
using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00
lo/lou,min = lb/lb = 0.30
su1 = 0.4*esu1_nominal ((5.5), TBDY) = 0.032
From table 5A.1, TBDY: esu1_nominal = 0.08,
For calculation of esu1_nominal and y1, sh1,ft1,fy1, it is considered
characteristic value fsy1 = fs1/1.2, from table 5.1, TBDY.
y1, sh1,ft1,fy1, are also multiplied by Min(1,1.25*(lb/lb)^ 2/3), from 10.3.5, ASCE 41-17.
with fs1 = fs = 311.2056
with Es1 = Es = 200000.00
y2 = 0.00129669
sh2 = 0.0044814
ft2 = 373.4467
fy2 = 311.2056
su2 = 0.00512
using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00
lo/lou,min = lb/lb,min = 0.30
su2 = 0.4*esu2_nominal ((5.5), TBDY) = 0.032
From table 5A.1, TBDY: esu2_nominal = 0.08,
For calculation of esu2_nominal and y2, sh2,ft2,fy2, it is considered
characteristic value fsy2 = fs2/1.2, from table 5.1, TBDY.
y1, sh1,ft1,fy1, are also multiplied by Min(1,1.25*(lb/lb)^ 2/3), from 10.3.5, ASCE 41-17.
with fs2 = fs = 311.2056
with Es2 = Es = 200000.00
yv = 0.00129669
shv = 0.0044814
ftv = 373.4467
fyv = 311.2056
suv = 0.00512
using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00
lo/lou,min = lb/lb = 0.30
suv = 0.4*esuv_nominal ((5.5), TBDY) = 0.032
From table 5A.1, TBDY: esuv_nominal = 0.08,
considering characteristic value fsyv = fsv/1.2, from table 5.1, TBDY
For calculation of esuv_nominal and yv, shv,ftv,fyv, it is considered
characteristic value fsyv = fsv/1.2, from table 5.1, TBDY.
y1, sh1,ft1,fy1, are also multiplied by Min(1,1.25*(lb/lb)^ 2/3), from 10.3.5, ASCE 41-17.
with fsv = fs = 311.2056

with $E_s = E_s = 200000.00$
 $1 = A_{sl,ten}/(b*d)*(f_{s1}/f_c) = 0.08763528$
 $2 = A_{sl,com}/(b*d)*(f_{s2}/f_c) = 0.08946101$
 $v = A_{sl,mid}/(b*d)*(f_{sv}/f_c) = 0.04473051$
and confined core properties:
 $b = 240.00$
 $d = 327.00$
 $d' = 12.00$
 $f_{cc} (5A.2, TBDY) = 20.00$
 $cc (5A.5, TBDY) = 0.002$
 $c = \text{confinement factor} = 1.00$
 $1 = A_{sl,ten}/(b*d)*(f_{s1}/f_c) = 0.11959401$
 $2 = A_{sl,com}/(b*d)*(f_{s2}/f_c) = 0.12208556$
 $v = A_{sl,mid}/(b*d)*(f_{sv}/f_c) = 0.06104278$
Case/Assumption: Unconfined full section - Steel rupture
'satisfies Eq. (4.3)

--->
 $v < v_{s,y2}$ - LHS eq.(4.5) is satisfied
--->
 $su (4.9) = 0.19877808$
 $Mu = MR_c (4.14) = 8.0451E+007$
 $u = su (4.1) = 1.7899831E-005$

Calculation of ratio l_b/d

Inadequate Lap Length with $l_b/d = 0.30$

Calculation of $Mu1$ -

Calculation of ultimate curvature u according to 4.1, Biskinis/Fardis 2013:
 $u = 1.7901443E-005$
 $Mu = 8.1957E+007$

with full section properties:

$b = 300.00$
 $d = 358.00$
 $d' = 43.00$
 $v = 0.00018626$
 $N = 400.0832$
 $f_c = 20.00$
 $co (5A.5, TBDY) = 0.002$
Final value of cu : $cu^* = \text{shear_factor} * \text{Max}(cu, cc) = 0.00583896$
The Shear_factor is considered equal to 1 (pure moment strength)
From (5.4b), TBDY: $cu = 0.00583896$
 $w_e (5.4c) = 0.0034192$
 $a_{se} ((5.4d), TBDY) = 0.15672608$
 $bo = 240.00$
 $ho = 340.00$
 $bi2 = 346400.00$
 $p_{sh,min} = \text{Min}(p_{sh,x}, p_{sh,y}) = 0.00261799$
Expression ((5.4d), TBDY) for $p_{sh,min}$ has been multiplied by 0.3 according to 15.7.1.3 for members without earthquake detailing (90° closed stirrups)

 $p_{sh,x} (5.4d) = 0.00349066$
 $A_{sh} = A_{stir} * n_s = 78.53982$
No stirrups, $n_s = 2.00$
 $bk = 300.00$

$p_{sh,y} (5.4d) = 0.00261799$
 $A_{sh} = A_{stir} * n_s = 78.53982$
No stirrups, $n_s = 2.00$
 $bk = 400.00$

```

s = 150.00
fywe = 555.55
fce = 20.00
From ((5A.5), TBDY), TBDY: cc = 0.002
c = confinement factor = 1.00
y1 = 0.00129669
sh1 = 0.0044814
ft1 = 373.4467
fy1 = 311.2056
su1 = 0.00512
using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00
lo/lou,min = lb/d = 0.30
su1 = 0.4*esu1_nominal ((5.5), TBDY) = 0.032
From table 5A.1, TBDY: esu1_nominal = 0.08,
For calculation of esu1_nominal and y1, sh1,ft1,fy1, it is considered
characteristic value fsy1 = fs1/1.2, from table 5.1, TBDY.
y1, sh1,ft1,fy1, are also multiplied by Min(1,1.25*(lb/d)^ 2/3), from 10.3.5, ASCE 41-17.
with fs1 = fs = 311.2056
with Es1 = Es = 200000.00
y2 = 0.00129669
sh2 = 0.0044814
ft2 = 373.4467
fy2 = 311.2056
su2 = 0.00512
using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00
lo/lou,min = lb/lb,min = 0.30
su2 = 0.4*esu2_nominal ((5.5), TBDY) = 0.032
From table 5A.1, TBDY: esu2_nominal = 0.08,
For calculation of esu2_nominal and y2, sh2,ft2,fy2, it is considered
characteristic value fsy2 = fs2/1.2, from table 5.1, TBDY.
y1, sh1,ft1,fy1, are also multiplied by Min(1,1.25*(lb/d)^ 2/3), from 10.3.5, ASCE 41-17.
with fs2 = fs = 311.2056
with Es2 = Es = 200000.00
yv = 0.00129669
shv = 0.0044814
ftv = 373.4467
fyv = 311.2056
suv = 0.00512
using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00
lo/lou,min = lb/d = 0.30
suv = 0.4*esuv_nominal ((5.5), TBDY) = 0.032
From table 5A.1, TBDY: esuv_nominal = 0.08,
considering characteristic value fsyv = fsv/1.2, from table 5.1, TBDY
For calculation of esuv_nominal and yv, shv,ftv,fyv, it is considered
characteristic value fsyv = fsv/1.2, from table 5.1, TBDY.
y1, sh1,ft1,fy1, are also multiplied by Min(1,1.25*(lb/d)^ 2/3), from 10.3.5, ASCE 41-17.
with fsv = fs = 311.2056
with Esv = Es = 200000.00
1 = Asl,ten/(b*d)*(fs1/fc) = 0.08921112
2 = Asl,com/(b*d)*(fs2/fc) = 0.08739049
v = Asl,mid/(b*d)*(fsv/fc) = 0.04460556
and confined core properties:
b = 240.00
d = 328.00
d' = 13.00
fcc (5A.2, TBDY) = 20.00
cc (5A.5, TBDY) = 0.002
c = confinement factor = 1.00
1 = Asl,ten/(b*d)*(fs1/fc) = 0.12171334
2 = Asl,com/(b*d)*(fs2/fc) = 0.1192294

```

$$v = A_{sl, mid} / (b \cdot d) \cdot (f_{sv} / f_c) = 0.06085667$$

Case/Assumption: Unconfined full section - Steel rupture
' satisfies Eq. (4.3)

--->

$v < v_{s,y2}$ - LHS eq.(4.5) is satisfied

--->

$$s_u(4.9) = 0.20108809$$

$$M_u = M_{Rc}(4.14) = 8.1957E+007$$

$$u = s_u(4.1) = 1.7901443E-005$$

Calculation of ratio I_b/I_d

Inadequate Lap Length with $I_b/I_d = 0.30$

Calculation of M_{u2+}

Calculation of ultimate curvature ϕ_u according to 4.1, Biskinis/Fardis 2013:

$$u = 1.7862388E-005$$

$$M_u = 8.0533E+007$$

with full section properties:

$$b = 300.00$$

$$d = 358.00$$

$$d' = 43.00$$

$$v = 0.00018626$$

$$N = 400.0832$$

$$f_c = 20.00$$

$$\phi_{co}(5A.5, \text{TBDY}) = 0.002$$

$$\text{Final value of } \phi_{cu}: \phi_{cu}^* = \text{shear_factor} \cdot \text{Max}(\phi_{cu}, \phi_{cc}) = 0.00583896$$

The Shear_factor is considered equal to 1 (pure moment strength)

$$\text{From (5.4b), TBDY: } \phi_{cu} = 0.00583896$$

$$\phi_{we}(5.4c) = 0.0034192$$

$$\phi_{ase}((5.4d), \text{TBDY}) = 0.15672608$$

$$b_o = 240.00$$

$$h_o = 340.00$$

$$b_i^2 = 346400.00$$

$$\phi_{psh, min} = \text{Min}(\phi_{psh, x}, \phi_{psh, y}) = 0.00261799$$

Expression ((5.4d), TBDY) for $\phi_{psh, min}$ has been multiplied by 0.3 according to 15.7.1.3 for members without earthquake detailing (90° closed stirrups)

$$\phi_{psh, x}(5.4d) = 0.00349066$$

$$A_{sh} = A_{stir} \cdot n_s = 78.53982$$

$$\text{No stirrups, } n_s = 2.00$$

$$b_k = 300.00$$

$$\phi_{psh, y}(5.4d) = 0.00261799$$

$$A_{sh} = A_{stir} \cdot n_s = 78.53982$$

$$\text{No stirrups, } n_s = 2.00$$

$$b_k = 400.00$$

$$s = 150.00$$

$$f_{ywe} = 555.55$$

$$f_{ce} = 20.00$$

$$\text{From ((5.A5), TBDY), TBDY: } \phi_{cc} = 0.002$$

$$c = \text{confinement factor} = 1.00$$

$$y_1 = 0.00129669$$

$$sh_1 = 0.0044814$$

$$ft_1 = 373.4467$$

$$fy_1 = 311.2056$$

$$su_1 = 0.00512$$

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with


```

Shear_factor = 1.00
lo/lou,min = lb/ld = 0.30
su1 = 0.4*esu1_nominal ((5.5), TBDY) = 0.032
From table 5A.1, TBDY: esu1_nominal = 0.08,
For calculation of esu1_nominal and y1, sh1,ft1,fy1, it is considered
characteristic value fsy1 = fs1/1.2, from table 5.1, TBDY.
y1, sh1,ft1,fy1, are also multiplied by Min(1,1.25*(lb/ld)^ 2/3), from 10.3.5, ASCE 41-17.
with fs1 = fs = 311.2056
with Es1 = Es = 200000.00
y2 = 0.00129669
sh2 = 0.0044814
ft2 = 373.4467
fy2 = 311.2056
su2 = 0.00512
using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00
lo/lou,min = lb/lb,min = 0.30
su2 = 0.4*esu2_nominal ((5.5), TBDY) = 0.032
From table 5A.1, TBDY: esu2_nominal = 0.08,
For calculation of esu2_nominal and y2, sh2,ft2,fy2, it is considered
characteristic value fsy2 = fs2/1.2, from table 5.1, TBDY.
y1, sh1,ft1,fy1, are also multiplied by Min(1,1.25*(lb/ld)^ 2/3), from 10.3.5, ASCE 41-17.
with fs2 = fs = 311.2056
with Es2 = Es = 200000.00
yv = 0.00129669
shv = 0.0044814
ftv = 373.4467
fyv = 311.2056
suv = 0.00512
using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00
lo/lou,min = lb/ld = 0.30
suv = 0.4*esuv_nominal ((5.5), TBDY) = 0.032
From table 5A.1, TBDY: esuv_nominal = 0.08,
considering characteristic value fsyv = fsv/1.2, from table 5.1, TBDY
For calculation of esuv_nominal and yv, shv,ftv,fyv, it is considered
characteristic value fsyv = fsv/1.2, from table 5.1, TBDY.
y1, sh1,ft1,fy1, are also multiplied by Min(1,1.25*(lb/ld)^ 2/3), from 10.3.5, ASCE 41-17.
with fsv = fs = 311.2056
with Esv = Es = 200000.00
1 = Asl,ten/(b*d)*(fs1/fc) = 0.08739049
2 = Asl,com/(b*d)*(fs2/fc) = 0.08921112
v = Asl,mid/(b*d)*(fsv/fc) = 0.04460556

```

and confined core properties:

```

b = 240.00
d = 328.00
d' = 13.00
fcc (5A.2, TBDY) = 20.00
cc (5A.5, TBDY) = 0.002
c = confinement factor = 1.00
1 = Asl,ten/(b*d)*(fs1/fc) = 0.1192294
2 = Asl,com/(b*d)*(fs2/fc) = 0.12171334
v = Asl,mid/(b*d)*(fsv/fc) = 0.06085667

```

Case/Assumption: Unconfined full section - Steel rupture

' satisfies Eq. (4.3)

--->

v < vsy2 - LHS eq.(4.5) is satisfied

--->

```

su (4.9) = 0.19934131
Mu = MRc (4.14) = 8.0533E+007
u = su (4.1) = 1.7862388E-005

```

Calculation of ratio lb/ld

Inadequate Lap Length with $l_b/l_d = 0.30$

Calculation of μ_2 -

Calculation of ultimate curvature μ according to 4.1, Biskinis/Fardis 2013:

$$\mu = 1.7939215E-005$$

$$\mu_u = 8.1873E+007$$

with full section properties:

$$b = 300.00$$

$$d = 357.00$$

$$d' = 42.00$$

$$\nu = 0.00018678$$

$$N = 400.0832$$

$$f_c = 20.00$$

$$\alpha_c (5A.5, \text{TB DY}) = 0.002$$

$$\text{Final value of } \mu_u: \mu_u^* = \text{shear_factor} * \text{Max}(\mu_u, \alpha_c) = 0.00583896$$

The Shear_factor is considered equal to 1 (pure moment strength)

$$\text{From (5.4b), TB DY: } \mu_u = 0.00583896$$

$$\mu_{ue} (5.4c) = 0.0034192$$

$$\alpha_{se} ((5.4d), \text{TB DY}) = 0.15672608$$

$$b_o = 240.00$$

$$h_o = 340.00$$

$$b_{i2} = 346400.00$$

$$\mu_{sh,min} = \text{Min}(\mu_{sh,x}, \mu_{sh,y}) = 0.00261799$$

Expression ((5.4d), TB DY) for $\mu_{sh,min}$ has been multiplied by 0.3 according to 15.7.1.3 for members without earthquake detailing (90° closed stirrups)

$$\mu_{sh,x} (5.4d) = 0.00349066$$

$$A_{sh} = A_{stir} * n_s = 78.53982$$

$$\text{No stirrups, } n_s = 2.00$$

$$b_k = 300.00$$

$$\mu_{sh,y} (5.4d) = 0.00261799$$

$$A_{sh} = A_{stir} * n_s = 78.53982$$

$$\text{No stirrups, } n_s = 2.00$$

$$b_k = 400.00$$

$$s = 150.00$$

$$f_{ywe} = 555.55$$

$$f_{ce} = 20.00$$

$$\text{From ((5.A5), TB DY), TB DY: } \alpha_c = 0.002$$

$$\alpha_c = \text{confinement factor} = 1.00$$

$$y_1 = 0.00129669$$

$$sh_1 = 0.0044814$$

$$f_{t1} = 373.4467$$

$$f_{y1} = 311.2056$$

$$s_{u1} = 0.00512$$

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor and also multiplied by the shear_factor according to 15.7.1.4, with Shear_factor = 1.00

$$l_o/l_{ou,min} = l_b/l_d = 0.30$$

$$s_{u1} = 0.4 * s_{u1,nominal} ((5.5), \text{TB DY}) = 0.032$$

$$\text{From table 5A.1, TB DY: } s_{u1,nominal} = 0.08$$

For calculation of $s_{u1,nominal}$ and $y_1, sh_1, f_{t1}, f_{y1}$, it is considered characteristic value $f_{sy1} = f_s/1.2$, from table 5.1, TB DY.

$y_1, sh_1, f_{t1}, f_{y1}$, are also multiplied by $\text{Min}(1, 1.25 * (l_b/l_d)^{2/3})$, from 10.3.5, ASCE 41-17.

$$\text{with } f_{s1} = f_s = 311.2056$$

$$\text{with } E_{s1} = E_s = 200000.00$$

$$y_2 = 0.00129669$$

$$sh_2 = 0.0044814$$

$$f_{t2} = 373.4467$$

$$f_{y2} = 311.2056$$

```

su2 = 0.00512
using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00
lo/lou,min = lb/lb,min = 0.30
su2 = 0.4*esu2_nominal ((5.5), TBDY) = 0.032
From table 5A.1, TBDY: esu2_nominal = 0.08,
For calculation of esu2_nominal and y2, sh2,ft2,fy2, it is considered
characteristic value fsy2 = fs2/1.2, from table 5.1, TBDY.
y1, sh1,ft1,fy1, are also multiplied by Min(1,1.25*(lb/ld)^ 2/3), from 10.3.5, ASCE 41-17.
with fs2 = fs = 311.2056
with Es2 = Es = 200000.00
yv = 0.00129669
shv = 0.0044814
ftv = 373.4467
fyv = 311.2056
suv = 0.00512
using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00
lo/lou,min = lb/ld = 0.30
suv = 0.4*esuv_nominal ((5.5), TBDY) = 0.032
From table 5A.1, TBDY: esuv_nominal = 0.08,
considering characteristic value fsyv = fsv/1.2, from table 5.1, TBDY
For calculation of esuv_nominal and yv, shv,ftv,fyv, it is considered
characteristic value fsyv = fsv/1.2, from table 5.1, TBDY.
y1, sh1,ft1,fy1, are also multiplied by Min(1,1.25*(lb/ld)^ 2/3), from 10.3.5, ASCE 41-17.
with fsv = fs = 311.2056
with Esv = Es = 200000.00
1 = Asl,ten/(b*d)*(fs1/fc) = 0.08946101
2 = Asl,com/(b*d)*(fs2/fc) = 0.08763528
v = Asl,mid/(b*d)*(fsv/fc) = 0.04473051
and confined core properties:
b = 240.00
d = 327.00
d' = 12.00
fcc (5A.2, TBDY) = 20.00
cc (5A.5, TBDY) = 0.002
c = confinement factor = 1.00
1 = Asl,ten/(b*d)*(fs1/fc) = 0.12208556
2 = Asl,com/(b*d)*(fs2/fc) = 0.11959401
v = Asl,mid/(b*d)*(fsv/fc) = 0.06104278
Case/Assumption: Unconfined full section - Steel rupture
'satisfies Eq. (4.3)
--->
v < vs,y2 - LHS eq.(4.5) is satisfied
--->
su (4.9) = 0.20053711
Mu = MRc (4.14) = 8.1873E+007
u = su (4.1) = 1.7939215E-005

```

Calculation of ratio lb/ld

Inadequate Lap Length with lb/ld = 0.30

Calculation of Shear Strength $V_r = \min(V_{r1}, V_{r2}) = 227879.44$

Calculation of Shear Strength at edge 1, $V_{r1} = 227879.44$
 $V_{r1} = V_n$ ((22.5.1.1), ACI 318-14)

NOTE: In expression (22.5.1.1) 'Vw' is replaced by 'Vw+ f*Vf'
 where Vf is the contribution of FRPs (11.3), ACI 440).

From Table (22.5.5.1), ACI 318-14: $V_c = 78946.167$
 $= 1$ (normal-weight concrete)
 $f'_c = 20.00$, but $f_c^{0.5} \leq 8.3$ MPa (22.5.3.1, ACI 318-14)
 $\rho_w = A_s/(b_w \cdot d) = 0.00628319$
 A_s (tension reinf.) = 603.1858
 $b_w = 300.00$
 $d = 320.00$
 $V_u \cdot d / M_u < 1 = 1.00$
 $M_u = 60442.822$
 $V_u = 4076.60$
From (11.5.4.8), ACI 318-14: $V_s = 148933.273$
 $A_v = 157079.633$
 $f_y = 444.44$
 $s = 150.00$
 V_s has been multiplied by 1 ($s < d/2$, according to ASCE 41-17,10.3.4)
 V_f ((11-3)-(11.4), ACI 440) = 0.00
From (11-11), ACI 440: $V_s + V_f \leq 285202.276$

Calculation of Shear Strength at edge 2, $V_{r2} = 227879.44$
 $V_{r2} = V_n$ ((22.5.1.1), ACI 318-14)

NOTE: In expression (22.5.1.1) ' V_w ' is replaced by ' $V_w + f \cdot V_f$ '
where V_f is the contribution of FRPs (11.3), ACI 440).

From Table (22.5.5.1), ACI 318-14: $V_c = 78946.167$
 $= 1$ (normal-weight concrete)
 $f'_c = 20.00$, but $f_c^{0.5} \leq 8.3$ MPa (22.5.3.1, ACI 318-14)
 $\rho_w = A_s/(b_w \cdot d) = 0.00628319$
 A_s (tension reinf.) = 603.1858
 $b_w = 300.00$
 $d = 320.00$
 $V_u \cdot d / M_u < 1 = 1.00$
 $M_u = 155096.693$
 $V_u = 4178.928$
From (11.5.4.8), ACI 318-14: $V_s = 148933.273$
 $A_v = 157079.633$
 $f_y = 444.44$
 $s = 150.00$
 V_s has been multiplied by 1 ($s < d/2$, according to ASCE 41-17,10.3.4)
 V_f ((11-3)-(11.4), ACI 440) = 0.00
From (11-11), ACI 440: $V_s + V_f \leq 285202.276$

End Of Calculation of Shear Capacity ratio for element: beam B1 of floor 1
At local axis: 3

Start Of Calculation of Shear Capacity ratio for element: beam B1 of floor 1
At Shear local axis: 2
(Bending local axis: 3)
Section Type: rcars

Constant Properties

Knowledge Factor, $= 1.00$
Mean strength values are used for both shear and moment calculations.
Consequently:
Existing material of Secondary Member: Concrete Strength, $f_c = f_{cm} = 20.00$
Existing material of Secondary Member: Steel Strength, $f_s = f_{sm} = 444.44$
Concrete Elasticity, $E_c = 21019.039$
Steel Elasticity, $E_s = 200000.00$

Note: Especially for the calculation of moment strengths,
the above steel re-bar strengths are multiplied by 1.25 according to R18.6.5, ACI 318-14
Existing material: Steel Strength, $f_s = 1.25 \cdot f_{sm} = 555.55$
#####

Section Height, $H = 400.00$
 Section Width, $W = 300.00$
 Cover Thickness, $c = 25.00$
 Mean Confinement Factor overall section = 1.00
 Element Length, $L = 1850.00$
 Secondary Member
 Ribbed Bars
 Ductile Steel
 Without Detailing for Earthquake Resistance (including stirrups not closed at 135°)
 Longitudinal Bars With Ends Lapped Starting at the End Sections
 Inadequate Lap Length with $l_o/l_{o,min} = 0.30$
 No FRP Wrapping

Stepwise Properties

At local axis: 2
 EDGE -A-
 Shear Force, $V_a = -1.0090939E-010$
 EDGE -B-
 Shear Force, $V_b = 1.0090939E-010$
 BOTH EDGES
 Axial Force, $F = -400.0832$
 Longitudinal Reinforcement Area Distribution (in 2 divisions)
 -Tension: $As_t = 603.1858$
 -Compression: $As_c = 923.6282$
 Longitudinal Reinforcement Area Distribution (in 3 divisions)
 -Tension: $As_{t,ten} = 508.938$
 -Compression: $As_{c,com} = 508.938$
 -Middle: $As_{mid} = 508.938$

Calculation of Shear Capacity ratio, $V_e/V_r = 0.37923485$
 Member Controlled by Flexure ($V_e/V_r < 1$)
 Calculation of Shear Demand from fig. R18.6.5, ACI 318-14 $V_e = (M_{pr1} + M_{pr2})/l_n \pm w_u \cdot l_n / 2 = 57820.79$
 with
 $M_{pr1} = \max(\mu_{u1+}, \mu_{u1-}) = 5.3484E+007$
 $\mu_{u1+} = 5.3484E+007$, is the ultimate moment strength at the edge 1 of the member in the actual moment direction which is defined for the static loading combination
 $\mu_{u1-} = 5.3484E+007$, is the ultimate moment strength at the edge 1 of the member in the opposite moment direction which is defined for the static loading combination
 $M_{pr2} = \max(\mu_{u2+}, \mu_{u2-}) = 5.3484E+007$
 $\mu_{u2+} = 5.3484E+007$, is the ultimate moment strength at the edge 2 of the member in the actual moment direction which is defined for the static loading combination
 $\mu_{u2-} = 5.3484E+007$, is the ultimate moment strength at the edge 2 of the member in the opposite moment direction which is defined for the static loading combination
 and
 $\pm w_u \cdot l_n = (|V_1| + |V_2|)/2$
 with
 $V_1 = -1.0090939E-010$, is the shear force acting at edge 1 for the static loading combination
 $V_2 = 1.0090939E-010$, is the shear force acting at edge 2 for the static loading combination

Calculation of μ_{u1+}

Calculation of ultimate curvature ϕ_u according to 4.1, Biskinis/Fardis 2013:
 $\phi_u = 2.5364147E-005$
 $M_u = 5.3484E+007$

with full section properties:

$b = 400.00$
 $d = 258.00$
 $d' = 42.00$

$v = 0.00019384$
 $N = 400.0832$
 $fc = 20.00$
 $co (5A.5, TBDY) = 0.002$
 Final value of cu : $cu^* = shear_factor * Max(cu, cc) = 0.00583896$
 The Shear_factor is considered equal to 1 (pure moment strength)
 From (5.4b), TBDY: $cu = 0.00583896$
 $we (5.4c) = 0.0034192$
 $ase ((5.4d), TBDY) = 0.15672608$
 $bo = 240.00$
 $ho = 340.00$
 $bi2 = 346400.00$
 $psh,min = Min(psh,x, psh,y) = 0.00261799$
 Expression ((5.4d), TBDY) for psh,min has been multiplied by 0.3 according to 15.7.1.3 for members without earthquake detailing (90° closed stirrups)

$psh,x (5.4d) = 0.00349066$
 $Ash = Astir*ns = 78.53982$
 No stirrups, $ns = 2.00$
 $bk = 300.00$

$psh,y (5.4d) = 0.00261799$
 $Ash = Astir*ns = 78.53982$
 No stirrups, $ns = 2.00$
 $bk = 400.00$

$s = 150.00$
 $fywe = 555.55$
 $fce = 20.00$
 From ((5.A5), TBDY), TBDY: $cc = 0.002$
 $c = confinement\ factor = 1.00$
 $y1 = 0.00129669$
 $sh1 = 0.0044814$
 $ft1 = 373.4467$
 $fy1 = 311.2056$
 $su1 = 0.00512$
 using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
 and also multiplied by the shear_factor according to 15.7.1.4, with
 Shear_factor = 1.00
 $lo/lou,min = lb/l_d = 0.30$
 $su1 = 0.4*esu1_nominal ((5.5), TBDY) = 0.032$
 From table 5A.1, TBDY: $esu1_nominal = 0.08$,
 For calculation of $esu1_nominal$ and $y1, sh1, ft1, fy1$, it is considered
 characteristic value $fsy1 = fs1/1.2$, from table 5.1, TBDY.
 $y1, sh1, ft1, fy1$, are also multiplied by $Min(1, 1.25*(lb/l_d)^{2/3})$, from 10.3.5, ASCE 41-17.
 with $fs1 = fs = 311.2056$
 with $Es1 = Es = 200000.00$
 $y2 = 0.00129669$
 $sh2 = 0.0044814$
 $ft2 = 373.4467$
 $fy2 = 311.2056$
 $su2 = 0.00512$
 using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
 and also multiplied by the shear_factor according to 15.7.1.4, with
 Shear_factor = 1.00
 $lo/lou,min = lb/l_b,min = 0.30$
 $su2 = 0.4*esu2_nominal ((5.5), TBDY) = 0.032$
 From table 5A.1, TBDY: $esu2_nominal = 0.08$,
 For calculation of $esu2_nominal$ and $y2, sh2, ft2, fy2$, it is considered
 characteristic value $fsy2 = fs2/1.2$, from table 5.1, TBDY.
 $y1, sh1, ft1, fy1$, are also multiplied by $Min(1, 1.25*(lb/l_d)^{2/3})$, from 10.3.5, ASCE 41-17.
 with $fs2 = fs = 311.2056$
 with $Es2 = Es = 200000.00$
 $yv = 0.00129669$
 $shv = 0.0044814$
 $ftv = 373.4467$
 $fyv = 311.2056$

$suv = 0.00512$
 using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
 and also multiplied by the shear_factor according to 15.7.1.4, with
 $Shear_factor = 1.00$
 $lo/lo_{u,min} = lb/ld = 0.30$
 $suv = 0.4 * esuv_nominal ((5.5), TBDY) = 0.032$
 From table 5A.1, TBDY: $esuv_nominal = 0.08$,
 considering characteristic value $fsyv = fsv/1.2$, from table 5.1, TBDY
 For calculation of $esuv_nominal$ and yv , shv , ftv , fyv , it is considered
 characteristic value $fsyv = fsv/1.2$, from table 5.1, TBDY.
 $y1$, $sh1$, $ft1$, $fy1$, are also multiplied by $Min(1, 1.25 * (lb/ld)^{2/3})$, from 10.3.5, ASCE 41-17.
 with $fsv = fs = 311.2056$
 with $Esv = Es = 200000.00$
 $1 = Asl_{ten}/(b*d) * (fs1/fc) = 0.0767366$
 $2 = Asl_{com}/(b*d) * (fs2/fc) = 0.0767366$
 $v = Asl_{mid}/(b*d) * (fsv/fc) = 0.0767366$
 and confined core properties:
 $b = 340.00$
 $d = 228.00$
 $d' = 12.00$
 $fcc (5A.2, TBDY) = 20.00$
 $cc (5A.5, TBDY) = 0.002$
 $c = \text{confinement factor} = 1.00$
 $1 = Asl_{ten}/(b*d) * (fs1/fc) = 0.10215708$
 $2 = Asl_{com}/(b*d) * (fs2/fc) = 0.10215708$
 $v = Asl_{mid}/(b*d) * (fsv/fc) = 0.10215708$
 Case/Assumption: Unconfined full section - Steel rupture
 ' satisfies Eq. (4.3)
 --->
 $v < vs_{y2}$ - LHS eq.(4.5) is satisfied
 --->
 $su (4.9) = 0.21759794$
 $Mu = MRc (4.14) = 5.3484E+007$
 $u = su (4.1) = 2.5364147E-005$

Calculation of ratio lb/ld

Inadequate Lap Length with $lb/ld = 0.30$

Calculation of $Mu1$ -

Calculation of ultimate curvature u according to 4.1, Biskinis/Fardis 2013:

$u = 2.5364147E-005$

$Mu = 5.3484E+007$

with full section properties:

$b = 400.00$

$d = 258.00$

$d' = 42.00$

$v = 0.00019384$

$N = 400.0832$

$fc = 20.00$

$co (5A.5, TBDY) = 0.002$

Final value of cu : $cu^* = shear_factor * Max(cu, cc) = 0.00583896$

The Shear_factor is considered equal to 1 (pure moment strength)

From (5.4b), TBDY: $cu = 0.00583896$

$we (5.4c) = 0.0034192$

$ase ((5.4d), TBDY) = 0.15672608$

$bo = 240.00$

$ho = 340.00$

$bi2 = 346400.00$

$psh_{min} = Min(psh_x, psh_y) = 0.00261799$

Expression ((5.4d), TBDY) for psh,min has been multiplied by 0.3 according to 15.7.1.3 for members without earthquake detailing (90° closed stirrups)

psh,x (5.4d) = 0.00349066
Ash = Astir*ns = 78.53982
No stirups, ns = 2.00
bk = 300.00

psh,y (5.4d) = 0.00261799
Ash = Astir*ns = 78.53982
No stirups, ns = 2.00
bk = 400.00

s = 150.00
fywe = 555.55
fce = 20.00

From ((5.A5), TBDY), TBDY: cc = 0.002
c = confinement factor = 1.00

y1 = 0.00129669
sh1 = 0.0044814
ft1 = 373.4467
fy1 = 311.2056
su1 = 0.00512

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00

lo/lou,min = lb/lb = 0.30

su1 = 0.4*esu1_nominal ((5.5), TBDY) = 0.032

From table 5A.1, TBDY: esu1_nominal = 0.08,

For calculation of esu1_nominal and y1, sh1,ft1,fy1, it is considered
characteristic value fsy1 = fs1/1.2, from table 5.1, TBDY.

y1, sh1,ft1,fy1, are also multiplied by $\text{Min}(1, 1.25 \cdot (lb/lb)^{2/3})$, from 10.3.5, ASCE 41-17.

with fs1 = fs = 311.2056

with Es1 = Es = 200000.00

y2 = 0.00129669
sh2 = 0.0044814
ft2 = 373.4467
fy2 = 311.2056
su2 = 0.00512

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00

lo/lou,min = lb/lb,min = 0.30

su2 = 0.4*esu2_nominal ((5.5), TBDY) = 0.032

From table 5A.1, TBDY: esu2_nominal = 0.08,

For calculation of esu2_nominal and y2, sh2,ft2,fy2, it is considered
characteristic value fsy2 = fs2/1.2, from table 5.1, TBDY.

y1, sh1,ft1,fy1, are also multiplied by $\text{Min}(1, 1.25 \cdot (lb/lb)^{2/3})$, from 10.3.5, ASCE 41-17.

with fs2 = fs = 311.2056

with Es2 = Es = 200000.00

yv = 0.00129669
shv = 0.0044814
ftv = 373.4467
fyv = 311.2056
suv = 0.00512

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00

lo/lou,min = lb/lb = 0.30

suv = 0.4*esuv_nominal ((5.5), TBDY) = 0.032

From table 5A.1, TBDY: esuv_nominal = 0.08,

considering characteristic value fsyv = fsv/1.2, from table 5.1, TBDY

For calculation of esuv_nominal and yv, shv,ftv,fyv, it is considered
characteristic value fsyv = fsv/1.2, from table 5.1, TBDY.

y1, sh1,ft1,fy1, are also multiplied by $\text{Min}(1, 1.25 \cdot (lb/lb)^{2/3})$, from 10.3.5, ASCE 41-17.

with fsv = fs = 311.2056

with Esv = Es = 200000.00

$$1 = A_{sl,ten}/(b*d)*(f_{s1}/f_c) = 0.0767366$$

$$2 = A_{sl,com}/(b*d)*(f_{s2}/f_c) = 0.0767366$$

$$v = A_{sl,mid}/(b*d)*(f_{sv}/f_c) = 0.0767366$$

and confined core properties:

$$b = 340.00$$

$$d = 228.00$$

$$d' = 12.00$$

$$f_{cc} (5A.2, TBDY) = 20.00$$

$$cc (5A.5, TBDY) = 0.002$$

$$c = \text{confinement factor} = 1.00$$

$$1 = A_{sl,ten}/(b*d)*(f_{s1}/f_c) = 0.10215708$$

$$2 = A_{sl,com}/(b*d)*(f_{s2}/f_c) = 0.10215708$$

$$v = A_{sl,mid}/(b*d)*(f_{sv}/f_c) = 0.10215708$$

Case/Assumption: Unconfined full section - Steel rupture

' satisfies Eq. (4.3)

--->

$v < v_{s,y2}$ - LHS eq.(4.5) is satisfied

--->

$$s_u (4.9) = 0.21759794$$

$$\mu_u = M_{Rc} (4.14) = 5.3484E+007$$

$$u = s_u (4.1) = 2.5364147E-005$$

Calculation of ratio I_b/I_d

Inadequate Lap Length with $I_b/I_d = 0.30$

Calculation of μ_{u2+}

Calculation of ultimate curvature μ_u according to 4.1, Biskinis/Fardis 2013:

$$u = 2.5364147E-005$$

$$\mu_u = 5.3484E+007$$

with full section properties:

$$b = 400.00$$

$$d = 258.00$$

$$d' = 42.00$$

$$v = 0.00019384$$

$$N = 400.0832$$

$$f_c = 20.00$$

$$cc (5A.5, TBDY) = 0.002$$

$$\text{Final value of } \mu_u: \mu_u^* = \text{shear_factor} * \text{Max}(\mu_u, cc) = 0.00583896$$

The Shear_factor is considered equal to 1 (pure moment strength)

$$\text{From (5.4b), TBDY: } \mu_u = 0.00583896$$

$$\mu_{ue} (5.4c) = 0.0034192$$

$$\mu_{ase} ((5.4d), TBDY) = 0.15672608$$

$$b_o = 240.00$$

$$h_o = 340.00$$

$$b_{i2} = 346400.00$$

$$\mu_{psh,min} = \text{Min}(\mu_{psh,x}, \mu_{psh,y}) = 0.00261799$$

Expression ((5.4d), TBDY) for $\mu_{psh,min}$ has been multiplied by 0.3 according to 15.7.1.3 for members without earthquake detailing (90° closed stirrups)

$$\mu_{psh,x} (5.4d) = 0.00349066$$

$$A_{sh} = A_{stir} * n_s = 78.53982$$

$$\text{No stirrups, } n_s = 2.00$$

$$b_k = 300.00$$

$$\mu_{psh,y} (5.4d) = 0.00261799$$

$$A_{sh} = A_{stir} * n_s = 78.53982$$

$$\text{No stirrups, } n_s = 2.00$$

$$b_k = 400.00$$

```

s = 150.00
fywe = 555.55
fce = 20.00
From ((5.A.5), TBDY), TBDY: cc = 0.002
c = confinement factor = 1.00
y1 = 0.00129669
sh1 = 0.0044814
ft1 = 373.4467
fy1 = 311.2056
su1 = 0.00512
using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00
lo/lou,min = lb/lb = 0.30
su1 = 0.4*esu1_nominal ((5.5), TBDY) = 0.032
From table 5A.1, TBDY: esu1_nominal = 0.08,
For calculation of esu1_nominal and y1, sh1,ft1,fy1, it is considered
characteristic value fsy1 = fs1/1.2, from table 5.1, TBDY.
y1, sh1,ft1,fy1, are also multiplied by Min(1,1.25*(lb/lb)^ 2/3), from 10.3.5, ASCE 41-17.
with fs1 = fs = 311.2056
with Es1 = Es = 200000.00
y2 = 0.00129669
sh2 = 0.0044814
ft2 = 373.4467
fy2 = 311.2056
su2 = 0.00512
using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00
lo/lou,min = lb/lb,min = 0.30
su2 = 0.4*esu2_nominal ((5.5), TBDY) = 0.032
From table 5A.1, TBDY: esu2_nominal = 0.08,
For calculation of esu2_nominal and y2, sh2,ft2,fy2, it is considered
characteristic value fsy2 = fs2/1.2, from table 5.1, TBDY.
y1, sh1,ft1,fy1, are also multiplied by Min(1,1.25*(lb/lb)^ 2/3), from 10.3.5, ASCE 41-17.
with fs2 = fs = 311.2056
with Es2 = Es = 200000.00
yv = 0.00129669
shv = 0.0044814
ftv = 373.4467
fyv = 311.2056
suv = 0.00512
using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00
lo/lou,min = lb/lb = 0.30
suv = 0.4*esuv_nominal ((5.5), TBDY) = 0.032
From table 5A.1, TBDY: esuv_nominal = 0.08,
considering characteristic value fsyv = fsv/1.2, from table 5.1, TBDY
For calculation of esuv_nominal and yv, shv,ftv,fyv, it is considered
characteristic value fsyv = fsv/1.2, from table 5.1, TBDY.
y1, sh1,ft1,fy1, are also multiplied by Min(1,1.25*(lb/lb)^ 2/3), from 10.3.5, ASCE 41-17.
with fsv = fs = 311.2056
with Esv = Es = 200000.00
1 = Asl,ten/(b*d)*(fs1/fc) = 0.0767366
2 = Asl,com/(b*d)*(fs2/fc) = 0.0767366
v = Asl,mid/(b*d)*(fsv/fc) = 0.0767366
and confined core properties:
b = 340.00
d = 228.00
d' = 12.00
fcc (5A.2, TBDY) = 20.00
cc (5A.5, TBDY) = 0.002
c = confinement factor = 1.00
1 = Asl,ten/(b*d)*(fs1/fc) = 0.10215708
2 = Asl,com/(b*d)*(fs2/fc) = 0.10215708
v = Asl,mid/(b*d)*(fsv/fc) = 0.10215708

```

Case/Assumption: Unconfined full section - Steel rupture
' satisfies Eq. (4.3)

--->

$v < v_{s,y2}$ - LHS eq.(4.5) is satisfied

--->

μ_u (4.9) = 0.21759794

$M_u = M_{Rc}$ (4.14) = 5.3484E+007

$u = \mu_u$ (4.1) = 2.5364147E-005

Calculation of ratio I_b/I_d

Inadequate Lap Length with $I_b/I_d = 0.30$

Calculation of μ_{u2} -

Calculation of ultimate curvature μ_u according to 4.1, Biskinis/Fardis 2013:

$u = 2.5364147E-005$

$M_u = 5.3484E+007$

with full section properties:

$b = 400.00$

$d = 258.00$

$d' = 42.00$

$v = 0.00019384$

$N = 400.0832$

$f_c = 20.00$

ϕ_c (5A.5, TBDY) = 0.002

Final value of ϕ_{cu} : $\phi_{cu}^* = \text{shear_factor} * \text{Max}(\phi_{cu}, \phi_{cc}) = 0.00583896$

The Shear_factor is considered equal to 1 (pure moment strength)

From (5.4b), TBDY: $\phi_{cu} = 0.00583896$

ϕ_{we} (5.4c) = 0.0034192

ϕ_{ase} ((5.4d), TBDY) = 0.15672608

$b_o = 240.00$

$h_o = 340.00$

$b_{i2} = 346400.00$

$\phi_{psh,min} = \text{Min}(\phi_{psh,x}, \phi_{psh,y}) = 0.00261799$

Expression ((5.4d), TBDY) for $\phi_{psh,min}$ has been multiplied by 0.3 according to 15.7.1.3 for members without earthquake detailing (90° closed stirrups)

$\phi_{psh,x}$ (5.4d) = 0.00349066

$A_{sh} = A_{stir} * n_s = 78.53982$

No stirrups, $n_s = 2.00$

$b_k = 300.00$

$\phi_{psh,y}$ (5.4d) = 0.00261799

$A_{sh} = A_{stir} * n_s = 78.53982$

No stirrups, $n_s = 2.00$

$b_k = 400.00$

$s = 150.00$

$f_{ywe} = 555.55$

$f_{ce} = 20.00$

From ((5.A5), TBDY), TBDY: $\phi_{cc} = 0.002$

c = confinement factor = 1.00

$y_1 = 0.00129669$

$sh_1 = 0.0044814$

$ft_1 = 373.4467$

$fy_1 = 311.2056$

$\mu_{u1} = 0.00512$

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00

$l_o/l_{ou,min} = l_b/l_d = 0.30$
 $su_1 = 0.4 * esu_{1,nominal} ((5.5), TBDY) = 0.032$
 From table 5A.1, TBDY: $esu_{1,nominal} = 0.08$,
 For calculation of $esu_{1,nominal}$ and y_1, sh_1, ft_1, fy_1 , it is considered
 characteristic value $fsy_1 = fs_1/1.2$, from table 5.1, TBDY.
 y_1, sh_1, ft_1, fy_1 , are also multiplied by $Min(1, 1.25 * (l_b/l_d)^{2/3})$, from 10.3.5, ASCE 41-17.
 with $fs_1 = fs = 311.2056$
 with $Es_1 = Es = 200000.00$
 $y_2 = 0.00129669$
 $sh_2 = 0.0044814$
 $ft_2 = 373.4467$
 $fy_2 = 311.2056$
 $su_2 = 0.00512$
 using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
 and also multiplied by the shear_factor according to 15.7.1.4, with
 Shear_factor = 1.00
 $l_o/l_{ou,min} = l_b/l_{b,min} = 0.30$
 $su_2 = 0.4 * esu_{2,nominal} ((5.5), TBDY) = 0.032$
 From table 5A.1, TBDY: $esu_{2,nominal} = 0.08$,
 For calculation of $esu_{2,nominal}$ and y_2, sh_2, ft_2, fy_2 , it is considered
 characteristic value $fsy_2 = fs_2/1.2$, from table 5.1, TBDY.
 y_1, sh_1, ft_1, fy_1 , are also multiplied by $Min(1, 1.25 * (l_b/l_d)^{2/3})$, from 10.3.5, ASCE 41-17.
 with $fs_2 = fs = 311.2056$
 with $Es_2 = Es = 200000.00$
 $y_v = 0.00129669$
 $sh_v = 0.0044814$
 $ft_v = 373.4467$
 $fy_v = 311.2056$
 $suv = 0.00512$
 using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
 and also multiplied by the shear_factor according to 15.7.1.4, with
 Shear_factor = 1.00
 $l_o/l_{ou,min} = l_b/l_d = 0.30$
 $suv = 0.4 * esuv_{nominal} ((5.5), TBDY) = 0.032$
 From table 5A.1, TBDY: $esuv_{nominal} = 0.08$,
 considering characteristic value $fsyv = fs_v/1.2$, from table 5.1, TBDY
 For calculation of $esuv_{nominal}$ and y_v, sh_v, ft_v, fy_v , it is considered
 characteristic value $fsyv = fs_v/1.2$, from table 5.1, TBDY.
 y_1, sh_1, ft_1, fy_1 , are also multiplied by $Min(1, 1.25 * (l_b/l_d)^{2/3})$, from 10.3.5, ASCE 41-17.
 with $fs_v = fs = 311.2056$
 with $Es_v = Es = 200000.00$
 $1 = Asl_{ten}/(b * d) * (fs_1/f_c) = 0.0767366$
 $2 = Asl_{com}/(b * d) * (fs_2/f_c) = 0.0767366$
 $v = Asl_{mid}/(b * d) * (fs_v/f_c) = 0.0767366$

and confined core properties:

$b = 340.00$
 $d = 228.00$
 $d' = 12.00$
 $f_{cc} (5A.2, TBDY) = 20.00$
 $cc (5A.5, TBDY) = 0.002$
 $c = \text{confinement factor} = 1.00$
 $1 = Asl_{ten}/(b * d) * (fs_1/f_c) = 0.10215708$
 $2 = Asl_{com}/(b * d) * (fs_2/f_c) = 0.10215708$
 $v = Asl_{mid}/(b * d) * (fs_v/f_c) = 0.10215708$

Case/Assumption: Unconfined full section - Steel rupture

' satisfies Eq. (4.3)

--->

$v < v_s, y_2$ - LHS eq.(4.5) is satisfied

--->

$su (4.9) = 0.21759794$
 $Mu = MRc (4.14) = 5.3484E+007$
 $u = su (4.1) = 2.5364147E-005$

Calculation of ratio l_b/l_d

Inadequate Lap Length with $l_b/l_d = 0.30$

Calculation of Shear Strength $V_r = \text{Min}(V_{r1}, V_{r2}) = 152466.975$

Calculation of Shear Strength at edge 1, $V_{r1} = 152466.975$
 $V_{r1} = V_n$ ((22.5.1.1), ACI 318-14)

NOTE: In expression (22.5.1.1) ' V_w ' is replaced by ' $V_w + f \cdot V_f$ '
where V_f is the contribution of FRPs (11.3), ACI 440).

From Table (22.5.5.1), ACI 318-14: $V_c = 68692.008$
= 1 (normal-weight concrete)
 $f_c' = 20.00$, but $f_c'^{0.5} \leq 8.3$ MPa (22.5.3.1, ACI 318-14)
 $\rho_w = A_s / (b_w \cdot d) = 0.00628319$
 A_s (tension reinf.) = 603.1858
 $b_w = 400.00$
 $d = 240.00$
 $V_u \cdot d / M_u < 1 = 0.00$
 $M_u = 2.0746991\text{E-}007$
 $V_u = 1.0090939\text{E-}010$

From (11.5.4.8), ACI 318-14: $V_s = 83774.966$
 $A_v = 157079.633$
 $f_y = 444.44$
 $s = 150.00$

V_s has been multiplied by $2(1-s/d)$ ($s > d/2$, according to ASCE 41-17, 10.3.4)

$2(1-s/d) = 0.75$

V_f ((11-3)-(11.4), ACI 440) = 0.00

From (11-11), ACI 440: $V_s + V_f \leq 285202.276$

Calculation of Shear Strength at edge 2, $V_{r2} = 152466.975$
 $V_{r2} = V_n$ ((22.5.1.1), ACI 318-14)

NOTE: In expression (22.5.1.1) ' V_w ' is replaced by ' $V_w + f \cdot V_f$ '
where V_f is the contribution of FRPs (11.3), ACI 440).

From Table (22.5.5.1), ACI 318-14: $V_c = 68692.008$
= 1 (normal-weight concrete)
 $f_c' = 20.00$, but $f_c'^{0.5} \leq 8.3$ MPa (22.5.3.1, ACI 318-14)
 $\rho_w = A_s / (b_w \cdot d) = 0.00628319$
 A_s (tension reinf.) = 603.1858
 $b_w = 400.00$
 $d = 240.00$
 $V_u \cdot d / M_u < 1 = 0.00$
 $M_u = 2.0781750\text{E-}008$
 $V_u = 1.0090939\text{E-}010$

From (11.5.4.8), ACI 318-14: $V_s = 83774.966$
 $A_v = 157079.633$
 $f_y = 444.44$
 $s = 150.00$

V_s has been multiplied by $2(1-s/d)$ ($s > d/2$, according to ASCE 41-17, 10.3.4)

$2(1-s/d) = 0.75$

V_f ((11-3)-(11.4), ACI 440) = 0.00

From (11-11), ACI 440: $V_s + V_f \leq 285202.276$

End Of Calculation of Shear Capacity ratio for element: beam B1 of floor 1
At local axis: 2

Start Of Calculation of Chord Rotation Capacity for element: beam B1 of floor 1
At local axis: 2
Integration Section: (a)
Section Type: rcars

Constant Properties

Knowledge Factor, $\phi = 1.00$

Chord Rotation is generally considered as Deformation-Controlled Action according to Table C7-1, ASCE 41-17.

Mean strengths are used for Deformation-Controlled Actions according to 7.5.1.3, ASCE 41-17

Consequently:

Existing material of Secondary Member: Concrete Strength, $f_c = f_{cm} = 20.00$

Existing material of Secondary Member: Steel Strength, $f_s = f_{sm} = 444.44$

Concrete Elasticity, $E_c = 21019.039$

Steel Elasticity, $E_s = 200000.00$

Section Height, $H = 400.00$

Section Width, $W = 300.00$

Cover Thickness, $c = 25.00$

Element Length, $L = 1850.00$

Secondary Member

Ribbed Bars

Ductile Steel

Without Detailing for Earthquake Resistance (including stirrups not closed at 135°)

Longitudinal Bars With Ends Lapped Starting at the End Sections

Inadequate Lap Length with $l_b/l_d = 0.30$

No FRP Wrapping

Stepwise Properties

Bending Moment, $M = 6.5579E+006$

Shear Force, $V_2 = -6.2288147E-008$

Shear Force, $V_3 = -3588.176$

Axial Force, $F = -1388.628$

Longitudinal Reinforcement Area Distribution (in 2 divisions)

-Tension: $A_{st} = 603.1858$

-Compression: $A_{sc} = 923.6282$

Longitudinal Reinforcement Area Distribution (in 3 divisions)

-Tension: $A_{st,ten} = 603.1858$

-Compression: $A_{st,com} = 615.7522$

-Middle: $A_{st,mid} = 307.8761$

Mean Diameter of Tension Reinforcement, $D_bL = 16.00$

Existing component: From table 7-7, ASCE 41_17: Final chord rotation Capacity $u_R = \phi \cdot u = 0.00838366$

$u = \gamma + \rho = 0.00838366$

- Calculation of γ -

$\gamma = (M \cdot L_s / 3) / E_{eff} = 0.00338366$ ((4.29), Biskinis Phd))

$M \gamma = 5.6036E+007$

$L_s = M/V$ (with $L_s > 0.1 \cdot L$ and $L_s < 2 \cdot L$) = 1827.648

From table 10.5, ASCE 41_17: $E_{eff} = 0.3 \cdot E_c \cdot I_g = 1.0089E+013$

Calculation of Yielding Moment M_y

Calculation of γ and M_y according to Annex 7 -

$\gamma = \text{Min}(\gamma_{ten}, \gamma_{com})$

$\gamma_{ten} = 4.8184594E-006$

with ((10.1), ASCE 41-17) $f_y = \text{Min}(f_y, 1.25 \cdot f_y \cdot (l_b/l_d)^{2/3}) = 248.9644$

$d = 357.00$

$\gamma = 0.2763461$

$A = 0.01430805$

$B = 0.00796688$

with $p_t = 0.00563199$

$p_c = 0.00574932$

$p_v = 0.00287466$
 $N = 1388.628$
 $b = 300.00$
 $" = 0.11764706$
 $y_{comp} = 1.7400393E-005$
 with $f_c = 20.00$
 $E_c = 21019.039$
 $y = 0.27571625$
 $A = 0.01421812$
 $B = 0.00791481$
 with $E_s = 200000.00$

Calculation of ratio I_b/I_d

Inadequate Lap Length with $I_b/I_d = 0.30$

- Calculation of p -

From table 10-7: $p = 0.005$

with:

- Condition iv occurred

Beam controlled by inadequate embedment into beam-column joint:
 $(I_b/I_d < 1$ and With Lapping in the Vicinity of the End Regions

- Condition i occurred

Beam controlled by flexure: $V_p/V_o \leq 1$

shear control ratio $V_p/V_o = 0.40672566$

- Transverse Reinforcement: NC

- Stirrup Spacing $> d/3$

- Low ductility demand, $\gamma < 2$ (table 10-6, ASCE 41-17)

$= 7.5866881E-005$

- Stirrup Spacing $\leq d/2$

$d = 357.00$

$s = 150.00$

- Strength provided by hoops $V_s < 3/4 \times \text{design Shear}$

$V_s = 148933.273$, already given in calculation of shear control ratio

design Shear = 3588.176

- $(\rho - \rho')/b_w d = -0.160191$

$= A_{st}/(b_w d) = 0.00563199$

Tension Reinf Area: $A_{st} = 603.1858$

$\rho' = A_{sc}/(b_w d) = 0.00862398$

Compression Reinf Area: $A_{sc} = 923.6282$

From (B-1), ACI 318-11: $\rho_{bal} = 0.01867766$

$f_c = 20.00$

$f_y = 444.44$

From 10.2.7.3, ACI 318-11: $\beta_1 = 0.85$

From fig R10.3.3, ACI 318-11 (Ence 454, too): $87000/(87000 + f_y) = c_b/d_t = 0.003/(0.003 + \gamma) = 0.57447053$

$\gamma = 0.0022222$

- $V/(b_w d f_c^{0.5}) = 0.09021785$, NOTE: units in lb & in

$b_w = 300.00$

End Of Calculation of Chord Rotation Capacity for element: beam B1 of floor 1

At local axis: 2

Integration Section: (a)

Calculation No. 3

beam B1, Floor 1



Limit State: Operational Level (data interpolation between analysis steps 1 and 2)

Analysis: Uniform +X

Check: Shear capacity V_{Rd}

Edge: Start

Local Axis: (3)



Start Of Calculation of Shear Capacity for element: beam B1 of floor 1

At local axis: 3

Integration Section: (a)

Section Type: rcars

Constant Properties

Knowledge Factor, $\gamma = 1.00$

Member Shear Force is generally considered as Force-Controlled Action according to Table C7-1, ASCE 41-17.

Lower-bound strengths are used for Force-Controlled Actions according to 7.5.1.3, ASCE 41-17

Consequently:

Existing material of Secondary Member: Concrete Strength, $f_c = f_{c_lower_bound} = 16.00$

Existing material of Secondary Member: Steel Strength, $f_s = f_{s_lower_bound} = 400.00$

Concrete Elasticity, $E_c = 21019.039$

Steel Elasticity, $E_s = 200000.00$

Section Height, $H = 400.00$

Section Width, $W = 300.00$

Cover Thickness, $c = 25.00$

Element Length, $L = 1850.00$

Secondary Member

Ribbed Bars

Ductile Steel

Without Detailing for Earthquake Resistance (including stirrups not closed at 135°)

Longitudinal Bars With Ends Lapped Starting at the End Sections

Inadequate Lap Length with $l_o/l_{ou,min} = l_b/l_d = 0.30$

No FRP Wrapping

Stepwise Properties

EDGE -A-

Bending Moment, $M_a = 6.5579E+006$

Shear Force, $V_a = -3588.176$
 EDGE -B-
 Bending Moment, $M_b = 7.7166E+006$
 Shear Force, $V_b = 11843.705$
 BOTH EDGES
 Axial Force, $F = -1388.628$
 Longitudinal Reinforcement Area Distribution (in 2 divisions)
 -Tension: $As_t = 603.1858$
 -Compression: $As_c = 923.6282$
 Longitudinal Reinforcement Area Distribution (in 3 divisions)
 -Tension: $As_{t,ten} = 603.1858$
 -Compression: $As_{c,com} = 615.7522$
 -Middle: $As_{mid} = 307.8761$
 Mean Diameter of Tension Reinforcement, $Db_{L,ten} = 16.00$

Existing component: From table 7-7, ASCE 41_17: Final Shear Capacity $V_R = V_n = 197276.671$
 $V_n ((22.5.1.1), ACI 318-14) = 197276.671$

NOTE: In expression (22.5.1.1) ' V_w ' is replaced by ' $V_w + V_f$ '
 where V_f is the contribution of FRPs (11.3), ACI 440).

From Table (22.5.5.1), ACI 318-14: $V_c = 63235.385$
 = 1 (normal-weight concrete)
 $f'_c = 16.00$, but $f'_c^{0.5} \leq 8.3$ MPa (22.5.3.1, ACI 318-14)
 $\rho_w = A_s / (b_w \cdot d) = 0.00628319$
 A_s (tension reinf.) = 603.1858
 $b_w = 300.00$
 $d = 320.00$
 $V_u \cdot d / M_u < 1 = 0.17508845$
 $M_u = 6.5579E+006$
 $V_u = 3588.176$
 From (11.5.4.8), ACI 318-14: $V_s = 134041.287$
 $A_v = 157079.633$
 $f_y = 400.00$
 $s = 150.00$
 V_s has been multiplied by 1 ($s \leq d/2$, according to ASCE 41-17, 10.3.4)
 $V_f ((11-3)-(11.4), ACI 440) = 0.00$
 From (11-11), ACI 440: $V_s + V_f \leq 255092.67$

End Of Calculation of Shear Capacity for element: beam B1 of floor 1
 At local axis: 3
 Integration Section: (a)

Calculation No. 4

beam B1, Floor 1


Limit State: Operational Level (data interpolation between analysis steps 1 and 2)

Analysis: Uniform +X

Check: Chord rotation capacity (ϕ)

Edge: Start

Local Axis: (3)



Start Of Calculation of Shear Capacity ratio for element: beam B1 of floor 1

At Shear local axis: 3

(Bending local axis: 2)

Section Type: rcars

Constant Properties

Knowledge Factor, $\gamma = 1.00$

Mean strength values are used for both shear and moment calculations.

Consequently:

Existing material of Secondary Member: Concrete Strength, $f_c = f_{cm} = 20.00$

Existing material of Secondary Member: Steel Strength, $f_s = f_{sm} = 444.44$

Concrete Elasticity, $E_c = 21019.039$

Steel Elasticity, $E_s = 200000.00$

#####

Note: Especially for the calculation of moment strengths,

the above steel re-bar strengths are multiplied by 1.25 according to R18.6.5, ACI 318-14

Existing material: Steel Strength, $f_s = 1.25 \cdot f_{sm} = 555.55$

#####

Section Height, $H = 400.00$

Section Width, $W = 300.00$

Cover Thickness, $c = 25.00$

Mean Confinement Factor overall section = 1.00

Element Length, $L = 1850.00$

Secondary Member

Ribbed Bars

Ductile Steel

Without Detailing for Earthquake Resistance (including stirrups not closed at 135°)

Longitudinal Bars With Ends Lapped Starting at the End Sections

Inadequate Lap Length with $l_o/l_{ou,min} = 0.30$

No FRP Wrapping

Stepwise Properties

At local axis: 3

EDGE -A-

Shear Force, $V_a = 4076.60$

EDGE -B-

Shear Force, $V_b = 4178.928$
 BOTH EDGES
 Axial Force, $F = -400.0832$
 Longitudinal Reinforcement Area Distribution (in 2 divisions)
 -Tension: $As_t = 603.1858$
 -Compression: $As_c = 923.6282$
 Longitudinal Reinforcement Area Distribution (in 3 divisions)
 -Tension: $As_{t,ten} = 603.1858$
 -Compression: $As_{c,com} = 615.7522$
 -Middle: $As_{mid} = 307.8761$

 Calculation of Shear Capacity ratio, $V_e/V_r = 0.40672566$
 Member Controlled by Flexure ($V_e/V_r < 1$)
 Calculation of Shear Demand from fig. R18.6.5, ACI 318-14 $V_e = (M_{pr1} + M_{pr2})/l_n \pm w_u \cdot l_n/2 = 92684.415$
 with
 $M_{pr1} = \text{Max}(\mu_{u1+}, \mu_{u1-}) = 8.1957E+007$
 $\mu_{u1+} = 8.0451E+007$, is the ultimate moment strength at the edge 1 of the member in the actual moment direction
 which is defined for the static loading combination
 $\mu_{u1-} = 8.1957E+007$, is the ultimate moment strength at the edge 1 of the member in the opposite moment
 direction which is defined for the static loading combination
 $M_{pr2} = \text{Max}(\mu_{u2+}, \mu_{u2-}) = 8.1873E+007$
 $\mu_{u2+} = 8.0533E+007$, is the ultimate moment strength at the edge 2 of the member in the actual moment direction
 which is defined for the the static loading combination
 $\mu_{u2-} = 8.1873E+007$, is the ultimate moment strength at the edge 2 of the member in the opposite moment
 direction which is defined for the the static loading combination
 and
 $\pm w_u \cdot l_n = (|V_1| + |V_2|)/2$
 with
 $V_1 = 4076.60$, is the shear force acting at edge 1 for the the static loading combination
 $V_2 = 4178.928$, is the shear force acting at edge 2 for the the static loading combination

 Calculation of μ_{u1+}

 Calculation of ultimate curvature μ_u according to 4.1, Biskinis/Fardis 2013:

$\mu_u = 1.7899831E-005$
 $\mu_u = 8.0451E+007$

 with full section properties:

$b = 300.00$
 $d = 357.00$
 $d' = 42.00$
 $v = 0.00018678$
 $N = 400.0832$
 $f_c = 20.00$
 $\phi_c \text{ (5A.5, TBDY)} = 0.002$
 Final value of ϕ_c : $\phi_c^* = \text{shear_factor} \cdot \text{Max}(\phi_c, \phi_c) = 0.00583896$
 The Shear_factor is considered equal to 1 (pure moment strength)
 From (5.4b), TBDY: $\phi_c = 0.00583896$
 $\phi_w \text{ (5.4c)} = 0.0034192$
 $\phi_{se} \text{ ((5.4d), TBDY)} = 0.15672608$
 $b_o = 240.00$
 $h_o = 340.00$
 $b_{i2} = 346400.00$
 $\phi_{sh,min} = \text{Min}(\phi_{sh,x}, \phi_{sh,y}) = 0.00261799$
 Expression ((5.4d), TBDY) for $\phi_{sh,min}$ has been multiplied by 0.3 according to 15.7.1.3 for members without
 earthquake detailing (90° closed stirrups)

 $\phi_{sh,x} \text{ (5.4d)} = 0.00349066$
 $A_{sh} = A_{stir} \cdot n_s = 78.53982$
 No stirrups, $n_s = 2.00$
 $b_k = 300.00$

psh,y (5.4d) = 0.00261799
 Ash = Astir*ns = 78.53982
 No stirups, ns = 2.00
 bk = 400.00

s = 150.00
 fywe = 555.55
 fce = 20.00

From ((5.A5), TBDY), TBDY: cc = 0.002
 c = confinement factor = 1.00

y1 = 0.00129669
 sh1 = 0.0044814
 ft1 = 373.4467
 fy1 = 311.2056
 su1 = 0.00512

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
 and also multiplied by the shear_factor according to 15.7.1.4, with
 Shear_factor = 1.00

lo/lou,min = lb/lb,min = 0.30

su1 = 0.4*esu1_nominal ((5.5), TBDY) = 0.032

From table 5A.1, TBDY: esu1_nominal = 0.08,

For calculation of esu1_nominal and y1, sh1,ft1,fy1, it is considered
 characteristic value fsy1 = fs1/1.2, from table 5.1, TBDY.

y1, sh1,ft1,fy1, are also multiplied by $\text{Min}(1, 1.25 \cdot (lb/lb)^{2/3})$, from 10.3.5, ASCE 41-17.

with fs1 = fs = 311.2056

with Es1 = Es = 200000.00

y2 = 0.00129669
 sh2 = 0.0044814
 ft2 = 373.4467
 fy2 = 311.2056
 su2 = 0.00512

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
 and also multiplied by the shear_factor according to 15.7.1.4, with
 Shear_factor = 1.00

lo/lou,min = lb/lb,min = 0.30

su2 = 0.4*esu2_nominal ((5.5), TBDY) = 0.032

From table 5A.1, TBDY: esu2_nominal = 0.08,

For calculation of esu2_nominal and y2, sh2,ft2,fy2, it is considered
 characteristic value fsy2 = fs2/1.2, from table 5.1, TBDY.

y1, sh1,ft1,fy1, are also multiplied by $\text{Min}(1, 1.25 \cdot (lb/lb)^{2/3})$, from 10.3.5, ASCE 41-17.

with fs2 = fs = 311.2056

with Es2 = Es = 200000.00

yv = 0.00129669
 shv = 0.0044814
 ftv = 373.4467
 fyv = 311.2056
 suv = 0.00512

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
 and also multiplied by the shear_factor according to 15.7.1.4, with
 Shear_factor = 1.00

lo/lou,min = lb/lb,min = 0.30

suv = 0.4*esuv_nominal ((5.5), TBDY) = 0.032

From table 5A.1, TBDY: esuv_nominal = 0.08,

considering characteristic value fsyv = fsv/1.2, from table 5.1, TBDY

For calculation of esuv_nominal and yv, shv,ftv,fyv, it is considered
 characteristic value fsyv = fsv/1.2, from table 5.1, TBDY.

y1, sh1,ft1,fy1, are also multiplied by $\text{Min}(1, 1.25 \cdot (lb/lb)^{2/3})$, from 10.3.5, ASCE 41-17.

with fsv = fs = 311.2056

with Esv = Es = 200000.00

1 = Asl,ten/(b*d)*(fs1/fc) = 0.08763528

2 = Asl,com/(b*d)*(fs2/fc) = 0.08946101

v = Asl,mid/(b*d)*(fsv/fc) = 0.04473051

and confined core properties:

b = 240.00
 d = 327.00
 d' = 12.00

```

fcc (5A.2, TBDY) = 20.00
cc (5A.5, TBDY) = 0.002
c = confinement factor = 1.00
1 = Asl,ten/(b*d)*(fs1/fc) = 0.11959401
2 = Asl,com/(b*d)*(fs2/fc) = 0.12208556
v = Asl,mid/(b*d)*(fsv/fc) = 0.06104278
Case/Assumption: Unconfined full section - Steel rupture
'satisfies Eq. (4.3)
--->
v < vs,y2 - LHS eq.(4.5) is satisfied
--->
su (4.9) = 0.19877808
Mu = MRc (4.14) = 8.0451E+007
u = su (4.1) = 1.7899831E-005

```

Calculation of ratio lb/ld

Inadequate Lap Length with lb/ld = 0.30

Calculation of Mu1-

Calculation of ultimate curvature u according to 4.1, Biskinis/Fardis 2013:

u = 1.7901443E-005

Mu = 8.1957E+007

with full section properties:

b = 300.00

d = 358.00

d' = 43.00

v = 0.00018626

N = 400.0832

fc = 20.00

co (5A.5, TBDY) = 0.002

Final value of cu: cu* = shear_factor * Max(cu, cc) = 0.00583896

The Shear_factor is considered equal to 1 (pure moment strength)

From (5.4b), TBDY: cu = 0.00583896

we (5.4c) = 0.0034192

ase ((5.4d), TBDY) = 0.15672608

bo = 240.00

ho = 340.00

bi2 = 346400.00

psh,min = Min(psh,x , psh,y) = 0.00261799

Expression ((5.4d), TBDY) for psh,min has been multiplied by 0.3 according to 15.7.1.3 for members without earthquake detailing (90° closed stirrups)

psh,x (5.4d) = 0.00349066

Ash = Astir*ns = 78.53982

No stirups, ns = 2.00

bk = 300.00

psh,y (5.4d) = 0.00261799

Ash = Astir*ns = 78.53982

No stirups, ns = 2.00

bk = 400.00

s = 150.00

fywe = 555.55

fce = 20.00

From ((5.A5), TBDY), TBDY: cc = 0.002

c = confinement factor = 1.00

y1 = 0.00129669

sh1 = 0.0044814

```

ft1 = 373.4467
fy1 = 311.2056
su1 = 0.00512
    using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
    and also multiplied by the shear_factor according to 15.7.1.4, with
    Shear_factor = 1.00
    lo/lou,min = lb/lb,min = 0.30
    su1 = 0.4*esu1_nominal ((5.5), TBDY) = 0.032
    From table 5A.1, TBDY: esu1_nominal = 0.08,
    For calculation of esu1_nominal and y1, sh1,ft1,fy1, it is considered
    characteristic value fsy1 = fs1/1.2, from table 5.1, TBDY.
    y1, sh1,ft1,fy1, are also multiplied by Min(1,1.25*(lb/lb,min)^ 2/3), from 10.3.5, ASCE 41-17.
    with fs1 = fs = 311.2056
    with Es1 = Es = 200000.00
y2 = 0.00129669
sh2 = 0.0044814
ft2 = 373.4467
fy2 = 311.2056
su2 = 0.00512
    using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
    and also multiplied by the shear_factor according to 15.7.1.4, with
    Shear_factor = 1.00
    lo/lou,min = lb/lb,min = 0.30
    su2 = 0.4*esu2_nominal ((5.5), TBDY) = 0.032
    From table 5A.1, TBDY: esu2_nominal = 0.08,
    For calculation of esu2_nominal and y2, sh2,ft2,fy2, it is considered
    characteristic value fsy2 = fs2/1.2, from table 5.1, TBDY.
    y1, sh1,ft1,fy1, are also multiplied by Min(1,1.25*(lb/lb,min)^ 2/3), from 10.3.5, ASCE 41-17.
    with fs2 = fs = 311.2056
    with Es2 = Es = 200000.00
yv = 0.00129669
shv = 0.0044814
ftv = 373.4467
fyv = 311.2056
suv = 0.00512
    using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
    and also multiplied by the shear_factor according to 15.7.1.4, with
    Shear_factor = 1.00
    lo/lou,min = lb/lb,min = 0.30
    suv = 0.4*esuv_nominal ((5.5), TBDY) = 0.032
    From table 5A.1, TBDY: esuv_nominal = 0.08,
    considering characteristic value fsyv = fsv/1.2, from table 5.1, TBDY
    For calculation of esuv_nominal and yv, shv,ftv,fyv, it is considered
    characteristic value fsyv = fsv/1.2, from table 5.1, TBDY.
    y1, sh1,ft1,fy1, are also multiplied by Min(1,1.25*(lb/lb,min)^ 2/3), from 10.3.5, ASCE 41-17.
    with fsv = fs = 311.2056
    with Esv = Es = 200000.00
1 = Asl,ten/(b*d)*(fs1/fc) = 0.08921112
2 = Asl,com/(b*d)*(fs2/fc) = 0.08739049
v = Asl,mid/(b*d)*(fsv/fc) = 0.04460556
and confined core properties:
b = 240.00
d = 328.00
d' = 13.00
fcc (5A.2, TBDY) = 20.00
cc (5A.5, TBDY) = 0.002
    c = confinement factor = 1.00
1 = Asl,ten/(b*d)*(fs1/fc) = 0.12171334
2 = Asl,com/(b*d)*(fs2/fc) = 0.1192294
v = Asl,mid/(b*d)*(fsv/fc) = 0.06085667
Case/Assumption: Unconfined full section - Steel rupture
' satisfies Eq. (4.3)
--->
v < vs,y2 - LHS eq.(4.5) is satisfied
--->
su (4.9) = 0.20108809
Mu = MRc (4.14) = 8.1957E+007

```

$$u = su(4.1) = 1.7901443E-005$$

Calculation of ratio l_b/l_d

Inadequate Lap Length with $l_b/l_d = 0.30$

Calculation of μ_{u2}

Calculation of ultimate curvature μ_u according to 4.1, Biskinis/Fardis 2013:

$$\mu_u = 1.7862388E-005$$

$$\mu_u = 8.0533E+007$$

with full section properties:

$$b = 300.00$$

$$d = 358.00$$

$$d' = 43.00$$

$$v = 0.00018626$$

$$N = 400.0832$$

$$f_c = 20.00$$

$$\alpha_{co}(5A.5, \text{TB DY}) = 0.002$$

$$\text{Final value of } \mu_{cu}: \mu_{cu}^* = \text{shear_factor} * \text{Max}(\mu_{cu}, \mu_{cc}) = 0.00583896$$

The Shear_factor is considered equal to 1 (pure moment strength)

$$\text{From (5.4b), TB DY: } \mu_{cu} = 0.00583896$$

$$\mu_{we}(5.4c) = 0.0034192$$

$$\mu_{ase}((5.4d), \text{TB DY}) = 0.15672608$$

$$b_o = 240.00$$

$$h_o = 340.00$$

$$b_{i2} = 346400.00$$

$$\mu_{psh,min} = \text{Min}(\mu_{psh,x}, \mu_{psh,y}) = 0.00261799$$

Expression ((5.4d), TB DY) for $\mu_{psh,min}$ has been multiplied by 0.3 according to 15.7.1.3 for members without earthquake detailing (90° closed stirrups)

$$\mu_{psh,x}(5.4d) = 0.00349066$$

$$A_{sh} = A_{stir} * n_s = 78.53982$$

$$\text{No stirrups, } n_s = 2.00$$

$$b_k = 300.00$$

$$\mu_{psh,y}(5.4d) = 0.00261799$$

$$A_{sh} = A_{stir} * n_s = 78.53982$$

$$\text{No stirrups, } n_s = 2.00$$

$$b_k = 400.00$$

$$s = 150.00$$

$$f_{ywe} = 555.55$$

$$f_{ce} = 20.00$$

$$\text{From ((5.A5), TB DY), TB DY: } \mu_{cc} = 0.002$$

$$c = \text{confinement factor} = 1.00$$

$$y_1 = 0.00129669$$

$$sh_1 = 0.0044814$$

$$ft_1 = 373.4467$$

$$fy_1 = 311.2056$$

$$su_1 = 0.00512$$

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor and also multiplied by the shear_factor according to 15.7.1.4, with Shear_factor = 1.00

$$l_o/l_{ou,min} = l_b/l_d = 0.30$$

$$su_1 = 0.4 * su_{1,nominal}((5.5), \text{TB DY}) = 0.032$$

$$\text{From table 5A.1, TB DY: } su_{1,nominal} = 0.08,$$

For calculation of $su_{1,nominal}$ and y_1 , sh_1 , ft_1 , fy_1 , it is considered characteristic value $fsy_1 = fs_1/1.2$, from table 5.1, TB DY.

y_1 , sh_1 , ft_1 , fy_1 , are also multiplied by $\text{Min}(1, 1.25 * (l_b/l_d)^{2/3})$, from 10.3.5, ASCE 41-17.

$$\text{with } fs_1 = fs = 311.2056$$

```

with Es1 = Es = 200000.00
y2 = 0.00129669
sh2 = 0.0044814
ft2 = 373.4467
fy2 = 311.2056
su2 = 0.00512
using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00
lo/lou,min = lb/lb,min = 0.30
su2 = 0.4*esu2_nominal ((5.5), TBDY) = 0.032
From table 5A.1, TBDY: esu2_nominal = 0.08,
For calculation of esu2_nominal and y2, sh2,ft2,fy2, it is considered
characteristic value fsy2 = fs2/1.2, from table 5.1, TBDY.
y1, sh1,ft1,fy1, are also multiplied by Min(1,1.25*(lb/d)^ 2/3), from 10.3.5, ASCE 41-17.
with fs2 = fs = 311.2056
with Es2 = Es = 200000.00
yv = 0.00129669
shv = 0.0044814
ftv = 373.4467
fyv = 311.2056
suv = 0.00512
using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00
lo/lou,min = lb/d = 0.30
suv = 0.4*esuv_nominal ((5.5), TBDY) = 0.032
From table 5A.1, TBDY: esuv_nominal = 0.08,
considering characteristic value fsyv = fsv/1.2, from table 5.1, TBDY
For calculation of esuv_nominal and yv, shv,ftv,fyv, it is considered
characteristic value fsyv = fsv/1.2, from table 5.1, TBDY.
y1, sh1,ft1,fy1, are also multiplied by Min(1,1.25*(lb/d)^ 2/3), from 10.3.5, ASCE 41-17.
with fsv = fs = 311.2056
with Esv = Es = 200000.00
1 = Asl,ten/(b*d)*(fs1/fc) = 0.08739049
2 = Asl,com/(b*d)*(fs2/fc) = 0.08921112
v = Asl,mid/(b*d)*(fsv/fc) = 0.04460556
and confined core properties:
b = 240.00
d = 328.00
d' = 13.00
fcc (5A.2, TBDY) = 20.00
cc (5A.5, TBDY) = 0.002
c = confinement factor = 1.00
1 = Asl,ten/(b*d)*(fs1/fc) = 0.1192294
2 = Asl,com/(b*d)*(fs2/fc) = 0.12171334
v = Asl,mid/(b*d)*(fsv/fc) = 0.06085667
Case/Assumption: Unconfined full section - Steel rupture
' satisfies Eq. (4.3)
--->
v < vs,y2 - LHS eq.(4.5) is satisfied
--->
su (4.9) = 0.19934131
Mu = MRc (4.14) = 8.0533E+007
u = su (4.1) = 1.7862388E-005

```

Calculation of ratio lb/d

Inadequate Lap Length with lb/d = 0.30

Calculation of Mu2-

Calculation of ultimate curvature ϕ_u according to 4.1, Biskinis/Fardis 2013:

$$\phi_u = 1.7939215 \times 10^{-5}$$

$$\mu = 8.1873 \times 10^7$$

with full section properties:

$$b = 300.00$$

$$d = 357.00$$

$$d' = 42.00$$

$$v = 0.00018678$$

$$N = 400.0832$$

$$f_c = 20.00$$

$$\phi_{(5A.5, \text{TBDY})} = 0.002$$

$$\text{Final value of } \phi_u: \phi_u^* = \text{shear_factor} * \text{Max}(\phi_u, \phi_c) = 0.00583896$$

The Shear_factor is considered equal to 1 (pure moment strength)

$$\text{From (5.4b), TBDY: } \phi_u = 0.00583896$$

$$\phi_{we} \text{ (5.4c)} = 0.0034192$$

$$\phi_{ase} \text{ ((5.4d), TBDY)} = 0.15672608$$

$$b_o = 240.00$$

$$h_o = 340.00$$

$$b_i^2 = 346400.00$$

$$\phi_{sh, \min} = \text{Min}(\phi_{sh, x}, \phi_{sh, y}) = 0.00261799$$

Expression ((5.4d), TBDY) for $\phi_{sh, \min}$ has been multiplied by 0.3 according to 15.7.1.3 for members without earthquake detailing (90° closed stirrups)

$$\phi_{sh, x} \text{ (5.4d)} = 0.00349066$$

$$A_{sh} = A_{stir} * n_s = 78.53982$$

$$\text{No stirrups, } n_s = 2.00$$

$$b_k = 300.00$$

$$\phi_{sh, y} \text{ (5.4d)} = 0.00261799$$

$$A_{sh} = A_{stir} * n_s = 78.53982$$

$$\text{No stirrups, } n_s = 2.00$$

$$b_k = 400.00$$

$$s = 150.00$$

$$f_{ywe} = 555.55$$

$$f_{ce} = 20.00$$

$$\text{From ((5.A5), TBDY), TBDY: } \phi_c = 0.002$$

$$c = \text{confinement factor} = 1.00$$

$$y_1 = 0.00129669$$

$$sh_1 = 0.0044814$$

$$f_{t1} = 373.4467$$

$$f_{y1} = 311.2056$$

$$su_1 = 0.00512$$

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00

$$l_o/l_{ou, \min} = l_b/l_d = 0.30$$

$$su_1 = 0.4 * \phi_{su1_nominal} \text{ ((5.5), TBDY)} = 0.032$$

$$\text{From table 5A.1, TBDY: } \phi_{su1_nominal} = 0.08,$$

For calculation of $\phi_{su1_nominal}$ and y_1 , sh_1 , f_{t1} , f_{y1} , it is considered
characteristic value $f_{sy1} = f_{s1}/1.2$, from table 5.1, TBDY.

y_1 , sh_1 , f_{t1} , f_{y1} , are also multiplied by $\text{Min}(1, 1.25 * (l_b/l_d)^{2/3})$, from 10.3.5, ASCE 41-17.

$$\text{with } f_{s1} = f_s = 311.2056$$

$$\text{with } E_{s1} = E_s = 200000.00$$

$$y_2 = 0.00129669$$

$$sh_2 = 0.0044814$$

$$f_{t2} = 373.4467$$

$$f_{y2} = 311.2056$$

$$su_2 = 0.00512$$

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00

$$l_o/l_{ou, \min} = l_b/l_{b, \min} = 0.30$$

$$su_2 = 0.4 * \phi_{su2_nominal} \text{ ((5.5), TBDY)} = 0.032$$

$$\text{From table 5A.1, TBDY: } \phi_{su2_nominal} = 0.08,$$

For calculation of $\phi_{su2_nominal}$ and y_2 , sh_2 , f_{t2} , f_{y2} , it is considered

characteristic value $fsy2 = fs2/1.2$, from table 5.1, TBDY.
 $y1, sh1, ft1, fy1$, are also multiplied by $\text{Min}(1, 1.25 \cdot (lb/ld)^{2/3})$, from 10.3.5, ASCE 41-17.
 with $fs2 = fs = 311.2056$
 with $Es2 = Es = 200000.00$
 $yv = 0.00129669$
 $shv = 0.0044814$
 $ftv = 373.4467$
 $fyv = 311.2056$
 $suv = 0.00512$
 using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
 and also multiplied by the shear_factor according to 15.7.1.4, with
 Shear_factor = 1.00
 $lo/lou, min = lb/ld = 0.30$
 $suv = 0.4 \cdot esuv_nominal ((5.5), TBDY) = 0.032$
 From table 5A.1, TBDY: $esuv_nominal = 0.08$,
 considering characteristic value $fsyv = fsv/1.2$, from table 5.1, TBDY
 For calculation of $esuv_nominal$ and yv, shv, ftv, fyv , it is considered
 characteristic value $fsyv = fsv/1.2$, from table 5.1, TBDY.
 $y1, sh1, ft1, fy1$, are also multiplied by $\text{Min}(1, 1.25 \cdot (lb/ld)^{2/3})$, from 10.3.5, ASCE 41-17.
 with $fsv = fs = 311.2056$
 with $Esv = Es = 200000.00$
 $1 = Asl, ten / (b \cdot d) \cdot (fs1 / fc) = 0.08946101$
 $2 = Asl, com / (b \cdot d) \cdot (fs2 / fc) = 0.08763528$
 $v = Asl, mid / (b \cdot d) \cdot (fsv / fc) = 0.04473051$
 and confined core properties:
 $b = 240.00$
 $d = 327.00$
 $d' = 12.00$
 $fcc (5A.2, TBDY) = 20.00$
 $cc (5A.5, TBDY) = 0.002$
 $c = \text{confinement factor} = 1.00$
 $1 = Asl, ten / (b \cdot d) \cdot (fs1 / fc) = 0.12208556$
 $2 = Asl, com / (b \cdot d) \cdot (fs2 / fc) = 0.11959401$
 $v = Asl, mid / (b \cdot d) \cdot (fsv / fc) = 0.06104278$
 Case/Assumption: Unconfined full section - Steel rupture
 ' satisfies Eq. (4.3)
 --->
 $v < vs, y2$ - LHS eq.(4.5) is satisfied
 --->
 $su (4.9) = 0.20053711$
 $Mu = MRc (4.14) = 8.1873E+007$
 $u = su (4.1) = 1.7939215E-005$

 Calculation of ratio lb/ld

Inadequate Lap Length with $lb/ld = 0.30$

Calculation of Shear Strength $Vr = \text{Min}(Vr1, Vr2) = 227879.44$

Calculation of Shear Strength at edge 1, $Vr1 = 227879.44$
 $Vr1 = Vn ((22.5.1.1), ACI 318-14)$

NOTE: In expression (22.5.1.1) 'Vw' is replaced by 'Vw+ f*Vf'
 where Vf is the contribution of FRPs (11.3), ACI 440).

From Table (22.5.5.1), ACI 318-14: $Vc = 78946.167$
 $= 1$ (normal-weight concrete)
 $fc' = 20.00$, but $fc'^{0.5} \leq 8.3$ MPa (22.5.3.1, ACI 318-14)
 $pw = As / (bw \cdot d) = 0.00628319$
 As (tension reinf.) = 603.1858
 $bw = 300.00$
 $d = 320.00$
 $Vu \cdot d / Mu < 1 = 1.00$

$$\mu_u = 60442.822$$

$$V_u = 4076.60$$

$$\text{From (11.5.4.8), ACI 318-14: } V_s = 148933.273$$

$$A_v = 157079.633$$

$$f_y = 444.44$$

$$s = 150.00$$

V_s has been multiplied by 1 ($s < d/2$, according to ASCE 41-17, 10.3.4)

$$V_f \text{ ((11-3)-(11.4), ACI 440)} = 0.00$$

$$\text{From (11-11), ACI 440: } V_s + V_f \leq 285202.276$$

Calculation of Shear Strength at edge 2, $V_{r2} = 227879.44$

$$V_{r2} = V_n \text{ ((22.5.1.1), ACI 318-14)}$$

NOTE: In expression (22.5.1.1) ' V_w ' is replaced by ' $V_w + f \cdot V_f$ '
where V_f is the contribution of FRPs (11.3), ACI 440).

$$\text{From Table (22.5.5.1), ACI 318-14: } V_c = 78946.167$$

= 1 (normal-weight concrete)

$$f'_c = 20.00, \text{ but } f'_c^{0.5} \leq 8.3 \text{ MPa (22.5.3.1, ACI 318-14)}$$

$$p_w = A_s / (b_w \cdot d) = 0.00628319$$

$$A_s \text{ (tension reinf.)} = 603.1858$$

$$b_w = 300.00$$

$$d = 320.00$$

$$V_u \cdot d / \mu_u < 1 = 1.00$$

$$\mu_u = 155096.693$$

$$V_u = 4178.928$$

$$\text{From (11.5.4.8), ACI 318-14: } V_s = 148933.273$$

$$A_v = 157079.633$$

$$f_y = 444.44$$

$$s = 150.00$$

V_s has been multiplied by 1 ($s < d/2$, according to ASCE 41-17, 10.3.4)

$$V_f \text{ ((11-3)-(11.4), ACI 440)} = 0.00$$

$$\text{From (11-11), ACI 440: } V_s + V_f \leq 285202.276$$

End Of Calculation of Shear Capacity ratio for element: beam B1 of floor 1
At local axis: 3

Start Of Calculation of Shear Capacity ratio for element: beam B1 of floor 1
At Shear local axis: 2
(Bending local axis: 3)
Section Type: rcars

Constant Properties

$$\text{Knowledge Factor, } = 1.00$$

Mean strength values are used for both shear and moment calculations.

Consequently:

$$\text{Existing material of Secondary Member: Concrete Strength, } f_c = f_{cm} = 20.00$$

$$\text{Existing material of Secondary Member: Steel Strength, } f_s = f_{sm} = 444.44$$

$$\text{Concrete Elasticity, } E_c = 21019.039$$

$$\text{Steel Elasticity, } E_s = 200000.00$$

#####

Note: Especially for the calculation of moment strengths,

the above steel re-bar strengths are multiplied by 1.25 according to R18.6.5, ACI 318-14

$$\text{Existing material: Steel Strength, } f_s = 1.25 \cdot f_{sm} = 555.55$$

#####

$$\text{Section Height, } H = 400.00$$

$$\text{Section Width, } W = 300.00$$

$$\text{Cover Thickness, } c = 25.00$$

$$\text{Mean Confinement Factor overall section} = 1.00$$

$$\text{Element Length, } L = 1850.00$$

Secondary Member

Ribbed Bars

Ductile Steel

Without Detailing for Earthquake Resistance (including stirrups not closed at 135°)
Longitudinal Bars With Ends Lapped Starting at the End Sections
Inadequate Lap Length with $l_o/l_{ou,min} = 0.30$
No FRP Wrapping

Stepwise Properties

At local axis: 2
EDGE -A-
Shear Force, $V_a = -1.0090939E-010$
EDGE -B-
Shear Force, $V_b = 1.0090939E-010$
BOTH EDGES
Axial Force, $F = -400.0832$
Longitudinal Reinforcement Area Distribution (in 2 divisions)
-Tension: $Asl_t = 603.1858$
-Compression: $Asl_c = 923.6282$
Longitudinal Reinforcement Area Distribution (in 3 divisions)
-Tension: $Asl_{ten} = 508.938$
-Compression: $Asl_{com} = 508.938$
-Middle: $Asl_{mid} = 508.938$

Calculation of Shear Capacity ratio, $V_e/V_r = 0.37923485$
Member Controlled by Flexure ($V_e/V_r < 1$)
Calculation of Shear Demand from fig. R18.6.5, ACI 318-14 $V_e = (M_{pr1} + M_{pr2})/l_n \pm w_u \cdot l_n/2 = 57820.79$
with
 $M_{pr1} = \text{Max}(Mu_{1+}, Mu_{1-}) = 5.3484E+007$
 $Mu_{1+} = 5.3484E+007$, is the ultimate moment strength at the edge 1 of the member in the actual moment direction which is defined for the static loading combination
 $Mu_{1-} = 5.3484E+007$, is the ultimate moment strength at the edge 1 of the member in the opposite moment direction which is defined for the static loading combination
 $M_{pr2} = \text{Max}(Mu_{2+}, Mu_{2-}) = 5.3484E+007$
 $Mu_{2+} = 5.3484E+007$, is the ultimate moment strength at the edge 2 of the member in the actual moment direction which is defined for the the static loading combination
 $Mu_{2-} = 5.3484E+007$, is the ultimate moment strength at the edge 2 of the member in the opposite moment direction which is defined for the the static loading combination
and
 $\pm w_u \cdot l_n = (|V_1| + |V_2|)/2$
with
 $V_1 = -1.0090939E-010$, is the shear force acting at edge 1 for the the static loading combination
 $V_2 = 1.0090939E-010$, is the shear force acting at edge 2 for the the static loading combination

Calculation of Mu_{1+}

Calculation of ultimate curvature ϕ_u according to 4.1, Biskinis/Fardis 2013:
 $\phi_u = 2.5364147E-005$
 $M_u = 5.3484E+007$

with full section properties:

$b = 400.00$
 $d = 258.00$
 $d' = 42.00$
 $v = 0.00019384$
 $N = 400.0832$
 $f_c = 20.00$
 $\phi_o (5A.5, TBDY) = 0.002$
Final value of ϕ_u : $\phi_u^* = \text{shear_factor} \cdot \text{Max}(\phi_u, \phi_o) = 0.00583896$
The Shear_factor is considered equal to 1 (pure moment strength)
From (5.4b), TBDY: $\phi_u = 0.00583896$
we (5.4c) = 0.0034192

$ase((5.4d), TBDY) = 0.15672608$
 $bo = 240.00$
 $ho = 340.00$
 $bi2 = 346400.00$
 $psh,min = \text{Min}(psh,x, psh,y) = 0.00261799$
 Expression $((5.4d), TBDY)$ for psh,min has been multiplied by 0.3 according to 15.7.1.3 for members without earthquake detailing (90° closed stirrups)

$psh,x(5.4d) = 0.00349066$
 $Ash = Astir*ns = 78.53982$
 No stirrups, $ns = 2.00$
 $bk = 300.00$

$psh,y(5.4d) = 0.00261799$
 $Ash = Astir*ns = 78.53982$
 No stirrups, $ns = 2.00$
 $bk = 400.00$

$s = 150.00$
 $fywe = 555.55$
 $fce = 20.00$
 From $((5.A5), TBDY)$, $TBDY$: $cc = 0.002$
 $c = \text{confinement factor} = 1.00$
 $y1 = 0.00129669$
 $sh1 = 0.0044814$
 $ft1 = 373.4467$
 $fy1 = 311.2056$
 $su1 = 0.00512$
 using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
 and also multiplied by the shear_factor according to 15.7.1.4, with
 $\text{Shear_factor} = 1.00$
 $lo/lou,min = lb/ld = 0.30$
 $su1 = 0.4*esu1_nominal((5.5), TBDY) = 0.032$
 From table 5A.1, $TBDY$: $esu1_nominal = 0.08$,
 For calculation of $esu1_nominal$ and $y1, sh1, ft1, fy1$, it is considered
 characteristic value $fsy1 = fs1/1.2$, from table 5.1, $TBDY$.
 $y1, sh1, ft1, fy1$, are also multiplied by $\text{Min}(1, 1.25*(lb/ld)^{2/3})$, from 10.3.5, ASCE 41-17.
 with $fs1 = fs = 311.2056$
 with $Es1 = Es = 200000.00$
 $y2 = 0.00129669$
 $sh2 = 0.0044814$
 $ft2 = 373.4467$
 $fy2 = 311.2056$
 $su2 = 0.00512$
 using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
 and also multiplied by the shear_factor according to 15.7.1.4, with
 $\text{Shear_factor} = 1.00$
 $lo/lou,min = lb/lb,min = 0.30$
 $su2 = 0.4*esu2_nominal((5.5), TBDY) = 0.032$
 From table 5A.1, $TBDY$: $esu2_nominal = 0.08$,
 For calculation of $esu2_nominal$ and $y2, sh2, ft2, fy2$, it is considered
 characteristic value $fsy2 = fs2/1.2$, from table 5.1, $TBDY$.
 $y1, sh1, ft1, fy1$, are also multiplied by $\text{Min}(1, 1.25*(lb/ld)^{2/3})$, from 10.3.5, ASCE 41-17.
 with $fs2 = fs = 311.2056$
 with $Es2 = Es = 200000.00$
 $yv = 0.00129669$
 $shv = 0.0044814$
 $ftv = 373.4467$
 $fyv = 311.2056$
 $suv = 0.00512$
 using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
 and also multiplied by the shear_factor according to 15.7.1.4, with
 $\text{Shear_factor} = 1.00$
 $lo/lou,min = lb/ld = 0.30$
 $suv = 0.4*esuv_nominal((5.5), TBDY) = 0.032$
 From table 5A.1, $TBDY$: $esuv_nominal = 0.08$,
 considering characteristic value $fsyv = fsv/1.2$, from table 5.1, $TBDY$

For calculation of $\epsilon_{sv_nominal}$ and γ_v , ϕ_v , ϕ_{ftv} , ϕ_{fyv} , it is considered characteristic value $f_{sv} = f_{sv}/1.2$, from table 5.1, TBDY.

γ_1 , ϕ_1 , ϕ_{ft1} , ϕ_{fy1} , are also multiplied by $\text{Min}(1, 1.25 \cdot (l_b/l_d)^{2/3})$, from 10.3.5, ASCE 41-17.

with $f_{sv} = f_s = 311.2056$

with $E_{sv} = E_s = 200000.00$

$1 = A_{sl,ten}/(b \cdot d) \cdot (f_{s1}/f_c) = 0.0767366$

$2 = A_{sl,com}/(b \cdot d) \cdot (f_{s2}/f_c) = 0.0767366$

$v = A_{sl,mid}/(b \cdot d) \cdot (f_{sv}/f_c) = 0.0767366$

and confined core properties:

$b = 340.00$

$d = 228.00$

$d' = 12.00$

$f_{cc} \text{ (5A.2, TBDY)} = 20.00$

$cc \text{ (5A.5, TBDY)} = 0.002$

$c = \text{confinement factor} = 1.00$

$1 = A_{sl,ten}/(b \cdot d) \cdot (f_{s1}/f_c) = 0.10215708$

$2 = A_{sl,com}/(b \cdot d) \cdot (f_{s2}/f_c) = 0.10215708$

$v = A_{sl,mid}/(b \cdot d) \cdot (f_{sv}/f_c) = 0.10215708$

Case/Assumption: Unconfined full section - Steel rupture

' satisfies Eq. (4.3)

--->

$v < v_{s,y2}$ - LHS eq.(4.5) is satisfied

--->

$\mu_u \text{ (4.9)} = 0.21759794$

$\mu_u = M_{Rc} \text{ (4.14)} = 5.3484E+007$

$u = \mu_u \text{ (4.1)} = 2.5364147E-005$

Calculation of ratio l_b/l_d

Inadequate Lap Length with $l_b/l_d = 0.30$

Calculation of μ_{u1} -

Calculation of ultimate curvature μ_u according to 4.1, Biskinis/Fardis 2013:

$u = 2.5364147E-005$

$\mu_u = 5.3484E+007$

with full section properties:

$b = 400.00$

$d = 258.00$

$d' = 42.00$

$v = 0.00019384$

$N = 400.0832$

$f_c = 20.00$

$cc \text{ (5A.5, TBDY)} = 0.002$

Final value of μ_u : $\mu_u^* = \text{shear_factor} \cdot \text{Max}(\mu_u, cc) = 0.00583896$

The Shear_factor is considered equal to 1 (pure moment strength)

From (5.4b), TBDY: $\mu_u = 0.00583896$

$\mu_u \text{ (5.4c)} = 0.0034192$

$\mu_u \text{ (5.4d), TBDY)} = 0.15672608$

$b_o = 240.00$

$h_o = 340.00$

$b_{i2} = 346400.00$

$\mu_{sh,min} = \text{Min}(\mu_{sh,x}, \mu_{sh,y}) = 0.00261799$

Expression ((5.4d), TBDY) for $\mu_{sh,min}$ has been multiplied by 0.3 according to 15.7.1.3 for members without earthquake detailing (90° closed stirrups)

$\mu_{sh,x} \text{ (5.4d)} = 0.00349066$

$A_{sh} = A_{stir} \cdot n_s = 78.53982$

No stirrups, $n_s = 2.00$

$b_k = 300.00$

psh,y (5.4d) = 0.00261799
Ash = Astir*ns = 78.53982
No stirups, ns = 2.00
bk = 400.00

s = 150.00
fywe = 555.55
fce = 20.00

From ((5.A5), TBDY), TBDY: cc = 0.002
c = confinement factor = 1.00

y1 = 0.00129669
sh1 = 0.0044814

ft1 = 373.4467

fy1 = 311.2056

su1 = 0.00512

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00

lo/lou,min = lb/lb,min = 0.30

su1 = 0.4*esu1_nominal ((5.5), TBDY) = 0.032

From table 5A.1, TBDY: esu1_nominal = 0.08,

For calculation of esu1_nominal and y1, sh1,ft1,fy1, it is considered
characteristic value fsy1 = fs1/1.2, from table 5.1, TBDY.

y1, sh1,ft1,fy1, are also multiplied by $\text{Min}(1, 1.25 \cdot (lb/lb)^{2/3})$, from 10.3.5, ASCE 41-17.

with fs1 = fs = 311.2056

with Es1 = Es = 200000.00

y2 = 0.00129669

sh2 = 0.0044814

ft2 = 373.4467

fy2 = 311.2056

su2 = 0.00512

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00

lo/lou,min = lb/lb,min = 0.30

su2 = 0.4*esu2_nominal ((5.5), TBDY) = 0.032

From table 5A.1, TBDY: esu2_nominal = 0.08,

For calculation of esu2_nominal and y2, sh2,ft2,fy2, it is considered
characteristic value fsy2 = fs2/1.2, from table 5.1, TBDY.

y1, sh1,ft1,fy1, are also multiplied by $\text{Min}(1, 1.25 \cdot (lb/lb)^{2/3})$, from 10.3.5, ASCE 41-17.

with fs2 = fs = 311.2056

with Es2 = Es = 200000.00

yv = 0.00129669

shv = 0.0044814

ftv = 373.4467

fyv = 311.2056

suv = 0.00512

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00

lo/lou,min = lb/lb,min = 0.30

suv = 0.4*esuv_nominal ((5.5), TBDY) = 0.032

From table 5A.1, TBDY: esuv_nominal = 0.08,

considering characteristic value fsyv = fsv/1.2, from table 5.1, TBDY

For calculation of esuv_nominal and yv, shv,ftv,fyv, it is considered
characteristic value fsyv = fsv/1.2, from table 5.1, TBDY.

y1, sh1,ft1,fy1, are also multiplied by $\text{Min}(1, 1.25 \cdot (lb/lb)^{2/3})$, from 10.3.5, ASCE 41-17.

with fsv = fs = 311.2056

with Esv = Es = 200000.00

1 = Asl,ten/(b*d)*(fs1/fc) = 0.0767366

2 = Asl,com/(b*d)*(fs2/fc) = 0.0767366

v = Asl,mid/(b*d)*(fsv/fc) = 0.0767366

and confined core properties:

b = 340.00

d = 228.00

d' = 12.00

fcc (5A.2, TBDY) = 20.00

```

cc (5A.5, TBDY) = 0.002
c = confinement factor = 1.00
1 = Asl,ten/(b*d)*(fs1/fc) = 0.10215708
2 = Asl,com/(b*d)*(fs2/fc) = 0.10215708
v = Asl,mid/(b*d)*(fsv/fc) = 0.10215708
Case/Assumption: Unconfined full section - Steel rupture
'satisfies Eq. (4.3)
--->
v < vs,y2 - LHS eq.(4.5) is satisfied
--->
su (4.9) = 0.21759794
Mu = MRc (4.14) = 5.3484E+007
u = su (4.1) = 2.5364147E-005

```

Calculation of ratio lb/ld

Inadequate Lap Length with lb/ld = 0.30

Calculation of Mu2+

Calculation of ultimate curvature u according to 4.1, Biskinis/Fardis 2013:

```

u = 2.5364147E-005
Mu = 5.3484E+007

```

with full section properties:

```

b = 400.00
d = 258.00
d' = 42.00
v = 0.00019384
N = 400.0832
fc = 20.00
co (5A.5, TBDY) = 0.002
Final value of cu: cu* = shear_factor * Max( cu, cc) = 0.00583896
The Shear_factor is considered equal to 1 (pure moment strength)
From (5.4b), TBDY: cu = 0.00583896
we (5.4c) = 0.0034192
ase ((5.4d), TBDY) = 0.15672608
bo = 240.00
ho = 340.00
bi2 = 346400.00
psh,min = Min(psh,x , psh,y) = 0.00261799

```

Expression ((5.4d), TBDY) for psh,min has been multiplied by 0.3 according to 15.7.1.3 for members without earthquake detailing (90° closed stirrups)

```

psh,x (5.4d) = 0.00349066
Ash = Astir*ns = 78.53982
No stirups, ns = 2.00
bk = 300.00

```

```

psh,y (5.4d) = 0.00261799
Ash = Astir*ns = 78.53982
No stirups, ns = 2.00
bk = 400.00

```

```

s = 150.00
fywe = 555.55
fce = 20.00
From ((5.A5), TBDY), TBDY: cc = 0.002
c = confinement factor = 1.00
y1 = 0.00129669
sh1 = 0.0044814
ft1 = 373.4467

```



```

fy1 = 311.2056
su1 = 0.00512
    using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
    and also multiplied by the shear_factor according to 15.7.1.4, with
    Shear_factor = 1.00
    lo/lou,min = lb/ld = 0.30
    su1 = 0.4*esu1_nominal ((5.5), TBDY) = 0.032
    From table 5A.1, TBDY: esu1_nominal = 0.08,
    For calculation of esu1_nominal and y1, sh1,ft1,fy1, it is considered
    characteristic value fsy1 = fs1/1.2, from table 5.1, TBDY.
    y1, sh1,ft1,fy1, are also multiplied by Min(1,1.25*(lb/ld)^ 2/3), from 10.3.5, ASCE 41-17.
    with fs1 = fs = 311.2056
    with Es1 = Es = 200000.00
y2 = 0.00129669
sh2 = 0.0044814
ft2 = 373.4467
fy2 = 311.2056
su2 = 0.00512
    using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
    and also multiplied by the shear_factor according to 15.7.1.4, with
    Shear_factor = 1.00
    lo/lou,min = lb/lb,min = 0.30
    su2 = 0.4*esu2_nominal ((5.5), TBDY) = 0.032
    From table 5A.1, TBDY: esu2_nominal = 0.08,
    For calculation of esu2_nominal and y2, sh2,ft2,fy2, it is considered
    characteristic value fsy2 = fs2/1.2, from table 5.1, TBDY.
    y1, sh1,ft1,fy1, are also multiplied by Min(1,1.25*(lb/ld)^ 2/3), from 10.3.5, ASCE 41-17.
    with fs2 = fs = 311.2056
    with Es2 = Es = 200000.00
yv = 0.00129669
shv = 0.0044814
ftv = 373.4467
fyv = 311.2056
suv = 0.00512
    using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
    and also multiplied by the shear_factor according to 15.7.1.4, with
    Shear_factor = 1.00
    lo/lou,min = lb/ld = 0.30
    suv = 0.4*esuv_nominal ((5.5), TBDY) = 0.032
    From table 5A.1, TBDY: esuv_nominal = 0.08,
    considering characteristic value fsyv = fsv/1.2, from table 5.1, TBDY
    For calculation of esuv_nominal and yv, shv,ftv,fyv, it is considered
    characteristic value fsyv = fsv/1.2, from table 5.1, TBDY.
    y1, sh1,ft1,fy1, are also multiplied by Min(1,1.25*(lb/ld)^ 2/3), from 10.3.5, ASCE 41-17.
    with fsv = fs = 311.2056
    with Esv = Es = 200000.00
1 = Asl,ten/(b*d)*(fs1/fc) = 0.0767366
2 = Asl,com/(b*d)*(fs2/fc) = 0.0767366
v = Asl,mid/(b*d)*(fsv/fc) = 0.0767366
and confined core properties:
b = 340.00
d = 228.00
d' = 12.00
fcc (5A.2, TBDY) = 20.00
cc (5A.5, TBDY) = 0.002
    c = confinement factor = 1.00
1 = Asl,ten/(b*d)*(fs1/fc) = 0.10215708
2 = Asl,com/(b*d)*(fs2/fc) = 0.10215708
v = Asl,mid/(b*d)*(fsv/fc) = 0.10215708
Case/Assumption: Unconfined full section - Steel rupture
' satisfies Eq. (4.3)
--->
v < vs,y2 - LHS eq.(4.5) is satisfied
--->
su (4.9) = 0.21759794
Mu = MRc (4.14) = 5.3484E+007
u = su (4.1) = 2.5364147E-005

```

Calculation of ratio l_b/l_d

Inadequate Lap Length with $l_b/l_d = 0.30$

Calculation of μ_2 -

Calculation of ultimate curvature μ according to 4.1, Biskinis/Fardis 2013:

$$\mu = 2.5364147E-005$$

$$\mu_u = 5.3484E+007$$

with full section properties:

$$b = 400.00$$

$$d = 258.00$$

$$d' = 42.00$$

$$v = 0.00019384$$

$$N = 400.0832$$

$$f_c = 20.00$$

$$\omega (5A.5, \text{TB DY}) = 0.002$$

$$\text{Final value of } \mu_u: \mu_u^* = \text{shear_factor} * \text{Max}(\mu_u, \mu_c) = 0.00583896$$

The Shear_factor is considered equal to 1 (pure moment strength)

$$\text{From (5.4b), TB DY: } \mu_u = 0.00583896$$

$$\mu_w (5.4c) = 0.0034192$$

$$\mu_{ase} ((5.4d), \text{TB DY}) = 0.15672608$$

$$b_o = 240.00$$

$$h_o = 340.00$$

$$b_{i2} = 346400.00$$

$$\mu_{sh,min} = \text{Min}(\mu_{sh,x}, \mu_{sh,y}) = 0.00261799$$

Expression ((5.4d), TB DY) for $\mu_{sh,min}$ has been multiplied by 0.3 according to 15.7.1.3 for members without earthquake detailing (90° closed stirrups)

$$\mu_{sh,x} (5.4d) = 0.00349066$$

$$A_{sh} = A_{stir} * n_s = 78.53982$$

$$\text{No stirrups, } n_s = 2.00$$

$$b_k = 300.00$$

$$\mu_{sh,y} (5.4d) = 0.00261799$$

$$A_{sh} = A_{stir} * n_s = 78.53982$$

$$\text{No stirrups, } n_s = 2.00$$

$$b_k = 400.00$$

$$s = 150.00$$

$$f_{ywe} = 555.55$$

$$f_{ce} = 20.00$$

$$\text{From ((5.A.5), TB DY), TB DY: } \mu_c = 0.002$$

$$c = \text{confinement factor} = 1.00$$

$$y_1 = 0.00129669$$

$$sh_1 = 0.0044814$$

$$ft_1 = 373.4467$$

$$fy_1 = 311.2056$$

$$su_1 = 0.00512$$

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor and also multiplied by the shear_factor according to 15.7.1.4, with Shear_factor = 1.00

$$l_o/l_{ou,min} = l_b/l_d = 0.30$$

$$su_1 = 0.4 * \mu_{su1_nominal} ((5.5), \text{TB DY}) = 0.032$$

$$\text{From table 5A.1, TB DY: } \mu_{su1_nominal} = 0.08,$$

For calculation of $\mu_{su1_nominal}$ and y_1, sh_1, ft_1, fy_1 , it is considered characteristic value $fs_1 = fs_1/1.2$, from table 5.1, TB DY.

y_1, sh_1, ft_1, fy_1 , are also multiplied by $\text{Min}(1, 1.25 * (l_b/l_d)^{2/3})$, from 10.3.5, ASCE 41-17.

$$\text{with } fs_1 = fs = 311.2056$$

$$\text{with } E_{s1} = E_s = 200000.00$$

```

y2 = 0.00129669
sh2 = 0.0044814
ft2 = 373.4467
fy2 = 311.2056
su2 = 0.00512
using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00
lo/lou,min = lb/lb,min = 0.30
su2 = 0.4*esu2_nominal ((5.5), TBDY) = 0.032
From table 5A.1, TBDY: esu2_nominal = 0.08,
For calculation of esu2_nominal and y2, sh2,ft2,fy2, it is considered
characteristic value fsy2 = fs2/1.2, from table 5.1, TBDY.
y1, sh1,ft1,fy1, are also multiplied by Min(1,1.25*(lb/ld)^ 2/3), from 10.3.5, ASCE 41-17.
with fs2 = fs = 311.2056
with Es2 = Es = 200000.00
yv = 0.00129669
shv = 0.0044814
ftv = 373.4467
fyv = 311.2056
suv = 0.00512
using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00
lo/lou,min = lb/ld = 0.30
suv = 0.4*esuv_nominal ((5.5), TBDY) = 0.032
From table 5A.1, TBDY: esuv_nominal = 0.08,
considering characteristic value fsyv = fsv/1.2, from table 5.1, TBDY
For calculation of esuv_nominal and yv, shv,ftv,fyv, it is considered
characteristic value fsyv = fsv/1.2, from table 5.1, TBDY.
y1, sh1,ft1,fy1, are also multiplied by Min(1,1.25*(lb/ld)^ 2/3), from 10.3.5, ASCE 41-17.
with fsv = fs = 311.2056
with Esv = Es = 200000.00
1 = Asl,ten/(b*d)*(fs1/fc) = 0.0767366
2 = Asl,com/(b*d)*(fs2/fc) = 0.0767366
v = Asl,mid/(b*d)*(fsv/fc) = 0.0767366
and confined core properties:
b = 340.00
d = 228.00
d' = 12.00
fcc (5A.2, TBDY) = 20.00
cc (5A.5, TBDY) = 0.002
c = confinement factor = 1.00
1 = Asl,ten/(b*d)*(fs1/fc) = 0.10215708
2 = Asl,com/(b*d)*(fs2/fc) = 0.10215708
v = Asl,mid/(b*d)*(fsv/fc) = 0.10215708
Case/Assumption: Unconfined full section - Steel rupture
'satisfies Eq. (4.3)
--->
v < vs,y2 - LHS eq.(4.5) is satisfied
--->
su (4.9) = 0.21759794
Mu = MRc (4.14) = 5.3484E+007
u = su (4.1) = 2.5364147E-005

```

Calculation of ratio lb/ld

Inadequate Lap Length with lb/ld = 0.30

Calculation of Shear Strength $V_r = \min(V_{r1}, V_{r2}) = 152466.975$

Calculation of Shear Strength at edge 1, $V_{r1} = 152466.975$
 $V_{r1} = V_n ((22.5.1.1), \text{ACI } 318-14)$

NOTE: In expression (22.5.1.1) 'Vw' is replaced by 'Vw+ f*Vf'
where Vf is the contribution of FRPs (11.3), ACI 440).

From Table (22.5.5.1), ACI 318-14: $V_c = 68692.008$

= 1 (normal-weight concrete)

$f_c' = 20.00$, but $f_c'^{0.5} \leq 8.3$ MPa (22.5.3.1, ACI 318-14)

$\rho_w = A_s/(b_w*d) = 0.00628319$

A_s (tension reinf.) = 603.1858

$b_w = 400.00$

$d = 240.00$

$V_u*d/M_u < 1 = 0.00$

$M_u = 2.0746991E-007$

$V_u = 1.0090939E-010$

From (11.5.4.8), ACI 318-14: $V_s = 83774.966$

$A_v = 157079.633$

$f_y = 444.44$

$s = 150.00$

V_s has been multiplied by $2(1-s/d)$ ($s > d/2$, according to ASCE 41-17,10.3.4)

$2(1-s/d) = 0.75$

V_f ((11-3)-(11.4), ACI 440) = 0.00

From (11-11), ACI 440: $V_s + V_f \leq 285202.276$

Calculation of Shear Strength at edge 2, $V_{r2} = 152466.975$

$V_{r2} = V_n$ ((22.5.1.1), ACI 318-14)

NOTE: In expression (22.5.1.1) 'Vw' is replaced by 'Vw+ f*Vf'
where Vf is the contribution of FRPs (11.3), ACI 440).

From Table (22.5.5.1), ACI 318-14: $V_c = 68692.008$

= 1 (normal-weight concrete)

$f_c' = 20.00$, but $f_c'^{0.5} \leq 8.3$ MPa (22.5.3.1, ACI 318-14)

$\rho_w = A_s/(b_w*d) = 0.00628319$

A_s (tension reinf.) = 603.1858

$b_w = 400.00$

$d = 240.00$

$V_u*d/M_u < 1 = 0.00$

$M_u = 2.0781750E-008$

$V_u = 1.0090939E-010$

From (11.5.4.8), ACI 318-14: $V_s = 83774.966$

$A_v = 157079.633$

$f_y = 444.44$

$s = 150.00$

V_s has been multiplied by $2(1-s/d)$ ($s > d/2$, according to ASCE 41-17,10.3.4)

$2(1-s/d) = 0.75$

V_f ((11-3)-(11.4), ACI 440) = 0.00

From (11-11), ACI 440: $V_s + V_f \leq 285202.276$

End Of Calculation of Shear Capacity ratio for element: beam B1 of floor 1

At local axis: 2

Start Of Calculation of Chord Rotation Capacity for element: beam B1 of floor 1

At local axis: 3

Integration Section: (a)

Section Type: rcars

Constant Properties

Knowledge Factor, = 1.00

Chord Rotation is generally considered as Deformation-Controlled Action according to Table C7-1, ASCE 41-17.

Mean strengths are used for Deformation-Controlled Actions according to 7.5.1.3, ASCE 41-17

Consequently:

Existing material of Secondary Member: Concrete Strength, $f_c = f_{cm} = 20.00$

Existing material of Secondary Member: Steel Strength, $f_s = f_{sm} = 444.44$

Concrete Elasticity, $E_c = 21019.039$
 Steel Elasticity, $E_s = 200000.00$
 Section Height, $H = 400.00$
 Section Width, $W = 300.00$
 Cover Thickness, $c = 25.00$
 Element Length, $L = 1850.00$
 Secondary Member
 Ribbed Bars
 Ductile Steel
 Without Detailing for Earthquake Resistance (including stirrups not closed at 135°)
 Longitudinal Bars With Ends Lapped Starting at the End Sections
 Inadequate Lap Length with $l_b/l_d = 0.30$
 No FRP Wrapping

Stepwise Properties

Bending Moment, $M = -5.3891561E-005$
 Shear Force, $V_2 = -6.2288147E-008$
 Shear Force, $V_3 = -3588.176$
 Axial Force, $F = -1388.628$
 Longitudinal Reinforcement Area Distribution (in 2 divisions)
 -Tension: $A_{st} = 603.1858$
 -Compression: $A_{sc} = 923.6282$
 Longitudinal Reinforcement Area Distribution (in 3 divisions)
 -Tension: $A_{st,ten} = 508.938$
 -Compression: $A_{sc,com} = 508.938$
 -Middle: $A_{st,mid} = 508.938$
 Mean Diameter of Tension Reinforcement, $D_bL = 14.66667$

Existing component: From table 7-7, ASCE 41_17: Final chord rotation Capacity $u_R = \frac{1}{2} u = 0.00709447$
 $u = y + p = 0.00709447$

- Calculation of y -

$y = (M_y * L_s / 3) / E_{eff} = 0.00209447$ ((4.29), Biskinis Phd))
 $M_y = 3.8551E+007$
 $L_s = M/V$ (with $L_s > 0.1 * L$ and $L_s < 2 * L$) = 925.00
 From table 10.5, ASCE 41_17: $E_{eff} = 0.3 * E_c * I_g = 5.6751E+012$

Calculation of Yielding Moment M_y

Calculation of y and M_y according to Annex 7 -

$y = \min(y_{ten}, y_{com})$
 $y_{ten} = 6.7808955E-006$
 with ((10.1), ASCE 41-17) $f_y = \min(f_y, 1.25 * f_y * (l_b/l_d)^{2/3}) = 248.9644$
 $d = 258.00$
 $y = 0.28845796$
 $A = 0.01484876$
 $B = 0.00865562$
 with $p_t = 0.00493157$
 $p_c = 0.00493157$
 $p_v = 0.00493157$
 $N = 1388.628$
 $b = 400.00$
 $" = 0.1627907$
 $y_{comp} = 2.3061901E-005$
 with $f_c = 20.00$
 $E_c = 21019.039$
 $y = 0.2878557$

A = 0.01475543
B = 0.00860158
with Es = 200000.00

Calculation of ratio l_b/d

Inadequate Lap Length with $l_b/d = 0.30$

- Calculation of p -

From table 10-7: $p = 0.005$

with:

- Condition iv occurred

Beam controlled by inadequate embedment into beam-column joint:
($l_b/d < 1$ and With Lapping in the Vicinity of the End Regions)

- Condition i occurred

Beam controlled by flexure: $V_p/V_o \leq 1$

shear control ratio $V_p/V_o = 0.37923485$

- Transverse Reinforcement: NC

- Stirrup Spacing $> d/3$

- Low ductility demand, $\lambda_y < 2$ (table 10-6, ASCE 41-17)
 $= -6.4106695E-016$

- Stirrup Spacing $> d/2$

$d = 258.00$

$s = 150.00$

- Strength provided by hoops $V_s < 3/4 \times \text{design Shear}$

$V_s = 111699.955$, already given in calculation of shear control ratio

design Shear = $6.2288147E-008$

- (λ_y)/ $\lambda_{bal} = -0.16624473$

$= A_{st}/(b_w \times d) = 0.00584482$

Tension Reinf Area: $A_{st} = 603.1858$

$\lambda_y = A_{sc}/(b_w \times d) = 0.00894989$

Compression Reinf Area: $A_{sc} = 923.6282$

From (B-1), ACI 318-11: $\lambda_{bal} = 0.01867766$

$f_c = 20.00$

$f_y = 444.44$

From 10.2.7.3, ACI 318-11: $\lambda_y = 0.85$

From fig R10.3.3, ACI 318-11 (Ence 454, too): $87000/(87000 + f_y) = c_b/d_t = 0.003/(0.003 + \lambda_y) = 0.57447053$
 $\lambda_y = 0.0022222$

- $V/(b_w \times d \times f_c^{0.5}) = 1.6253015E-012$, NOTE: units in lb & in

$b_w = 400.00$

End Of Calculation of Chord Rotation Capacity for element: beam B1 of floor 1

At local axis: 3

Integration Section: (a)

Calculation No. 5

beam B1, Floor 1


Limit State: Operational Level (data interpolation between analysis steps 1 and 2)

Analysis: Uniform +X

Check: Shear capacity V_{Rd}

Edge: End

Local Axis: (2)



Start Of Calculation of Shear Capacity for element: beam B1 of floor 1

At local axis: 2

Integration Section: (b)

Section Type: rcars

Constant Properties

Knowledge Factor, $\gamma = 1.00$

Member Shear Force is generally considered as Force-Controlled Action according to Table C7-1, ASCE 41-17.

Lower-bound strengths are used for Force-Controlled Actions according to 7.5.1.3, ASCE 41-17

Consequently:

Existing material of Secondary Member: Concrete Strength, $f_c = f_{c_lower_bound} = 16.00$

Existing material of Secondary Member: Steel Strength, $f_s = f_{s_lower_bound} = 400.00$

Concrete Elasticity, $E_c = 21019.039$

Steel Elasticity, $E_s = 200000.00$

Section Height, $H = 400.00$

Section Width, $W = 300.00$

Cover Thickness, $c = 25.00$

Element Length, $L = 1850.00$

Secondary Member

Ribbed Bars

Ductile Steel

Without Detailing for Earthquake Resistance (including stirrups not closed at 135°)

Longitudinal Bars With Ends Lapped Starting at the End Sections

Inadequate Lap Length with $l_o/l_{ou,min} = l_b/l_d = 0.30$

No FRP Wrapping

Stepwise Properties

EDGE -A-

Bending Moment, $M_a = -5.3891561E-005$

Shear Force, $V_a = -6.2288147E-008$

EDGE -B-

Bending Moment, $M_b = -6.4263222E-005$

Shear Force, $V_b = 6.2288147E-008$

BOTH EDGES

Axial Force, $F = -1388.628$

Longitudinal Reinforcement Area Distribution (in 2 divisions)

-Tension: $A_{st} = 615.7522$
 -Compression: $A_{sc} = 911.0619$
 Longitudinal Reinforcement Area Distribution (in 3 divisions)
 -Tension: $A_{st,ten} = 508.938$
 -Compression: $A_{sc,com} = 508.938$
 -Middle: $A_{st,mid} = 508.938$
 Mean Diameter of Tension Reinforcement, $D_{bL,ten} = 14.66667$

Existing component: From table 7-7, ASCE 41_17: Final Shear Capacity $V_R = V_n = 139273.28$
 V_n ((22.5.1.1), ACI 318-14) = 139273.28



NOTE: In expression (22.5.1.1) ' V_w ' is replaced by ' $V_w + f_v V_f$ '
 where V_f is the contribution of FRPs (11.3), ACI 440).

From Table (22.5.5.1), ACI 318-14: $V_c = 63875.056$
 = 1 (normal-weight concrete)
 $f_c' = 16.00$, but $f_c'^{0.5} \leq 8.3$ MPa (22.5.3.1, ACI 318-14)
 $\rho_w = A_s / (b_w \cdot d) = 0.00641409$
 A_s (tension reinf.) = 615.7522
 $b_w = 400.00$
 $d = 240.00$
 $V_u \cdot d / M_u < 1 = 0.23262381$
 $M_u = 6.4263222E-005$
 $V_u = 6.2288147E-008$
 From (11.5.4.8), ACI 318-14: $V_s = 75398.224$
 $A_v = 157079.633$
 $f_y = 400.00$
 $s = 150.00$
 V_s has been multiplied by $2(1-s/d)$ ($s > d/2$, according to ASCE 41-17, 10.3.4)
 $2(1-s/d) = 0.75$
 V_f ((11-3)-(11.4), ACI 440) = 0.00
 From (11-11), ACI 440: $V_s + V_f \leq 255092.67$

End Of Calculation of Shear Capacity for element: beam B1 of floor 1
 At local axis: 2
 Integration Section: (b)

Calculation No. 6

beam B1, Floor 1
 Limit State: Operational Level (data interpolation between analysis steps 1 and 2)
 Analysis: Uniform +X
 Check: Chord rotation capacity (ϕ_r)
 Edge: End
 Local Axis: (2)



Start Of Calculation of Shear Capacity ratio for element: beam B1 of floor 1

At Shear local axis: 3

(Bending local axis: 2)

Section Type: rcars

Constant Properties

Knowledge Factor, $\gamma = 1.00$

Mean strength values are used for both shear and moment calculations.

Consequently:

Existing material of Secondary Member: Concrete Strength, $f_c = f_{cm} = 20.00$

Existing material of Secondary Member: Steel Strength, $f_s = f_{sm} = 444.44$

Concrete Elasticity, $E_c = 21019.039$

Steel Elasticity, $E_s = 200000.00$

#####

Note: Especially for the calculation of moment strengths,

the above steel re-bar strengths are multiplied by 1.25 according to R18.6.5, ACI 318-14

Existing material: Steel Strength, $f_s = 1.25 \cdot f_{sm} = 555.55$

#####

Section Height, $H = 400.00$

Section Width, $W = 300.00$

Cover Thickness, $c = 25.00$

Mean Confinement Factor overall section = 1.00

Element Length, $L = 1850.00$

Secondary Member

Ribbed Bars

Ductile Steel

Without Detailing for Earthquake Resistance (including stirrups not closed at 135°)

Longitudinal Bars With Ends Lapped Starting at the End Sections

Inadequate Lap Length with $l_o/l_{ou,min} = 0.30$

No FRP Wrapping

Stepwise Properties

At local axis: 3

EDGE -A-

Shear Force, $V_a = 4076.60$

EDGE -B-

Shear Force, $V_b = 4178.928$

BOTH EDGES

Axial Force, $F = -400.0832$

Longitudinal Reinforcement Area Distribution (in 2 divisions)

-Tension: $A_{sl,t} = 603.1858$

-Compression: $A_{sl,c} = 923.6282$

Longitudinal Reinforcement Area Distribution (in 3 divisions)

-Tension: $A_{sl,ten} = 603.1858$

-Compression: $A_{sl,com} = 615.7522$

-Middle: $A_{sl,mid} = 307.8761$

Calculation of Shear Capacity ratio , $V_e/V_r = 0.40672566$
 Member Controlled by Flexure ($V_e/V_r < 1$)
 Calculation of Shear Demand from fig. R18.6.5, ACI 318-14 $V_e = (M_{pr1} + M_{pr2})/l_n \pm w_u \cdot l_n/2 = 92684.415$
 with
 $M_{pr1} = \text{Max}(\mu_{1+}, \mu_{1-}) = 8.1957\text{E}+007$
 $\mu_{1+} = 8.0451\text{E}+007$, is the ultimate moment strength at the edge 1 of the member in the actual moment direction
 which is defined for the static loading combination
 $\mu_{1-} = 8.1957\text{E}+007$, is the ultimate moment strength at the edge 1 of the member in the opposite moment
 direction which is defined for the static loading combination
 $M_{pr2} = \text{Max}(\mu_{2+}, \mu_{2-}) = 8.1873\text{E}+007$
 $\mu_{2+} = 8.0533\text{E}+007$, is the ultimate moment strength at the edge 2 of the member in the actual moment direction
 which is defined for the the static loading combination
 $\mu_{2-} = 8.1873\text{E}+007$, is the ultimate moment strength at the edge 2 of the member in the opposite moment
 direction which is defined for the the static loading combination
 and
 $\pm w_u \cdot l_n = (|V_1| + |V_2|)/2$
 with
 $V_1 = 4076.60$, is the shear force acting at edge 1 for the the static loading combination
 $V_2 = 4178.928$, is the shear force acting at edge 2 for the the static loading combination

 Calculation of μ_{1+}

 Calculation of ultimate curvature μ according to 4.1, Biskinis/Fardis 2013:

$$\mu = 1.7899831\text{E}-005$$

$$\mu_u = 8.0451\text{E}+007$$

 with full section properties:

$$b = 300.00$$

$$d = 357.00$$

$$d' = 42.00$$

$$v = 0.00018678$$

$$N = 400.0832$$

$$f_c = 20.00$$

$$c_o(5A.5, \text{TB DY}) = 0.002$$

$$\text{Final value of } \mu_u: \mu_u^* = \text{shear_factor} * \text{Max}(\mu_u, \mu_c) = 0.00583896$$

The Shear_factor is considered equal to 1 (pure moment strength)

$$\text{From (5.4b), TB DY: } \mu_u = 0.00583896$$

$$\mu_w(5.4c) = 0.0034192$$

$$\mu_{ase}((5.4d), \text{TB DY}) = 0.15672608$$

$$b_o = 240.00$$

$$h_o = 340.00$$

$$b_{i2} = 346400.00$$

$$\mu_{psh,min} = \text{Min}(\mu_{psh,x}, \mu_{psh,y}) = 0.00261799$$

Expression ((5.4d), TB DY) for $\mu_{psh,min}$ has been multiplied by 0.3 according to 15.7.1.3 for members without
 earthquake detailing (90° closed stirrups)

 $\mu_{psh,x}(5.4d) = 0.00349066$

$$A_{sh} = A_{stir} \cdot n_s = 78.53982$$

$$\text{No stirrups, } n_s = 2.00$$

$$b_k = 300.00$$

 $\mu_{psh,y}(5.4d) = 0.00261799$

$$A_{sh} = A_{stir} \cdot n_s = 78.53982$$

$$\text{No stirrups, } n_s = 2.00$$

$$b_k = 400.00$$

 $s = 150.00$

$$f_{ywe} = 555.55$$

$$f_{ce} = 20.00$$

$$\text{From ((5.A5), TB DY), TB DY: } \mu_c = 0.002$$

$$c = \text{confinement factor} = 1.00$$

$$y_1 = 0.00129669$$

$$sh_1 = 0.0044814$$

```

ft1 = 373.4467
fy1 = 311.2056
su1 = 0.00512
    using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
    and also multiplied by the shear_factor according to 15.7.1.4, with
    Shear_factor = 1.00
    lo/lou,min = lb/lb,min = 0.30
    su1 = 0.4*esu1_nominal ((5.5), TBDY) = 0.032
    From table 5A.1, TBDY: esu1_nominal = 0.08,
    For calculation of esu1_nominal and y1, sh1,ft1,fy1, it is considered
    characteristic value fsy1 = fs1/1.2, from table 5.1, TBDY.
    y1, sh1,ft1,fy1, are also multiplied by Min(1,1.25*(lb/lb)^ 2/3), from 10.3.5, ASCE 41-17.
    with fs1 = fs = 311.2056
    with Es1 = Es = 200000.00
y2 = 0.00129669
sh2 = 0.0044814
ft2 = 373.4467
fy2 = 311.2056
su2 = 0.00512
    using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
    and also multiplied by the shear_factor according to 15.7.1.4, with
    Shear_factor = 1.00
    lo/lou,min = lb/lb,min = 0.30
    su2 = 0.4*esu2_nominal ((5.5), TBDY) = 0.032
    From table 5A.1, TBDY: esu2_nominal = 0.08,
    For calculation of esu2_nominal and y2, sh2,ft2,fy2, it is considered
    characteristic value fsy2 = fs2/1.2, from table 5.1, TBDY.
    y1, sh1,ft1,fy1, are also multiplied by Min(1,1.25*(lb/lb)^ 2/3), from 10.3.5, ASCE 41-17.
    with fs2 = fs = 311.2056
    with Es2 = Es = 200000.00
yv = 0.00129669
shv = 0.0044814
ftv = 373.4467
fyv = 311.2056
suv = 0.00512
    using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
    and also multiplied by the shear_factor according to 15.7.1.4, with
    Shear_factor = 1.00
    lo/lou,min = lb/lb,min = 0.30
    suv = 0.4*esuv_nominal ((5.5), TBDY) = 0.032
    From table 5A.1, TBDY: esuv_nominal = 0.08,
    considering characteristic value fsyv = fsv/1.2, from table 5.1, TBDY
    For calculation of esuv_nominal and yv, shv,ftv,fyv, it is considered
    characteristic value fsyv = fsv/1.2, from table 5.1, TBDY.
    y1, sh1,ft1,fy1, are also multiplied by Min(1,1.25*(lb/lb)^ 2/3), from 10.3.5, ASCE 41-17.
    with fsv = fs = 311.2056
    with Esv = Es = 200000.00
1 = Asl,ten/(b*d)*(fs1/fc) = 0.08763528
2 = Asl,com/(b*d)*(fs2/fc) = 0.08946101
v = Asl,mid/(b*d)*(fsv/fc) = 0.04473051
and confined core properties:
b = 240.00
d = 327.00
d' = 12.00
fcc (5A.2, TBDY) = 20.00
cc (5A.5, TBDY) = 0.002
    c = confinement factor = 1.00
    1 = Asl,ten/(b*d)*(fs1/fc) = 0.11959401
    2 = Asl,com/(b*d)*(fs2/fc) = 0.12208556
    v = Asl,mid/(b*d)*(fsv/fc) = 0.06104278
Case/Assumption: Unconfined full section - Steel rupture
' satisfies Eq. (4.3)
--->
v < vs,y2 - LHS eq.(4.5) is satisfied
--->
su (4.9) = 0.19877808
Mu = MRc (4.14) = 8.0451E+007

```

$$u = su(4.1) = 1.7899831E-005$$

Calculation of ratio l_b/l_d

Inadequate Lap Length with $l_b/l_d = 0.30$

Calculation of μ_{u1} -

Calculation of ultimate curvature μ_u according to 4.1, Biskinis/Fardis 2013:

$$\mu_u = 1.7901443E-005$$

$$\mu_u = 8.1957E+007$$

with full section properties:

$$b = 300.00$$

$$d = 358.00$$

$$d' = 43.00$$

$$v = 0.00018626$$

$$N = 400.0832$$

$$f_c = 20.00$$

$$\alpha_{co}(5A.5, \text{TB DY}) = 0.002$$

$$\text{Final value of } \mu_{cu}: \mu_{cu}^* = \text{shear_factor} * \text{Max}(\mu_{cu}, \mu_{cc}) = 0.00583896$$

The Shear_factor is considered equal to 1 (pure moment strength)

$$\text{From (5.4b), TB DY: } \mu_{cu} = 0.00583896$$

$$\mu_{we}(5.4c) = 0.0034192$$

$$\mu_{ase}((5.4d), \text{TB DY}) = 0.15672608$$

$$b_o = 240.00$$

$$h_o = 340.00$$

$$b_{i2} = 346400.00$$

$$\mu_{psh,min} = \text{Min}(\mu_{psh,x}, \mu_{psh,y}) = 0.00261799$$

Expression ((5.4d), TB DY) for $\mu_{psh,min}$ has been multiplied by 0.3 according to 15.7.1.3 for members without earthquake detailing (90° closed stirrups)

$$\mu_{psh,x}(5.4d) = 0.00349066$$

$$A_{sh} = A_{stir} * n_s = 78.53982$$

$$\text{No stirrups, } n_s = 2.00$$

$$b_k = 300.00$$

$$\mu_{psh,y}(5.4d) = 0.00261799$$

$$A_{sh} = A_{stir} * n_s = 78.53982$$

$$\text{No stirrups, } n_s = 2.00$$

$$b_k = 400.00$$

$$s = 150.00$$

$$f_{ywe} = 555.55$$

$$f_{ce} = 20.00$$

$$\text{From ((5.A5), TB DY), TB DY: } \mu_{cc} = 0.002$$

$$c = \text{confinement factor} = 1.00$$

$$y_1 = 0.00129669$$

$$sh_1 = 0.0044814$$

$$ft_1 = 373.4467$$

$$fy_1 = 311.2056$$

$$su_1 = 0.00512$$

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor and also multiplied by the shear_factor according to 15.7.1.4, with Shear_factor = 1.00

$$l_o/l_{ou,min} = l_b/l_d = 0.30$$

$$su_1 = 0.4 * su_{1,nominal}((5.5), \text{TB DY}) = 0.032$$

$$\text{From table 5A.1, TB DY: } su_{1,nominal} = 0.08,$$

For calculation of $su_{1,nominal}$ and y_1 , sh_1 , ft_1 , fy_1 , it is considered characteristic value $fsy_1 = fs_1/1.2$, from table 5.1, TB DY.

y_1 , sh_1 , ft_1 , fy_1 , are also multiplied by $\text{Min}(1, 1.25 * (l_b/l_d)^{2/3})$, from 10.3.5, ASCE 41-17.

$$\text{with } fs_1 = fs = 311.2056$$

```

with Es1 = Es = 200000.00
y2 = 0.00129669
sh2 = 0.0044814
ft2 = 373.4467
fy2 = 311.2056
su2 = 0.00512
using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00
lo/lou,min = lb/lb,min = 0.30
su2 = 0.4*esu2_nominal ((5.5), TBDY) = 0.032
From table 5A.1, TBDY: esu2_nominal = 0.08,
For calculation of esu2_nominal and y2, sh2,ft2,fy2, it is considered
characteristic value fsy2 = fs2/1.2, from table 5.1, TBDY.
y1, sh1,ft1,fy1, are also multiplied by Min(1,1.25*(lb/lb)^ 2/3), from 10.3.5, ASCE 41-17.
with fs2 = fs = 311.2056
with Es2 = Es = 200000.00
yv = 0.00129669
shv = 0.0044814
ftv = 373.4467
fyv = 311.2056
suv = 0.00512
using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00
lo/lou,min = lb/lb = 0.30
suv = 0.4*esuv_nominal ((5.5), TBDY) = 0.032
From table 5A.1, TBDY: esuv_nominal = 0.08,
considering characteristic value fsyv = fsv/1.2, from table 5.1, TBDY
For calculation of esuv_nominal and yv, shv,ftv,fyv, it is considered
characteristic value fsyv = fsv/1.2, from table 5.1, TBDY.
y1, sh1,ft1,fy1, are also multiplied by Min(1,1.25*(lb/lb)^ 2/3), from 10.3.5, ASCE 41-17.
with fsv = fs = 311.2056
with Esv = Es = 200000.00
1 = Asl,ten/(b*d)*(fs1/fc) = 0.08921112
2 = Asl,com/(b*d)*(fs2/fc) = 0.08739049
v = Asl,mid/(b*d)*(fsv/fc) = 0.04460556
and confined core properties:
b = 240.00
d = 328.00
d' = 13.00
fcc (5A.2, TBDY) = 20.00
cc (5A.5, TBDY) = 0.002
c = confinement factor = 1.00
1 = Asl,ten/(b*d)*(fs1/fc) = 0.12171334
2 = Asl,com/(b*d)*(fs2/fc) = 0.1192294
v = Asl,mid/(b*d)*(fsv/fc) = 0.06085667
Case/Assumption: Unconfined full section - Steel rupture
'satisfies Eq. (4.3)
--->
v < vs,y2 - LHS eq.(4.5) is satisfied
--->
su (4.9) = 0.20108809
Mu = MRc (4.14) = 8.1957E+007
u = su (4.1) = 1.7901443E-005

```

Calculation of ratio lb/lb

Inadequate Lap Length with lb/lb = 0.30

Calculation of Mu2+

Calculation of ultimate curvature ϕ_u according to 4.1, Biskinis/Fardis 2013:

$$\phi_u = 1.7862388E-005$$

$$\mu_u = 8.0533E+007$$

with full section properties:

$$b = 300.00$$

$$d = 358.00$$

$$d' = 43.00$$

$$v = 0.00018626$$

$$N = 400.0832$$

$$f_c = 20.00$$

$$\phi_{cc} (5A.5, \text{TBDY}) = 0.002$$

$$\text{Final value of } \phi_{cu}: \phi_{cu}^* = \text{shear_factor} * \text{Max}(\phi_{cu}, \phi_{cc}) = 0.00583896$$

The Shear_factor is considered equal to 1 (pure moment strength)

$$\text{From (5.4b), TBDY: } \phi_{cu} = 0.00583896$$

$$\phi_{we} (5.4c) = 0.0034192$$

$$\phi_{ase} ((5.4d), \text{TBDY}) = 0.15672608$$

$$b_o = 240.00$$

$$h_o = 340.00$$

$$b_i^2 = 346400.00$$

$$\phi_{psh,min} = \text{Min}(\phi_{psh,x}, \phi_{psh,y}) = 0.00261799$$

Expression ((5.4d), TBDY) for $\phi_{psh,min}$ has been multiplied by 0.3 according to 15.7.1.3 for members without earthquake detailing (90° closed stirrups)

$$\phi_{psh,x} (5.4d) = 0.00349066$$

$$A_{sh} = A_{stir} * n_s = 78.53982$$

$$\text{No stirrups, } n_s = 2.00$$

$$b_k = 300.00$$

$$\phi_{psh,y} (5.4d) = 0.00261799$$

$$A_{sh} = A_{stir} * n_s = 78.53982$$

$$\text{No stirrups, } n_s = 2.00$$

$$b_k = 400.00$$

$$s = 150.00$$

$$f_{ywe} = 555.55$$

$$f_{ce} = 20.00$$

$$\text{From ((5.A5), TBDY), TBDY: } \phi_{cc} = 0.002$$

$$c = \text{confinement factor} = 1.00$$

$$y_1 = 0.00129669$$

$$sh_1 = 0.0044814$$

$$ft_1 = 373.4467$$

$$fy_1 = 311.2056$$

$$su_1 = 0.00512$$

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00

$$l_o/l_{ou,min} = l_b/l_d = 0.30$$

$$su_1 = 0.4 * \phi_{su1_nominal} ((5.5), \text{TBDY}) = 0.032$$

$$\text{From table 5A.1, TBDY: } \phi_{su1_nominal} = 0.08,$$

For calculation of $\phi_{su1_nominal}$ and y_1 , sh_1 , ft_1 , fy_1 , it is considered
characteristic value $fs_1 = f_s/1.2$, from table 5.1, TBDY.

$$y_1, sh_1, ft_1, fy_1, \text{ are also multiplied by } \text{Min}(1, 1.25 * (l_b/l_d)^{2/3}), \text{ from 10.3.5, ASCE 41-17.}$$

$$\text{with } fs_1 = f_s = 311.2056$$

$$\text{with } E_{s1} = E_s = 200000.00$$

$$y_2 = 0.00129669$$

$$sh_2 = 0.0044814$$

$$ft_2 = 373.4467$$

$$fy_2 = 311.2056$$

$$su_2 = 0.00512$$

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00

$$l_o/l_{ou,min} = l_b/l_{b,min} = 0.30$$

$$su_2 = 0.4 * \phi_{su2_nominal} ((5.5), \text{TBDY}) = 0.032$$

$$\text{From table 5A.1, TBDY: } \phi_{su2_nominal} = 0.08,$$

For calculation of $\phi_{su2_nominal}$ and y_2 , sh_2 , ft_2 , fy_2 , it is considered

characteristic value $f_{sy2} = f_{s2}/1.2$, from table 5.1, TBDY.
 $y1, sh1, ft1, fy1$, are also multiplied by $\text{Min}(1, 1.25 \cdot (l_b/l_d)^{2/3})$, from 10.3.5, ASCE 41-17.
 with $f_{s2} = f_s = 311.2056$
 with $E_{s2} = E_s = 200000.00$
 $y_v = 0.00129669$
 $sh_v = 0.0044814$
 $ft_v = 373.4467$
 $fy_v = 311.2056$
 $suv = 0.00512$
 using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
 and also multiplied by the shear_factor according to 15.7.1.4, with
 Shear_factor = 1.00
 $l_o/l_{ou,min} = l_b/l_d = 0.30$
 $suv = 0.4 \cdot esuv_{nominal} ((5.5), TBDY) = 0.032$
 From table 5A.1, TBDY: $esuv_{nominal} = 0.08$,
 considering characteristic value $f_{syv} = f_{sv}/1.2$, from table 5.1, TBDY
 For calculation of $esuv_{nominal}$ and y_v, sh_v, ft_v, fy_v , it is considered
 characteristic value $f_{syv} = f_{sv}/1.2$, from table 5.1, TBDY.
 $y1, sh1, ft1, fy1$, are also multiplied by $\text{Min}(1, 1.25 \cdot (l_b/l_d)^{2/3})$, from 10.3.5, ASCE 41-17.
 with $f_{sv} = f_s = 311.2056$
 with $E_{sv} = E_s = 200000.00$
 $1 = A_{sl,ten}/(b \cdot d) \cdot (f_{s1}/f_c) = 0.08739049$
 $2 = A_{sl,com}/(b \cdot d) \cdot (f_{s2}/f_c) = 0.08921112$
 $v = A_{sl,mid}/(b \cdot d) \cdot (f_{sv}/f_c) = 0.04460556$

and confined core properties:

$b = 240.00$
 $d = 328.00$
 $d' = 13.00$
 $f_{cc} (5A.2, TBDY) = 20.00$
 $cc (5A.5, TBDY) = 0.002$
 $c = \text{confinement factor} = 1.00$
 $1 = A_{sl,ten}/(b \cdot d) \cdot (f_{s1}/f_c) = 0.1192294$
 $2 = A_{sl,com}/(b \cdot d) \cdot (f_{s2}/f_c) = 0.12171334$
 $v = A_{sl,mid}/(b \cdot d) \cdot (f_{sv}/f_c) = 0.06085667$

Case/Assumption: Unconfined full section - Steel rupture

' satisfies Eq. (4.3)

--->

$v < v_{s,y2}$ - LHS eq.(4.5) is satisfied

--->

$su (4.9) = 0.19934131$
 $Mu = MR_c (4.14) = 8.0533E+007$
 $u = su (4.1) = 1.7862388E-005$

Calculation of ratio l_b/l_d

Inadequate Lap Length with $l_b/l_d = 0.30$

Calculation of $Mu2$ -

Calculation of ultimate curvature u according to 4.1, Biskinis/Fardis 2013:

$u = 1.7939215E-005$
 $Mu = 8.1873E+007$

with full section properties:

$b = 300.00$
 $d = 357.00$
 $d' = 42.00$
 $v = 0.00018678$
 $N = 400.0832$
 $f_c = 20.00$
 $co (5A.5, TBDY) = 0.002$
 Final value of cu : $cu^* = \text{shear_factor} \cdot \text{Max}(cu, cc) = 0.00583896$

The Shear_factor is considered equal to 1 (pure moment strength)
 From (5.4b), TBDY: $c_u = 0.00583896$
 w_e (5.4c) = 0.0034192
 a_{se} ((5.4d), TBDY) = 0.15672608
 $b_o = 240.00$
 $h_o = 340.00$
 $b_{i2} = 346400.00$
 $p_{sh,min} = \text{Min}(p_{sh,x}, p_{sh,y}) = 0.00261799$
 Expression ((5.4d), TBDY) for $p_{sh,min}$ has been multiplied by 0.3 according to 15.7.1.3 for members without earthquake detailing (90° closed stirrups)

 $p_{sh,x}$ (5.4d) = 0.00349066
 $A_{sh} = A_{stir} * n_s = 78.53982$
 No stirrups, $n_s = 2.00$
 $b_k = 300.00$

 $p_{sh,y}$ (5.4d) = 0.00261799
 $A_{sh} = A_{stir} * n_s = 78.53982$
 No stirrups, $n_s = 2.00$
 $b_k = 400.00$

 $s = 150.00$
 $f_{ywe} = 555.55$
 $f_{ce} = 20.00$
 From ((5.A5), TBDY), TBDY: $c_c = 0.002$
 $c = \text{confinement factor} = 1.00$
 $y_1 = 0.00129669$
 $sh_1 = 0.0044814$
 $ft_1 = 373.4467$
 $fy_1 = 311.2056$
 $su_1 = 0.00512$
 using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
 and also multiplied by the shear_factor according to 15.7.1.4, with
 Shear_factor = 1.00
 $l_o/l_{ou,min} = l_b/l_d = 0.30$
 $su_1 = 0.4 * esu1_{nominal}$ ((5.5), TBDY) = 0.032
 From table 5A.1, TBDY: $esu1_{nominal} = 0.08$,
 For calculation of $esu1_{nominal}$ and y_1, sh_1, ft_1, fy_1 , it is considered
 characteristic value $fsy_1 = fs_1/1.2$, from table 5.1, TBDY.
 y_1, sh_1, ft_1, fy_1 , are also multiplied by $\text{Min}(1, 1.25 * (l_b/l_d)^{2/3})$, from 10.3.5, ASCE 41-17.
 with $fs_1 = fs = 311.2056$
 with $Es_1 = Es = 200000.00$
 $y_2 = 0.00129669$
 $sh_2 = 0.0044814$
 $ft_2 = 373.4467$
 $fy_2 = 311.2056$
 $su_2 = 0.00512$
 using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
 and also multiplied by the shear_factor according to 15.7.1.4, with
 Shear_factor = 1.00
 $l_o/l_{ou,min} = l_b/l_{b,min} = 0.30$
 $su_2 = 0.4 * esu2_{nominal}$ ((5.5), TBDY) = 0.032
 From table 5A.1, TBDY: $esu2_{nominal} = 0.08$,
 For calculation of $esu2_{nominal}$ and y_2, sh_2, ft_2, fy_2 , it is considered
 characteristic value $fsy_2 = fs_2/1.2$, from table 5.1, TBDY.
 y_1, sh_1, ft_1, fy_1 , are also multiplied by $\text{Min}(1, 1.25 * (l_b/l_d)^{2/3})$, from 10.3.5, ASCE 41-17.
 with $fs_2 = fs = 311.2056$
 with $Es_2 = Es = 200000.00$
 $y_v = 0.00129669$
 $sh_v = 0.0044814$
 $ft_v = 373.4467$
 $fy_v = 311.2056$
 $suv = 0.00512$
 using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
 and also multiplied by the shear_factor according to 15.7.1.4, with
 Shear_factor = 1.00
 $l_o/l_{ou,min} = l_b/l_d = 0.30$

$suv = 0.4 \cdot esuv_nominal ((5.5), TBDY) = 0.032$
 From table 5A.1, TBDY: $esuv_nominal = 0.08$,
 considering characteristic value $fsyv = fsv/1.2$, from table 5.1, TBDY
 For calculation of $esuv_nominal$ and yv , shv , ftv , fyv , it is considered
 characteristic value $fsyv = fsv/1.2$, from table 5.1, TBDY.
 $y1$, $sh1$, $ft1$, $fy1$, are also multiplied by $\text{Min}(1, 1.25 \cdot (lb/ld)^{2/3})$, from 10.3.5, ASCE 41-17.
 with $fsv = fs = 311.2056$
 with $Esv = Es = 200000.00$
 $1 = Asl,ten/(b \cdot d) \cdot (fs1/fc) = 0.08946101$
 $2 = Asl,com/(b \cdot d) \cdot (fs2/fc) = 0.08763528$
 $v = Asl,mid/(b \cdot d) \cdot (fsv/fc) = 0.04473051$
 and confined core properties:
 $b = 240.00$
 $d = 327.00$
 $d' = 12.00$
 $fcc (5A.2, TBDY) = 20.00$
 $cc (5A.5, TBDY) = 0.002$
 $c = \text{confinement factor} = 1.00$
 $1 = Asl,ten/(b \cdot d) \cdot (fs1/fc) = 0.12208556$
 $2 = Asl,com/(b \cdot d) \cdot (fs2/fc) = 0.11959401$
 $v = Asl,mid/(b \cdot d) \cdot (fsv/fc) = 0.06104278$
 Case/Assumption: Unconfined full section - Steel rupture
 ' satisfies Eq. (4.3)
 --->
 $v < vs,y2$ - LHS eq.(4.5) is satisfied
 ---->
 $su (4.9) = 0.20053711$
 $Mu = MRc (4.14) = 8.1873E+007$
 $u = su (4.1) = 1.7939215E-005$

Calculation of ratio lb/ld

Inadequate Lap Length with $lb/ld = 0.30$

Calculation of Shear Strength $Vr = \text{Min}(Vr1, Vr2) = 227879.44$

Calculation of Shear Strength at edge 1, $Vr1 = 227879.44$
 $Vr1 = Vn ((22.5.1.1), ACI 318-14)$

NOTE: In expression (22.5.1.1) ' Vw ' is replaced by ' $Vw + f \cdot Vf$ '
 where Vf is the contribution of FRPs (11.3), ACI 440).

From Table (22.5.5.1), ACI 318-14: $Vc = 78946.167$
 $= 1$ (normal-weight concrete)
 $fc' = 20.00$, but $fc^{0.5} \leq 8.3 \text{ MPa}$ (22.5.3.1, ACI 318-14)
 $pw = As/(bw \cdot d) = 0.00628319$
 As (tension reinf.) = 603.1858
 $bw = 300.00$
 $d = 320.00$
 $Vu \cdot d / Mu < 1 = 1.00$
 $Mu = 60442.822$
 $Vu = 4076.60$

From (11.5.4.8), ACI 318-14: $Vs = 148933.273$
 $Av = 157079.633$
 $fy = 444.44$
 $s = 150.00$

Vs has been multiplied by 1 ($s < d/2$, according to ASCE 41-17, 10.3.4)

$Vf ((11-3)-(11.4), ACI 440) = 0.00$

From (11-11), ACI 440: $Vs + Vf \leq 285202.276$

Calculation of Shear Strength at edge 2, $Vr2 = 227879.44$
 $Vr2 = Vn ((22.5.1.1), ACI 318-14)$

NOTE: In expression (22.5.1.1) 'Vw' is replaced by 'Vw+ f*Vf'
where Vf is the contribution of FRPs (11.3), ACI 440).

From Table (22.5.5.1), ACI 318-14: $V_c = 78946.167$
= 1 (normal-weight concrete)

$f'_c = 20.00$, but $f_c^{0.5} \leq 8.3$ MPa (22.5.3.1, ACI 318-14)

$\rho_w = A_s/(b_w*d) = 0.00628319$

A_s (tension reinf.) = 603.1858

$b_w = 300.00$

$d = 320.00$

$V_u*d/M_u < 1 = 1.00$

$M_u = 155096.693$

$V_u = 4178.928$

From (11.5.4.8), ACI 318-14: $V_s = 148933.273$

$A_v = 157079.633$

$f_y = 444.44$

$s = 150.00$

V_s has been multiplied by 1 ($s < d/2$, according to ASCE 41-17, 10.3.4)

V_f ((11-3)-(11.4), ACI 440) = 0.00

From (11-11), ACI 440: $V_s + V_f \leq 285202.276$

End Of Calculation of Shear Capacity ratio for element: beam B1 of floor 1
At local axis: 3

Start Of Calculation of Shear Capacity ratio for element: beam B1 of floor 1
At Shear local axis: 2
(Bending local axis: 3)
Section Type: rcars

Constant Properties

Knowledge Factor, = 1.00

Mean strength values are used for both shear and moment calculations.

Consequently:

Existing material of Secondary Member: Concrete Strength, $f_c = f_{cm} = 20.00$

Existing material of Secondary Member: Steel Strength, $f_s = f_{sm} = 444.44$

Concrete Elasticity, $E_c = 21019.039$

Steel Elasticity, $E_s = 200000.00$

#####

Note: Especially for the calculation of moment strengths,

the above steel re-bar strengths are multiplied by 1.25 according to R18.6.5, ACI 318-14

Existing material: Steel Strength, $f_s = 1.25*f_{sm} = 555.55$

#####

Section Height, $H = 400.00$

Section Width, $W = 300.00$

Cover Thickness, $c = 25.00$

Mean Confinement Factor overall section = 1.00

Element Length, $L = 1850.00$

Secondary Member

Ribbed Bars

Ductile Steel

Without Detailing for Earthquake Resistance (including stirrups not closed at 135°)

Longitudinal Bars With Ends Lapped Starting at the End Sections

Inadequate Lap Length with $l_o/l_{ou,min} = 0.30$

No FRP Wrapping

Stepwise Properties

At local axis: 2

EDGE -A-

Shear Force, $V_a = -1.0090939E-010$

EDGE -B-

Shear Force, $V_b = 1.0090939E-010$

BOTH EDGES

Axial Force, $F = -400.0832$

Longitudinal Reinforcement Area Distribution (in 2 divisions)

-Tension: $As_t = 603.1858$

-Compression: $As_c = 923.6282$

Longitudinal Reinforcement Area Distribution (in 3 divisions)

-Tension: $As_{t,ten} = 508.938$

-Compression: $As_{c,com} = 508.938$

-Middle: $As_{mid} = 508.938$

Calculation of Shear Capacity ratio, $V_e/V_r = 0.37923485$

Member Controlled by Flexure ($V_e/V_r < 1$)

Calculation of Shear Demand from fig. R18.6.5, ACI 318-14 $V_e = (M_{pr1} + M_{pr2})/l_n \pm w_u \cdot l_n/2 = 57820.79$ with

$M_{pr1} = \text{Max}(Mu_{1+}, Mu_{1-}) = 5.3484E+007$

$Mu_{1+} = 5.3484E+007$, is the ultimate moment strength at the edge 1 of the member in the actual moment direction which is defined for the static loading combination

$Mu_{1-} = 5.3484E+007$, is the ultimate moment strength at the edge 1 of the member in the opposite moment direction which is defined for the static loading combination

$M_{pr2} = \text{Max}(Mu_{2+}, Mu_{2-}) = 5.3484E+007$

$Mu_{2+} = 5.3484E+007$, is the ultimate moment strength at the edge 2 of the member in the actual moment direction which is defined for the static loading combination

$Mu_{2-} = 5.3484E+007$, is the ultimate moment strength at the edge 2 of the member in the opposite moment direction which is defined for the static loading combination

and

$\pm w_u \cdot l_n = (|V_1| + |V_2|)/2$

with

$V_1 = -1.0090939E-010$, is the shear force acting at edge 1 for the static loading combination

$V_2 = 1.0090939E-010$, is the shear force acting at edge 2 for the static loading combination

Calculation of Mu_{1+}

Calculation of ultimate curvature ϕ_u according to 4.1, Biskinis/Fardis 2013:

$\phi_u = 2.5364147E-005$

$M_u = 5.3484E+007$

with full section properties:

$b = 400.00$

$d = 258.00$

$d' = 42.00$

$v = 0.00019384$

$N = 400.0832$

$f_c = 20.00$

ϕ_c (5A.5, TBDY) = 0.002

Final value of ϕ_u : $\phi_u^* = \text{shear_factor} \cdot \text{Max}(\phi_u, \phi_c) = 0.00583896$

The Shear_factor is considered equal to 1 (pure moment strength)

From (5.4b), TBDY: $\phi_u = 0.00583896$

w_e (5.4c) = 0.0034192

a_{se} ((5.4d), TBDY) = 0.15672608

$b_o = 240.00$

$h_o = 340.00$

$bi_2 = 346400.00$

$\phi_{sh,min} = \text{Min}(\phi_{sh,x}, \phi_{sh,y}) = 0.00261799$

Expression ((5.4d), TBDY) for $\phi_{sh,min}$ has been multiplied by 0.3 according to 15.7.1.3 for members without earthquake detailing (90° closed stirrups)

$\phi_{sh,x}$ (5.4d) = 0.00349066

$A_{sh} = A_{stir} \cdot n_s = 78.53982$

No stirrups, $n_s = 2.00$

$b_k = 300.00$

psh,y (5.4d) = 0.00261799
 Ash = Astir*ns = 78.53982
 No stirups, ns = 2.00
 bk = 400.00

s = 150.00
 fywe = 555.55
 fce = 20.00

From ((5.A5), TBDY), TBDY: cc = 0.002
 c = confinement factor = 1.00

y1 = 0.00129669
 sh1 = 0.0044814

ft1 = 373.4467

fy1 = 311.2056

su1 = 0.00512

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
 and also multiplied by the shear_factor according to 15.7.1.4, with
 Shear_factor = 1.00

lo/lou,min = lb/ld = 0.30

su1 = 0.4*esu1_nominal ((5.5), TBDY) = 0.032

From table 5A.1, TBDY: esu1_nominal = 0.08,

For calculation of esu1_nominal and y1, sh1,ft1,fy1, it is considered
 characteristic value fsy1 = fs1/1.2, from table 5.1, TBDY.

y1, sh1,ft1,fy1, are also multiplied by $\text{Min}(1, 1.25 \cdot (lb/ld)^{2/3})$, from 10.3.5, ASCE 41-17.

with fs1 = fs = 311.2056

with Es1 = Es = 200000.00

y2 = 0.00129669

sh2 = 0.0044814

ft2 = 373.4467

fy2 = 311.2056

su2 = 0.00512

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
 and also multiplied by the shear_factor according to 15.7.1.4, with
 Shear_factor = 1.00

lo/lou,min = lb/lb,min = 0.30

su2 = 0.4*esu2_nominal ((5.5), TBDY) = 0.032

From table 5A.1, TBDY: esu2_nominal = 0.08,

For calculation of esu2_nominal and y2, sh2,ft2,fy2, it is considered
 characteristic value fsy2 = fs2/1.2, from table 5.1, TBDY.

y1, sh1,ft1,fy1, are also multiplied by $\text{Min}(1, 1.25 \cdot (lb/ld)^{2/3})$, from 10.3.5, ASCE 41-17.

with fs2 = fs = 311.2056

with Es2 = Es = 200000.00

yv = 0.00129669

shv = 0.0044814

ftv = 373.4467

fyv = 311.2056

suv = 0.00512

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
 and also multiplied by the shear_factor according to 15.7.1.4, with
 Shear_factor = 1.00

lo/lou,min = lb/ld = 0.30

suv = 0.4*esuv_nominal ((5.5), TBDY) = 0.032

From table 5A.1, TBDY: esuv_nominal = 0.08,

considering characteristic value fsyv = fsv/1.2, from table 5.1, TBDY

For calculation of esuv_nominal and yv, shv,ftv,fyv, it is considered
 characteristic value fsyv = fsv/1.2, from table 5.1, TBDY.

y1, sh1,ft1,fy1, are also multiplied by $\text{Min}(1, 1.25 \cdot (lb/ld)^{2/3})$, from 10.3.5, ASCE 41-17.

with fsv = fs = 311.2056

with Esv = Es = 200000.00

1 = Asl,ten/(b*d)*(fs1/fc) = 0.0767366

2 = Asl,com/(b*d)*(fs2/fc) = 0.0767366

v = Asl,mid/(b*d)*(fsv/fc) = 0.0767366

and confined core properties:

b = 340.00

d = 228.00

d' = 12.00

fcc (5A.2, TBDY) = 20.00

```

cc (5A.5, TBDY) = 0.002
c = confinement factor = 1.00
1 = Asl,ten/(b*d)*(fs1/fc) = 0.10215708
2 = Asl,com/(b*d)*(fs2/fc) = 0.10215708
v = Asl,mid/(b*d)*(fsv/fc) = 0.10215708
Case/Assumption: Unconfined full section - Steel rupture
'satisfies Eq. (4.3)
--->
v < vs,y2 - LHS eq.(4.5) is satisfied
--->
su (4.9) = 0.21759794
Mu = MRc (4.14) = 5.3484E+007
u = su (4.1) = 2.5364147E-005

```

Calculation of ratio lb/ld

Inadequate Lap Length with lb/ld = 0.30

Calculation of Mu1-

Calculation of ultimate curvature u according to 4.1, Biskinis/Fardis 2013:

```

u = 2.5364147E-005
Mu = 5.3484E+007

```

with full section properties:

```

b = 400.00
d = 258.00
d' = 42.00
v = 0.00019384
N = 400.0832
fc = 20.00
co (5A.5, TBDY) = 0.002
Final value of cu: cu* = shear_factor * Max( cu, cc) = 0.00583896
The Shear_factor is considered equal to 1 (pure moment strength)
From (5.4b), TBDY: cu = 0.00583896
we (5.4c) = 0.0034192
ase ((5.4d), TBDY) = 0.15672608
bo = 240.00
ho = 340.00
bi2 = 346400.00
psh,min = Min(psh,x , psh,y) = 0.00261799

```

Expression ((5.4d), TBDY) for psh,min has been multiplied by 0.3 according to 15.7.1.3 for members without earthquake detailing (90° closed stirrups)

```

psh,x (5.4d) = 0.00349066
Ash = Astir*ns = 78.53982
No stirups, ns = 2.00
bk = 300.00

```

```

psh,y (5.4d) = 0.00261799
Ash = Astir*ns = 78.53982
No stirups, ns = 2.00
bk = 400.00

```

```

s = 150.00
fywe = 555.55
fce = 20.00
From ((5.A5), TBDY), TBDY: cc = 0.002
c = confinement factor = 1.00
y1 = 0.00129669
sh1 = 0.0044814
ft1 = 373.4467

```

```

fy1 = 311.2056
su1 = 0.00512
    using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
    and also multiplied by the shear_factor according to 15.7.1.4, with
    Shear_factor = 1.00
    lo/lou,min = lb/ld = 0.30
    su1 = 0.4*esu1_nominal ((5.5), TBDY) = 0.032
    From table 5A.1, TBDY: esu1_nominal = 0.08,
    For calculation of esu1_nominal and y1, sh1,ft1,fy1, it is considered
    characteristic value fsy1 = fs1/1.2, from table 5.1, TBDY.
    y1, sh1,ft1,fy1, are also multiplied by Min(1,1.25*(lb/ld)^ 2/3), from 10.3.5, ASCE 41-17.
    with fs1 = fs = 311.2056
    with Es1 = Es = 200000.00
y2 = 0.00129669
sh2 = 0.0044814
ft2 = 373.4467
fy2 = 311.2056
su2 = 0.00512
    using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
    and also multiplied by the shear_factor according to 15.7.1.4, with
    Shear_factor = 1.00
    lo/lou,min = lb/lb,min = 0.30
    su2 = 0.4*esu2_nominal ((5.5), TBDY) = 0.032
    From table 5A.1, TBDY: esu2_nominal = 0.08,
    For calculation of esu2_nominal and y2, sh2,ft2,fy2, it is considered
    characteristic value fsy2 = fs2/1.2, from table 5.1, TBDY.
    y1, sh1,ft1,fy1, are also multiplied by Min(1,1.25*(lb/ld)^ 2/3), from 10.3.5, ASCE 41-17.
    with fs2 = fs = 311.2056
    with Es2 = Es = 200000.00
yv = 0.00129669
shv = 0.0044814
ftv = 373.4467
fyv = 311.2056
suv = 0.00512
    using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
    and also multiplied by the shear_factor according to 15.7.1.4, with
    Shear_factor = 1.00
    lo/lou,min = lb/ld = 0.30
    suv = 0.4*esuv_nominal ((5.5), TBDY) = 0.032
    From table 5A.1, TBDY: esuv_nominal = 0.08,
    considering characteristic value fsyv = fsv/1.2, from table 5.1, TBDY
    For calculation of esuv_nominal and yv, shv,ftv,fyv, it is considered
    characteristic value fsyv = fsv/1.2, from table 5.1, TBDY.
    y1, sh1,ft1,fy1, are also multiplied by Min(1,1.25*(lb/ld)^ 2/3), from 10.3.5, ASCE 41-17.
    with fsv = fs = 311.2056
    with Esv = Es = 200000.00
1 = Asl,ten/(b*d)*(fs1/fc) = 0.0767366
2 = Asl,com/(b*d)*(fs2/fc) = 0.0767366
v = Asl,mid/(b*d)*(fsv/fc) = 0.0767366
and confined core properties:
b = 340.00
d = 228.00
d' = 12.00
fcc (5A.2, TBDY) = 20.00
cc (5A.5, TBDY) = 0.002
    c = confinement factor = 1.00
1 = Asl,ten/(b*d)*(fs1/fc) = 0.10215708
2 = Asl,com/(b*d)*(fs2/fc) = 0.10215708
v = Asl,mid/(b*d)*(fsv/fc) = 0.10215708
Case/Assumption: Unconfined full section - Steel rupture
' satisfies Eq. (4.3)
--->
v < vs,y2 - LHS eq.(4.5) is satisfied
--->
su (4.9) = 0.21759794
Mu = MRc (4.14) = 5.3484E+007
u = su (4.1) = 2.5364147E-005

```

Calculation of ratio l_b/l_d

Inadequate Lap Length with $l_b/l_d = 0.30$

Calculation of μ_{2+}

Calculation of ultimate curvature μ according to 4.1, Biskinis/Fardis 2013:

$$\mu = 2.5364147E-005$$

$$\mu_u = 5.3484E+007$$

with full section properties:

$$b = 400.00$$

$$d = 258.00$$

$$d' = 42.00$$

$$\nu = 0.00019384$$

$$N = 400.0832$$

$$f_c = 20.00$$

$$\omega (5A.5, \text{TB DY}) = 0.002$$

$$\text{Final value of } \mu_u: \mu_u^* = \text{shear_factor} * \text{Max}(\mu_u, \mu_c) = 0.00583896$$

The Shear_factor is considered equal to 1 (pure moment strength)

$$\text{From (5.4b), TB DY: } \mu_u = 0.00583896$$

$$\mu_w (5.4c) = 0.0034192$$

$$\mu_{ase} ((5.4d), \text{TB DY}) = 0.15672608$$

$$b_o = 240.00$$

$$h_o = 340.00$$

$$b_{i2} = 346400.00$$

$$\mu_{sh,min} = \text{Min}(\mu_{sh,x}, \mu_{sh,y}) = 0.00261799$$

Expression ((5.4d), TB DY) for $\mu_{sh,min}$ has been multiplied by 0.3 according to 15.7.1.3 for members without earthquake detailing (90° closed stirrups)

$$\mu_{sh,x} (5.4d) = 0.00349066$$

$$A_{sh} = A_{stir} * n_s = 78.53982$$

$$\text{No stirrups, } n_s = 2.00$$

$$b_k = 300.00$$

$$\mu_{sh,y} (5.4d) = 0.00261799$$

$$A_{sh} = A_{stir} * n_s = 78.53982$$

$$\text{No stirrups, } n_s = 2.00$$

$$b_k = 400.00$$

$$s = 150.00$$

$$f_{ywe} = 555.55$$

$$f_{ce} = 20.00$$

$$\text{From ((5.A.5), TB DY), TB DY: } \mu_c = 0.002$$

$$c = \text{confinement factor} = 1.00$$

$$y_1 = 0.00129669$$

$$sh_1 = 0.0044814$$

$$ft_1 = 373.4467$$

$$fy_1 = 311.2056$$

$$su_1 = 0.00512$$

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor and also multiplied by the shear_factor according to 15.7.1.4, with Shear_factor = 1.00

$$l_o/l_{ou,min} = l_b/l_d = 0.30$$

$$su_1 = 0.4 * su_{1_nominal} ((5.5), \text{TB DY}) = 0.032$$

$$\text{From table 5A.1, TB DY: } su_{1_nominal} = 0.08,$$

For calculation of $su_{1_nominal}$ and y_1, sh_1, ft_1, fy_1 , it is considered characteristic value $fsy_1 = fs_1/1.2$, from table 5.1, TB DY.

y_1, sh_1, ft_1, fy_1 , are also multiplied by $\text{Min}(1, 1.25 * (l_b/l_d)^{2/3})$, from 10.3.5, ASCE 41-17.

$$\text{with } fs_1 = fs = 311.2056$$

$$\text{with } Es_1 = Es = 200000.00$$

```

y2 = 0.00129669
sh2 = 0.0044814
ft2 = 373.4467
fy2 = 311.2056
su2 = 0.00512
using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00
lo/lou,min = lb/lb,min = 0.30
su2 = 0.4*esu2_nominal ((5.5), TBDY) = 0.032
From table 5A.1, TBDY: esu2_nominal = 0.08,
For calculation of esu2_nominal and y2, sh2,ft2,fy2, it is considered
characteristic value fsy2 = fs2/1.2, from table 5.1, TBDY.
y1, sh1,ft1,fy1, are also multiplied by Min(1,1.25*(lb/ld)^ 2/3), from 10.3.5, ASCE 41-17.
with fs2 = fs = 311.2056
with Es2 = Es = 200000.00
yv = 0.00129669
shv = 0.0044814
ftv = 373.4467
fyv = 311.2056
suv = 0.00512
using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00
lo/lou,min = lb/ld = 0.30
suv = 0.4*esuv_nominal ((5.5), TBDY) = 0.032
From table 5A.1, TBDY: esuv_nominal = 0.08,
considering characteristic value fsyv = fsv/1.2, from table 5.1, TBDY
For calculation of esuv_nominal and yv, shv,ftv,fyv, it is considered
characteristic value fsyv = fsv/1.2, from table 5.1, TBDY.
y1, sh1,ft1,fy1, are also multiplied by Min(1,1.25*(lb/ld)^ 2/3), from 10.3.5, ASCE 41-17.
with fsv = fs = 311.2056
with Esv = Es = 200000.00
1 = Asl,ten/(b*d)*(fs1/fc) = 0.0767366
2 = Asl,com/(b*d)*(fs2/fc) = 0.0767366
v = Asl,mid/(b*d)*(fsv/fc) = 0.0767366
and confined core properties:
b = 340.00
d = 228.00
d' = 12.00
fcc (5A.2, TBDY) = 20.00
cc (5A.5, TBDY) = 0.002
c = confinement factor = 1.00
1 = Asl,ten/(b*d)*(fs1/fc) = 0.10215708
2 = Asl,com/(b*d)*(fs2/fc) = 0.10215708
v = Asl,mid/(b*d)*(fsv/fc) = 0.10215708
Case/Assumption: Unconfined full section - Steel rupture
'satisfies Eq. (4.3)
--->
v < vs,y2 - LHS eq.(4.5) is satisfied
--->
su (4.9) = 0.21759794
Mu = MRc (4.14) = 5.3484E+007
u = su (4.1) = 2.5364147E-005

```

Calculation of ratio lb/ld

Inadequate Lap Length with lb/ld = 0.30

Calculation of Mu2-

Calculation of ultimate curvature u according to 4.1, Biskinis/Fardis 2013:

u = 2.5364147E-005
Mu = 5.3484E+007

with full section properties:

b = 400.00

d = 258.00

d' = 42.00

v = 0.00019384

N = 400.0832

fc = 20.00

co (5A.5, TBDY) = 0.002

Final value of cu: $cu^* = \text{shear_factor} * \text{Max}(cu, cc) = 0.00583896$

The Shear_factor is considered equal to 1 (pure moment strength)

From (5.4b), TBDY: $cu = 0.00583896$

we (5.4c) = 0.0034192

ase ((5.4d), TBDY) = 0.15672608

bo = 240.00

ho = 340.00

bi2 = 346400.00

psh,min = Min(psh,x , psh,y) = 0.00261799

Expression ((5.4d), TBDY) for psh,min has been multiplied by 0.3 according to 15.7.1.3 for members without earthquake detailing (90° closed stirrups)

psh,x (5.4d) = 0.00349066

Ash = Astir*ns = 78.53982

No stirrups, ns = 2.00

bk = 300.00

psh,y (5.4d) = 0.00261799

Ash = Astir*ns = 78.53982

No stirrups, ns = 2.00

bk = 400.00

s = 150.00

fywe = 555.55

fce = 20.00

From ((5.A5), TBDY), TBDY: $cc = 0.002$

c = confinement factor = 1.00

y1 = 0.00129669

sh1 = 0.0044814

ft1 = 373.4467

fy1 = 311.2056

su1 = 0.00512

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00

lo/lou,min = lb/d = 0.30

su1 = $0.4 * esu1_nominal$ ((5.5), TBDY) = 0.032

From table 5A.1, TBDY: $esu1_nominal = 0.08$,

For calculation of $esu1_nominal$ and $y1$, $sh1$, $ft1$, $fy1$, it is considered
characteristic value $fsy1 = fs1/1.2$, from table 5.1, TBDY.

$y1$, $sh1$, $ft1$, $fy1$, are also multiplied by $\text{Min}(1, 1.25 * (lb/d)^{2/3})$, from 10.3.5, ASCE 41-17.

with $fs1 = fs = 311.2056$

with $Es1 = Es = 200000.00$

y2 = 0.00129669

sh2 = 0.0044814

ft2 = 373.4467

fy2 = 311.2056

su2 = 0.00512

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00

lo/lou,min = lb/lb,min = 0.30

su2 = $0.4 * esu2_nominal$ ((5.5), TBDY) = 0.032

From table 5A.1, TBDY: $esu2_nominal = 0.08$,

For calculation of $esu2_nominal$ and $y2$, $sh2$, $ft2$, $fy2$, it is considered
characteristic value $fsy2 = fs2/1.2$, from table 5.1, TBDY.

$y1, sh1, ft1, fy1$, are also multiplied by $\text{Min}(1, 1.25 \cdot (lb/ld)^{2/3})$, from 10.3.5, ASCE 41-17.
 with $fs2 = fs = 311.2056$
 with $Es2 = Es = 200000.00$
 $yv = 0.00129669$
 $shv = 0.0044814$
 $ftv = 373.4467$
 $fyv = 311.2056$
 $suv = 0.00512$
 using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
 and also multiplied by the shear_factor according to 15.7.1.4, with
 Shear_factor = 1.00
 $lo/lou, min = lb/ld = 0.30$
 $suv = 0.4 \cdot esuv_nominal \cdot ((5.5), TBDY) = 0.032$
 From table 5A.1, TBDY: $esuv_nominal = 0.08$,
 considering characteristic value $fsyv = fsv/1.2$, from table 5.1, TBDY
 For calculation of $esuv_nominal$ and yv, shv, ftv, fyv , it is considered
 characteristic value $fsyv = fsv/1.2$, from table 5.1, TBDY.
 $y1, sh1, ft1, fy1$, are also multiplied by $\text{Min}(1, 1.25 \cdot (lb/ld)^{2/3})$, from 10.3.5, ASCE 41-17.
 with $fsv = fs = 311.2056$
 with $Es = 200000.00$
 $1 = Asl, ten / (b \cdot d) \cdot (fs1 / fc) = 0.0767366$
 $2 = Asl, com / (b \cdot d) \cdot (fs2 / fc) = 0.0767366$
 $v = Asl, mid / (b \cdot d) \cdot (fsv / fc) = 0.0767366$

and confined core properties:

$b = 340.00$
 $d = 228.00$
 $d' = 12.00$
 $fcc \text{ (5A.2, TBDY)} = 20.00$
 $cc \text{ (5A.5, TBDY)} = 0.002$
 $c = \text{confinement factor} = 1.00$
 $1 = Asl, ten / (b \cdot d) \cdot (fs1 / fc) = 0.10215708$
 $2 = Asl, com / (b \cdot d) \cdot (fs2 / fc) = 0.10215708$
 $v = Asl, mid / (b \cdot d) \cdot (fsv / fc) = 0.10215708$

Case/Assumption: Unconfined full section - Steel rupture
 ' satisfies Eq. (4.3)

--->
 $v < vs, y2$ - LHS eq.(4.5) is satisfied
 --->
 $su \text{ (4.9)} = 0.21759794$
 $Mu = MRc \text{ (4.14)} = 5.3484E+007$
 $u = su \text{ (4.1)} = 2.5364147E-005$

Calculation of ratio lb/ld

Inadequate Lap Length with $lb/ld = 0.30$

Calculation of Shear Strength $Vr = \text{Min}(Vr1, Vr2) = 152466.975$

Calculation of Shear Strength at edge 1, $Vr1 = 152466.975$
 $Vr1 = Vn \text{ ((22.5.1.1), ACI 318-14)}$

NOTE: In expression (22.5.1.1) ' Vw ' is replaced by ' $Vw + f \cdot Vf$ '
 where Vf is the contribution of FRPs (11.3), ACI 440).

From Table (22.5.5.1), ACI 318-14: $Vc = 68692.008$
 $= 1$ (normal-weight concrete)
 $fc' = 20.00$, but $fc'^{0.5} \leq 8.3 \text{ MPa}$ (22.5.3.1, ACI 318-14)
 $pw = As / (bw \cdot d) = 0.00628319$
 $As \text{ (tension reinf.)} = 603.1858$
 $bw = 400.00$
 $d = 240.00$
 $Vu \cdot d / Mu < 1 = 0.00$
 $Mu = 2.0746991E-007$

$$V_u = 1.0090939E-010$$

From (11.5.4.8), ACI 318-14: $V_s = 83774.966$

$$A_v = 157079.633$$

$$f_y = 444.44$$

$$s = 150.00$$

V_s has been multiplied by $2(1-s/d)$ ($s > d/2$, according to ASCE 41-17, 10.3.4)

$$2(1-s/d) = 0.75$$

$$V_f ((11-3)-(11.4), \text{ACI 440}) = 0.00$$

$$\text{From (11-11), ACI 440: } V_s + V_f \leq 285202.276$$

Calculation of Shear Strength at edge 2, $V_{r2} = 152466.975$

$$V_{r2} = V_n ((22.5.1.1), \text{ACI 318-14})$$

NOTE: In expression (22.5.1.1) ' V_w ' is replaced by ' $V_w + f \cdot V_f$ ' where V_f is the contribution of FRPs (11.3), ACI 440).

From Table (22.5.5.1), ACI 318-14: $V_c = 68692.008$

= 1 (normal-weight concrete)

$$f_c' = 20.00, \text{ but } f_c'^{0.5} \leq 8.3 \text{ MPa (22.5.3.1, ACI 318-14)}$$

$$p_w = A_s / (b_w \cdot d) = 0.00628319$$

$$A_s (\text{tension reinf.}) = 603.1858$$

$$b_w = 400.00$$

$$d = 240.00$$

$$V_u \cdot d / M_u < 1 = 0.00$$

$$M_u = 2.0781750E-008$$

$$V_u = 1.0090939E-010$$

From (11.5.4.8), ACI 318-14: $V_s = 83774.966$

$$A_v = 157079.633$$

$$f_y = 444.44$$

$$s = 150.00$$

V_s has been multiplied by $2(1-s/d)$ ($s > d/2$, according to ASCE 41-17, 10.3.4)

$$2(1-s/d) = 0.75$$

$$V_f ((11-3)-(11.4), \text{ACI 440}) = 0.00$$

$$\text{From (11-11), ACI 440: } V_s + V_f \leq 285202.276$$

End Of Calculation of Shear Capacity ratio for element: beam B1 of floor 1

At local axis: 2

Start Of Calculation of Chord Rotation Capacity for element: beam B1 of floor 1

At local axis: 2

Integration Section: (b)

Section Type: rcars

Constant Properties

Knowledge Factor, = 1.00

Chord Rotation is generally considered as Deformation-Controlled Action according to Table C7-1, ASCE 41-17.

Mean strengths are used for Deformation-Controlled Actions according to 7.5.1.3, ASCE 41-17

Consequently:

Existing material of Secondary Member: Concrete Strength, $f_c = f_{cm} = 20.00$

Existing material of Secondary Member: Steel Strength, $f_s = f_{sm} = 444.44$

Concrete Elasticity, $E_c = 21019.039$

Steel Elasticity, $E_s = 200000.00$

Section Height, $H = 400.00$

Section Width, $W = 300.00$

Cover Thickness, $c = 25.00$

Element Length, $L = 1850.00$

Secondary Member

Ribbed Bars

Ductile Steel

Without Detailing for Earthquake Resistance (including stirrups not closed at 135°)

Longitudinal Bars With Ends Lapped Starting at the End Sections

Inadequate Lap Length with $l_b / l_d = 0.30$

No FRP Wrapping

Stepwise Properties

Bending Moment, $M = 7.7166\text{E}+006$

Shear Force, $V2 = 6.2288147\text{E}-008$

Shear Force, $V3 = 11843.705$

Axial Force, $F = -1388.628$

Longitudinal Reinforcement Area Distribution (in 2 divisions)

-Tension: $Asl_{ten} = 615.7522$

-Compression: $Asl_{com} = 911.0619$

Longitudinal Reinforcement Area Distribution (in 3 divisions)

-Tension: $Asl_{ten} = 615.7522$

-Compression: $Asl_{com} = 603.1858$

-Middle: $Asl_{mid} = 307.8761$

Mean Diameter of Tension Reinforcement, $DbL = 14.00$

Existing component: From table 7-7, ASCE 41_17: Final chord rotation Capacity $u_{R} = u = 0.00623007$

$u = y + p = 0.00623007$

- Calculation of y -

$y = (My * Ls / 3) / Eleff = 0.00123007$ ((4.29), Biskinis Phd))

$My = 5.7144\text{E}+007$

$Ls = M/V$ (with $Ls > 0.1 * L$ and $Ls < 2 * L$) = 651.5325

From table 10.5, ASCE 41_17: $Eleff = 0.3 * Ec * Ig = 1.0089\text{E}+013$

Calculation of Yielding Moment My

Calculation of y and My according to Annex 7 -

$y = \text{Min}(y_{ten}, y_{com})$

$y_{ten} = 4.8217801\text{E}-006$

with ((10.1), ASCE 41-17) $f_y = \text{Min}(f_y, 1.25 * f_y * (l_b / d)^{2/3}) = 248.9644$

$d = 358.00$

$y = 0.27886447$

$A = 0.01426808$

$B = 0.00806524$

with $pt = 0.00573326$

$pc = 0.00561626$

$pv = 0.00286663$

$N = 1388.628$

$b = 300.00$

$" = 0.12011173$

$y_{comp} = 1.7194102\text{E}-005$

with $fc = 20.00$

$Ec = 21019.039$

$y = 0.27824483$

$A = 0.0141784$

$B = 0.00801331$

with $Es = 200000.00$

Calculation of ratio l_b / d

Inadequate Lap Length with $l_b / d = 0.30$

- Calculation of p -

From table 10-7: $p = 0.005$

with:

- Condition iv occurred
Beam controlled by inadequate embedment into beam-column joint:
($l_b/d < 1$ and With Lapping in the Vicinity of the End Regions)
- Condition i occurred
Beam controlled by flexure: $V_p/V_o \leq 1$
shear control ratio $V_p/V_o = 0.40672566$
- Transverse Reinforcement: NC
- Stirrup Spacing $> d/3$
- Low ductility demand, $\lambda / y < 2$ (table 10-6, ASCE 41-17)
 $= 3.9256559E-005$
- Stirrup Spacing $\leq d/2$
 $d = 358.00$
 $s = 150.00$
- Strength provided by hoops $V_s < 3/4 \times \text{design Shear}$
 $V_s = 148933.273$, already given in calculation of shear control ratio
design Shear = 11843.705
- ($\lambda - \lambda'$)/ bal = -0.14721463
 $= A_{sl}/(b_w \times d) = 0.00573326$
Tension Reinf Area: $A_{sl} = 615.7522$
 $\lambda' = A_{slc}/(b_w \times d) = 0.00848289$
Compression Reinf Area: $A_{slc} = 911.0619$
- From (B-1), ACI 318-11: bal = 0.01867766
 $f_c = 20.00$
 $f_y = 444.44$
From 10.2.7.3, ACI 318-11: $\lambda = 0.85$
From fig R10.3.3, ACI 318-11 (Ence 454, too): $87000/(87000 + f_y) = c_b/d_t = 0.003/(0.003 + y) = 0.57447053$
 $y = 0.0022222$
- $V/(b_w \times d \times f_c^{0.5}) = 0.2969556$, NOTE: units in lb & in
 $b_w = 300.00$

End Of Calculation of Chord Rotation Capacity for element: beam B1 of floor 1

At local axis: 2

Integration Section: (b)

Calculation No. 7

beam B1, Floor 1



Limit State: Operational Level (data interpolation between analysis steps 1 and 2)

Analysis: Uniform +X

Check: Shear capacity V_{Rd}

Edge: End

Local Axis: (3)



Start Of Calculation of Shear Capacity for element: beam B1 of floor 1

At local axis: 3

Integration Section: (b)

Section Type: rcars

Constant Properties

Knowledge Factor, $\gamma = 1.00$

Member Shear Force is generally considered as Force-Controlled Action according to Table C7-1, ASCE 41-17.

Lower-bound strengths are used for Force-Controlled Actions according to 7.5.1.3, ASCE 41-17

Consequently:

Existing material of Secondary Member: Concrete Strength, $f_c = f_{c_lower_bound} = 16.00$

Existing material of Secondary Member: Steel Strength, $f_s = f_{s_lower_bound} = 400.00$

Concrete Elasticity, $E_c = 21019.039$

Steel Elasticity, $E_s = 200000.00$

Section Height, $H = 400.00$

Section Width, $W = 300.00$

Cover Thickness, $c = 25.00$

Element Length, $L = 1850.00$

Secondary Member

Ribbed Bars

Ductile Steel

Without Detailing for Earthquake Resistance (including stirrups not closed at 135°)

Longitudinal Bars With Ends Lapped Starting at the End Sections

Inadequate Lap Length with $l_o/l_{o,min} = l_b/l_d = 0.30$

No FRP Wrapping

Stepwise Properties

EDGE -A-

Bending Moment, $M_a = 6.5579E+006$

Shear Force, $V_a = -3588.176$

EDGE -B-

Bending Moment, $M_b = 7.7166E+006$

Shear Force, $V_b = 11843.705$

BOTH EDGES

Axial Force, $F = -1388.628$

Longitudinal Reinforcement Area Distribution (in 2 divisions)

-Tension: $As_{lt} = 615.7522$

-Compression: $As_{lc} = 911.0619$

Longitudinal Reinforcement Area Distribution (in 3 divisions)

-Tension: $As_{l,ten} = 615.7522$

-Compression: $As_{l,com} = 603.1858$

-Middle: $As_{l,mid} = 307.8761$

Mean Diameter of Tension Reinforcement, $Db_{L,ten} = 14.00$

Existing component: From table 7-7, ASCE 41_17: Final Shear Capacity $VR = *V_n = 200622.537$

$V_n ((22.5.1.1), ACI 318-14) = 200622.537$

NOTE: In expression (22.5.1.1) 'Vw' is replaced by 'Vw+ f*Vf' where Vf is the contribution of FRPs (11.3), ACI 440).

From Table (22.5.5.1), ACI 318-14: $V_c = 66581.25$

= 1 (normal-weight concrete)

$f'_c = 16.00$, but $f'_c^{0.5} \leq 8.3$ MPa (22.5.3.1, ACI 318-14)

$\rho_w = A_s / (b_w * d) = 0.00641409$

A_s (tension reinf.) = 615.7522

$b_w = 300.00$

$d = 320.00$

$V_u * d / M_u < 1 = 0.49114971$

$M_u = 7.7166E+006$

$V_u = 11843.705$

From (11.5.4.8), ACI 318-14: $V_s = 134041.287$

$A_v = 157079.633$

$f_y = 400.00$

$s = 150.00$

V_s has been multiplied by 1 ($s < d/2$, according to ASCE 41-17, 10.3.4)

V_f ((11-3)-(11.4), ACI 440) = 0.00

From (11-11), ACI 440: $V_s + V_f \leq 255092.67$

End Of Calculation of Shear Capacity for element: beam B1 of floor 1

At local axis: 3

Integration Section: (b)

Calculation No. 8

beam B1, Floor 1



Limit State: Operational Level (data interpolation between analysis steps 1 and 2)

Analysis: Uniform +X

Check: Chord rotation capacity (μ)

Edge: End

Local Axis: (3)



Start Of Calculation of Shear Capacity ratio for element: beam B1 of floor 1

At Shear local axis: 3

(Bending local axis: 2)

Section Type: rcars

Constant Properties

Knowledge Factor, $\phi = 1.00$

Mean strength values are used for both shear and moment calculations.

Consequently:

Existing material of Secondary Member: Concrete Strength, $f_c = f_{cm} = 20.00$

Existing material of Secondary Member: Steel Strength, $f_s = f_{sm} = 444.44$

Concrete Elasticity, $E_c = 21019.039$

Steel Elasticity, $E_s = 200000.00$

#####

Note: Especially for the calculation of moment strengths,

the above steel re-bar strengths are multiplied by 1.25 according to R18.6.5, ACI 318-14

Existing material: Steel Strength, $f_s = 1.25 \cdot f_{sm} = 555.55$

#####

Section Height, $H = 400.00$

Section Width, $W = 300.00$

Cover Thickness, $c = 25.00$

Mean Confinement Factor overall section = 1.00

Element Length, $L = 1850.00$

Secondary Member

Ribbed Bars

Ductile Steel

Without Detailing for Earthquake Resistance (including stirrups not closed at 135°)

Longitudinal Bars With Ends Lapped Starting at the End Sections

Inadequate Lap Length with $l_o/l_{ou,min} = 0.30$

No FRP Wrapping

Stepwise Properties

At local axis: 3

EDGE -A-

Shear Force, $V_a = 4076.60$

EDGE -B-

Shear Force, $V_b = 4178.928$

BOTH EDGES

Axial Force, $F = -400.0832$

Longitudinal Reinforcement Area Distribution (in 2 divisions)

-Tension: $As_t = 603.1858$

-Compression: $As_c = 923.6282$

Longitudinal Reinforcement Area Distribution (in 3 divisions)

-Tension: $As_{t,ten} = 603.1858$

-Compression: $As_{l,com} = 615.7522$

-Middle: $As_{l,mid} = 307.8761$

Calculation of Shear Capacity ratio, $V_e/V_r = 0.40672566$

Member Controlled by Flexure ($V_e/V_r < 1$)

Calculation of Shear Demand from fig. R18.6.5, ACI 318-14 $V_e = (M_{pr1} + M_{pr2})/l_n \pm w_u \cdot l_n/2 = 92684.415$

with $M_{pr1} = \max(\mu_{u1+}, \mu_{u1-}) = 8.1957E+007$

$\mu_{u1+} = 8.0451E+007$, is the ultimate moment strength at the edge 1 of the member in the actual moment direction which is defined for the static loading combination

$\mu_{u1-} = 8.1957E+007$, is the ultimate moment strength at the edge 1 of the member in the opposite moment direction which is defined for the static loading combination

$M_{pr2} = \max(\mu_{u2+}, \mu_{u2-}) = 8.1873E+007$

$\mu_{u2+} = 8.0533E+007$, is the ultimate moment strength at the edge 2 of the member in the actual moment direction which is defined for the the static loading combination

$\mu_{u2-} = 8.1873E+007$, is the ultimate moment strength at the edge 2 of the member in the opposite moment direction which is defined for the the static loading combination

and

$\pm w_u \cdot l_n = (|V_1| + |V_2|)/2$

with

V1 = 4076.60, is the shear force acting at edge 1 for the the static loading combination
V2 = 4178.928, is the shear force acting at edge 2 for the the static loading combination

Calculation of Mu1+

Calculation of ultimate curvature ϕ_u according to 4.1, Biskinis/Fardis 2013:

$$\phi_u = 1.7899831E-005$$

$$M_u = 8.0451E+007$$

with full section properties:

$$b = 300.00$$

$$d = 357.00$$

$$d' = 42.00$$

$$\nu = 0.00018678$$

$$N = 400.0832$$

$$f_c = 20.00$$

$$\phi_{co} (5A.5, TBDY) = 0.002$$

$$\text{Final value of } \phi_{cu}: \phi_{cu}^* = \text{shear_factor} * \text{Max}(\phi_{cu}, \phi_{co}) = 0.00583896$$

The Shear_factor is considered equal to 1 (pure moment strength)

$$\text{From (5.4b), TBDY: } \phi_{cu} = 0.00583896$$

$$\phi_{we} (5.4c) = 0.0034192$$

$$\phi_{ase} ((5.4d), TBDY) = 0.15672608$$

$$b_o = 240.00$$

$$h_o = 340.00$$

$$b_{i2} = 346400.00$$

$$\phi_{psh,min} = \text{Min}(\phi_{psh,x}, \phi_{psh,y}) = 0.00261799$$

Expression ((5.4d), TBDY) for $\phi_{psh,min}$ has been multiplied by 0.3 according to 15.7.1.3 for members without earthquake detailing (90° closed stirrups)

$$\phi_{psh,x} (5.4d) = 0.00349066$$

$$A_{sh} = A_{stir} * n_s = 78.53982$$

$$\text{No stirrups, } n_s = 2.00$$

$$b_k = 300.00$$

$$\phi_{psh,y} (5.4d) = 0.00261799$$

$$A_{sh} = A_{stir} * n_s = 78.53982$$

$$\text{No stirrups, } n_s = 2.00$$

$$b_k = 400.00$$

$$s = 150.00$$

$$f_{ywe} = 555.55$$

$$f_{ce} = 20.00$$

$$\text{From ((5.A5), TBDY), TBDY: } \phi_{cc} = 0.002$$

$$\phi_c = \text{confinement factor} = 1.00$$

$$y_1 = 0.00129669$$

$$sh_1 = 0.0044814$$

$$ft_1 = 373.4467$$

$$fy_1 = 311.2056$$

$$su_1 = 0.00512$$

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00

$$l_o/l_{ou,min} = l_b/l_d = 0.30$$

$$su_1 = 0.4 * \phi_{su1,nominal} ((5.5), TBDY) = 0.032$$

$$\text{From table 5A.1, TBDY: } \phi_{su1,nominal} = 0.08,$$

For calculation of $\phi_{su1,nominal}$ and y_1, sh_1, ft_1, fy_1 , it is considered
characteristic value $fsy_1 = fs_1/1.2$, from table 5.1, TBDY.

y_1, sh_1, ft_1, fy_1 , are also multiplied by $\text{Min}(1, 1.25 * (l_b/l_d)^{2/3})$, from 10.3.5, ASCE 41-17.

$$\text{with } fs_1 = fs = 311.2056$$

$$\text{with } E_{s1} = E_s = 200000.00$$

$$y_2 = 0.00129669$$

$$sh_2 = 0.0044814$$

$$ft_2 = 373.4467$$

$$fy_2 = 311.2056$$

```

su2 = 0.00512
using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00
lo/lou,min = lb/lb,min = 0.30
su2 = 0.4*esu2_nominal ((5.5), TBDY) = 0.032
From table 5A.1, TBDY: esu2_nominal = 0.08,
For calculation of esu2_nominal and y2, sh2,ft2,fy2, it is considered
characteristic value fsy2 = fs2/1.2, from table 5.1, TBDY.
y1, sh1,ft1,fy1, are also multiplied by Min(1,1.25*(lb/ld)^ 2/3), from 10.3.5, ASCE 41-17.
with fs2 = fs = 311.2056
with Es2 = Es = 200000.00
yv = 0.00129669
shv = 0.0044814
ftv = 373.4467
fyv = 311.2056
suv = 0.00512
using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00
lo/lou,min = lb/ld = 0.30
suv = 0.4*esuv_nominal ((5.5), TBDY) = 0.032
From table 5A.1, TBDY: esuv_nominal = 0.08,
considering characteristic value fsyv = fsv/1.2, from table 5.1, TBDY
For calculation of esuv_nominal and yv, shv,ftv,fyv, it is considered
characteristic value fsyv = fsv/1.2, from table 5.1, TBDY.
y1, sh1,ft1,fy1, are also multiplied by Min(1,1.25*(lb/ld)^ 2/3), from 10.3.5, ASCE 41-17.
with fsv = fs = 311.2056
with Esv = Es = 200000.00
1 = Asl,ten/(b*d)*(fs1/fc) = 0.08763528
2 = Asl,com/(b*d)*(fs2/fc) = 0.08946101
v = Asl,mid/(b*d)*(fsv/fc) = 0.04473051
and confined core properties:
b = 240.00
d = 327.00
d' = 12.00
fcc (5A.2, TBDY) = 20.00
cc (5A.5, TBDY) = 0.002
c = confinement factor = 1.00
1 = Asl,ten/(b*d)*(fs1/fc) = 0.11959401
2 = Asl,com/(b*d)*(fs2/fc) = 0.12208556
v = Asl,mid/(b*d)*(fsv/fc) = 0.06104278
Case/Assumption: Unconfined full section - Steel rupture
' satisfies Eq. (4.3)
--->
v < vs,y2 - LHS eq.(4.5) is satisfied
--->
su (4.9) = 0.19877808
Mu = MRc (4.14) = 8.0451E+007
u = su (4.1) = 1.7899831E-005

```

Calculation of ratio lb/ld

Inadequate Lap Length with lb/ld = 0.30

Calculation of Mu1-

Calculation of ultimate curvature u according to 4.1, Biskinis/Fardis 2013:

u = 1.7901443E-005
Mu = 8.1957E+007

with full section properties:

$b = 300.00$
 $d = 358.00$
 $d' = 43.00$
 $v = 0.00018626$
 $N = 400.0832$
 $fc = 20.00$
 $co(5A.5, TBDY) = 0.002$
 Final value of cu : $cu^* = shear_factor * Max(cu, cc) = 0.00583896$
 The Shear_factor is considered equal to 1 (pure moment strength)
 From (5.4b), TBDY: $cu = 0.00583896$
 $we(5.4c) = 0.0034192$
 $ase((5.4d), TBDY) = 0.15672608$
 $bo = 240.00$
 $ho = 340.00$
 $bi2 = 346400.00$
 $psh,min = Min(psh,x, psh,y) = 0.00261799$
 Expression ((5.4d), TBDY) for psh,min has been multiplied by 0.3 according to 15.7.1.3 for members without earthquake detailing (90° closed stirrups)

$psh,x(5.4d) = 0.00349066$
 $Ash = Astir * ns = 78.53982$
 No stirrups, $ns = 2.00$
 $bk = 300.00$

$psh,y(5.4d) = 0.00261799$
 $Ash = Astir * ns = 78.53982$
 No stirrups, $ns = 2.00$
 $bk = 400.00$

$s = 150.00$
 $fywe = 555.55$
 $fce = 20.00$
 From ((5.A5), TBDY), TBDY: $cc = 0.002$
 $c = confinement\ factor = 1.00$
 $y1 = 0.00129669$
 $sh1 = 0.0044814$
 $ft1 = 373.4467$
 $fy1 = 311.2056$
 $su1 = 0.00512$
 using (30) in Biskinis/Fardis (2013) multiplied with shear_factor and also multiplied by the shear_factor according to 15.7.1.4, with Shear_factor = 1.00
 $lo/lou,min = lb/d = 0.30$
 $su1 = 0.4 * esu1_nominal((5.5), TBDY) = 0.032$
 From table 5A.1, TBDY: $esu1_nominal = 0.08$,
 For calculation of $esu1_nominal$ and $y1, sh1, ft1, fy1$, it is considered characteristic value $fsy1 = fs1/1.2$, from table 5.1, TBDY.
 $y1, sh1, ft1, fy1$, are also multiplied by $Min(1, 1.25 * (lb/d)^{2/3})$, from 10.3.5, ASCE 41-17.
 with $fs1 = fs = 311.2056$
 with $Es1 = Es = 200000.00$
 $y2 = 0.00129669$
 $sh2 = 0.0044814$
 $ft2 = 373.4467$
 $fy2 = 311.2056$
 $su2 = 0.00512$
 using (30) in Biskinis/Fardis (2013) multiplied with shear_factor and also multiplied by the shear_factor according to 15.7.1.4, with Shear_factor = 1.00
 $lo/lou,min = lb/lb,min = 0.30$
 $su2 = 0.4 * esu2_nominal((5.5), TBDY) = 0.032$
 From table 5A.1, TBDY: $esu2_nominal = 0.08$,
 For calculation of $esu2_nominal$ and $y2, sh2, ft2, fy2$, it is considered characteristic value $fsy2 = fs2/1.2$, from table 5.1, TBDY.
 $y1, sh1, ft1, fy1$, are also multiplied by $Min(1, 1.25 * (lb/d)^{2/3})$, from 10.3.5, ASCE 41-17.
 with $fs2 = fs = 311.2056$
 with $Es2 = Es = 200000.00$
 $yv = 0.00129669$

```

shv = 0.0044814
ftv = 373.4467
fyv = 311.2056
suv = 0.00512
    using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
    and also multiplied by the shear_factor according to 15.7.1.4, with
    Shear_factor = 1.00
    lo/lo,min = lb/ld = 0.30
    suv = 0.4*esuv_nominal ((5.5), TBDY) = 0.032
    From table 5A.1, TBDY: esuv_nominal = 0.08,
    considering characteristic value fsyv = fsv/1.2, from table 5.1, TBDY
    For calculation of esuv_nominal and yv, shv,ftv,fyv, it is considered
    characteristic value fsyv = fsv/1.2, from table 5.1, TBDY.
    y1, sh1,ft1,fy1, are also multiplied by Min(1,1.25*(lb/ld)^ 2/3), from 10.3.5, ASCE 41-17.
    with fsv = fs = 311.2056
    with Esv = Es = 200000.00
    1 = Asl,ten/(b*d)*(fs1/fc) = 0.08921112
    2 = Asl,com/(b*d)*(fs2/fc) = 0.08739049
    v = Asl,mid/(b*d)*(fsv/fc) = 0.04460556
and confined core properties:
b = 240.00
d = 328.00
d' = 13.00
fcc (5A.2, TBDY) = 20.00
cc (5A.5, TBDY) = 0.002
    c = confinement factor = 1.00
    1 = Asl,ten/(b*d)*(fs1/fc) = 0.12171334
    2 = Asl,com/(b*d)*(fs2/fc) = 0.1192294
    v = Asl,mid/(b*d)*(fsv/fc) = 0.06085667
Case/Assumption: Unconfined full section - Steel rupture
' satisfies Eq. (4.3)
--->
v < vs,y2 - LHS eq.(4.5) is satisfied
--->
su (4.9) = 0.20108809
Mu = MRc (4.14) = 8.1957E+007
u = su (4.1) = 1.7901443E-005
-----

```

Calculation of ratio lb/ld

Inadequate Lap Length with lb/ld = 0.30

Calculation of Mu2+

Calculation of ultimate curvature u according to 4.1, Biskinis/Fardis 2013:

```

u = 1.7862388E-005
Mu = 8.0533E+007
-----

```

with full section properties:

```

b = 300.00
d = 358.00
d' = 43.00
v = 0.00018626
N = 400.0832
fc = 20.00
co (5A.5, TBDY) = 0.002
Final value of cu: cu* = shear_factor * Max( cu, cc) = 0.00583896
The Shear_factor is considered equal to 1 (pure moment strength)
From (5.4b), TBDY: cu = 0.00583896
we (5.4c) = 0.0034192
ase ((5.4d), TBDY) = 0.15672608
bo = 240.00

```

$h_o = 340.00$
 $bi2 = 346400.00$
 $psh,min = \text{Min}(psh,x, psh,y) = 0.00261799$
 Expression ((5.4d), TBDY) for psh,min has been multiplied by 0.3 according to 15.7.1.3 for members without earthquake detailing (90° closed stirrups)

$psh,x (5.4d) = 0.00349066$
 $Ash = Astir*ns = 78.53982$
 No stirrups, $ns = 2.00$
 $bk = 300.00$

$psh,y (5.4d) = 0.00261799$
 $Ash = Astir*ns = 78.53982$
 No stirrups, $ns = 2.00$
 $bk = 400.00$

$s = 150.00$
 $fywe = 555.55$
 $fce = 20.00$
 From ((5.A5), TBDY), TBDY: $cc = 0.002$
 $c = \text{confinement factor} = 1.00$
 $y1 = 0.00129669$
 $sh1 = 0.0044814$
 $ft1 = 373.4467$
 $fy1 = 311.2056$
 $su1 = 0.00512$
 using (30) in Biskinis/Fardis (2013) multiplied with shear_factor and also multiplied by the shear_factor according to 15.7.1.4, with Shear_factor = 1.00
 $lo/lou,min = lb/ld = 0.30$
 $su1 = 0.4*esu1_nominal ((5.5), TBDY) = 0.032$
 From table 5A.1, TBDY: $esu1_nominal = 0.08$,
 For calculation of $esu1_nominal$ and $y1, sh1, ft1, fy1$, it is considered characteristic value $fsy1 = fs/1.2$, from table 5.1, TBDY.
 $y1, sh1, ft1, fy1$, are also multiplied by $\text{Min}(1, 1.25*(lb/ld)^{2/3})$, from 10.3.5, ASCE 41-17.
 with $fs1 = fs = 311.2056$
 with $Es1 = Es = 200000.00$
 $y2 = 0.00129669$
 $sh2 = 0.0044814$
 $ft2 = 373.4467$
 $fy2 = 311.2056$
 $su2 = 0.00512$
 using (30) in Biskinis/Fardis (2013) multiplied with shear_factor and also multiplied by the shear_factor according to 15.7.1.4, with Shear_factor = 1.00
 $lo/lou,min = lb/lb,min = 0.30$
 $su2 = 0.4*esu2_nominal ((5.5), TBDY) = 0.032$
 From table 5A.1, TBDY: $esu2_nominal = 0.08$,
 For calculation of $esu2_nominal$ and $y2, sh2, ft2, fy2$, it is considered characteristic value $fsy2 = fs/1.2$, from table 5.1, TBDY.
 $y1, sh1, ft1, fy1$, are also multiplied by $\text{Min}(1, 1.25*(lb/ld)^{2/3})$, from 10.3.5, ASCE 41-17.
 with $fs2 = fs = 311.2056$
 with $Es2 = Es = 200000.00$
 $yv = 0.00129669$
 $shv = 0.0044814$
 $ftv = 373.4467$
 $fyv = 311.2056$
 $suv = 0.00512$
 using (30) in Biskinis/Fardis (2013) multiplied with shear_factor and also multiplied by the shear_factor according to 15.7.1.4, with Shear_factor = 1.00
 $lo/lou,min = lb/ld = 0.30$
 $suv = 0.4*esuv_nominal ((5.5), TBDY) = 0.032$
 From table 5A.1, TBDY: $esuv_nominal = 0.08$,
 considering characteristic value $fsyv = fsv/1.2$, from table 5.1, TBDY
 For calculation of $esuv_nominal$ and yv, shv, ftv, fyv , it is considered characteristic value $fsyv = fsv/1.2$, from table 5.1, TBDY.

$y1, sh1, ft1, fy1$, are also multiplied by $\text{Min}(1, 1.25 \cdot (lb/d)^{2/3})$, from 10.3.5, ASCE 41-17.
 with $fsv = fs = 311.2056$
 with $Esv = Es = 200000.00$
 $1 = Asl,ten/(b \cdot d) \cdot (fs1/fc) = 0.08739049$
 $2 = Asl,com/(b \cdot d) \cdot (fs2/fc) = 0.08921112$
 $v = Asl,mid/(b \cdot d) \cdot (fsv/fc) = 0.04460556$
 and confined core properties:
 $b = 240.00$
 $d = 328.00$
 $d' = 13.00$
 $fcc (5A.2, TBDY) = 20.00$
 $cc (5A.5, TBDY) = 0.002$
 $c = \text{confinement factor} = 1.00$
 $1 = Asl,ten/(b \cdot d) \cdot (fs1/fc) = 0.1192294$
 $2 = Asl,com/(b \cdot d) \cdot (fs2/fc) = 0.12171334$
 $v = Asl,mid/(b \cdot d) \cdot (fsv/fc) = 0.06085667$
 Case/Assumption: Unconfined full section - Steel rupture
 ' satisfies Eq. (4.3)
 --->
 $v < vs,y2$ - LHS eq.(4.5) is satisfied
 --->
 $su (4.9) = 0.19934131$
 $Mu = MRc (4.14) = 8.0533E+007$
 $u = su (4.1) = 1.7862388E-005$

 Calculation of ratio lb/d

 Inadequate Lap Length with $lb/d = 0.30$

 Calculation of $Mu2$ -

 Calculation of ultimate curvature u according to 4.1, Biskinis/Fardis 2013:
 $u = 1.7939215E-005$
 $Mu = 8.1873E+007$

 with full section properties:
 $b = 300.00$
 $d = 357.00$
 $d' = 42.00$
 $v = 0.00018678$
 $N = 400.0832$
 $fc = 20.00$
 $co (5A.5, TBDY) = 0.002$
 Final value of cu : $cu^* = \text{shear_factor} \cdot \text{Max}(cu, cc) = 0.00583896$
 The Shear_factor is considered equal to 1 (pure moment strength)
 From (5.4b), TBDY: $cu = 0.00583896$
 $we (5.4c) = 0.0034192$
 $ase ((5.4d), TBDY) = 0.15672608$
 $bo = 240.00$
 $ho = 340.00$
 $bi2 = 346400.00$
 $psh,min = \text{Min}(psh,x, psh,y) = 0.00261799$
 Expression ((5.4d), TBDY) for psh,min has been multiplied by 0.3 according to 15.7.1.3 for members without
 earthquake detailing (90° closed stirrups)

 $psh,x (5.4d) = 0.00349066$
 $Ash = Astir \cdot ns = 78.53982$
 No stirrups, $ns = 2.00$
 $bk = 300.00$

 $psh,y (5.4d) = 0.00261799$
 $Ash = Astir \cdot ns = 78.53982$

No stirrups, ns = 2.00
bk = 400.00

s = 150.00
fywe = 555.55
fce = 20.00

From ((5A.5), TBDY), TBDY: cc = 0.002
c = confinement factor = 1.00

y1 = 0.00129669
sh1 = 0.0044814
ft1 = 373.4467
fy1 = 311.2056
su1 = 0.00512

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00

lo/lou,min = lb/lb = 0.30

su1 = 0.4*esu1_nominal ((5.5), TBDY) = 0.032

From table 5A.1, TBDY: esu1_nominal = 0.08,

For calculation of esu1_nominal and y1, sh1,ft1,fy1, it is considered
characteristic value fsy1 = fs1/1.2, from table 5.1, TBDY.

y1, sh1,ft1,fy1, are also multiplied by $\text{Min}(1, 1.25 \cdot (lb/lb)^{2/3})$, from 10.3.5, ASCE 41-17.

with fs1 = fs = 311.2056

with Es1 = Es = 200000.00

y2 = 0.00129669
sh2 = 0.0044814
ft2 = 373.4467
fy2 = 311.2056
su2 = 0.00512

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00

lo/lou,min = lb/lb,min = 0.30

su2 = 0.4*esu2_nominal ((5.5), TBDY) = 0.032

From table 5A.1, TBDY: esu2_nominal = 0.08,

For calculation of esu2_nominal and y2, sh2,ft2,fy2, it is considered
characteristic value fsy2 = fs2/1.2, from table 5.1, TBDY.

y1, sh1,ft1,fy1, are also multiplied by $\text{Min}(1, 1.25 \cdot (lb/lb)^{2/3})$, from 10.3.5, ASCE 41-17.

with fs2 = fs = 311.2056

with Es2 = Es = 200000.00

yv = 0.00129669
shv = 0.0044814
ftv = 373.4467
fyv = 311.2056
suv = 0.00512

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00

lo/lou,min = lb/lb = 0.30

suv = 0.4*esuv_nominal ((5.5), TBDY) = 0.032

From table 5A.1, TBDY: esuv_nominal = 0.08,

considering characteristic value fsyv = fsv/1.2, from table 5.1, TBDY

For calculation of esuv_nominal and yv, shv,ftv,fyv, it is considered
characteristic value fsyv = fsv/1.2, from table 5.1, TBDY.

y1, sh1,ft1,fy1, are also multiplied by $\text{Min}(1, 1.25 \cdot (lb/lb)^{2/3})$, from 10.3.5, ASCE 41-17.

with fsv = fs = 311.2056

with Esv = Es = 200000.00

1 = Asl,ten/(b*d)*(fs1/fc) = 0.08946101

2 = Asl,com/(b*d)*(fs2/fc) = 0.08763528

v = Asl,mid/(b*d)*(fsv/fc) = 0.04473051

and confined core properties:

b = 240.00
d = 327.00
d' = 12.00

fcc (5A.2, TBDY) = 20.00

cc (5A.5, TBDY) = 0.002

c = confinement factor = 1.00

$$1 = A_{sl,ten}/(b*d)*(f_{s1}/f_c) = 0.12208556$$

$$2 = A_{sl,com}/(b*d)*(f_{s2}/f_c) = 0.11959401$$

$$v = A_{sl,mid}/(b*d)*(f_{sv}/f_c) = 0.06104278$$

Case/Assumption: Unconfined full section - Steel rupture
' satisfies Eq. (4.3)

--->

$v < v_{s,y2}$ - LHS eq.(4.5) is satisfied

--->

$$s_u(4.9) = 0.20053711$$

$$M_u = M_{Rc}(4.14) = 8.1873E+007$$

$$u = s_u(4.1) = 1.7939215E-005$$

Calculation of ratio l_b/l_d

Inadequate Lap Length with $l_b/l_d = 0.30$

Calculation of Shear Strength $V_r = \min(V_{r1}, V_{r2}) = 227879.44$

Calculation of Shear Strength at edge 1, $V_{r1} = 227879.44$

$V_{r1} = V_n((22.5.1.1), \text{ACI 318-14})$

NOTE: In expression (22.5.1.1) 'Vw' is replaced by 'Vw+ f*Vf'
where Vf is the contribution of FRPs (11.3), ACI 440).

From Table (22.5.5.1), ACI 318-14: $V_c = 78946.167$

= 1 (normal-weight concrete)

$f_c' = 20.00$, but $f_c'^{0.5} \leq 8.3 \text{ MPa}$ (22.5.3.1, ACI 318-14)

$p_w = A_s/(b_w*d) = 0.00628319$

A_s (tension reinf.) = 603.1858

$b_w = 300.00$

$d = 320.00$

$V_u*d/M_u < 1 = 1.00$

$M_u = 60442.822$

$V_u = 4076.60$

From (11.5.4.8), ACI 318-14: $V_s = 148933.273$

$A_v = 157079.633$

$f_y = 444.44$

$s = 150.00$

V_s has been multiplied by 1 ($s < d/2$, according to ASCE 41-17,10.3.4)

$V_f((11-3)-(11.4), \text{ACI 440}) = 0.00$

From (11-11), ACI 440: $V_s + V_f \leq 285202.276$

Calculation of Shear Strength at edge 2, $V_{r2} = 227879.44$

$V_{r2} = V_n((22.5.1.1), \text{ACI 318-14})$

NOTE: In expression (22.5.1.1) 'Vw' is replaced by 'Vw+ f*Vf'
where Vf is the contribution of FRPs (11.3), ACI 440).

From Table (22.5.5.1), ACI 318-14: $V_c = 78946.167$

= 1 (normal-weight concrete)

$f_c' = 20.00$, but $f_c'^{0.5} \leq 8.3 \text{ MPa}$ (22.5.3.1, ACI 318-14)

$p_w = A_s/(b_w*d) = 0.00628319$

A_s (tension reinf.) = 603.1858

$b_w = 300.00$

$d = 320.00$

$V_u*d/M_u < 1 = 1.00$

$M_u = 155096.693$

$V_u = 4178.928$

From (11.5.4.8), ACI 318-14: $V_s = 148933.273$

$A_v = 157079.633$

$f_y = 444.44$

$s = 150.00$

V_s has been multiplied by 1 ($s < d/2$, according to ASCE 41-17,10.3.4)

Vf ((11-3)-(11.4), ACI 440) = 0.00
From (11-11), ACI 440: Vs + Vf <= 285202.276

End Of Calculation of Shear Capacity ratio for element: beam B1 of floor 1
At local axis: 3

Start Of Calculation of Shear Capacity ratio for element: beam B1 of floor 1
At Shear local axis: 2
(Bending local axis: 3)
Section Type: rcars

Constant Properties

Knowledge Factor, = 1.00
Mean strength values are used for both shear and moment calculations.
Consequently:
Existing material of Secondary Member: Concrete Strength, fc = fcm = 20.00
Existing material of Secondary Member: Steel Strength, fs = fsm = 444.44
Concrete Elasticity, Ec = 21019.039
Steel Elasticity, Es = 200000.00

Note: Especially for the calculation of moment strengths,
the above steel re-bar strengths are multiplied by 1.25 according to R18.6.5, ACI 318-14
Existing material: Steel Strength, fs = 1.25*fsm = 555.55

Section Height, H = 400.00
Section Width, W = 300.00
Cover Thickness, c = 25.00
Mean Confinement Factor overall section = 1.00
Element Length, L = 1850.00
Secondary Member
Ribbed Bars
Ductile Steel
Without Detailing for Earthquake Resistance (including stirrups not closed at 135°)
Longitudinal Bars With Ends Lapped Starting at the End Sections
Inadequate Lap Length with lo/lo,min = 0.30
No FRP Wrapping

Stepwise Properties

At local axis: 2
EDGE -A-
Shear Force, Va = -1.0090939E-010
EDGE -B-
Shear Force, Vb = 1.0090939E-010
BOTH EDGES
Axial Force, F = -400.0832
Longitudinal Reinforcement Area Distribution (in 2 divisions)
-Tension: Aslt = 603.1858
-Compression: Aslc = 923.6282
Longitudinal Reinforcement Area Distribution (in 3 divisions)
-Tension: Asl,ten = 508.938
-Compression: Asl,com = 508.938
-Middle: Asl,mid = 508.938

Calculation of Shear Capacity ratio , Ve/Vr = 0.37923485
Member Controlled by Flexure (Ve/Vr < 1)
Calculation of Shear Demand from fig. R18.6.5, ACI 318-14 Ve = (Mpr1 + Mpr2)/ln ± wu*ln/2 = 57820.79
with
Mpr1 = Max(Mu1+ , Mu1-) = 5.3484E+007

Mu1+ = 5.3484E+007, is the ultimate moment strength at the edge 1 of the member in the actual moment direction which is defined for the static loading combination

Mu1- = 5.3484E+007, is the ultimate moment strength at the edge 1 of the member in the opposite moment direction which is defined for the static loading combination

Mpr2 = Max(Mu2+ , Mu2-) = 5.3484E+007

Mu2+ = 5.3484E+007, is the ultimate moment strength at the edge 2 of the member in the actual moment direction which is defined for the the static loading combination

Mu2- = 5.3484E+007, is the ultimate moment strength at the edge 2 of the member in the opposite moment direction which is defined for the the static loading combination

and

$\pm v_u \cdot l_n = (|V1| + |V2|)/2$

with

V1 = -1.0090939E-010, is the shear force acting at edge 1 for the the static loading combination

V2 = 1.0090939E-010, is the shear force acting at edge 2 for the the static loading combination

Calculation of Mu1+

Calculation of ultimate curvature ϕ_u according to 4.1, Biskinis/Fardis 2013:

$\phi_u = 2.5364147E-005$

$M_u = 5.3484E+007$

with full section properties:

b = 400.00

d = 258.00

d' = 42.00

$\nu = 0.00019384$

N = 400.0832

$f_{ck} = 20.00$

$\alpha_{cc} (5A.5, TBDY) = 0.002$

Final value of ϕ_u : $\phi_u^* = \text{shear_factor} * \text{Max}(\phi_u, \phi_{cc}) = 0.00583896$

The Shear_factor is considered equal to 1 (pure moment strength)

From (5.4b), TBDY: $\phi_u = 0.00583896$

$\phi_{we} (5.4c) = 0.0034192$

$\phi_{ase} ((5.4d), TBDY) = 0.15672608$

$b_o = 240.00$

$h_o = 340.00$

$b_i^2 = 346400.00$

$\phi_{sh,min} = \text{Min}(\phi_{sh,x}, \phi_{sh,y}) = 0.00261799$

Expression ((5.4d), TBDY) for $\phi_{sh,min}$ has been multiplied by 0.3 according to 15.7.1.3 for members without earthquake detailing (90° closed stirrups)

 $\phi_{sh,x} (5.4d) = 0.00349066$

$A_{sh} = A_{stir} * n_s = 78.53982$

No stirrups, $n_s = 2.00$

$b_k = 300.00$

$\phi_{sh,y} (5.4d) = 0.00261799$

$A_{sh} = A_{stir} * n_s = 78.53982$

No stirrups, $n_s = 2.00$

$b_k = 400.00$

s = 150.00

$f_{ywe} = 555.55$

$f_{cke} = 20.00$

From ((5.A5), TBDY), TBDY: $\phi_{cc} = 0.002$

c = confinement factor = 1.00

$\gamma_1 = 0.00129669$

$\gamma_{sh1} = 0.0044814$

$f_{t1} = 373.4467$

$f_{y1} = 311.2056$

$\gamma_{su1} = 0.00512$

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor

and also multiplied by the shear_factor according to 15.7.1.4, with

Shear_factor = 1.00

```

lo/lou,min = lb/d = 0.30
su1 = 0.4*esu1_nominal ((5.5), TBDY) = 0.032
From table 5A.1, TBDY: esu1_nominal = 0.08,
For calculation of esu1_nominal and y1, sh1,ft1,fy1, it is considered
characteristic value fsy1 = fs1/1.2, from table 5.1, TBDY.
y1, sh1,ft1,fy1, are also multiplied by Min(1,1.25*(lb/d)^ 2/3), from 10.3.5, ASCE 41-17.
with fs1 = fs = 311.2056
with Es1 = Es = 200000.00
y2 = 0.00129669
sh2 = 0.0044814
ft2 = 373.4467
fy2 = 311.2056
su2 = 0.00512
using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00
lo/lou,min = lb/lb,min = 0.30
su2 = 0.4*esu2_nominal ((5.5), TBDY) = 0.032
From table 5A.1, TBDY: esu2_nominal = 0.08,
For calculation of esu2_nominal and y2, sh2,ft2,fy2, it is considered
characteristic value fsy2 = fs2/1.2, from table 5.1, TBDY.
y1, sh1,ft1,fy1, are also multiplied by Min(1,1.25*(lb/d)^ 2/3), from 10.3.5, ASCE 41-17.
with fs2 = fs = 311.2056
with Es2 = Es = 200000.00
yv = 0.00129669
shv = 0.0044814
ftv = 373.4467
fyv = 311.2056
suv = 0.00512
using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00
lo/lou,min = lb/d = 0.30
suv = 0.4*esuv_nominal ((5.5), TBDY) = 0.032
From table 5A.1, TBDY: esuv_nominal = 0.08,
considering characteristic value fsyv = fsv/1.2, from table 5.1, TBDY
For calculation of esuv_nominal and yv, shv,ftv,fyv, it is considered
characteristic value fsyv = fsv/1.2, from table 5.1, TBDY.
y1, sh1,ft1,fy1, are also multiplied by Min(1,1.25*(lb/d)^ 2/3), from 10.3.5, ASCE 41-17.
with fsv = fs = 311.2056
with Esv = Es = 200000.00
1 = Asl,ten/(b*d)*(fs1/fc) = 0.0767366
2 = Asl,com/(b*d)*(fs2/fc) = 0.0767366
v = Asl,mid/(b*d)*(fsv/fc) = 0.0767366
and confined core properties:
b = 340.00
d = 228.00
d' = 12.00
fcc (5A.2, TBDY) = 20.00
cc (5A.5, TBDY) = 0.002
c = confinement factor = 1.00
1 = Asl,ten/(b*d)*(fs1/fc) = 0.10215708
2 = Asl,com/(b*d)*(fs2/fc) = 0.10215708
v = Asl,mid/(b*d)*(fsv/fc) = 0.10215708
Case/Assumption: Unconfined full section - Steel rupture
' satisfies Eq. (4.3)
--->
v < vs,y2 - LHS eq.(4.5) is satisfied
--->
su (4.9) = 0.21759794
Mu = MRc (4.14) = 5.3484E+007
u = su (4.1) = 2.5364147E-005

```

Calculation of ratio lb/d

Inadequate Lap Length with lb/d = 0.30

Calculation of Mu1-

Calculation of ultimate curvature ϕ_u according to 4.1, Biskinis/Fardis 2013:

$$\phi_u = 2.5364147E-005$$

$$M_u = 5.3484E+007$$

with full section properties:

$$b = 400.00$$

$$d = 258.00$$

$$d' = 42.00$$

$$\nu = 0.00019384$$

$$N = 400.0832$$

$$f_c = 20.00$$

$$\phi_{co} (5A.5, \text{TB DY}) = 0.002$$

$$\text{Final value of } \phi_{cu}: \phi_{cu}^* = \text{shear_factor} * \text{Max}(\phi_{cu}, \phi_{co}) = 0.00583896$$

The Shear_factor is considered equal to 1 (pure moment strength)

$$\text{From (5.4b), TB DY: } \phi_{cu} = 0.00583896$$

$$\phi_{we} (5.4c) = 0.0034192$$

$$\phi_{ase} ((5.4d), \text{TB DY}) = 0.15672608$$

$$b_o = 240.00$$

$$h_o = 340.00$$

$$b_{i2} = 346400.00$$

$$\phi_{psh,min} = \text{Min}(\phi_{psh,x}, \phi_{psh,y}) = 0.00261799$$

Expression ((5.4d), TB DY) for $\phi_{psh,min}$ has been multiplied by 0.3 according to 15.7.1.3 for members without earthquake detailing (90° closed stirrups)

$$\phi_{psh,x} (5.4d) = 0.00349066$$

$$A_{sh} = A_{stir} * n_s = 78.53982$$

$$\text{No stirrups, } n_s = 2.00$$

$$b_k = 300.00$$

$$\phi_{psh,y} (5.4d) = 0.00261799$$

$$A_{sh} = A_{stir} * n_s = 78.53982$$

$$\text{No stirrups, } n_s = 2.00$$

$$b_k = 400.00$$

$$s = 150.00$$

$$f_{ywe} = 555.55$$

$$f_{ce} = 20.00$$

$$\text{From ((5.A5), TB DY), TB DY: } \phi_{cc} = 0.002$$

$$\phi_c = \text{confinement factor} = 1.00$$

$$y_1 = 0.00129669$$

$$sh_1 = 0.0044814$$

$$f_{t1} = 373.4467$$

$$f_{y1} = 311.2056$$

$$su_1 = 0.00512$$

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00

$$l_o/l_{ou,min} = l_b/l_d = 0.30$$

$$su_1 = 0.4 * \phi_{su1_nominal} ((5.5), \text{TB DY}) = 0.032$$

$$\text{From table 5A.1, TB DY: } \phi_{su1_nominal} = 0.08,$$

For calculation of $\phi_{su1_nominal}$ and $y_1, sh_1, f_{t1}, f_{y1}$, it is considered
characteristic value $f_{sy1} = f_{s1}/1.2$, from table 5.1, TB DY.

$y_1, sh_1, f_{t1}, f_{y1}$, are also multiplied by $\text{Min}(1, 1.25 * (l_b/l_d)^{2/3})$, from 10.3.5, ASCE 41-17.

$$\text{with } f_{s1} = f_s = 311.2056$$

$$\text{with } E_{s1} = E_s = 200000.00$$

$$y_2 = 0.00129669$$

$$sh_2 = 0.0044814$$

$$f_{t2} = 373.4467$$

$$f_{y2} = 311.2056$$

$$su_2 = 0.00512$$

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00
 $l_o/l_{ou,min} = l_b/l_{b,min} = 0.30$
 $su_2 = 0.4 * esu_{2,nominal} ((5.5), TBDY) = 0.032$
From table 5A.1, TBDY: $esu_{2,nominal} = 0.08$,
For calculation of $esu_{2,nominal}$ and y_2, sh_2, ft_2, fy_2 , it is considered
characteristic value $fsy_2 = fs_2/1.2$, from table 5.1, TBDY.
 y_1, sh_1, ft_1, fy_1 , are also multiplied by $Min(1, 1.25 * (l_b/l_d)^{2/3})$, from 10.3.5, ASCE 41-17.
with $fs_2 = fs = 311.2056$
with $Es_2 = Es = 200000.00$
 $y_v = 0.00129669$
 $sh_v = 0.0044814$
 $ft_v = 373.4467$
 $fy_v = 311.2056$
 $suv = 0.00512$
using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00
 $l_o/l_{ou,min} = l_b/l_d = 0.30$
 $suv = 0.4 * esuv_{nominal} ((5.5), TBDY) = 0.032$
From table 5A.1, TBDY: $esuv_{nominal} = 0.08$,
considering characteristic value $fsy_v = fsv/1.2$, from table 5.1, TBDY
For calculation of $esuv_{nominal}$ and y_v, sh_v, ft_v, fy_v , it is considered
characteristic value $fsy_v = fsv/1.2$, from table 5.1, TBDY.
 y_1, sh_1, ft_1, fy_1 , are also multiplied by $Min(1, 1.25 * (l_b/l_d)^{2/3})$, from 10.3.5, ASCE 41-17.
with $fsv = fs = 311.2056$
with $Es_v = Es = 200000.00$
 $1 = Asl_{ten}/(b * d) * (fs_1/f_c) = 0.0767366$
 $2 = Asl_{com}/(b * d) * (fs_2/f_c) = 0.0767366$
 $v = Asl_{mid}/(b * d) * (fsv/f_c) = 0.0767366$
and confined core properties:
 $b = 340.00$
 $d = 228.00$
 $d' = 12.00$
 $f_{cc} (5A.2, TBDY) = 20.00$
 $cc (5A.5, TBDY) = 0.002$
 $c = \text{confinement factor} = 1.00$
 $1 = Asl_{ten}/(b * d) * (fs_1/f_c) = 0.10215708$
 $2 = Asl_{com}/(b * d) * (fs_2/f_c) = 0.10215708$
 $v = Asl_{mid}/(b * d) * (fsv/f_c) = 0.10215708$
Case/Assumption: Unconfined full section - Steel rupture
' satisfies Eq. (4.3)
--->
 $v < v_{s,y_2}$ - LHS eq.(4.5) is satisfied
--->
 $su (4.9) = 0.21759794$
 $Mu = MRc (4.14) = 5.3484E+007$
 $u = su (4.1) = 2.5364147E-005$

Calculation of ratio l_b/l_d

Inadequate Lap Length with $l_b/l_d = 0.30$

Calculation of Mu_{2+}

Calculation of ultimate curvature u according to 4.1, Biskinis/Fardis 2013:

$$u = 2.5364147E-005$$

$$Mu = 5.3484E+007$$

with full section properties:

$$b = 400.00$$

$d = 258.00$
 $d' = 42.00$
 $v = 0.00019384$
 $N = 400.0832$
 $f_c = 20.00$
 $\phi (5A.5, TBDY) = 0.002$
 Final value of ϕ : $\phi^* = \text{shear_factor} * \text{Max}(\phi, \phi_c) = 0.00583896$
 The Shear_factor is considered equal to 1 (pure moment strength)
 From (5.4b), TBDY: $\phi = 0.00583896$
 $\phi_w (5.4c) = 0.0034192$
 $\phi_{se} ((5.4d), TBDY) = 0.15672608$
 $\phi_o = 240.00$
 $\phi_h = 340.00$
 $\phi_{i2} = 346400.00$
 $\phi_{sh,min} = \text{Min}(\phi_{sh,x}, \phi_{sh,y}) = 0.00261799$
 Expression ((5.4d), TBDY) for $\phi_{sh,min}$ has been multiplied by 0.3 according to 15.7.1.3 for members without earthquake detailing (90° closed stirrups)

$\phi_{sh,x} (5.4d) = 0.00349066$
 $A_{sh} = A_{stir} * n_s = 78.53982$
 No stirrups, $n_s = 2.00$
 $b_k = 300.00$

$\phi_{sh,y} (5.4d) = 0.00261799$
 $A_{sh} = A_{stir} * n_s = 78.53982$
 No stirrups, $n_s = 2.00$
 $b_k = 400.00$

$s = 150.00$
 $f_{ywe} = 555.55$
 $f_{ce} = 20.00$
 From ((5.A5), TBDY), TBDY: $\phi_c = 0.002$
 $\phi = \text{confinement factor} = 1.00$
 $y_1 = 0.00129669$
 $sh_1 = 0.0044814$
 $ft_1 = 373.4467$
 $fy_1 = 311.2056$
 $su_1 = 0.00512$
 using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
 and also multiplied by the shear_factor according to 15.7.1.4, with
 Shear_factor = 1.00
 $\phi_o/\phi_{ou,min} = \phi_b/\phi_d = 0.30$
 $su_1 = 0.4 * \phi_{su1_nominal} ((5.5), TBDY) = 0.032$
 From table 5A.1, TBDY: $\phi_{su1_nominal} = 0.08$,
 For calculation of $\phi_{su1_nominal}$ and y_1, sh_1, ft_1, fy_1 , it is considered
 characteristic value $fsy_1 = fs_1/1.2$, from table 5.1, TBDY.
 y_1, sh_1, ft_1, fy_1 , are also multiplied by $\text{Min}(1, 1.25 * (\phi_b/\phi_d)^{2/3})$, from 10.3.5, ASCE 41-17.
 with $fs_1 = fs = 311.2056$
 with $Es_1 = Es = 200000.00$
 $y_2 = 0.00129669$
 $sh_2 = 0.0044814$
 $ft_2 = 373.4467$
 $fy_2 = 311.2056$
 $su_2 = 0.00512$
 using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
 and also multiplied by the shear_factor according to 15.7.1.4, with
 Shear_factor = 1.00
 $\phi_o/\phi_{ou,min} = \phi_b/\phi_{b,min} = 0.30$
 $su_2 = 0.4 * \phi_{su2_nominal} ((5.5), TBDY) = 0.032$
 From table 5A.1, TBDY: $\phi_{su2_nominal} = 0.08$,
 For calculation of $\phi_{su2_nominal}$ and y_2, sh_2, ft_2, fy_2 , it is considered
 characteristic value $fsy_2 = fs_2/1.2$, from table 5.1, TBDY.
 y_1, sh_1, ft_1, fy_1 , are also multiplied by $\text{Min}(1, 1.25 * (\phi_b/\phi_d)^{2/3})$, from 10.3.5, ASCE 41-17.
 with $fs_2 = fs = 311.2056$
 with $Es_2 = Es = 200000.00$
 $y_v = 0.00129669$
 $sh_v = 0.0044814$

```

ftv = 373.4467
fyv = 311.2056
suv = 0.00512
    using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
    and also multiplied by the shear_factor according to 15.7.1.4, with
    Shear_factor = 1.00
    lo/lo,min = lb/ld = 0.30
    suv = 0.4*esuv_nominal ((5.5), TBDY) = 0.032
    From table 5A.1, TBDY: esuv_nominal = 0.08,
    considering characteristic value fsyv = fsv/1.2, from table 5.1, TBDY
    For calculation of esuv_nominal and yv, shv,ftv,fyv, it is considered
    characteristic value fsyv = fsv/1.2, from table 5.1, TBDY.
    y1, sh1,ft1,fy1, are also multiplied by Min(1,1.25*(lb/ld)^ 2/3), from 10.3.5, ASCE 41-17.
    with fsv = fs = 311.2056
    with Esv = Es = 200000.00
    1 = Asl,ten/(b*d)*(fs1/fc) = 0.0767366
    2 = Asl,com/(b*d)*(fs2/fc) = 0.0767366
    v = Asl,mid/(b*d)*(fsv/fc) = 0.0767366
and confined core properties:
b = 340.00
d = 228.00
d' = 12.00
fcc (5A.2, TBDY) = 20.00
cc (5A.5, TBDY) = 0.002
    c = confinement factor = 1.00
    1 = Asl,ten/(b*d)*(fs1/fc) = 0.10215708
    2 = Asl,com/(b*d)*(fs2/fc) = 0.10215708
    v = Asl,mid/(b*d)*(fsv/fc) = 0.10215708
Case/Assumption: Unconfined full section - Steel rupture
' satisfies Eq. (4.3)
--->
v < vs,y2 - LHS eq.(4.5) is satisfied
--->
su (4.9) = 0.21759794
Mu = MRc (4.14) = 5.3484E+007
u = su (4.1) = 2.5364147E-005

```

Calculation of ratio lb/ld

Inadequate Lap Length with lb/ld = 0.30

Calculation of Mu2-

Calculation of ultimate curvature u according to 4.1, Biskinis/Fardis 2013:

u = 2.5364147E-005

Mu = 5.3484E+007

with full section properties:

b = 400.00

d = 258.00

d' = 42.00

v = 0.00019384

N = 400.0832

fc = 20.00

co (5A.5, TBDY) = 0.002

Final value of cu: cu* = shear_factor * Max(cu, cc) = 0.00583896

The Shear_factor is considered equal to 1 (pure moment strength)

From (5.4b), TBDY: cu = 0.00583896

we (5.4c) = 0.0034192

ase ((5.4d), TBDY) = 0.15672608

bo = 240.00

ho = 340.00

```

bi2 = 346400.00
psh,min = Min(psh,x , psh,y) = 0.00261799
Expression ((5.4d), TBDY) for psh,min has been multiplied by 0.3 according to 15.7.1.3 for members without
earthquake detailing (90° closed stirrups)
-----
psh,x (5.4d) = 0.00349066
Ash = Astir*ns = 78.53982
No stirups, ns = 2.00
bk = 300.00
-----
psh,y (5.4d) = 0.00261799
Ash = Astir*ns = 78.53982
No stirups, ns = 2.00
bk = 400.00
-----
s = 150.00
fywe = 555.55
fce = 20.00
From ((5.A5), TBDY), TBDY: cc = 0.002
c = confinement factor = 1.00
y1 = 0.00129669
sh1 = 0.0044814
ft1 = 373.4467
fy1 = 311.2056
su1 = 0.00512
using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00
lo/lou,min = lb/lb,min = 0.30
su1 = 0.4*esu1_nominal ((5.5), TBDY) = 0.032
From table 5A.1, TBDY: esu1_nominal = 0.08,
For calculation of esu1_nominal and y1, sh1,ft1,fy1, it is considered
characteristic value fsy1 = fs1/1.2, from table 5.1, TBDY.
y1, sh1,ft1,fy1, are also multiplied by Min(1,1.25*(lb/lb,min)^ 2/3), from 10.3.5, ASCE 41-17.
with fs1 = fs = 311.2056
with Es1 = Es = 200000.00
y2 = 0.00129669
sh2 = 0.0044814
ft2 = 373.4467
fy2 = 311.2056
su2 = 0.00512
using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00
lo/lou,min = lb/lb,min = 0.30
su2 = 0.4*esu2_nominal ((5.5), TBDY) = 0.032
From table 5A.1, TBDY: esu2_nominal = 0.08,
For calculation of esu2_nominal and y2, sh2,ft2,fy2, it is considered
characteristic value fsy2 = fs2/1.2, from table 5.1, TBDY.
y1, sh1,ft1,fy1, are also multiplied by Min(1,1.25*(lb/lb,min)^ 2/3), from 10.3.5, ASCE 41-17.
with fs2 = fs = 311.2056
with Es2 = Es = 200000.00
yv = 0.00129669
shv = 0.0044814
ftv = 373.4467
fyv = 311.2056
suv = 0.00512
using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00
lo/lou,min = lb/lb,min = 0.30
suv = 0.4*esuv_nominal ((5.5), TBDY) = 0.032
From table 5A.1, TBDY: esuv_nominal = 0.08,
considering characteristic value fsyv = fsv/1.2, from table 5.1, TBDY
For calculation of esuv_nominal and yv, shv,ftv,fyv, it is considered
characteristic value fsyv = fsv/1.2, from table 5.1, TBDY.
y1, sh1,ft1,fy1, are also multiplied by Min(1,1.25*(lb/lb,min)^ 2/3), from 10.3.5, ASCE 41-17.

```



```

with fsv = fs = 311.2056
with Esv = Es = 200000.00
1 = Asl,ten/(b*d)*(fs1/fc) = 0.0767366
2 = Asl,com/(b*d)*(fs2/fc) = 0.0767366
v = Asl,mid/(b*d)*(fsv/fc) = 0.0767366
and confined core properties:
b = 340.00
d = 228.00
d' = 12.00
fcc (5A.2, TBDY) = 20.00
cc (5A.5, TBDY) = 0.002
c = confinement factor = 1.00
1 = Asl,ten/(b*d)*(fs1/fc) = 0.10215708
2 = Asl,com/(b*d)*(fs2/fc) = 0.10215708
v = Asl,mid/(b*d)*(fsv/fc) = 0.10215708
Case/Assumption: Unconfined full section - Steel rupture
'satisfies Eq. (4.3)
--->
v < vs,y2 - LHS eq.(4.5) is satisfied
--->
su (4.9) = 0.21759794
Mu = MRc (4.14) = 5.3484E+007
u = su (4.1) = 2.5364147E-005

```

Calculation of ratio lb/d

Inadequate Lap Length with lb/d = 0.30

Calculation of Shear Strength $V_r = \min(V_{r1}, V_{r2}) = 152466.975$

Calculation of Shear Strength at edge 1, $V_{r1} = 152466.975$
 $V_{r1} = V_n$ ((22.5.1.1), ACI 318-14)

NOTE: In expression (22.5.1.1) 'Vw' is replaced by 'Vw+ f*Vf'
where Vf is the contribution of FRPs (11.3), ACI 440).

From Table (22.5.5.1), ACI 318-14: $V_c = 68692.008$
= 1 (normal-weight concrete)
 $f'_c = 20.00$, but $f_c^{0.5} \leq 8.3$ MPa (22.5.3.1, ACI 318-14)
 $p_w = A_s/(b_w*d) = 0.00628319$
 A_s (tension reinf.) = 603.1858
 $b_w = 400.00$
 $d = 240.00$
 $V_u*d/M_u < 1 = 0.00$
 $M_u = 2.0746991E-007$
 $V_u = 1.0090939E-010$
From (11.5.4.8), ACI 318-14: $V_s = 83774.966$
 $A_v = 157079.633$
 $f_y = 444.44$
 $s = 150.00$
 V_s has been multiplied by $2(1-s/d)$ ($s > d/2$, according to ASCE 41-17,10.3.4)
 $2(1-s/d) = 0.75$
 V_f ((11-3)-(11.4), ACI 440) = 0.00
From (11-11), ACI 440: $V_s + V_f \leq 285202.276$

Calculation of Shear Strength at edge 2, $V_{r2} = 152466.975$
 $V_{r2} = V_n$ ((22.5.1.1), ACI 318-14)

NOTE: In expression (22.5.1.1) 'Vw' is replaced by 'Vw+ f*Vf'
where Vf is the contribution of FRPs (11.3), ACI 440).

From Table (22.5.5.1), ACI 318-14: $V_c = 68692.008$
= 1 (normal-weight concrete)

$fc' = 20.00$, but $fc'^{0.5} \leq 8.3$ MPa (22.5.3.1, ACI 318-14)

$\rho_w = A_s/(b_w \cdot d) = 0.00628319$

A_s (tension reinf.) = 603.1858

$b_w = 400.00$

$d = 240.00$

$V_u \cdot d / M_u < 1 = 0.00$

$M_u = 2.0781750E-008$

$V_u = 1.0090939E-010$

From (11.5.4.8), ACI 318-14: $V_s = 83774.966$

$A_v = 157079.633$

$f_y = 444.44$

$s = 150.00$

V_s has been multiplied by $2(1-s/d)$ ($s > d/2$, according to ASCE 41-17, 10.3.4)

$2(1-s/d) = 0.75$

V_f ((11-3)-(11.4), ACI 440) = 0.00

From (11-11), ACI 440: $V_s + V_f \leq 285202.276$

End Of Calculation of Shear Capacity ratio for element: beam B1 of floor 1

At local axis: 2

Start Of Calculation of Chord Rotation Capacity for element: beam B1 of floor 1

At local axis: 3

Integration Section: (b)

Section Type: rcars

Constant Properties

Knowledge Factor, $\gamma = 1.00$

Chord Rotation is generally considered as Deformation-Controlled Action according to Table C7-1, ASCE 41-17.

Mean strengths are used for Deformation-Controlled Actions according to 7.5.1.3, ASCE 41-17

Consequently:

Existing material of Secondary Member: Concrete Strength, $f_c = f_{cm} = 20.00$

Existing material of Secondary Member: Steel Strength, $f_s = f_{sm} = 444.44$

Concrete Elasticity, $E_c = 21019.039$

Steel Elasticity, $E_s = 200000.00$

Section Height, $H = 400.00$

Section Width, $W = 300.00$

Cover Thickness, $c = 25.00$

Element Length, $L = 1850.00$

Secondary Member

Ribbed Bars

Ductile Steel

Without Detailing for Earthquake Resistance (including stirrups not closed at 135°)

Longitudinal Bars With Ends Lapped Starting at the End Sections

Inadequate Lap Length with $l_b/l_d = 0.30$

No FRP Wrapping

Stepwise Properties

Bending Moment, $M = -6.4263222E-005$

Shear Force, $V_2 = 6.2288147E-008$

Shear Force, $V_3 = 11843.705$

Axial Force, $F = -1388.628$

Longitudinal Reinforcement Area Distribution (in 2 divisions)

-Tension: $A_{st} = 615.7522$

-Compression: $A_{sc} = 911.0619$

Longitudinal Reinforcement Area Distribution (in 3 divisions)

-Tension: $A_{st,ten} = 508.938$

-Compression: $A_{sc,com} = 508.938$

-Middle: $A_{st,mid} = 508.938$

Mean Diameter of Tension Reinforcement, $Db_L = 14.66667$

Existing component: From table 7-7, ASCE 41_17: Final chord rotation Capacity $u_R = u = 0.00709447$
 $u = y + p = 0.00709447$

- Calculation of y -

$y = (M_y * L_s / 3) / E_{eff} = 0.00209447$ ((4.29), Biskinis Phd))
 $M_y = 3.8551E+007$
 $L_s = M/V$ (with $L_s > 0.1 * L$ and $L_s < 2 * L$) = 925.00
From table 10.5, ASCE 41_17: $E_{eff} = 0.3 * E_c * I_g = 5.6751E+012$

Calculation of Yielding Moment M_y

Calculation of y and M_y according to Annex 7 -

$y = \text{Min}(y_{ten}, y_{com})$
 $y_{ten} = 6.7808955E-006$
with ((10.1), ASCE 41-17) $f_y = \text{Min}(f_y, 1.25 * f_y * (l_b / l_d)^{2/3}) = 248.9644$
 $d = 258.00$
 $y = 0.28845796$
 $A = 0.01484876$
 $B = 0.00865562$
with $p_t = 0.00493157$
 $p_c = 0.00493157$
 $p_v = 0.00493157$
 $N = 1388.628$
 $b = 400.00$
 $" = 0.1627907$
 $y_{comp} = 2.3061901E-005$
with $f_c = 20.00$
 $E_c = 21019.039$
 $y = 0.2878557$
 $A = 0.01475543$
 $B = 0.00860158$
with $E_s = 200000.00$

Calculation of ratio l_b / l_d

Inadequate Lap Length with $l_b / l_d = 0.30$

- Calculation of p -

From table 10-7: $p = 0.005$

with:


- Condition iv occurred
Beam controlled by inadequate embedment into beam-column joint:
($l_b / l_d < 1$ and With Lapping in the Vicinity of the End Regions)
- Condition i occurred
Beam controlled by flexure: $V_p / V_o \leq 1$
shear control ratio $V_p / V_o = 0.37923485$
- Transverse Reinforcement: NC
- Stirrup Spacing $> d / 3$
- Low ductility demand, $\phi_y < 2$ (table 10-6, ASCE 41-17)
 $= -1.1246655E-015$
- Stirrup Spacing $> d / 2$
 $d = 258.00$
 $s = 150.00$
- Strength provided by hoops $V_s < 3/4 * \text{design Shear}$
 $V_s = 111699.955$, already given in calculation of shear control ratio
design Shear = $6.2288147E-008$

$\rho = \rho' = 0.00596659$
 $\rho = \rho' = 0.00596659$
 Tension Reinf Area: $A_{st} = 615.7522$
 $\rho = \rho' = 0.00882812$
 Compression Reinf Area: $A_{sc} = 911.0619$
 From (B-1), ACI 318-11: $\rho = 0.01867766$
 $f_c = 20.00$
 $f_y = 444.44$
 From 10.2.7.3, ACI 318-11: $\phi = 0.85$
 From fig R10.3.3, ACI 318-11 (Ence 454, too): $\phi = 0.003 / (0.003 + \rho) = 0.57447053$
 $\phi = 0.0022222$
 $V / (b_w \cdot d \cdot f_c^{0.5}) = 1.6253015E-012$, NOTE: units in lb & in
 $b_w = 400.00$

End Of Calculation of Chord Rotation Capacity for element: beam B1 of floor 1
 At local axis: 3
 Integration Section: (b)

Calculation No. 9

beam B1, Floor 1
 Limit State: Life Safety (data interpolation between analysis steps 1 and 2)
 Analysis: Uniform +X
 Check: Shear capacity V_{Rd}
 Edge: Start
 Local Axis: (2)



Start Of Calculation of Shear Capacity for element: beam B1 of floor 1
 At local axis: 2
 Integration Section: (a)
 Section Type: rcars

Constant Properties

Knowledge Factor, $\phi = 1.00$

Member Shear Force is generally considered as Force-Controlled Action according to Table C7-1, ASCE 41-17.
 Lower-bound strengths are used for Force-Controlled Actions according to 7.5.1.3, ASCE 41-17
 Consequently:
 Existing material of Secondary Member: Concrete Strength, $f_c = f_{c_lower_bound} = 16.00$
 Existing material of Secondary Member: Steel Strength, $f_s = f_{s_lower_bound} = 400.00$
 Concrete Elasticity, $E_c = 21019.039$
 Steel Elasticity, $E_s = 200000.00$
 Section Height, $H = 400.00$
 Section Width, $W = 300.00$
 Cover Thickness, $c = 25.00$
 Element Length, $L = 1850.00$
 Secondary Member
 Ribbed Bars
 Ductile Steel
 Without Detailing for Earthquake Resistance (including stirrups not closed at 135°)
 Longitudinal Bars With Ends Lapped Starting at the End Sections
 Inadequate Lap Length with $l_o/l_{o,min} = l_b/l_d = 0.30$
 No FRP Wrapping

Stepwise Properties

EDGE -A-
 Bending Moment, $M_a = -4.4694326E-005$
 Shear Force, $V_a = -5.1634141E-008$
 EDGE -B-
 Bending Moment, $M_b = -5.3249995E-005$
 Shear Force, $V_b = 5.1634141E-008$
 BOTH EDGES
 Axial Force, $F = -1219.269$
 Longitudinal Reinforcement Area Distribution (in 2 divisions)
 -Tension: $A_{st} = 603.1858$
 -Compression: $A_{sc} = 923.6282$
 Longitudinal Reinforcement Area Distribution (in 3 divisions)
 -Tension: $A_{st,ten} = 508.938$
 -Compression: $A_{st,com} = 508.938$
 -Middle: $A_{st,mid} = 508.938$
 Mean Diameter of Tension Reinforcement, $D_{bL,ten} = 14.66667$

Existing component: From table 7-7, ASCE 41_17: Final Shear Capacity $V_R = V_n = 139681.348$
 V_n ((22.5.1.1), ACI 318-14) = 139681.348


NOTE: In expression (22.5.1.1) ' V_w ' is replaced by ' $V_w + f \cdot V_f$ '
 where V_f is the contribution of FRPs ((11.3), ACI 440).

From Table (22.5.5.1), ACI 318-14: $V_c = 64283.124$
 = 1 (normal-weight concrete)
 $f'_c = 16.00$, but $f_c^{0.5} \leq 8.3$ MPa ((22.5.3.1, ACI 318-14)
 $\rho_w = A_s/(b_w \cdot d) = 0.00628319$
 A_s (tension reinf.) = 603.1858
 $b_w = 400.00$
 $d = 240.00$
 $V_u \cdot d / M_u < 1 = 0.27726548$
 $M_u = 4.4694326E-005$
 $V_u = 5.1634141E-008$
 From (11.5.4.8), ACI 318-14: $V_s = 75398.224$
 $A_v = 157079.633$
 $f_y = 400.00$
 $s = 150.00$
 V_s has been multiplied by $2(1-s/d)$ ($s > d/2$, according to ASCE 41-17, 10.3.4)
 $2(1-s/d) = 0.75$
 V_f ((11-3)-(11.4), ACI 440) = 0.00
 From (11-11), ACI 440: $V_s + V_f \leq 255092.67$

End Of Calculation of Shear Capacity for element: beam B1 of floor 1
At local axis: 2
Integration Section: (a)

Calculation No. 10

beam B1, Floor 1
Limit State: Life Safety (data interpolation between analysis steps 1 and 2)
Analysis: Uniform +X
Check: Chord rotation capacity (ϕ)
Edge: Start
Local Axis: (2)



Start Of Calculation of Shear Capacity ratio for element: beam B1 of floor 1
At Shear local axis: 3
(Bending local axis: 2)
Section Type: rcars

Constant Properties

Knowledge Factor, $\phi = 1.00$

Mean strength values are used for both shear and moment calculations.

Consequently:

Existing material of Secondary Member: Concrete Strength, $f_c = f_{cm} = 20.00$

Existing material of Secondary Member: Steel Strength, $f_s = f_{sm} = 444.44$

Concrete Elasticity, $E_c = 21019.039$

Steel Elasticity, $E_s = 200000.00$

#####

Note: Especially for the calculation of moment strengths,

the above steel re-bar strengths are multiplied by 1.25 according to R18.6.5, ACI 318-14

Existing material: Steel Strength, $f_s = 1.25 \cdot f_{sm} = 555.55$

#####

Section Height, $H = 400.00$

Section Width, $W = 300.00$

Cover Thickness, $c = 25.00$

Mean Confinement Factor overall section = 1.00

Element Length, $L = 1850.00$

Secondary Member

Ribbed Bars
Ductile Steel
Without Detailing for Earthquake Resistance (including stirrups not closed at 135°)
Longitudinal Bars With Ends Lapped Starting at the End Sections
Inadequate Lap Length with $l_o/l_{o,min} = 0.30$
No FRP Wrapping

Stepwise Properties

At local axis: 3
EDGE -A-
Shear Force, $V_a = 4076.60$
EDGE -B-
Shear Force, $V_b = 4178.928$
BOTH EDGES
Axial Force, $F = -400.0832$
Longitudinal Reinforcement Area Distribution (in 2 divisions)
-Tension: $As_t = 603.1858$
-Compression: $As_c = 923.6282$
Longitudinal Reinforcement Area Distribution (in 3 divisions)
-Tension: $As_{t,ten} = 603.1858$
-Compression: $As_{l,com} = 615.7522$
-Middle: $As_{l,mid} = 307.8761$

Calculation of Shear Capacity ratio, $V_e/V_r = 0.40672566$
Member Controlled by Flexure ($V_e/V_r < 1$)
Calculation of Shear Demand from fig. R18.6.5, ACI 318-14 $V_e = (M_{pr1} + M_{pr2})/l_n \pm w_u \cdot l_n/2 = 92684.415$
with
 $M_{pr1} = \text{Max}(Mu_{1+}, Mu_{1-}) = 8.1957E+007$
 $Mu_{1+} = 8.0451E+007$, is the ultimate moment strength at the edge 1 of the member in the actual moment direction which is defined for the static loading combination
 $Mu_{1-} = 8.1957E+007$, is the ultimate moment strength at the edge 1 of the member in the opposite moment direction which is defined for the static loading combination
 $M_{pr2} = \text{Max}(Mu_{2+}, Mu_{2-}) = 8.1873E+007$
 $Mu_{2+} = 8.0533E+007$, is the ultimate moment strength at the edge 2 of the member in the actual moment direction which is defined for the the static loading combination
 $Mu_{2-} = 8.1873E+007$, is the ultimate moment strength at the edge 2 of the member in the opposite moment direction which is defined for the the static loading combination
and
 $\pm w_u \cdot l_n = (|V_1| + |V_2|)/2$
with
 $V_1 = 4076.60$, is the shear force acting at edge 1 for the the static loading combination
 $V_2 = 4178.928$, is the shear force acting at edge 2 for the the static loading combination

Calculation of Mu_{1+}

Calculation of ultimate curvature ϕ_u according to 4.1, Biskinis/Fardis 2013:
 $\phi_u = 1.7899831E-005$
 $Mu = 8.0451E+007$

with full section properties:

$b = 300.00$
 $d = 357.00$
 $d' = 42.00$
 $v = 0.00018678$
 $N = 400.0832$
 $f_c = 20.00$
 $\phi_o (5A.5, TBDY) = 0.002$
Final value of ϕ_u : $\phi_u^* = \text{shear_factor} * \text{Max}(\phi_u, \phi_o) = 0.00583896$
The Shear_factor is considered equal to 1 (pure moment strength)

From (5.4b), TBDY: $c_u = 0.00583896$
 w_e (5.4c) = 0.0034192
 a_{se} ((5.4d), TBDY) = 0.15672608
 $b_o = 240.00$
 $h_o = 340.00$
 $b_{i2} = 346400.00$
 $p_{sh,min} = \text{Min}(p_{sh,x}, p_{sh,y}) = 0.00261799$
 Expression ((5.4d), TBDY) for $p_{sh,min}$ has been multiplied by 0.3 according to 15.7.1.3 for members without earthquake detailing (90° closed stirrups)

 $p_{sh,x}$ (5.4d) = 0.00349066
 $A_{sh} = A_{stir} \cdot n_s = 78.53982$
 No stirrups, $n_s = 2.00$
 $b_k = 300.00$

 $p_{sh,y}$ (5.4d) = 0.00261799
 $A_{sh} = A_{stir} \cdot n_s = 78.53982$
 No stirrups, $n_s = 2.00$
 $b_k = 400.00$

 $s = 150.00$
 $f_{ywe} = 555.55$
 $f_{ce} = 20.00$
 From ((5.A5), TBDY), TBDY: $c_c = 0.002$
 $c = \text{confinement factor} = 1.00$
 $y_1 = 0.00129669$
 $sh_1 = 0.0044814$
 $ft_1 = 373.4467$
 $fy_1 = 311.2056$
 $su_1 = 0.00512$
 using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
 and also multiplied by the shear_factor according to 15.7.1.4, with
 $\text{Shear_factor} = 1.00$
 $l_o/l_{ou,min} = l_b/l_d = 0.30$
 $su_1 = 0.4 \cdot esu1_nominal$ ((5.5), TBDY) = 0.032
 From table 5A.1, TBDY: $esu1_nominal = 0.08$,
 For calculation of $esu1_nominal$ and y_1, sh_1, ft_1, fy_1 , it is considered
 characteristic value $fsy_1 = fs_1/1.2$, from table 5.1, TBDY.
 y_1, sh_1, ft_1, fy_1 , are also multiplied by $\text{Min}(1, 1.25 \cdot (l_b/l_d)^{2/3})$, from 10.3.5, ASCE 41-17.
 with $fs_1 = fs = 311.2056$
 with $Es_1 = Es = 200000.00$
 $y_2 = 0.00129669$
 $sh_2 = 0.0044814$
 $ft_2 = 373.4467$
 $fy_2 = 311.2056$
 $su_2 = 0.00512$
 using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
 and also multiplied by the shear_factor according to 15.7.1.4, with
 $\text{Shear_factor} = 1.00$
 $l_o/l_{ou,min} = l_b/l_{b,min} = 0.30$
 $su_2 = 0.4 \cdot esu2_nominal$ ((5.5), TBDY) = 0.032
 From table 5A.1, TBDY: $esu2_nominal = 0.08$,
 For calculation of $esu2_nominal$ and y_2, sh_2, ft_2, fy_2 , it is considered
 characteristic value $fsy_2 = fs_2/1.2$, from table 5.1, TBDY.
 y_1, sh_1, ft_1, fy_1 , are also multiplied by $\text{Min}(1, 1.25 \cdot (l_b/l_d)^{2/3})$, from 10.3.5, ASCE 41-17.
 with $fs_2 = fs = 311.2056$
 with $Es_2 = Es = 200000.00$
 $y_v = 0.00129669$
 $sh_v = 0.0044814$
 $ft_v = 373.4467$
 $fy_v = 311.2056$
 $suv = 0.00512$
 using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
 and also multiplied by the shear_factor according to 15.7.1.4, with
 $\text{Shear_factor} = 1.00$
 $l_o/l_{ou,min} = l_b/l_d = 0.30$
 $suv = 0.4 \cdot esuv_nominal$ ((5.5), TBDY) = 0.032

From table 5A.1, TBDY: $e_{suv_nominal} = 0.08$,
considering characteristic value $f_{syv} = f_{sv}/1.2$, from table 5.1, TBDY
For calculation of $e_{suv_nominal}$ and y_v , sh_v , ft_v , f_{yv} , it is considered
characteristic value $f_{syv} = f_{sv}/1.2$, from table 5.1, TBDY.
 y_1 , sh_1 , ft_1 , f_{y1} , are also multiplied by $\text{Min}(1, 1.25 \cdot (l_b/l_d)^{2/3})$, from 10.3.5, ASCE 41-17.
with $f_{sv} = f_s = 311.2056$
with $E_{sv} = E_s = 200000.00$
 $1 = A_{sl,ten}/(b \cdot d) \cdot (f_{s1}/f_c) = 0.08763528$
 $2 = A_{sl,com}/(b \cdot d) \cdot (f_{s2}/f_c) = 0.08946101$
 $v = A_{sl,mid}/(b \cdot d) \cdot (f_{sv}/f_c) = 0.04473051$
and confined core properties:
 $b = 240.00$
 $d = 327.00$
 $d' = 12.00$
 $f_{cc} \text{ (5A.2, TBDY)} = 20.00$
 $cc \text{ (5A.5, TBDY)} = 0.002$
 $c = \text{confinement factor} = 1.00$
 $1 = A_{sl,ten}/(b \cdot d) \cdot (f_{s1}/f_c) = 0.11959401$
 $2 = A_{sl,com}/(b \cdot d) \cdot (f_{s2}/f_c) = 0.12208556$
 $v = A_{sl,mid}/(b \cdot d) \cdot (f_{sv}/f_c) = 0.06104278$
Case/Assumption: Unconfined full section - Steel rupture
'satisfies Eq. (4.3)
--->
 $v < v_{s,y2}$ - LHS eq.(4.5) is satisfied
--->
 $su \text{ (4.9)} = 0.19877808$
 $Mu = MR_c \text{ (4.14)} = 8.0451E+007$
 $u = su \text{ (4.1)} = 1.7899831E-005$

Calculation of ratio l_b/l_d

Inadequate Lap Length with $l_b/l_d = 0.30$

Calculation of Mu_1 -

Calculation of ultimate curvature u according to 4.1, Biskinis/Fardis 2013:
 $u = 1.7901443E-005$
 $Mu = 8.1957E+007$

with full section properties:
 $b = 300.00$
 $d = 358.00$
 $d' = 43.00$
 $v = 0.00018626$
 $N = 400.0832$
 $f_c = 20.00$
 $co \text{ (5A.5, TBDY)} = 0.002$
Final value of cu : $cu^* = \text{shear_factor} \cdot \text{Max}(cu, cc) = 0.00583896$
The Shear_factor is considered equal to 1 (pure moment strength)
From (5.4b), TBDY: $cu = 0.00583896$
 $w_e \text{ (5.4c)} = 0.0034192$
 $ase \text{ ((5.4d), TBDY)} = 0.15672608$
 $bo = 240.00$
 $ho = 340.00$
 $bi2 = 346400.00$
 $psh,min = \text{Min}(psh,x, psh,y) = 0.00261799$
Expression ((5.4d), TBDY) for psh,min has been multiplied by 0.3 according to 15.7.1.3 for members without
earthquake detailing (90° closed stirrups)

 $psh,x \text{ (5.4d)} = 0.00349066$
 $A_{sh} = A_{stir} \cdot n_s = 78.53982$
No stirrups, $n_s = 2.00$

bk = 300.00

psh,y (5.4d) = 0.00261799

Ash = Astir*ns = 78.53982

No stirups, ns = 2.00

bk = 400.00

s = 150.00

fywe = 555.55

fce = 20.00

From ((5.A5), TBDY), TBDY: cc = 0.002

c = confinement factor = 1.00

y1 = 0.00129669

sh1 = 0.0044814

ft1 = 373.4467

fy1 = 311.2056

su1 = 0.00512

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor

and also multiplied by the shear_factor according to 15.7.1.4, with

Shear_factor = 1.00

lo/lou,min = lb/ld = 0.30

su1 = 0.4*esu1_nominal ((5.5), TBDY) = 0.032

From table 5A.1, TBDY: esu1_nominal = 0.08,

For calculation of esu1_nominal and y1, sh1,ft1,fy1, it is considered characteristic value fsy1 = fs1/1.2, from table 5.1, TBDY.

y1, sh1,ft1,fy1, are also multiplied by $\text{Min}(1, 1.25 \cdot (lb/ld)^{2/3})$, from 10.3.5, ASCE 41-17.

with fs1 = fs = 311.2056

with Es1 = Es = 200000.00

y2 = 0.00129669

sh2 = 0.0044814

ft2 = 373.4467

fy2 = 311.2056

su2 = 0.00512

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor

and also multiplied by the shear_factor according to 15.7.1.4, with

Shear_factor = 1.00

lo/lou,min = lb/lb,min = 0.30

su2 = 0.4*esu2_nominal ((5.5), TBDY) = 0.032

From table 5A.1, TBDY: esu2_nominal = 0.08,

For calculation of esu2_nominal and y2, sh2,ft2,fy2, it is considered characteristic value fsy2 = fs2/1.2, from table 5.1, TBDY.

y1, sh1,ft1,fy1, are also multiplied by $\text{Min}(1, 1.25 \cdot (lb/ld)^{2/3})$, from 10.3.5, ASCE 41-17.

with fs2 = fs = 311.2056

with Es2 = Es = 200000.00

yv = 0.00129669

shv = 0.0044814

ftv = 373.4467

fyv = 311.2056

suv = 0.00512

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor

and also multiplied by the shear_factor according to 15.7.1.4, with

Shear_factor = 1.00

lo/lou,min = lb/ld = 0.30

suv = 0.4*esuv_nominal ((5.5), TBDY) = 0.032

From table 5A.1, TBDY: esuv_nominal = 0.08,

considering characteristic value fsyv = fsv/1.2, from table 5.1, TBDY

For calculation of esuv_nominal and yv, shv,ftv,fyv, it is considered characteristic value fsyv = fsv/1.2, from table 5.1, TBDY.

y1, sh1,ft1,fy1, are also multiplied by $\text{Min}(1, 1.25 \cdot (lb/ld)^{2/3})$, from 10.3.5, ASCE 41-17.

with fsv = fs = 311.2056

with Esv = Es = 200000.00

1 = Asl,ten/(b*d)*(fs1/fc) = 0.08921112

2 = Asl,com/(b*d)*(fs2/fc) = 0.08739049

v = Asl,mid/(b*d)*(fsv/fc) = 0.04460556

and confined core properties:

b = 240.00

d = 328.00

```

d' = 13.00
fcc (5A.2, TBDY) = 20.00
cc (5A.5, TBDY) = 0.002
  c = confinement factor = 1.00
  1 = Asl,ten/(b*d)*(fs1/fc) = 0.12171334
  2 = Asl,com/(b*d)*(fs2/fc) = 0.1192294
  v = Asl,mid/(b*d)*(fsv/fc) = 0.06085667
Case/Assumption: Unconfined full section - Steel rupture
' satisfies Eq. (4.3)
--->
v < vs,y2 - LHS eq.(4.5) is satisfied
--->
su (4.9) = 0.20108809
Mu = MRc (4.14) = 8.1957E+007
u = su (4.1) = 1.7901443E-005

```

Calculation of ratio lb/d

Inadequate Lap Length with lb/d = 0.30

Calculation of Mu2+

Calculation of ultimate curvature u according to 4.1, Biskinis/Fardis 2013:

```

u = 1.7862388E-005
Mu = 8.0533E+007

```

with full section properties:

```

b = 300.00
d = 358.00
d' = 43.00
v = 0.00018626
N = 400.0832
fc = 20.00
co (5A.5, TBDY) = 0.002
Final value of cu: cu* = shear_factor * Max( cu, cc) = 0.00583896
The Shear_factor is considered equal to 1 (pure moment strength)
From (5.4b), TBDY: cu = 0.00583896
we (5.4c) = 0.0034192
ase ((5.4d), TBDY) = 0.15672608
bo = 240.00
ho = 340.00
bi2 = 346400.00
psh,min = Min(psh,x , psh,y) = 0.00261799

```

Expression ((5.4d), TBDY) for psh,min has been multiplied by 0.3 according to 15.7.1.3 for members without earthquake detailing (90° closed stirrups)

```

psh,x (5.4d) = 0.00349066
Ash = Astir*ns = 78.53982
No stirups, ns = 2.00
bk = 300.00

```

```

psh,y (5.4d) = 0.00261799
Ash = Astir*ns = 78.53982
No stirups, ns = 2.00
bk = 400.00

```

```

s = 150.00
fywe = 555.55
fce = 20.00
From ((5.A5), TBDY), TBDY: cc = 0.002
c = confinement factor = 1.00
y1 = 0.00129669

```

```

sh1 = 0.0044814
ft1 = 373.4467
fy1 = 311.2056
su1 = 0.00512
    using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
    and also multiplied by the shear_factor according to 15.7.1.4, with
    Shear_factor = 1.00
    lo/lou,min = lb/lb,min = 0.30
    su1 = 0.4*esu1_nominal ((5.5), TBDY) = 0.032
    From table 5A.1, TBDY: esu1_nominal = 0.08,
    For calculation of esu1_nominal and y1, sh1,ft1,fy1, it is considered
    characteristic value fsy1 = fs1/1.2, from table 5.1, TBDY.
    y1, sh1,ft1,fy1, are also multiplied by Min(1,1.25*(lb/lb,min)^ 2/3), from 10.3.5, ASCE 41-17.
    with fs1 = fs = 311.2056
    with Es1 = Es = 200000.00
y2 = 0.00129669
sh2 = 0.0044814
ft2 = 373.4467
fy2 = 311.2056
su2 = 0.00512
    using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
    and also multiplied by the shear_factor according to 15.7.1.4, with
    Shear_factor = 1.00
    lo/lou,min = lb/lb,min = 0.30
    su2 = 0.4*esu2_nominal ((5.5), TBDY) = 0.032
    From table 5A.1, TBDY: esu2_nominal = 0.08,
    For calculation of esu2_nominal and y2, sh2,ft2,fy2, it is considered
    characteristic value fsy2 = fs2/1.2, from table 5.1, TBDY.
    y1, sh1,ft1,fy1, are also multiplied by Min(1,1.25*(lb/lb,min)^ 2/3), from 10.3.5, ASCE 41-17.
    with fs2 = fs = 311.2056
    with Es2 = Es = 200000.00
yv = 0.00129669
shv = 0.0044814
ftv = 373.4467
fyv = 311.2056
suv = 0.00512
    using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
    and also multiplied by the shear_factor according to 15.7.1.4, with
    Shear_factor = 1.00
    lo/lou,min = lb/lb,min = 0.30
    suv = 0.4*esuv_nominal ((5.5), TBDY) = 0.032
    From table 5A.1, TBDY: esuv_nominal = 0.08,
    considering characteristic value fsyv = fsv/1.2, from table 5.1, TBDY
    For calculation of esuv_nominal and yv, shv,ftv,fyv, it is considered
    characteristic value fsyv = fsv/1.2, from table 5.1, TBDY.
    y1, sh1,ft1,fy1, are also multiplied by Min(1,1.25*(lb/lb,min)^ 2/3), from 10.3.5, ASCE 41-17.
    with fsv = fs = 311.2056
    with Esv = Es = 200000.00
1 = Asl,ten/(b*d)*(fs1/fc) = 0.08739049
2 = Asl,com/(b*d)*(fs2/fc) = 0.08921112
v = Asl,mid/(b*d)*(fsv/fc) = 0.04460556
and confined core properties:
b = 240.00
d = 328.00
d' = 13.00
fcc (5A.2, TBDY) = 20.00
cc (5A.5, TBDY) = 0.002
    c = confinement factor = 1.00
    1 = Asl,ten/(b*d)*(fs1/fc) = 0.1192294
    2 = Asl,com/(b*d)*(fs2/fc) = 0.12171334
    v = Asl,mid/(b*d)*(fsv/fc) = 0.06085667
Case/Assumption: Unconfined full section - Steel rupture
' satisfies Eq. (4.3)
--->
v < vs,y2 - LHS eq.(4.5) is satisfied
--->
su (4.9) = 0.19934131

```

$$\begin{aligned} \mu_u &= M/R_c (4.14) = 8.0533E+007 \\ u &= s_u (4.1) = 1.7862388E-005 \end{aligned}$$

Calculation of ratio l_b/l_d

Inadequate Lap Length with $l_b/l_d = 0.30$

Calculation of μ_u

Calculation of ultimate curvature μ_u according to 4.1, Biskinis/Fardis 2013:

$$\begin{aligned} u &= 1.7939215E-005 \\ \mu_u &= 8.1873E+007 \end{aligned}$$

with full section properties:

$$\begin{aligned} b &= 300.00 \\ d &= 357.00 \\ d' &= 42.00 \\ v &= 0.00018678 \\ N &= 400.0832 \\ f_c &= 20.00 \\ c_o (5A.5, \text{TB DY}) &= 0.002 \\ \text{Final value of } c_u: c_u^* &= \text{shear_factor} * \text{Max}(c_u, c_c) = 0.00583896 \\ \text{The Shear_factor is considered equal to 1 (pure moment strength)} \\ \text{From (5.4b), TB DY: } c_u &= 0.00583896 \\ w_e (5.4c) &= 0.0034192 \\ a_s e ((5.4d), \text{TB DY}) &= 0.15672608 \\ b_o &= 240.00 \\ h_o &= 340.00 \\ b_{i2} &= 346400.00 \end{aligned}$$

$p_{sh,min} = \text{Min}(p_{sh,x}, p_{sh,y}) = 0.00261799$
Expression ((5.4d), TB DY) for $p_{sh,min}$ has been multiplied by 0.3 according to 15.7.1.3 for members without earthquake detailing (90° closed stirrups)

$$\begin{aligned} p_{sh,x} (5.4d) &= 0.00349066 \\ A_{sh} &= A_{stir} * n_s = 78.53982 \\ \text{No stirrups, } n_s &= 2.00 \\ b_k &= 300.00 \end{aligned}$$

$$\begin{aligned} p_{sh,y} (5.4d) &= 0.00261799 \\ A_{sh} &= A_{stir} * n_s = 78.53982 \\ \text{No stirrups, } n_s &= 2.00 \\ b_k &= 400.00 \end{aligned}$$

$$\begin{aligned} s &= 150.00 \\ f_{ywe} &= 555.55 \\ f_{ce} &= 20.00 \\ \text{From ((5.A5), TB DY), TB DY: } c_c &= 0.002 \\ c &= \text{confinement factor} = 1.00 \\ y_1 &= 0.00129669 \\ sh_1 &= 0.0044814 \\ ft_1 &= 373.4467 \\ fy_1 &= 311.2056 \\ su_1 &= 0.00512 \\ \text{using (30) in Biskinis/Fardis (2013) multiplied with shear_factor} \\ \text{and also multiplied by the shear_factor according to 15.7.1.4, with} \\ \text{Shear_factor} &= 1.00 \\ l_o/l_{ou,min} &= l_b/l_d = 0.30 \\ su_1 &= 0.4 * esu_1_{nominal} ((5.5), \text{TB DY}) = 0.032 \\ \text{From table 5A.1, TB DY: } esu_1_{nominal} &= 0.08, \\ \text{For calculation of } esu_1_{nominal} \text{ and } y_1, sh_1, ft_1, fy_1, \text{ it is considered} \\ \text{characteristic value } fsy_1 &= fs_1/1.2, \text{ from table 5.1, TB DY.} \\ y_1, sh_1, ft_1, fy_1, &\text{ are also multiplied by } \text{Min}(1, 1.25 * (l_b/l_d)^{2/3}), \text{ from 10.3.5, ASCE 41-17.} \end{aligned}$$

```

with fs1 = fs = 311.2056
with Es1 = Es = 200000.00
y2 = 0.00129669
sh2 = 0.0044814
ft2 = 373.4467
fy2 = 311.2056
su2 = 0.00512
using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00
lo/lou,min = lb/lb,min = 0.30
su2 = 0.4*esu2_nominal ((5.5), TBDY) = 0.032
From table 5A.1, TBDY: esu2_nominal = 0.08,
For calculation of esu2_nominal and y2, sh2,ft2,fy2, it is considered
characteristic value fsy2 = fs2/1.2, from table 5.1, TBDY.
y1, sh1,ft1,fy1, are also multiplied by Min(1,1.25*(lb/lb)^2/3), from 10.3.5, ASCE 41-17.
with fs2 = fs = 311.2056
with Es2 = Es = 200000.00
yv = 0.00129669
shv = 0.0044814
ftv = 373.4467
fyv = 311.2056
suv = 0.00512
using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00
lo/lou,min = lb/lb = 0.30
suv = 0.4*esuv_nominal ((5.5), TBDY) = 0.032
From table 5A.1, TBDY: esuv_nominal = 0.08,
considering characteristic value fsyv = fsv/1.2, from table 5.1, TBDY
For calculation of esuv_nominal and yv, shv,ftv,fyv, it is considered
characteristic value fsyv = fsv/1.2, from table 5.1, TBDY.
y1, sh1,ft1,fy1, are also multiplied by Min(1,1.25*(lb/lb)^2/3), from 10.3.5, ASCE 41-17.
with fsv = fs = 311.2056
with Esv = Es = 200000.00
1 = Asl,ten/(b*d)*(fs1/fc) = 0.08946101
2 = Asl,com/(b*d)*(fs2/fc) = 0.08763528
v = Asl,mid/(b*d)*(fsv/fc) = 0.04473051
and confined core properties:
b = 240.00
d = 327.00
d' = 12.00
fcc (5A.2, TBDY) = 20.00
cc (5A.5, TBDY) = 0.002
c = confinement factor = 1.00
1 = Asl,ten/(b*d)*(fs1/fc) = 0.12208556
2 = Asl,com/(b*d)*(fs2/fc) = 0.11959401
v = Asl,mid/(b*d)*(fsv/fc) = 0.06104278
Case/Assumption: Unconfined full section - Steel rupture
'satisfies Eq. (4.3)
--->
v < vs,y2 - LHS eq.(4.5) is satisfied
--->
su (4.9) = 0.20053711
Mu = MRc (4.14) = 8.1873E+007
u = su (4.1) = 1.7939215E-005

```

Calculation of ratio lb/lb

Inadequate Lap Length with lb/lb = 0.30

Calculation of Shear Strength $V_r = \text{Min}(V_{r1}, V_{r2}) = 227879.44$

Calculation of Shear Strength at edge 1, $V_{r1} = 227879.44$
 $V_{r1} = V_n$ ((22.5.1.1), ACI 318-14)

NOTE: In expression (22.5.1.1) ' V_w ' is replaced by ' $V_w + f^*V_f$ '
where V_f is the contribution of FRPs (11.3), ACI 440).

From Table (22.5.5.1), ACI 318-14: $V_c = 78946.167$
= 1 (normal-weight concrete)
 $f'_c = 20.00$, but $f'_c^{0.5} \leq 8.3$ MPa (22.5.3.1, ACI 318-14)
 $\rho_w = A_s/(b_w*d) = 0.00628319$
 A_s (tension reinf.) = 603.1858
 $b_w = 300.00$
 $d = 320.00$
 $V_u*d/\mu_u < 1 = 1.00$
 $\mu_u = 60442.822$
 $V_u = 4076.60$

From (11.5.4.8), ACI 318-14: $V_s = 148933.273$
 $A_v = 157079.633$
 $f_y = 444.44$
 $s = 150.00$
 V_s has been multiplied by 1 ($s < d/2$, according to ASCE 41-17,10.3.4)
 V_f ((11-3)-(11.4), ACI 440) = 0.00
From (11-11), ACI 440: $V_s + V_f \leq 285202.276$

Calculation of Shear Strength at edge 2, $V_{r2} = 227879.44$
 $V_{r2} = V_n$ ((22.5.1.1), ACI 318-14)

NOTE: In expression (22.5.1.1) ' V_w ' is replaced by ' $V_w + f^*V_f$ '
where V_f is the contribution of FRPs (11.3), ACI 440).

From Table (22.5.5.1), ACI 318-14: $V_c = 78946.167$
= 1 (normal-weight concrete)
 $f'_c = 20.00$, but $f'_c^{0.5} \leq 8.3$ MPa (22.5.3.1, ACI 318-14)
 $\rho_w = A_s/(b_w*d) = 0.00628319$
 A_s (tension reinf.) = 603.1858
 $b_w = 300.00$
 $d = 320.00$
 $V_u*d/\mu_u < 1 = 1.00$
 $\mu_u = 155096.693$
 $V_u = 4178.928$

From (11.5.4.8), ACI 318-14: $V_s = 148933.273$
 $A_v = 157079.633$
 $f_y = 444.44$
 $s = 150.00$
 V_s has been multiplied by 1 ($s < d/2$, according to ASCE 41-17,10.3.4)
 V_f ((11-3)-(11.4), ACI 440) = 0.00
From (11-11), ACI 440: $V_s + V_f \leq 285202.276$

End Of Calculation of Shear Capacity ratio for element: beam B1 of floor 1
At local axis: 3

Start Of Calculation of Shear Capacity ratio for element: beam B1 of floor 1
At Shear local axis: 2
(Bending local axis: 3)
Section Type: rcars

Constant Properties

Knowledge Factor, $\phi = 1.00$
Mean strength values are used for both shear and moment calculations.
Consequently:
Existing material of Secondary Member: Concrete Strength, $f_c = f_{cm} = 20.00$
Existing material of Secondary Member: Steel Strength, $f_s = f_{sm} = 444.44$
Concrete Elasticity, $E_c = 21019.039$

```

Steel Elasticity, Es = 200000.00
#####
Note: Especially for the calculation of moment strengths,
the above steel re-bar strengths are multiplied by 1.25 according to R18.6.5, ACI 318-14
Existing material: Steel Strength, fs = 1.25*fsm = 555.55
#####
Section Height, H = 400.00
Section Width, W = 300.00
Cover Thickness, c = 25.00
Mean Confinement Factor overall section = 1.00
Element Length, L = 1850.00
Secondary Member
Ribbed Bars
Ductile Steel
Without Detailing for Earthquake Resistance (including stirrups not closed at 135°)
Longitudinal Bars With Ends Lapped Starting at the End Sections
Inadequate Lap Length with lo/lo,min = 0.30
No FRP Wrapping
-----

Stepwise Properties
-----
At local axis: 2
EDGE -A-
Shear Force, Va = -1.0090939E-010
EDGE -B-
Shear Force, Vb = 1.0090939E-010
BOTH EDGES
Axial Force, F = -400.0832
Longitudinal Reinforcement Area Distribution (in 2 divisions)
  -Tension: Aslt = 603.1858
  -Compression: Aslc = 923.6282
Longitudinal Reinforcement Area Distribution (in 3 divisions)
  -Tension: Asl,ten = 508.938
  -Compression: Asl,com = 508.938
  -Middle: Asl,mid = 508.938
-----
-----

Calculation of Shear Capacity ratio , Ve/Vr = 0.37923485
Member Controlled by Flexure (Ve/Vr < 1)
Calculation of Shear Demand from fig. R18.6.5, ACI 318-14 Ve = (Mpr1 + Mpr2)/ln ± vu*ln/2 = 57820.79
with
Mpr1 = Max(Mu1+ , Mu1-) = 5.3484E+007
  Mu1+ = 5.3484E+007, is the ultimate moment strength at the edge 1 of the member in the actual moment direction
  which is defined for the static loading combination
  Mu1- = 5.3484E+007, is the ultimate moment strength at the edge 1 of the member in the opposite moment
  direction which is defined for the static loading combination
Mpr2 = Max(Mu2+ , Mu2-) = 5.3484E+007
  Mu2+ = 5.3484E+007, is the ultimate moment strength at the edge 2 of the member in the actual moment direction
  which is defined for the the static loading combination
  Mu2- = 5.3484E+007, is the ultimate moment strength at the edge 2 of the member in the opposite moment
  direction which is defined for the the static loading combination
and
± vu*ln = (|V1| + |V2|)/2
with
V1 = -1.0090939E-010, is the shear force acting at edge 1 for the the static loading combination
V2 = 1.0090939E-010, is the shear force acting at edge 2 for the the static loading combination
-----

Calculation of Mu1+
-----
-----

Calculation of ultimate curvature u according to 4.1, Biskinis/Fardis 2013:
u = 2.5364147E-005

```


$$\mu_u = 5.3484E+007$$

with full section properties:

$$b = 400.00$$

$$d = 258.00$$

$$d' = 42.00$$

$$v = 0.00019384$$

$$N = 400.0832$$

$$f_c = 20.00$$

$$\phi_c(5A.5, \text{TB DY}) = 0.002$$

$$\text{Final value of } \phi_{cu} = \phi_{cu}^* = \text{shear_factor} * \text{Max}(\phi_{cu}, \phi_{cc}) = 0.00583896$$

The Shear_factor is considered equal to 1 (pure moment strength)

$$\text{From (5.4b), TB DY: } \phi_{cu} = 0.00583896$$

$$\phi_{we}(5.4c) = 0.0034192$$

$$\phi_{ase}((5.4d), \text{TB DY}) = 0.15672608$$

$$b_o = 240.00$$

$$h_o = 340.00$$

$$b_i^2 = 346400.00$$

$$\phi_{psh,min} = \text{Min}(\phi_{psh,x}, \phi_{psh,y}) = 0.00261799$$

Expression ((5.4d), TB DY) for $\phi_{psh,min}$ has been multiplied by 0.3 according to 15.7.1.3 for members without earthquake detailing (90° closed stirrups)

$$\phi_{psh,x}(5.4d) = 0.00349066$$

$$A_{sh} = A_{stir} * n_s = 78.53982$$

$$\text{No stirrups, } n_s = 2.00$$

$$b_k = 300.00$$

$$\phi_{psh,y}(5.4d) = 0.00261799$$

$$A_{sh} = A_{stir} * n_s = 78.53982$$

$$\text{No stirrups, } n_s = 2.00$$

$$b_k = 400.00$$

$$s = 150.00$$

$$f_{ywe} = 555.55$$

$$f_{ce} = 20.00$$

$$\text{From ((5.A5), TB DY), TB DY: } \phi_{cc} = 0.002$$

$$c = \text{confinement factor} = 1.00$$

$$y_1 = 0.00129669$$

$$sh_1 = 0.0044814$$

$$f_{t1} = 373.4467$$

$$f_{y1} = 311.2056$$

$$su_1 = 0.00512$$

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor and also multiplied by the shear_factor according to 15.7.1.4, with Shear_factor = 1.00

$$l_o/l_{ou,min} = l_b/l_d = 0.30$$

$$su_1 = 0.4 * esu1_nominal((5.5), \text{TB DY}) = 0.032$$

$$\text{From table 5A.1, TB DY: } esu1_nominal = 0.08,$$

For calculation of $esu1_nominal$ and y_1 , sh_1 , f_{t1} , f_{y1} , it is considered characteristic value $f_{sy1} = f_{s1}/1.2$, from table 5.1, TB DY.

y_1 , sh_1 , f_{t1} , f_{y1} , are also multiplied by $\text{Min}(1, 1.25 * (l_b/l_d)^{2/3})$, from 10.3.5, ASCE 41-17.

$$\text{with } f_{s1} = f_s = 311.2056$$

$$\text{with } E_{s1} = E_s = 200000.00$$

$$y_2 = 0.00129669$$

$$sh_2 = 0.0044814$$

$$f_{t2} = 373.4467$$

$$f_{y2} = 311.2056$$

$$su_2 = 0.00512$$

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor and also multiplied by the shear_factor according to 15.7.1.4, with Shear_factor = 1.00

$$l_o/l_{ou,min} = l_b/l_{b,min} = 0.30$$

$$su_2 = 0.4 * esu2_nominal((5.5), \text{TB DY}) = 0.032$$

$$\text{From table 5A.1, TB DY: } esu2_nominal = 0.08,$$

For calculation of $esu2_nominal$ and y_2 , sh_2 , f_{t2} , f_{y2} , it is considered characteristic value $f_{sy2} = f_{s2}/1.2$, from table 5.1, TB DY.

y_1 , sh_1 , f_{t1} , f_{y1} , are also multiplied by $\text{Min}(1, 1.25 * (l_b/l_d)^{2/3})$, from 10.3.5, ASCE 41-17.

```

with fs2 = fs = 311.2056
with Es2 = Es = 200000.00
yv = 0.00129669
shv = 0.0044814
ftv = 373.4467
fyv = 311.2056
suv = 0.00512
using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00
lo/lou,min = lb/ld = 0.30
suv = 0.4*esuv_nominal ((5.5), TBDY) = 0.032
From table 5A.1, TBDY: esuv_nominal = 0.08,
considering characteristic value fsyv = fsv/1.2, from table 5.1, TBDY
For calculation of esuv_nominal and yv, shv,ftv,fyv, it is considered
characteristic value fsyv = fsv/1.2, from table 5.1, TBDY.
y1, sh1,ft1,fy1, are also multiplied by Min(1,1.25*(lb/ld)^2/3), from 10.3.5, ASCE 41-17.
with fsv = fs = 311.2056
with Esv = Es = 200000.00
1 = Asl,ten/(b*d)*(fs1/fc) = 0.0767366
2 = Asl,com/(b*d)*(fs2/fc) = 0.0767366
v = Asl,mid/(b*d)*(fsv/fc) = 0.0767366
and confined core properties:
b = 340.00
d = 228.00
d' = 12.00
fcc (5A.2, TBDY) = 20.00
cc (5A.5, TBDY) = 0.002
c = confinement factor = 1.00
1 = Asl,ten/(b*d)*(fs1/fc) = 0.10215708
2 = Asl,com/(b*d)*(fs2/fc) = 0.10215708
v = Asl,mid/(b*d)*(fsv/fc) = 0.10215708
Case/Assumption: Unconfined full section - Steel rupture
' satisfies Eq. (4.3)
--->
v < vs,y2 - LHS eq.(4.5) is satisfied
--->
su (4.9) = 0.21759794
Mu = MRc (4.14) = 5.3484E+007
u = su (4.1) = 2.5364147E-005

```

Calculation of ratio lb/ld

Inadequate Lap Length with lb/ld = 0.30

Calculation of Mu1-

Calculation of ultimate curvature u according to 4.1, Biskinis/Fardis 2013:

```

u = 2.5364147E-005
Mu = 5.3484E+007

```

with full section properties:

```

b = 400.00
d = 258.00
d' = 42.00
v = 0.00019384
N = 400.0832
fc = 20.00
co (5A.5, TBDY) = 0.002
Final value of cu: cu* = shear_factor * Max( cu, cc) = 0.00583896
The Shear_factor is considered equal to 1 (pure moment strength)
From (5.4b), TBDY: cu = 0.00583896

```

w_e (5.4c) = 0.0034192
 a_{se} ((5.4d), TBDY) = 0.15672608
 b_o = 240.00
 h_o = 340.00
 b_{i2} = 346400.00
 $p_{sh,min}$ = $\text{Min}(p_{sh,x}, p_{sh,y})$ = 0.00261799
 Expression ((5.4d), TBDY) for $p_{sh,min}$ has been multiplied by 0.3 according to 15.7.1.3 for members without earthquake detailing (90° closed stirrups)

$p_{sh,x}$ (5.4d) = 0.00349066
 A_{sh} = $A_{stir} \cdot n_s$ = 78.53982
 No stirrups, n_s = 2.00
 b_k = 300.00

$p_{sh,y}$ (5.4d) = 0.00261799
 A_{sh} = $A_{stir} \cdot n_s$ = 78.53982
 No stirrups, n_s = 2.00
 b_k = 400.00

s = 150.00
 f_{ywe} = 555.55
 f_{ce} = 20.00
 From ((5.A5), TBDY), TBDY: c_c = 0.002
 c = confinement factor = 1.00
 y_1 = 0.00129669
 sh_1 = 0.0044814
 ft_1 = 373.4467
 fy_1 = 311.2056
 su_1 = 0.00512
 using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
 and also multiplied by the shear_factor according to 15.7.1.4, with
 Shear_factor = 1.00
 $l_o/l_{ou,min}$ = l_b/l_d = 0.30
 su_1 = $0.4 \cdot esu1_{nominal}$ ((5.5), TBDY) = 0.032
 From table 5A.1, TBDY: $esu1_{nominal}$ = 0.08,
 For calculation of $esu1_{nominal}$ and y_1, sh_1, ft_1, fy_1 , it is considered
 characteristic value fsy_1 = $fs_1/1.2$, from table 5.1, TBDY.
 y_1, sh_1, ft_1, fy_1 , are also multiplied by $\text{Min}(1, 1.25 \cdot (l_b/l_d)^{2/3})$, from 10.3.5, ASCE 41-17.
 with fs_1 = fs = 311.2056
 with Es_1 = Es = 200000.00
 y_2 = 0.00129669
 sh_2 = 0.0044814
 ft_2 = 373.4467
 fy_2 = 311.2056
 su_2 = 0.00512
 using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
 and also multiplied by the shear_factor according to 15.7.1.4, with
 Shear_factor = 1.00
 $l_o/l_{ou,min}$ = $l_b/l_{b,min}$ = 0.30
 su_2 = $0.4 \cdot esu2_{nominal}$ ((5.5), TBDY) = 0.032
 From table 5A.1, TBDY: $esu2_{nominal}$ = 0.08,
 For calculation of $esu2_{nominal}$ and y_2, sh_2, ft_2, fy_2 , it is considered
 characteristic value fsy_2 = $fs_2/1.2$, from table 5.1, TBDY.
 y_2, sh_2, ft_2, fy_2 , are also multiplied by $\text{Min}(1, 1.25 \cdot (l_b/l_d)^{2/3})$, from 10.3.5, ASCE 41-17.
 with fs_2 = fs = 311.2056
 with Es_2 = Es = 200000.00
 y_v = 0.00129669
 sh_v = 0.0044814
 ft_v = 373.4467
 fy_v = 311.2056
 suv = 0.00512
 using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
 and also multiplied by the shear_factor according to 15.7.1.4, with
 Shear_factor = 1.00
 $l_o/l_{ou,min}$ = l_b/l_d = 0.30
 suv = $0.4 \cdot esuv_{nominal}$ ((5.5), TBDY) = 0.032
 From table 5A.1, TBDY: $esuv_{nominal}$ = 0.08,

considering characteristic value $f_{sv} = f_{sv}/1.2$, from table 5.1, TBDY
For calculation of $e_{sv_nominal}$ and y_v , sh_v , ft_v , fy_v , it is considered
characteristic value $f_{sv} = f_{sv}/1.2$, from table 5.1, TBDY.

y_1 , sh_1 , ft_1 , fy_1 , are also multiplied by $\text{Min}(1, 1.25 \cdot (l_b/l_d)^{2/3})$, from 10.3.5, ASCE 41-17.

with $f_{sv} = f_s = 311.2056$

with $E_{sv} = E_s = 200000.00$

1 = $A_{sl,ten}/(b \cdot d) \cdot (f_{s1}/f_c) = 0.0767366$

2 = $A_{sl,com}/(b \cdot d) \cdot (f_{s2}/f_c) = 0.0767366$

$v = A_{sl,mid}/(b \cdot d) \cdot (f_{sv}/f_c) = 0.0767366$

and confined core properties:

$b = 340.00$

$d = 228.00$

$d' = 12.00$

f_{cc} (5A.2, TBDY) = 20.00

cc (5A.5, TBDY) = 0.002

c = confinement factor = 1.00

1 = $A_{sl,ten}/(b \cdot d) \cdot (f_{s1}/f_c) = 0.10215708$

2 = $A_{sl,com}/(b \cdot d) \cdot (f_{s2}/f_c) = 0.10215708$

$v = A_{sl,mid}/(b \cdot d) \cdot (f_{sv}/f_c) = 0.10215708$

Case/Assumption: Unconfined full section - Steel rupture

' satisfies Eq. (4.3)

--->

$v < v_{s,y2}$ - LHS eq.(4.5) is satisfied

--->

su (4.9) = 0.21759794

$Mu = MR_c$ (4.14) = 5.3484E+007

$u = su$ (4.1) = 2.5364147E-005

Calculation of ratio l_b/l_d

Inadequate Lap Length with $l_b/l_d = 0.30$

Calculation of Mu_{2+}

Calculation of ultimate curvature u according to 4.1, Biskinis/Fardis 2013:

$u = 2.5364147E-005$

$Mu = 5.3484E+007$

with full section properties:

$b = 400.00$

$d = 258.00$

$d' = 42.00$

$v = 0.00019384$

$N = 400.0832$

$f_c = 20.00$

co (5A.5, TBDY) = 0.002

Final value of cu : $cu^* = \text{shear_factor} \cdot \text{Max}(cu, cc) = 0.00583896$

The Shear_factor is considered equal to 1 (pure moment strength)

From (5.4b), TBDY: $cu = 0.00583896$

w_e (5.4c) = 0.0034192

ase ((5.4d), TBDY) = 0.15672608

$bo = 240.00$

$ho = 340.00$

$bi_2 = 346400.00$

$psh,min = \text{Min}(psh,x, psh,y) = 0.00261799$

Expression ((5.4d), TBDY) for psh,min has been multiplied by 0.3 according to 15.7.1.3 for members without earthquake detailing (90° closed stirrups)

psh,x (5.4d) = 0.00349066

$A_{sh} = A_{stir} \cdot n_s = 78.53982$

No stirrups, $n_s = 2.00$

$bk = 300.00$

psh,y (5.4d) = 0.00261799
 Ash = Astir*ns = 78.53982
 No stirups, ns = 2.00
 bk = 400.00

s = 150.00
 fywe = 555.55
 fce = 20.00

From ((5.A5), TBDY), TBDY: cc = 0.002
 c = confinement factor = 1.00

y1 = 0.00129669
 sh1 = 0.0044814
 ft1 = 373.4467
 fy1 = 311.2056
 su1 = 0.00512

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
 and also multiplied by the shear_factor according to 15.7.1.4, with
 Shear_factor = 1.00

lo/lou,min = lb/lb,min = 0.30

su1 = 0.4*esu1_nominal ((5.5), TBDY) = 0.032

From table 5A.1, TBDY: esu1_nominal = 0.08,

For calculation of esu1_nominal and y1, sh1,ft1,fy1, it is considered
 characteristic value fsy1 = fs1/1.2, from table 5.1, TBDY.

y1, sh1,ft1,fy1, are also multiplied by $\text{Min}(1, 1.25 \cdot (lb/lb)^{2/3})$, from 10.3.5, ASCE 41-17.

with fs1 = fs = 311.2056

with Es1 = Es = 200000.00

y2 = 0.00129669
 sh2 = 0.0044814
 ft2 = 373.4467
 fy2 = 311.2056
 su2 = 0.00512

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
 and also multiplied by the shear_factor according to 15.7.1.4, with
 Shear_factor = 1.00

lo/lou,min = lb/lb,min = 0.30

su2 = 0.4*esu2_nominal ((5.5), TBDY) = 0.032

From table 5A.1, TBDY: esu2_nominal = 0.08,

For calculation of esu2_nominal and y2, sh2,ft2,fy2, it is considered
 characteristic value fsy2 = fs2/1.2, from table 5.1, TBDY.

y1, sh1,ft1,fy1, are also multiplied by $\text{Min}(1, 1.25 \cdot (lb/lb)^{2/3})$, from 10.3.5, ASCE 41-17.

with fs2 = fs = 311.2056

with Es2 = Es = 200000.00

yv = 0.00129669
 shv = 0.0044814
 ftv = 373.4467
 fyv = 311.2056
 suv = 0.00512

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
 and also multiplied by the shear_factor according to 15.7.1.4, with
 Shear_factor = 1.00

lo/lou,min = lb/lb,min = 0.30

suv = 0.4*esuv_nominal ((5.5), TBDY) = 0.032

From table 5A.1, TBDY: esuv_nominal = 0.08,

considering characteristic value fsyv = fsv/1.2, from table 5.1, TBDY

For calculation of esuv_nominal and yv, shv,ftv,fyv, it is considered
 characteristic value fsyv = fsv/1.2, from table 5.1, TBDY.

y1, sh1,ft1,fy1, are also multiplied by $\text{Min}(1, 1.25 \cdot (lb/lb)^{2/3})$, from 10.3.5, ASCE 41-17.

with fsv = fs = 311.2056

with Esv = Es = 200000.00

1 = Asl,ten/(b*d)*(fs1/fc) = 0.0767366

2 = Asl,com/(b*d)*(fs2/fc) = 0.0767366

v = Asl,mid/(b*d)*(fsv/fc) = 0.0767366

and confined core properties:

b = 340.00
 d = 228.00
 d' = 12.00

```

fcc (5A.2, TBDY) = 20.00
cc (5A.5, TBDY) = 0.002
c = confinement factor = 1.00
1 = Asl,ten/(b*d)*(fs1/fc) = 0.10215708
2 = Asl,com/(b*d)*(fs2/fc) = 0.10215708
v = Asl,mid/(b*d)*(fsv/fc) = 0.10215708
Case/Assumption: Unconfined full section - Steel rupture
' satisfies Eq. (4.3)
--->
v < vs,y2 - LHS eq.(4.5) is satisfied
--->
su (4.9) = 0.21759794
Mu = MRc (4.14) = 5.3484E+007
u = su (4.1) = 2.5364147E-005

```

Calculation of ratio lb/ld

Inadequate Lap Length with lb/ld = 0.30

Calculation of Mu2-

Calculation of ultimate curvature u according to 4.1, Biskinis/Fardis 2013:

u = 2.5364147E-005

Mu = 5.3484E+007

with full section properties:

b = 400.00

d = 258.00

d' = 42.00

v = 0.00019384

N = 400.0832

fc = 20.00

co (5A.5, TBDY) = 0.002

Final value of cu: cu* = shear_factor * Max(cu, cc) = 0.00583896

The Shear_factor is considered equal to 1 (pure moment strength)

From (5.4b), TBDY: cu = 0.00583896

we (5.4c) = 0.0034192

ase ((5.4d), TBDY) = 0.15672608

bo = 240.00

ho = 340.00

bi2 = 346400.00

psh,min = Min(psh,x , psh,y) = 0.00261799

Expression ((5.4d), TBDY) for psh,min has been multiplied by 0.3 according to 15.7.1.3 for members without earthquake detailing (90° closed stirrups)

psh,x (5.4d) = 0.00349066

Ash = Astir*ns = 78.53982

No stirups, ns = 2.00

bk = 300.00

psh,y (5.4d) = 0.00261799

Ash = Astir*ns = 78.53982

No stirups, ns = 2.00

bk = 400.00

s = 150.00

fywe = 555.55

fce = 20.00

From ((5.A5), TBDY), TBDY: cc = 0.002

c = confinement factor = 1.00

y1 = 0.00129669

sh1 = 0.0044814

```

ft1 = 373.4467
fy1 = 311.2056
su1 = 0.00512
    using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
    and also multiplied by the shear_factor according to 15.7.1.4, with
    Shear_factor = 1.00
    lo/lou,min = lb/lb,min = 0.30
    su1 = 0.4*esu1_nominal ((5.5), TBDY) = 0.032
    From table 5A.1, TBDY: esu1_nominal = 0.08,
    For calculation of esu1_nominal and y1, sh1,ft1,fy1, it is considered
    characteristic value fsy1 = fs1/1.2, from table 5.1, TBDY.
    y1, sh1,ft1,fy1, are also multiplied by Min(1,1.25*(lb/lb)^ 2/3), from 10.3.5, ASCE 41-17.
    with fs1 = fs = 311.2056
    with Es1 = Es = 200000.00
y2 = 0.00129669
sh2 = 0.0044814
ft2 = 373.4467
fy2 = 311.2056
su2 = 0.00512
    using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
    and also multiplied by the shear_factor according to 15.7.1.4, with
    Shear_factor = 1.00
    lo/lou,min = lb/lb,min = 0.30
    su2 = 0.4*esu2_nominal ((5.5), TBDY) = 0.032
    From table 5A.1, TBDY: esu2_nominal = 0.08,
    For calculation of esu2_nominal and y2, sh2,ft2,fy2, it is considered
    characteristic value fsy2 = fs2/1.2, from table 5.1, TBDY.
    y1, sh1,ft1,fy1, are also multiplied by Min(1,1.25*(lb/lb)^ 2/3), from 10.3.5, ASCE 41-17.
    with fs2 = fs = 311.2056
    with Es2 = Es = 200000.00
yv = 0.00129669
shv = 0.0044814
ftv = 373.4467
fyv = 311.2056
suv = 0.00512
    using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
    and also multiplied by the shear_factor according to 15.7.1.4, with
    Shear_factor = 1.00
    lo/lou,min = lb/lb,min = 0.30
    suv = 0.4*esuv_nominal ((5.5), TBDY) = 0.032
    From table 5A.1, TBDY: esuv_nominal = 0.08,
    considering characteristic value fsyv = fsv/1.2, from table 5.1, TBDY
    For calculation of esuv_nominal and yv, shv,ftv,fyv, it is considered
    characteristic value fsyv = fsv/1.2, from table 5.1, TBDY.
    y1, sh1,ft1,fy1, are also multiplied by Min(1,1.25*(lb/lb)^ 2/3), from 10.3.5, ASCE 41-17.
    with fsv = fs = 311.2056
    with Esv = Es = 200000.00
1 = Asl,ten/(b*d)*(fs1/fc) = 0.0767366
2 = Asl,com/(b*d)*(fs2/fc) = 0.0767366
v = Asl,mid/(b*d)*(fsv/fc) = 0.0767366
and confined core properties:
b = 340.00
d = 228.00
d' = 12.00
fcc (5A.2, TBDY) = 20.00
cc (5A.5, TBDY) = 0.002
    c = confinement factor = 1.00
    1 = Asl,ten/(b*d)*(fs1/fc) = 0.10215708
    2 = Asl,com/(b*d)*(fs2/fc) = 0.10215708
    v = Asl,mid/(b*d)*(fsv/fc) = 0.10215708
Case/Assumption: Unconfined full section - Steel rupture
' satisfies Eq. (4.3)
--->
v < vs,y2 - LHS eq.(4.5) is satisfied
--->
su (4.9) = 0.21759794
Mu = MRc (4.14) = 5.3484E+007

```

$$u = su(4.1) = 2.5364147E-005$$

Calculation of ratio l_b/l_d

Inadequate Lap Length with $l_b/l_d = 0.30$

Calculation of Shear Strength $V_r = \text{Min}(V_{r1}, V_{r2}) = 152466.975$

Calculation of Shear Strength at edge 1, $V_{r1} = 152466.975$
 $V_{r1} = V_n ((22.5.1.1), \text{ACI } 318-14)$

NOTE: In expression (22.5.1.1) ' V_w ' is replaced by ' $V_w + f^*V_f$ '
 where V_f is the contribution of FRPs (11.3), ACI 440).

From Table (22.5.5.1), ACI 318-14: $V_c = 68692.008$
 $= 1$ (normal-weight concrete)
 $f_c' = 20.00$, but $f_c'^{0.5} \leq 8.3$ MPa (22.5.3.1, ACI 318-14)
 $\rho_w = A_s/(b_w*d) = 0.00628319$
 A_s (tension reinf.) = 603.1858
 $b_w = 400.00$
 $d = 240.00$
 $V_u*d/M_u < 1 = 0.00$
 $M_u = 2.0746991E-007$
 $V_u = 1.0090939E-010$

From (11.5.4.8), ACI 318-14: $V_s = 83774.966$
 $A_v = 157079.633$
 $f_y = 444.44$
 $s = 150.00$
 V_s has been multiplied by $2(1-s/d)$ ($s > d/2$, according to ASCE 41-17,10.3.4)
 $2(1-s/d) = 0.75$
 $V_f ((11-3)-(11.4), \text{ACI } 440) = 0.00$
 From (11-11), ACI 440: $V_s + V_f \leq 285202.276$

Calculation of Shear Strength at edge 2, $V_{r2} = 152466.975$
 $V_{r2} = V_n ((22.5.1.1), \text{ACI } 318-14)$

NOTE: In expression (22.5.1.1) ' V_w ' is replaced by ' $V_w + f^*V_f$ '
 where V_f is the contribution of FRPs (11.3), ACI 440).

From Table (22.5.5.1), ACI 318-14: $V_c = 68692.008$
 $= 1$ (normal-weight concrete)
 $f_c' = 20.00$, but $f_c'^{0.5} \leq 8.3$ MPa (22.5.3.1, ACI 318-14)
 $\rho_w = A_s/(b_w*d) = 0.00628319$
 A_s (tension reinf.) = 603.1858
 $b_w = 400.00$
 $d = 240.00$
 $V_u*d/M_u < 1 = 0.00$
 $M_u = 2.0781750E-008$
 $V_u = 1.0090939E-010$

From (11.5.4.8), ACI 318-14: $V_s = 83774.966$
 $A_v = 157079.633$
 $f_y = 444.44$
 $s = 150.00$
 V_s has been multiplied by $2(1-s/d)$ ($s > d/2$, according to ASCE 41-17,10.3.4)
 $2(1-s/d) = 0.75$
 $V_f ((11-3)-(11.4), \text{ACI } 440) = 0.00$
 From (11-11), ACI 440: $V_s + V_f \leq 285202.276$

End Of Calculation of Shear Capacity ratio for element: beam B1 of floor 1
 At local axis: 2

Start Of Calculation of Chord Rotation Capacity for element: beam B1 of floor 1

At local axis: 2

Integration Section: (a)

Section Type: rcars

Constant Properties

Knowledge Factor, $\phi = 1.00$

Chord Rotation is generally considered as Deformation-Controlled Action according to Table C7-1, ASCE 41-17.

Mean strengths are used for Deformation-Controlled Actions according to 7.5.1.3, ASCE 41-17

Consequently:

Existing material of Secondary Member: Concrete Strength, $f_c = f_{cm} = 20.00$

Existing material of Secondary Member: Steel Strength, $f_s = f_{sm} = 444.44$

Concrete Elasticity, $E_c = 21019.039$

Steel Elasticity, $E_s = 200000.00$

Section Height, $H = 400.00$

Section Width, $W = 300.00$

Cover Thickness, $c = 25.00$

Element Length, $L = 1850.00$

Secondary Member

Ribbed Bars

Ductile Steel

Without Detailing for Earthquake Resistance (including stirrups not closed at 135°)

Longitudinal Bars With Ends Lapped Starting at the End Sections

Inadequate Lap Length with $l_b/l_d = 0.30$

No FRP Wrapping

Stepwise Properties

Bending Moment, $M = 5.4241E+006$

Shear Force, $V_2 = -5.1634141E-008$

Shear Force, $V_3 = -2275.035$

Axial Force, $F = -1219.269$

Longitudinal Reinforcement Area Distribution (in 2 divisions)

-Tension: $A_{st} = 603.1858$

-Compression: $A_{sc} = 923.6282$

Longitudinal Reinforcement Area Distribution (in 3 divisions)

-Tension: $A_{st,ten} = 603.1858$

-Compression: $A_{sc,com} = 615.7522$

-Middle: $A_{st,mid} = 307.8761$

Mean Diameter of Tension Reinforcement, $D_bL = 16.00$

Existing component: From table 7-7, ASCE 41_17: Final chord rotation Capacity $\phi_{u,R} = \phi_u = 0.02441198$

$\phi_u = \phi_y + \phi_p = 0.02441198$

- Calculation of ϕ_y -

$\phi_y = (M_y * L_s / 3) / E_{eff} = 0.00441198$ ((4.29), Biskinis Phd))

$M_y = 5.6011E+007$

$L_s = M/V$ (with $L_s > 0.1 * L$ and $L_s < 2 * L$) = 2384.162

From table 10.5, ASCE 41_17: $E_{eff} = 0.3 * E_c * I_g = 1.0089E+013$

Calculation of Yielding Moment M_y

Calculation of ϕ_y and M_y according to Annex 7 -

$\phi_y = \min(\phi_{y,ten}, \phi_{y,com})$

$\phi_{y,ten} = 4.8177533E-006$

with ((10.1), ASCE 41-17) $f_y = \min(f_y, 1.25 * f_y * (l_b/l_d)^{2/3}) = 248.9644$

$d = 357.00$
 $y = 0.27624004$
 $A = 0.01430169$
 $B = 0.00796053$
 with $p_t = 0.00563199$
 $p_c = 0.00574932$
 $p_v = 0.00287466$
 $N = 1219.269$
 $b = 300.00$
 $" = 0.11764706$
 $y_{comp} = 1.7402253E-005$
 with $f_c = 20.00$
 $E_c = 21019.039$
 $y = 0.27568679$
 $A = 0.01422273$
 $B = 0.00791481$
 with $E_s = 200000.00$

Calculation of ratio I_b/I_d

Inadequate Lap Length with $I_b/I_d = 0.30$

- Calculation of p -

From table 10-7: $p = 0.02$

with:

- Condition iv occurred

Beam controlled by inadequate embedment into beam-column joint:
 $(I_b/I_d < 1$ and With Lapping in the Vicinity of the End Regions

- Condition i occurred

Beam controlled by flexure: $V_p/V_o \leq 1$

shear control ratio $V_p/V_o = 0.40672566$

- Transverse Reinforcement: NC

- Stirrup Spacing $> d/3$

- Low ductility demand, $\lambda / y < 2$ (table 10-6, ASCE 41-17)
 $= 6.8202775E-005$

- Stirrup Spacing $\leq d/2$

$d = 357.00$

$s = 150.00$

- Strength provided by hoops $V_s < 3/4 \times \text{design Shear}$

$V_s = 148933.273$, already given in calculation of shear control ratio

design Shear = 2275.035

- $(\lambda - \lambda') / \lambda = -0.160191$

$= A_{sl}/(b_w \cdot d) = 0.00563199$

Tension Reinf Area: $A_{sl} = 603.1858$

$\lambda' = A_{slc}/(b_w \cdot d) = 0.00862398$

Compression Reinf Area: $A_{slc} = 923.6282$

From (B-1), ACI 318-11: $\lambda = 0.01867766$

$f_c = 20.00$

$f_y = 444.44$

From 10.2.7.3, ACI 318-11: $\lambda = 0.85$

From fig R10.3.3, ACI 318-11 (Ence 454, too): $87000/(87000 + f_y) = c_b/d_t = 0.003/(0.003 + y) = 0.57447053$
 $y = 0.0022222$

- $V/(b_w \cdot d \cdot f_c^{0.5}) = 0.05720144$, NOTE: units in lb & in

$b_w = 300.00$

End Of Calculation of Chord Rotation Capacity for element: beam B1 of floor 1

At local axis: 2

Integration Section: (a)

Calculation No. 11

beam B1, Floor 1



Limit State: Life Safety (data interpolation between analysis steps 1 and 2)

Analysis: Uniform +X

Check: Shear capacity VR_d

Edge: Start

Local Axis: (3)



Start Of Calculation of Shear Capacity for element: beam B1 of floor 1

At local axis: 3

Integration Section: (a)

Section Type: rcars

Constant Properties

Knowledge Factor, $\gamma = 1.00$

Member Shear Force is generally considered as Force-Controlled Action according to Table C7-1, ASCE 41-17.

Lower-bound strengths are used for Force-Controlled Actions according to 7.5.1.3, ASCE 41-17

Consequently:

Existing material of Secondary Member: Concrete Strength, $f_c = f_{c_lower_bound} = 16.00$

Existing material of Secondary Member: Steel Strength, $f_s = f_{s_lower_bound} = 400.00$

Concrete Elasticity, $E_c = 21019.039$

Steel Elasticity, $E_s = 200000.00$

Section Height, $H = 400.00$

Section Width, $W = 300.00$

Cover Thickness, $c = 25.00$

Element Length, $L = 1850.00$

Secondary Member

Ribbed Bars

Ductile Steel

Without Detailing for Earthquake Resistance (including stirrups not closed at 135°)

Longitudinal Bars With Ends Lapped Starting at the End Sections

Inadequate Lap Length with $l_o/l_{ou,min} = l_b/l_d = 0.30$

No FRP Wrapping

Stepwise Properties

EDGE -A-
 Bending Moment, $M_a = 5.4241\text{E}+006$
 Shear Force, $V_a = -2275.035$
 EDGE -B-
 Bending Moment, $M_b = 6.4211\text{E}+006$
 Shear Force, $V_b = 10530.564$
 BOTH EDGES
 Axial Force, $F = -1219.269$
 Longitudinal Reinforcement Area Distribution (in 2 divisions)
 -Tension: $A_{st} = 603.1858$
 -Compression: $A_{sc} = 923.6282$
 Longitudinal Reinforcement Area Distribution (in 3 divisions)
 -Tension: $A_{st,ten} = 603.1858$
 -Compression: $A_{sc,com} = 615.7522$
 -Middle: $A_{sc,mid} = 307.8761$
 Mean Diameter of Tension Reinforcement, $D_{bL,ten} = 16.00$

Existing component: From table 7-7, ASCE 41_17: Final Shear Capacity $V_R = V_n = 196857.59$
 $V_n ((22.5.1.1), \text{ACI } 318-14) = 196857.59$

NOTE: In expression (22.5.1.1) ' V_w ' is replaced by ' $V_w + f_v V_f$ '
 where V_f is the contribution of FRPs (11.3), ACI 440).

From Table (22.5.5.1), ACI 318-14: $V_c = 62816.303$
 = 1 (normal-weight concrete)
 $f_c' = 16.00$, but $f_c'^{0.5} \leq 8.3 \text{ MPa}$ (22.5.3.1, ACI 318-14)
 $\rho_w = A_s / (b_w \cdot d) = 0.00628319$
 A_s (tension reinf.) = 603.1858
 $b_w = 300.00$
 $d = 320.00$
 $V_u \cdot d / M_u < 1 = 0.13421905$
 $M_u = 5.4241\text{E}+006$
 $V_u = 2275.035$
 From (11.5.4.8), ACI 318-14: $V_s = 134041.287$
 $A_v = 157079.633$
 $f_y = 400.00$
 $s = 150.00$
 V_s has been multiplied by 1 ($s < d/2$, according to ASCE 41-17, 10.3.4)
 $V_f ((11-3)-(11.4), \text{ACI } 440) = 0.00$
 From (11-11), ACI 440: $V_s + V_f \leq 255092.67$

End Of Calculation of Shear Capacity for element: beam B1 of floor 1
 At local axis: 3
 Integration Section: (a)

Calculation No. 12

beam B1, Floor 1


Limit State: Life Safety (data interpolation between analysis steps 1 and 2)

Analysis: Uniform +X

Check: Chord rotation capacity (μ)

Edge: Start

Local Axis: (3)



Start Of Calculation of Shear Capacity ratio for element: beam B1 of floor 1

At Shear local axis: 3

(Bending local axis: 2)

Section Type: rcars

Constant Properties

Knowledge Factor, $\gamma = 1.00$

Mean strength values are used for both shear and moment calculations.

Consequently:

Existing material of Secondary Member: Concrete Strength, $f_c = f_{cm} = 20.00$

Existing material of Secondary Member: Steel Strength, $f_s = f_{sm} = 444.44$

Concrete Elasticity, $E_c = 21019.039$

Steel Elasticity, $E_s = 200000.00$

#####

Note: Especially for the calculation of moment strengths,

the above steel re-bar strengths are multiplied by 1.25 according to R18.6.5, ACI 318-14

Existing material: Steel Strength, $f_s = 1.25 \cdot f_{sm} = 555.55$

#####

Section Height, $H = 400.00$

Section Width, $W = 300.00$

Cover Thickness, $c = 25.00$

Mean Confinement Factor overall section = 1.00

Element Length, $L = 1850.00$

Secondary Member

Ribbed Bars

Ductile Steel

Without Detailing for Earthquake Resistance (including stirrups not closed at 135°)

Longitudinal Bars With Ends Lapped Starting at the End Sections

Inadequate Lap Length with $l_o/l_{ou,min} = 0.30$

No FRP Wrapping

Stepwise Properties

At local axis: 3

EDGE -A-

Shear Force, $V_a = 4076.60$

EDGE -B-

Shear Force, $V_b = 4178.928$
 BOTH EDGES
 Axial Force, $F = -400.0832$
 Longitudinal Reinforcement Area Distribution (in 2 divisions)
 -Tension: $As_t = 603.1858$
 -Compression: $As_c = 923.6282$
 Longitudinal Reinforcement Area Distribution (in 3 divisions)
 -Tension: $As_{t,ten} = 603.1858$
 -Compression: $As_{c,com} = 615.7522$
 -Middle: $As_{mid} = 307.8761$

 Calculation of Shear Capacity ratio, $V_e/V_r = 0.40672566$
 Member Controlled by Flexure ($V_e/V_r < 1$)
 Calculation of Shear Demand from fig. R18.6.5, ACI 318-14 $V_e = (M_{pr1} + M_{pr2})/l_n \pm w_u \cdot l_n/2 = 92684.415$
 with
 $M_{pr1} = \text{Max}(\mu_{u1+}, \mu_{u1-}) = 8.1957E+007$
 $\mu_{u1+} = 8.0451E+007$, is the ultimate moment strength at the edge 1 of the member in the actual moment direction
 which is defined for the static loading combination
 $\mu_{u1-} = 8.1957E+007$, is the ultimate moment strength at the edge 1 of the member in the opposite moment
 direction which is defined for the static loading combination
 $M_{pr2} = \text{Max}(\mu_{u2+}, \mu_{u2-}) = 8.1873E+007$
 $\mu_{u2+} = 8.0533E+007$, is the ultimate moment strength at the edge 2 of the member in the actual moment direction
 which is defined for the the static loading combination
 $\mu_{u2-} = 8.1873E+007$, is the ultimate moment strength at the edge 2 of the member in the opposite moment
 direction which is defined for the the static loading combination
 and
 $\pm w_u \cdot l_n = (|V_1| + |V_2|)/2$
 with
 $V_1 = 4076.60$, is the shear force acting at edge 1 for the the static loading combination
 $V_2 = 4178.928$, is the shear force acting at edge 2 for the the static loading combination

 Calculation of μ_{u1+}

 Calculation of ultimate curvature μ_u according to 4.1, Biskinis/Fardis 2013:

$\mu_u = 1.7899831E-005$
 $\mu_u = 8.0451E+007$

 with full section properties:

$b = 300.00$
 $d = 357.00$
 $d' = 42.00$
 $v = 0.00018678$
 $N = 400.0832$
 $f_c = 20.00$
 ϕ_c (5A.5, TBDY) = 0.002
 Final value of ϕ_c : $\phi_c^* = \text{shear_factor} \cdot \text{Max}(\phi_c, \phi_c) = 0.00583896$
 The Shear_factor is considered equal to 1 (pure moment strength)
 From (5.4b), TBDY: $\phi_c = 0.00583896$
 ϕ_w (5.4c) = 0.0034192
 ϕ_{se} ((5.4d), TBDY) = 0.15672608
 $b_o = 240.00$
 $h_o = 340.00$
 $b_{i2} = 346400.00$
 $\phi_{sh,min} = \text{Min}(\phi_{sh,x}, \phi_{sh,y}) = 0.00261799$
 Expression ((5.4d), TBDY) for $\phi_{sh,min}$ has been multiplied by 0.3 according to 15.7.1.3 for members without
 earthquake detailing (90° closed stirrups)

 $\phi_{sh,x}$ (5.4d) = 0.00349066
 $A_{sh} = A_{stir} \cdot n_s = 78.53982$
 No stirrups, $n_s = 2.00$
 $b_k = 300.00$

psh,y (5.4d) = 0.00261799
 Ash = Astir*ns = 78.53982
 No stirups, ns = 2.00
 bk = 400.00

s = 150.00
 fywe = 555.55
 fce = 20.00

From ((5.A5), TBDY), TBDY: cc = 0.002
 c = confinement factor = 1.00

y1 = 0.00129669
 sh1 = 0.0044814
 ft1 = 373.4467
 fy1 = 311.2056
 su1 = 0.00512

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
 and also multiplied by the shear_factor according to 15.7.1.4, with
 Shear_factor = 1.00

lo/lou,min = lb/lb,min = 0.30

su1 = 0.4*esu1_nominal ((5.5), TBDY) = 0.032

From table 5A.1, TBDY: esu1_nominal = 0.08,

For calculation of esu1_nominal and y1, sh1,ft1,fy1, it is considered
 characteristic value fsy1 = fs1/1.2, from table 5.1, TBDY.

y1, sh1,ft1,fy1, are also multiplied by $\text{Min}(1, 1.25 \cdot (lb/ld)^{2/3})$, from 10.3.5, ASCE 41-17.

with fs1 = fs = 311.2056

with Es1 = Es = 200000.00

y2 = 0.00129669
 sh2 = 0.0044814
 ft2 = 373.4467
 fy2 = 311.2056
 su2 = 0.00512

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
 and also multiplied by the shear_factor according to 15.7.1.4, with
 Shear_factor = 1.00

lo/lou,min = lb/lb,min = 0.30

su2 = 0.4*esu2_nominal ((5.5), TBDY) = 0.032

From table 5A.1, TBDY: esu2_nominal = 0.08,

For calculation of esu2_nominal and y2, sh2,ft2,fy2, it is considered
 characteristic value fsy2 = fs2/1.2, from table 5.1, TBDY.

y1, sh1,ft1,fy1, are also multiplied by $\text{Min}(1, 1.25 \cdot (lb/ld)^{2/3})$, from 10.3.5, ASCE 41-17.

with fs2 = fs = 311.2056

with Es2 = Es = 200000.00

yv = 0.00129669
 shv = 0.0044814
 ftv = 373.4467
 fyv = 311.2056
 suv = 0.00512

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
 and also multiplied by the shear_factor according to 15.7.1.4, with
 Shear_factor = 1.00

lo/lou,min = lb/ld = 0.30

suv = 0.4*esuv_nominal ((5.5), TBDY) = 0.032

From table 5A.1, TBDY: esuv_nominal = 0.08,

considering characteristic value fsyv = fsv/1.2, from table 5.1, TBDY

For calculation of esuv_nominal and yv, shv,ftv,fyv, it is considered
 characteristic value fsyv = fsv/1.2, from table 5.1, TBDY.

y1, sh1,ft1,fy1, are also multiplied by $\text{Min}(1, 1.25 \cdot (lb/ld)^{2/3})$, from 10.3.5, ASCE 41-17.

with fsv = fs = 311.2056

with Esv = Es = 200000.00

1 = Asl,ten/(b*d)*(fs1/fc) = 0.08763528

2 = Asl,com/(b*d)*(fs2/fc) = 0.08946101

v = Asl,mid/(b*d)*(fsv/fc) = 0.04473051

and confined core properties:

b = 240.00
 d = 327.00
 d' = 12.00

```

fcc (5A.2, TBDY) = 20.00
cc (5A.5, TBDY) = 0.002
c = confinement factor = 1.00
1 = Asl,ten/(b*d)*(fs1/fc) = 0.11959401
2 = Asl,com/(b*d)*(fs2/fc) = 0.12208556
v = Asl,mid/(b*d)*(fsv/fc) = 0.06104278
Case/Assumption: Unconfined full section - Steel rupture
'satisfies Eq. (4.3)
--->
v < vs,y2 - LHS eq.(4.5) is satisfied
--->
su (4.9) = 0.19877808
Mu = MRc (4.14) = 8.0451E+007
u = su (4.1) = 1.7899831E-005

```

Calculation of ratio lb/ld

Inadequate Lap Length with lb/ld = 0.30

Calculation of Mu1-

Calculation of ultimate curvature u according to 4.1, Biskinis/Fardis 2013:

u = 1.7901443E-005

Mu = 8.1957E+007

with full section properties:

b = 300.00

d = 358.00

d' = 43.00

v = 0.00018626

N = 400.0832

fc = 20.00

co (5A.5, TBDY) = 0.002

Final value of cu: cu* = shear_factor * Max(cu, cc) = 0.00583896

The Shear_factor is considered equal to 1 (pure moment strength)

From (5.4b), TBDY: cu = 0.00583896

we (5.4c) = 0.0034192

ase ((5.4d), TBDY) = 0.15672608

bo = 240.00

ho = 340.00

bi2 = 346400.00

psh,min = Min(psh,x , psh,y) = 0.00261799

Expression ((5.4d), TBDY) for psh,min has been multiplied by 0.3 according to 15.7.1.3 for members without earthquake detailing (90° closed stirrups)

psh,x (5.4d) = 0.00349066

Ash = Astir*ns = 78.53982

No stirups, ns = 2.00

bk = 300.00

psh,y (5.4d) = 0.00261799

Ash = Astir*ns = 78.53982

No stirups, ns = 2.00

bk = 400.00

s = 150.00

fywe = 555.55

fce = 20.00

From ((5.A5), TBDY), TBDY: cc = 0.002

c = confinement factor = 1.00

y1 = 0.00129669

sh1 = 0.0044814


```

ft1 = 373.4467
fy1 = 311.2056
su1 = 0.00512
    using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
    and also multiplied by the shear_factor according to 15.7.1.4, with
    Shear_factor = 1.00
    lo/lou,min = lb/lb,min = 0.30
    su1 = 0.4*esu1_nominal ((5.5), TBDY) = 0.032
    From table 5A.1, TBDY: esu1_nominal = 0.08,
    For calculation of esu1_nominal and y1, sh1,ft1,fy1, it is considered
    characteristic value fsy1 = fs1/1.2, from table 5.1, TBDY.
    y1, sh1,ft1,fy1, are also multiplied by Min(1,1.25*(lb/lb)^ 2/3), from 10.3.5, ASCE 41-17.
    with fs1 = fs = 311.2056
    with Es1 = Es = 200000.00
y2 = 0.00129669
sh2 = 0.0044814
ft2 = 373.4467
fy2 = 311.2056
su2 = 0.00512
    using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
    and also multiplied by the shear_factor according to 15.7.1.4, with
    Shear_factor = 1.00
    lo/lou,min = lb/lb,min = 0.30
    su2 = 0.4*esu2_nominal ((5.5), TBDY) = 0.032
    From table 5A.1, TBDY: esu2_nominal = 0.08,
    For calculation of esu2_nominal and y2, sh2,ft2,fy2, it is considered
    characteristic value fsy2 = fs2/1.2, from table 5.1, TBDY.
    y1, sh1,ft1,fy1, are also multiplied by Min(1,1.25*(lb/lb)^ 2/3), from 10.3.5, ASCE 41-17.
    with fs2 = fs = 311.2056
    with Es2 = Es = 200000.00
yv = 0.00129669
shv = 0.0044814
ftv = 373.4467
fyv = 311.2056
suv = 0.00512
    using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
    and also multiplied by the shear_factor according to 15.7.1.4, with
    Shear_factor = 1.00
    lo/lou,min = lb/lb,min = 0.30
    suv = 0.4*esuv_nominal ((5.5), TBDY) = 0.032
    From table 5A.1, TBDY: esuv_nominal = 0.08,
    considering characteristic value fsyv = fsv/1.2, from table 5.1, TBDY
    For calculation of esuv_nominal and yv, shv,ftv,fyv, it is considered
    characteristic value fsyv = fsv/1.2, from table 5.1, TBDY.
    y1, sh1,ft1,fy1, are also multiplied by Min(1,1.25*(lb/lb)^ 2/3), from 10.3.5, ASCE 41-17.
    with fsv = fs = 311.2056
    with Esv = Es = 200000.00
1 = Asl,ten/(b*d)*(fs1/fc) = 0.08921112
2 = Asl,com/(b*d)*(fs2/fc) = 0.08739049
v = Asl,mid/(b*d)*(fsv/fc) = 0.04460556
and confined core properties:
b = 240.00
d = 328.00
d' = 13.00
fcc (5A.2, TBDY) = 20.00
cc (5A.5, TBDY) = 0.002
    c = confinement factor = 1.00
    1 = Asl,ten/(b*d)*(fs1/fc) = 0.12171334
    2 = Asl,com/(b*d)*(fs2/fc) = 0.1192294
    v = Asl,mid/(b*d)*(fsv/fc) = 0.06085667
Case/Assumption: Unconfined full section - Steel rupture
' satisfies Eq. (4.3)
--->
v < vs,y2 - LHS eq.(4.5) is satisfied
--->
su (4.9) = 0.20108809
Mu = MRc (4.14) = 8.1957E+007

```

$$u = s_u(4.1) = 1.7901443E-005$$

Calculation of ratio l_b/d

Inadequate Lap Length with $l_b/d = 0.30$

Calculation of μ_{u2}

Calculation of ultimate curvature μ_u according to 4.1, Biskinis/Fardis 2013:

$$u = 1.7862388E-005$$

$$\mu_u = 8.0533E+007$$

with full section properties:

$$b = 300.00$$

$$d = 358.00$$

$$d' = 43.00$$

$$v = 0.00018626$$

$$N = 400.0832$$

$$f_c = 20.00$$

$$\phi_{co}(5A.5, \text{TB DY}) = 0.002$$

$$\text{Final value of } \phi_{cu}: \phi_{cu}^* = \text{shear_factor} * \text{Max}(\phi_{cu}, \phi_{cc}) = 0.00583896$$

The Shear_factor is considered equal to 1 (pure moment strength)

$$\text{From (5.4b), TB DY: } \phi_{cu} = 0.00583896$$

$$\phi_{we}(5.4c) = 0.0034192$$

$$\phi_{ase}((5.4d), \text{TB DY}) = 0.15672608$$

$$b_o = 240.00$$

$$h_o = 340.00$$

$$b_{i2} = 346400.00$$

$$\phi_{psh,min} = \text{Min}(\phi_{psh,x}, \phi_{psh,y}) = 0.00261799$$

Expression ((5.4d), TB DY) for $\phi_{psh,min}$ has been multiplied by 0.3 according to 15.7.1.3 for members without earthquake detailing (90° closed stirrups)

$$\phi_{psh,x}(5.4d) = 0.00349066$$

$$A_{sh} = A_{stir} * n_s = 78.53982$$

$$\text{No stirrups, } n_s = 2.00$$

$$b_k = 300.00$$

$$\phi_{psh,y}(5.4d) = 0.00261799$$

$$A_{sh} = A_{stir} * n_s = 78.53982$$

$$\text{No stirrups, } n_s = 2.00$$

$$b_k = 400.00$$

$$s = 150.00$$

$$f_{ywe} = 555.55$$

$$f_{ce} = 20.00$$

$$\text{From ((5.A5), TB DY), TB DY: } \phi_{cc} = 0.002$$

$$c = \text{confinement factor} = 1.00$$

$$y_1 = 0.00129669$$

$$sh_1 = 0.0044814$$

$$f_{t1} = 373.4467$$

$$f_{y1} = 311.2056$$

$$s_{u1} = 0.00512$$

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor and also multiplied by the shear_factor according to 15.7.1.4, with Shear_factor = 1.00

$$l_o/l_{ou,min} = l_b/d = 0.30$$

$$s_{u1} = 0.4 * s_{u1_nominal}((5.5), \text{TB DY}) = 0.032$$

$$\text{From table 5A.1, TB DY: } s_{u1_nominal} = 0.08,$$

For calculation of $s_{u1_nominal}$ and y_1 , sh_1 , f_{t1} , f_{y1} , it is considered characteristic value $f_{sy1} = f_{s1}/1.2$, from table 5.1, TB DY.

y_1 , sh_1 , f_{t1} , f_{y1} , are also multiplied by $\text{Min}(1, 1.25 * (l_b/d)^{2/3})$, from 10.3.5, ASCE 41-17.

$$\text{with } f_{s1} = f_s = 311.2056$$

```

with Es1 = Es = 200000.00
y2 = 0.00129669
sh2 = 0.0044814
ft2 = 373.4467
fy2 = 311.2056
su2 = 0.00512
using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00
lo/lou,min = lb/lb,min = 0.30
su2 = 0.4*esu2_nominal ((5.5), TBDY) = 0.032
From table 5A.1, TBDY: esu2_nominal = 0.08,
For calculation of esu2_nominal and y2, sh2,ft2,fy2, it is considered
characteristic value fsy2 = fs2/1.2, from table 5.1, TBDY.
y1, sh1,ft1,fy1, are also multiplied by Min(1,1.25*(lb/d)^ 2/3), from 10.3.5, ASCE 41-17.
with fs2 = fs = 311.2056
with Es2 = Es = 200000.00
yv = 0.00129669
shv = 0.0044814
ftv = 373.4467
fyv = 311.2056
suv = 0.00512
using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00
lo/lou,min = lb/d = 0.30
suv = 0.4*esuv_nominal ((5.5), TBDY) = 0.032
From table 5A.1, TBDY: esuv_nominal = 0.08,
considering characteristic value fsyv = fsv/1.2, from table 5.1, TBDY
For calculation of esuv_nominal and yv, shv,ftv,fyv, it is considered
characteristic value fsyv = fsv/1.2, from table 5.1, TBDY.
y1, sh1,ft1,fy1, are also multiplied by Min(1,1.25*(lb/d)^ 2/3), from 10.3.5, ASCE 41-17.
with fsv = fs = 311.2056
with Esv = Es = 200000.00
1 = Asl,ten/(b*d)*(fs1/fc) = 0.08739049
2 = Asl,com/(b*d)*(fs2/fc) = 0.08921112
v = Asl,mid/(b*d)*(fsv/fc) = 0.04460556
and confined core properties:
b = 240.00
d = 328.00
d' = 13.00
fcc (5A.2, TBDY) = 20.00
cc (5A.5, TBDY) = 0.002
c = confinement factor = 1.00
1 = Asl,ten/(b*d)*(fs1/fc) = 0.1192294
2 = Asl,com/(b*d)*(fs2/fc) = 0.12171334
v = Asl,mid/(b*d)*(fsv/fc) = 0.06085667
Case/Assumption: Unconfined full section - Steel rupture
'satisfies Eq. (4.3)
--->
v < vs,y2 - LHS eq.(4.5) is satisfied
--->
su (4.9) = 0.19934131
Mu = MRc (4.14) = 8.0533E+007
u = su (4.1) = 1.7862388E-005

```

Calculation of ratio lb/d

Inadequate Lap Length with lb/d = 0.30

Calculation of Mu2-

Calculation of ultimate curvature ϕ_u according to 4.1, Biskinis/Fardis 2013:

$$\phi_u = 1.7939215 \times 10^{-5}$$

$$\mu = 8.1873 \times 10^7$$

with full section properties:

$$b = 300.00$$

$$d = 357.00$$

$$d' = 42.00$$

$$v = 0.00018678$$

$$N = 400.0832$$

$$f_c = 20.00$$

$$\phi_0 (5A.5, \text{TB DY}) = 0.002$$

$$\text{Final value of } \phi_u: \phi_u^* = \text{shear_factor} * \text{Max}(\phi_u, \phi_0) = 0.00583896$$

The Shear_factor is considered equal to 1 (pure moment strength)

$$\text{From (5.4b), TB DY: } \phi_u = 0.00583896$$

$$\phi_{ue} (5.4c) = 0.0034192$$

$$\phi_{ase} ((5.4d), \text{TB DY}) = 0.15672608$$

$$b_o = 240.00$$

$$h_o = 340.00$$

$$b_i^2 = 346400.00$$

$$\phi_{sh,min} = \text{Min}(\phi_{sh,x}, \phi_{sh,y}) = 0.00261799$$

Expression ((5.4d), TB DY) for $\phi_{sh,min}$ has been multiplied by 0.3 according to 15.7.1.3 for members without earthquake detailing (90° closed stirrups)

$$\phi_{sh,x} (5.4d) = 0.00349066$$

$$A_{sh} = A_{stir} * n_s = 78.53982$$

$$\text{No stirrups, } n_s = 2.00$$

$$b_k = 300.00$$

$$\phi_{sh,y} (5.4d) = 0.00261799$$

$$A_{sh} = A_{stir} * n_s = 78.53982$$

$$\text{No stirrups, } n_s = 2.00$$

$$b_k = 400.00$$

$$s = 150.00$$

$$f_{ywe} = 555.55$$

$$f_{ce} = 20.00$$

$$\text{From ((5.A5), TB DY), TB DY: } \phi_c = 0.002$$

$$c = \text{confinement factor} = 1.00$$

$$y_1 = 0.00129669$$

$$sh_1 = 0.0044814$$

$$f_{t1} = 373.4467$$

$$f_{y1} = 311.2056$$

$$su_1 = 0.00512$$

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00

$$l_o/l_{ou,min} = l_b/l_d = 0.30$$

$$su_1 = 0.4 * \phi_{su1_nominal} ((5.5), \text{TB DY}) = 0.032$$

$$\text{From table 5A.1, TB DY: } \phi_{su1_nominal} = 0.08,$$

For calculation of $\phi_{su1_nominal}$ and y_1 , sh_1 , f_{t1} , f_{y1} , it is considered
characteristic value $f_{sy1} = f_{s1}/1.2$, from table 5.1, TB DY.

$$y_1, sh_1, f_{t1}, f_{y1}, \text{ are also multiplied by } \text{Min}(1, 1.25 * (l_b/l_d)^{2/3}), \text{ from 10.3.5, ASCE 41-17.}$$

$$\text{with } f_{s1} = f_s = 311.2056$$

$$\text{with } E_{s1} = E_s = 200000.00$$

$$y_2 = 0.00129669$$

$$sh_2 = 0.0044814$$

$$f_{t2} = 373.4467$$

$$f_{y2} = 311.2056$$

$$su_2 = 0.00512$$

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00

$$l_o/l_{ou,min} = l_b/l_{b,min} = 0.30$$

$$su_2 = 0.4 * \phi_{su2_nominal} ((5.5), \text{TB DY}) = 0.032$$

$$\text{From table 5A.1, TB DY: } \phi_{su2_nominal} = 0.08,$$

For calculation of $\phi_{su2_nominal}$ and y_2 , sh_2 , f_{t2} , f_{y2} , it is considered

characteristic value $fsy2 = fs2/1.2$, from table 5.1, TBDY.
 $y1, sh1, ft1, fy1$, are also multiplied by $\text{Min}(1, 1.25 \cdot (lb/ld)^{2/3})$, from 10.3.5, ASCE 41-17.
 with $fs2 = fs = 311.2056$
 with $Es2 = Es = 200000.00$
 $yv = 0.00129669$
 $shv = 0.0044814$
 $ftv = 373.4467$
 $fyv = 311.2056$
 $suv = 0.00512$
 using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
 and also multiplied by the shear_factor according to 15.7.1.4, with
 Shear_factor = 1.00
 $lo/lou, min = lb/ld = 0.30$
 $suv = 0.4 \cdot esuv_nominal ((5.5), TBDY) = 0.032$
 From table 5A.1, TBDY: $esuv_nominal = 0.08$,
 considering characteristic value $fsyv = fsv/1.2$, from table 5.1, TBDY
 For calculation of $esuv_nominal$ and yv, shv, ftv, fyv , it is considered
 characteristic value $fsyv = fsv/1.2$, from table 5.1, TBDY.
 $y1, sh1, ft1, fy1$, are also multiplied by $\text{Min}(1, 1.25 \cdot (lb/ld)^{2/3})$, from 10.3.5, ASCE 41-17.
 with $fsv = fs = 311.2056$
 with $Es = 200000.00$
 $1 = Asl, ten / (b \cdot d) \cdot (fs1 / fc) = 0.08946101$
 $2 = Asl, com / (b \cdot d) \cdot (fs2 / fc) = 0.08763528$
 $v = Asl, mid / (b \cdot d) \cdot (fsv / fc) = 0.04473051$
 and confined core properties:
 $b = 240.00$
 $d = 327.00$
 $d' = 12.00$
 $fcc (5A.2, TBDY) = 20.00$
 $cc (5A.5, TBDY) = 0.002$
 $c = \text{confinement factor} = 1.00$
 $1 = Asl, ten / (b \cdot d) \cdot (fs1 / fc) = 0.12208556$
 $2 = Asl, com / (b \cdot d) \cdot (fs2 / fc) = 0.11959401$
 $v = Asl, mid / (b \cdot d) \cdot (fsv / fc) = 0.06104278$
 Case/Assumption: Unconfined full section - Steel rupture
 ' satisfies Eq. (4.3)
 --->
 $v < vs, y2$ - LHS eq.(4.5) is satisfied
 --->
 $su (4.9) = 0.20053711$
 $Mu = MRc (4.14) = 8.1873E+007$
 $u = su (4.1) = 1.7939215E-005$

Calculation of ratio lb/ld

Inadequate Lap Length with $lb/ld = 0.30$

Calculation of Shear Strength $Vr = \text{Min}(Vr1, Vr2) = 227879.44$

Calculation of Shear Strength at edge 1, $Vr1 = 227879.44$
 $Vr1 = Vn ((22.5.1.1), ACI 318-14)$

NOTE: In expression (22.5.1.1) 'Vw' is replaced by 'Vw+ f*Vf'
 where Vf is the contribution of FRPs (11.3), ACI 440).

From Table (22.5.5.1), ACI 318-14: $Vc = 78946.167$
 $= 1$ (normal-weight concrete)
 $fc' = 20.00$, but $fc'^{0.5} \leq 8.3$ MPa (22.5.3.1, ACI 318-14)
 $pw = As / (bw \cdot d) = 0.00628319$
 As (tension reinf.) = 603.1858
 $bw = 300.00$
 $d = 320.00$
 $Vu \cdot d / Mu < 1 = 1.00$

$$M_u = 60442.822$$

$$V_u = 4076.60$$

$$\text{From (11.5.4.8), ACI 318-14: } V_s = 148933.273$$

$$A_v = 157079.633$$

$$f_y = 444.44$$

$$s = 150.00$$

V_s has been multiplied by 1 ($s < d/2$, according to ASCE 41-17, 10.3.4)

$$V_f ((11-3)-(11.4), \text{ACI 440}) = 0.00$$

$$\text{From (11-11), ACI 440: } V_s + V_f \leq 285202.276$$

Calculation of Shear Strength at edge 2, $V_{r2} = 227879.44$

$$V_{r2} = V_n ((22.5.1.1), \text{ACI 318-14})$$

NOTE: In expression (22.5.1.1) ' V_w ' is replaced by ' $V_w + f \cdot V_f$ '
where V_f is the contribution of FRPs (11.3), ACI 440).

$$\text{From Table (22.5.5.1), ACI 318-14: } V_c = 78946.167$$

= 1 (normal-weight concrete)

$$f'_c = 20.00, \text{ but } f'_c^{0.5} \leq 8.3 \text{ MPa (22.5.3.1, ACI 318-14)}$$

$$p_w = A_s / (b_w \cdot d) = 0.00628319$$

$$A_s (\text{tension reinf.}) = 603.1858$$

$$b_w = 300.00$$

$$d = 320.00$$

$$V_u \cdot d / M_u < 1 = 1.00$$

$$M_u = 155096.693$$

$$V_u = 4178.928$$

$$\text{From (11.5.4.8), ACI 318-14: } V_s = 148933.273$$

$$A_v = 157079.633$$

$$f_y = 444.44$$

$$s = 150.00$$

V_s has been multiplied by 1 ($s < d/2$, according to ASCE 41-17, 10.3.4)

$$V_f ((11-3)-(11.4), \text{ACI 440}) = 0.00$$

$$\text{From (11-11), ACI 440: } V_s + V_f \leq 285202.276$$

End Of Calculation of Shear Capacity ratio for element: beam B1 of floor 1
At local axis: 3

Start Of Calculation of Shear Capacity ratio for element: beam B1 of floor 1
At Shear local axis: 2
(Bending local axis: 3)
Section Type: rcars

Constant Properties

$$\text{Knowledge Factor, } = 1.00$$

Mean strength values are used for both shear and moment calculations.

Consequently:

$$\text{Existing material of Secondary Member: Concrete Strength, } f_c = f_{cm} = 20.00$$

$$\text{Existing material of Secondary Member: Steel Strength, } f_s = f_{sm} = 444.44$$

$$\text{Concrete Elasticity, } E_c = 21019.039$$

$$\text{Steel Elasticity, } E_s = 200000.00$$

#####

Note: Especially for the calculation of moment strengths,

the above steel re-bar strengths are multiplied by 1.25 according to R18.6.5, ACI 318-14

$$\text{Existing material: Steel Strength, } f_s = 1.25 \cdot f_{sm} = 555.55$$

#####

$$\text{Section Height, } H = 400.00$$

$$\text{Section Width, } W = 300.00$$

$$\text{Cover Thickness, } c = 25.00$$

$$\text{Mean Confinement Factor overall section} = 1.00$$

$$\text{Element Length, } L = 1850.00$$

Secondary Member

Ribbed Bars

Ductile Steel

Without Detailing for Earthquake Resistance (including stirrups not closed at 135°)
Longitudinal Bars With Ends Lapped Starting at the End Sections
Inadequate Lap Length with $l_o/l_{ou,min} = 0.30$
No FRP Wrapping

Stepwise Properties

At local axis: 2
EDGE -A-
Shear Force, $V_a = -1.0090939E-010$
EDGE -B-
Shear Force, $V_b = 1.0090939E-010$
BOTH EDGES
Axial Force, $F = -400.0832$
Longitudinal Reinforcement Area Distribution (in 2 divisions)
-Tension: $As_t = 603.1858$
-Compression: $As_c = 923.6282$
Longitudinal Reinforcement Area Distribution (in 3 divisions)
-Tension: $As_{t,ten} = 508.938$
-Compression: $As_{c,com} = 508.938$
-Middle: $As_{mid} = 508.938$

Calculation of Shear Capacity ratio, $V_e/V_r = 0.37923485$
Member Controlled by Flexure ($V_e/V_r < 1$)
Calculation of Shear Demand from fig. R18.6.5, ACI 318-14 $V_e = (M_{pr1} + M_{pr2})/l_n \pm w_u \cdot l_n/2 = 57820.79$
with
 $M_{pr1} = \text{Max}(Mu_{1+}, Mu_{1-}) = 5.3484E+007$
 $Mu_{1+} = 5.3484E+007$, is the ultimate moment strength at the edge 1 of the member in the actual moment direction which is defined for the static loading combination
 $Mu_{1-} = 5.3484E+007$, is the ultimate moment strength at the edge 1 of the member in the opposite moment direction which is defined for the static loading combination
 $M_{pr2} = \text{Max}(Mu_{2+}, Mu_{2-}) = 5.3484E+007$
 $Mu_{2+} = 5.3484E+007$, is the ultimate moment strength at the edge 2 of the member in the actual moment direction which is defined for the the static loading combination
 $Mu_{2-} = 5.3484E+007$, is the ultimate moment strength at the edge 2 of the member in the opposite moment direction which is defined for the the static loading combination
and
 $\pm w_u \cdot l_n = (|V_1| + |V_2|)/2$
with
 $V_1 = -1.0090939E-010$, is the shear force acting at edge 1 for the the static loading combination
 $V_2 = 1.0090939E-010$, is the shear force acting at edge 2 for the the static loading combination

Calculation of Mu_{1+}

Calculation of ultimate curvature ϕ_u according to 4.1, Biskinis/Fardis 2013:
 $\phi_u = 2.5364147E-005$
 $M_u = 5.3484E+007$

with full section properties:

$b = 400.00$
 $d = 258.00$
 $d' = 42.00$
 $v = 0.00019384$
 $N = 400.0832$
 $f_c = 20.00$
 $\phi_o (5A.5, TBDY) = 0.002$
Final value of ϕ_u : $\phi_u^* = \text{shear_factor} \cdot \text{Max}(\phi_u, \phi_o) = 0.00583896$
The Shear_factor is considered equal to 1 (pure moment strength)
From (5.4b), TBDY: $\phi_u = 0.00583896$
we (5.4c) = 0.0034192

$ase((5.4d), TBDY) = 0.15672608$
 $bo = 240.00$
 $ho = 340.00$
 $bi2 = 346400.00$
 $psh,min = \text{Min}(psh,x, psh,y) = 0.00261799$
 Expression $((5.4d), TBDY)$ for psh,min has been multiplied by 0.3 according to 15.7.1.3 for members without earthquake detailing (90° closed stirrups)

$psh,x(5.4d) = 0.00349066$
 $Ash = Astir*ns = 78.53982$
 No stirrups, $ns = 2.00$
 $bk = 300.00$

$psh,y(5.4d) = 0.00261799$
 $Ash = Astir*ns = 78.53982$
 No stirrups, $ns = 2.00$
 $bk = 400.00$

$s = 150.00$
 $fywe = 555.55$
 $fce = 20.00$
 From $((5.A5), TBDY)$, $TBDY$: $cc = 0.002$
 $c = \text{confinement factor} = 1.00$
 $y1 = 0.00129669$
 $sh1 = 0.0044814$
 $ft1 = 373.4467$
 $fy1 = 311.2056$
 $su1 = 0.00512$
 using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
 and also multiplied by the shear_factor according to 15.7.1.4, with
 $\text{Shear_factor} = 1.00$
 $lo/lou,min = lb/ld = 0.30$
 $su1 = 0.4*esu1_nominal((5.5), TBDY) = 0.032$
 From table 5A.1, $TBDY$: $esu1_nominal = 0.08$,
 For calculation of $esu1_nominal$ and $y1, sh1, ft1, fy1$, it is considered
 characteristic value $fsy1 = fs1/1.2$, from table 5.1, $TBDY$.
 $y1, sh1, ft1, fy1$, are also multiplied by $\text{Min}(1, 1.25*(lb/ld)^{2/3})$, from 10.3.5, ASCE 41-17.
 with $fs1 = fs = 311.2056$
 with $Es1 = Es = 200000.00$
 $y2 = 0.00129669$
 $sh2 = 0.0044814$
 $ft2 = 373.4467$
 $fy2 = 311.2056$
 $su2 = 0.00512$
 using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
 and also multiplied by the shear_factor according to 15.7.1.4, with
 $\text{Shear_factor} = 1.00$
 $lo/lou,min = lb/lb,min = 0.30$
 $su2 = 0.4*esu2_nominal((5.5), TBDY) = 0.032$
 From table 5A.1, $TBDY$: $esu2_nominal = 0.08$,
 For calculation of $esu2_nominal$ and $y2, sh2, ft2, fy2$, it is considered
 characteristic value $fsy2 = fs2/1.2$, from table 5.1, $TBDY$.
 $y1, sh1, ft1, fy1$, are also multiplied by $\text{Min}(1, 1.25*(lb/ld)^{2/3})$, from 10.3.5, ASCE 41-17.
 with $fs2 = fs = 311.2056$
 with $Es2 = Es = 200000.00$
 $yv = 0.00129669$
 $shv = 0.0044814$
 $ftv = 373.4467$
 $fyv = 311.2056$
 $suv = 0.00512$
 using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
 and also multiplied by the shear_factor according to 15.7.1.4, with
 $\text{Shear_factor} = 1.00$
 $lo/lou,min = lb/ld = 0.30$
 $suv = 0.4*esuv_nominal((5.5), TBDY) = 0.032$
 From table 5A.1, $TBDY$: $esuv_nominal = 0.08$,
 considering characteristic value $fsyv = fsv/1.2$, from table 5.1, $TBDY$

For calculation of $\epsilon_{sv_nominal}$ and γ_v , ϕ_v , ϕ_{ftv} , ϕ_{fyv} , it is considered characteristic value $f_{sv} = f_{sv}/1.2$, from table 5.1, TBDY.

γ_1 , ϕ_1 , ϕ_{ft1} , ϕ_{fy1} , are also multiplied by $\text{Min}(1, 1.25 \cdot (l_b/l_d)^{2/3})$, from 10.3.5, ASCE 41-17.

with $f_{sv} = f_s = 311.2056$

with $E_{sv} = E_s = 200000.00$

1 = $A_{sl,ten}/(b \cdot d) \cdot (f_{s1}/f_c) = 0.0767366$

2 = $A_{sl,com}/(b \cdot d) \cdot (f_{s2}/f_c) = 0.0767366$

$v = A_{sl,mid}/(b \cdot d) \cdot (f_{sv}/f_c) = 0.0767366$

and confined core properties:

$b = 340.00$

$d = 228.00$

$d' = 12.00$

f_{cc} (5A.2, TBDY) = 20.00

c_c (5A.5, TBDY) = 0.002

$c = \text{confinement factor} = 1.00$

1 = $A_{sl,ten}/(b \cdot d) \cdot (f_{s1}/f_c) = 0.10215708$

2 = $A_{sl,com}/(b \cdot d) \cdot (f_{s2}/f_c) = 0.10215708$

$v = A_{sl,mid}/(b \cdot d) \cdot (f_{sv}/f_c) = 0.10215708$

Case/Assumption: Unconfined full section - Steel rupture

' satisfies Eq. (4.3)

--->

$v < v_{s,y2}$ - LHS eq.(4.5) is satisfied

--->

ϕ_u (4.9) = 0.21759794

$\mu_u = M_{Rc}$ (4.14) = 5.3484E+007

$u = \phi_u$ (4.1) = 2.5364147E-005

Calculation of ratio l_b/l_d

Inadequate Lap Length with $l_b/l_d = 0.30$

Calculation of μ_{u1} -

Calculation of ultimate curvature ϕ_u according to 4.1, Biskinis/Fardis 2013:

$u = 2.5364147E-005$

$\mu_u = 5.3484E+007$

with full section properties:

$b = 400.00$

$d = 258.00$

$d' = 42.00$

$v = 0.00019384$

$N = 400.0832$

$f_c = 20.00$

c_c (5A.5, TBDY) = 0.002

Final value of ϕ_u : $\phi_u^* = \text{shear_factor} \cdot \text{Max}(\phi_u, c_c) = 0.00583896$

The Shear_factor is considered equal to 1 (pure moment strength)

From (5.4b), TBDY: $\phi_u = 0.00583896$

ϕ_{ue} (5.4c) = 0.0034192

ϕ_{ase} ((5.4d), TBDY) = 0.15672608

$b_o = 240.00$

$h_o = 340.00$

$b_{i2} = 346400.00$

$\phi_{sh,min} = \text{Min}(\phi_{sh,x}, \phi_{sh,y}) = 0.00261799$

Expression ((5.4d), TBDY) for $\phi_{sh,min}$ has been multiplied by 0.3 according to 15.7.1.3 for members without earthquake detailing (90° closed stirrups)

$\phi_{sh,x}$ (5.4d) = 0.00349066

$A_{sh} = A_{stir} \cdot n_s = 78.53982$

No stirrups, $n_s = 2.00$

$b_k = 300.00$

psh,y (5.4d) = 0.00261799
 Ash = Astir*ns = 78.53982
 No stirups, ns = 2.00
 bk = 400.00

s = 150.00
 fywe = 555.55
 fce = 20.00

From ((5.A5), TBDY), TBDY: cc = 0.002
 c = confinement factor = 1.00

y1 = 0.00129669
 sh1 = 0.0044814

ft1 = 373.4467

fy1 = 311.2056

su1 = 0.00512

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
 and also multiplied by the shear_factor according to 15.7.1.4, with
 Shear_factor = 1.00

lo/lou,min = lb/lb,min = 0.30

su1 = 0.4*esu1_nominal ((5.5), TBDY) = 0.032

From table 5A.1, TBDY: esu1_nominal = 0.08,

For calculation of esu1_nominal and y1, sh1,ft1,fy1, it is considered
 characteristic value fsy1 = fs1/1.2, from table 5.1, TBDY.

y1, sh1,ft1,fy1, are also multiplied by $\text{Min}(1, 1.25 \cdot (lb/lb)^{2/3})$, from 10.3.5, ASCE 41-17.

with fs1 = fs = 311.2056

with Es1 = Es = 200000.00

y2 = 0.00129669

sh2 = 0.0044814

ft2 = 373.4467

fy2 = 311.2056

su2 = 0.00512

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
 and also multiplied by the shear_factor according to 15.7.1.4, with
 Shear_factor = 1.00

lo/lou,min = lb/lb,min = 0.30

su2 = 0.4*esu2_nominal ((5.5), TBDY) = 0.032

From table 5A.1, TBDY: esu2_nominal = 0.08,

For calculation of esu2_nominal and y2, sh2,ft2,fy2, it is considered
 characteristic value fsy2 = fs2/1.2, from table 5.1, TBDY.

y1, sh1,ft1,fy1, are also multiplied by $\text{Min}(1, 1.25 \cdot (lb/lb)^{2/3})$, from 10.3.5, ASCE 41-17.

with fs2 = fs = 311.2056

with Es2 = Es = 200000.00

yv = 0.00129669

shv = 0.0044814

ftv = 373.4467

fyv = 311.2056

suv = 0.00512

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
 and also multiplied by the shear_factor according to 15.7.1.4, with
 Shear_factor = 1.00

lo/lou,min = lb/lb,min = 0.30

suv = 0.4*esuv_nominal ((5.5), TBDY) = 0.032

From table 5A.1, TBDY: esuv_nominal = 0.08,

considering characteristic value fsyv = fsv/1.2, from table 5.1, TBDY

For calculation of esuv_nominal and yv, shv,ftv,fyv, it is considered
 characteristic value fsyv = fsv/1.2, from table 5.1, TBDY.

y1, sh1,ft1,fy1, are also multiplied by $\text{Min}(1, 1.25 \cdot (lb/lb)^{2/3})$, from 10.3.5, ASCE 41-17.

with fsv = fs = 311.2056

with Esv = Es = 200000.00

1 = Asl,ten/(b*d)*(fs1/fc) = 0.0767366

2 = Asl,com/(b*d)*(fs2/fc) = 0.0767366

v = Asl,mid/(b*d)*(fsv/fc) = 0.0767366

and confined core properties:

b = 340.00

d = 228.00

d' = 12.00

fcc (5A.2, TBDY) = 20.00

```

cc (5A.5, TBDY) = 0.002
c = confinement factor = 1.00
1 = Asl,ten/(b*d)*(fs1/fc) = 0.10215708
2 = Asl,com/(b*d)*(fs2/fc) = 0.10215708
v = Asl,mid/(b*d)*(fsv/fc) = 0.10215708
Case/Assumption: Unconfined full section - Steel rupture
'satisfies Eq. (4.3)
--->
v < vs,y2 - LHS eq.(4.5) is satisfied
--->
su (4.9) = 0.21759794
Mu = MRc (4.14) = 5.3484E+007
u = su (4.1) = 2.5364147E-005

```

Calculation of ratio lb/ld

Inadequate Lap Length with lb/ld = 0.30

Calculation of Mu2+

Calculation of ultimate curvature u according to 4.1, Biskinis/Fardis 2013:

```

u = 2.5364147E-005
Mu = 5.3484E+007

```

with full section properties:

```

b = 400.00
d = 258.00
d' = 42.00
v = 0.00019384
N = 400.0832
fc = 20.00
co (5A.5, TBDY) = 0.002
Final value of cu: cu* = shear_factor * Max( cu, cc) = 0.00583896
The Shear_factor is considered equal to 1 (pure moment strength)
From (5.4b), TBDY: cu = 0.00583896
we (5.4c) = 0.0034192
ase ((5.4d), TBDY) = 0.15672608
bo = 240.00
ho = 340.00
bi2 = 346400.00
psh,min = Min(psh,x , psh,y) = 0.00261799

```

Expression ((5.4d), TBDY) for psh,min has been multiplied by 0.3 according to 15.7.1.3 for members without earthquake detailing (90° closed stirrups)

```

psh,x (5.4d) = 0.00349066
Ash = Astir*ns = 78.53982
No stirups, ns = 2.00
bk = 300.00

```

```

psh,y (5.4d) = 0.00261799
Ash = Astir*ns = 78.53982
No stirups, ns = 2.00
bk = 400.00

```

```

s = 150.00
fywe = 555.55
fce = 20.00
From ((5.A5), TBDY), TBDY: cc = 0.002
c = confinement factor = 1.00
y1 = 0.00129669
sh1 = 0.0044814
ft1 = 373.4467

```

```

fy1 = 311.2056
su1 = 0.00512
    using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
    and also multiplied by the shear_factor according to 15.7.1.4, with
    Shear_factor = 1.00
    lo/lou,min = lb/lb = 0.30
    su1 = 0.4*esu1_nominal ((5.5), TBDY) = 0.032
    From table 5A.1, TBDY: esu1_nominal = 0.08,
    For calculation of esu1_nominal and y1, sh1,ft1,fy1, it is considered
    characteristic value fsy1 = fs1/1.2, from table 5.1, TBDY.
    y1, sh1,ft1,fy1, are also multiplied by Min(1,1.25*(lb/lb)^2/3), from 10.3.5, ASCE 41-17.
    with fs1 = fs = 311.2056
    with Es1 = Es = 200000.00
y2 = 0.00129669
sh2 = 0.0044814
ft2 = 373.4467
fy2 = 311.2056
su2 = 0.00512
    using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
    and also multiplied by the shear_factor according to 15.7.1.4, with
    Shear_factor = 1.00
    lo/lou,min = lb/lb,min = 0.30
    su2 = 0.4*esu2_nominal ((5.5), TBDY) = 0.032
    From table 5A.1, TBDY: esu2_nominal = 0.08,
    For calculation of esu2_nominal and y2, sh2,ft2,fy2, it is considered
    characteristic value fsy2 = fs2/1.2, from table 5.1, TBDY.
    y1, sh1,ft1,fy1, are also multiplied by Min(1,1.25*(lb/lb)^2/3), from 10.3.5, ASCE 41-17.
    with fs2 = fs = 311.2056
    with Es2 = Es = 200000.00
yv = 0.00129669
shv = 0.0044814
ftv = 373.4467
fyv = 311.2056
suv = 0.00512
    using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
    and also multiplied by the shear_factor according to 15.7.1.4, with
    Shear_factor = 1.00
    lo/lou,min = lb/lb = 0.30
    suv = 0.4*esuv_nominal ((5.5), TBDY) = 0.032
    From table 5A.1, TBDY: esuv_nominal = 0.08,
    considering characteristic value fsyv = fsv/1.2, from table 5.1, TBDY
    For calculation of esuv_nominal and yv, shv,ftv,fyv, it is considered
    characteristic value fsyv = fsv/1.2, from table 5.1, TBDY.
    y1, sh1,ft1,fy1, are also multiplied by Min(1,1.25*(lb/lb)^2/3), from 10.3.5, ASCE 41-17.
    with fsv = fs = 311.2056
    with Esv = Es = 200000.00
1 = Asl,ten/(b*d)*(fs1/fc) = 0.0767366
2 = Asl,com/(b*d)*(fs2/fc) = 0.0767366
v = Asl,mid/(b*d)*(fsv/fc) = 0.0767366
and confined core properties:
b = 340.00
d = 228.00
d' = 12.00
fcc (5A.2, TBDY) = 20.00
cc (5A.5, TBDY) = 0.002
    c = confinement factor = 1.00
1 = Asl,ten/(b*d)*(fs1/fc) = 0.10215708
2 = Asl,com/(b*d)*(fs2/fc) = 0.10215708
v = Asl,mid/(b*d)*(fsv/fc) = 0.10215708
Case/Assumption: Unconfined full section - Steel rupture
' satisfies Eq. (4.3)
--->
v < vs,y2 - LHS eq.(4.5) is satisfied
--->
su (4.9) = 0.21759794
Mu = MRc (4.14) = 5.3484E+007
u = su (4.1) = 2.5364147E-005

```

Calculation of ratio l_b/l_d

Inadequate Lap Length with $l_b/l_d = 0.30$

Calculation of μ_2 -

Calculation of ultimate curvature μ according to 4.1, Biskinis/Fardis 2013:

$$\mu = 2.5364147E-005$$

$$\mu_u = 5.3484E+007$$

with full section properties:

$$b = 400.00$$

$$d = 258.00$$

$$d' = 42.00$$

$$v = 0.00019384$$

$$N = 400.0832$$

$$f_c = 20.00$$

$$\omega (5A.5, \text{TB DY}) = 0.002$$

$$\text{Final value of } \mu_u: \mu_u^* = \text{shear_factor} * \text{Max}(\mu_u, \mu_c) = 0.00583896$$

The Shear_factor is considered equal to 1 (pure moment strength)

$$\text{From (5.4b), TB DY: } \mu_u = 0.00583896$$

$$\mu_w (5.4c) = 0.0034192$$

$$\mu_{ase} ((5.4d), \text{TB DY}) = 0.15672608$$

$$b_o = 240.00$$

$$h_o = 340.00$$

$$b_{i2} = 346400.00$$

$$\mu_{sh,min} = \text{Min}(\mu_{sh,x}, \mu_{sh,y}) = 0.00261799$$

Expression ((5.4d), TB DY) for $\mu_{sh,min}$ has been multiplied by 0.3 according to 15.7.1.3 for members without earthquake detailing (90° closed stirrups)

$$\mu_{sh,x} (5.4d) = 0.00349066$$

$$A_{sh} = A_{stir} * n_s = 78.53982$$

$$\text{No stirrups, } n_s = 2.00$$

$$b_k = 300.00$$

$$\mu_{sh,y} (5.4d) = 0.00261799$$

$$A_{sh} = A_{stir} * n_s = 78.53982$$

$$\text{No stirrups, } n_s = 2.00$$

$$b_k = 400.00$$

$$s = 150.00$$

$$f_{ywe} = 555.55$$

$$f_{ce} = 20.00$$

$$\text{From ((5.A.5), TB DY), TB DY: } \mu_c = 0.002$$

$$c = \text{confinement factor} = 1.00$$

$$y_1 = 0.00129669$$

$$sh_1 = 0.0044814$$

$$ft_1 = 373.4467$$

$$fy_1 = 311.2056$$

$$su_1 = 0.00512$$

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor and also multiplied by the shear_factor according to 15.7.1.4, with Shear_factor = 1.00

$$l_o/l_{o,min} = l_b/l_d = 0.30$$

$$su_1 = 0.4 * \mu_{su1_nominal} ((5.5), \text{TB DY}) = 0.032$$

$$\text{From table 5A.1, TB DY: } \mu_{su1_nominal} = 0.08,$$

For calculation of $\mu_{su1_nominal}$ and y_1, sh_1, ft_1, fy_1 , it is considered characteristic value $fsy_1 = fs_1/1.2$, from table 5.1, TB DY.

$$y_1, sh_1, ft_1, fy_1, \text{ are also multiplied by } \text{Min}(1, 1.25 * (l_b/l_d)^{2/3}), \text{ from 10.3.5, ASCE 41-17.}$$

$$\text{with } fs_1 = fs = 311.2056$$

$$\text{with } E_{s1} = E_s = 200000.00$$

```

y2 = 0.00129669
sh2 = 0.0044814
ft2 = 373.4467
fy2 = 311.2056
su2 = 0.00512
using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00
lo/lou,min = lb/lb,min = 0.30
su2 = 0.4*esu2_nominal ((5.5), TBDY) = 0.032
From table 5A.1, TBDY: esu2_nominal = 0.08,
For calculation of esu2_nominal and y2, sh2,ft2,fy2, it is considered
characteristic value fsy2 = fs2/1.2, from table 5.1, TBDY.
y1, sh1,ft1,fy1, are also multiplied by Min(1,1.25*(lb/ld)^ 2/3), from 10.3.5, ASCE 41-17.
with fs2 = fs = 311.2056
with Es2 = Es = 200000.00
yv = 0.00129669
shv = 0.0044814
ftv = 373.4467
fyv = 311.2056
suv = 0.00512
using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00
lo/lou,min = lb/ld = 0.30
suv = 0.4*esuv_nominal ((5.5), TBDY) = 0.032
From table 5A.1, TBDY: esuv_nominal = 0.08,
considering characteristic value fsyv = fsv/1.2, from table 5.1, TBDY
For calculation of esuv_nominal and yv, shv,ftv,fyv, it is considered
characteristic value fsyv = fsv/1.2, from table 5.1, TBDY.
y1, sh1,ft1,fy1, are also multiplied by Min(1,1.25*(lb/ld)^ 2/3), from 10.3.5, ASCE 41-17.
with fsv = fs = 311.2056
with Esv = Es = 200000.00
1 = Asl,ten/(b*d)*(fs1/fc) = 0.0767366
2 = Asl,com/(b*d)*(fs2/fc) = 0.0767366
v = Asl,mid/(b*d)*(fsv/fc) = 0.0767366
and confined core properties:
b = 340.00
d = 228.00
d' = 12.00
fcc (5A.2, TBDY) = 20.00
cc (5A.5, TBDY) = 0.002
c = confinement factor = 1.00
1 = Asl,ten/(b*d)*(fs1/fc) = 0.10215708
2 = Asl,com/(b*d)*(fs2/fc) = 0.10215708
v = Asl,mid/(b*d)*(fsv/fc) = 0.10215708
Case/Assumption: Unconfined full section - Steel rupture
'satisfies Eq. (4.3)
--->
v < vs,y2 - LHS eq.(4.5) is satisfied
--->
su (4.9) = 0.21759794
Mu = MRc (4.14) = 5.3484E+007
u = su (4.1) = 2.5364147E-005

```

Calculation of ratio lb/ld

Inadequate Lap Length with lb/ld = 0.30

Calculation of Shear Strength $V_r = \text{Min}(V_{r1}, V_{r2}) = 152466.975$

Calculation of Shear Strength at edge 1, $V_{r1} = 152466.975$
 $V_{r1} = V_n ((22.5.1.1), \text{ACI } 318-14)$

NOTE: In expression (22.5.1.1) 'Vw' is replaced by 'Vw+ f*Vf'
where Vf is the contribution of FRPs (11.3), ACI 440).

From Table (22.5.5.1), ACI 318-14: $V_c = 68692.008$

= 1 (normal-weight concrete)

$f_c' = 20.00$, but $f_c'^{0.5} \leq 8.3$ MPa (22.5.3.1, ACI 318-14)

$\rho_w = A_s/(b_w*d) = 0.00628319$

A_s (tension reinf.) = 603.1858

$b_w = 400.00$

$d = 240.00$

$V_u*d/M_u < 1 = 0.00$

$M_u = 2.0746991E-007$

$V_u = 1.0090939E-010$

From (11.5.4.8), ACI 318-14: $V_s = 83774.966$

$A_v = 157079.633$

$f_y = 444.44$

$s = 150.00$

V_s has been multiplied by $2(1-s/d)$ ($s > d/2$, according to ASCE 41-17,10.3.4)

$2(1-s/d) = 0.75$

V_f ((11-3)-(11.4), ACI 440) = 0.00

From (11-11), ACI 440: $V_s + V_f \leq 285202.276$

Calculation of Shear Strength at edge 2, $V_{r2} = 152466.975$

$V_{r2} = V_n$ ((22.5.1.1), ACI 318-14)

NOTE: In expression (22.5.1.1) 'Vw' is replaced by 'Vw+ f*Vf'
where Vf is the contribution of FRPs (11.3), ACI 440).

From Table (22.5.5.1), ACI 318-14: $V_c = 68692.008$

= 1 (normal-weight concrete)

$f_c' = 20.00$, but $f_c'^{0.5} \leq 8.3$ MPa (22.5.3.1, ACI 318-14)

$\rho_w = A_s/(b_w*d) = 0.00628319$

A_s (tension reinf.) = 603.1858

$b_w = 400.00$

$d = 240.00$

$V_u*d/M_u < 1 = 0.00$

$M_u = 2.0781750E-008$

$V_u = 1.0090939E-010$

From (11.5.4.8), ACI 318-14: $V_s = 83774.966$

$A_v = 157079.633$

$f_y = 444.44$

$s = 150.00$

V_s has been multiplied by $2(1-s/d)$ ($s > d/2$, according to ASCE 41-17,10.3.4)

$2(1-s/d) = 0.75$

V_f ((11-3)-(11.4), ACI 440) = 0.00

From (11-11), ACI 440: $V_s + V_f \leq 285202.276$

End Of Calculation of Shear Capacity ratio for element: beam B1 of floor 1

At local axis: 2

Start Of Calculation of Chord Rotation Capacity for element: beam B1 of floor 1

At local axis: 3

Integration Section: (a)

Section Type: rcars

Constant Properties

Knowledge Factor, $\phi = 1.00$

Chord Rotation is generally considered as Deformation-Controlled Action according to Table C7-1, ASCE 41-17.

Mean strengths are used for Deformation-Controlled Actions according to 7.5.1.3, ASCE 41-17

Consequently:

Existing material of Secondary Member: Concrete Strength, $f_c = f_{cm} = 20.00$

Existing material of Secondary Member: Steel Strength, $f_s = f_{sm} = 444.44$

Concrete Elasticity, $E_c = 21019.039$
 Steel Elasticity, $E_s = 200000.00$
 Section Height, $H = 400.00$
 Section Width, $W = 300.00$
 Cover Thickness, $c = 25.00$
 Element Length, $L = 1850.00$
 Secondary Member
 Ribbed Bars
 Ductile Steel
 Without Detailing for Earthquake Resistance (including stirrups not closed at 135°)
 Longitudinal Bars With Ends Lapped Starting at the End Sections
 Inadequate Lap Length with $l_b/l_d = 0.30$
 No FRP Wrapping

Stepwise Properties

Bending Moment, $M = -4.4694326E-005$
 Shear Force, $V_2 = -5.1634141E-008$
 Shear Force, $V_3 = -2275.035$
 Axial Force, $F = -1219.269$
 Longitudinal Reinforcement Area Distribution (in 2 divisions)
 -Tension: $A_{st} = 603.1858$
 -Compression: $A_{sc} = 923.6282$
 Longitudinal Reinforcement Area Distribution (in 3 divisions)
 -Tension: $A_{st,ten} = 508.938$
 -Compression: $A_{st,com} = 508.938$
 -Middle: $A_{st,mid} = 508.938$
 Mean Diameter of Tension Reinforcement, $DbL = 14.66667$

Existing component: From table 7-7, ASCE 41_17: Final chord rotation Capacity $u_R = \gamma + p = 0.02209347$

- Calculation of γ -

$\gamma = (M_y * L_s / 3) / E_{eff} = 0.00209347$ ((4.29), Biskinis Phd))
 $M_y = 3.8532E+007$
 $L_s = M/V$ (with $L_s > 0.1 * L$ and $L_s < 2 * L$) = 925.00
 From table 10.5, ASCE 41_17: $E_{eff} = 0.3 * E_c * I_g = 5.6751E+012$

Calculation of Yielding Moment M_y

Calculation of γ and M_y according to Annex 7 -

$\gamma = \min(\gamma_{ten}, \gamma_{com})$
 $\gamma_{ten} = 6.7799058E-006$
 with ((10.1), ASCE 41-17) $f_y = \min(f_y, 1.25 * f_y * (l_b/l_d)^{2/3}) = 248.9644$
 $d = 258.00$
 $\gamma = 0.28835408$
 $A = 0.01484216$
 $B = 0.00864903$
 with $p_t = 0.00493157$
 $p_c = 0.00493157$
 $p_v = 0.00493157$
 $N = 1219.269$
 $b = 400.00$
 $\gamma = 0.1627907$
 $\gamma_{comp} = 2.3064356E-005$
 with $f_c = 20.00$
 $E_c = 21019.039$
 $\gamma = 0.28782506$

A = 0.01476022
B = 0.00860158
with Es = 200000.00

Calculation of ratio l_b/l_d

Inadequate Lap Length with $l_b/l_d = 0.30$

- Calculation of p -

From table 10-7: $p = 0.02$

with:

- Condition iv occurred

Beam controlled by inadequate embedment into beam-column joint:
($l_b/l_d < 1$ and With Lapping in the Vicinity of the End Regions)

- Condition i occurred

Beam controlled by flexure: $V_p/V_o \leq 1$

shear control ratio $V_p/V_o = 0.37923485$

- Transverse Reinforcement: NC

- Stirrup Spacing $> d/3$

- Low ductility demand, $\lambda_y < 2$ (table 10-6, ASCE 41-17)
 $= -5.3240681E-016$

- Stirrup Spacing $> d/2$

$d = 258.00$

$s = 150.00$

- Strength provided by hoops $V_s < 3/4 \times \text{design Shear}$

$V_s = 111699.955$, already given in calculation of shear control ratio

design Shear = $5.1634141E-008$

- (λ_y)/ $\lambda_{bal} = -0.16624473$

$= A_{st}/(b_w \times d) = 0.00584482$

Tension Reinf Area: $A_{st} = 603.1858$

$\lambda_y = A_{sc}/(b_w \times d) = 0.00894989$

Compression Reinf Area: $A_{sc} = 923.6282$

From (B-1), ACI 318-11: $\lambda_{bal} = 0.01867766$

$f_c = 20.00$

$f_y = 444.44$

From 10.2.7.3, ACI 318-11: $\lambda_y = 0.85$

From fig R10.3.3, ACI 318-11 (Ence 454, too): $87000/(87000 + f_y) = c_b/d_t = 0.003/(0.003 + \lambda_y) = 0.57447053$
 $\lambda_y = 0.0022222$

- $V/(b_w \times d \times f_c^{0.5}) = 1.3473037E-012$, NOTE: units in lb & in

$b_w = 400.00$

End Of Calculation of Chord Rotation Capacity for element: beam B1 of floor 1

At local axis: 3

Integration Section: (a)

Calculation No. 13

beam B1, Floor 1


Limit State: Life Safety (data interpolation between analysis steps 1 and 2)

Analysis: Uniform +X

Check: Shear capacity V_{Rd}

Edge: End

Local Axis: (2)



Start Of Calculation of Shear Capacity for element: beam B1 of floor 1

At local axis: 2

Integration Section: (b)

Section Type: rcars

Constant Properties

Knowledge Factor, $\gamma = 1.00$

Member Shear Force is generally considered as Force-Controlled Action according to Table C7-1, ASCE 41-17.

Lower-bound strengths are used for Force-Controlled Actions according to 7.5.1.3, ASCE 41-17

Consequently:

Existing material of Secondary Member: Concrete Strength, $f_c = f_{c_lower_bound} = 16.00$

Existing material of Secondary Member: Steel Strength, $f_s = f_{s_lower_bound} = 400.00$

Concrete Elasticity, $E_c = 21019.039$

Steel Elasticity, $E_s = 200000.00$

Section Height, $H = 400.00$

Section Width, $W = 300.00$

Cover Thickness, $c = 25.00$

Element Length, $L = 1850.00$

Secondary Member

Ribbed Bars

Ductile Steel

Without Detailing for Earthquake Resistance (including stirrups not closed at 135°)

Longitudinal Bars With Ends Lapped Starting at the End Sections

Inadequate Lap Length with $l_o/l_{ou,min} = l_b/l_d = 0.30$

No FRP Wrapping

Stepwise Properties

EDGE -A-

Bending Moment, $M_a = -4.4694326E-005$

Shear Force, $V_a = -5.1634141E-008$

EDGE -B-

Bending Moment, $M_b = -5.3249995E-005$

Shear Force, $V_b = 5.1634141E-008$

BOTH EDGES

Axial Force, $F = -1219.269$

Longitudinal Reinforcement Area Distribution (in 2 divisions)

-Tension: $As_t = 615.7522$
-Compression: $As_c = 911.0619$
Longitudinal Reinforcement Area Distribution (in 3 divisions)
-Tension: $As_{t,ten} = 508.938$
-Compression: $As_{c,com} = 508.938$
-Middle: $As_{mid} = 508.938$
Mean Diameter of Tension Reinforcement, $Db_{L,ten} = 14.66667$

Existing component: From table 7-7, ASCE 41_17: Final Shear Capacity $VR = \phi V_n = 139274.259$
 $V_n ((22.5.1.1), ACI 318-14) = 139274.259$

NOTE: In expression (22.5.1.1) ' V_w ' is replaced by ' $V_w + \phi V_f$ '
where V_f is the contribution of FRPs (11.3), ACI 440).

From Table (22.5.5.1), ACI 318-14: $V_c = 63876.035$
= 1 (normal-weight concrete)
 $f'_c = 16.00$, but $f'_c^{0.5} \leq 8.3$ MPa (22.5.3.1, ACI 318-14)
 $\rho_w = As/(b_w \cdot d) = 0.00641409$
 As (tension reinf.) = 615.7522
 $b_w = 400.00$
 $d = 240.00$
 $V_u \cdot d / M_u < 1 = 0.23271728$
 $M_u = 5.3249995E-005$
 $V_u = 5.1634141E-008$

From (11.5.4.8), ACI 318-14: $V_s = 75398.224$
 $A_v = 157079.633$
 $f_y = 400.00$
 $s = 150.00$

V_s has been multiplied by $2(1-s/d)$ ($s > d/2$, according to ASCE 41-17, 10.3.4)

$2(1-s/d) = 0.75$

$V_f ((11-3)-(11.4), ACI 440) = 0.00$

From (11-11), ACI 440: $V_s + V_f \leq 255092.67$

End Of Calculation of Shear Capacity for element: beam B1 of floor 1
At local axis: 2
Integration Section: (b)

Calculation No. 14

beam B1, Floor 1



Limit State: Life Safety (data interpolation between analysis steps 1 and 2)

Analysis: Uniform +X

Check: Chord rotation capacity (ϕ_r)

Edge: End

Local Axis: (2)



Start Of Calculation of Shear Capacity ratio for element: beam B1 of floor 1

At Shear local axis: 3

(Bending local axis: 2)

Section Type: rcars

Constant Properties

Knowledge Factor, $\gamma = 1.00$

Mean strength values are used for both shear and moment calculations.

Consequently:

Existing material of Secondary Member: Concrete Strength, $f_c = f_{cm} = 20.00$

Existing material of Secondary Member: Steel Strength, $f_s = f_{sm} = 444.44$

Concrete Elasticity, $E_c = 21019.039$

Steel Elasticity, $E_s = 200000.00$

#####

Note: Especially for the calculation of moment strengths,

the above steel re-bar strengths are multiplied by 1.25 according to R18.6.5, ACI 318-14

Existing material: Steel Strength, $f_s = 1.25 \cdot f_{sm} = 555.55$

#####

Section Height, $H = 400.00$

Section Width, $W = 300.00$

Cover Thickness, $c = 25.00$

Mean Confinement Factor overall section = 1.00

Element Length, $L = 1850.00$

Secondary Member

Ribbed Bars

Ductile Steel

Without Detailing for Earthquake Resistance (including stirrups not closed at 135°)

Longitudinal Bars With Ends Lapped Starting at the End Sections

Inadequate Lap Length with $l_o/l_{ou,min} = 0.30$

No FRP Wrapping

Stepwise Properties

At local axis: 3

EDGE -A-

Shear Force, $V_a = 4076.60$

EDGE -B-

Shear Force, $V_b = 4178.928$

BOTH EDGES

Axial Force, $F = -400.0832$

Longitudinal Reinforcement Area Distribution (in 2 divisions)

-Tension: $A_{sl,t} = 603.1858$

-Compression: $A_{sl,c} = 923.6282$

Longitudinal Reinforcement Area Distribution (in 3 divisions)

-Tension: $A_{sl,ten} = 603.1858$

-Compression: $A_{sl,com} = 615.7522$

-Middle: $A_{sl,mid} = 307.8761$

Calculation of Shear Capacity ratio , $V_e/V_r = 0.40672566$
 Member Controlled by Flexure ($V_e/V_r < 1$)
 Calculation of Shear Demand from fig. R18.6.5, ACI 318-14 $V_e = (M_{pr1} + M_{pr2})/l_n \pm w_u \cdot l_n/2 = 92684.415$
 with
 $M_{pr1} = \text{Max}(\mu_{1+}, \mu_{1-}) = 8.1957\text{E}+007$
 $\mu_{1+} = 8.0451\text{E}+007$, is the ultimate moment strength at the edge 1 of the member in the actual moment direction
 which is defined for the static loading combination
 $\mu_{1-} = 8.1957\text{E}+007$, is the ultimate moment strength at the edge 1 of the member in the opposite moment
 direction which is defined for the static loading combination
 $M_{pr2} = \text{Max}(\mu_{2+}, \mu_{2-}) = 8.1873\text{E}+007$
 $\mu_{2+} = 8.0533\text{E}+007$, is the ultimate moment strength at the edge 2 of the member in the actual moment direction
 which is defined for the the static loading combination
 $\mu_{2-} = 8.1873\text{E}+007$, is the ultimate moment strength at the edge 2 of the member in the opposite moment
 direction which is defined for the the static loading combination
 and
 $\pm w_u \cdot l_n = (|V_1| + |V_2|)/2$
 with
 $V_1 = 4076.60$, is the shear force acting at edge 1 for the the static loading combination
 $V_2 = 4178.928$, is the shear force acting at edge 2 for the the static loading combination

 Calculation of μ_{1+}

 Calculation of ultimate curvature μ according to 4.1, Biskinis/Fardis 2013:

$\mu = 1.7899831\text{E}-005$

$\mu_u = 8.0451\text{E}+007$

with full section properties:

$b = 300.00$

$d = 357.00$

$d' = 42.00$

$v = 0.00018678$

$N = 400.0832$

$f_c = 20.00$

$\phi_c (5A.5, \text{TB DY}) = 0.002$

Final value of ϕ_c : $\phi_c^* = \text{shear_factor} \cdot \text{Max}(\phi_c, \phi_{cc}) = 0.00583896$

The Shear_factor is considered equal to 1 (pure moment strength)

From (5.4b), TB DY: $\phi_c = 0.00583896$

$w_e (5.4c) = 0.0034192$

$a_{se} ((5.4d), \text{TB DY}) = 0.15672608$

$b_o = 240.00$

$h_o = 340.00$

$b_{i2} = 346400.00$

$\phi_{sh,min} = \text{Min}(\phi_{sh,x}, \phi_{sh,y}) = 0.00261799$

Expression ((5.4d), TB DY) for $\phi_{sh,min}$ has been multiplied by 0.3 according to 15.7.1.3 for members without
 earthquake detailing (90° closed stirrups)

 $\phi_{sh,x} (5.4d) = 0.00349066$

$A_{sh} = A_{stir} \cdot n_s = 78.53982$

No stirrups, $n_s = 2.00$

$b_k = 300.00$

$\phi_{sh,y} (5.4d) = 0.00261799$

$A_{sh} = A_{stir} \cdot n_s = 78.53982$

No stirrups, $n_s = 2.00$

$b_k = 400.00$

$s = 150.00$

$f_{ywe} = 555.55$

$f_{ce} = 20.00$

From ((5.A5), TB DY), TB DY: $\phi_{cc} = 0.002$

$c = \text{confinement factor} = 1.00$

$y_1 = 0.00129669$

$sh_1 = 0.0044814$

```

ft1 = 373.4467
fy1 = 311.2056
su1 = 0.00512
    using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
    and also multiplied by the shear_factor according to 15.7.1.4, with
    Shear_factor = 1.00
    lo/lou,min = lb/lb,min = 0.30
    su1 = 0.4*esu1_nominal ((5.5), TBDY) = 0.032
    From table 5A.1, TBDY: esu1_nominal = 0.08,
    For calculation of esu1_nominal and y1, sh1,ft1,fy1, it is considered
    characteristic value fsy1 = fs1/1.2, from table 5.1, TBDY.
    y1, sh1,ft1,fy1, are also multiplied by Min(1,1.25*(lb/lb)^ 2/3), from 10.3.5, ASCE 41-17.
    with fs1 = fs = 311.2056
    with Es1 = Es = 200000.00
y2 = 0.00129669
sh2 = 0.0044814
ft2 = 373.4467
fy2 = 311.2056
su2 = 0.00512
    using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
    and also multiplied by the shear_factor according to 15.7.1.4, with
    Shear_factor = 1.00
    lo/lou,min = lb/lb,min = 0.30
    su2 = 0.4*esu2_nominal ((5.5), TBDY) = 0.032
    From table 5A.1, TBDY: esu2_nominal = 0.08,
    For calculation of esu2_nominal and y2, sh2,ft2,fy2, it is considered
    characteristic value fsy2 = fs2/1.2, from table 5.1, TBDY.
    y1, sh1,ft1,fy1, are also multiplied by Min(1,1.25*(lb/lb)^ 2/3), from 10.3.5, ASCE 41-17.
    with fs2 = fs = 311.2056
    with Es2 = Es = 200000.00
yv = 0.00129669
shv = 0.0044814
ftv = 373.4467
fyv = 311.2056
suv = 0.00512
    using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
    and also multiplied by the shear_factor according to 15.7.1.4, with
    Shear_factor = 1.00
    lo/lou,min = lb/lb,min = 0.30
    suv = 0.4*esuv_nominal ((5.5), TBDY) = 0.032
    From table 5A.1, TBDY: esuv_nominal = 0.08,
    considering characteristic value fsyv = fsv/1.2, from table 5.1, TBDY
    For calculation of esuv_nominal and yv, shv,ftv,fyv, it is considered
    characteristic value fsyv = fsv/1.2, from table 5.1, TBDY.
    y1, sh1,ft1,fy1, are also multiplied by Min(1,1.25*(lb/lb)^ 2/3), from 10.3.5, ASCE 41-17.
    with fsv = fs = 311.2056
    with Esv = Es = 200000.00
1 = Asl,ten/(b*d)*(fs1/fc) = 0.08763528
2 = Asl,com/(b*d)*(fs2/fc) = 0.08946101
v = Asl,mid/(b*d)*(fsv/fc) = 0.04473051
and confined core properties:
b = 240.00
d = 327.00
d' = 12.00
fcc (5A.2, TBDY) = 20.00
cc (5A.5, TBDY) = 0.002
    c = confinement factor = 1.00
    1 = Asl,ten/(b*d)*(fs1/fc) = 0.11959401
    2 = Asl,com/(b*d)*(fs2/fc) = 0.12208556
    v = Asl,mid/(b*d)*(fsv/fc) = 0.06104278
Case/Assumption: Unconfined full section - Steel rupture
' satisfies Eq. (4.3)
--->
v < vs,y2 - LHS eq.(4.5) is satisfied
--->
su (4.9) = 0.19877808
Mu = MRc (4.14) = 8.0451E+007

```

$$u = su(4.1) = 1.7899831E-005$$

Calculation of ratio l_b/l_d

Inadequate Lap Length with $l_b/l_d = 0.30$

Calculation of μ_1 -

Calculation of ultimate curvature μ according to 4.1, Biskinis/Fardis 2013:

$$u = 1.7901443E-005$$

$$\mu = 8.1957E+007$$

with full section properties:

$$b = 300.00$$

$$d = 358.00$$

$$d' = 43.00$$

$$v = 0.00018626$$

$$N = 400.0832$$

$$f_c = 20.00$$

$$\alpha(5A.5, \text{TB DY}) = 0.002$$

$$\text{Final value of } \mu: \mu^* = \text{shear_factor} * \text{Max}(\mu, \alpha) = 0.00583896$$

The Shear_factor is considered equal to 1 (pure moment strength)

$$\text{From (5.4b), TB DY: } \mu = 0.00583896$$

$$\mu(5.4c) = 0.0034192$$

$$\alpha(5.4d), \text{TB DY} = 0.15672608$$

$$b_o = 240.00$$

$$h_o = 340.00$$

$$b_i^2 = 346400.00$$

$$\mu_{\min} = \text{Min}(\mu_x, \mu_y) = 0.00261799$$

Expression ((5.4d), TB DY) for μ_{\min} has been multiplied by 0.3 according to 15.7.1.3 for members without earthquake detailing (90° closed stirrups)

$$\mu_x(5.4d) = 0.00349066$$

$$A_{sh} = A_{stir} * n_s = 78.53982$$

$$\text{No stirrups, } n_s = 2.00$$

$$b_k = 300.00$$

$$\mu_y(5.4d) = 0.00261799$$

$$A_{sh} = A_{stir} * n_s = 78.53982$$

$$\text{No stirrups, } n_s = 2.00$$

$$b_k = 400.00$$

$$s = 150.00$$

$$f_{ywe} = 555.55$$

$$f_{ce} = 20.00$$

$$\text{From ((5.A5), TB DY), TB DY: } \alpha = 0.002$$

$$c = \text{confinement factor} = 1.00$$

$$y_1 = 0.00129669$$

$$sh_1 = 0.0044814$$

$$f_{t1} = 373.4467$$

$$f_{y1} = 311.2056$$

$$\mu_1 = 0.00512$$

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor and also multiplied by the shear_factor according to 15.7.1.4, with Shear_factor = 1.00

$$l_o/l_{o,\min} = l_b/l_d = 0.30$$

$$\mu_1 = 0.4 * \mu_{1,\text{nominal}}((5.5), \text{TB DY}) = 0.032$$

From table 5A.1, TB DY: $\mu_{1,\text{nominal}} = 0.08$,

For calculation of $\mu_{1,\text{nominal}}$ and $y_1, sh_1, f_{t1}, f_{y1}$, it is considered characteristic value $f_{s1} = f_{s1}/1.2$, from table 5.1, TB DY.

$y_1, sh_1, f_{t1}, f_{y1}$, are also multiplied by $\text{Min}(1, 1.25 * (l_b/l_d)^{2/3})$, from 10.3.5, ASCE 41-17.

$$\text{with } f_{s1} = f_s = 311.2056$$

```

with Es1 = Es = 200000.00
y2 = 0.00129669
sh2 = 0.0044814
ft2 = 373.4467
fy2 = 311.2056
su2 = 0.00512
using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00
lo/lou,min = lb/lb,min = 0.30
su2 = 0.4*esu2_nominal ((5.5), TBDY) = 0.032
From table 5A.1, TBDY: esu2_nominal = 0.08,
For calculation of esu2_nominal and y2, sh2,ft2,fy2, it is considered
characteristic value fsy2 = fs2/1.2, from table 5.1, TBDY.
y1, sh1,ft1,fy1, are also multiplied by Min(1,1.25*(lb/d)^ 2/3), from 10.3.5, ASCE 41-17.
with fs2 = fs = 311.2056
with Es2 = Es = 200000.00
yv = 0.00129669
shv = 0.0044814
ftv = 373.4467
fyv = 311.2056
suv = 0.00512
using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00
lo/lou,min = lb/d = 0.30
suv = 0.4*esuv_nominal ((5.5), TBDY) = 0.032
From table 5A.1, TBDY: esuv_nominal = 0.08,
considering characteristic value fsyv = fsv/1.2, from table 5.1, TBDY
For calculation of esuv_nominal and yv, shv,ftv,fyv, it is considered
characteristic value fsyv = fsv/1.2, from table 5.1, TBDY.
y1, sh1,ft1,fy1, are also multiplied by Min(1,1.25*(lb/d)^ 2/3), from 10.3.5, ASCE 41-17.
with fsv = fs = 311.2056
with Esv = Es = 200000.00
1 = Asl,ten/(b*d)*(fs1/fc) = 0.08921112
2 = Asl,com/(b*d)*(fs2/fc) = 0.08739049
v = Asl,mid/(b*d)*(fsv/fc) = 0.04460556
and confined core properties:
b = 240.00
d = 328.00
d' = 13.00
fcc (5A.2, TBDY) = 20.00
cc (5A.5, TBDY) = 0.002
c = confinement factor = 1.00
1 = Asl,ten/(b*d)*(fs1/fc) = 0.12171334
2 = Asl,com/(b*d)*(fs2/fc) = 0.1192294
v = Asl,mid/(b*d)*(fsv/fc) = 0.06085667
Case/Assumption: Unconfined full section - Steel rupture
'satisfies Eq. (4.3)
--->
v < vs,y2 - LHS eq.(4.5) is satisfied
--->
su (4.9) = 0.20108809
Mu = MRc (4.14) = 8.1957E+007
u = su (4.1) = 1.7901443E-005

```

Calculation of ratio lb/d

Inadequate Lap Length with lb/d = 0.30

Calculation of Mu2+

Calculation of ultimate curvature ϕ_u according to 4.1, Biskinis/Fardis 2013:

$$\phi_u = 1.7862388E-005$$

$$\mu_u = 8.0533E+007$$

with full section properties:

$$b = 300.00$$

$$d = 358.00$$

$$d' = 43.00$$

$$v = 0.00018626$$

$$N = 400.0832$$

$$f_c = 20.00$$

$$\phi_{cc} (5A.5, \text{TBDY}) = 0.002$$

$$\text{Final value of } \phi_{cu}: \phi_{cu}^* = \text{shear_factor} * \text{Max}(\phi_{cu}, \phi_{cc}) = 0.00583896$$

The Shear_factor is considered equal to 1 (pure moment strength)

$$\text{From (5.4b), TBDY: } \phi_{cu} = 0.00583896$$

$$\phi_{we} (5.4c) = 0.0034192$$

$$\phi_{ase} ((5.4d), \text{TBDY}) = 0.15672608$$

$$b_o = 240.00$$

$$h_o = 340.00$$

$$b_i^2 = 346400.00$$

$$\phi_{psh,min} = \text{Min}(\phi_{psh,x}, \phi_{psh,y}) = 0.00261799$$

Expression ((5.4d), TBDY) for $\phi_{psh,min}$ has been multiplied by 0.3 according to 15.7.1.3 for members without earthquake detailing (90° closed stirrups)

$$\phi_{psh,x} (5.4d) = 0.00349066$$

$$A_{sh} = A_{stir} * n_s = 78.53982$$

$$\text{No stirrups, } n_s = 2.00$$

$$b_k = 300.00$$

$$\phi_{psh,y} (5.4d) = 0.00261799$$

$$A_{sh} = A_{stir} * n_s = 78.53982$$

$$\text{No stirrups, } n_s = 2.00$$

$$b_k = 400.00$$

$$s = 150.00$$

$$f_{ywe} = 555.55$$

$$f_{ce} = 20.00$$

$$\text{From ((5.A.5), TBDY), TBDY: } \phi_{cc} = 0.002$$

$$c = \text{confinement factor} = 1.00$$

$$y_1 = 0.00129669$$

$$sh_1 = 0.0044814$$

$$f_{t1} = 373.4467$$

$$f_{y1} = 311.2056$$

$$su_1 = 0.00512$$

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00

$$l_o/l_{ou,min} = l_b/l_d = 0.30$$

$$su_1 = 0.4 * \phi_{su1_nominal} ((5.5), \text{TBDY}) = 0.032$$

$$\text{From table 5A.1, TBDY: } \phi_{su1_nominal} = 0.08,$$

For calculation of $\phi_{su1_nominal}$ and y_1 , sh_1 , f_{t1} , f_{y1} , it is considered
characteristic value $f_{sy1} = f_{s1}/1.2$, from table 5.1, TBDY.

y_1 , sh_1 , f_{t1} , f_{y1} , are also multiplied by $\text{Min}(1, 1.25 * (l_b/l_d)^{2/3})$, from 10.3.5, ASCE 41-17.

$$\text{with } f_{s1} = f_s = 311.2056$$

$$\text{with } E_{s1} = E_s = 200000.00$$

$$y_2 = 0.00129669$$

$$sh_2 = 0.0044814$$

$$f_{t2} = 373.4467$$

$$f_{y2} = 311.2056$$

$$su_2 = 0.00512$$

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00

$$l_o/l_{ou,min} = l_b/l_{b,min} = 0.30$$

$$su_2 = 0.4 * \phi_{su2_nominal} ((5.5), \text{TBDY}) = 0.032$$

$$\text{From table 5A.1, TBDY: } \phi_{su2_nominal} = 0.08,$$

For calculation of $\phi_{su2_nominal}$ and y_2 , sh_2 , f_{t2} , f_{y2} , it is considered

characteristic value $f_{sy2} = f_{s2}/1.2$, from table 5.1, TBDY.
 $y1, sh1, ft1, fy1$, are also multiplied by $\text{Min}(1, 1.25 \cdot (l_b/l_d)^{2/3})$, from 10.3.5, ASCE 41-17.
 with $f_{s2} = f_s = 311.2056$
 with $E_{s2} = E_s = 200000.00$
 $y_v = 0.00129669$
 $sh_v = 0.0044814$
 $ft_v = 373.4467$
 $fy_v = 311.2056$
 $suv = 0.00512$
 using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
 and also multiplied by the shear_factor according to 15.7.1.4, with
 Shear_factor = 1.00
 $l_o/l_{ou,min} = l_b/l_d = 0.30$
 $suv = 0.4 \cdot esuv_{nominal} ((5.5), TBDY) = 0.032$
 From table 5A.1, TBDY: $esuv_{nominal} = 0.08$,
 considering characteristic value $f_{syv} = f_{sv}/1.2$, from table 5.1, TBDY
 For calculation of $esuv_{nominal}$ and y_v, sh_v, ft_v, fy_v , it is considered
 characteristic value $f_{syv} = f_{sv}/1.2$, from table 5.1, TBDY.
 $y1, sh1, ft1, fy1$, are also multiplied by $\text{Min}(1, 1.25 \cdot (l_b/l_d)^{2/3})$, from 10.3.5, ASCE 41-17.
 with $f_{sv} = f_s = 311.2056$
 with $E_{sv} = E_s = 200000.00$
 $1 = A_{sl,ten}/(b \cdot d) \cdot (f_{s1}/f_c) = 0.08739049$
 $2 = A_{sl,com}/(b \cdot d) \cdot (f_{s2}/f_c) = 0.08921112$
 $v = A_{sl,mid}/(b \cdot d) \cdot (f_{sv}/f_c) = 0.04460556$
 and confined core properties:
 $b = 240.00$
 $d = 328.00$
 $d' = 13.00$
 $f_{cc} (5A.2, TBDY) = 20.00$
 $cc (5A.5, TBDY) = 0.002$
 $c = \text{confinement factor} = 1.00$
 $1 = A_{sl,ten}/(b \cdot d) \cdot (f_{s1}/f_c) = 0.1192294$
 $2 = A_{sl,com}/(b \cdot d) \cdot (f_{s2}/f_c) = 0.12171334$
 $v = A_{sl,mid}/(b \cdot d) \cdot (f_{sv}/f_c) = 0.06085667$
 Case/Assumption: Unconfined full section - Steel rupture
 ' satisfies Eq. (4.3)
 --->
 $v < v_{s,y2}$ - LHS eq.(4.5) is satisfied
 --->
 $su (4.9) = 0.19934131$
 $Mu = MR_c (4.14) = 8.0533E+007$
 $u = su (4.1) = 1.7862388E-005$

Calculation of ratio l_b/l_d

Inadequate Lap Length with $l_b/l_d = 0.30$

Calculation of $Mu2$ -

Calculation of ultimate curvature ϕ_u according to 4.1, Biskinis/Fardis 2013:

$u = 1.7939215E-005$
 $Mu = 8.1873E+007$

with full section properties:

$b = 300.00$
 $d = 357.00$
 $d' = 42.00$
 $v = 0.00018678$
 $N = 400.0832$
 $f_c = 20.00$
 $cc (5A.5, TBDY) = 0.002$
 Final value of ϕ_u : $\phi_u^* = \text{shear_factor} \cdot \text{Max}(\phi_u, cc) = 0.00583896$

The Shear_factor is considered equal to 1 (pure moment strength)
 From (5.4b), TBDY: $c_u = 0.00583896$
 w_e (5.4c) = 0.0034192
 a_{se} ((5.4d), TBDY) = 0.15672608
 $b_o = 240.00$
 $h_o = 340.00$
 $b_{i2} = 346400.00$
 $p_{sh,min} = \text{Min}(p_{sh,x}, p_{sh,y}) = 0.00261799$
 Expression ((5.4d), TBDY) for $p_{sh,min}$ has been multiplied by 0.3 according to 15.7.1.3 for members without earthquake detailing (90° closed stirrups)

 $p_{sh,x}$ (5.4d) = 0.00349066
 $A_{sh} = A_{stir} \cdot n_s = 78.53982$
 No stirrups, $n_s = 2.00$
 $b_k = 300.00$

 $p_{sh,y}$ (5.4d) = 0.00261799
 $A_{sh} = A_{stir} \cdot n_s = 78.53982$
 No stirrups, $n_s = 2.00$
 $b_k = 400.00$

 $s = 150.00$
 $f_{ywe} = 555.55$
 $f_{ce} = 20.00$
 From ((5.A5), TBDY), TBDY: $c_c = 0.002$
 $c = \text{confinement factor} = 1.00$
 $y_1 = 0.00129669$
 $sh_1 = 0.0044814$
 $ft_1 = 373.4467$
 $fy_1 = 311.2056$
 $su_1 = 0.00512$
 using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
 and also multiplied by the shear_factor according to 15.7.1.4, with
 Shear_factor = 1.00
 $l_o/l_{ou,min} = l_b/l_d = 0.30$
 $su_1 = 0.4 \cdot esu1_{nominal}$ ((5.5), TBDY) = 0.032
 From table 5A.1, TBDY: $esu1_{nominal} = 0.08$,
 For calculation of $esu1_{nominal}$ and y_1, sh_1, ft_1, fy_1 , it is considered
 characteristic value $fsy_1 = fs_1/1.2$, from table 5.1, TBDY.
 y_1, sh_1, ft_1, fy_1 , are also multiplied by $\text{Min}(1, 1.25 \cdot (l_b/l_d)^{2/3})$, from 10.3.5, ASCE 41-17.
 with $fs_1 = fs = 311.2056$
 with $Es_1 = Es = 200000.00$
 $y_2 = 0.00129669$
 $sh_2 = 0.0044814$
 $ft_2 = 373.4467$
 $fy_2 = 311.2056$
 $su_2 = 0.00512$
 using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
 and also multiplied by the shear_factor according to 15.7.1.4, with
 Shear_factor = 1.00
 $l_o/l_{ou,min} = l_b/l_{b,min} = 0.30$
 $su_2 = 0.4 \cdot esu2_{nominal}$ ((5.5), TBDY) = 0.032
 From table 5A.1, TBDY: $esu2_{nominal} = 0.08$,
 For calculation of $esu2_{nominal}$ and y_2, sh_2, ft_2, fy_2 , it is considered
 characteristic value $fsy_2 = fs_2/1.2$, from table 5.1, TBDY.
 y_1, sh_1, ft_1, fy_1 , are also multiplied by $\text{Min}(1, 1.25 \cdot (l_b/l_d)^{2/3})$, from 10.3.5, ASCE 41-17.
 with $fs_2 = fs = 311.2056$
 with $Es_2 = Es = 200000.00$
 $y_v = 0.00129669$
 $sh_v = 0.0044814$
 $ft_v = 373.4467$
 $fy_v = 311.2056$
 $suv = 0.00512$
 using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
 and also multiplied by the shear_factor according to 15.7.1.4, with
 Shear_factor = 1.00
 $l_o/l_{ou,min} = l_b/l_d = 0.30$

$suv = 0.4 * esuv_nominal ((5.5), TBDY) = 0.032$
 From table 5A.1, TBDY: $esuv_nominal = 0.08$,
 considering characteristic value $fsyv = fsv/1.2$, from table 5.1, TBDY
 For calculation of $esuv_nominal$ and yv, shv, ftv, fyv , it is considered
 characteristic value $fsyv = fsv/1.2$, from table 5.1, TBDY.
 $y1, sh1, ft1, fy1$, are also multiplied by $Min(1, 1.25 * (lb/ld)^{2/3})$, from 10.3.5, ASCE 41-17.
 with $fsv = fs = 311.2056$
 with $Esv = Es = 200000.00$
 $1 = Asl,ten/(b*d)*(fs1/fc) = 0.08946101$
 $2 = Asl,com/(b*d)*(fs2/fc) = 0.08763528$
 $v = Asl,mid/(b*d)*(fsv/fc) = 0.04473051$
 and confined core properties:
 $b = 240.00$
 $d = 327.00$
 $d' = 12.00$
 $fcc (5A.2, TBDY) = 20.00$
 $cc (5A.5, TBDY) = 0.002$
 $c = \text{confinement factor} = 1.00$
 $1 = Asl,ten/(b*d)*(fs1/fc) = 0.12208556$
 $2 = Asl,com/(b*d)*(fs2/fc) = 0.11959401$
 $v = Asl,mid/(b*d)*(fsv/fc) = 0.06104278$
 Case/Assumption: Unconfined full section - Steel rupture
 ' satisfies Eq. (4.3)
 --->
 $v < vs,y2$ - LHS eq.(4.5) is satisfied
 ---->
 $su (4.9) = 0.20053711$
 $Mu = MRc (4.14) = 8.1873E+007$
 $u = su (4.1) = 1.7939215E-005$

Calculation of ratio lb/ld

Inadequate Lap Length with $lb/ld = 0.30$

Calculation of Shear Strength $Vr = Min(Vr1, Vr2) = 227879.44$

Calculation of Shear Strength at edge 1, $Vr1 = 227879.44$
 $Vr1 = Vn ((22.5.1.1), ACI 318-14)$

NOTE: In expression (22.5.1.1) ' Vw ' is replaced by ' $Vw + f*Vf$ '
 where Vf is the contribution of FRPs (11.3), ACI 440).

From Table (22.5.5.1), ACI 318-14: $Vc = 78946.167$
 $= 1$ (normal-weight concrete)
 $fc' = 20.00$, but $fc^{0.5} \leq 8.3$ MPa (22.5.3.1, ACI 318-14)
 $pw = As/(bw*d) = 0.00628319$
 As (tension reinf.) = 603.1858
 $bw = 300.00$
 $d = 320.00$
 $Vu*d/Mu < 1 = 1.00$
 $Mu = 60442.822$
 $Vu = 4076.60$

From (11.5.4.8), ACI 318-14: $Vs = 148933.273$
 $Av = 157079.633$
 $fy = 444.44$
 $s = 150.00$

Vs has been multiplied by 1 ($s < d/2$, according to ASCE 41-17, 10.3.4)

$Vf ((11-3)-(11.4), ACI 440) = 0.00$

From (11-11), ACI 440: $Vs + Vf \leq 285202.276$

Calculation of Shear Strength at edge 2, $Vr2 = 227879.44$
 $Vr2 = Vn ((22.5.1.1), ACI 318-14)$

NOTE: In expression (22.5.1.1) 'Vw' is replaced by 'Vw+ f*Vf'
where Vf is the contribution of FRPs (11.3), ACI 440).

From Table (22.5.5.1), ACI 318-14: $V_c = 78946.167$
= 1 (normal-weight concrete)

$f'_c = 20.00$, but $f'_c^{0.5} \leq 8.3$ MPa (22.5.3.1, ACI 318-14)

$\rho_w = A_s/(b_w*d) = 0.00628319$

A_s (tension reinf.) = 603.1858

$b_w = 300.00$

$d = 320.00$

$V_u*d/M_u < 1 = 1.00$

$M_u = 155096.693$

$V_u = 4178.928$

From (11.5.4.8), ACI 318-14: $V_s = 148933.273$

$A_v = 157079.633$

$f_y = 444.44$

$s = 150.00$

V_s has been multiplied by 1 ($s < d/2$, according to ASCE 41-17, 10.3.4)

V_f ((11-3)-(11.4), ACI 440) = 0.00

From (11-11), ACI 440: $V_s + V_f \leq 285202.276$

End Of Calculation of Shear Capacity ratio for element: beam B1 of floor 1
At local axis: 3

Start Of Calculation of Shear Capacity ratio for element: beam B1 of floor 1
At Shear local axis: 2
(Bending local axis: 3)
Section Type: rcars

Constant Properties

Knowledge Factor, = 1.00

Mean strength values are used for both shear and moment calculations.

Consequently:

Existing material of Secondary Member: Concrete Strength, $f_c = f_{cm} = 20.00$

Existing material of Secondary Member: Steel Strength, $f_s = f_{sm} = 444.44$

Concrete Elasticity, $E_c = 21019.039$

Steel Elasticity, $E_s = 200000.00$

#####

Note: Especially for the calculation of moment strengths,

the above steel re-bar strengths are multiplied by 1.25 according to R18.6.5, ACI 318-14

Existing material: Steel Strength, $f_s = 1.25*f_{sm} = 555.55$

#####

Section Height, $H = 400.00$

Section Width, $W = 300.00$

Cover Thickness, $c = 25.00$

Mean Confinement Factor overall section = 1.00

Element Length, $L = 1850.00$

Secondary Member

Ribbed Bars

Ductile Steel

Without Detailing for Earthquake Resistance (including stirrups not closed at 135°)

Longitudinal Bars With Ends Lapped Starting at the End Sections

Inadequate Lap Length with $l_o/l_{ou,min} = 0.30$

No FRP Wrapping

Stepwise Properties

At local axis: 2

EDGE -A-

Shear Force, $V_a = -1.0090939E-010$

EDGE -B-

Shear Force, $V_b = 1.0090939E-010$

BOTH EDGES

Axial Force, $F = -400.0832$

Longitudinal Reinforcement Area Distribution (in 2 divisions)

-Tension: $As_t = 603.1858$

-Compression: $As_c = 923.6282$

Longitudinal Reinforcement Area Distribution (in 3 divisions)

-Tension: $As_{t,ten} = 508.938$

-Compression: $As_{c,com} = 508.938$

-Middle: $As_{mid} = 508.938$

Calculation of Shear Capacity ratio, $V_e/V_r = 0.37923485$

Member Controlled by Flexure ($V_e/V_r < 1$)

Calculation of Shear Demand from fig. R18.6.5, ACI 318-14 $V_e = (M_{pr1} + M_{pr2})/l_n \pm w_u \cdot l_n/2 = 57820.79$ with

$M_{pr1} = \text{Max}(Mu_{1+}, Mu_{1-}) = 5.3484E+007$

$Mu_{1+} = 5.3484E+007$, is the ultimate moment strength at the edge 1 of the member in the actual moment direction which is defined for the static loading combination

$Mu_{1-} = 5.3484E+007$, is the ultimate moment strength at the edge 1 of the member in the opposite moment direction which is defined for the static loading combination

$M_{pr2} = \text{Max}(Mu_{2+}, Mu_{2-}) = 5.3484E+007$

$Mu_{2+} = 5.3484E+007$, is the ultimate moment strength at the edge 2 of the member in the actual moment direction which is defined for the static loading combination

$Mu_{2-} = 5.3484E+007$, is the ultimate moment strength at the edge 2 of the member in the opposite moment direction which is defined for the static loading combination

and

$\pm w_u \cdot l_n = (|V_1| + |V_2|)/2$

with

$V_1 = -1.0090939E-010$, is the shear force acting at edge 1 for the static loading combination

$V_2 = 1.0090939E-010$, is the shear force acting at edge 2 for the static loading combination

Calculation of Mu_{1+}

Calculation of ultimate curvature ϕ_u according to 4.1, Biskinis/Fardis 2013:

$\phi_u = 2.5364147E-005$

$M_u = 5.3484E+007$

with full section properties:

$b = 400.00$

$d = 258.00$

$d' = 42.00$

$v = 0.00019384$

$N = 400.0832$

$f_c = 20.00$

ϕ_c (5A.5, TBDY) = 0.002

Final value of ϕ_u : $\phi_u^* = \text{shear_factor} \cdot \text{Max}(\phi_u, \phi_c) = 0.00583896$

The Shear_factor is considered equal to 1 (pure moment strength)

From (5.4b), TBDY: $\phi_u = 0.00583896$

w_e (5.4c) = 0.0034192

a_{se} ((5.4d), TBDY) = 0.15672608

$b_o = 240.00$

$h_o = 340.00$

$bi_2 = 346400.00$

$\phi_{sh,min} = \text{Min}(\phi_{sh,x}, \phi_{sh,y}) = 0.00261799$

Expression ((5.4d), TBDY) for $\phi_{sh,min}$ has been multiplied by 0.3 according to 15.7.1.3 for members without earthquake detailing (90° closed stirrups)

$\phi_{sh,x}$ (5.4d) = 0.00349066

$A_{sh} = A_{stir} \cdot n_s = 78.53982$

No stirrups, $n_s = 2.00$

$b_k = 300.00$

psh,y (5.4d) = 0.00261799
 Ash = Astir*ns = 78.53982
 No stirups, ns = 2.00
 bk = 400.00

s = 150.00
 fywe = 555.55
 fce = 20.00

From ((5.A.5), TBDY), TBDY: cc = 0.002
 c = confinement factor = 1.00

y1 = 0.00129669
 sh1 = 0.0044814

ft1 = 373.4467

fy1 = 311.2056

su1 = 0.00512

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
 and also multiplied by the shear_factor according to 15.7.1.4, with
 Shear_factor = 1.00

lo/lou,min = lb/lb,min = 0.30

su1 = 0.4*esu1_nominal ((5.5), TBDY) = 0.032

From table 5A.1, TBDY: esu1_nominal = 0.08,

For calculation of esu1_nominal and y1, sh1,ft1,fy1, it is considered
 characteristic value fsy1 = fs1/1.2, from table 5.1, TBDY.

y1, sh1,ft1,fy1, are also multiplied by $\text{Min}(1, 1.25 \cdot (lb/ld)^{2/3})$, from 10.3.5, ASCE 41-17.

with fs1 = fs = 311.2056

with Es1 = Es = 200000.00

y2 = 0.00129669

sh2 = 0.0044814

ft2 = 373.4467

fy2 = 311.2056

su2 = 0.00512

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
 and also multiplied by the shear_factor according to 15.7.1.4, with
 Shear_factor = 1.00

lo/lou,min = lb/lb,min = 0.30

su2 = 0.4*esu2_nominal ((5.5), TBDY) = 0.032

From table 5A.1, TBDY: esu2_nominal = 0.08,

For calculation of esu2_nominal and y2, sh2,ft2,fy2, it is considered
 characteristic value fsy2 = fs2/1.2, from table 5.1, TBDY.

y1, sh1,ft1,fy1, are also multiplied by $\text{Min}(1, 1.25 \cdot (lb/ld)^{2/3})$, from 10.3.5, ASCE 41-17.

with fs2 = fs = 311.2056

with Es2 = Es = 200000.00

yv = 0.00129669

shv = 0.0044814

ftv = 373.4467

fyv = 311.2056

suv = 0.00512

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
 and also multiplied by the shear_factor according to 15.7.1.4, with
 Shear_factor = 1.00

lo/lou,min = lb/ld = 0.30

suv = 0.4*esuv_nominal ((5.5), TBDY) = 0.032

From table 5A.1, TBDY: esuv_nominal = 0.08,

considering characteristic value fsyv = fsv/1.2, from table 5.1, TBDY

For calculation of esuv_nominal and yv, shv,ftv,fyv, it is considered
 characteristic value fsyv = fsv/1.2, from table 5.1, TBDY.

y1, sh1,ft1,fy1, are also multiplied by $\text{Min}(1, 1.25 \cdot (lb/ld)^{2/3})$, from 10.3.5, ASCE 41-17.

with fsv = fs = 311.2056

with Esv = Es = 200000.00

1 = Asl,ten/(b*d)*(fs1/fc) = 0.0767366

2 = Asl,com/(b*d)*(fs2/fc) = 0.0767366

v = Asl,mid/(b*d)*(fsv/fc) = 0.0767366

and confined core properties:

b = 340.00

d = 228.00

d' = 12.00

fcc (5A.2, TBDY) = 20.00

```

cc (5A.5, TBDY) = 0.002
c = confinement factor = 1.00
1 = Asl,ten/(b*d)*(fs1/fc) = 0.10215708
2 = Asl,com/(b*d)*(fs2/fc) = 0.10215708
v = Asl,mid/(b*d)*(fsv/fc) = 0.10215708
Case/Assumption: Unconfined full section - Steel rupture
'satisfies Eq. (4.3)
--->
v < vs,y2 - LHS eq.(4.5) is satisfied
--->
su (4.9) = 0.21759794
Mu = MRc (4.14) = 5.3484E+007
u = su (4.1) = 2.5364147E-005

```

Calculation of ratio lb/ld

Inadequate Lap Length with lb/ld = 0.30

Calculation of Mu1-

Calculation of ultimate curvature u according to 4.1, Biskinis/Fardis 2013:

```

u = 2.5364147E-005
Mu = 5.3484E+007

```

with full section properties:

```

b = 400.00
d = 258.00
d' = 42.00
v = 0.00019384
N = 400.0832
fc = 20.00
co (5A.5, TBDY) = 0.002
Final value of cu: cu* = shear_factor * Max( cu, cc) = 0.00583896
The Shear_factor is considered equal to 1 (pure moment strength)
From (5.4b), TBDY: cu = 0.00583896
we (5.4c) = 0.0034192
ase ((5.4d), TBDY) = 0.15672608
bo = 240.00
ho = 340.00
bi2 = 346400.00
psh,min = Min(psh,x , psh,y) = 0.00261799

```

Expression ((5.4d), TBDY) for psh,min has been multiplied by 0.3 according to 15.7.1.3 for members without earthquake detailing (90° closed stirrups)

```

psh,x (5.4d) = 0.00349066
Ash = Astir*ns = 78.53982
No stirups, ns = 2.00
bk = 300.00

```

```

psh,y (5.4d) = 0.00261799
Ash = Astir*ns = 78.53982
No stirups, ns = 2.00
bk = 400.00

```

```

s = 150.00
fywe = 555.55
fce = 20.00
From ((5.A5), TBDY), TBDY: cc = 0.002
c = confinement factor = 1.00
y1 = 0.00129669
sh1 = 0.0044814
ft1 = 373.4467

```



```

fy1 = 311.2056
su1 = 0.00512
    using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
    and also multiplied by the shear_factor according to 15.7.1.4, with
    Shear_factor = 1.00
    lo/lou,min = lb/lb = 0.30
    su1 = 0.4*esu1_nominal ((5.5), TBDY) = 0.032
    From table 5A.1, TBDY: esu1_nominal = 0.08,
    For calculation of esu1_nominal and y1, sh1,ft1,fy1, it is considered
    characteristic value fsy1 = fs1/1.2, from table 5.1, TBDY.
    y1, sh1,ft1,fy1, are also multiplied by Min(1,1.25*(lb/lb)^ 2/3), from 10.3.5, ASCE 41-17.
    with fs1 = fs = 311.2056
    with Es1 = Es = 200000.00
y2 = 0.00129669
sh2 = 0.0044814
ft2 = 373.4467
fy2 = 311.2056
su2 = 0.00512
    using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
    and also multiplied by the shear_factor according to 15.7.1.4, with
    Shear_factor = 1.00
    lo/lou,min = lb/lb,min = 0.30
    su2 = 0.4*esu2_nominal ((5.5), TBDY) = 0.032
    From table 5A.1, TBDY: esu2_nominal = 0.08,
    For calculation of esu2_nominal and y2, sh2,ft2,fy2, it is considered
    characteristic value fsy2 = fs2/1.2, from table 5.1, TBDY.
    y1, sh1,ft1,fy1, are also multiplied by Min(1,1.25*(lb/lb)^ 2/3), from 10.3.5, ASCE 41-17.
    with fs2 = fs = 311.2056
    with Es2 = Es = 200000.00
yv = 0.00129669
shv = 0.0044814
ftv = 373.4467
fyv = 311.2056
suv = 0.00512
    using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
    and also multiplied by the shear_factor according to 15.7.1.4, with
    Shear_factor = 1.00
    lo/lou,min = lb/lb = 0.30
    suv = 0.4*esuv_nominal ((5.5), TBDY) = 0.032
    From table 5A.1, TBDY: esuv_nominal = 0.08,
    considering characteristic value fsyv = fsv/1.2, from table 5.1, TBDY
    For calculation of esuv_nominal and yv, shv,ftv,fyv, it is considered
    characteristic value fsyv = fsv/1.2, from table 5.1, TBDY.
    y1, sh1,ft1,fy1, are also multiplied by Min(1,1.25*(lb/lb)^ 2/3), from 10.3.5, ASCE 41-17.
    with fsv = fs = 311.2056
    with Esv = Es = 200000.00
1 = Asl,ten/(b*d)*(fs1/fc) = 0.0767366
2 = Asl,com/(b*d)*(fs2/fc) = 0.0767366
v = Asl,mid/(b*d)*(fsv/fc) = 0.0767366
and confined core properties:
b = 340.00
d = 228.00
d' = 12.00
fcc (5A.2, TBDY) = 20.00
cc (5A.5, TBDY) = 0.002
    c = confinement factor = 1.00
1 = Asl,ten/(b*d)*(fs1/fc) = 0.10215708
2 = Asl,com/(b*d)*(fs2/fc) = 0.10215708
v = Asl,mid/(b*d)*(fsv/fc) = 0.10215708
Case/Assumption: Unconfined full section - Steel rupture
' satisfies Eq. (4.3)
--->
v < vs,y2 - LHS eq.(4.5) is satisfied
--->
su (4.9) = 0.21759794
Mu = MRc (4.14) = 5.3484E+007
u = su (4.1) = 2.5364147E-005

```

Calculation of ratio l_b/l_d

Inadequate Lap Length with $l_b/l_d = 0.30$

Calculation of μ_{2+}

Calculation of ultimate curvature μ according to 4.1, Biskinis/Fardis 2013:

$$\mu = 2.5364147E-005$$

$$\mu = 5.3484E+007$$

with full section properties:

$$b = 400.00$$

$$d = 258.00$$

$$d' = 42.00$$

$$v = 0.00019384$$

$$N = 400.0832$$

$$f_c = 20.00$$

$$\alpha (5A.5, \text{TB DY}) = 0.002$$

$$\text{Final value of } \mu: \mu^* = \text{shear_factor} * \text{Max}(\mu, \alpha) = 0.00583896$$

The Shear_factor is considered equal to 1 (pure moment strength)

$$\text{From (5.4b), TB DY: } \mu = 0.00583896$$

$$\mu (5.4c) = 0.0034192$$

$$\alpha (5.4d), \text{TB DY} = 0.15672608$$

$$b_o = 240.00$$

$$h_o = 340.00$$

$$b_{i2} = 346400.00$$

$$\mu_{sh,min} = \text{Min}(\mu_{sh,x}, \mu_{sh,y}) = 0.00261799$$

Expression ((5.4d), TB DY) for $\mu_{sh,min}$ has been multiplied by 0.3 according to 15.7.1.3 for members without earthquake detailing (90° closed stirrups)

$$\mu_{sh,x} (5.4d) = 0.00349066$$

$$A_{sh} = A_{stir} * n_s = 78.53982$$

$$\text{No stirrups, } n_s = 2.00$$

$$b_k = 300.00$$

$$\mu_{sh,y} (5.4d) = 0.00261799$$

$$A_{sh} = A_{stir} * n_s = 78.53982$$

$$\text{No stirrups, } n_s = 2.00$$

$$b_k = 400.00$$

$$s = 150.00$$

$$f_{ywe} = 555.55$$

$$f_{ce} = 20.00$$

$$\text{From ((5.A.5), TB DY), TB DY: } \alpha = 0.002$$

$$c = \text{confinement factor} = 1.00$$

$$y_1 = 0.00129669$$

$$sh_1 = 0.0044814$$

$$ft_1 = 373.4467$$

$$fy_1 = 311.2056$$

$$su_1 = 0.00512$$

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor and also multiplied by the shear_factor according to 15.7.1.4, with Shear_factor = 1.00

$$l_o/l_{o,min} = l_b/l_d = 0.30$$

$$su_1 = 0.4 * su_{1,nominal} ((5.5), \text{TB DY}) = 0.032$$

$$\text{From table 5A.1, TB DY: } su_{1,nominal} = 0.08,$$

For calculation of $su_{1,nominal}$ and y_1, sh_1, ft_1, fy_1 , it is considered characteristic value $fs_1 = fs_1/1.2$, from table 5.1, TB DY.

y_1, sh_1, ft_1, fy_1 , are also multiplied by $\text{Min}(1, 1.25 * (l_b/l_d)^{2/3})$, from 10.3.5, ASCE 41-17.

$$\text{with } fs_1 = fs = 311.2056$$

$$\text{with } E_{s1} = E_s = 200000.00$$

```

y2 = 0.00129669
sh2 = 0.0044814
ft2 = 373.4467
fy2 = 311.2056
su2 = 0.00512
using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00
lo/lou,min = lb/lb,min = 0.30
su2 = 0.4*esu2_nominal ((5.5), TBDY) = 0.032
From table 5A.1, TBDY: esu2_nominal = 0.08,
For calculation of esu2_nominal and y2, sh2,ft2,fy2, it is considered
characteristic value fsy2 = fs2/1.2, from table 5.1, TBDY.
y1, sh1,ft1,fy1, are also multiplied by Min(1,1.25*(lb/ld)^ 2/3), from 10.3.5, ASCE 41-17.
with fs2 = fs = 311.2056
with Es2 = Es = 200000.00
yv = 0.00129669
shv = 0.0044814
ftv = 373.4467
fyv = 311.2056
suv = 0.00512
using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00
lo/lou,min = lb/ld = 0.30
suv = 0.4*esuv_nominal ((5.5), TBDY) = 0.032
From table 5A.1, TBDY: esuv_nominal = 0.08,
considering characteristic value fsyv = fsv/1.2, from table 5.1, TBDY
For calculation of esuv_nominal and yv, shv,ftv,fyv, it is considered
characteristic value fsyv = fsv/1.2, from table 5.1, TBDY.
y1, sh1,ft1,fy1, are also multiplied by Min(1,1.25*(lb/ld)^ 2/3), from 10.3.5, ASCE 41-17.
with fsv = fs = 311.2056
with Esv = Es = 200000.00
1 = Asl,ten/(b*d)*(fs1/fc) = 0.0767366
2 = Asl,com/(b*d)*(fs2/fc) = 0.0767366
v = Asl,mid/(b*d)*(fsv/fc) = 0.0767366
and confined core properties:
b = 340.00
d = 228.00
d' = 12.00
fcc (5A.2, TBDY) = 20.00
cc (5A.5, TBDY) = 0.002
c = confinement factor = 1.00
1 = Asl,ten/(b*d)*(fs1/fc) = 0.10215708
2 = Asl,com/(b*d)*(fs2/fc) = 0.10215708
v = Asl,mid/(b*d)*(fsv/fc) = 0.10215708
Case/Assumption: Unconfined full section - Steel rupture
'satisfies Eq. (4.3)
--->
v < vs,y2 - LHS eq.(4.5) is satisfied
--->
su (4.9) = 0.21759794
Mu = MRc (4.14) = 5.3484E+007
u = su (4.1) = 2.5364147E-005

```

Calculation of ratio lb/ld

Inadequate Lap Length with lb/ld = 0.30

Calculation of Mu2-

Calculation of ultimate curvature u according to 4.1, Biskinis/Fardis 2013:

u = 2.5364147E-005
Mu = 5.3484E+007

with full section properties:

b = 400.00

d = 258.00

d' = 42.00

v = 0.00019384

N = 400.0832

fc = 20.00

co (5A.5, TBDY) = 0.002

Final value of cu: $cu^* = \text{shear_factor} * \text{Max}(cu, cc) = 0.00583896$

The Shear_factor is considered equal to 1 (pure moment strength)

From (5.4b), TBDY: $cu = 0.00583896$

we (5.4c) = 0.0034192

ase ((5.4d), TBDY) = 0.15672608

bo = 240.00

ho = 340.00

bi2 = 346400.00

psh,min = Min(psh,x , psh,y) = 0.00261799

Expression ((5.4d), TBDY) for psh,min has been multiplied by 0.3 according to 15.7.1.3 for members without earthquake detailing (90° closed stirrups)

psh,x (5.4d) = 0.00349066

Ash = Astir*ns = 78.53982

No stirrups, ns = 2.00

bk = 300.00

psh,y (5.4d) = 0.00261799

Ash = Astir*ns = 78.53982

No stirrups, ns = 2.00

bk = 400.00

s = 150.00

fywe = 555.55

fce = 20.00

From ((5.A5), TBDY), TBDY: $cc = 0.002$

c = confinement factor = 1.00

y1 = 0.00129669

sh1 = 0.0044814

ft1 = 373.4467

fy1 = 311.2056

su1 = 0.00512

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00

lo/lou,min = lb/lb = 0.30

su1 = $0.4 * \text{esu1_nominal} ((5.5), \text{TBDY}) = 0.032$

From table 5A.1, TBDY: $\text{esu1_nominal} = 0.08$,

For calculation of esu1_nominal and $y1, sh1, ft1, fy1$, it is considered
characteristic value $\text{fsy1} = \text{fs1}/1.2$, from table 5.1, TBDY.

$y1, sh1, ft1, fy1$, are also multiplied by $\text{Min}(1, 1.25 * (\text{lb}/\text{ld})^{2/3})$, from 10.3.5, ASCE 41-17.

with $\text{fs1} = \text{fs} = 311.2056$

with $\text{Es1} = \text{Es} = 200000.00$

y2 = 0.00129669

sh2 = 0.0044814

ft2 = 373.4467

fy2 = 311.2056

su2 = 0.00512

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00

lo/lou,min = lb/lb,min = 0.30

su2 = $0.4 * \text{esu2_nominal} ((5.5), \text{TBDY}) = 0.032$

From table 5A.1, TBDY: $\text{esu2_nominal} = 0.08$,

For calculation of esu2_nominal and $y2, sh2, ft2, fy2$, it is considered
characteristic value $\text{fsy2} = \text{fs2}/1.2$, from table 5.1, TBDY.

y_1, sh_1, ft_1, fy_1 , are also multiplied by $\text{Min}(1, 1.25 \cdot (l_b/l_d)^{2/3})$, from 10.3.5, ASCE 41-17.
 with $fs_2 = fs = 311.2056$
 with $Es_2 = Es = 200000.00$
 $y_v = 0.00129669$
 $sh_v = 0.0044814$
 $ft_v = 373.4467$
 $fy_v = 311.2056$
 $suv = 0.00512$
 using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
 and also multiplied by the shear_factor according to 15.7.1.4, with
 Shear_factor = 1.00
 $l_o/l_{o,min} = l_b/l_d = 0.30$
 $suv = 0.4 \cdot esuv_{nominal} ((5.5), TBDY) = 0.032$
 From table 5A.1, TBDY: $esuv_{nominal} = 0.08$,
 considering characteristic value $fsyv = fsv/1.2$, from table 5.1, TBDY
 For calculation of $esuv_{nominal}$ and y_v, sh_v, ft_v, fy_v , it is considered
 characteristic value $fsyv = fsv/1.2$, from table 5.1, TBDY.
 y_1, sh_1, ft_1, fy_1 , are also multiplied by $\text{Min}(1, 1.25 \cdot (l_b/l_d)^{2/3})$, from 10.3.5, ASCE 41-17.
 with $fsv = fs = 311.2056$
 with $Es_v = Es = 200000.00$
 $1 = A_{sl,ten}/(b \cdot d) \cdot (fs_1/f_c) = 0.0767366$
 $2 = A_{sl,com}/(b \cdot d) \cdot (fs_2/f_c) = 0.0767366$
 $v = A_{sl,mid}/(b \cdot d) \cdot (fsv/f_c) = 0.0767366$

and confined core properties:

$b = 340.00$
 $d = 228.00$
 $d' = 12.00$
 $f_{cc} (5A.2, TBDY) = 20.00$
 $cc (5A.5, TBDY) = 0.002$
 $c = \text{confinement factor} = 1.00$
 $1 = A_{sl,ten}/(b \cdot d) \cdot (fs_1/f_c) = 0.10215708$
 $2 = A_{sl,com}/(b \cdot d) \cdot (fs_2/f_c) = 0.10215708$
 $v = A_{sl,mid}/(b \cdot d) \cdot (fsv/f_c) = 0.10215708$

Case/Assumption: Unconfined full section - Steel rupture
 ' satisfies Eq. (4.3)

--->
 $v < v_{s,y2}$ - LHS eq.(4.5) is satisfied
 --->
 $su (4.9) = 0.21759794$
 $Mu = MRc (4.14) = 5.3484E+007$
 $u = su (4.1) = 2.5364147E-005$

Calculation of ratio l_b/l_d

Inadequate Lap Length with $l_b/l_d = 0.30$

Calculation of Shear Strength $V_r = \text{Min}(V_{r1}, V_{r2}) = 152466.975$

Calculation of Shear Strength at edge 1, $V_{r1} = 152466.975$
 $V_{r1} = V_n ((22.5.1.1), ACI 318-14)$

NOTE: In expression (22.5.1.1) ' V_w ' is replaced by ' $V_w + f \cdot V_f$ '
 where V_f is the contribution of FRPs (11.3), ACI 440).

From Table (22.5.5.1), ACI 318-14: $V_c = 68692.008$
 $= 1$ (normal-weight concrete)
 $f_c' = 20.00$, but $f_c'^{0.5} \leq 8.3 \text{ MPa}$ (22.5.3.1, ACI 318-14)
 $pw = A_s/(b_w \cdot d) = 0.00628319$
 A_s (tension reinf.) = 603.1858
 $b_w = 400.00$
 $d = 240.00$
 $V_u \cdot d / Mu < 1 = 0.00$
 $Mu = 2.0746991E-007$

$$V_u = 1.0090939E-010$$

From (11.5.4.8), ACI 318-14: $V_s = 83774.966$

$$A_v = 157079.633$$

$$f_y = 444.44$$

$$s = 150.00$$

V_s has been multiplied by $2(1-s/d)$ ($s > d/2$, according to ASCE 41-17, 10.3.4)

$$2(1-s/d) = 0.75$$

$$V_f ((11-3)-(11.4), \text{ACI 440}) = 0.00$$

$$\text{From (11-11), ACI 440: } V_s + V_f \leq 285202.276$$

Calculation of Shear Strength at edge 2, $V_{r2} = 152466.975$

$$V_{r2} = V_n ((22.5.1.1), \text{ACI 318-14})$$

NOTE: In expression (22.5.1.1) ' V_w ' is replaced by ' $V_w + f \cdot V_f$ '
where V_f is the contribution of FRPs (11.3), ACI 440).

From Table (22.5.5.1), ACI 318-14: $V_c = 68692.008$

= 1 (normal-weight concrete)

$$f_c' = 20.00, \text{ but } f_c'^{0.5} \leq 8.3 \text{ MPa (22.5.3.1, ACI 318-14)}$$

$$p_w = A_s / (b_w \cdot d) = 0.00628319$$

$$A_s (\text{tension reinf.}) = 603.1858$$

$$b_w = 400.00$$

$$d = 240.00$$

$$V_u \cdot d / M_u < 1 = 0.00$$

$$M_u = 2.0781750E-008$$

$$V_u = 1.0090939E-010$$

From (11.5.4.8), ACI 318-14: $V_s = 83774.966$

$$A_v = 157079.633$$

$$f_y = 444.44$$

$$s = 150.00$$

V_s has been multiplied by $2(1-s/d)$ ($s > d/2$, according to ASCE 41-17, 10.3.4)

$$2(1-s/d) = 0.75$$

$$V_f ((11-3)-(11.4), \text{ACI 440}) = 0.00$$

$$\text{From (11-11), ACI 440: } V_s + V_f \leq 285202.276$$

End Of Calculation of Shear Capacity ratio for element: beam B1 of floor 1

At local axis: 2

Start Of Calculation of Chord Rotation Capacity for element: beam B1 of floor 1

At local axis: 2

Integration Section: (b)

Section Type: rcars

Constant Properties

Knowledge Factor, = 1.00

Chord Rotation is generally considered as Deformation-Controlled Action according to Table C7-1, ASCE 41-17.

Mean strengths are used for Deformation-Controlled Actions according to 7.5.1.3, ASCE 41-17

Consequently:

Existing material of Secondary Member: Concrete Strength, $f_c = f_{cm} = 20.00$

Existing material of Secondary Member: Steel Strength, $f_s = f_{sm} = 444.44$

Concrete Elasticity, $E_c = 21019.039$

Steel Elasticity, $E_s = 200000.00$

Section Height, $H = 400.00$

Section Width, $W = 300.00$

Cover Thickness, $c = 25.00$

Element Length, $L = 1850.00$

Secondary Member

Ribbed Bars

Ductile Steel

Without Detailing for Earthquake Resistance (including stirrups not closed at 135°)

Longitudinal Bars With Ends Lapped Starting at the End Sections

Inadequate Lap Length with $l_b / l_d = 0.30$

No FRP Wrapping

Stepwise Properties

Bending Moment, $M = 6.4211\text{E}+006$

Shear Force, $V2 = 5.1634141\text{E}-008$

Shear Force, $V3 = 10530.564$

Axial Force, $F = -1219.269$

Longitudinal Reinforcement Area Distribution (in 2 divisions)

-Tension: $Asl_t = 615.7522$

-Compression: $Asl_c = 911.0619$

Longitudinal Reinforcement Area Distribution (in 3 divisions)

-Tension: $Asl_{ten} = 615.7522$

-Compression: $Asl_{com} = 603.1858$

-Middle: $Asl_{mid} = 307.8761$

Mean Diameter of Tension Reinforcement, $DbL = 14.00$

Existing component: From table 7-7, ASCE 41_17: Final chord rotation Capacity $u_R =$ * $u = 0.02115069$

$u = y + p = 0.02115069$

- Calculation of y -

$y = (My * Ls / 3) / Eleff = 0.00115069$ ((4.29), Biskinis Phd))

$My = 5.7118\text{E}+007$

$Ls = M/V$ (with $Ls > 0.1 * L$ and $Ls < 2 * L$) = 609.7601

From table 10.5, ASCE 41_17: $Eleff = 0.3 * Ec * Ig = 1.0089\text{E}+013$

Calculation of Yielding Moment My

Calculation of y and My according to Annex 7 -

$y = \text{Min}(y_{ten}, y_{com})$

$y_{ten} = 4.8210792\text{E}-006$

with ((10.1), ASCE 41-17) $fy = \text{Min}(fy, 1.25 * fy * (lb/d)^{2/3}) = 248.9644$

$d = 358.00$

$y = 0.27875962$

$A = 0.01426174$

$B = 0.00805891$

with $pt = 0.00573326$

$pc = 0.00561626$

$pv = 0.00286663$

$N = 1219.269$

$b = 300.00$

$" = 0.12011173$

$y_{comp} = 1.7195925\text{E}-005$

with $fc = 20.00$

$Ec = 21019.039$

$y = 0.27821534$

$A = 0.014183$

$B = 0.00801331$

with $Es = 200000.00$

Calculation of ratio lb/d

Inadequate Lap Length with $lb/d = 0.30$

- Calculation of p -

From table 10-7: $p = 0.02$

with:

- Condition iv occurred
Beam controlled by inadequate embedment into beam-column joint:
($l_b/d < 1$ and With Lapping in the Vicinity of the End Regions)
- Condition i occurred
Beam controlled by flexure: $V_p/V_o \leq 1$
shear control ratio $V_p/V_o = 0.40672566$
- Transverse Reinforcement: NC
- Stirrup Spacing $> d/3$
- Low ductility demand, $\lambda / y < 2$ (table 10-6, ASCE 41-17)
 $= 2.7328286E-005$
- Stirrup Spacing $\leq d/2$
 $d = 358.00$
 $s = 150.00$
- Strength provided by hoops $V_s < 3/4 \times \text{design Shear}$
 $V_s = 148933.273$, already given in calculation of shear control ratio
design Shear = 10530.564
- ($\rho - \rho'$)/ $\rho_{bal} = -0.14721463$
 $= A_{st}/(b_w \times d) = 0.00573326$
Tension Reinf Area: $A_{st} = 615.7522$
 $\rho' = A_{sc}/(b_w \times d) = 0.00848289$
Compression Reinf Area: $A_{sc} = 911.0619$
- From (B-1), ACI 318-11: $\rho_{bal} = 0.01867766$
 $f_c = 20.00$
 $f_y = 444.44$
From 10.2.7.3, ACI 318-11: $\lambda = 0.85$
From fig R10.3.3, ACI 318-11 (Ence 454, too): $87000/(87000 + f_y) = c_b/d_t = 0.003/(0.003 + y) = 0.57447053$
 $y = 0.0022222$
- $V/(b_w \times d \times f_c^{0.5}) = 0.26403141$, NOTE: units in lb & in
 $b_w = 300.00$

End Of Calculation of Chord Rotation Capacity for element: beam B1 of floor 1

At local axis: 2

Integration Section: (b)

Calculation No. 15

beam B1, Floor 1



Limit State: Life Safety (data interpolation between analysis steps 1 and 2)

Analysis: Uniform +X

Check: Shear capacity V_{Rd}

Edge: End

Local Axis: (3)



Start Of Calculation of Shear Capacity for element: beam B1 of floor 1

At local axis: 3

Integration Section: (b)

Section Type: rcars

Constant Properties

Knowledge Factor, $\gamma = 1.00$

Member Shear Force is generally considered as Force-Controlled Action according to Table C7-1, ASCE 41-17.

Lower-bound strengths are used for Force-Controlled Actions according to 7.5.1.3, ASCE 41-17

Consequently:

Existing material of Secondary Member: Concrete Strength, $f_c = f_{c_lower_bound} = 16.00$

Existing material of Secondary Member: Steel Strength, $f_s = f_{s_lower_bound} = 400.00$

Concrete Elasticity, $E_c = 21019.039$

Steel Elasticity, $E_s = 200000.00$

Section Height, $H = 400.00$

Section Width, $W = 300.00$

Cover Thickness, $c = 25.00$

Element Length, $L = 1850.00$

Secondary Member

Ribbed Bars

Ductile Steel

Without Detailing for Earthquake Resistance (including stirrups not closed at 135°)

Longitudinal Bars With Ends Lapped Starting at the End Sections

Inadequate Lap Length with $l_o/l_{o,min} = l_b/l_d = 0.30$

No FRP Wrapping

Stepwise Properties

EDGE -A-

Bending Moment, $M_a = 5.4241E+006$

Shear Force, $V_a = -2275.035$

EDGE -B-

Bending Moment, $M_b = 6.4211E+006$

Shear Force, $V_b = 10530.564$

BOTH EDGES

Axial Force, $F = -1219.269$

Longitudinal Reinforcement Area Distribution (in 2 divisions)

-Tension: $As_{lt} = 615.7522$

-Compression: $As_{lc} = 911.0619$

Longitudinal Reinforcement Area Distribution (in 3 divisions)

-Tension: $As_{l,ten} = 615.7522$

-Compression: $As_{l,com} = 603.1858$

-Middle: $As_{l,mid} = 307.8761$

Mean Diameter of Tension Reinforcement, $Db_{L,ten} = 14.00$

Existing component: From table 7-7, ASCE 41_17: Final Shear Capacity $VR = *V_n = 200974.745$

$V_n ((22.5.1.1), ACI 318-14) = 200974.745$

NOTE: In expression (22.5.1.1) 'Vw' is replaced by 'Vw+ f*Vf' where Vf is the contribution of FRPs (11.3), ACI 440).

From Table (22.5.5.1), ACI 318-14: $V_c = 66933.458$

= 1 (normal-weight concrete)

$f'_c = 16.00$, but $f'_c^{0.5} \leq 8.3$ MPa (22.5.3.1, ACI 318-14)

$\rho_w = A_s/(b_w*d) = 0.00641409$

A_s (tension reinf.) = 615.7522

$b_w = 300.00$

$d = 320.00$

$V_u*d/M_u < 1 = 0.52479654$

$M_u = 6.4211E+006$

$V_u = 10530.564$

From (11.5.4.8), ACI 318-14: $V_s = 134041.287$

$A_v = 157079.633$

$f_y = 400.00$

$s = 150.00$

V_s has been multiplied by 1 ($s \leq d/2$, according to ASCE 41-17, 10.3.4)

V_f ((11-3)-(11.4), ACI 440) = 0.00

From (11-11), ACI 440: $V_s + V_f \leq 255092.67$

End Of Calculation of Shear Capacity for element: beam B1 of floor 1

At local axis: 3

Integration Section: (b)

Calculation No. 16

beam B1, Floor 1



Limit State: Life Safety (data interpolation between analysis steps 1 and 2)

Analysis: Uniform +X

Check: Chord rotation capacity (ϕ_r)

Edge: End

Local Axis: (3)



Start Of Calculation of Shear Capacity ratio for element: beam B1 of floor 1

At Shear local axis: 3

(Bending local axis: 2)

Section Type: rcars

Constant Properties

Knowledge Factor, $\phi = 1.00$

Mean strength values are used for both shear and moment calculations.

Consequently:

Existing material of Secondary Member: Concrete Strength, $f_c = f_{cm} = 20.00$

Existing material of Secondary Member: Steel Strength, $f_s = f_{sm} = 444.44$

Concrete Elasticity, $E_c = 21019.039$

Steel Elasticity, $E_s = 200000.00$

#####

Note: Especially for the calculation of moment strengths,

the above steel re-bar strengths are multiplied by 1.25 according to R18.6.5, ACI 318-14

Existing material: Steel Strength, $f_s = 1.25 \cdot f_{sm} = 555.55$

#####

Section Height, $H = 400.00$

Section Width, $W = 300.00$

Cover Thickness, $c = 25.00$

Mean Confinement Factor overall section = 1.00

Element Length, $L = 1850.00$

Secondary Member

Ribbed Bars

Ductile Steel

Without Detailing for Earthquake Resistance (including stirrups not closed at 135°)

Longitudinal Bars With Ends Lapped Starting at the End Sections

Inadequate Lap Length with $l_o/l_{ou,min} = 0.30$

No FRP Wrapping

Stepwise Properties

At local axis: 3

EDGE -A-

Shear Force, $V_a = 4076.60$

EDGE -B-

Shear Force, $V_b = 4178.928$

BOTH EDGES

Axial Force, $F = -400.0832$

Longitudinal Reinforcement Area Distribution (in 2 divisions)

-Tension: $As_t = 603.1858$

-Compression: $As_c = 923.6282$

Longitudinal Reinforcement Area Distribution (in 3 divisions)

-Tension: $As_{t,ten} = 603.1858$

-Compression: $As_{l,com} = 615.7522$

-Middle: $As_{l,mid} = 307.8761$

Calculation of Shear Capacity ratio, $V_e/V_r = 0.40672566$

Member Controlled by Flexure ($V_e/V_r < 1$)

Calculation of Shear Demand from fig. R18.6.5, ACI 318-14 $V_e = (M_{pr1} + M_{pr2})/l_n \pm w_u \cdot l_n/2 = 92684.415$

with $M_{pr1} = \max(\mu_{u1+}, \mu_{u1-}) = 8.1957E+007$

$\mu_{u1+} = 8.0451E+007$, is the ultimate moment strength at the edge 1 of the member in the actual moment direction which is defined for the static loading combination

$\mu_{u1-} = 8.1957E+007$, is the ultimate moment strength at the edge 1 of the member in the opposite moment direction which is defined for the static loading combination

$M_{pr2} = \max(\mu_{u2+}, \mu_{u2-}) = 8.1873E+007$

$\mu_{u2+} = 8.0533E+007$, is the ultimate moment strength at the edge 2 of the member in the actual moment direction which is defined for the static loading combination

$\mu_{u2-} = 8.1873E+007$, is the ultimate moment strength at the edge 2 of the member in the opposite moment direction which is defined for the static loading combination

and

$\pm w_u \cdot l_n = (|V_1| + |V_2|)/2$

with

V1 = 4076.60, is the shear force acting at edge 1 for the the static loading combination
V2 = 4178.928, is the shear force acting at edge 2 for the the static loading combination

Calculation of Mu1+

Calculation of ultimate curvature ϕ_u according to 4.1, Biskinis/Fardis 2013:

$$\phi_u = 1.7899831E-005$$

$$M_u = 8.0451E+007$$

with full section properties:

$$b = 300.00$$

$$d = 357.00$$

$$d' = 42.00$$

$$v = 0.00018678$$

$$N = 400.0832$$

$$f_c = 20.00$$

$$\phi_{co} (5A.5, TBDY) = 0.002$$

$$\text{Final value of } \phi_{cu}: \phi_{cu}^* = \text{shear_factor} * \text{Max}(\phi_{cu}, \phi_{co}) = 0.00583896$$

The Shear_factor is considered equal to 1 (pure moment strength)

$$\text{From (5.4b), TBDY: } \phi_{cu} = 0.00583896$$

$$\phi_{we} (5.4c) = 0.0034192$$

$$\phi_{ase} ((5.4d), TBDY) = 0.15672608$$

$$b_o = 240.00$$

$$h_o = 340.00$$

$$b_{i2} = 346400.00$$

$$\phi_{psh,min} = \text{Min}(\phi_{psh,x}, \phi_{psh,y}) = 0.00261799$$

Expression ((5.4d), TBDY) for $\phi_{psh,min}$ has been multiplied by 0.3 according to 15.7.1.3 for members without earthquake detailing (90° closed stirrups)

$$\phi_{psh,x} (5.4d) = 0.00349066$$

$$A_{sh} = A_{stir} * n_s = 78.53982$$

$$\text{No stirrups, } n_s = 2.00$$

$$b_k = 300.00$$

$$\phi_{psh,y} (5.4d) = 0.00261799$$

$$A_{sh} = A_{stir} * n_s = 78.53982$$

$$\text{No stirrups, } n_s = 2.00$$

$$b_k = 400.00$$

$$s = 150.00$$

$$f_{ywe} = 555.55$$

$$f_{ce} = 20.00$$

$$\text{From ((5.A5), TBDY), TBDY: } \phi_{cc} = 0.002$$

$$c = \text{confinement factor} = 1.00$$

$$y_1 = 0.00129669$$

$$sh_1 = 0.0044814$$

$$f_{t1} = 373.4467$$

$$f_{y1} = 311.2056$$

$$su_1 = 0.00512$$

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00

$$l_o/l_{ou,min} = l_b/l_d = 0.30$$

$$su_1 = 0.4 * esu_{1,nominal} ((5.5), TBDY) = 0.032$$

$$\text{From table 5A.1, TBDY: } esu_{1,nominal} = 0.08,$$

For calculation of $esu_{1,nominal}$ and $y_1, sh_1, f_{t1}, f_{y1}$, it is considered
characteristic value $fsy_1 = f_s/1.2$, from table 5.1, TBDY.

$y_1, sh_1, f_{t1}, f_{y1}$, are also multiplied by $\text{Min}(1, 1.25 * (l_b/l_d)^{2/3})$, from 10.3.5, ASCE 41-17.

$$\text{with } fs_1 = f_s = 311.2056$$

$$\text{with } Es_1 = E_s = 200000.00$$

$$y_2 = 0.00129669$$

$$sh_2 = 0.0044814$$

$$f_{t2} = 373.4467$$

$$f_{y2} = 311.2056$$

```

su2 = 0.00512
using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00
lo/lo,min = lb/lb,min = 0.30
su2 = 0.4*esu2_nominal ((5.5), TBDY) = 0.032
From table 5A.1, TBDY: esu2_nominal = 0.08,
For calculation of esu2_nominal and y2, sh2,ft2,fy2, it is considered
characteristic value fsy2 = fs2/1.2, from table 5.1, TBDY.
y1, sh1,ft1,fy1, are also multiplied by Min(1,1.25*(lb/ld)^ 2/3), from 10.3.5, ASCE 41-17.
with fs2 = fs = 311.2056
with Es2 = Es = 200000.00
yv = 0.00129669
shv = 0.0044814
ftv = 373.4467
fyv = 311.2056
suv = 0.00512
using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00
lo/lo,min = lb/ld = 0.30
suv = 0.4*esuv_nominal ((5.5), TBDY) = 0.032
From table 5A.1, TBDY: esuv_nominal = 0.08,
considering characteristic value fsyv = fsv/1.2, from table 5.1, TBDY
For calculation of esuv_nominal and yv, shv,ftv,fyv, it is considered
characteristic value fsyv = fsv/1.2, from table 5.1, TBDY.
y1, sh1,ft1,fy1, are also multiplied by Min(1,1.25*(lb/ld)^ 2/3), from 10.3.5, ASCE 41-17.
with fsv = fs = 311.2056
with Esv = Es = 200000.00
1 = Asl,ten/(b*d)*(fs1/fc) = 0.08763528
2 = Asl,com/(b*d)*(fs2/fc) = 0.08946101
v = Asl,mid/(b*d)*(fsv/fc) = 0.04473051
and confined core properties:
b = 240.00
d = 327.00
d' = 12.00
fcc (5A.2, TBDY) = 20.00
cc (5A.5, TBDY) = 0.002
c = confinement factor = 1.00
1 = Asl,ten/(b*d)*(fs1/fc) = 0.11959401
2 = Asl,com/(b*d)*(fs2/fc) = 0.12208556
v = Asl,mid/(b*d)*(fsv/fc) = 0.06104278
Case/Assumption: Unconfined full section - Steel rupture
'satisfies Eq. (4.3)
--->
v < vs,y2 - LHS eq.(4.5) is satisfied
--->
su (4.9) = 0.19877808
Mu = MRc (4.14) = 8.0451E+007
u = su (4.1) = 1.7899831E-005

```

Calculation of ratio lb/ld

Inadequate Lap Length with lb/ld = 0.30

Calculation of Mu1-

Calculation of ultimate curvature u according to 4.1, Biskinis/Fardis 2013:

u = 1.7901443E-005
Mu = 8.1957E+007

with full section properties:

$b = 300.00$
 $d = 358.00$
 $d' = 43.00$
 $v = 0.00018626$
 $N = 400.0832$
 $fc = 20.00$
 $co (5A.5, TBDY) = 0.002$
 Final value of cu : $cu^* = shear_factor * Max(cu, cc) = 0.00583896$
 The Shear_factor is considered equal to 1 (pure moment strength)
 From (5.4b), TBDY: $cu = 0.00583896$
 $we (5.4c) = 0.0034192$
 $ase ((5.4d), TBDY) = 0.15672608$
 $bo = 240.00$
 $ho = 340.00$
 $bi2 = 346400.00$
 $psh,min = Min(psh,x, psh,y) = 0.00261799$
 Expression ((5.4d), TBDY) for psh,min has been multiplied by 0.3 according to 15.7.1.3 for members without earthquake detailing (90° closed stirrups)

$psh,x (5.4d) = 0.00349066$
 $Ash = Astir*ns = 78.53982$
 No stirrups, $ns = 2.00$
 $bk = 300.00$

$psh,y (5.4d) = 0.00261799$
 $Ash = Astir*ns = 78.53982$
 No stirrups, $ns = 2.00$
 $bk = 400.00$

$s = 150.00$
 $fywe = 555.55$
 $fce = 20.00$
 From ((5.A5), TBDY), TBDY: $cc = 0.002$
 $c = confinement\ factor = 1.00$
 $y1 = 0.00129669$
 $sh1 = 0.0044814$
 $ft1 = 373.4467$
 $fy1 = 311.2056$
 $su1 = 0.00512$
 using (30) in Biskinis/Fardis (2013) multiplied with shear_factor and also multiplied by the shear_factor according to 15.7.1.4, with Shear_factor = 1.00
 $lo/lou,min = lb/d = 0.30$
 $su1 = 0.4*esu1_nominal ((5.5), TBDY) = 0.032$
 From table 5A.1, TBDY: $esu1_nominal = 0.08$,
 For calculation of $esu1_nominal$ and $y1, sh1, ft1, fy1$, it is considered characteristic value $fsy1 = fs1/1.2$, from table 5.1, TBDY.
 $y1, sh1, ft1, fy1$, are also multiplied by $Min(1, 1.25*(lb/d)^{2/3})$, from 10.3.5, ASCE 41-17.
 with $fs1 = fs = 311.2056$
 with $Es1 = Es = 200000.00$
 $y2 = 0.00129669$
 $sh2 = 0.0044814$
 $ft2 = 373.4467$
 $fy2 = 311.2056$
 $su2 = 0.00512$
 using (30) in Biskinis/Fardis (2013) multiplied with shear_factor and also multiplied by the shear_factor according to 15.7.1.4, with Shear_factor = 1.00
 $lo/lou,min = lb/lb,min = 0.30$
 $su2 = 0.4*esu2_nominal ((5.5), TBDY) = 0.032$
 From table 5A.1, TBDY: $esu2_nominal = 0.08$,
 For calculation of $esu2_nominal$ and $y2, sh2, ft2, fy2$, it is considered characteristic value $fsy2 = fs2/1.2$, from table 5.1, TBDY.
 $y1, sh1, ft1, fy1$, are also multiplied by $Min(1, 1.25*(lb/d)^{2/3})$, from 10.3.5, ASCE 41-17.
 with $fs2 = fs = 311.2056$
 with $Es2 = Es = 200000.00$
 $yv = 0.00129669$

```

shv = 0.0044814
ftv = 373.4467
fyv = 311.2056
suv = 0.00512
    using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
    and also multiplied by the shear_factor according to 15.7.1.4, with
    Shear_factor = 1.00
    lo/lo,min = lb/ld = 0.30
    suv = 0.4*esuv_nominal ((5.5), TBDY) = 0.032
    From table 5A.1, TBDY: esuv_nominal = 0.08,
    considering characteristic value fsyv = fsv/1.2, from table 5.1, TBDY
    For calculation of esuv_nominal and yv, shv,ftv,fyv, it is considered
    characteristic value fsyv = fsv/1.2, from table 5.1, TBDY.
    y1, sh1,ft1,fy1, are also multiplied by Min(1,1.25*(lb/ld)^ 2/3), from 10.3.5, ASCE 41-17.
    with fsv = fs = 311.2056
    with Esv = Es = 200000.00
    1 = Asl,ten/(b*d)*(fs1/fc) = 0.08921112
    2 = Asl,com/(b*d)*(fs2/fc) = 0.08739049
    v = Asl,mid/(b*d)*(fsv/fc) = 0.04460556
and confined core properties:
b = 240.00
d = 328.00
d' = 13.00
fcc (5A.2, TBDY) = 20.00
cc (5A.5, TBDY) = 0.002
    c = confinement factor = 1.00
    1 = Asl,ten/(b*d)*(fs1/fc) = 0.12171334
    2 = Asl,com/(b*d)*(fs2/fc) = 0.1192294
    v = Asl,mid/(b*d)*(fsv/fc) = 0.06085667
Case/Assumption: Unconfined full section - Steel rupture
' satisfies Eq. (4.3)
--->
v < vs,y2 - LHS eq.(4.5) is satisfied
--->
su (4.9) = 0.20108809
Mu = MRc (4.14) = 8.1957E+007
u = su (4.1) = 1.7901443E-005

```

Calculation of ratio lb/ld

Inadequate Lap Length with lb/ld = 0.30

Calculation of Mu2+

Calculation of ultimate curvature u according to 4.1, Biskinis/Fardis 2013:

```

u = 1.7862388E-005
Mu = 8.0533E+007

```

with full section properties:

```

b = 300.00
d = 358.00
d' = 43.00
v = 0.00018626
N = 400.0832
fc = 20.00
co (5A.5, TBDY) = 0.002
Final value of cu: cu* = shear_factor * Max( cu, cc) = 0.00583896
The Shear_factor is considered equal to 1 (pure moment strength)
From (5.4b), TBDY: cu = 0.00583896
we (5.4c) = 0.0034192
ase ((5.4d), TBDY) = 0.15672608
bo = 240.00

```

$h_o = 340.00$
 $bi2 = 346400.00$
 $psh,min = \text{Min}(psh,x, psh,y) = 0.00261799$
 Expression ((5.4d), TBDY) for psh,min has been multiplied by 0.3 according to 15.7.1.3 for members without earthquake detailing (90° closed stirrups)

$psh,x (5.4d) = 0.00349066$
 $Ash = Astir*ns = 78.53982$
 No stirrups, $ns = 2.00$
 $bk = 300.00$

$psh,y (5.4d) = 0.00261799$
 $Ash = Astir*ns = 78.53982$
 No stirrups, $ns = 2.00$
 $bk = 400.00$

$s = 150.00$
 $fywe = 555.55$
 $fce = 20.00$
 From ((5.A5), TBDY), TBDY: $cc = 0.002$
 $c = \text{confinement factor} = 1.00$
 $y1 = 0.00129669$
 $sh1 = 0.0044814$
 $ft1 = 373.4467$
 $fy1 = 311.2056$
 $su1 = 0.00512$
 using (30) in Biskinis/Fardis (2013) multiplied with shear_factor and also multiplied by the shear_factor according to 15.7.1.4, with Shear_factor = 1.00
 $lo/lou,min = lb/ld = 0.30$
 $su1 = 0.4*esu1_nominal ((5.5), TBDY) = 0.032$
 From table 5A.1, TBDY: $esu1_nominal = 0.08$,
 For calculation of $esu1_nominal$ and $y1, sh1, ft1, fy1$, it is considered characteristic value $fsy1 = fs1/1.2$, from table 5.1, TBDY.
 $y1, sh1, ft1, fy1$, are also multiplied by $\text{Min}(1, 1.25*(lb/ld)^{2/3})$, from 10.3.5, ASCE 41-17.
 with $fs1 = fs = 311.2056$
 with $Es1 = Es = 200000.00$
 $y2 = 0.00129669$
 $sh2 = 0.0044814$
 $ft2 = 373.4467$
 $fy2 = 311.2056$
 $su2 = 0.00512$
 using (30) in Biskinis/Fardis (2013) multiplied with shear_factor and also multiplied by the shear_factor according to 15.7.1.4, with Shear_factor = 1.00
 $lo/lou,min = lb/lb,min = 0.30$
 $su2 = 0.4*esu2_nominal ((5.5), TBDY) = 0.032$
 From table 5A.1, TBDY: $esu2_nominal = 0.08$,
 For calculation of $esu2_nominal$ and $y2, sh2, ft2, fy2$, it is considered characteristic value $fsy2 = fs2/1.2$, from table 5.1, TBDY.
 $y1, sh1, ft1, fy1$, are also multiplied by $\text{Min}(1, 1.25*(lb/ld)^{2/3})$, from 10.3.5, ASCE 41-17.
 with $fs2 = fs = 311.2056$
 with $Es2 = Es = 200000.00$
 $yv = 0.00129669$
 $shv = 0.0044814$
 $ftv = 373.4467$
 $fyv = 311.2056$
 $suv = 0.00512$
 using (30) in Biskinis/Fardis (2013) multiplied with shear_factor and also multiplied by the shear_factor according to 15.7.1.4, with Shear_factor = 1.00
 $lo/lou,min = lb/ld = 0.30$
 $suv = 0.4*esuv_nominal ((5.5), TBDY) = 0.032$
 From table 5A.1, TBDY: $esuv_nominal = 0.08$,
 considering characteristic value $fsyv = fsv/1.2$, from table 5.1, TBDY
 For calculation of $esuv_nominal$ and yv, shv, ftv, fyv , it is considered characteristic value $fsyv = fsv/1.2$, from table 5.1, TBDY.

$y1, sh1, ft1, fy1$, are also multiplied by $\text{Min}(1, 1.25 \cdot (lb/d)^{2/3})$, from 10.3.5, ASCE 41-17.
 with $fsv = fs = 311.2056$
 with $Esv = Es = 200000.00$
 $1 = Asl,ten/(b \cdot d) \cdot (fs1/fc) = 0.08739049$
 $2 = Asl,com/(b \cdot d) \cdot (fs2/fc) = 0.08921112$
 $v = Asl,mid/(b \cdot d) \cdot (fsv/fc) = 0.04460556$
 and confined core properties:
 $b = 240.00$
 $d = 328.00$
 $d' = 13.00$
 $fcc (5A.2, TBDY) = 20.00$
 $cc (5A.5, TBDY) = 0.002$
 $c = \text{confinement factor} = 1.00$
 $1 = Asl,ten/(b \cdot d) \cdot (fs1/fc) = 0.1192294$
 $2 = Asl,com/(b \cdot d) \cdot (fs2/fc) = 0.12171334$
 $v = Asl,mid/(b \cdot d) \cdot (fsv/fc) = 0.06085667$
 Case/Assumption: Unconfined full section - Steel rupture
 ' satisfies Eq. (4.3)
 --->
 $v < vs,y2$ - LHS eq.(4.5) is satisfied
 --->
 $su (4.9) = 0.19934131$
 $Mu = MRc (4.14) = 8.0533E+007$
 $u = su (4.1) = 1.7862388E-005$

 Calculation of ratio lb/d

 Inadequate Lap Length with $lb/d = 0.30$

 Calculation of $Mu2$ -

 Calculation of ultimate curvature u according to 4.1, Biskinis/Fardis 2013:
 $u = 1.7939215E-005$
 $Mu = 8.1873E+007$

 with full section properties:
 $b = 300.00$
 $d = 357.00$
 $d' = 42.00$
 $v = 0.00018678$
 $N = 400.0832$
 $fc = 20.00$
 $co (5A.5, TBDY) = 0.002$
 Final value of cu : $cu^* = \text{shear_factor} \cdot \text{Max}(cu, cc) = 0.00583896$
 The Shear_factor is considered equal to 1 (pure moment strength)
 From (5.4b), TBDY: $cu = 0.00583896$
 $we (5.4c) = 0.0034192$
 $ase ((5.4d), TBDY) = 0.15672608$
 $bo = 240.00$
 $ho = 340.00$
 $bi2 = 346400.00$
 $psh,min = \text{Min}(psh,x, psh,y) = 0.00261799$
 Expression ((5.4d), TBDY) for psh,min has been multiplied by 0.3 according to 15.7.1.3 for members without
 earthquake detailing (90° closed stirrups)

 $psh,x (5.4d) = 0.00349066$
 $Ash = Astir \cdot ns = 78.53982$
 No stirrups, $ns = 2.00$
 $bk = 300.00$

 $psh,y (5.4d) = 0.00261799$
 $Ash = Astir \cdot ns = 78.53982$

No stirrups, ns = 2.00
bk = 400.00

s = 150.00
fywe = 555.55
fce = 20.00

From ((5A.5), TBDY), TBDY: cc = 0.002
c = confinement factor = 1.00

y1 = 0.00129669
sh1 = 0.0044814
ft1 = 373.4467
fy1 = 311.2056
su1 = 0.00512

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00

lo/lou,min = lb/lb = 0.30

su1 = 0.4*esu1_nominal ((5.5), TBDY) = 0.032

From table 5A.1, TBDY: esu1_nominal = 0.08,

For calculation of esu1_nominal and y1, sh1,ft1,fy1, it is considered
characteristic value fsy1 = fs1/1.2, from table 5.1, TBDY.

y1, sh1,ft1,fy1, are also multiplied by $\text{Min}(1, 1.25 \cdot (lb/lb)^{2/3})$, from 10.3.5, ASCE 41-17.

with fs1 = fs = 311.2056

with Es1 = Es = 200000.00

y2 = 0.00129669
sh2 = 0.0044814
ft2 = 373.4467
fy2 = 311.2056
su2 = 0.00512

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00

lo/lou,min = lb/lb,min = 0.30

su2 = 0.4*esu2_nominal ((5.5), TBDY) = 0.032

From table 5A.1, TBDY: esu2_nominal = 0.08,

For calculation of esu2_nominal and y2, sh2,ft2,fy2, it is considered
characteristic value fsy2 = fs2/1.2, from table 5.1, TBDY.

y1, sh1,ft1,fy1, are also multiplied by $\text{Min}(1, 1.25 \cdot (lb/lb)^{2/3})$, from 10.3.5, ASCE 41-17.

with fs2 = fs = 311.2056

with Es2 = Es = 200000.00

yv = 0.00129669
shv = 0.0044814
ftv = 373.4467
fyv = 311.2056
suv = 0.00512

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00

lo/lou,min = lb/lb = 0.30

suv = 0.4*esuv_nominal ((5.5), TBDY) = 0.032

From table 5A.1, TBDY: esuv_nominal = 0.08,

considering characteristic value fsyv = fsv/1.2, from table 5.1, TBDY

For calculation of esuv_nominal and yv, shv,ftv,fyv, it is considered
characteristic value fsyv = fsv/1.2, from table 5.1, TBDY.

y1, sh1,ft1,fy1, are also multiplied by $\text{Min}(1, 1.25 \cdot (lb/lb)^{2/3})$, from 10.3.5, ASCE 41-17.

with fsv = fs = 311.2056

with Esv = Es = 200000.00

1 = Asl,ten/(b*d)*(fs1/fc) = 0.08946101

2 = Asl,com/(b*d)*(fs2/fc) = 0.08763528

v = Asl,mid/(b*d)*(fsv/fc) = 0.04473051

and confined core properties:

b = 240.00
d = 327.00
d' = 12.00

fcc (5A.2, TBDY) = 20.00

cc (5A.5, TBDY) = 0.002

c = confinement factor = 1.00

$$1 = A_{sl,ten}/(b*d)*(f_{s1}/f_c) = 0.12208556$$

$$2 = A_{sl,com}/(b*d)*(f_{s2}/f_c) = 0.11959401$$

$$v = A_{sl,mid}/(b*d)*(f_{sv}/f_c) = 0.06104278$$

Case/Assumption: Unconfined full section - Steel rupture
' satisfies Eq. (4.3)

--->

$v < v_{s,y2}$ - LHS eq.(4.5) is satisfied

--->

$$s_u(4.9) = 0.20053711$$

$$M_u = M_{Rc}(4.14) = 8.1873E+007$$

$$u = s_u(4.1) = 1.7939215E-005$$

Calculation of ratio l_b/l_d

Inadequate Lap Length with $l_b/l_d = 0.30$

Calculation of Shear Strength $V_r = \min(V_{r1}, V_{r2}) = 227879.44$

Calculation of Shear Strength at edge 1, $V_{r1} = 227879.44$

$V_{r1} = V_n((22.5.1.1), \text{ACI 318-14})$

NOTE: In expression (22.5.1.1) 'Vw' is replaced by 'Vw+ f*Vf'
where Vf is the contribution of FRPs (11.3), ACI 440).

From Table (22.5.5.1), ACI 318-14: $V_c = 78946.167$

= 1 (normal-weight concrete)

$f'_c = 20.00$, but $f_c^{0.5} \leq 8.3 \text{ MPa}$ (22.5.3.1, ACI 318-14)

$$p_w = A_s/(b_w*d) = 0.00628319$$

$$A_s (\text{tension reinf.}) = 603.1858$$

$$b_w = 300.00$$

$$d = 320.00$$

$$V_u*d/M_u < 1 = 1.00$$

$$M_u = 60442.822$$

$$V_u = 4076.60$$

From (11.5.4.8), ACI 318-14: $V_s = 148933.273$

$$A_v = 157079.633$$

$$f_y = 444.44$$

$$s = 150.00$$

V_s has been multiplied by 1 ($s < d/2$, according to ASCE 41-17,10.3.4)

$$V_f ((11-3)-(11.4), \text{ACI 440}) = 0.00$$

$$\text{From (11-11), ACI 440: } V_s + V_f \leq 285202.276$$

Calculation of Shear Strength at edge 2, $V_{r2} = 227879.44$

$V_{r2} = V_n((22.5.1.1), \text{ACI 318-14})$

NOTE: In expression (22.5.1.1) 'Vw' is replaced by 'Vw+ f*Vf'
where Vf is the contribution of FRPs (11.3), ACI 440).

From Table (22.5.5.1), ACI 318-14: $V_c = 78946.167$

= 1 (normal-weight concrete)

$f'_c = 20.00$, but $f_c^{0.5} \leq 8.3 \text{ MPa}$ (22.5.3.1, ACI 318-14)

$$p_w = A_s/(b_w*d) = 0.00628319$$

$$A_s (\text{tension reinf.}) = 603.1858$$

$$b_w = 300.00$$

$$d = 320.00$$

$$V_u*d/M_u < 1 = 1.00$$

$$M_u = 155096.693$$

$$V_u = 4178.928$$

From (11.5.4.8), ACI 318-14: $V_s = 148933.273$

$$A_v = 157079.633$$

$$f_y = 444.44$$

$$s = 150.00$$

V_s has been multiplied by 1 ($s < d/2$, according to ASCE 41-17,10.3.4)

Vf ((11-3)-(11.4), ACI 440) = 0.00
From (11-11), ACI 440: Vs + Vf <= 285202.276

End Of Calculation of Shear Capacity ratio for element: beam B1 of floor 1
At local axis: 3

Start Of Calculation of Shear Capacity ratio for element: beam B1 of floor 1
At Shear local axis: 2
(Bending local axis: 3)
Section Type: rcars

Constant Properties

Knowledge Factor, = 1.00
Mean strength values are used for both shear and moment calculations.
Consequently:
Existing material of Secondary Member: Concrete Strength, fc = fcm = 20.00
Existing material of Secondary Member: Steel Strength, fs = fsm = 444.44
Concrete Elasticity, Ec = 21019.039
Steel Elasticity, Es = 200000.00

Note: Especially for the calculation of moment strengths,
the above steel re-bar strengths are multiplied by 1.25 according to R18.6.5, ACI 318-14
Existing material: Steel Strength, fs = 1.25*fsm = 555.55

Section Height, H = 400.00
Section Width, W = 300.00
Cover Thickness, c = 25.00
Mean Confinement Factor overall section = 1.00
Element Length, L = 1850.00
Secondary Member
Ribbed Bars
Ductile Steel
Without Detailing for Earthquake Resistance (including stirrups not closed at 135°)
Longitudinal Bars With Ends Lapped Starting at the End Sections
Inadequate Lap Length with lo/lo,min = 0.30
No FRP Wrapping

Stepwise Properties

At local axis: 2
EDGE -A-
Shear Force, Va = -1.0090939E-010
EDGE -B-
Shear Force, Vb = 1.0090939E-010
BOTH EDGES
Axial Force, F = -400.0832
Longitudinal Reinforcement Area Distribution (in 2 divisions)
-Tension: Aslt = 603.1858
-Compression: Aslc = 923.6282
Longitudinal Reinforcement Area Distribution (in 3 divisions)
-Tension: Asl,ten = 508.938
-Compression: Asl,com = 508.938
-Middle: Asl,mid = 508.938

Calculation of Shear Capacity ratio , Ve/Vr = 0.37923485
Member Controlled by Flexure (Ve/Vr < 1)
Calculation of Shear Demand from fig. R18.6.5, ACI 318-14 Ve = (Mpr1 + Mpr2)/ln ± wu*ln/2 = 57820.79
with
Mpr1 = Max(Mu1+ , Mu1-) = 5.3484E+007

Mu1+ = 5.3484E+007, is the ultimate moment strength at the edge 1 of the member in the actual moment direction which is defined for the static loading combination

Mu1- = 5.3484E+007, is the ultimate moment strength at the edge 1 of the member in the opposite moment direction which is defined for the static loading combination

Mpr2 = Max(Mu2+ , Mu2-) = 5.3484E+007

Mu2+ = 5.3484E+007, is the ultimate moment strength at the edge 2 of the member in the actual moment direction which is defined for the the static loading combination

Mu2- = 5.3484E+007, is the ultimate moment strength at the edge 2 of the member in the opposite moment direction which is defined for the the static loading combination

and

$\pm v_u \cdot l_n = (|V_1| + |V_2|)/2$

with

V1 = -1.0090939E-010, is the shear force acting at edge 1 for the the static loading combination

V2 = 1.0090939E-010, is the shear force acting at edge 2 for the the static loading combination

Calculation of Mu1+

Calculation of ultimate curvature ϕ_u according to 4.1, Biskinis/Fardis 2013:

$\phi_u = 2.5364147E-005$

$M_u = 5.3484E+007$

with full section properties:

b = 400.00

d = 258.00

d' = 42.00

$\nu = 0.00019384$

N = 400.0832

$f_{ck} = 20.00$

$\alpha_{cc} \text{ (5A.5, TBDY)} = 0.002$

Final value of ϕ_u : $\phi_u^* = \text{shear_factor} \cdot \text{Max}(\phi_u, \phi_{cc}) = 0.00583896$

The Shear_factor is considered equal to 1 (pure moment strength)

From (5.4b), TBDY: $\phi_u = 0.00583896$

$\phi_{we} \text{ (5.4c)} = 0.0034192$

$\phi_{ase} \text{ ((5.4d), TBDY)} = 0.15672608$

$b_o = 240.00$

$h_o = 340.00$

$b_{i2} = 346400.00$

$\phi_{sh,min} = \text{Min}(\phi_{sh,x}, \phi_{sh,y}) = 0.00261799$

Expression ((5.4d), TBDY) for $\phi_{sh,min}$ has been multiplied by 0.3 according to 15.7.1.3 for members without earthquake detailing (90° closed stirrups)

 $\phi_{sh,x} \text{ (5.4d)} = 0.00349066$

$A_{sh} = A_{stir} \cdot n_s = 78.53982$

No stirrups, $n_s = 2.00$

$b_k = 300.00$

$\phi_{sh,y} \text{ (5.4d)} = 0.00261799$

$A_{sh} = A_{stir} \cdot n_s = 78.53982$

No stirrups, $n_s = 2.00$

$b_k = 400.00$

s = 150.00

$f_{ywe} = 555.55$

$f_{cke} = 20.00$

From ((5.A5), TBDY), TBDY: $\alpha_{cc} = 0.002$

c = confinement factor = 1.00

$\gamma_1 = 0.00129669$

$\gamma_{sh1} = 0.0044814$

$f_{t1} = 373.4467$

$f_{y1} = 311.2056$

$\gamma_{su1} = 0.00512$

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor

and also multiplied by the shear_factor according to 15.7.1.4, with

Shear_factor = 1.00

$l_o/l_{ou,min} = l_b/l_d = 0.30$
 $su_1 = 0.4 * esu_{1,nominal} ((5.5), TBDY) = 0.032$
 From table 5A.1, TBDY: $esu_{1,nominal} = 0.08$,
 For calculation of $esu_{1,nominal}$ and y_1, sh_1, ft_1, fy_1 , it is considered
 characteristic value $fsy_1 = fs_1/1.2$, from table 5.1, TBDY.
 y_1, sh_1, ft_1, fy_1 , are also multiplied by $Min(1, 1.25 * (l_b/l_d)^{2/3})$, from 10.3.5, ASCE 41-17.
 with $fs_1 = fs = 311.2056$
 with $Es_1 = Es = 200000.00$
 $y_2 = 0.00129669$
 $sh_2 = 0.0044814$
 $ft_2 = 373.4467$
 $fy_2 = 311.2056$
 $su_2 = 0.00512$
 using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
 and also multiplied by the shear_factor according to 15.7.1.4, with
 Shear_factor = 1.00
 $l_o/l_{ou,min} = l_b/l_{b,min} = 0.30$
 $su_2 = 0.4 * esu_{2,nominal} ((5.5), TBDY) = 0.032$
 From table 5A.1, TBDY: $esu_{2,nominal} = 0.08$,
 For calculation of $esu_{2,nominal}$ and y_2, sh_2, ft_2, fy_2 , it is considered
 characteristic value $fsy_2 = fs_2/1.2$, from table 5.1, TBDY.
 y_1, sh_1, ft_1, fy_1 , are also multiplied by $Min(1, 1.25 * (l_b/l_d)^{2/3})$, from 10.3.5, ASCE 41-17.
 with $fs_2 = fs = 311.2056$
 with $Es_2 = Es = 200000.00$
 $y_v = 0.00129669$
 $sh_v = 0.0044814$
 $ft_v = 373.4467$
 $fy_v = 311.2056$
 $suv = 0.00512$
 using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
 and also multiplied by the shear_factor according to 15.7.1.4, with
 Shear_factor = 1.00
 $l_o/l_{ou,min} = l_b/l_d = 0.30$
 $suv = 0.4 * esuv_{nominal} ((5.5), TBDY) = 0.032$
 From table 5A.1, TBDY: $esuv_{nominal} = 0.08$,
 considering characteristic value $fsyv = fsv/1.2$, from table 5.1, TBDY
 For calculation of $esuv_{nominal}$ and y_v, sh_v, ft_v, fy_v , it is considered
 characteristic value $fsyv = fsv/1.2$, from table 5.1, TBDY.
 y_1, sh_1, ft_1, fy_1 , are also multiplied by $Min(1, 1.25 * (l_b/l_d)^{2/3})$, from 10.3.5, ASCE 41-17.
 with $fsv = fs = 311.2056$
 with $Esv = Es = 200000.00$
 $1 = Asl_{ten}/(b * d) * (fs_1/f_c) = 0.0767366$
 $2 = Asl_{com}/(b * d) * (fs_2/f_c) = 0.0767366$
 $v = Asl_{mid}/(b * d) * (fsv/f_c) = 0.0767366$

and confined core properties:

$b = 340.00$
 $d = 228.00$
 $d' = 12.00$
 $f_{cc} (5A.2, TBDY) = 20.00$
 $cc (5A.5, TBDY) = 0.002$
 $c = \text{confinement factor} = 1.00$
 $1 = Asl_{ten}/(b * d) * (fs_1/f_c) = 0.10215708$
 $2 = Asl_{com}/(b * d) * (fs_2/f_c) = 0.10215708$
 $v = Asl_{mid}/(b * d) * (fsv/f_c) = 0.10215708$

Case/Assumption: Unconfined full section - Steel rupture

' satisfies Eq. (4.3)

--->

$v < v_{s,y2}$ - LHS eq.(4.5) is satisfied

--->

$su (4.9) = 0.21759794$
 $Mu = MRc (4.14) = 5.3484E+007$
 $u = su (4.1) = 2.5364147E-005$

Calculation of ratio l_b/l_d

Inadequate Lap Length with $l_b/l_d = 0.30$

Calculation of Mu1-

Calculation of ultimate curvature ϕ_u according to 4.1, Biskinis/Fardis 2013:

$$\phi_u = 2.5364147E-005$$

$$M_u = 5.3484E+007$$

with full section properties:

$$b = 400.00$$

$$d = 258.00$$

$$d' = 42.00$$

$$\nu = 0.00019384$$

$$N = 400.0832$$

$$f_c = 20.00$$

$$\phi_{co} \text{ (5A.5, TBDY)} = 0.002$$

$$\text{Final value of } \phi_{cu}: \phi_{cu}^* = \text{shear_factor} * \text{Max}(\phi_{cu}, \phi_{co}) = 0.00583896$$

The Shear_factor is considered equal to 1 (pure moment strength)

$$\text{From (5.4b), TBDY: } \phi_{cu} = 0.00583896$$

$$\phi_{we} \text{ (5.4c)} = 0.0034192$$

$$\phi_{ase} \text{ ((5.4d), TBDY)} = 0.15672608$$

$$b_o = 240.00$$

$$h_o = 340.00$$

$$b_{i2} = 346400.00$$

$$\phi_{psh,min} = \text{Min}(\phi_{psh,x}, \phi_{psh,y}) = 0.00261799$$

Expression ((5.4d), TBDY) for $\phi_{psh,min}$ has been multiplied by 0.3 according to 15.7.1.3 for members without earthquake detailing (90° closed stirrups)

$$\phi_{psh,x} \text{ (5.4d)} = 0.00349066$$

$$A_{sh} = A_{stir} * n_s = 78.53982$$

$$\text{No stirrups, } n_s = 2.00$$

$$b_k = 300.00$$

$$\phi_{psh,y} \text{ (5.4d)} = 0.00261799$$

$$A_{sh} = A_{stir} * n_s = 78.53982$$

$$\text{No stirrups, } n_s = 2.00$$

$$b_k = 400.00$$

$$s = 150.00$$

$$f_{ywe} = 555.55$$

$$f_{ce} = 20.00$$

$$\text{From ((5.A5), TBDY), TBDY: } \phi_{cc} = 0.002$$

$$\phi_c = \text{confinement factor} = 1.00$$

$$y_1 = 0.00129669$$

$$sh_1 = 0.0044814$$

$$f_{t1} = 373.4467$$

$$f_{y1} = 311.2056$$

$$su_1 = 0.00512$$

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00

$$l_o/l_{ou,min} = l_b/l_d = 0.30$$

$$su_1 = 0.4 * \phi_{su1_nominal} \text{ ((5.5), TBDY)} = 0.032$$

$$\text{From table 5A.1, TBDY: } \phi_{su1_nominal} = 0.08$$

For calculation of $\phi_{su1_nominal}$ and $y_1, sh_1, f_{t1}, f_{y1}$, it is considered
characteristic value $f_{sy1} = f_s/1.2$, from table 5.1, TBDY.

$y_1, sh_1, f_{t1}, f_{y1}$, are also multiplied by $\text{Min}(1, 1.25 * (l_b/l_d)^{2/3})$, from 10.3.5, ASCE 41-17.

$$\text{with } f_{s1} = f_s = 311.2056$$

$$\text{with } E_{s1} = E_s = 200000.00$$

$$y_2 = 0.00129669$$

$$sh_2 = 0.0044814$$

$$f_{t2} = 373.4467$$

$$f_{y2} = 311.2056$$

$$su_2 = 0.00512$$

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00
 $l_o/l_{ou,min} = l_b/l_{b,min} = 0.30$
 $su_2 = 0.4 * esu_{2,nominal} ((5.5), TBDY) = 0.032$
From table 5A.1, TBDY: $esu_{2,nominal} = 0.08$,
For calculation of $esu_{2,nominal}$ and y_2, sh_2, ft_2, fy_2 , it is considered
characteristic value $fsy_2 = fs_2/1.2$, from table 5.1, TBDY.
 y_1, sh_1, ft_1, fy_1 , are also multiplied by $Min(1, 1.25 * (l_b/l_d)^{2/3})$, from 10.3.5, ASCE 41-17.
with $fs_2 = fs = 311.2056$
with $Es_2 = Es = 200000.00$
 $y_v = 0.00129669$
 $sh_v = 0.0044814$
 $ft_v = 373.4467$
 $fy_v = 311.2056$
 $suv = 0.00512$
using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00
 $l_o/l_{ou,min} = l_b/l_d = 0.30$
 $suv = 0.4 * esuv_{nominal} ((5.5), TBDY) = 0.032$
From table 5A.1, TBDY: $esuv_{nominal} = 0.08$,
considering characteristic value $fsy_v = fsv/1.2$, from table 5.1, TBDY
For calculation of $esuv_{nominal}$ and y_v, sh_v, ft_v, fy_v , it is considered
characteristic value $fsy_v = fsv/1.2$, from table 5.1, TBDY.
 y_1, sh_1, ft_1, fy_1 , are also multiplied by $Min(1, 1.25 * (l_b/l_d)^{2/3})$, from 10.3.5, ASCE 41-17.
with $fsv = fs = 311.2056$
with $Es_v = Es = 200000.00$
 $1 = Asl_{ten}/(b * d) * (fs_1/f_c) = 0.0767366$
 $2 = Asl_{com}/(b * d) * (fs_2/f_c) = 0.0767366$
 $v = Asl_{mid}/(b * d) * (fsv/f_c) = 0.0767366$
and confined core properties:
 $b = 340.00$
 $d = 228.00$
 $d' = 12.00$
 $f_{cc} (5A.2, TBDY) = 20.00$
 $cc (5A.5, TBDY) = 0.002$
 $c = \text{confinement factor} = 1.00$
 $1 = Asl_{ten}/(b * d) * (fs_1/f_c) = 0.10215708$
 $2 = Asl_{com}/(b * d) * (fs_2/f_c) = 0.10215708$
 $v = Asl_{mid}/(b * d) * (fsv/f_c) = 0.10215708$
Case/Assumption: Unconfined full section - Steel rupture
' satisfies Eq. (4.3)
--->
 $v < v_{s,y_2}$ - LHS eq.(4.5) is satisfied
--->
 $su (4.9) = 0.21759794$
 $Mu = MRc (4.14) = 5.3484E+007$
 $u = su (4.1) = 2.5364147E-005$

Calculation of ratio l_b/l_d

Inadequate Lap Length with $l_b/l_d = 0.30$

Calculation of Mu_{2+}

Calculation of ultimate curvature u according to 4.1, Biskinis/Fardis 2013:

$$u = 2.5364147E-005$$

$$Mu = 5.3484E+007$$

with full section properties:

$$b = 400.00$$

$d = 258.00$
 $d' = 42.00$
 $v = 0.00019384$
 $N = 400.0832$
 $f_c = 20.00$
 $\phi (5A.5, TBDY) = 0.002$
 Final value of ϕ : $\phi^* = \text{shear_factor} * \text{Max}(\phi, \phi_c) = 0.00583896$
 The Shear_factor is considered equal to 1 (pure moment strength)
 From (5.4b), TBDY: $\phi = 0.00583896$
 $\phi_w (5.4c) = 0.0034192$
 $\phi_{se} ((5.4d), TBDY) = 0.15672608$
 $\phi_o = 240.00$
 $\phi_h = 340.00$
 $\phi_{i2} = 346400.00$
 $\phi_{sh,min} = \text{Min}(\phi_{sh,x}, \phi_{sh,y}) = 0.00261799$
 Expression ((5.4d), TBDY) for $\phi_{sh,min}$ has been multiplied by 0.3 according to 15.7.1.3 for members without earthquake detailing (90° closed stirrups)

$\phi_{sh,x} (5.4d) = 0.00349066$
 $A_{sh} = A_{stir} * n_s = 78.53982$
 No stirrups, $n_s = 2.00$
 $b_k = 300.00$

$\phi_{sh,y} (5.4d) = 0.00261799$
 $A_{sh} = A_{stir} * n_s = 78.53982$
 No stirrups, $n_s = 2.00$
 $b_k = 400.00$

$s = 150.00$
 $f_{ywe} = 555.55$
 $f_{ce} = 20.00$
 From ((5.A5), TBDY), TBDY: $\phi_c = 0.002$
 $\phi = \text{confinement factor} = 1.00$
 $y_1 = 0.00129669$
 $sh_1 = 0.0044814$
 $ft_1 = 373.4467$
 $fy_1 = 311.2056$
 $su_1 = 0.00512$
 using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
 and also multiplied by the shear_factor according to 15.7.1.4, with
 Shear_factor = 1.00
 $\phi_o/\phi_{ou,min} = \phi_b/\phi_d = 0.30$
 $su_1 = 0.4 * \phi_{su1_nominal} ((5.5), TBDY) = 0.032$
 From table 5A.1, TBDY: $\phi_{su1_nominal} = 0.08$,
 For calculation of $\phi_{su1_nominal}$ and y_1, sh_1, ft_1, fy_1 , it is considered
 characteristic value $fsy_1 = fs_1/1.2$, from table 5.1, TBDY.
 y_1, sh_1, ft_1, fy_1 , are also multiplied by $\text{Min}(1, 1.25 * (\phi_b/\phi_d)^{2/3})$, from 10.3.5, ASCE 41-17.
 with $fs_1 = fs = 311.2056$
 with $E_{s1} = E_s = 200000.00$
 $y_2 = 0.00129669$
 $sh_2 = 0.0044814$
 $ft_2 = 373.4467$
 $fy_2 = 311.2056$
 $su_2 = 0.00512$
 using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
 and also multiplied by the shear_factor according to 15.7.1.4, with
 Shear_factor = 1.00
 $\phi_o/\phi_{ou,min} = \phi_b/\phi_{b,min} = 0.30$
 $su_2 = 0.4 * \phi_{su2_nominal} ((5.5), TBDY) = 0.032$
 From table 5A.1, TBDY: $\phi_{su2_nominal} = 0.08$,
 For calculation of $\phi_{su2_nominal}$ and y_2, sh_2, ft_2, fy_2 , it is considered
 characteristic value $fsy_2 = fs_2/1.2$, from table 5.1, TBDY.
 y_1, sh_1, ft_1, fy_1 , are also multiplied by $\text{Min}(1, 1.25 * (\phi_b/\phi_d)^{2/3})$, from 10.3.5, ASCE 41-17.
 with $fs_2 = fs = 311.2056$
 with $E_{s2} = E_s = 200000.00$
 $y_v = 0.00129669$
 $sh_v = 0.0044814$

```

ftv = 373.4467
fyv = 311.2056
suv = 0.00512
    using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
    and also multiplied by the shear_factor according to 15.7.1.4, with
    Shear_factor = 1.00
    lo/lo,min = lb/ld = 0.30
    suv = 0.4*esuv_nominal ((5.5), TBDY) = 0.032
    From table 5A.1, TBDY: esuv_nominal = 0.08,
    considering characteristic value fsyv = fsv/1.2, from table 5.1, TBDY
    For calculation of esuv_nominal and yv, shv,ftv,fyv, it is considered
    characteristic value fsyv = fsv/1.2, from table 5.1, TBDY.
    y1, sh1,ft1,fy1, are also multiplied by Min(1,1.25*(lb/ld)^ 2/3), from 10.3.5, ASCE 41-17.
    with fsv = fs = 311.2056
    with Esv = Es = 200000.00
    1 = Asl,ten/(b*d)*(fs1/fc) = 0.0767366
    2 = Asl,com/(b*d)*(fs2/fc) = 0.0767366
    v = Asl,mid/(b*d)*(fsv/fc) = 0.0767366
and confined core properties:
b = 340.00
d = 228.00
d' = 12.00
fcc (5A.2, TBDY) = 20.00
cc (5A.5, TBDY) = 0.002
    c = confinement factor = 1.00
    1 = Asl,ten/(b*d)*(fs1/fc) = 0.10215708
    2 = Asl,com/(b*d)*(fs2/fc) = 0.10215708
    v = Asl,mid/(b*d)*(fsv/fc) = 0.10215708
Case/Assumption: Unconfined full section - Steel rupture
' satisfies Eq. (4.3)
--->
v < vs,y2 - LHS eq.(4.5) is satisfied
--->
su (4.9) = 0.21759794
Mu = MRc (4.14) = 5.3484E+007
u = su (4.1) = 2.5364147E-005

```

Calculation of ratio lb/ld

Inadequate Lap Length with lb/ld = 0.30

Calculation of Mu2-

Calculation of ultimate curvature u according to 4.1, Biskinis/Fardis 2013:

u = 2.5364147E-005

Mu = 5.3484E+007

with full section properties:

b = 400.00

d = 258.00

d' = 42.00

v = 0.00019384

N = 400.0832

fc = 20.00

co (5A.5, TBDY) = 0.002

Final value of cu: cu* = shear_factor * Max(cu, cc) = 0.00583896

The Shear_factor is considered equal to 1 (pure moment strength)

From (5.4b), TBDY: cu = 0.00583896

we (5.4c) = 0.0034192

ase ((5.4d), TBDY) = 0.15672608

bo = 240.00

ho = 340.00

```

bi2 = 346400.00
psh,min = Min(psh,x , psh,y) = 0.00261799
Expression ((5.4d), TBDY) for psh,min has been multiplied by 0.3 according to 15.7.1.3 for members without
earthquake detailing (90° closed stirrups)
-----
psh,x (5.4d) = 0.00349066
Ash = Astir*ns = 78.53982
No stirups, ns = 2.00
bk = 300.00
-----
psh,y (5.4d) = 0.00261799
Ash = Astir*ns = 78.53982
No stirups, ns = 2.00
bk = 400.00
-----
s = 150.00
fywe = 555.55
fce = 20.00
From ((5.A5), TBDY), TBDY: cc = 0.002
c = confinement factor = 1.00
y1 = 0.00129669
sh1 = 0.0044814
ft1 = 373.4467
fy1 = 311.2056
su1 = 0.00512
using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00
lo/lou,min = lb/lb,min = 0.30
su1 = 0.4*esu1_nominal ((5.5), TBDY) = 0.032
From table 5A.1, TBDY: esu1_nominal = 0.08,
For calculation of esu1_nominal and y1, sh1,ft1,fy1, it is considered
characteristic value fsy1 = fs1/1.2, from table 5.1, TBDY.
y1, sh1,ft1,fy1, are also multiplied by Min(1,1.25*(lb/lb,min)^ 2/3), from 10.3.5, ASCE 41-17.
with fs1 = fs = 311.2056
with Es1 = Es = 200000.00
y2 = 0.00129669
sh2 = 0.0044814
ft2 = 373.4467
fy2 = 311.2056
su2 = 0.00512
using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00
lo/lou,min = lb/lb,min = 0.30
su2 = 0.4*esu2_nominal ((5.5), TBDY) = 0.032
From table 5A.1, TBDY: esu2_nominal = 0.08,
For calculation of esu2_nominal and y2, sh2,ft2,fy2, it is considered
characteristic value fsy2 = fs2/1.2, from table 5.1, TBDY.
y1, sh1,ft1,fy1, are also multiplied by Min(1,1.25*(lb/lb,min)^ 2/3), from 10.3.5, ASCE 41-17.
with fs2 = fs = 311.2056
with Es2 = Es = 200000.00
yv = 0.00129669
shv = 0.0044814
ftv = 373.4467
fyv = 311.2056
suv = 0.00512
using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00
lo/lou,min = lb/lb,min = 0.30
suv = 0.4*esuv_nominal ((5.5), TBDY) = 0.032
From table 5A.1, TBDY: esuv_nominal = 0.08,
considering characteristic value fsyv = fsv/1.2, from table 5.1, TBDY
For calculation of esuv_nominal and yv, shv,ftv,fyv, it is considered
characteristic value fsyv = fsv/1.2, from table 5.1, TBDY.
y1, sh1,ft1,fy1, are also multiplied by Min(1,1.25*(lb/lb,min)^ 2/3), from 10.3.5, ASCE 41-17.

```

```

with fsv = fs = 311.2056
with Esv = Es = 200000.00
1 = Asl,ten/(b*d)*(fs1/fc) = 0.0767366
2 = Asl,com/(b*d)*(fs2/fc) = 0.0767366
v = Asl,mid/(b*d)*(fsv/fc) = 0.0767366
and confined core properties:
b = 340.00
d = 228.00
d' = 12.00
fcc (5A.2, TBDY) = 20.00
cc (5A.5, TBDY) = 0.002
c = confinement factor = 1.00
1 = Asl,ten/(b*d)*(fs1/fc) = 0.10215708
2 = Asl,com/(b*d)*(fs2/fc) = 0.10215708
v = Asl,mid/(b*d)*(fsv/fc) = 0.10215708
Case/Assumption: Unconfined full section - Steel rupture
'satisfies Eq. (4.3)
--->
v < vs,y2 - LHS eq.(4.5) is satisfied
--->
su (4.9) = 0.21759794
Mu = MRc (4.14) = 5.3484E+007
u = su (4.1) = 2.5364147E-005

```

Calculation of ratio lb/d

Inadequate Lap Length with lb/d = 0.30

Calculation of Shear Strength $V_r = \min(V_{r1}, V_{r2}) = 152466.975$

Calculation of Shear Strength at edge 1, $V_{r1} = 152466.975$
 $V_{r1} = V_n$ ((22.5.1.1), ACI 318-14)

NOTE: In expression (22.5.1.1) 'Vw' is replaced by 'Vw+ f*Vf' where Vf is the contribution of FRPs (11.3), ACI 440).

```

From Table (22.5.5.1), ACI 318-14: Vc = 68692.008
= 1 (normal-weight concrete)
fc' = 20.00, but  $fc'^{0.5} \leq 8.3$  MPa (22.5.3.1, ACI 318-14)
pw = As/(bw*d) = 0.00628319
As (tension reinf.) = 603.1858
bw = 400.00
d = 240.00
Vu*d/Mu < 1 = 0.00
Mu = 2.0746991E-007
Vu = 1.0090939E-010
From (11.5.4.8), ACI 318-14: Vs = 83774.966
Av = 157079.633
fy = 444.44
s = 150.00
Vs has been multiplied by 2(1-s/d) (s>d/2, according to ASCE 41-17,10.3.4)
2(1-s/d) = 0.75
Vf ((11-3)-(11.4), ACI 440) = 0.00
From (11-11), ACI 440: Vs + Vf <= 285202.276

```

Calculation of Shear Strength at edge 2, $V_{r2} = 152466.975$
 $V_{r2} = V_n$ ((22.5.1.1), ACI 318-14)

NOTE: In expression (22.5.1.1) 'Vw' is replaced by 'Vw+ f*Vf' where Vf is the contribution of FRPs (11.3), ACI 440).

```

From Table (22.5.5.1), ACI 318-14: Vc = 68692.008
= 1 (normal-weight concrete)

```

$fc' = 20.00$, but $fc'^{0.5} \leq 8.3$ MPa (22.5.3.1, ACI 318-14)

$\rho_w = A_s/(b_w \cdot d) = 0.00628319$

A_s (tension reinf.) = 603.1858

$b_w = 400.00$

$d = 240.00$

$V_u \cdot d / M_u < 1 = 0.00$

$M_u = 2.0781750E-008$

$V_u = 1.0090939E-010$

From (11.5.4.8), ACI 318-14: $V_s = 83774.966$

$A_v = 157079.633$

$f_y = 444.44$

$s = 150.00$

V_s has been multiplied by $2(1-s/d)$ ($s > d/2$, according to ASCE 41-17, 10.3.4)

$2(1-s/d) = 0.75$

V_f ((11-3)-(11.4), ACI 440) = 0.00

From (11-11), ACI 440: $V_s + V_f \leq 285202.276$

End Of Calculation of Shear Capacity ratio for element: beam B1 of floor 1

At local axis: 2

Start Of Calculation of Chord Rotation Capacity for element: beam B1 of floor 1

At local axis: 3

Integration Section: (b)

Section Type: rcars

Constant Properties

Knowledge Factor, $\gamma = 1.00$

Chord Rotation is generally considered as Deformation-Controlled Action according to Table C7-1, ASCE 41-17.

Mean strengths are used for Deformation-Controlled Actions according to 7.5.1.3, ASCE 41-17

Consequently:

Existing material of Secondary Member: Concrete Strength, $f_c = f_{cm} = 20.00$

Existing material of Secondary Member: Steel Strength, $f_s = f_{sm} = 444.44$

Concrete Elasticity, $E_c = 21019.039$

Steel Elasticity, $E_s = 200000.00$

Section Height, $H = 400.00$

Section Width, $W = 300.00$

Cover Thickness, $c = 25.00$

Element Length, $L = 1850.00$

Secondary Member

Ribbed Bars

Ductile Steel

Without Detailing for Earthquake Resistance (including stirrups not closed at 135°)

Longitudinal Bars With Ends Lapped Starting at the End Sections

Inadequate Lap Length with $l_b/l_d = 0.30$

No FRP Wrapping

Stepwise Properties

Bending Moment, $M = -5.3249995E-005$

Shear Force, $V_2 = 5.1634141E-008$

Shear Force, $V_3 = 10530.564$

Axial Force, $F = -1219.269$

Longitudinal Reinforcement Area Distribution (in 2 divisions)

-Tension: $A_{st} = 615.7522$

-Compression: $A_{sc} = 911.0619$

Longitudinal Reinforcement Area Distribution (in 3 divisions)

-Tension: $A_{st,ten} = 508.938$

-Compression: $A_{sc,com} = 508.938$

-Middle: $A_{st,mid} = 508.938$

Mean Diameter of Tension Reinforcement, $Db_L = 14.66667$

Existing component: From table 7-7, ASCE 41_17: Final chord rotation Capacity $u_R = u = 0.02209347$
 $u = y + p = 0.02209347$

- Calculation of y -

$y = (M_y * L_s / 3) / E_{eff} = 0.00209347$ ((4.29), Biskinis Phd))
 $M_y = 3.8532E+007$
 $L_s = M/V$ (with $L_s > 0.1 * L$ and $L_s < 2 * L$) = 925.00
From table 10.5, ASCE 41_17: $E_{eff} = 0.3 * E_c * I_g = 5.6751E+012$

Calculation of Yielding Moment M_y

Calculation of y and M_y according to Annex 7 -

$y = \text{Min}(y_{ten}, y_{com})$
 $y_{ten} = 6.7799058E-006$
with ((10.1), ASCE 41-17) $f_y = \text{Min}(f_y, 1.25 * f_y * (I_b / I_d)^{2/3}) = 248.9644$
 $d = 258.00$
 $y = 0.28835408$
 $A = 0.01484216$
 $B = 0.00864903$
with $p_t = 0.00493157$
 $p_c = 0.00493157$
 $p_v = 0.00493157$
 $N = 1219.269$
 $b = 400.00$
 $" = 0.1627907$
 $y_{comp} = 2.3064356E-005$
with $f_c = 20.00$
 $E_c = 21019.039$
 $y = 0.28782506$
 $A = 0.01476022$
 $B = 0.00860158$
with $E_s = 200000.00$

Calculation of ratio I_b / I_d

Inadequate Lap Length with $I_b / I_d = 0.30$

- Calculation of p -

From table 10-7: $p = 0.02$

with:

- Condition iv occurred
Beam controlled by inadequate embedment into beam-column joint:
($I_b / I_d < 1$ and With Lapping in the Vicinity of the End Regions)
- Condition i occurred
Beam controlled by flexure: $V_p / V_o \leq 1$
shear control ratio $V_p / V_o = 0.37923485$
- Transverse Reinforcement: NC
- Stirrup Spacing $> d/3$
- Low ductility demand, $y < 2$ (table 10-6, ASCE 41-17)
 $= -9.3129548E-016$
- Stirrup Spacing $> d/2$
 $d = 258.00$
 $s = 150.00$
- Strength provided by hoops $V_s < 3/4 * \text{design Shear}$
 $V_s = 111699.955$, already given in calculation of shear control ratio
design Shear = $5.1634141E-008$

- (- ')/ bal = -0.15320593
 = Aslt/(bw*d) = 0.00596659
 Tension Reinf Area: Aslt = 615.7522
 ' = Aslc/(bw*d) = 0.00882812
 Compression Reinf Area: Aslc = 911.0619
 From (B-1), ACI 318-11: bal = 0.01867766
 fc = 20.00
 fy = 444.44
 From 10.2.7.3, ACI 318-11: 1 = 0.85
 From fig R10.3.3, ACI 318-11 (Ence 454, too): $87000/(87000 + fy) = cb/dt = 0.003/(0.003 + y) = 0.57447053$
 y = 0.0022222
 - $V/(bw*d*fc^{0.5}) = 1.3473037E-012$, NOTE: units in lb & in
 bw = 400.00

 End Of Calculation of Chord Rotation Capacity for element: beam B1 of floor 1
 At local axis: 3
 Integration Section: (b)