

Detailed Joint Calculations

Units: N&mm

Regulation: ASCE 41-17


Calculation No. 1

Col. C2 - Beam B2 - Beam B1, Floor : 1

Limit State: Life Safety (data interpolation between analysis steps 3 and 4)

Analysis: Uniform +X

Check: Shear Force



Demanded Shear Force: $V_{jhd} = \text{Max}(V_{jhd1}, V_{jhd2}) = 566032.40$, where V_{jhd1}, V_{jhd2} are calculated for beam 1 and beam 2, respectively, using TBDY, (7.11) and ACI 318-14, 18.8.2.1.

Beam 1:

$V_{jhd1} = 566032.40$

with

$V_{kol} = \text{Min}(V_{kol, \text{above_joint}}, V_{kol, \text{below_joint}}) = 11235.25$

$As1 = 615.7522$

$As2 = 307.8761$

NewMaterial: $f_y d = f_{s_Lower_bound} = 500.00$

Beam 2:

$V_{jhd2} = 450578.87$

with

$V_{kol} = \text{Min}(V_{kol,above_joint}, V_{kol,below_joint}) = 11235.25$

$A_{s1} = 615.7522$

$A_{s2} = 307.8761$

Existing Material: $f_y d = f_{s_Lower_bound} = 400.00$

knowledge factor, $= 1.00$

$V_n = \text{Min}(V_{n1}, V_{n2}) = 996455.744$, where

provided Shear Forces are calculated for beam 1 and beam 2, respectively

Beam 1:

Existing Joint: From table 7-7, ASCE 41-17: Final value $V_{n1,R} = *V_{n1} = 996455.744$

$V_{n1} = 996455.744$ from (10.4) ASCE 41-17

with

$f_c = \text{Min}(f_{c_beam}, f_{c_Column}) = 16.00$

Existing Material: $f_{c_column} = f_{c_lower_bound_column} = 16.00$

New Material: $f_{cd_beam} = f_{c_lower_bound_beam} = 25.00$

$A_j = = 150000.00$

$h_c = 600.00$

$b_j = 250.00$

column width = 250.00

beam width plus joint depth = 850.00

Min perpendicular distance of beam axis to column sides = 125.00

= 20.00, from table 10-12, ASCE 41-17)

column hoops spacing = 100.00

Beam 2:

Existing Joint: From table 7-7, ASCE 41-17: Final value $V_{n1,R} = *V_{n1} = 996455.744$

$V_{n1} = 996455.744$ from (10.4) ASCE 41-17

with

$f_c = \text{Min}(f_{c_beam}, f_{c_Column}) = 16.00$

Existing Material: $f_{c_column} = f_{c_lower_bound_column} = 16.00$

Existing Material: $f_{c_beam} = f_{c_lower_bound_beam} = 16.00$

$A_j = = 150000.00$

$h_c = 600.00$

$b_j = 250.00$

column width = 250.00

beam width plus joint depth = 850.00

Min perpendicular distance of beam axis to column sides = 125.00

= 20.00, from table 10-12, ASCE 41-17)

column hoops spacing = 100.00


Calculation No. 2

Col. C2 - Beam B2 - Beam B1, Floor : 1

Limit State: Collapse Prevention (data interpolation between analysis steps 4 and 5)

Analysis: Uniform +X

Check: Shear Force



Demanded Shear Force: $V_{jhd} = \text{Max}(V_{jhd1}, V_{jhd2}) = 563562.64$, where V_{jhd1}, V_{jhd2} are calculated for beam 1 and beam 2, respectively, using TBDY, (7.11) and ACI 318-14, 18.8.2.1.

Beam 1:

$V_{jhd1} = 563562.64$

with

$V_{kol} = \text{Min}(V_{kol, \text{above_joint}}, V_{kol, \text{below_joint}}) = 13705.01$

$A_{s1} = 615.7522$

$A_{s2} = 307.8761$

New Material: $f_{yd} = f_{s_Lower_bound} = 500.00$

Beam 2:

$V_{jhd2} = 448109.11$

with

$V_{kol} = \text{Min}(V_{kol, \text{above_joint}}, V_{kol, \text{below_joint}}) = 13705.01$

$A_{s1} = 615.7522$

$A_{s2} = 307.8761$

Existing Material: $f_{yd} = f_{s_Lower_bound} = 400.00$

knowledge factor, $= 1.00$

$V_n = \text{Min}(V_{n1}, V_{n2}) = 996455.744$, where

provided Shear Forces are calculated for beam 1 and beam 2, respectively

Beam 1:

Existing Joint: From table 7-7, ASCE 41-17: Final value $V_{n1,R} = *V_{n1} = 996455.744$

$V_{n1} = 996455.744$ from (10.4) ASCE 41-17

with

$f_c = \text{Min}(f_{c_beam}, f_{c_Column}) = 16.00$

Existing Material: $f_{c_column} = f_{c_lower_bound_column} = 16.00$

New Material: $f_{cd_beam} = f_{c_lower_bound_beam} = 25.00$

$A_j = 150000.00$

$h_c = 600.00$

$b_j = 250.00$

column width = 250.00

beam width plus joint depth = 850.00

Min perpendicular distance of beam axis to column sides = 125.00

= 20.00, from table 10-12, ASCE 41-17)

column hoops spacing = 100.00

Beam 2:

Existing Joint: From table 7-7, ASCE 41-17: Final value $V_{n1,R} = *V_{n1} = 996455.744$

$V_{n1} = 996455.744$ from (10.4) ASCE 41-17

with

$f_c = \text{Min}(f_{c_beam}, f_{c_Column}) = 16.00$
Existing Material: $f_{c_column} = f_{c_lower_bound_column} = 16.00$
Existing Material: $f_{c_beam} = f_{c_lower_bound_beam} = 16.00$
 $A_j = = 150000.00$
 $h_c = 600.00$
 $b_j = 250.00$
column width = 250.00
beam width plus joint depth = 850.00
Min perpendicular distance of beam axis to column sides = 125.00
= 20.00, from table 10-12, ASCE 41-17)
column hoops spacing = 100.00