

Detailed Member Calculations

Units: N&mm

Regulation: ASCE 41-17

Calculation No. 1

column C1, Floor 1


Limit State: Immediate Occupancy (data interpolation between analysis steps 1 and 2)

Analysis: Uniform +X

Check: Shear capacity V_{Rd}

Edge: Start

Local Axis: (2)



Start Of Calculation of Shear Capacity for element: column JCC1 of floor 1

At local axis: 2

Integration Section: (a)

Section Type: rcjcs

Constant Properties

Knowledge Factor, $\gamma = 1.00$

Member Shear Force is generally considered as Force-Controlled Action according to Table C7-1, ASCE 41-17.

Lower-bound strengths are used for Force-Controlled Actions according to 7.5.1.3, ASCE 41-17

Consequently:

Jacket

New material of Primary Member: Concrete Strength, $f_c = f_{c_lower_bound} = 25.00$

New material of Primary Member: Steel Strength, $f_s = f_{s_lower_bound} = 500.00$

Concrete Elasticity, $E_c = 26999.444$
 Steel Elasticity, $E_s = 200000.00$
 Existing Column
 New material of Primary Member: Concrete Strength, $f_c = f_{c_lower_bound} = 25.00$
 New material of Primary Member: Steel Strength, $f_s = f_{s_lower_bound} = 500.00$
 Concrete Elasticity, $E_c = 26999.444$
 Steel Elasticity, $E_s = 200000.00$
 #####
 Note: Especially for the calculation of γ for displacement ductility demand,
 the expected (mean value) strengths are used (7.5.1.3, ASCE 41-17) because bending is considered as
 Deformation-Controlled Action (Table C7-1, ASCE 41-17).
 Jacket
 New material: Concrete Strength, $f_c = f_{cm} = 33.00$
 New material: Steel Strength, $f_s = f_{sm} = 555.56$
 Existing Column
 New material: Concrete Strength, $f_c = f_{cm} = 33.00$
 New material: Steel Strength, $f_s = f_{sm} = 555.56$
 #####
 External Diameter, $D = 500.00$
 Internal Diameter, $D = 300.00$
 Cover Thickness, $c = 25.00$
 Element Length, $L = 3000.00$
 Primary Member
 Ribbed Bars
 Ductile Steel
 Without Detailing for Earthquake Resistance (including stirrups not closed at 135°)
 Longitudinal Bars With Ends Lapped Starting at the End Sections
 Inadequate Lap Length with $l_o/l_{ou,min} = l_b/l_d = 0.30$
 FRP Wrapping Data
 Type: Carbon
 Dry properties (design values)
 Thickness, $t = 1.00$
 Tensile Strength, $f_{fu} = 840.00$
 Tensile Modulus, $E_f = 82000.00$
 Elongation, $e_{fu} = 0.009$
 Number of directions, $NoDir = 1$
 Fiber orientations, $bi: 0.00^\circ$
 Number of layers, $NL = 1$
 Radius of rounding corners, $R = 40.00$

 Stepwise Properties

EDGE -A-
 Bending Moment, $M_a = -1.4341E+007$
 Shear Force, $V_a = -4779.203$
 EDGE -B-
 Bending Moment, $M_b = 0.07981876$
 Shear Force, $V_b = 4779.203$
 BOTH EDGES
 Axial Force, $F = -7387.302$
 Longitudinal Reinforcement Area Distribution (in 2 divisions)
 -Tension: $As_t = 0.00$
 -Compression: $As_c = 3053.628$
 Longitudinal Reinforcement Area Distribution (in 3 divisions)
 -Tension: $As_{t,ten} = 1017.876$
 -Compression: $As_{c,com} = 1017.876$
 -Middle: $As_{mid} = 1017.876$
 Mean Diameter of Tension Reinforcement, $Db_{L,ten} = 18.00$

 New component: From table 7-7, ASCE 41_17: Final Shear Capacity $V_R = 1.0 * V_n = 515957.182$
 $V_n ((10.3), ASCE 41-17) = knl * V_{ColO} = 515957.182$
 $V_{Col} = 515957.182$
 $knl = 1.00$

displacement_ductility_demand = 0.01760997

NOTE: In expression (10-3) ' $V_s = A_v \cdot f_y \cdot d / s$ ' is replaced by ' $V_s + f \cdot V_f$ ' where V_f is the contribution of FRPs (11.3), ACI 440).

= 1 (normal-weight concrete)

Mean concrete strength: $f_c' = (f_c'_{\text{jacket}} \cdot \text{Area}_{\text{jacket}} + f_c'_{\text{core}} \cdot \text{Area}_{\text{core}}) / \text{Area}_{\text{section}} = 25.00$, but $f_c'^{0.5} \leq 8.3$ MPa (22.5.3.1, ACI 318-14)

$M/Vd = 4.00$

$\mu_u = 1.4341E+007$

$V_u = 4779.203$

$d = 0.8 \cdot D = 400.00$

$N_u = 7387.302$

$A_g = 196349.541$

From (11.5.4.8), ACI 318-14: $V_s = V_{s1} + V_{s2} = 246740.11$

$V_{s1} = 246740.11$ is calculated for jacket, with:

$A_v = \sqrt{2} \cdot A_{\text{stirrup}} = 123370.055$

$f_y = 500.00$

$s = 100.00$

V_{s1} is multiplied by $\text{Col1} = 1.00$

$s/d = 0.25$

$V_{s2} = 0.00$ is calculated for core, with:

$A_v = \sqrt{2} \cdot A_{\text{stirrup}} = 78956.835$

$f_y = 500.00$

$s = 250.00$

V_{s2} is multiplied by $\text{Col2} = 0.00$

$s/d = 1.04167$

V_f ((11-3)-(11.4), ACI 440) = 308320.00

$f = 0.95$, for fully-wrapped sections

$w_f/s_f = 1$ (FRP strips adjacent to one another).

In (11.3) $\sin^2 + \cos^2$ is replaced with $(\cot^2 + \csc^2) \sin^2 \alpha$ which is more a generalised expression,

where α is the angle of the crack direction (see KANEPE).

This later relation, considered as a function $V_f(\alpha)$, is implemented for every different fiber orientation α_i , as well as for 2 crack directions, $\alpha = 45^\circ$ and $\alpha = -45^\circ$ to take into consideration the cyclic seismic loading.

orientation 1: $\alpha = b_1 + 90^\circ = 90.00$

$V_f = \text{Min}(|V_f(45, \alpha)|, |V_f(-45, \alpha)|)$, with:

total thickness per orientation, $t_{f1} = N_L \cdot t / \text{NoDir} = 1.00$

$d_{fv} = d$ (figure 11.2, ACI 440) = 470.00

f_{fe} ((11-5), ACI 440) = 328.00

$E_f = 82000.00$

$f_e = 0.004$, from (11.6a), ACI 440

with $f_u = 0.009$

From (11-11), ACI 440: $V_s + V_f \leq 417394.406$

$b_w \cdot d = \sqrt{2} \cdot d^2 / 4 = 125663.706$

displacement_ductility_demand is calculated as δ / y

- Calculation of δ / y for END A -
for rotation axis 3 and integ. section (a)

From analysis, chord rotation $\theta = 0.00015961$

$y = (M_y \cdot L_s / 3) / E_{\text{eff}} = 0.00906346$ ((4.29), Biskinis Phd))

$M_y = 2.2517E+008$

$L_s = M/V$ (with $L_s > 0.1 \cdot L$ and $L_s < 2 \cdot L$) = 3000.736

From table 10.5, ASCE 41_17: $E_{\text{eff}} = \text{factor} \cdot E_c \cdot I_g = 2.4850E+013$

factor = 0.30

$A_g = 196349.541$

Mean concrete strength: $f_c' = (f_c'_{\text{jacket}} \cdot \text{Area}_{\text{jacket}} + f_c'_{\text{core}} \cdot \text{Area}_{\text{core}}) / \text{Area}_{\text{section}} = 33.00$

$N = 7387.302$

$E_c \cdot I_g = E_c \cdot I_{g_{\text{jacket}}} + E_c \cdot I_{g_{\text{core}}} = 8.2833E+013$

Calculation of Yielding Moment M_y

Calculation of y and M_y according to (7) - (8) in Biskinis and Fardis

$$M_y = \text{Min}(M_{y_ten}, M_{y_com}) = 2.2517E+008$$

$$y = 6.4424840E-006$$

$$M_{y_ten} (8c) = 2.2517E+008$$

$$y_{ten} (7c) = 61.8137$$

$$\text{error of function (7c)} = 0.00026387$$

$$M_{y_com} (8d) = 8.1922E+008$$

$$y_{com} (7d) = 63.67468$$

$$\text{error of function (7d)} = -0.0087488$$

$$\text{with } ((10.1), \text{ASCE 41-17}) \text{ } e_y = \text{Min}(e_y, 1.25 * e_y * (l_b / l_d)^{2/3}) = 0.0027778$$

$$e_{co} = 0.002$$

$$a_{pl} = 0.45 \text{ ((9c) in Biskinis and Fardis for FRP Wrap)}$$

$$d_1 = 44.00$$

$$R = 250.00$$

$$v = 0.00101374$$

$$N = 7387.302$$

$$A_c = 196349.541$$

$$((10.1), \text{ASCE 41-17}) = \text{Min}(, 1.25 * (l_b / l_d)^{2/3}) = 0.23280363$$

$$\text{with } f_c^* \text{ ((12.3), ACI 440)} = 37.11312$$

$$f_c = 33.00$$

$$f_l = 1.312$$

$$k = 1$$

$$\text{Effective FRP thickness, } t_f = N L * t * \text{Cos}(b_1) = 1.00$$

$$e_{fe} \text{ ((12.5) and (12.7))} = 0.004$$

$$f_u = 0.009$$

$$E_f = 82000.00$$

Calculation of ratio l_b / l_d

Inadequate Lap Length with $l_b / l_d = 0.30$

End Of Calculation of Shear Capacity for element: column JCC1 of floor 1

At local axis: 2

Integration Section: (a)

Calculation No. 2

column C1, Floor 1



Limit State: Immediate Occupancy (data interpolation between analysis steps 1 and 2)

Analysis: Uniform +X

Check: Chord rotation capacity (θ_u)

Edge: Start

Local Axis: (2)



Start Of Calculation of Shear Capacity ratio for element: column JCC1 of floor 1

At Shear local axis: 3
 (Bending local axis: 2)
 Section Type: rcjcs

Constant Properties

Knowledge Factor, $\gamma = 1.00$
 Mean strength values are used for both shear and moment calculations.
 Consequently:

Jacket

New material of Primary Member: Concrete Strength, $f_c = f_{cm} = 33.00$
 New material of Primary Member: Steel Strength, $f_s = f_{sm} = 555.56$
 Concrete Elasticity, $E_c = 26999.444$
 Steel Elasticity, $E_s = 200000.00$

Existing Column

New material of Primary Member: Concrete Strength, $f_c = f_{cm} = 33.00$
 New material of Primary Member: Steel Strength, $f_s = f_{sm} = 555.56$
 Concrete Elasticity, $E_c = 26999.444$
 Steel Elasticity, $E_s = 200000.00$

#####

Note: Especially for the calculation of moment strengths,
 the above steel re-bar strengths are multiplied by 1.25 according to R18.6.5, ACI 318-14

Jacket

New material: Steel Strength, $f_s = 1.25 \cdot f_{sm} = 694.45$

Existing Column

New material: Steel Strength, $f_s = 1.25 \cdot f_{sm} = 694.45$

#####

External Diameter, $D = 500.00$

Internal Diameter, $D = 300.00$

Cover Thickness, $c = 25.00$

Mean Confinement Factor overall section = 1.51481

Element Length, $L = 3000.00$

Primary Member

Ribbed Bars

Ductile Steel

Without Detailing for Earthquake Resistance (including stirrups not closed at 135°)

Longitudinal Bars With Ends Lapped Starting at the End Sections

Inadequate Lap Length with $l_o/l_{ou, \min} = 0.30$

FRP Wrapping Data

Type: Carbon

Dry properties (design values)

Thickness, $t = 1.00$

Tensile Strength, $f_{fu} = 840.00$

Tensile Modulus, $E_f = 82000.00$

Elongation, $e_{fu} = 0.009$

Number of directions, $NoDir = 1$

Fiber orientations, $bi = 0.00^\circ$

Number of layers, $NL = 1$

Radius of rounding corners, $R = 40.00$

Stepwise Properties

At local axis: 3

EDGE -A-

Shear Force, $V_a = 3.4807814E-030$

EDGE -B-

Shear Force, $V_b = -3.4807814E-030$

BOTH EDGES

Axial Force, $F = -7389.214$

Longitudinal Reinforcement Area Distribution (in 2 divisions)

-Tension: $A_{st} = 0.00$

-Compression: $A_{sc} = 3053.628$

Longitudinal Reinforcement Area Distribution (in 3 divisions)

-Tension: $A_{st,ten} = 1017.876$

-Compression: $A_{sc,com} = 1017.876$

-Middle: $A_{s,mid} = 1017.876$

Calculation of Shear Capacity ratio, $V_e/V_r = 0.23017425$

Member Controlled by Flexure ($V_e/V_r < 1$)

Calculation of Shear Demand from fig. R18.6.5, ACI 318-14 $V_e = (M_{pr1} + M_{pr2})/l_n = 162459.651$

with

$M_{pr1} = \text{Max}(M_{u1+}, M_{u1-}) = 2.4369E+008$

$M_{u1+} = 2.4369E+008$, is the ultimate moment strength at the edge 1 of the member in the actual moment direction which is defined for the static loading combination

$M_{u1-} = 2.4369E+008$, is the ultimate moment strength at the edge 1 of the member in the opposite moment direction which is defined for the static loading combination

$M_{pr2} = \text{Max}(M_{u2+}, M_{u2-}) = 2.4369E+008$

$M_{u2+} = 2.4369E+008$, is the ultimate moment strength at the edge 2 of the member in the actual moment direction which is defined for the the static loading combination

$M_{u2-} = 2.4369E+008$, is the ultimate moment strength at the edge 2 of the member in the opposite moment direction which is defined for the the static loading combination

Calculation of M_{u1+}

Calculation of ultimate Moment Strength ((3.67), Biskinis Phd), M_u

$M_u = 2.4369E+008$

$\phi = 0.80285146$

$\phi' = 0.71403327$

error of function (3.68), Biskinis Phd = 27987.158

From 5A.2, TBDY: $f_{cc} = f_c^* c = 49.98874$

conf. factor $c = 1.51481$

$f_c = 33.00$

From 10.3.5, ASCE 41-17, Final value of f_y : $f_y * \text{Min}(1, 1.25 * (l_b/l_d)^{2/3}) = 389.0139$

$l_b/l_d = 0.30$

$d_1 = 44.00$

$R = 250.00$

$v = 0.00100813$

$N = 7389.214$

$A_c = 196349.541$

$\phi * \text{Min}(1, 1.25 * (l_b/l_d)^{2/3}) = 0.1620683$

Calculation of ratio l_b/l_d

Inadequate Lap Length with $l_b/l_d = 0.30$

Calculation of M_{u1-}

Calculation of ultimate Moment Strength ((3.67), Biskinis Phd), Mu

Mu = 2.4369E+008

= 0.80285146

' = 0.71403327

error of function (3.68), Biskinis Phd = 27987.158

From 5A.2, TBDY: $f_{cc} = f_c \cdot c = 49.98874$

conf. factor $c = 1.51481$

$f_c = 33.00$

From 10.3.5, ASCE 41-17, Final value of f_y : $f_y \cdot \text{Min}(1, 1.25 \cdot (l_b/d)^{2/3}) = 389.0139$

$l_b/d = 0.30$

$d_1 = 44.00$

$R = 250.00$

$v = 0.00100813$

$N = 7389.214$

$Ac = 196349.541$

= $\cdot \text{Min}(1, 1.25 \cdot (l_b/d)^{2/3}) = 0.1620683$

Calculation of ratio l_b/d

Inadequate Lap Length with $l_b/d = 0.30$

Calculation of Mu2+

Calculation of ultimate Moment Strength ((3.67), Biskinis Phd), Mu

Mu = 2.4369E+008

= 0.80285146

' = 0.71403327

error of function (3.68), Biskinis Phd = 27987.158

From 5A.2, TBDY: $f_{cc} = f_c \cdot c = 49.98874$

conf. factor $c = 1.51481$

$f_c = 33.00$

From 10.3.5, ASCE 41-17, Final value of f_y : $f_y \cdot \text{Min}(1, 1.25 \cdot (l_b/d)^{2/3}) = 389.0139$

$l_b/d = 0.30$

$d_1 = 44.00$

$R = 250.00$

$v = 0.00100813$

$N = 7389.214$

$Ac = 196349.541$

= $\cdot \text{Min}(1, 1.25 \cdot (l_b/d)^{2/3}) = 0.1620683$

Calculation of ratio l_b/d

Inadequate Lap Length with $l_b/d = 0.30$

Calculation of Mu2-

Calculation of ultimate Moment Strength ((3.67), Biskinis Phd), Mu

Mu = 2.4369E+008

= 0.80285146

' = 0.71403327

error of function (3.68), Biskinis Phd = 27987.158

From 5A.2, TBDY: $f_{cc} = f_c \cdot c = 49.98874$

conf. factor $c = 1.51481$

$f_c = 33.00$

From 10.3.5, ASCE 41-17, Final value of f_y : $f_y \cdot \text{Min}(1, 1.25 \cdot (l_b/d)^{2/3}) = 389.0139$

$l_b/d = 0.30$

$d_1 = 44.00$

$R = 250.00$

$v = 0.00100813$

$N = 7389.214$

$A_c = 196349.541$

$= \cdot \text{Min}(1, 1.25 \cdot (l_b/d)^{2/3}) = 0.1620683$

Calculation of ratio l_b/d

Inadequate Lap Length with $l_b/d = 0.30$

Calculation of Shear Strength $V_r = \text{Min}(V_{r1}, V_{r2}) = 705811.584$

Calculation of Shear Strength at edge 1, $V_{r1} = 705811.584$

$V_{r1} = V_{\text{Col}} ((10.3), \text{ASCE } 41-17) = k_{nl} \cdot V_{\text{Col}0}$

$V_{\text{Col}0} = 705811.584$

$k_{nl} = 1$ (zero step-static loading)

NOTE: In expression (10-3) ' $V_s = A_v \cdot f_y \cdot d/s$ ' is replaced by ' $V_s + f \cdot V_f$ ' where V_f is the contribution of FRPs (11.3), ACI 440).

$= 1$ (normal-weight concrete)

Mean concrete strength: $f_c' = (f_c'_{\text{jacket}} \cdot \text{Area}_{\text{jacket}} + f_c'_{\text{core}} \cdot \text{Area}_{\text{core}}) / \text{Area}_{\text{section}} = 33.00$, but $f_c'^{0.5} \leq 8.3$ MPa (22.5.3.1, ACI 318-14)

$M/d = 2.00$

$\mu_u = 1.2438899\text{E}-011$

$\nu_u = 3.4807814\text{E}-030$

$d = 0.8 \cdot D = 400.00$

$N_u = 7389.214$

$A_g = 196349.541$

From (11.5.4.8), ACI 318-14: $V_s = V_{s1} + V_{s2} = 274157.871$

$V_{s1} = 274157.871$ is calculated for jacket, with:

$A_v = \frac{1}{2} \cdot A_{\text{stirrup}} = 123370.055$

$f_y = 555.56$

$s = 100.00$

V_{s1} is multiplied by $\text{Col}1 = 1.00$

$s/d = 0.25$

$V_{s2} = 0.00$ is calculated for core, with:

$A_v = \frac{1}{2} \cdot A_{\text{stirrup}} = 78956.835$

$f_y = 555.56$

$s = 250.00$

V_{s2} is multiplied by $\text{Col}2 = 0.00$

$s/d = 1.04167$

$V_f ((11-3)-(11.4), \text{ACI } 440) = 308320.00$

$f = 0.95$, for fully-wrapped sections

$w_f/s_f = 1$ (FRP strips adjacent to one another).

In (11.3) $\sin \theta + \cos \theta$ is replaced with $(\cot \theta + \csc \theta) \sin \alpha$ which is more a generalised expression, where θ is the angle of the crack direction (see KANEPE).

This later relation, considered as a function $V_f(\theta, \alpha)$, is implemented for every different fiber orientation α_i , as well as for 2 crack directions, $\theta = 45^\circ$ and $\theta = -45^\circ$ to take into consideration the cyclic seismic loading.

orientation 1: $\theta = 45^\circ + 90^\circ = 135^\circ$

$V_f = \text{Min}(|V_f(45, \theta)|, |V_f(-45, \theta)|)$, with:

total thickness per orientation, $t_{f1} = N_L \cdot t / N_{\text{Dir}} = 1.00$

$d_{fv} = d$ (figure 11.2, ACI 440) = 470.00

$f_{fe} ((11-5), \text{ACI } 440) = 328.00$

$E_f = 82000.00$

$f_e = 0.004$, from (11.6a), ACI 440

with $f_u = 0.009$

From (11-11), ACI 440: $V_s + V_f \leq 479549.663$

$$b_w*d = \frac{b*d}{4} = 125663.706$$

Calculation of Shear Strength at edge 2, $V_{r2} = 705811.584$

$$V_{r2} = V_{CoI} \text{ ((10.3), ASCE 41-17)} = k_{nl} * V_{CoI0}$$

$$V_{CoI0} = 705811.584$$

$k_{nl} = 1$ (zero step-static loading)

NOTE: In expression (10-3) ' $V_s = A_v * f_y * d / s$ ' is replaced by ' $V_s + f * V_f$ ' where V_f is the contribution of FRPs (11.3), ACI 440).

$\lambda = 1$ (normal-weight concrete)

Mean concrete strength: $f_c' = (f_c'_{jacket} * Area_{jacket} + f_c'_{core} * Area_{core}) / Area_{section} = 33.00$, but $f_c'^{0.5} \leq 8.3$ MPa (22.5.3.1, ACI 318-14)

$$M/Vd = 2.00$$

$$\mu_u = 1.2438899E-011$$

$$\nu_u = 3.4807814E-030$$

$$d = 0.8 * D = 400.00$$

$$N_u = 7389.214$$

$$A_g = 196349.541$$

From (11.5.4.8), ACI 318-14: $V_s = V_{s1} + V_{s2} = 274157.871$

$V_{s1} = 274157.871$ is calculated for jacket, with:

$$A_v = \frac{1}{2} * A_{stirrup} = 123370.055$$

$$f_y = 555.56$$

$$s = 100.00$$

V_{s1} is multiplied by $Col1 = 1.00$

$$s/d = 0.25$$

$V_{s2} = 0.00$ is calculated for core, with:

$$A_v = \frac{1}{2} * A_{stirrup} = 78956.835$$

$$f_y = 555.56$$

$$s = 250.00$$

V_{s2} is multiplied by $Col2 = 0.00$

$$s/d = 1.04167$$

V_f ((11-3)-(11.4), ACI 440) = 308320.00

$f = 0.95$, for fully-wrapped sections

$w_f/s_f = 1$ (FRP strips adjacent to one another).

In (11.3) $\sin + \cos$ is replaced with $(\cot + \cot_a) \sin a$ which is more a generalised expression, where a is the angle of the crack direction (see KANEPE).

This later relation, considered as a function $V_f(\theta, a)$, is implemented for every different fiber orientation a_i , as well as for 2 crack directions, $\theta = 45^\circ$ and $\theta = -45^\circ$ to take into consideration the cyclic seismic loading.

orientation 1: $\theta = b1 + 90^\circ = 90.00$

$V_f = \text{Min}(|V_f(45, \theta)|, |V_f(-45, a1)|)$, with:

total thickness per orientation, $t_{f1} = N_L * t / N_{oDir} = 1.00$

$d_{fv} = d$ (figure 11.2, ACI 440) = 470.00

f_{fe} ((11-5), ACI 440) = 328.00

$$E_f = 82000.00$$

$$f_e = 0.004, \text{ from (11.6a), ACI 440}$$

$$\text{with } f_u = 0.009$$

From (11-11), ACI 440: $V_s + V_f \leq 479549.663$

$$b_w*d = \frac{b*d}{4} = 125663.706$$

End Of Calculation of Shear Capacity ratio for element: column JCC1 of floor 1

At local axis: 3

Start Of Calculation of Shear Capacity ratio for element: column JCC1 of floor 1

At Shear local axis: 2

(Bending local axis: 3)

Section Type: rcjcs

Constant Properties

Knowledge Factor, $\phi = 1.00$

Mean strength values are used for both shear and moment calculations.

Consequently:

Jacket

New material of Primary Member: Concrete Strength, $f_c = f_{cm} = 33.00$

New material of Primary Member: Steel Strength, $f_s = f_{sm} = 555.56$

Concrete Elasticity, $E_c = 26999.444$

Steel Elasticity, $E_s = 200000.00$

Existing Column

New material of Primary Member: Concrete Strength, $f_c = f_{cm} = 33.00$

New material of Primary Member: Steel Strength, $f_s = f_{sm} = 555.56$

Concrete Elasticity, $E_c = 26999.444$

Steel Elasticity, $E_s = 200000.00$

#####

Note: Especially for the calculation of moment strengths,

the above steel re-bar strengths are multiplied by 1.25 according to R18.6.5, ACI 318-14

Jacket

New material: Steel Strength, $f_s = 1.25 \cdot f_{sm} = 694.45$

Existing Column

New material: Steel Strength, $f_s = 1.25 \cdot f_{sm} = 694.45$

#####

External Diameter, $D = 500.00$

Internal Diameter, $D = 300.00$

Cover Thickness, $c = 25.00$

Mean Confinement Factor overall section = 1.51481

Element Length, $L = 3000.00$

Primary Member

Ribbed Bars

Ductile Steel

Without Detailing for Earthquake Resistance (including stirrups not closed at 135°)

Longitudinal Bars With Ends Lapped Starting at the End Sections

Inadequate Lap Length with $l_o/l_{ou, \min} = 0.30$

FRP Wrapping Data

Type: Carbon

Dry properties (design values)

Thickness, $t = 1.00$

Tensile Strength, $f_{fu} = 840.00$

Tensile Modulus, $E_f = 82000.00$

Elongation, $e_{fu} = 0.009$

Number of directions, $N_{oDir} = 1$

Fiber orientations, $b_i: 0.00^\circ$

Number of layers, $N_L = 1$

Radius of rounding corners, $R = 40.00$

Stepwise Properties

At local axis: 2

EDGE -A-

Shear Force, $V_a = -2.1312935E-046$

EDGE -B-

Shear Force, $V_b = 2.1312935E-046$

BOTH EDGES

Axial Force, $F = -7389.214$

Longitudinal Reinforcement Area Distribution (in 2 divisions)

-Tension: $A_{slt} = 0.00$

-Compression: $A_{slc} = 3053.628$

Longitudinal Reinforcement Area Distribution (in 3 divisions)

-Tension: $A_{sl, \text{ten}} = 1017.876$

-Compression: $A_{sl, \text{com}} = 1017.876$

-Middle: $A_{sl, \text{mid}} = 1017.876$

Calculation of Shear Capacity ratio, $V_e/V_r = 0.23017425$

Member Controlled by Flexure ($V_e/V_r < 1$)

Calculation of Shear Demand from fig. R18.6.5, ACI 318-14 $V_e = (M_{pr1} + M_{pr2})/l_n = 162459.651$

with

$$M_{pr1} = \text{Max}(M_{u1+}, M_{u1-}) = 2.4369E+008$$

$M_{u1+} = 2.4369E+008$, is the ultimate moment strength at the edge 1 of the member in the actual moment direction which is defined for the static loading combination

$M_{u1-} = 2.4369E+008$, is the ultimate moment strength at the edge 1 of the member in the opposite moment direction which is defined for the static loading combination

$$M_{pr2} = \text{Max}(M_{u2+}, M_{u2-}) = 2.4369E+008$$

$M_{u2+} = 2.4369E+008$, is the ultimate moment strength at the edge 2 of the member in the actual moment direction which is defined for the the static loading combination

$M_{u2-} = 2.4369E+008$, is the ultimate moment strength at the edge 2 of the member in the opposite moment direction which is defined for the the static loading combination

Calculation of M_{u1+}

Calculation of ultimate Moment Strength ((3.67), Biskinis Phd), M_u
 $M_u = 2.4369E+008$

$$= 0.80285146$$

$$' = 0.71403327$$

error of function (3.68), Biskinis Phd = 27987.158

From 5A.2, TBDY: $f_{cc} = f_c \cdot c = 49.98874$

conf. factor $c = 1.51481$

$$f_c = 33.00$$

From 10.3.5, ASCE 41-17, Final value of f_y : $f_y \cdot \text{Min}(1, 1.25 \cdot (l_b/d)^{2/3}) = 389.0139$

$$l_b/d = 0.30$$

$$d_1 = 44.00$$

$$R = 250.00$$

$$v = 0.00100813$$

$$N = 7389.214$$

$$A_c = 196349.541$$

$$= \cdot \text{Min}(1, 1.25 \cdot (l_b/d)^{2/3}) = 0.1620683$$

Calculation of ratio l_b/d

Inadequate Lap Length with $l_b/d = 0.30$

Calculation of M_{u1-}

Calculation of ultimate Moment Strength ((3.67), Biskinis Phd), M_u
 $M_u = 2.4369E+008$

$$= 0.80285146$$

$$' = 0.71403327$$

error of function (3.68), Biskinis Phd = 27987.158

From 5A.2, TBDY: $f_{cc} = f_c \cdot c = 49.98874$

conf. factor $c = 1.51481$

$$f_c = 33.00$$

From 10.3.5, ASCE 41-17, Final value of f_y : $f_y \cdot \text{Min}(1, 1.25 \cdot (l_b/d)^{2/3}) = 389.0139$

$$l_b/d = 0.30$$

$$d_1 = 44.00$$

$$R = 250.00$$

$$v = 0.00100813$$

$$N = 7389.214$$

$$A_c = 196349.541$$

$$= \cdot \text{Min}(1, 1.25 \cdot (l_b/d)^{2/3}) = 0.1620683$$

Calculation of ratio l_b/d

Inadequate Lap Length with $l_b/d = 0.30$

Calculation of Mu2+

Calculation of ultimate Moment Strength ((3.67), Biskinis Phd), Mu
Mu = 2.4369E+008

$$= 0.80285146$$

$$' = 0.71403327$$

error of function (3.68), Biskinis Phd = 27987.158

From 5A.2, TBDY: fcc = fc* c = 49.98874

$$\text{conf. factor } c = 1.51481$$

$$fc = 33.00$$

From 10.3.5, ASCE 41-17, Final value of fy: fy*Min(1,1.25*(lb/d)^ 2/3) = 389.0139

$$lb/d = 0.30$$

$$d1 = 44.00$$

$$R = 250.00$$

$$v = 0.00100813$$

$$N = 7389.214$$

$$Ac = 196349.541$$

$$= *Min(1,1.25*(lb/d)^ 2/3) = 0.1620683$$

Calculation of ratio lb/d

Inadequate Lap Length with lb/d = 0.30

Calculation of Mu2-

Calculation of ultimate Moment Strength ((3.67), Biskinis Phd), Mu
Mu = 2.4369E+008

$$= 0.80285146$$

$$' = 0.71403327$$

error of function (3.68), Biskinis Phd = 27987.158

From 5A.2, TBDY: fcc = fc* c = 49.98874

$$\text{conf. factor } c = 1.51481$$

$$fc = 33.00$$

From 10.3.5, ASCE 41-17, Final value of fy: fy*Min(1,1.25*(lb/d)^ 2/3) = 389.0139

$$lb/d = 0.30$$

$$d1 = 44.00$$

$$R = 250.00$$

$$v = 0.00100813$$

$$N = 7389.214$$

$$Ac = 196349.541$$

$$= *Min(1,1.25*(lb/d)^ 2/3) = 0.1620683$$

Calculation of ratio lb/d

Inadequate Lap Length with lb/d = 0.30

Calculation of Shear Strength Vr = Min(Vr1,Vr2) = 705811.584

Calculation of Shear Strength at edge 1, Vr1 = 705811.584

Vr1 = VCol ((10.3), ASCE 41-17) = knl*VColO

$$VColO = 705811.584$$

$k_{nl} = 1$ (zero step-static loading)

NOTE: In expression (10-3) ' $V_s = A_v \cdot f_y \cdot d / s$ ' is replaced by ' $V_s + f \cdot V_f$ ' where V_f is the contribution of FRPs (11.3), ACI 440).

$\lambda = 1$ (normal-weight concrete)

Mean concrete strength: $f'_c = (f'_{c_jacket} \cdot Area_jacket + f'_{c_core} \cdot Area_core) / Area_section = 33.00$, but $f_c^{0.5} \leq 8.3$ MPa (22.5.3.1, ACI 318-14)

$M/Vd = 2.00$

$\mu_u = 1.5940012E-011$

$\nu_u = 2.1312935E-046$

$d = 0.8 \cdot D = 400.00$

$N_u = 7389.214$

$A_g = 196349.541$

From (11.5.4.8), ACI 318-14: $V_s = V_{s1} + V_{s2} = 274157.871$

$V_{s1} = 274157.871$ is calculated for jacket, with:

$A_v = \frac{1}{2} \cdot A_{stirrup} = 123370.055$

$f_y = 555.56$

$s = 100.00$

V_{s1} is multiplied by $Col1 = 1.00$

$s/d = 0.25$

$V_{s2} = 0.00$ is calculated for core, with:

$A_v = \frac{1}{2} \cdot A_{stirrup} = 78956.835$

$f_y = 555.56$

$s = 250.00$

V_{s2} is multiplied by $Col2 = 0.00$

$s/d = 1.04167$

V_f ((11-3)-(11.4), ACI 440) = 308320.00

$f = 0.95$, for fully-wrapped sections

$w_f/s_f = 1$ (FRP strips adjacent to one another).

In (11.3) $\sin \theta + \cos \theta$ is replaced with $(\cot \theta + \csc \theta) \sin \alpha$ which is more a generalised expression,

where θ is the angle of the crack direction (see KANEPE).

This later relation, considered as a function $V_f(\theta, \alpha)$, is implemented for every different fiber orientation α_i , as well as for 2 crack directions, $\theta = 45^\circ$ and $\theta = -45^\circ$ to take into consideration the cyclic seismic loading.

orientation 1: $\theta = b_1 + 90^\circ = 90.00$

$V_f = \text{Min}(|V_f(45, \theta)|, |V_f(-45, \theta)|)$, with:

total thickness per orientation, $t_{f1} = N_L \cdot t / N_{oDir} = 1.00$

$d_{fv} = d$ (figure 11.2, ACI 440) = 470.00

f_{fe} ((11-5), ACI 440) = 328.00

$E_f = 82000.00$

$f_e = 0.004$, from (11.6a), ACI 440

with $f_u = 0.009$

From (11-11), ACI 440: $V_s + V_f \leq 479549.663$

$b_w \cdot d = \frac{1}{4} \cdot d \cdot d = 125663.706$

Calculation of Shear Strength at edge 2, $V_{r2} = 705811.584$

$V_{r2} = V_{Col}$ ((10.3), ASCE 41-17) = $k_{nl} \cdot V_{Col0}$

$V_{Col0} = 705811.584$

$k_{nl} = 1$ (zero step-static loading)

NOTE: In expression (10-3) ' $V_s = A_v \cdot f_y \cdot d / s$ ' is replaced by ' $V_s + f \cdot V_f$ ' where V_f is the contribution of FRPs (11.3), ACI 440).

$\lambda = 1$ (normal-weight concrete)

Mean concrete strength: $f'_c = (f'_{c_jacket} \cdot Area_jacket + f'_{c_core} \cdot Area_core) / Area_section = 33.00$, but $f_c^{0.5} \leq 8.3$ MPa (22.5.3.1, ACI 318-14)

$M/Vd = 2.00$

$\mu_u = 1.5940012E-011$

$\nu_u = 2.1312935E-046$

$d = 0.8 \cdot D = 400.00$

$N_u = 7389.214$

$A_g = 196349.541$

From (11.5.4.8), ACI 318-14: $V_s = V_{s1} + V_{s2} = 274157.871$

$V_{s1} = 274157.871$ is calculated for jacket, with:

$A_v = \frac{1}{2} \cdot A_{stirrup} = 123370.055$

$f_y = 555.56$

$s = 100.00$
 V_{s1} is multiplied by $Col1 = 1.00$
 $s/d = 0.25$
 $V_{s2} = 0.00$ is calculated for core, with:
 $A_v = \sqrt{2} \cdot A_{stirrup} = 78956.835$
 $f_y = 555.56$
 $s = 250.00$
 V_{s2} is multiplied by $Col2 = 0.00$
 $s/d = 1.04167$
 $V_f((11-3)-(11.4), ACI 440) = 308320.00$
 $f = 0.95$, for fully-wrapped sections
 $w_f/s_f = 1$ (FRP strips adjacent to one another).
 In (11.3) $\sin \theta + \cos \theta$ is replaced with $(\cot \theta + \cot \alpha) \sin \alpha$ which is more a generalised expression,
 where θ is the angle of the crack direction (see KANEPE).
 This later relation, considered as a function $V_f(\theta, \alpha)$, is implemented for every different fiber orientation α_i ,
 as well as for 2 crack directions, $\theta = 45^\circ$ and $\theta = -45^\circ$ to take into consideration the cyclic seismic loading.
 orientation 1: $\theta = \theta_1 + 90^\circ = 90.00$
 $V_f = \text{Min}(|V_f(45, \theta_1)|, |V_f(-45, \theta_1)|)$, with:
 total thickness per orientation, $t_{f1} = N_L \cdot t / N_{oDir} = 1.00$
 $d_{fv} = d$ (figure 11.2, ACI 440) = 470.00
 $f_{fe}((11-5), ACI 440) = 328.00$
 $E_f = 82000.00$
 $f_e = 0.004$, from (11.6a), ACI 440
 with $f_u = 0.009$
 From (11-11), ACI 440: $V_s + V_f \leq 479549.663$
 $b_w \cdot d = \sqrt{V_s + V_f} \cdot d / 4 = 125663.706$

 End Of Calculation of Shear Capacity ratio for element: column JCC1 of floor 1
 At local axis: 2

 Start Of Calculation of Chord Rotation Capacity for element: column JCC1 of floor 1
 At local axis: 2
 Integration Section: (a)
 Section Type: rcjcs

Constant Properties

 Knowledge Factor, $\phi = 1.00$
 Chord Rotation is generally considered as Deformation-Controlled Action according to Table C7-1, ASCE 41-17.
 Mean strengths are used for Deformation-Controlled Actions according to 7.5.1.3, ASCE 41-17
 Consequently:
 Jacket
 New material of Primary Member: Concrete Strength, $f_c = f_{cm} = 33.00$
 New material of Primary Member: Steel Strength, $f_s = f_{sm} = 555.56$
 Concrete Elasticity, $E_c = 26999.444$
 Steel Elasticity, $E_s = 200000.00$
 Existing Column
 New material of Primary Member: Concrete Strength, $f_c = f_{cm} = 33.00$
 New material of Primary Member: Steel Strength, $f_s = f_{sm} = 555.56$
 Concrete Elasticity, $E_c = 26999.444$
 Steel Elasticity, $E_s = 200000.00$
 External Diameter, $D = 500.00$
 Internal Diameter, $D = 300.00$
 Cover Thickness, $c = 25.00$
 Element Length, $L = 3000.00$
 Primary Member
 Ribbed Bars
 Ductile Steel
 Without Detailing for Earthquake Resistance (including stirrups not closed at 135°)
 Longitudinal Bars With Ends Lapped Starting at the End Sections
 Inadequate Lap Length with $l_b/l_d = 0.30$
 FRP Wrapping Data
 Type: Carbon

Dry properties (design values)

Thickness, $t = 1.00$
Tensile Strength, $f_{fu} = 840.00$
Tensile Modulus, $E_f = 82000.00$
Elongation, $e_{fu} = 0.009$
Number of directions, $N_{oDir} = 1$
Fiber orientations, $b_i = 0.00^\circ$
Number of layers, $N_L = 1$
Radius of rounding corners, $R = 40.00$

Stepwise Properties

Bending Moment, $M = 7.3474831E-010$
Shear Force, $V_2 = -4779.203$
Shear Force, $V_3 = -2.1566928E-013$
Axial Force, $F = -7387.302$
Longitudinal Reinforcement Area Distribution (in 2 divisions)
-Tension: $A_{sl,t} = 0.00$
-Compression: $A_{sl,c} = 3053.628$
Longitudinal Reinforcement Area Distribution (in 3 divisions)
-Tension: $A_{sl,ten} = 1017.876$
-Compression: $A_{sl,com} = 1017.876$
-Middle: $A_{sl,mid} = 1017.876$
Mean Diameter of Tension Reinforcement, $D_{bL} = 18.00$

New component: From table 7-7, ASCE 41_17: Final chord rotation Capacity $u_{,R} = 1.0^*$ $u = 0.00453062$
 $u = y + p = 0.00453062$

- Calculation of y -

 $y = (M_y * L_s / 3) / E_{eff} = 0.00453062$ ((4.29), Biskinis Phd))
 $M_y = 2.2517E+008$
 $L_s = M/V$ (with $L_s > 0.1 * L$ and $L_s < 2 * L$) = 1500.00
From table 10.5, ASCE 41_17: $E_{eff} = factor * E_c * I_g = 2.4850E+013$
 $factor = 0.30$
 $A_g = 196349.541$
Mean concrete strength: $f_c' = (f_c'_{jacket} * Area_{jacket} + f_c'_{core} * Area_{core}) / Area_{section} = 33.00$
 $N = 7387.302$
 $E_c * I_g = E_c * I_{g,jacket} + E_c * I_{g,core} = 8.2833E+013$

Calculation of Yielding Moment M_y

Calculation of y and M_y according to (7) - (8) in Biskinis and Fardis

 $M_y = \min(M_{y,ten}, M_{y,com}) = 2.2517E+008$
 $y = 6.4424840E-006$
 $M_{y,ten}$ (8c) = $2.2517E+008$
 $_{ten}$ (7c) = 61.8137
error of function (7c) = 0.00026387
 $M_{y,com}$ (8d) = $8.1922E+008$
 $_{com}$ (7d) = 63.67468
error of function (7d) = -0.0087488
with ((10.1), ASCE 41-17) $e_y = \min(e_y, 1.25 * e_y * (l_b / l_d)^{2/3}) = 0.0027778$
 $e_{co} = 0.002$
 $a_{pl} = 0.45$ ((9c) in Biskinis and Fardis for FRP Wrap)
 $d_1 = 44.00$
 $R = 250.00$
 $v = 0.00101374$
 $N = 7387.302$
 $A_c = 196349.541$

$((10.1), ASCE 41-17) = \text{Min}(, 1.25 * (lb/ld)^{2/3}) = 0.23280363$
 with f_c ((12.3), ACI 440) = 37.11312
 $f_c = 33.00$
 $\phi = 1.312$
 $k = 1$
 Effective FRP thickness, $t_f = NL * t * \text{Cos}(b1) = 1.00$
 e_{fe} ((12.5) and (12.7)) = 0.004
 $f_u = 0.009$
 $E_f = 82000.00$

Calculation of ratio lb/ld

Inadequate Lap Length with $lb/ld = 0.30$

- Calculation of ρ -

From table 10-9: $\rho = 0.00$

with:

- Columns controlled by inadequate development or splicing along the clear height because $lb/ld < 1$

shear control ratio $V_y E / V_{col} O E = 0.23017425$

$d = d_{\text{external}} = 0.00$

$s = s_{\text{external}} = 0.00$

$t = s_1 + s_2 + 2 * t_f / bw * (f_{fe} / f_s) = 0.00795744$

jacket: $s_1 = A_{v1} * (Dc1 / 2) / (s_1 * A_g) = 0.0027646$

$A_{v1} = 78.53982$, is the area of stirrup

$Dc1 = D_{\text{ext}} - 2 * \text{cover} - \text{External Hoop Diameter} = 440.00$, is the total Length of all stirrups parallel to loading

(shear) direction

$s_1 = 100.00$

core: $s_2 = A_{v2} * (Dc2 / 2) / (s_2 * A_g) = 0.00046968$

$A_{v2} = 50.26548$, is the area of stirrup

$Dc2 = D_{\text{int}} - \text{Internal Hoop Diameter} = 292.00$, is the total Length of all stirrups parallel to loading (shear)

direction

$s_2 = 250.00$

The term $2 * t_f / bw * (f_{fe} / f_s)$ is implemented to account for FRP contribution

where $f = 2 * t_f / bw$ is FRP ratio (EC8 - 3, A.4.4.3(6)) and f_{fe} / f_s normalises f to steel strength

All these variables have already been given in Shear control ratio calculation.

For the normalisation f_s of jacket is used.

$N_{UD} = 7387.302$

$A_g = 196349.541$

$f_{cE} = (f_{c_{\text{jacket}}} * \text{Area}_{\text{jacket}} + f_{c_{\text{core}}} * \text{Area}_{\text{core}}) / \text{section_area} = 33.00$

$f_{yIE} = (f_{y_{\text{ext_Long_Reinf}}} * \text{Area}_{\text{ext_Long_Reinf}} + f_{y_{\text{int_Long_Reinf}}} * \text{Area}_{\text{int_Long_Reinf}}) / \text{Area}_{\text{Tot_Long_Rein}} = 2.1219958E-314$

$f_{yTE} = (f_{y_{\text{ext_Trans_Reinf}}} * \text{Area}_{\text{ext_Trans_Reinf}} + f_{y_{\text{int_Trans_Reinf}}} * \text{Area}_{\text{int_Trans_Reinf}}) / \text{Area}_{\text{Tot_Trans_Rein}} = 555.56$

$\rho_l = \text{Area}_{\text{Tot_Long_Rein}} / (A_g) = 0.015552$

$f_{cE} = 33.00$

End Of Calculation of Chord Rotation Capacity for element: column JCC1 of floor 1

At local axis: 2

Integration Section: (a)

Calculation No. 3

column C1, Floor 1


Limit State: Immediate Occupancy (data interpolation between analysis steps 1 and 2)

Analysis: Uniform +X

Check: Shear capacity VRd

Edge: Start

Local Axis: (3)



Start Of Calculation of Shear Capacity for element: column JCC1 of floor 1

At local axis: 3

Integration Section: (a)

Section Type: rcjcs

Constant Properties

Knowledge Factor, $\gamma = 1.00$

Member Shear Force is generally considered as Force-Controlled Action according to Table C7-1, ASCE 41-17.

Lower-bound strengths are used for Force-Controlled Actions according to 7.5.1.3, ASCE 41-17

Consequently:

Jacket

New material of Primary Member: Concrete Strength, $f_c = f_{c_lower_bound} = 25.00$

New material of Primary Member: Steel Strength, $f_s = f_{s_lower_bound} = 500.00$

Concrete Elasticity, $E_c = 26999.444$

Steel Elasticity, $E_s = 200000.00$

Existing Column

New material of Primary Member: Concrete Strength, $f_c = f_{c_lower_bound} = 25.00$

New material of Primary Member: Steel Strength, $f_s = f_{s_lower_bound} = 500.00$

Concrete Elasticity, $E_c = 26999.444$

Steel Elasticity, $E_s = 200000.00$

#####

Note: Especially for the calculation of γ for displacement ductility demand, the expected (mean value) strengths are used (7.5.1.3, ASCE 41-17) because bending is considered as Deformation-Controlled Action (Table C7-1, ASCE 41-17).

Jacket

New material: Concrete Strength, $f_c = f_{cm} = 33.00$

New material: Steel Strength, $f_s = f_{sm} = 555.56$

Existing Column

New material: Concrete Strength, $f_c = f_{cm} = 33.00$

New material: Steel Strength, $f_s = f_{sm} = 555.56$

#####

External Diameter, $D = 500.00$

Internal Diameter, $D = 300.00$

Cover Thickness, $c = 25.00$

Element Length, $L = 3000.00$

Primary Member

Ribbed Bars

Ductile Steel

Without Detailing for Earthquake Resistance (including stirrups not closed at 135°)
Longitudinal Bars With Ends Lapped Starting at the End Sections
Inadequate Lap Length with $l_o/l_{ou,min} = l_b/l_d = 0.30$
FRP Wrapping Data
Type: Carbon
Dry properties (design values)
Thickness, $t = 1.00$
Tensile Strength, $f_{fu} = 840.00$
Tensile Modulus, $E_f = 82000.00$
Elongation, $e_{fu} = 0.009$
Number of directions, $NoDir = 1$
Fiber orientations, $bi: 0.00^\circ$
Number of layers, $NL = 1$
Radius of rounding corners, $R = 40.00$

Stepwise Properties

EDGE -A-
Bending Moment, $M_a = 7.3474831E-010$
Shear Force, $V_a = -2.1566928E-013$
EDGE -B-
Bending Moment, $M_b = -8.7529383E-011$
Shear Force, $V_b = 2.1566928E-013$
BOTH EDGES
Axial Force, $F = -7387.302$
Longitudinal Reinforcement Area Distribution (in 2 divisions)
-Tension: $As_t = 0.00$
-Compression: $As_c = 3053.628$
Longitudinal Reinforcement Area Distribution (in 3 divisions)
-Tension: $As_{t,ten} = 1017.876$
-Compression: $As_{c,com} = 1017.876$
-Middle: $As_{mid} = 1017.876$
Mean Diameter of Tension Reinforcement, $Db_{L,ten} = 18.00$

New component: From table 7-7, ASCE 41_17: Final Shear Capacity $V_R = 1.0 * V_n = 614519.957$
 $V_n ((10.3), ASCE 41-17) = knl * V_{CoI0} = 614519.957$
 $V_{CoI} = 614519.957$
 $knl = 1.00$
 $displacement_ductility_demand = 0.00$

NOTE: In expression (10-3) ' $V_s = A_v * f_y * d / s$ ' is replaced by ' $V_s + f * V_f$ '
where V_f is the contribution of FRPs (11.3), ACI 440).

= 1 (normal-weight concrete)
Mean concrete strength: $f'_c = (f'_c_jacket * Area_jacket + f'_c_core * Area_core) / Area_section = 25.00$, but $f'_c^{0.5} \leq 8.3$
MPa (22.5.3.1, ACI 318-14)
 $M / Vd = 2.00$
 $M_u = 7.3474831E-010$
 $V_u = 2.1566928E-013$
 $d = 0.8 * D = 400.00$
 $N_u = 7387.302$
 $A_g = 196349.541$
From (11.5.4.8), ACI 318-14: $V_s = V_{s1} + V_{s2} = 246740.11$
 $V_{s1} = 246740.11$ is calculated for jacket, with:
 $A_v = \sqrt{2} * A_stirrup = 123370.055$
 $f_y = 500.00$
 $s = 100.00$
 V_{s1} is multiplied by $Col1 = 1.00$
 $s/d = 0.25$
 $V_{s2} = 0.00$ is calculated for core, with:
 $A_v = \sqrt{2} * A_stirrup = 78956.835$
 $f_y = 500.00$
 $s = 250.00$

Vs2 is multiplied by Col2 = 0.00

s/d = 1.04167

Vf ((11-3)-(11.4), ACI 440) = 308320.00

f = 0.95, for fully-wrapped sections

wf/sf = 1 (FRP strips adjacent to one another).

In (11.3) $\sin \theta + \cos \theta$ is replaced with $(\cot \theta + \csc \theta) \sin \alpha$ which is more a generalised expression, where θ is the angle of the crack direction (see KANEPE).

This later relation, considered as a function Vf(θ , α), is implemented for every different fiber orientation ai, as well as for 2 crack directions, $\theta = 45^\circ$ and $\theta = -45^\circ$ to take into consideration the cyclic seismic loading.

orientation 1: $\theta = b1 + 90^\circ = 90.00$

Vf = Min(|Vf(45, θ)|, |Vf(-45, θ)|), with:

total thickness per orientation, tf1 = NL*t/NoDir = 1.00

dfv = d (figure 11.2, ACI 440) = 470.00

ffe ((11-5), ACI 440) = 328.00

Ef = 82000.00

fe = 0.004, from (11.6a), ACI 440

with fu = 0.009

From (11-11), ACI 440: Vs + Vf <= 417394.406

bw*d = $\frac{Vs + Vf}{4} = 125663.706$

displacement_ductility_demand is calculated as $\frac{V}{y}$

- Calculation of $\frac{V}{y}$ for END A -
for rotation axis 2 and integ. section (a)

From analysis, chord rotation $\theta = 9.5640318E-021$

y = (My* $L_s/3$)/Eleff = 0.00453062 ((4.29), Biskinis Phd)

My = 2.2517E+008

$L_s = M/V$ (with $L_s > 0.1*L$ and $L_s < 2*L$) = 1500.00

From table 10.5, ASCE 41_17: Eleff = factor*Ec*Ig = 2.4850E+013

factor = 0.30

Ag = 196349.541

Mean concrete strength: $f'_c = (f'_{c_jacket} * Area_jacket + f'_{c_core} * Area_core) / Area_section = 33.00$

N = 7387.302

$E_c * I_g = E_{c_jacket} * I_{g_jacket} + E_{c_core} * I_{g_core} = 8.2833E+013$

Calculation of Yielding Moment My

Calculation of $\frac{V}{y}$ and My according to (7) - (8) in Biskinis and Fardis

My = Min(My_ten, My_com) = 2.2517E+008

y = 6.4424840E-006

My_ten (8c) = 2.2517E+008

_ten (7c) = 61.8137

error of function (7c) = 0.00026387

My_com (8d) = 8.1922E+008

_com (7d) = 63.67468

error of function (7d) = -0.0087488

with ((10.1), ASCE 41-17) $e_y = \text{Min}(e_y, 1.25 * e_y * (l_b/l_d)^{2/3}) = 0.0027778$

eco = 0.002

apl = 0.45 ((9c) in Biskinis and Fardis for FRP Wrap)

d1 = 44.00

R = 250.00

v = 0.00101374

N = 7387.302

Ac = 196349.541

((10.1), ASCE 41-17) $e_y = \text{Min}(e_y, 1.25 * e_y * (l_b/l_d)^{2/3}) = 0.23280363$

with f'_c ((12.3), ACI 440) = 37.11312

$f'_c = 33.00$

fl = 1.312

k = 1

Effective FRP thickness, tf = NL*t*Cos(b1) = 1.00

efe ((12.5) and (12.7)) = 0.004

$f_u = 0.009$
 $E_f = 82000.00$

Calculation of ratio I_b/I_d

Inadequate Lap Length with $I_b/I_d = 0.30$

End Of Calculation of Shear Capacity for element: column JCC1 of floor 1

At local axis: 3

Integration Section: (a)

Calculation No. 4

column C1, Floor 1



Limit State: Immediate Occupancy (data interpolation between analysis steps 1 and 2)

Analysis: Uniform +X

Check: Chord rotation capacity (u)

Edge: Start

Local Axis: (3)



Start Of Calculation of Shear Capacity ratio for element: column JCC1 of floor 1

At Shear local axis: 3

(Bending local axis: 2)

Section Type: rcjcs

Constant Properties

Knowledge Factor, $= 1.00$

Mean strength values are used for both shear and moment calculations.

Consequently:

Jacket

New material of Primary Member: Concrete Strength, $f_c = f_{cm} = 33.00$

New material of Primary Member: Steel Strength, $f_s = f_{sm} = 555.56$

Concrete Elasticity, $E_c = 26999.444$

Steel Elasticity, $E_s = 200000.00$

Existing Column

New material of Primary Member: Concrete Strength, $f_c = f_{cm} = 33.00$

New material of Primary Member: Steel Strength, $f_s = f_{sm} = 555.56$

Concrete Elasticity, $E_c = 26999.444$

Steel Elasticity, $E_s = 200000.00$

#####

Note: Especially for the calculation of moment strengths,

the above steel re-bar strengths are multiplied by 1.25 according to R18.6.5, ACI 318-14

Jacket

New material: Steel Strength, $f_s = 1.25 \cdot f_{sm} = 694.45$

Existing Column

New material: Steel Strength, $f_s = 1.25 \cdot f_{sm} = 694.45$

#####

External Diameter, $D = 500.00$

Internal Diameter, $D = 300.00$

Cover Thickness, $c = 25.00$

Mean Confinement Factor overall section = 1.51481

Element Length, $L = 3000.00$

Primary Member

Ribbed Bars

Ductile Steel

Without Detailing for Earthquake Resistance (including stirrups not closed at 135°)

Longitudinal Bars With Ends Lapped Starting at the End Sections

Inadequate Lap Length with $l_o/l_{ou,min} = 0.30$

FRP Wrapping Data

Type: Carbon

Dry properties (design values)

Thickness, $t = 1.00$

Tensile Strength, $f_{fu} = 840.00$

Tensile Modulus, $E_f = 82000.00$

Elongation, $e_{fu} = 0.009$

Number of directions, $N_{oDir} = 1$

Fiber orientations, $b_i = 0.00^\circ$

Number of layers, $N_L = 1$

Radius of rounding corners, $R = 40.00$

Stepwise Properties

At local axis: 3

EDGE -A-

Shear Force, $V_a = 3.4807814E-030$

EDGE -B-

Shear Force, $V_b = -3.4807814E-030$

BOTH EDGES

Axial Force, $F = -7389.214$

Longitudinal Reinforcement Area Distribution (in 2 divisions)

-Tension: $A_{sl,t} = 0.00$

-Compression: $A_{sl,c} = 3053.628$

Longitudinal Reinforcement Area Distribution (in 3 divisions)

-Tension: $A_{sl,ten} = 1017.876$

-Compression: $A_{sl,com} = 1017.876$

-Middle: $A_{sl,mid} = 1017.876$

Calculation of Shear Capacity ratio, $V_e/V_r = 0.23017425$

Member Controlled by Flexure ($V_e/V_r < 1$)

Calculation of Shear Demand from fig. R18.6.5, ACI 318-14 $V_e = (M_{pr1} + M_{pr2})/l_n = 162459.651$

with

$M_{pr1} = \text{Max}(M_{u1+}, M_{u1-}) = 2.4369E+008$

$M_{u1+} = 2.4369E+008$, is the ultimate moment strength at the edge 1 of the member in the actual moment direction which is defined for the static loading combination

$M_{u1-} = 2.4369E+008$, is the ultimate moment strength at the edge 1 of the member in the opposite moment direction which is defined for the static loading combination

$M_{pr2} = \text{Max}(M_{u2+}, M_{u2-}) = 2.4369E+008$

Mu2+ = 2.4369E+008, is the ultimate moment strength at the edge 2 of the member in the actual moment direction which is defined for the the static loading combination

Mu2- = 2.4369E+008, is the ultimate moment strength at the edge 2 of the member in the opposite moment direction which is defined for the the static loading combination

Calculation of Mu1+

Calculation of ultimate Moment Strength ((3.67), Biskinis Phd), Mu

Mu = 2.4369E+008

= 0.80285146

' = 0.71403327

error of function (3.68), Biskinis Phd = 27987.158

From 5A.2, TBDY: fcc = fc* c = 49.98874

conf. factor c = 1.51481

fc = 33.00

From 10.3.5, ASCE 41-17, Final value of fy: fy*Min(1,1.25*(lb/d)^ 2/3) = 389.0139

lb/d = 0.30

d1 = 44.00

R = 250.00

v = 0.00100813

N = 7389.214

Ac = 196349.541

= *Min(1,1.25*(lb/d)^ 2/3) = 0.1620683

Calculation of ratio lb/d

Inadequate Lap Length with lb/d = 0.30

Calculation of Mu1-

Calculation of ultimate Moment Strength ((3.67), Biskinis Phd), Mu

Mu = 2.4369E+008

= 0.80285146

' = 0.71403327

error of function (3.68), Biskinis Phd = 27987.158

From 5A.2, TBDY: fcc = fc* c = 49.98874

conf. factor c = 1.51481

fc = 33.00

From 10.3.5, ASCE 41-17, Final value of fy: fy*Min(1,1.25*(lb/d)^ 2/3) = 389.0139

lb/d = 0.30

d1 = 44.00

R = 250.00

v = 0.00100813

N = 7389.214

Ac = 196349.541

= *Min(1,1.25*(lb/d)^ 2/3) = 0.1620683

Calculation of ratio lb/d

Inadequate Lap Length with lb/d = 0.30

Calculation of Mu2+

Calculation of ultimate Moment Strength ((3.67), Biskinis Phd), Mu
Mu = 2.4369E+008

$$= 0.80285146$$

$$' = 0.71403327$$

error of function (3.68), Biskinis Phd = 27987.158

From 5A.2, TBDY: $f_{cc} = f_c \cdot c = 49.98874$

$$\text{conf. factor } c = 1.51481$$

$$f_c = 33.00$$

From 10.3.5, ASCE 41-17, Final value of f_y : $f_y \cdot \text{Min}(1, 1.25 \cdot (l_b/d)^{2/3}) = 389.0139$

$$l_b/d = 0.30$$

$$d_1 = 44.00$$

$$R = 250.00$$

$$v = 0.00100813$$

$$N = 7389.214$$

$$A_c = 196349.541$$

$$= \cdot \text{Min}(1, 1.25 \cdot (l_b/d)^{2/3}) = 0.1620683$$

Calculation of ratio l_b/d

Inadequate Lap Length with $l_b/d = 0.30$

Calculation of Mu2-

Calculation of ultimate Moment Strength ((3.67), Biskinis Phd), Mu
Mu = 2.4369E+008

$$= 0.80285146$$

$$' = 0.71403327$$

error of function (3.68), Biskinis Phd = 27987.158

From 5A.2, TBDY: $f_{cc} = f_c \cdot c = 49.98874$

$$\text{conf. factor } c = 1.51481$$

$$f_c = 33.00$$

From 10.3.5, ASCE 41-17, Final value of f_y : $f_y \cdot \text{Min}(1, 1.25 \cdot (l_b/d)^{2/3}) = 389.0139$

$$l_b/d = 0.30$$

$$d_1 = 44.00$$

$$R = 250.00$$

$$v = 0.00100813$$

$$N = 7389.214$$

$$A_c = 196349.541$$

$$= \cdot \text{Min}(1, 1.25 \cdot (l_b/d)^{2/3}) = 0.1620683$$

Calculation of ratio l_b/d

Inadequate Lap Length with $l_b/d = 0.30$

Calculation of Shear Strength $V_r = \text{Min}(V_{r1}, V_{r2}) = 705811.584$

Calculation of Shear Strength at edge 1, $V_{r1} = 705811.584$

$V_{r1} = V_{Co1}$ ((10.3), ASCE 41-17) = $k_{nl} \cdot V_{Co10}$

$$V_{Co10} = 705811.584$$

$$k_{nl} = 1 \text{ (zero step-static loading)}$$

NOTE: In expression (10-3) ' $V_s = A_v \cdot f_y \cdot d/s$ ' is replaced by ' $V_s + f \cdot V_f$ ' where V_f is the contribution of FRPs (11.3), ACI 440).

$$= 1 \text{ (normal-weight concrete)}$$

Mean concrete strength: $f_c' = (f_c'_{\text{jacket}} \cdot \text{Area}_{\text{jacket}} + f_c'_{\text{core}} \cdot \text{Area}_{\text{core}}) / \text{Area}_{\text{section}} = 33.00$, but $f_c'^{0.5} \leq 8.3$ MPa (22.5.3.1, ACI 318-14)

$M/Vd = 2.00$

$\mu_u = 1.2438899E-011$

$V_u = 3.4807814E-030$

$d = 0.8 \cdot D = 400.00$

$N_u = 7389.214$

$A_g = 196349.541$

From (11.5.4.8), ACI 318-14: $V_s = V_{s1} + V_{s2} = 274157.871$

$V_{s1} = 274157.871$ is calculated for jacket, with:

$A_v = \sqrt{2} \cdot A_{\text{stirrup}} = 123370.055$

$f_y = 555.56$

$s = 100.00$

V_{s1} is multiplied by $\text{Col1} = 1.00$

$s/d = 0.25$

$V_{s2} = 0.00$ is calculated for core, with:

$A_v = \sqrt{2} \cdot A_{\text{stirrup}} = 78956.835$

$f_y = 555.56$

$s = 250.00$

V_{s2} is multiplied by $\text{Col2} = 0.00$

$s/d = 1.04167$

V_f ((11-3)-(11.4), ACI 440) = 308320.00

$f = 0.95$, for fully-wrapped sections

$w_f/s_f = 1$ (FRP strips adjacent to one another).

In (11.3) $\sin \theta + \cos \theta$ is replaced with $(\cot \theta + \cot \alpha) \sin \alpha$ which is more a generalised expression,

where θ is the angle of the crack direction (see KANEPE).

This later relation, considered as a function $V_f(\theta, \alpha)$, is implemented for every different fiber orientation α_i , as well as for 2 crack directions, $\theta = 45^\circ$ and $\theta = -45^\circ$ to take into consideration the cyclic seismic loading.

orientation 1: $\theta = b1 + 90^\circ = 90.00$

$V_f = \text{Min}(|V_f(45, \theta)|, |V_f(-45, \theta)|)$, with:

total thickness per orientation, $t_{f1} = N_L \cdot t / N_{\text{Dir}} = 1.00$

$d_{fv} = d$ (figure 11.2, ACI 440) = 470.00

f_{fe} ((11-5), ACI 440) = 328.00

$E_f = 82000.00$

$f_e = 0.004$, from (11.6a), ACI 440

with $f_u = 0.009$

From (11-11), ACI 440: $V_s + V_f \leq 479549.663$

$b_w \cdot d = \sqrt{2} \cdot d^2 / 4 = 125663.706$

Calculation of Shear Strength at edge 2, $V_{r2} = 705811.584$

$V_{r2} = V_{\text{Col}}((10.3), \text{ASCE } 41-17) = k_{nl} \cdot V_{\text{Col}0}$

$V_{\text{Col}0} = 705811.584$

$k_{nl} = 1$ (zero step-static loading)

NOTE: In expression (10-3) ' $V_s = A_v \cdot f_y \cdot d / s$ ' is replaced by ' $V_s + f \cdot V_f$ ' where V_f is the contribution of FRPs (11.3), ACI 440).

$\gamma = 1$ (normal-weight concrete)

Mean concrete strength: $f_c' = (f_c'_{\text{jacket}} \cdot \text{Area}_{\text{jacket}} + f_c'_{\text{core}} \cdot \text{Area}_{\text{core}}) / \text{Area}_{\text{section}} = 33.00$, but $f_c'^{0.5} \leq 8.3$ MPa (22.5.3.1, ACI 318-14)

$M/Vd = 2.00$

$\mu_u = 1.2438899E-011$

$V_u = 3.4807814E-030$

$d = 0.8 \cdot D = 400.00$

$N_u = 7389.214$

$A_g = 196349.541$

From (11.5.4.8), ACI 318-14: $V_s = V_{s1} + V_{s2} = 274157.871$

$V_{s1} = 274157.871$ is calculated for jacket, with:

$A_v = \sqrt{2} \cdot A_{\text{stirrup}} = 123370.055$

$f_y = 555.56$

$s = 100.00$

V_{s1} is multiplied by $\text{Col1} = 1.00$

$s/d = 0.25$

$V_{s2} = 0.00$ is calculated for core, with:

$A_v = \sqrt{2} \cdot A_{\text{stirrup}} = 78956.835$

$f_y = 555.56$

s = 250.00

Vs2 is multiplied by Col2 = 0.00

s/d = 1.04167

Vf ((11-3)-(11.4), ACI 440) = 308320.00

f = 0.95, for fully-wrapped sections

wf/sf = 1 (FRP strips adjacent to one another).

In (11.3) sin + cos is replaced with (cot + cota)sina which is more a generalised expression, where is the angle of the crack direction (see KANEPE).

This later relation, considered as a function Vf(,), is implemented for every different fiber orientation ai, as well as for 2 crack directions, = 45° and = -45° to take into consideration the cyclic seismic loading.

orientation 1: 1 = b1 + 90° = 90.00

Vf = Min(|Vf(45, 1)|, |Vf(-45,a1)|), with:

total thickness per orientation, tf1 = NL*t/NoDir = 1.00

dfv = d (figure 11.2, ACI 440) = 470.00

ffe ((11-5), ACI 440) = 328.00

Ef = 82000.00

fe = 0.004, from (11.6a), ACI 440

with fu = 0.009

From (11-11), ACI 440: Vs + Vf <= 479549.663

bw*d = *d*d/4 = 125663.706

End Of Calculation of Shear Capacity ratio for element: column JCC1 of floor 1
At local axis: 3

Start Of Calculation of Shear Capacity ratio for element: column JCC1 of floor 1
At Shear local axis: 2
(Bending local axis: 3)
Section Type: rcjcs

Constant Properties

Knowledge Factor, = 1.00

Mean strength values are used for both shear and moment calculations.

Consequently:

Jacket

New material of Primary Member: Concrete Strength, fc = fcm = 33.00

New material of Primary Member: Steel Strength, fs = fsm = 555.56

Concrete Elasticity, Ec = 26999.444

Steel Elasticity, Es = 200000.00

Existing Column

New material of Primary Member: Concrete Strength, fc = fcm = 33.00

New material of Primary Member: Steel Strength, fs = fsm = 555.56

Concrete Elasticity, Ec = 26999.444

Steel Elasticity, Es = 200000.00

#####

Note: Especially for the calculation of moment strengths,

the above steel re-bar strengths are multiplied by 1.25 according to R18.6.5, ACI 318-14

Jacket

New material: Steel Strength, fs = 1.25*fsm = 694.45

Existing Column

New material: Steel Strength, fs = 1.25*fsm = 694.45

#####

External Diameter, D = 500.00

Internal Diameter, D = 300.00

Cover Thickness, c = 25.00

Mean Confinement Factor overall section = 1.51481

Element Length, L = 3000.00

Primary Member

Ribbed Bars

Ductile Steel

Without Detailing for Earthquake Resistance (including stirrups not closed at 135°)

Longitudinal Bars With Ends Lapped Starting at the End Sections

Inadequate Lap Length with lo/lo,min = 0.30

FRP Wrapping Data

Type: Carbon

Dry properties (design values)

Thickness, $t = 1.00$

Tensile Strength, $f_{fu} = 840.00$

Tensile Modulus, $E_f = 82000.00$

Elongation, $\epsilon_{fu} = 0.009$

Number of directions, $N_{oDir} = 1$

Fiber orientations, $b_i = 0.00^\circ$

Number of layers, $N_L = 1$

Radius of rounding corners, $R = 40.00$

Stepwise Properties

At local axis: 2

EDGE -A-

Shear Force, $V_a = -2.1312935E-046$

EDGE -B-

Shear Force, $V_b = 2.1312935E-046$

BOTH EDGES

Axial Force, $F = -7389.214$

Longitudinal Reinforcement Area Distribution (in 2 divisions)

-Tension: $A_{sl,t} = 0.00$

-Compression: $A_{sl,c} = 3053.628$

Longitudinal Reinforcement Area Distribution (in 3 divisions)

-Tension: $A_{sl,ten} = 1017.876$

-Compression: $A_{sl,com} = 1017.876$

-Middle: $A_{sl,mid} = 1017.876$

Calculation of Shear Capacity ratio, $V_e/V_r = 0.23017425$

Member Controlled by Flexure ($V_e/V_r < 1$)

Calculation of Shear Demand from fig. R18.6.5, ACI 318-14 $V_e = (M_{pr1} + M_{pr2})/l_n = 162459.651$

with

$M_{pr1} = \text{Max}(M_{u1+}, M_{u1-}) = 2.4369E+008$

$M_{u1+} = 2.4369E+008$, is the ultimate moment strength at the edge 1 of the member in the actual moment direction which is defined for the static loading combination

$M_{u1-} = 2.4369E+008$, is the ultimate moment strength at the edge 1 of the member in the opposite moment direction which is defined for the static loading combination

$M_{pr2} = \text{Max}(M_{u2+}, M_{u2-}) = 2.4369E+008$

$M_{u2+} = 2.4369E+008$, is the ultimate moment strength at the edge 2 of the member in the actual moment direction which is defined for the static loading combination

$M_{u2-} = 2.4369E+008$, is the ultimate moment strength at the edge 2 of the member in the opposite moment direction which is defined for the static loading combination

Calculation of M_{u1+}

Calculation of ultimate Moment Strength ((3.67), Biskinis Phd), M_u

$M_u = 2.4369E+008$

$\lambda = 0.80285146$

$\lambda' = 0.71403327$

error of function (3.68), Biskinis Phd = 27987.158

From 5A.2, TBDY: $f_{cc} = f_c \cdot c = 49.98874$

conf. factor $c = 1.51481$

$f_c = 33.00$

From 10.3.5, ASCE 41-17, Final value of f_y : $f_y \cdot \text{Min}(1, 1.25 \cdot (l_b/l_d)^{2/3}) = 389.0139$

$l_b/l_d = 0.30$

$d_1 = 44.00$

$R = 250.00$

$v = 0.00100813$

$$N = 7389.214$$
$$Ac = 196349.541$$
$$= *Min(1,1.25*(lb/d)^{2/3}) = 0.1620683$$

Calculation of ratio lb/d

Inadequate Lap Length with lb/d = 0.30

Calculation of Mu1-

Calculation of ultimate Moment Strength ((3.67), Biskinis Phd), Mu
Mu = 2.4369E+008

$$= 0.80285146$$
$$' = 0.71403327$$

error of function (3.68), Biskinis Phd = 27987.158

From 5A.2, TBDY: fcc = fc* c = 49.98874

conf. factor c = 1.51481

fc = 33.00

From 10.3.5, ASCE 41-17, Final value of fy: fy*Min(1,1.25*(lb/d)^{2/3}) = 389.0139

lb/d = 0.30

d1 = 44.00

R = 250.00

v = 0.00100813

N = 7389.214

Ac = 196349.541

$$= *Min(1,1.25*(lb/d)^{2/3}) = 0.1620683$$

Calculation of ratio lb/d

Inadequate Lap Length with lb/d = 0.30

Calculation of Mu2+

Calculation of ultimate Moment Strength ((3.67), Biskinis Phd), Mu
Mu = 2.4369E+008

$$= 0.80285146$$
$$' = 0.71403327$$

error of function (3.68), Biskinis Phd = 27987.158

From 5A.2, TBDY: fcc = fc* c = 49.98874

conf. factor c = 1.51481

fc = 33.00

From 10.3.5, ASCE 41-17, Final value of fy: fy*Min(1,1.25*(lb/d)^{2/3}) = 389.0139

lb/d = 0.30

d1 = 44.00

R = 250.00

v = 0.00100813

N = 7389.214

Ac = 196349.541

$$= *Min(1,1.25*(lb/d)^{2/3}) = 0.1620683$$

Calculation of ratio lb/d

Inadequate Lap Length with lb/d = 0.30

Calculation of Mu2-

Calculation of ultimate Moment Strength ((3.67), Biskinis Phd), Mu
Mu = 2.4369E+008

$$= 0.80285146$$

$$' = 0.71403327$$

error of function (3.68), Biskinis Phd = 27987.158

From 5A.2, TBDY: $f_{cc} = f_c \cdot c = 49.98874$

conf. factor $c = 1.51481$

$f_c = 33.00$

From 10.3.5, ASCE 41-17, Final value of fy: $f_y \cdot \text{Min}(1, 1.25 \cdot (l_b/d)^{2/3}) = 389.0139$

$l_b/d = 0.30$

$d_1 = 44.00$

$R = 250.00$

$v = 0.00100813$

$N = 7389.214$

$A_c = 196349.541$

$= \cdot \text{Min}(1, 1.25 \cdot (l_b/d)^{2/3}) = 0.1620683$

Calculation of ratio l_b/d

Inadequate Lap Length with $l_b/d = 0.30$

Calculation of Shear Strength $V_r = \text{Min}(V_{r1}, V_{r2}) = 705811.584$

Calculation of Shear Strength at edge 1, $V_{r1} = 705811.584$

$V_{r1} = V_{Col}$ ((10.3), ASCE 41-17) = $k_{nl} \cdot V_{Col0}$

$V_{Col0} = 705811.584$

$k_{nl} = 1$ (zero step-static loading)

NOTE: In expression (10-3) ' $V_s = A_v \cdot f_y \cdot d/s$ ' is replaced by ' $V_s + f \cdot V_f$ ' where V_f is the contribution of FRPs (11.3), ACI 440).

$= 1$ (normal-weight concrete)

Mean concrete strength: $f_c' = (f_c'_{jacket} \cdot \text{Area}_{jacket} + f_c'_{core} \cdot \text{Area}_{core}) / \text{Area}_{section} = 33.00$, but $f_c'^{0.5} \leq 8.3$ MPa (22.5.3.1, ACI 318-14)

$M/Vd = 2.00$

$Mu = 1.5940012E-011$

$Vu = 2.1312935E-046$

$d = 0.8 \cdot D = 400.00$

$Nu = 7389.214$

$Ag = 196349.541$

From (11.5.4.8), ACI 318-14: $V_s = V_{s1} + V_{s2} = 274157.871$

$V_{s1} = 274157.871$ is calculated for jacket, with:

$A_v = \sqrt{2} \cdot A_{stirup} = 123370.055$

$f_y = 555.56$

$s = 100.00$

V_{s1} is multiplied by $Col1 = 1.00$

$s/d = 0.25$

$V_{s2} = 0.00$ is calculated for core, with:

$A_v = \sqrt{2} \cdot A_{stirup} = 78956.835$

$f_y = 555.56$

$s = 250.00$

V_{s2} is multiplied by $Col2 = 0.00$

$s/d = 1.04167$

V_f ((11-3)-(11.4), ACI 440) = 308320.00

$f = 0.95$, for fully-wrapped sections

$w_f/s_f = 1$ (FRP strips adjacent to one another).

In (11.3) $\sin \theta + \cos \theta$ is replaced with $(\cot \theta + \csc \theta) \sin \alpha$ which is more a generalised expression, where θ is the angle of the crack direction (see KANEPE). This later relation, considered as a function $V_f(\theta, \alpha)$, is implemented for every different fiber orientation α_i , as well as for 2 crack directions, $\theta = 45^\circ$ and $\theta = -45^\circ$ to take into consideration the cyclic seismic loading.

orientation 1: $\theta = 45^\circ + 90^\circ = 135^\circ$
 $V_f = \text{Min}(|V_f(45, \theta)|, |V_f(-45, \alpha)|)$, with:
total thickness per orientation, $t_{f1} = NL \cdot t / \text{NoDir} = 1.00$
 $d_{fv} = d$ (figure 11.2, ACI 440) = 470.00
 f_{fe} ((11-5), ACI 440) = 328.00
 $E_f = 82000.00$
 $f_e = 0.004$, from (11.6a), ACI 440
with $f_u = 0.009$
From (11-11), ACI 440: $V_s + V_f \leq 479549.663$
 $b_w \cdot d = \sqrt{V_s \cdot d} / 4 = 125663.706$

Calculation of Shear Strength at edge 2, $V_{r2} = 705811.584$
 $V_{r2} = V_{Col}$ ((10.3), ASCE 41-17) = $k_{nl} \cdot V_{Col0}$
 $V_{Col0} = 705811.584$
 $k_{nl} = 1$ (zero step-static loading)

NOTE: In expression (10-3) ' $V_s = A_v \cdot f_y \cdot d / s$ ' is replaced by ' $V_s + f \cdot V_f$ ' where V_f is the contribution of FRPs (11.3), ACI 440).

$k_{nl} = 1$ (normal-weight concrete)
Mean concrete strength: $f'_c = (f'_{c,jacket} \cdot \text{Area}_{jacket} + f'_{c,core} \cdot \text{Area}_{core}) / \text{Area}_{section} = 33.00$, but $f'_c^{0.5} \leq 8.3$ MPa (22.5.3.1, ACI 318-14)
 $M/Vd = 2.00$
 $\mu_u = 1.5940012E-011$
 $\nu_u = 2.1312935E-046$
 $d = 0.8 \cdot D = 400.00$
 $N_u = 7389.214$
 $A_g = 196349.541$
From (11.5.4.8), ACI 318-14: $V_s = V_{s1} + V_{s2} = 274157.871$
 $V_{s1} = 274157.871$ is calculated for jacket, with:
 $A_v = \sqrt{2} \cdot A_{stirrup} = 123370.055$
 $f_y = 555.56$
 $s = 100.00$
 V_{s1} is multiplied by $\text{Col1} = 1.00$
 $s/d = 0.25$
 $V_{s2} = 0.00$ is calculated for core, with:
 $A_v = \sqrt{2} \cdot A_{stirrup} = 78956.835$
 $f_y = 555.56$
 $s = 250.00$
 V_{s2} is multiplied by $\text{Col2} = 0.00$
 $s/d = 1.04167$
 V_f ((11-3)-(11.4), ACI 440) = 308320.00
 $f = 0.95$, for fully-wrapped sections
 $w_f / s_f = 1$ (FRP strips adjacent to one another).
In (11.3) $\sin \theta + \cos \theta$ is replaced with $(\cot \theta + \csc \theta) \sin \alpha$ which is more a generalised expression, where θ is the angle of the crack direction (see KANEPE). This later relation, considered as a function $V_f(\theta, \alpha)$, is implemented for every different fiber orientation α_i , as well as for 2 crack directions, $\theta = 45^\circ$ and $\theta = -45^\circ$ to take into consideration the cyclic seismic loading.

orientation 1: $\theta = 45^\circ + 90^\circ = 135^\circ$
 $V_f = \text{Min}(|V_f(45, \theta)|, |V_f(-45, \alpha)|)$, with:
total thickness per orientation, $t_{f1} = NL \cdot t / \text{NoDir} = 1.00$
 $d_{fv} = d$ (figure 11.2, ACI 440) = 470.00
 f_{fe} ((11-5), ACI 440) = 328.00
 $E_f = 82000.00$
 $f_e = 0.004$, from (11.6a), ACI 440
with $f_u = 0.009$
From (11-11), ACI 440: $V_s + V_f \leq 479549.663$
 $b_w \cdot d = \sqrt{V_s \cdot d} / 4 = 125663.706$

End Of Calculation of Shear Capacity ratio for element: column JCC1 of floor 1
At local axis: 2

Start Of Calculation of Chord Rotation Capacity for element: column JCC1 of floor 1

At local axis: 3

Integration Section: (a)

Section Type: rcjcs

Constant Properties

Knowledge Factor, $\gamma = 1.00$

Chord Rotation is generally considered as Deformation-Controlled Action according to Table C7-1, ASCE 41-17.

Mean strengths are used for Deformation-Controlled Actions according to 7.5.1.3, ASCE 41-17

Consequently:

Jacket

New material of Primary Member: Concrete Strength, $f_c = f_{cm} = 33.00$

New material of Primary Member: Steel Strength, $f_s = f_{sm} = 555.56$

Concrete Elasticity, $E_c = 26999.444$

Steel Elasticity, $E_s = 200000.00$

Existing Column

New material of Primary Member: Concrete Strength, $f_c = f_{cm} = 33.00$

New material of Primary Member: Steel Strength, $f_s = f_{sm} = 555.56$

Concrete Elasticity, $E_c = 26999.444$

Steel Elasticity, $E_s = 200000.00$

External Diameter, $D = 500.00$

Internal Diameter, $D = 300.00$

Cover Thickness, $c = 25.00$

Element Length, $L = 3000.00$

Primary Member

Ribbed Bars

Ductile Steel

Without Detailing for Earthquake Resistance (including stirrups not closed at 135°)

Longitudinal Bars With Ends Lapped Starting at the End Sections

Inadequate Lap Length with $l_b/l_d = 0.30$

FRP Wrapping Data

Type: Carbon

Dry properties (design values)

Thickness, $t = 1.00$

Tensile Strength, $f_{fu} = 840.00$

Tensile Modulus, $E_f = 82000.00$

Elongation, $e_{fu} = 0.009$

Number of directions, $N_{oDir} = 1$

Fiber orientations, $b_i = 0.00^\circ$

Number of layers, $N_L = 1$

Radius of rounding corners, $R = 40.00$

Stepwise Properties

Bending Moment, $M = -1.4341E+007$

Shear Force, $V_2 = -4779.203$

Shear Force, $V_3 = -2.1566928E-013$

Axial Force, $F = -7387.302$

Longitudinal Reinforcement Area Distribution (in 2 divisions)

-Tension: $A_{sl,t} = 0.00$

-Compression: $A_{sl,c} = 3053.628$

Longitudinal Reinforcement Area Distribution (in 3 divisions)

-Tension: $A_{sl,ten} = 1017.876$

-Compression: $A_{sl,com} = 1017.876$

-Middle: $A_{sl,mid} = 1017.876$

Mean Diameter of Tension Reinforcement, $DbL = 18.00$

New component: From table 7-7, ASCE 41_17: Final chord rotation Capacity $\mu_{,R} = 1.0^*$ $\mu = 0.00906346$

$$u = y + p = 0.00906346$$

- Calculation of y -

$$y = (M_y \cdot L_s / 3) / E_{\text{eff}} = 0.00906346 \text{ ((4.29), Biskinis Phd)}$$

$$M_y = 2.2517E+008$$

$$L_s = M/V \text{ (with } L_s > 0.1 \cdot L \text{ and } L_s < 2 \cdot L) = 3000.736$$

$$\text{From table 10.5, ASCE 41-17: } E_{\text{eff}} = \text{factor} \cdot E_c \cdot I_g = 2.4850E+013$$

$$\text{factor} = 0.30$$

$$A_g = 196349.541$$

$$\text{Mean concrete strength: } f_c' = (f_c'_{\text{jacket}} \cdot \text{Area}_{\text{jacket}} + f_c'_{\text{core}} \cdot \text{Area}_{\text{core}}) / \text{Area}_{\text{section}} = 33.00$$

$$N = 7387.302$$

$$E_c \cdot I_g = E_{c_{\text{jacket}}} \cdot I_{g_{\text{jacket}}} + E_{c_{\text{core}}} \cdot I_{g_{\text{core}}} = 8.2833E+013$$

Calculation of Yielding Moment M_y

Calculation of y and M_y according to (7) - (8) in Biskinis and Fardis

$$M_y = \text{Min}(M_{y_{\text{ten}}}, M_{y_{\text{com}}}) = 2.2517E+008$$

$$y = 6.4424840E-006$$

$$M_{y_{\text{ten}}} \text{ (8c)} = 2.2517E+008$$

$$y_{\text{ten}} \text{ (7c)} = 61.8137$$

$$\text{error of function (7c)} = 0.00026387$$

$$M_{y_{\text{com}}} \text{ (8d)} = 8.1922E+008$$

$$y_{\text{com}} \text{ (7d)} = 63.67468$$

$$\text{error of function (7d)} = -0.0087488$$

$$\text{with ((10.1), ASCE 41-17) } e_y = \text{Min}(e_y, 1.25 \cdot e_y \cdot (l_b / l_d)^{2/3}) = 0.0027778$$

$$e_{c0} = 0.002$$

$$a_{pl} = 0.45 \text{ ((9c) in Biskinis and Fardis for FRP Wrap)}$$

$$d_1 = 44.00$$

$$R = 250.00$$

$$v = 0.00101374$$

$$N = 7387.302$$

$$A_c = 196349.541$$

$$\text{((10.1), ASCE 41-17) } = \text{Min}(, 1.25 \cdot (l_b / l_d)^{2/3}) = 0.23280363$$

$$\text{with } f_c' \text{ ((12.3), ACI 440)} = 37.11312$$

$$f_c = 33.00$$

$$f_l = 1.312$$

$$k = 1$$

$$\text{Effective FRP thickness, } t_f = N \cdot l \cdot \text{Cos}(b_1) = 1.00$$

$$e_{fe} \text{ ((12.5) and (12.7))} = 0.004$$

$$f_u = 0.009$$

$$E_f = 82000.00$$

Calculation of ratio l_b / l_d

Inadequate Lap Length with $l_b / l_d = 0.30$

- Calculation of p -

From table 10-9: $p = 0.00$

with:

- Columns controlled by inadequate development or splicing along the clear height because $l_b / l_d < 1$

$$\text{shear control ratio } V_y E / V_c O_e = 0.23017425$$

$$d = d_{\text{external}} = 0.00$$

$$s = s_{\text{external}} = 0.00$$

$$t = s_1 + s_2 + 2 \cdot t_f / b_w \cdot (f_{fe} / f_s) = 0.00795744$$

$$\text{jacket: } s_1 = A_{v1} \cdot (D_{c1} / 2) / (s_1 \cdot A_g) = 0.0027646$$

$$A_{v1} = 78.53982, \text{ is the area of stirrup}$$

$D_{c1} = D_{\text{ext}} - 2 \cdot \text{cover} - \text{External Hoop Diameter} = 440.00$, is the total Length of all stirrups parallel to loading (shear) direction

$$s1 = 100.00$$

$$\text{core: } s2 = Av2 * (\pi * Dc2 / 2) / (s2 * Ag) = 0.00046968$$

Av2 = 50.26548, is the area of stirrup

Dc2 = Dint - Internal Hoop Diameter = 292.00, is the total Length of all stirrups parallel to loading (shear)

direction

$$s2 = 250.00$$

The term $2 * t_f / b_w * (f_{fe} / f_s)$ is implemented to account for FRP contribution

where $f = 2 * t_f / b_w$ is FRP ratio (EC8 - 3, A.4.4.3(6)) and f_{fe} / f_s normalises f to steel strength

All these variables have already been given in Shear control ratio calculation.

For the normalisation f_s of jacket is used.

$$NUD = 7387.302$$

$$Ag = 196349.541$$

$$f_{cE} = (f_{c_jacket} * Area_jacket + f_{c_core} * Area_core) / section_area = 33.00$$

$$f_{yIE} = (f_{y_ext_Long_Reinf} * Area_ext_Long_Reinf + f_{y_int_Long_Reinf} * Area_int_Long_Reinf) / Area_Tot_Long_Rein = 2.1219958E-314$$

$$f_{yTE} = (f_{y_ext_Trans_Reinf} * Area_ext_Trans_Reinf + f_{y_int_Trans_Reinf} * Area_int_Trans_Reinf) / Area_Tot_Trans_Rein = 555.56$$

$$\rho_l = Area_Tot_Long_Rein / (Ag) = 0.015552$$

$$f_{cE} = 33.00$$

End Of Calculation of Chord Rotation Capacity for element: column JCC1 of floor 1

At local axis: 3

Integration Section: (a)

Calculation No. 5

column C1, Floor 1


Limit State: Immediate Occupancy (data interpolation between analysis steps 1 and 2)

Analysis: Uniform +X

Check: Shear capacity V_{Rd}

Edge: End

Local Axis: (2)



Start Of Calculation of Shear Capacity for element: column JCC1 of floor 1

At local axis: 2

Integration Section: (b)

Section Type: rcjcs

Constant Properties

Knowledge Factor, $\gamma = 1.00$

Member Shear Force is generally considered as Force-Controlled Action according to Table C7-1, ASCE 41-17.

Lower-bound strengths are used for Force-Controlled Actions according to 7.5.1.3, ASCE 41-17

Consequently:

Jacket

New material of Primary Member: Concrete Strength, $f_c = f_{c_lower_bound} = 25.00$

New material of Primary Member: Steel Strength, $f_s = f_{s_lower_bound} = 500.00$

Concrete Elasticity, $E_c = 26999.444$

Steel Elasticity, $E_s = 200000.00$

Existing Column

New material of Primary Member: Concrete Strength, $f_c = f_{c_lower_bound} = 25.00$

New material of Primary Member: Steel Strength, $f_s = f_{s_lower_bound} = 500.00$

Concrete Elasticity, $E_c = 26999.444$

Steel Elasticity, $E_s = 200000.00$

#####

Note: Especially for the calculation of γ for displacement ductility demand, the expected (mean value) strengths are used (7.5.1.3, ASCE 41-17) because bending is considered as Deformation-Controlled Action (Table C7-1, ASCE 41-17).

Jacket

New material: Concrete Strength, $f_c = f_{cm} = 33.00$

New material: Steel Strength, $f_s = f_{sm} = 555.56$

Existing Column

New material: Concrete Strength, $f_c = f_{cm} = 33.00$

New material: Steel Strength, $f_s = f_{sm} = 555.56$

#####

External Diameter, $D = 500.00$

Internal Diameter, $D = 300.00$

Cover Thickness, $c = 25.00$

Element Length, $L = 3000.00$

Primary Member

Ribbed Bars

Ductile Steel

Without Detailing for Earthquake Resistance (including stirrups not closed at 135°)

Longitudinal Bars With Ends Lapped Starting at the End Sections

Inadequate Lap Length with $l_o/l_{ou,min} = l_b/l_d = 0.30$

FRP Wrapping Data

Type: Carbon

Dry properties (design values)

Thickness, $t = 1.00$

Tensile Strength, $f_{fu} = 840.00$

Tensile Modulus, $E_f = 82000.00$

Elongation, $e_{fu} = 0.009$

Number of directions, $NoDir = 1$

Fiber orientations, $bi = 0.00^\circ$

Number of layers, $NL = 1$

Radius of rounding corners, $R = 40.00$

Stepwise Properties

EDGE -A-

Bending Moment, $M_a = -1.4341E+007$

Shear Force, $V_a = -4779.203$

EDGE -B-

Bending Moment, $M_b = 0.07981876$

Shear Force, $V_b = 4779.203$

BOTH EDGES

Axial Force, $F = -7387.302$

Longitudinal Reinforcement Area Distribution (in 2 divisions)

-Tension: $As_t = 0.00$

-Compression: $As_c = 3053.628$

Longitudinal Reinforcement Area Distribution (in 3 divisions)

-Tension: $As_{l,ten} = 1017.876$

-Compression: $A_{sl,com} = 1017.876$

-Middle: $A_{sl,mid} = 1017.876$

Mean Diameter of Tension Reinforcement, $Db_{L,ten} = 18.00$

New component: From table 7-7, ASCE 41_17: Final Shear Capacity $V_R = 1.0 \cdot V_n = 614519.957$

V_n ((10.3), ASCE 41-17) = $k_n \cdot V_{CoI0} = 614519.957$

$V_{CoI} = 614519.957$

$k_n = 1.00$

$displacement_ductility_demand = 0.09552499$

NOTE: In expression (10-3) ' $V_s = A_v \cdot f_y \cdot d / s$ ' is replaced by ' $V_s + f \cdot V_f$ ' where V_f is the contribution of FRPs (11.3), ACI 440).

= 1 (normal-weight concrete)

Mean concrete strength: $f_c' = (f_c'_{jacket} \cdot Area_{jacket} + f_c'_{core} \cdot Area_{core}) / Area_{section} = 25.00$, but $f_c'^{0.5} \leq 8.3$ MPa (22.5.3.1, ACI 318-14)

$M/Vd = 2.00$

$\mu_u = 0.07981876$

$V_u = 4779.203$

$d = 0.8 \cdot D = 400.00$

$N_u = 7387.302$

$A_g = 196349.541$

From (11.5.4.8), ACI 318-14: $V_s = V_{s1} + V_{s2} = 246740.11$

$V_{s1} = 246740.11$ is calculated for jacket, with:

$A_v = \rho_s \cdot A_{stirrup} = 123370.055$

$f_y = 500.00$

$s = 100.00$

V_{s1} is multiplied by $Col1 = 1.00$

$s/d = 0.25$

$V_{s2} = 0.00$ is calculated for core, with:

$A_v = \rho_s \cdot A_{stirrup} = 78956.835$

$f_y = 500.00$

$s = 250.00$

V_{s2} is multiplied by $Col2 = 0.00$

$s/d = 1.04167$

V_f ((11-3)-(11.4), ACI 440) = 308320.00

$f = 0.95$, for fully-wrapped sections

$w_f/s_f = 1$ (FRP strips adjacent to one another).

In (11.3) $\sin \theta + \cos \theta$ is replaced with $(\cot \theta + \csc \theta) \sin \alpha$ which is more a generalised expression, where θ is the angle of the crack direction (see KANEPE).

This later relation, considered as a function $V_f(\theta, \alpha)$, is implemented for every different fiber orientation α_i , as well as for 2 crack directions, $\theta = 45^\circ$ and $\theta = -45^\circ$ to take into consideration the cyclic seismic loading.

orientation 1: $\theta = 45^\circ + 90^\circ = 90.00$

$V_f = \text{Min}(|V_f(45, \theta)|, |V_f(-45, \theta)|)$, with:

total thickness per orientation, $t_{f1} = N_L \cdot t / N_{Dir} = 1.00$

$d_{fv} = d$ (figure 11.2, ACI 440) = 470.00

f_{fe} ((11-5), ACI 440) = 328.00

$E_f = 82000.00$

$f_e = 0.004$, from (11.6a), ACI 440

with $f_u = 0.009$

From (11-11), ACI 440: $V_s + V_f \leq 417394.406$

$b_w \cdot d = \rho_s \cdot d^2 / 4 = 125663.706$

$displacement_ductility_demand$ is calculated as θ / y

- Calculation of θ / y for END B -

for rotation axis 3 and integ. section (b)

From analysis, chord rotation $\theta = 8.6557465E-005$

$y = (M_y \cdot L_s / 3) / E_{eff} = 0.00090612$ ((4.29), Biskinis Phd)

$M_y = 2.2517E+008$

$L_s = M/V$ (with $L_s > 0.1 \cdot L$ and $L_s < 2 \cdot L$) = 300.00

From table 10.5, ASCE 41_17: $E_{eff} = factor * E_c * I_g = 2.4850E+013$

factor = 0.30

$A_g = 196349.541$

Mean concrete strength: $f_c' = (f_c'_{jacket} * Area_{jacket} + f_c'_{core} * Area_{core}) / Area_{section} = 33.00$

$N = 7387.302$

$E_c * I_g = E_c_{jacket} * I_g_{jacket} + E_c_{core} * I_g_{core} = 8.2833E+013$

Calculation of Yielding Moment M_y

Calculation of ρ_y and M_y according to (7) - (8) in Biskinis and Fardis

$M_y = \text{Min}(M_{y_ten}, M_{y_com}) = 2.2517E+008$

$\rho_y = 6.4424840E-006$

$M_{y_ten} (8c) = 2.2517E+008$

$\rho_{y_ten} (7c) = 61.8137$

error of function (7c) = 0.00026387

$M_{y_com} (8d) = 8.1922E+008$

$\rho_{y_com} (7d) = 63.67468$

error of function (7d) = -0.0087488

with ((10.1), ASCE 41-17) $\rho_{ey} = \text{Min}(\rho_y, 1.25 * \rho_y * (I_b / I_d)^{2/3}) = 0.0027778$

$\rho_{eco} = 0.002$

$\rho_{apl} = 0.45$ ((9c) in Biskinis and Fardis for FRP Wrap)

$d_1 = 44.00$

$R = 250.00$

$v = 0.00101374$

$N = 7387.302$

$A_c = 196349.541$

with ((10.1), ASCE 41-17) $\rho_{ey} = \text{Min}(\rho_y, 1.25 * \rho_y * (I_b / I_d)^{2/3}) = 0.23280363$

with $f_c' ((12.3), ACI 440) = 37.11312$

$f_c = 33.00$

$f_l = 1.312$

$k = 1$

Effective FRP thickness, $t_f = NL * t * \text{Cos}(b_1) = 1.00$

$\rho_{efe} ((12.5) \text{ and } (12.7)) = 0.004$

$f_u = 0.009$

$E_f = 82000.00$

Calculation of ratio I_b / I_d

Inadequate Lap Length with $I_b / I_d = 0.30$

End Of Calculation of Shear Capacity for element: column JCC1 of floor 1

At local axis: 2

Integration Section: (b)

Calculation No. 6

column C1, Floor 1


Limit State: Immediate Occupancy (data interpolation between analysis steps 1 and 2)

Analysis: Uniform +X

Check: Chord rotation capacity (θ_r)

Edge: End

Local Axis: (2)



Start Of Calculation of Shear Capacity ratio for element: column JCC1 of floor 1

At Shear local axis: 3

(Bending local axis: 2)

Section Type: rcjcs

Constant Properties

Knowledge Factor, $\gamma = 1.00$

Mean strength values are used for both shear and moment calculations.

Consequently:

Jacket

New material of Primary Member: Concrete Strength, $f_c = f_{cm} = 33.00$

New material of Primary Member: Steel Strength, $f_s = f_{sm} = 555.56$

Concrete Elasticity, $E_c = 26999.444$

Steel Elasticity, $E_s = 200000.00$

Existing Column

New material of Primary Member: Concrete Strength, $f_c = f_{cm} = 33.00$

New material of Primary Member: Steel Strength, $f_s = f_{sm} = 555.56$

Concrete Elasticity, $E_c = 26999.444$

Steel Elasticity, $E_s = 200000.00$

#####

Note: Especially for the calculation of moment strengths,

the above steel re-bar strengths are multiplied by 1.25 according to R18.6.5, ACI 318-14

Jacket

New material: Steel Strength, $f_s = 1.25 \cdot f_{sm} = 694.45$

Existing Column

New material: Steel Strength, $f_s = 1.25 \cdot f_{sm} = 694.45$

#####

External Diameter, $D = 500.00$

Internal Diameter, $D = 300.00$

Cover Thickness, $c = 25.00$

Mean Confinement Factor overall section = 1.51481

Element Length, $L = 3000.00$

Primary Member

Ribbed Bars

Ductile Steel

Without Detailing for Earthquake Resistance (including stirrups not closed at 135°)

Longitudinal Bars With Ends Lapped Starting at the End Sections

Inadequate Lap Length with $l_o/l_{ou, \min} = 0.30$

FRP Wrapping Data

Type: Carbon

Dry properties (design values)

Thickness, $t = 1.00$

Tensile Strength, $f_{fu} = 840.00$

Tensile Modulus, $E_f = 82000.00$

Elongation, $\epsilon_{fu} = 0.009$

Number of directions, $N_{oDir} = 1$

Fiber orientations, $b_i = 0.00^\circ$

Number of layers, $N_L = 1$

Radius of rounding corners, $R = 40.00$

Stepwise Properties

At local axis: 3

EDGE -A-

Shear Force, $V_a = 3.4807814E-030$

EDGE -B-

Shear Force, $V_b = -3.4807814E-030$

BOTH EDGES

Axial Force, $F = -7389.214$

Longitudinal Reinforcement Area Distribution (in 2 divisions)

-Tension: $A_{sl,t} = 0.00$

-Compression: $A_{sl,c} = 3053.628$

Longitudinal Reinforcement Area Distribution (in 3 divisions)

-Tension: $A_{sl,ten} = 1017.876$

-Compression: $A_{sl,com} = 1017.876$

-Middle: $A_{sl,mid} = 1017.876$

Calculation of Shear Capacity ratio, $V_e/V_r = 0.23017425$

Member Controlled by Flexure ($V_e/V_r < 1$)

Calculation of Shear Demand from fig. R18.6.5, ACI 318-14 $V_e = (M_{pr1} + M_{pr2})/l_n = 162459.651$

with

$M_{pr1} = \text{Max}(M_{u1+}, M_{u1-}) = 2.4369E+008$

$M_{u1+} = 2.4369E+008$, is the ultimate moment strength at the edge 1 of the member in the actual moment direction which is defined for the static loading combination

$M_{u1-} = 2.4369E+008$, is the ultimate moment strength at the edge 1 of the member in the opposite moment direction which is defined for the static loading combination

$M_{pr2} = \text{Max}(M_{u2+}, M_{u2-}) = 2.4369E+008$

$M_{u2+} = 2.4369E+008$, is the ultimate moment strength at the edge 2 of the member in the actual moment direction which is defined for the static loading combination

$M_{u2-} = 2.4369E+008$, is the ultimate moment strength at the edge 2 of the member in the opposite moment direction which is defined for the static loading combination

Calculation of M_{u1+}

Calculation of ultimate Moment Strength ((3.67), Biskinis Phd), M_u

$M_u = 2.4369E+008$

$\lambda = 0.80285146$

$\lambda' = 0.71403327$

error of function (3.68), Biskinis Phd = 27987.158

From 5A.2, TBDY: $f_{cc} = f_c \cdot c = 49.98874$

conf. factor $c = 1.51481$

$f_c = 33.00$

From 10.3.5, ASCE 41-17, Final value of f_y : $f_y \cdot \text{Min}(1, 1.25 \cdot (l_b/d)^{2/3}) = 389.0139$

$l_b/d = 0.30$

$d_1 = 44.00$

$R = 250.00$

$v = 0.00100813$

$$N = 7389.214$$
$$Ac = 196349.541$$
$$= *Min(1,1.25*(lb/d)^{2/3}) = 0.1620683$$

Calculation of ratio lb/d

Inadequate Lap Length with lb/d = 0.30

Calculation of Mu1-

Calculation of ultimate Moment Strength ((3.67), Biskinis Phd), Mu
Mu = 2.4369E+008

$$= 0.80285146$$
$$' = 0.71403327$$

error of function (3.68), Biskinis Phd = 27987.158

From 5A.2, TBDY: fcc = fc* c = 49.98874

conf. factor c = 1.51481

fc = 33.00

From 10.3.5, ASCE 41-17, Final value of fy: fy*Min(1,1.25*(lb/d)^{2/3}) = 389.0139

lb/d = 0.30

d1 = 44.00

R = 250.00

v = 0.00100813

N = 7389.214

Ac = 196349.541

$$= *Min(1,1.25*(lb/d)^{2/3}) = 0.1620683$$

Calculation of ratio lb/d

Inadequate Lap Length with lb/d = 0.30

Calculation of Mu2+

Calculation of ultimate Moment Strength ((3.67), Biskinis Phd), Mu
Mu = 2.4369E+008

$$= 0.80285146$$
$$' = 0.71403327$$

error of function (3.68), Biskinis Phd = 27987.158

From 5A.2, TBDY: fcc = fc* c = 49.98874

conf. factor c = 1.51481

fc = 33.00

From 10.3.5, ASCE 41-17, Final value of fy: fy*Min(1,1.25*(lb/d)^{2/3}) = 389.0139

lb/d = 0.30

d1 = 44.00

R = 250.00

v = 0.00100813

N = 7389.214

Ac = 196349.541

$$= *Min(1,1.25*(lb/d)^{2/3}) = 0.1620683$$

Calculation of ratio lb/d

Inadequate Lap Length with lb/d = 0.30

Calculation of Mu2-

Calculation of ultimate Moment Strength ((3.67), Biskinis Phd), Mu
Mu = 2.4369E+008

$$= 0.80285146$$

$$' = 0.71403327$$

error of function (3.68), Biskinis Phd = 27987.158

From 5A.2, TBDY: $f_{cc} = f_c' \cdot c = 49.98874$

conf. factor $c = 1.51481$

$f_c = 33.00$

From 10.3.5, ASCE 41-17, Final value of fy: $f_y \cdot \text{Min}(1, 1.25 \cdot (l_b/d)^{2/3}) = 389.0139$

$l_b/d = 0.30$

$d_1 = 44.00$

$R = 250.00$

$v = 0.00100813$

$N = 7389.214$

$A_c = 196349.541$

$= \cdot \text{Min}(1, 1.25 \cdot (l_b/d)^{2/3}) = 0.1620683$

Calculation of ratio l_b/d

Inadequate Lap Length with $l_b/d = 0.30$

Calculation of Shear Strength $V_r = \text{Min}(V_{r1}, V_{r2}) = 705811.584$

Calculation of Shear Strength at edge 1, $V_{r1} = 705811.584$

$V_{r1} = V_{Col} \text{ ((10.3), ASCE 41-17)} = k_{nl} \cdot V_{Col0}$

$V_{Col0} = 705811.584$

$k_{nl} = 1$ (zero step-static loading)

NOTE: In expression (10-3) ' $V_s = A_v \cdot f_y \cdot d/s$ ' is replaced by ' $V_s + f \cdot V_f$ ' where V_f is the contribution of FRPs (11.3), ACI 440).

$= 1$ (normal-weight concrete)

Mean concrete strength: $f_c' = (f_c'_{jacket} \cdot \text{Area}_{jacket} + f_c'_{core} \cdot \text{Area}_{core}) / \text{Area}_{section} = 33.00$, but $f_c'^{0.5} \leq 8.3$ MPa (22.5.3.1, ACI 318-14)

$M/Vd = 2.00$

$\mu_u = 1.2438899E-011$

$\nu_u = 3.4807814E-030$

$d = 0.8 \cdot D = 400.00$

$N_u = 7389.214$

$A_g = 196349.541$

From (11.5.4.8), ACI 318-14: $V_s = V_{s1} + V_{s2} = 274157.871$

$V_{s1} = 274157.871$ is calculated for jacket, with:

$A_v = \sqrt{2} \cdot A_{stirup} = 123370.055$

$f_y = 555.56$

$s = 100.00$

V_{s1} is multiplied by $\phi_{col1} = 1.00$

$s/d = 0.25$

$V_{s2} = 0.00$ is calculated for core, with:

$A_v = \sqrt{2} \cdot A_{stirup} = 78956.835$

$f_y = 555.56$

$s = 250.00$

V_{s2} is multiplied by $\phi_{col2} = 0.00$

$s/d = 1.04167$

$V_f \text{ ((11-3)-(11.4), ACI 440)} = 308320.00$

$f = 0.95$, for fully-wrapped sections

$w_f/s_f = 1$ (FRP strips adjacent to one another).

In (11.3) $\sin \theta + \cos \theta$ is replaced with $(\cot \theta + \csc \theta) \sin \alpha$ which is more a generalised expression, where θ is the angle of the crack direction (see KANEPE). This later relation, considered as a function $V_f(\theta, \alpha)$, is implemented for every different fiber orientation α_i , as well as for 2 crack directions, $\theta = 45^\circ$ and $\theta = -45^\circ$ to take into consideration the cyclic seismic loading.

orientation 1: $\theta = 45^\circ + 90^\circ = 135^\circ$
 $V_f = \text{Min}(|V_f(45, \alpha)|, |V_f(-45, \alpha)|)$, with:
total thickness per orientation, $t_{f1} = N_L \cdot t / N_{\text{Dir}} = 1.00$
 $d_{fv} = d$ (figure 11.2, ACI 440) = 470.00
 f_{fe} ((11-5), ACI 440) = 328.00
 $E_f = 82000.00$
 $f_e = 0.004$, from (11.6a), ACI 440
with $f_u = 0.009$
From (11-11), ACI 440: $V_s + V_f \leq 479549.663$
 $b_w \cdot d = \frac{V_s \cdot d}{4} = 125663.706$

Calculation of Shear Strength at edge 2, $V_{r2} = 705811.584$
 $V_{r2} = V_{Col}$ ((10.3), ASCE 41-17) = $k_{nl} \cdot V_{Col0}$
 $V_{Col0} = 705811.584$
 $k_{nl} = 1$ (zero step-static loading)

NOTE: In expression (10-3) ' $V_s = A_v \cdot f_y \cdot d / s$ ' is replaced by ' $V_s + f \cdot V_f$ ' where V_f is the contribution of FRPs (11.3), ACI 440).

$k_{nl} = 1$ (normal-weight concrete)
Mean concrete strength: $f'_c = (f'_c \cdot \text{Area}_{\text{jacket}} + f'_c \cdot \text{Area}_{\text{core}}) / \text{Area}_{\text{section}} = 33.00$, but $f'_c^{0.5} \leq 8.3$ MPa (22.5.3.1, ACI 318-14)
 $M/Vd = 2.00$
 $\mu_u = 1.2438899E-011$
 $V_u = 3.4807814E-030$
 $d = 0.8 \cdot D = 400.00$
 $N_u = 7389.214$
 $A_g = 196349.541$
From (11.5.4.8), ACI 318-14: $V_s = V_{s1} + V_{s2} = 274157.871$
 $V_{s1} = 274157.871$ is calculated for jacket, with:
 $A_v = \frac{V_{s1}}{f_y} = 123370.055$
 $f_y = 555.56$
 $s = 100.00$
 V_{s1} is multiplied by $\text{Col1} = 1.00$
 $s/d = 0.25$
 $V_{s2} = 0.00$ is calculated for core, with:
 $A_v = \frac{V_{s2}}{f_y} = 78956.835$
 $f_y = 555.56$
 $s = 250.00$
 V_{s2} is multiplied by $\text{Col2} = 0.00$
 $s/d = 1.04167$
 V_f ((11-3)-(11.4), ACI 440) = 308320.00
 $f = 0.95$, for fully-wrapped sections
 $w_f / s_f = 1$ (FRP strips adjacent to one another).
In (11.3) $\sin \theta + \cos \theta$ is replaced with $(\cot \theta + \csc \theta) \sin \alpha$ which is more a generalised expression, where θ is the angle of the crack direction (see KANEPE). This later relation, considered as a function $V_f(\theta, \alpha)$, is implemented for every different fiber orientation α_i , as well as for 2 crack directions, $\theta = 45^\circ$ and $\theta = -45^\circ$ to take into consideration the cyclic seismic loading.

orientation 1: $\theta = 45^\circ + 90^\circ = 135^\circ$
 $V_f = \text{Min}(|V_f(45, \alpha)|, |V_f(-45, \alpha)|)$, with:
total thickness per orientation, $t_{f1} = N_L \cdot t / N_{\text{Dir}} = 1.00$
 $d_{fv} = d$ (figure 11.2, ACI 440) = 470.00
 f_{fe} ((11-5), ACI 440) = 328.00
 $E_f = 82000.00$
 $f_e = 0.004$, from (11.6a), ACI 440
with $f_u = 0.009$
From (11-11), ACI 440: $V_s + V_f \leq 479549.663$
 $b_w \cdot d = \frac{V_s \cdot d}{4} = 125663.706$

End Of Calculation of Shear Capacity ratio for element: column JCC1 of floor 1
At local axis: 3

Start Of Calculation of Shear Capacity ratio for element: column JCC1 of floor 1
At Shear local axis: 2
(Bending local axis: 3)
Section Type: rcjcs

Constant Properties

Knowledge Factor, = 1.00
Mean strength values are used for both shear and moment calculations.
Consequently:

Jacket

New material of Primary Member: Concrete Strength, $f_c = f_{cm} = 33.00$

New material of Primary Member: Steel Strength, $f_s = f_{sm} = 555.56$

Concrete Elasticity, $E_c = 26999.444$

Steel Elasticity, $E_s = 200000.00$

Existing Column

New material of Primary Member: Concrete Strength, $f_c = f_{cm} = 33.00$

New material of Primary Member: Steel Strength, $f_s = f_{sm} = 555.56$

Concrete Elasticity, $E_c = 26999.444$

Steel Elasticity, $E_s = 200000.00$

#####

Note: Especially for the calculation of moment strengths,
the above steel re-bar strengths are multiplied by 1.25 according to R18.6.5, ACI 318-14

Jacket

New material: Steel Strength, $f_s = 1.25 * f_{sm} = 694.45$

Existing Column

New material: Steel Strength, $f_s = 1.25 * f_{sm} = 694.45$

#####

External Diameter, $D = 500.00$

Internal Diameter, $D = 300.00$

Cover Thickness, $c = 25.00$

Mean Confinement Factor overall section = 1.51481

Element Length, $L = 3000.00$

Primary Member

Ribbed Bars

Ductile Steel

Without Detailing for Earthquake Resistance (including stirrups not closed at 135°)

Longitudinal Bars With Ends Lapped Starting at the End Sections

Inadequate Lap Length with $l_o/l_{ou,min} = 0.30$

FRP Wrapping Data

Type: Carbon

Dry properties (design values)

Thickness, $t = 1.00$

Tensile Strength, $f_{fu} = 840.00$

Tensile Modulus, $E_f = 82000.00$

Elongation, $e_{fu} = 0.009$

Number of directions, $N_{oDir} = 1$

Fiber orientations, $b_i: 0.00^\circ$

Number of layers, $N_L = 1$

Radius of rounding corners, $R = 40.00$

Stepwise Properties

At local axis: 2

EDGE -A-

Shear Force, $V_a = -2.1312935E-046$

EDGE -B-

Shear Force, $V_b = 2.1312935E-046$

BOTH EDGES

Axial Force, $F = -7389.214$

Longitudinal Reinforcement Area Distribution (in 2 divisions)

-Tension: $A_{st} = 0.00$

-Compression: $A_{sc} = 3053.628$
Longitudinal Reinforcement Area Distribution (in 3 divisions)
-Tension: $A_{s,ten} = 1017.876$
-Compression: $A_{s,com} = 1017.876$
-Middle: $A_{s,mid} = 1017.876$

Calculation of Shear Capacity ratio, $V_e/V_r = 0.23017425$
Member Controlled by Flexure ($V_e/V_r < 1$)
Calculation of Shear Demand from fig. R18.6.5, ACI 318-14 $V_e = (M_{pr1} + M_{pr2})/l_n = 162459.651$
with

$M_{pr1} = \text{Max}(M_{u1+}, M_{u1-}) = 2.4369E+008$
 $M_{u1+} = 2.4369E+008$, is the ultimate moment strength at the edge 1 of the member in the actual moment direction which is defined for the static loading combination
 $M_{u1-} = 2.4369E+008$, is the ultimate moment strength at the edge 1 of the member in the opposite moment direction which is defined for the static loading combination
 $M_{pr2} = \text{Max}(M_{u2+}, M_{u2-}) = 2.4369E+008$
 $M_{u2+} = 2.4369E+008$, is the ultimate moment strength at the edge 2 of the member in the actual moment direction which is defined for the static loading combination
 $M_{u2-} = 2.4369E+008$, is the ultimate moment strength at the edge 2 of the member in the opposite moment direction which is defined for the static loading combination

Calculation of M_{u1+}

Calculation of ultimate Moment Strength ((3.67), Biskinis Phd), M_u
 $M_u = 2.4369E+008$

= 0.80285146
' = 0.71403327
error of function (3.68), Biskinis Phd = 27987.158
From 5A.2, TBDY: $f_{cc} = f_c^* c = 49.98874$
conf. factor $c = 1.51481$
 $f_c = 33.00$
From 10.3.5, ASCE 41-17, Final value of $f_y: f_y \cdot \text{Min}(1, 1.25 \cdot (l_b/d)^{2/3}) = 389.0139$
 $l_b/d = 0.30$
 $d_1 = 44.00$
 $R = 250.00$
 $v = 0.00100813$
 $N = 7389.214$
 $A_c = 196349.541$
= $\text{Min}(1, 1.25 \cdot (l_b/d)^{2/3}) = 0.1620683$

Calculation of ratio l_b/d

Inadequate Lap Length with $l_b/d = 0.30$

Calculation of M_{u1-}

Calculation of ultimate Moment Strength ((3.67), Biskinis Phd), M_u
 $M_u = 2.4369E+008$

= 0.80285146
' = 0.71403327
error of function (3.68), Biskinis Phd = 27987.158
From 5A.2, TBDY: $f_{cc} = f_c^* c = 49.98874$
conf. factor $c = 1.51481$
 $f_c = 33.00$

From 10.3.5, ASCE 41-17, Final value of f_y : $f_y \cdot \text{Min}(1, 1.25 \cdot (l_b/d)^{2/3}) = 389.0139$

$$l_b/d = 0.30$$

$$d_1 = 44.00$$

$$R = 250.00$$

$$v = 0.00100813$$

$$N = 7389.214$$

$$A_c = 196349.541$$

$$= \text{Min}(1, 1.25 \cdot (l_b/d)^{2/3}) = 0.1620683$$

Calculation of ratio l_b/d

Inadequate Lap Length with $l_b/d = 0.30$

Calculation of μ_{2+}

Calculation of ultimate Moment Strength ((3.67), Biskinis Phd), μ

$$\mu = 2.4369E+008$$

$$= 0.80285146$$

$$' = 0.71403327$$

error of function (3.68), Biskinis Phd = 27987.158

From 5A.2, TBDY: $f_{cc} = f_c \cdot c = 49.98874$

$$\text{conf. factor } c = 1.51481$$

$$f_c = 33.00$$

From 10.3.5, ASCE 41-17, Final value of f_y : $f_y \cdot \text{Min}(1, 1.25 \cdot (l_b/d)^{2/3}) = 389.0139$

$$l_b/d = 0.30$$

$$d_1 = 44.00$$

$$R = 250.00$$

$$v = 0.00100813$$

$$N = 7389.214$$

$$A_c = 196349.541$$

$$= \text{Min}(1, 1.25 \cdot (l_b/d)^{2/3}) = 0.1620683$$

Calculation of ratio l_b/d

Inadequate Lap Length with $l_b/d = 0.30$

Calculation of μ_{2-}

Calculation of ultimate Moment Strength ((3.67), Biskinis Phd), μ

$$\mu = 2.4369E+008$$

$$= 0.80285146$$

$$' = 0.71403327$$

error of function (3.68), Biskinis Phd = 27987.158

From 5A.2, TBDY: $f_{cc} = f_c \cdot c = 49.98874$

$$\text{conf. factor } c = 1.51481$$

$$f_c = 33.00$$

From 10.3.5, ASCE 41-17, Final value of f_y : $f_y \cdot \text{Min}(1, 1.25 \cdot (l_b/d)^{2/3}) = 389.0139$

$$l_b/d = 0.30$$

$$d_1 = 44.00$$

$$R = 250.00$$

$$v = 0.00100813$$

$$N = 7389.214$$

$$A_c = 196349.541$$

$$= \text{Min}(1, 1.25 \cdot (l_b/d)^{2/3}) = 0.1620683$$

Calculation of ratio l_b/l_d

Inadequate Lap Length with $l_b/l_d = 0.30$

Calculation of Shear Strength $V_r = \text{Min}(V_{r1}, V_{r2}) = 705811.584$

Calculation of Shear Strength at edge 1, $V_{r1} = 705811.584$

$V_{r1} = V_{Col}$ ((10.3), ASCE 41-17) = $k_{nl} \cdot V_{Col0}$

$V_{Col0} = 705811.584$

$k_{nl} = 1$ (zero step-static loading)

NOTE: In expression (10-3) ' $V_s = A_v \cdot f_y \cdot d/s$ ' is replaced by ' $V_s + f \cdot V_f$ ' where V_f is the contribution of FRPs (11.3), ACI 440).

= 1 (normal-weight concrete)

Mean concrete strength: $f_c' = (f_c'_{jacket} \cdot \text{Area}_{jacket} + f_c'_{core} \cdot \text{Area}_{core}) / \text{Area}_{section} = 33.00$, but $f_c'^{0.5} \leq 8.3$ MPa (22.5.3.1, ACI 318-14)

$M/Vd = 2.00$

$\mu_u = 1.5940012E-011$

$\nu_u = 2.1312935E-046$

$d = 0.8 \cdot D = 400.00$

$N_u = 7389.214$

$A_g = 196349.541$

From (11.5.4.8), ACI 318-14: $V_s = V_{s1} + V_{s2} = 274157.871$

$V_{s1} = 274157.871$ is calculated for jacket, with:

$A_v = \sqrt{2} \cdot A_{stirrup} = 123370.055$

$f_y = 555.56$

$s = 100.00$

V_{s1} is multiplied by $\text{Col1} = 1.00$

$s/d = 0.25$

$V_{s2} = 0.00$ is calculated for core, with:

$A_v = \sqrt{2} \cdot A_{stirrup} = 78956.835$

$f_y = 555.56$

$s = 250.00$

V_{s2} is multiplied by $\text{Col2} = 0.00$

$s/d = 1.04167$

V_f ((11-3)-(11.4), ACI 440) = 308320.00

$f = 0.95$, for fully-wrapped sections

$w_f/s_f = 1$ (FRP strips adjacent to one another).

In (11.3) $\sin \theta + \cos \theta$ is replaced with $(\cot \theta + \cot \alpha) \sin \alpha$ which is more a generalised expression,

where θ is the angle of the crack direction (see KANEPE).

This later relation, considered as a function $V_f(\theta, \alpha)$, is implemented for every different fiber orientation α_i , as well as for 2 crack directions, $\theta = 45^\circ$ and $\theta = -45^\circ$ to take into consideration the cyclic seismic loading.

orientation 1: $\theta = b1 + 90^\circ = 90.00$

$V_f = \text{Min}(|V_f(45, \theta)|, |V_f(-45, \theta)|)$, with:

total thickness per orientation, $t_{f1} = N_L \cdot t / N_{Dir} = 1.00$

$d_{fv} = d$ (figure 11.2, ACI 440) = 470.00

f_{fe} ((11-5), ACI 440) = 328.00

$E_f = 82000.00$

$f_e = 0.004$, from (11.6a), ACI 440

with $f_u = 0.009$

From (11-11), ACI 440: $V_s + V_f \leq 479549.663$

$b_w \cdot d = \sqrt{2} \cdot d \cdot d / 4 = 125663.706$

Calculation of Shear Strength at edge 2, $V_{r2} = 705811.584$

$V_{r2} = V_{Col}$ ((10.3), ASCE 41-17) = $k_{nl} \cdot V_{Col0}$

$V_{Col0} = 705811.584$

$k_{nl} = 1$ (zero step-static loading)

NOTE: In expression (10-3) ' $V_s = A_v \cdot f_y \cdot d/s$ ' is replaced by ' $V_s + f \cdot V_f$ ' where V_f is the contribution of FRPs (11.3), ACI 440).

= 1 (normal-weight concrete)

Mean concrete strength: $f'_c = (f'_{c_jacket} \cdot Area_jacket + f'_{c_core} \cdot Area_core) / Area_section = 33.00$, but $f'_c^{0.5} \leq 8.3$ MPa (22.5.3.1, ACI 318-14)

$M/Vd = 2.00$

$\mu_u = 1.5940012E-011$

$V_u = 2.1312935E-046$

$d = 0.8 \cdot D = 400.00$

$N_u = 7389.214$

$A_g = 196349.541$

From (11.5.4.8), ACI 318-14: $V_s = V_{s1} + V_{s2} = 274157.871$

$V_{s1} = 274157.871$ is calculated for jacket, with:

$A_v = \sqrt{2} \cdot A_{stirrup} = 123370.055$

$f_y = 555.56$

$s = 100.00$

V_{s1} is multiplied by $\phi_{col1} = 1.00$

$s/d = 0.25$

$V_{s2} = 0.00$ is calculated for core, with:

$A_v = \sqrt{2} \cdot A_{stirrup} = 78956.835$

$f_y = 555.56$

$s = 250.00$

V_{s2} is multiplied by $\phi_{col2} = 0.00$

$s/d = 1.04167$

V_f ((11-3)-(11.4), ACI 440) = 308320.00

$f = 0.95$, for fully-wrapped sections

$w_f/s_f = 1$ (FRP strips adjacent to one another).

In (11.3) $\sin \theta + \cos \theta$ is replaced with $(\cot \theta + \csc \theta) \sin \alpha$ which is more a generalised expression, where θ is the angle of the crack direction (see KANEPE).

This later relation, considered as a function $V_f(\theta, \alpha)$, is implemented for every different fiber orientation α_i , as well as for 2 crack directions, $\theta = 45^\circ$ and $\theta = -45^\circ$ to take into consideration the cyclic seismic loading.

orientation 1: $\theta = \theta_1 + 90^\circ = 90.00$

$V_f = \text{Min}(|V_f(45, \theta_1)|, |V_f(-45, \theta_1)|)$, with:

total thickness per orientation, $t_{f1} = N_L \cdot t / N_{oDir} = 1.00$

$d_{fv} = d$ (figure 11.2, ACI 440) = 470.00

f_{fe} ((11-5), ACI 440) = 328.00

$E_f = 82000.00$

$f_{e} = 0.004$, from (11.6a), ACI 440

with $f_u = 0.009$

From (11-11), ACI 440: $V_s + V_f \leq 479549.663$

$b_w \cdot d = \sqrt{2} \cdot d^2 / 4 = 125663.706$

End Of Calculation of Shear Capacity ratio for element: column JCC1 of floor 1

At local axis: 2

Start Of Calculation of Chord Rotation Capacity for element: column JCC1 of floor 1

At local axis: 2

Integration Section: (b)

Section Type: rcjcs

Constant Properties

Knowledge Factor, $\phi = 1.00$

Chord Rotation is generally considered as Deformation-Controlled Action according to Table C7-1, ASCE 41-17.

Mean strengths are used for Deformation-Controlled Actions according to 7.5.1.3, ASCE 41-17

Consequently:

Jacket

New material of Primary Member: Concrete Strength, $f_c = f_{cm} = 33.00$

New material of Primary Member: Steel Strength, $f_s = f_{sm} = 555.56$

Concrete Elasticity, $E_c = 26999.444$

Steel Elasticity, $E_s = 200000.00$

Existing Column

New material of Primary Member: Concrete Strength, $f_c = f_{cm} = 33.00$

New material of Primary Member: Steel Strength, $f_s = f_{sm} = 555.56$

Concrete Elasticity, $E_c = 26999.444$

Steel Elasticity, $E_s = 200000.00$
 External Diameter, $D = 500.00$
 Internal Diameter, $D = 300.00$
 Cover Thickness, $c = 25.00$
 Element Length, $L = 3000.00$
 Primary Member
 Ribbed Bars
 Ductile Steel
 Without Detailing for Earthquake Resistance (including stirrups not closed at 135°)
 Longitudinal Bars With Ends Lapped Starting at the End Sections
 Inadequate Lap Length with $l_b/l_d = 0.30$
 FRP Wrapping Data
 Type: Carbon
 Dry properties (design values)
 Thickness, $t = 1.00$
 Tensile Strength, $f_{fu} = 840.00$
 Tensile Modulus, $E_f = 82000.00$
 Elongation, $e_{fu} = 0.009$
 Number of directions, $NoDir = 1$
 Fiber orientations, $bi = 0.00^\circ$
 Number of layers, $NL = 1$
 Radius of rounding corners, $R = 40.00$

Stepwise Properties

Bending Moment, $M = -8.7529383E-011$
 Shear Force, $V_2 = 4779.203$
 Shear Force, $V_3 = 2.1566928E-013$
 Axial Force, $F = -7387.302$
 Longitudinal Reinforcement Area Distribution (in 2 divisions)
 -Tension: $As_t = 0.00$
 -Compression: $As_c = 3053.628$
 Longitudinal Reinforcement Area Distribution (in 3 divisions)
 -Tension: $As_{t,ten} = 1017.876$
 -Compression: $As_{c,com} = 1017.876$
 -Middle: $As_{c,mid} = 1017.876$
 Mean Diameter of Tension Reinforcement, $Db_L = 18.00$

New component: From table 7-7, ASCE 41_17: Final chord rotation Capacity $u_{,R} = 1.0^*$ $u = 0.00453062$
 $u = y + p = 0.00453062$

- Calculation of y -

$y = (M_y * L_s / 3) / E_{eff} = 0.00453062$ ((4.29), Biskinis Phd)
 $M_y = 2.2517E+008$
 $L_s = M/V$ (with $L_s > 0.1 * L$ and $L_s < 2 * L$) = 1500.00
 From table 10.5, ASCE 41_17: $E_{eff} = factor * E_c * I_g = 2.4850E+013$
 factor = 0.30
 $A_g = 196349.541$
 Mean concrete strength: $f'_c = (f'_{c,jacket} * Area_{jacket} + f'_{c,core} * Area_{core}) / Area_{section} = 33.00$
 $N = 7387.302$
 $E_c * I_g = E_{c,jacket} * I_{g,jacket} + E_{c,core} * I_{g,core} = 8.2833E+013$

Calculation of Yielding Moment M_y

Calculation of y and M_y according to (7) - (8) in Biskinis and Fardis

$M_y = \text{Min}(M_{y,ten}, M_{y,com}) = 2.2517E+008$
 $y = 6.4424840E-006$
 $M_{y,ten} (8c) = 2.2517E+008$

$\rho_{ten}(7c) = 61.8137$
error of function (7c) = 0.00026387
My_com (8d) = 8.1922E+008
 $\rho_{com}(7d) = 63.67468$
error of function (7d) = -0.0087488
with ((10.1), ASCE 41-17) $e_y = \text{Min}(e_y, 1.25 * e_y * (l_b/l_d)^{2/3}) = 0.0027778$
 $e_{co} = 0.002$
apl = 0.45 ((9c) in Biskinis and Fardis for FRP Wrap)
d1 = 44.00
R = 250.00
v = 0.00101374
N = 7387.302
Ac = 196349.541
((10.1), ASCE 41-17) $\rho = \text{Min}(\rho, 1.25 * \rho * (l_b/l_d)^{2/3}) = 0.23280363$
with f_c^* ((12.3), ACI 440) = 37.11312
 $f_c = 33.00$
 $f_l = 1.312$
k = 1
Effective FRP thickness, $t_f = N L * t * \text{Cos}(b_1) = 1.00$
 e_{fe} ((12.5) and (12.7)) = 0.004
 $f_u = 0.009$
 $E_f = 82000.00$

Calculation of ratio l_b/l_d

Inadequate Lap Length with $l_b/l_d = 0.30$

- Calculation of ρ_p -

From table 10-9: $\rho_p = 0.00$

with:

- Columns controlled by inadequate development or splicing along the clear height because $l_b/l_d < 1$
shear control ratio $V_y E / V C o l O E = 0.23017425$
 $d = d_{external} = 0.00$
 $s = s_{external} = 0.00$
 $t = s_1 + s_2 + 2 * t_f / b_w * (f_{fe} / f_s) = 0.00795744$
jacket: $s_1 = A_{v1} * (D_{c1} / 2) / (s_1 * A_g) = 0.0027646$
 $A_{v1} = 78.53982$, is the area of stirrup
 $D_{c1} = D_{ext} - 2 * \text{cover} - \text{External Hoop Diameter} = 440.00$, is the total Length of all stirrups parallel to loading (shear) direction
 $s_1 = 100.00$
core: $s_2 = A_{v2} * (D_{c2} / 2) / (s_2 * A_g) = 0.00046968$
 $A_{v2} = 50.26548$, is the area of stirrup
 $D_{c2} = D_{int} - \text{Internal Hoop Diameter} = 292.00$, is the total Length of all stirrups parallel to loading (shear) direction
 $s_2 = 250.00$

The term $2 * t_f / b_w * (f_{fe} / f_s)$ is implemented to account for FRP contribution
where $f = 2 * t_f / b_w$ is FRP ratio (EC8 - 3, A.4.4.3(6)) and f_{fe} / f_s normalises f to steel strength
All these variables have already been given in Shear control ratio calculation.
For the normalisation f_s of jacket is used.

NUD = 7387.302
Ag = 196349.541
 $f_{cE} = (f_{c_jacket} * \text{Area_jacket} + f_{c_core} * \text{Area_core}) / \text{section_area} = 33.00$
 $f_{yLE} = (f_{y_ext_Long_Reinf} * \text{Area_ext_Long_Reinf} + f_{y_int_Long_Reinf} * \text{Area_int_Long_Reinf}) / \text{Area_Tot_Long_Rein} = 2.1219958E-314$
 $f_{yTE} = (f_{y_ext_Trans_Reinf} * \text{Area_ext_Trans_Reinf} + f_{y_int_Trans_Reinf} * \text{Area_int_Trans_Reinf}) / \text{Area_Tot_Trans_Rein} = 555.56$
 $\rho_l = \text{Area_Tot_Long_Rein} / (A_g) = 0.015552$
 $f_{cE} = 33.00$

End Of Calculation of Chord Rotation Capacity for element: column JCC1 of floor 1

At local axis: 2

Integration Section: (b)

Calculation No. 7

column C1, Floor 1


Limit State: Immediate Occupancy (data interpolation between analysis steps 1 and 2)

Analysis: Uniform +X

Check: Shear capacity VRd

Edge: End

Local Axis: (3)



Start Of Calculation of Shear Capacity for element: column JCC1 of floor 1

At local axis: 3

Integration Section: (b)

Section Type: rcjcs

Constant Properties

Knowledge Factor, $\gamma = 1.00$

Member Shear Force is generally considered as Force-Controlled Action according to Table C7-1, ASCE 41-17.

Lower-bound strengths are used for Force-Controlled Actions according to 7.5.1.3, ASCE 41-17

Consequently:

Jacket

New material of Primary Member: Concrete Strength, $f_c = f_{c_lower_bound} = 25.00$

New material of Primary Member: Steel Strength, $f_s = f_{s_lower_bound} = 500.00$

Concrete Elasticity, $E_c = 26999.444$

Steel Elasticity, $E_s = 200000.00$

Existing Column

New material of Primary Member: Concrete Strength, $f_c = f_{c_lower_bound} = 25.00$

New material of Primary Member: Steel Strength, $f_s = f_{s_lower_bound} = 500.00$

Concrete Elasticity, $E_c = 26999.444$

Steel Elasticity, $E_s = 200000.00$

#####

Note: Especially for the calculation of γ for displacement ductility demand, the expected (mean value) strengths are used (7.5.1.3, ASCE 41-17) because bending is considered as Deformation-Controlled Action (Table C7-1, ASCE 41-17).

Jacket

New material: Concrete Strength, $f_c = f_{cm} = 33.00$

New material: Steel Strength, $f_s = f_{sm} = 555.56$
 Existing Column
 New material: Concrete Strength, $f_c = f_{cm} = 33.00$
 New material: Steel Strength, $f_s = f_{sm} = 555.56$
 #####
 External Diameter, $D = 500.00$
 Internal Diameter, $D = 300.00$
 Cover Thickness, $c = 25.00$
 Element Length, $L = 3000.00$
 Primary Member
 Ribbed Bars
 Ductile Steel
 Without Detailing for Earthquake Resistance (including stirrups not closed at 135°)
 Longitudinal Bars With Ends Lapped Starting at the End Sections
 Inadequate Lap Length with $l_o/l_{ou,min} = l_b/l_d = 0.30$
 FRP Wrapping Data
 Type: Carbon
 Dry properties (design values)
 Thickness, $t = 1.00$
 Tensile Strength, $f_{fu} = 840.00$
 Tensile Modulus, $E_f = 82000.00$
 Elongation, $e_{fu} = 0.009$
 Number of directions, $N_{oDir} = 1$
 Fiber orientations, $b_i: 0.00^\circ$
 Number of layers, $N_L = 1$
 Radius of rounding corners, $R = 40.00$

 Stepwise Properties

EDGE -A-
 Bending Moment, $M_a = 7.3474831E-010$
 Shear Force, $V_a = -2.1566928E-013$
 EDGE -B-
 Bending Moment, $M_b = -8.7529383E-011$
 Shear Force, $V_b = 2.1566928E-013$
 BOTH EDGES
 Axial Force, $F = -7387.302$
 Longitudinal Reinforcement Area Distribution (in 2 divisions)
 -Tension: $A_{st} = 0.00$
 -Compression: $A_{sc} = 3053.628$
 Longitudinal Reinforcement Area Distribution (in 3 divisions)
 -Tension: $A_{st,ten} = 1017.876$
 -Compression: $A_{sc,com} = 1017.876$
 -Middle: $A_{sc,mid} = 1017.876$
 Mean Diameter of Tension Reinforcement, $D_{bL,ten} = 18.00$

 New component: From table 7-7, ASCE 41_17: Final Shear Capacity $V_R = 1.0 \cdot V_n = 614519.957$
 $V_n ((10.3), ASCE 41-17) = k_n l \cdot V_{CoI0} = 614519.957$
 $V_{CoI} = 614519.957$
 $k_n l = 1.00$
 displacement_ductility_demand = 0.00

 NOTE: In expression (10-3) ' $V_s = A_v \cdot f_y \cdot d / s$ ' is replaced by ' $V_{s+} = f \cdot V_f$ '
 where V_f is the contribution of FRPs (11.3), ACI 440).

 = 1 (normal-weight concrete)
 Mean concrete strength: $f_c' = (f_c'_{jacket} \cdot Area_{jacket} + f_c'_{core} \cdot Area_{core}) / Area_{section} = 25.00$, but $f_c'^{0.5} \leq 8.3$
 MPa (22.5.3.1, ACI 318-14)
 $M/Vd = 2.00$
 $M_u = 8.7529383E-011$
 $V_u = 2.1566928E-013$
 $d = 0.8 \cdot D = 400.00$
 $N_u = 7387.302$

$A_g = 196349.541$
 From (11.5.4.8), ACI 318-14: $V_s = V_{s1} + V_{s2} = 246740.11$
 $V_{s1} = 246740.11$ is calculated for jacket, with:
 $A_v = \sqrt{2} \cdot A_{stirrup} = 123370.055$
 $f_y = 500.00$
 $s = 100.00$
 V_{s1} is multiplied by $Col1 = 1.00$
 $s/d = 0.25$
 $V_{s2} = 0.00$ is calculated for core, with:
 $A_v = \sqrt{2} \cdot A_{stirrup} = 78956.835$
 $f_y = 500.00$
 $s = 250.00$
 V_{s2} is multiplied by $Col2 = 0.00$
 $s/d = 1.04167$
 V_f ((11-3)-(11.4), ACI 440) = 308320.00
 $f = 0.95$, for fully-wrapped sections
 $w_f/s_f = 1$ (FRP strips adjacent to one another).
 In (11.3) $\sin + \cos$ is replaced with $(\cot + \cot a) \sin a$ which is more a generalised expression,
 where a is the angle of the crack direction (see KANEPE).
 This later relation, considered as a function $V_f(\theta, a)$, is implemented for every different fiber orientation a_i ,
 as well as for 2 crack directions, $\theta = 45^\circ$ and $\theta = -45^\circ$ to take into consideration the cyclic seismic loading.
 orientation 1: $\theta = 45^\circ$ and $a = 90^\circ$
 $V_f = \text{Min}(|V_f(45, 90)|, |V_f(-45, 90)|)$, with:
 total thickness per orientation, $t_{f1} = NL \cdot t / \text{NoDir} = 1.00$
 $d_{fv} = d$ (figure 11.2, ACI 440) = 470.00
 f_{fe} ((11-5), ACI 440) = 328.00
 $E_f = 82000.00$
 $f_e = 0.004$, from (11.6a), ACI 440
 with $f_u = 0.009$
 From (11-11), ACI 440: $V_s + V_f \leq 417394.406$
 $b_w \cdot d = \sqrt{V_s \cdot V_f} = 125663.706$

displacement_ductility_demand is calculated as δ / y

- Calculation of δ / y for END B -
for rotation axis 2 and integ. section (b)

From analysis, chord rotation $\theta = 5.1499725E-021$
 $y = (M_y \cdot L_s / 3) / E_{eff} = 0.00453062$ ((4.29), Biskinis Phd)
 $M_y = 2.2517E+008$
 $L_s = M/V$ (with $L_s > 0.1 \cdot L$ and $L_s < 2 \cdot L$) = 1500.00
 From table 10.5, ASCE 41_17: $E_{eff} = \text{factor} \cdot E_c \cdot I_g = 2.4850E+013$
 factor = 0.30
 $A_g = 196349.541$
 Mean concrete strength: $f_c' = (f_c'_{jacket} \cdot \text{Area}_{jacket} + f_c'_{core} \cdot \text{Area}_{core}) / \text{Area}_{section} = 33.00$
 $N = 7387.302$
 $E_c \cdot I_g = E_{c,jacket} \cdot I_{g,jacket} + E_{c,core} \cdot I_{g,core} = 8.2833E+013$

Calculation of Yielding Moment M_y

Calculation of δ / y and M_y according to (7) - (8) in Biskinis and Fardis

$M_y = \text{Min}(M_{y,ten}, M_{y,com}) = 2.2517E+008$
 $y = 6.4424840E-006$
 $M_{y,ten}$ (8c) = 2.2517E+008
 δ / y (7c) = 61.8137
 error of function (7c) = 0.00026387
 $M_{y,com}$ (8d) = 8.1922E+008
 δ / y (7d) = 63.67468
 error of function (7d) = -0.0087488
 with ((10.1), ASCE 41-17) $e_y = \text{Min}(e_y, 1.25 \cdot e_y \cdot (I_b / I_d)^{2/3}) = 0.0027778$
 $e_{co} = 0.002$
 $\alpha_{pl} = 0.45$ ((9c) in Biskinis and Fardis for FRP Wrap)

$d1 = 44.00$
 $R = 250.00$
 $v = 0.00101374$
 $N = 7387.302$
 $Ac = 196349.541$
 $((10.1), ASCE 41-17) = \text{Min}(, 1.25 * (lb/d)^{2/3}) = 0.23280363$
 with fc^* ((12.3), ACI 440) = 37.11312
 $fc = 33.00$
 $fl = 1.312$
 $k = 1$
 Effective FRP thickness, $tf = NL * t * \text{Cos}(b1) = 1.00$
 efe ((12.5) and (12.7)) = 0.004
 $fu = 0.009$
 $Ef = 82000.00$

Calculation of ratio lb/d

Inadequate Lap Length with $lb/d = 0.30$

End Of Calculation of Shear Capacity for element: column JCC1 of floor 1

At local axis: 3

Integration Section: (b)

Calculation No. 8

column C1, Floor 1


Limit State: Immediate Occupancy (data interpolation between analysis steps 1 and 2)

Analysis: Uniform +X

Check: Chord rotation capacity (θ_u)

Edge: End

Local Axis: (3)



Start Of Calculation of Shear Capacity ratio for element: column JCC1 of floor 1

At Shear local axis: 3

(Bending local axis: 2)

Section Type: rcjcs

Constant Properties

Knowledge Factor, $k = 1.00$

Mean strength values are used for both shear and moment calculations.

Consequently:

Jacket

New material of Primary Member: Concrete Strength, $f_c = f_{cm} = 33.00$

New material of Primary Member: Steel Strength, $f_s = f_{sm} = 555.56$

Concrete Elasticity, $E_c = 26999.444$

Steel Elasticity, $E_s = 200000.00$

Existing Column

New material of Primary Member: Concrete Strength, $f_c = f_{cm} = 33.00$

New material of Primary Member: Steel Strength, $f_s = f_{sm} = 555.56$

Concrete Elasticity, $E_c = 26999.444$

Steel Elasticity, $E_s = 200000.00$

#####

Note: Especially for the calculation of moment strengths,

the above steel re-bar strengths are multiplied by 1.25 according to R18.6.5, ACI 318-14

Jacket

New material: Steel Strength, $f_s = 1.25 \cdot f_{sm} = 694.45$

Existing Column

New material: Steel Strength, $f_s = 1.25 \cdot f_{sm} = 694.45$

#####

External Diameter, $D = 500.00$

Internal Diameter, $D = 300.00$

Cover Thickness, $c = 25.00$

Mean Confinement Factor overall section = 1.51481

Element Length, $L = 3000.00$

Primary Member

Ribbed Bars

Ductile Steel

Without Detailing for Earthquake Resistance (including stirrups not closed at 135°)

Longitudinal Bars With Ends Lapped Starting at the End Sections

Inadequate Lap Length with $l_o/l_{ou, \min} = 0.30$

FRP Wrapping Data

Type: Carbon

Dry properties (design values)

Thickness, $t = 1.00$

Tensile Strength, $f_{fu} = 840.00$

Tensile Modulus, $E_f = 82000.00$

Elongation, $e_{fu} = 0.009$

Number of directions, $N_{oDir} = 1$

Fiber orientations, $b_i = 0.00^\circ$

Number of layers, $N_L = 1$

Radius of rounding corners, $R = 40.00$

Stepwise Properties

At local axis: 3

EDGE -A-

Shear Force, $V_a = 3.4807814E-030$

EDGE -B-

Shear Force, $V_b = -3.4807814E-030$

BOTH EDGES

Axial Force, $F = -7389.214$

Longitudinal Reinforcement Area Distribution (in 2 divisions)

-Tension: $A_{slt} = 0.00$

-Compression: $A_{slc} = 3053.628$

Longitudinal Reinforcement Area Distribution (in 3 divisions)

-Tension: $A_{sl,ten} = 1017.876$

-Compression: $A_{sl,com} = 1017.876$

-Middle: $A_{sl,mid} = 1017.876$

Calculation of Shear Capacity ratio , $V_e/V_r = 0.23017425$

Member Controlled by Flexure ($V_e/V_r < 1$)

Calculation of Shear Demand from fig. R18.6.5, ACI 318-14 $V_e = (M_{pr1} + M_{pr2})/l_n = 162459.651$

with

$M_{pr1} = \text{Max}(M_{u1+} , M_{u1-}) = 2.4369E+008$

$M_{u1+} = 2.4369E+008$, is the ultimate moment strength at the edge 1 of the member in the actual moment direction which is defined for the static loading combination

$M_{u1-} = 2.4369E+008$, is the ultimate moment strength at the edge 1 of the member in the opposite moment direction which is defined for the static loading combination

$M_{pr2} = \text{Max}(M_{u2+} , M_{u2-}) = 2.4369E+008$

$M_{u2+} = 2.4369E+008$, is the ultimate moment strength at the edge 2 of the member in the actual moment direction which is defined for the the static loading combination

$M_{u2-} = 2.4369E+008$, is the ultimate moment strength at the edge 2 of the member in the opposite moment direction which is defined for the the static loading combination

Calculation of M_{u1+}

Calculation of ultimate Moment Strength ((3.67), Biskinis Phd), M_u

$M_u = 2.4369E+008$

= 0.80285146

' = 0.71403327

error of function (3.68), Biskinis Phd = 27987.158

From 5A.2, TBDY: $f_{cc} = f_c^* \quad c = 49.98874$

conf. factor $c = 1.51481$

$f_c = 33.00$

From 10.3.5, ASCE 41-17, Final value of f_y : $f_y \cdot \text{Min}(1, 1.25 \cdot (l_b/d)^{2/3}) = 389.0139$

$l_b/d = 0.30$

$d_1 = 44.00$

$R = 250.00$

$v = 0.00100813$

$N = 7389.214$

$A_c = 196349.541$

= $\cdot \text{Min}(1, 1.25 \cdot (l_b/d)^{2/3}) = 0.1620683$

Calculation of ratio l_b/d

Inadequate Lap Length with $l_b/d = 0.30$

Calculation of M_{u1-}

Calculation of ultimate Moment Strength ((3.67), Biskinis Phd), M_u

$M_u = 2.4369E+008$

= 0.80285146

' = 0.71403327

error of function (3.68), Biskinis Phd = 27987.158

From 5A.2, TBDY: $f_{cc} = f_c^* \quad c = 49.98874$

conf. factor $c = 1.51481$

$f_c = 33.00$

From 10.3.5, ASCE 41-17, Final value of f_y : $f_y \cdot \text{Min}(1, 1.25 \cdot (l_b/d)^{2/3}) = 389.0139$

$l_b/d = 0.30$

$d_1 = 44.00$

$R = 250.00$

$v = 0.00100813$

$N = 7389.214$

$A_c = 196349.541$

$$= \text{Min}(1, 1.25 \cdot (l_b/d)^{2/3}) = 0.1620683$$

Calculation of ratio l_b/d

Inadequate Lap Length with $l_b/d = 0.30$

Calculation of μ_{2+}

Calculation of ultimate Moment Strength ((3.67), Biskinis Phd), μ
 $\mu = 2.4369E+008$

$$= 0.80285146$$

$$' = 0.71403327$$

error of function (3.68), Biskinis Phd = 27987.158

From 5A.2, TBDY: $f_{cc} = f_c \cdot c = 49.98874$

conf. factor $c = 1.51481$

$f_c = 33.00$

From 10.3.5, ASCE 41-17, Final value of f_y : $f_y \cdot \text{Min}(1, 1.25 \cdot (l_b/d)^{2/3}) = 389.0139$

$l_b/d = 0.30$

$d_1 = 44.00$

$R = 250.00$

$v = 0.00100813$

$N = 7389.214$

$A_c = 196349.541$

$$= \text{Min}(1, 1.25 \cdot (l_b/d)^{2/3}) = 0.1620683$$

Calculation of ratio l_b/d

Inadequate Lap Length with $l_b/d = 0.30$

Calculation of μ_{2-}

Calculation of ultimate Moment Strength ((3.67), Biskinis Phd), μ
 $\mu = 2.4369E+008$

$$= 0.80285146$$

$$' = 0.71403327$$

error of function (3.68), Biskinis Phd = 27987.158

From 5A.2, TBDY: $f_{cc} = f_c \cdot c = 49.98874$

conf. factor $c = 1.51481$

$f_c = 33.00$

From 10.3.5, ASCE 41-17, Final value of f_y : $f_y \cdot \text{Min}(1, 1.25 \cdot (l_b/d)^{2/3}) = 389.0139$

$l_b/d = 0.30$

$d_1 = 44.00$

$R = 250.00$

$v = 0.00100813$

$N = 7389.214$

$A_c = 196349.541$

$$= \text{Min}(1, 1.25 \cdot (l_b/d)^{2/3}) = 0.1620683$$

Calculation of ratio l_b/d

Inadequate Lap Length with $l_b/d = 0.30$

Calculation of Shear Strength $V_r = \text{Min}(V_{r1}, V_{r2}) = 705811.584$

Calculation of Shear Strength at edge 1, $V_{r1} = 705811.584$

$V_{r1} = V_{CoI} ((10.3), \text{ASCE } 41-17) = k_{nl} * V_{CoI0}$

$V_{CoI0} = 705811.584$

$k_{nl} = 1$ (zero step-static loading)

NOTE: In expression (10-3) ' $V_s = A_v * f_y * d / s$ ' is replaced by ' $V_s + f * V_f$ ' where V_f is the contribution of FRPs (11.3), ACI 440).

$\lambda = 1$ (normal-weight concrete)

Mean concrete strength: $f_c' = (f_c'_{\text{jacket}} * \text{Area}_{\text{jacket}} + f_c'_{\text{core}} * \text{Area}_{\text{core}}) / \text{Area}_{\text{section}} = 33.00$, but $f_c'^{0.5} \leq 8.3$ MPa (22.5.3.1, ACI 318-14)

$M / Vd = 2.00$

$M_u = 1.2438899E-011$

$V_u = 3.4807814E-030$

$d = 0.8 * D = 400.00$

$N_u = 7389.214$

$A_g = 196349.541$

From (11.5.4.8), ACI 318-14: $V_s = V_{s1} + V_{s2} = 274157.871$

$V_{s1} = 274157.871$ is calculated for jacket, with:

$A_v = \sqrt{2} * A_{\text{stirrup}} = 123370.055$

$f_y = 555.56$

$s = 100.00$

V_{s1} is multiplied by $Col1 = 1.00$

$s/d = 0.25$

$V_{s2} = 0.00$ is calculated for core, with:

$A_v = \sqrt{2} * A_{\text{stirrup}} = 78956.835$

$f_y = 555.56$

$s = 250.00$

V_{s2} is multiplied by $Col2 = 0.00$

$s/d = 1.04167$

$V_f ((11-3)-(11.4), \text{ACI } 440) = 308320.00$

$f = 0.95$, for fully-wrapped sections

$w_f / s_f = 1$ (FRP strips adjacent to one another).

In (11.3) $\sin + \cos$ is replaced with $(\cot + \cot_a) \sin a$ which is more a generalised expression, where a is the angle of the crack direction (see KANEPE).

This later relation, considered as a function $V_f(\theta, a)$, is implemented for every different fiber orientation a_i , as well as for 2 crack directions, $\theta = 45^\circ$ and $\theta = -45^\circ$ to take into consideration the cyclic seismic loading.

orientation 1: $\theta = b1 + 90^\circ = 90.00$

$V_f = \text{Min}(|V_f(45, \theta)|, |V_f(-45, a1)|)$, with:

total thickness per orientation, $t_{f1} = N_L * t / N_{oDir} = 1.00$

$d_{fv} = d$ (figure 11.2, ACI 440) = 470.00

$f_{fe} ((11-5), \text{ACI } 440) = 328.00$

$E_f = 82000.00$

$f_e = 0.004$, from (11.6a), ACI 440

with $f_u = 0.009$

From (11-11), ACI 440: $V_s + V_f \leq 479549.663$

$b_w * d = \sqrt{2} * d / 4 = 125663.706$

Calculation of Shear Strength at edge 2, $V_{r2} = 705811.584$

$V_{r2} = V_{CoI} ((10.3), \text{ASCE } 41-17) = k_{nl} * V_{CoI0}$

$V_{CoI0} = 705811.584$

$k_{nl} = 1$ (zero step-static loading)

NOTE: In expression (10-3) ' $V_s = A_v * f_y * d / s$ ' is replaced by ' $V_s + f * V_f$ ' where V_f is the contribution of FRPs (11.3), ACI 440).

$\lambda = 1$ (normal-weight concrete)

Mean concrete strength: $f_c' = (f_c'_{\text{jacket}} * \text{Area}_{\text{jacket}} + f_c'_{\text{core}} * \text{Area}_{\text{core}}) / \text{Area}_{\text{section}} = 33.00$, but $f_c'^{0.5} \leq 8.3$ MPa (22.5.3.1, ACI 318-14)

$M / Vd = 2.00$

$M_u = 1.2438899E-011$

$V_u = 3.4807814E-030$

$d = 0.8 * D = 400.00$

Nu = 7389.214
 Ag = 196349.541
 From (11.5.4.8), ACI 318-14: Vs = Vs1 + Vs2 = 274157.871
 Vs1 = 274157.871 is calculated for jacket, with:
 Av = /2*A_stirrup = 123370.055
 fy = 555.56
 s = 100.00
 Vs1 is multiplied by Col1 = 1.00
 s/d = 0.25
 Vs2 = 0.00 is calculated for core, with:
 Av = /2*A_stirrup = 78956.835
 fy = 555.56
 s = 250.00
 Vs2 is multiplied by Col2 = 0.00
 s/d = 1.04167
 Vf ((11-3)-(11.4), ACI 440) = 308320.00
 f = 0.95, for fully-wrapped sections
 wf/sf = 1 (FRP strips adjacent to one another).
 In (11.3) sin + cos is replaced with (cot + cota)sina which is more a generalised expression,
 where is the angle of the crack direction (see KANEPE).
 This later relation, considered as a function Vf(,), is implemented for every different fiber orientation ai,
 as well as for 2 crack directions, =45° and =-45° to take into consideration the cyclic seismic loading.
 orientation 1: 1 = b1 + 90° = 90.00
 Vf = Min(|Vf(45, 1)|, |Vf(-45,a1)|), with:
 total thickness per orientation, tf1 = NL*t/NoDir = 1.00
 dfv = d (figure 11.2, ACI 440) = 470.00
 ffe ((11-5), ACI 440) = 328.00
 Ef = 82000.00
 fe = 0.004, from (11.6a), ACI 440
 with fu = 0.009
 From (11-11), ACI 440: Vs + Vf <= 479549.663
 bw*d = *d*d/4 = 125663.706

 End Of Calculation of Shear Capacity ratio for element: column JCC1 of floor 1
 At local axis: 3

 Start Of Calculation of Shear Capacity ratio for element: column JCC1 of floor 1
 At Shear local axis: 2
 (Bending local axis: 3)
 Section Type: rcjcs

Constant Properties

 Knowledge Factor, = 1.00
 Mean strength values are used for both shear and moment calculations.
 Consequently:
 Jacket
 New material of Primary Member: Concrete Strength, fc = fcm = 33.00
 New material of Primary Member: Steel Strength, fs = fsm = 555.56
 Concrete Elasticity, Ec = 26999.444
 Steel Elasticity, Es = 200000.00
 Existing Column
 New material of Primary Member: Concrete Strength, fc = fcm = 33.00
 New material of Primary Member: Steel Strength, fs = fsm = 555.56
 Concrete Elasticity, Ec = 26999.444
 Steel Elasticity, Es = 200000.00
 #####
 Note: Especially for the calculation of moment strengths,
 the above steel re-bar strengths are multiplied by 1.25 according to R18.6.5, ACI 318-14
 Jacket
 New material: Steel Strength, fs = 1.25*fsm = 694.45
 Existing Column
 New material: Steel Strength, fs = 1.25*fsm = 694.45

#####

External Diameter, D = 500.00
Internal Diameter, D = 300.00
Cover Thickness, c = 25.00
Mean Confinement Factor overall section = 1.51481
Element Length, L = 3000.00
Primary Member
Ribbed Bars
Ductile Steel
Without Detailing for Earthquake Resistance (including stirrups not closed at 135°)
Longitudinal Bars With Ends Lapped Starting at the End Sections
Inadequate Lap Length with $l_o/l_{o,min}$ = 0.30
FRP Wrapping Data
Type: Carbon
Dry properties (design values)
Thickness, t = 1.00
Tensile Strength, f_{fu} = 840.00
Tensile Modulus, E_f = 82000.00
Elongation, e_{fu} = 0.009
Number of directions, NoDir = 1
Fiber orientations, b_i : 0.00°
Number of layers, NL = 1
Radius of rounding corners, R = 40.00

Stepwise Properties

At local axis: 2
EDGE -A-
Shear Force, V_a = -2.1312935E-046
EDGE -B-
Shear Force, V_b = 2.1312935E-046
BOTH EDGES
Axial Force, F = -7389.214
Longitudinal Reinforcement Area Distribution (in 2 divisions)
-Tension: $A_{sl,t}$ = 0.00
-Compression: $A_{sl,c}$ = 3053.628
Longitudinal Reinforcement Area Distribution (in 3 divisions)
-Tension: $A_{sl,ten}$ = 1017.876
-Compression: $A_{sl,com}$ = 1017.876
-Middle: $A_{sl,mid}$ = 1017.876

Calculation of Shear Capacity ratio , V_e/V_r = 0.23017425
Member Controlled by Flexure ($V_e/V_r < 1$)
Calculation of Shear Demand from fig. R18.6.5, ACI 318-14 $V_e = (M_{pr1} + M_{pr2})/l_n = 162459.651$
with
 $M_{pr1} = \text{Max}(\mu_{u1+} , \mu_{u1-}) = 2.4369E+008$
 $\mu_{u1+} = 2.4369E+008$, is the ultimate moment strength at the edge 1 of the member in the actual moment direction
which is defined for the static loading combination
 $\mu_{u1-} = 2.4369E+008$, is the ultimate moment strength at the edge 1 of the member in the opposite moment
direction which is defined for the static loading combination
 $M_{pr2} = \text{Max}(\mu_{u2+} , \mu_{u2-}) = 2.4369E+008$
 $\mu_{u2+} = 2.4369E+008$, is the ultimate moment strength at the edge 2 of the member in the actual moment direction
which is defined for the the static loading combination
 $\mu_{u2-} = 2.4369E+008$, is the ultimate moment strength at the edge 2 of the member in the opposite moment
direction which is defined for the the static loading combination

Calculation of μ_{u1+}

Calculation of ultimate Moment Strength ((3.67), Biskinis Phd), μ_u
 $\mu_u = 2.4369E+008$

= 0.80285146
' = 0.71403327
error of function (3.68), Biskinis Phd = 27987.158
From 5A.2, TBDY: $f_{cc} = f_c \cdot c = 49.98874$
conf. factor $c = 1.51481$
 $f_c = 33.00$
From 10.3.5, ASCE 41-17, Final value of f_y : $f_y \cdot \text{Min}(1, 1.25 \cdot (l_b/d)^{2/3}) = 389.0139$
 $l_b/d = 0.30$
 $d_1 = 44.00$
 $R = 250.00$
 $v = 0.00100813$
 $N = 7389.214$
 $Ac = 196349.541$
 $= \cdot \text{Min}(1, 1.25 \cdot (l_b/d)^{2/3}) = 0.1620683$

Calculation of ratio l_b/d

Inadequate Lap Length with $l_b/d = 0.30$

Calculation of μ_1 -

Calculation of ultimate Moment Strength ((3.67), Biskinis Phd), μ
 $\mu = 2.4369E+008$

= 0.80285146
' = 0.71403327
error of function (3.68), Biskinis Phd = 27987.158
From 5A.2, TBDY: $f_{cc} = f_c \cdot c = 49.98874$
conf. factor $c = 1.51481$
 $f_c = 33.00$
From 10.3.5, ASCE 41-17, Final value of f_y : $f_y \cdot \text{Min}(1, 1.25 \cdot (l_b/d)^{2/3}) = 389.0139$
 $l_b/d = 0.30$
 $d_1 = 44.00$
 $R = 250.00$
 $v = 0.00100813$
 $N = 7389.214$
 $Ac = 196349.541$
 $= \cdot \text{Min}(1, 1.25 \cdot (l_b/d)^{2/3}) = 0.1620683$

Calculation of ratio l_b/d

Inadequate Lap Length with $l_b/d = 0.30$

Calculation of μ_2 +

Calculation of ultimate Moment Strength ((3.67), Biskinis Phd), μ
 $\mu = 2.4369E+008$

= 0.80285146
' = 0.71403327
error of function (3.68), Biskinis Phd = 27987.158
From 5A.2, TBDY: $f_{cc} = f_c \cdot c = 49.98874$
conf. factor $c = 1.51481$
 $f_c = 33.00$
From 10.3.5, ASCE 41-17, Final value of f_y : $f_y \cdot \text{Min}(1, 1.25 \cdot (l_b/d)^{2/3}) = 389.0139$
 $l_b/d = 0.30$

d1 = 44.00
R = 250.00
v = 0.00100813
N = 7389.214
Ac = 196349.541
= *Min(1,1.25*(lb/d)^ 2/3) = 0.1620683

Calculation of ratio lb/d

Inadequate Lap Length with lb/d = 0.30

Calculation of Mu2-

Calculation of ultimate Moment Strength ((3.67), Biskinis Phd), Mu

Mu = 2.4369E+008

= 0.80285146

' = 0.71403327

error of function (3.68), Biskinis Phd = 27987.158

From 5A.2, TBDY: fcc = fc* c = 49.98874

conf. factor c = 1.51481

fc = 33.00

From 10.3.5, ASCE 41-17, Final value of fy: fy*Min(1,1.25*(lb/d)^ 2/3) = 389.0139

lb/d = 0.30

d1 = 44.00

R = 250.00

v = 0.00100813

N = 7389.214

Ac = 196349.541

= *Min(1,1.25*(lb/d)^ 2/3) = 0.1620683

Calculation of ratio lb/d

Inadequate Lap Length with lb/d = 0.30

Calculation of Shear Strength Vr = Min(Vr1,Vr2) = 705811.584

Calculation of Shear Strength at edge 1, Vr1 = 705811.584

Vr1 = VCol ((10.3), ASCE 41-17) = knl*VCol0

VCol0 = 705811.584

knl = 1 (zero step-static loading)

NOTE: In expression (10-3) 'Vs = Av*fy*d/s' is replaced by 'Vs+ f*Vf' where Vf is the contribution of FRPs (11.3), ACI 440).

= 1 (normal-weight concrete)

Mean concrete strength: fc' = (fc'_jacket*Area_jacket + fc'_core*Area_core)/Area_section = 33.00, but fc'^0.5 <= 8.3 MPa (22.5.3.1, ACI 318-14)

M/Vd = 2.00

Mu = 1.5940012E-011

Vu = 2.1312935E-046

d = 0.8*D = 400.00

Nu = 7389.214

Ag = 196349.541

From (11.5.4.8), ACI 318-14: Vs = Vs1 + Vs2 = 274157.871

Vs1 = 274157.871 is calculated for jacket, with:

Av = /2*A_stirrup = 123370.055

fy = 555.56

$s = 100.00$
 V_{s1} is multiplied by $Col1 = 1.00$
 $s/d = 0.25$
 $V_{s2} = 0.00$ is calculated for core, with:
 $A_v = \sqrt{2} \cdot A_{stirrup} = 78956.835$
 $f_y = 555.56$
 $s = 250.00$
 V_{s2} is multiplied by $Col2 = 0.00$
 $s/d = 1.04167$
 V_f ((11-3)-(11.4), ACI 440) = 308320.00
 $f = 0.95$, for fully-wrapped sections
 $w_f/s_f = 1$ (FRP strips adjacent to one another).
 In (11.3) $\sin \theta + \cos \theta$ is replaced with $(\cot \theta + \csc \theta) \sin \alpha$ which is more a generalised expression,
 where θ is the angle of the crack direction (see KANEPE).
 This later relation, considered as a function $V_f(\theta, \alpha)$, is implemented for every different fiber orientation α_i ,
 as well as for 2 crack directions, $\theta = 45^\circ$ and $\theta = -45^\circ$ to take into consideration the cyclic seismic loading.
 orientation 1: $\theta = b_1 + 90^\circ = 90.00$
 $V_f = \text{Min}(|V_f(45, \theta)|, |V_f(-45, \theta)|)$, with:
 total thickness per orientation, $t_{f1} = N_L \cdot t / N_{oDir} = 1.00$
 $d_{fv} = d$ (figure 11.2, ACI 440) = 470.00
 f_{fe} ((11-5), ACI 440) = 328.00
 $E_f = 82000.00$
 $f_e = 0.004$, from (11.6a), ACI 440
 with $f_u = 0.009$
 From (11-11), ACI 440: $V_s + V_f \leq 479549.663$
 $b_w \cdot d = \sqrt{V_s \cdot d} / 4 = 125663.706$

 Calculation of Shear Strength at edge 2, $V_{r2} = 705811.584$
 $V_{r2} = V_{Col}$ ((10.3), ASCE 41-17) = $k_{nl} \cdot V_{ColO}$
 $V_{ColO} = 705811.584$
 $k_{nl} = 1$ (zero step-static loading)

 NOTE: In expression (10-3) ' $V_s = A_v \cdot f_y \cdot d / s$ ' is replaced by ' $V_s + f \cdot V_f$ '
 where V_f is the contribution of FRPs (11.3), ACI 440).

 $\beta = 1$ (normal-weight concrete)
 Mean concrete strength: $f_c' = (f_c'_{jacket} \cdot Area_{jacket} + f_c'_{core} \cdot Area_{core}) / Area_{section} = 33.00$, but $f_c'^{0.5} \leq 8.3$
 MPa (22.5.3.1, ACI 318-14)
 $M/Vd = 2.00$
 $\mu_u = 1.5940012E-011$
 $\nu_u = 2.1312935E-046$
 $d = 0.8 \cdot D = 400.00$
 $N_u = 7389.214$
 $A_g = 196349.541$
 From (11.5.4.8), ACI 318-14: $V_s = V_{s1} + V_{s2} = 274157.871$
 $V_{s1} = 274157.871$ is calculated for jacket, with:
 $A_v = \sqrt{2} \cdot A_{stirrup} = 123370.055$
 $f_y = 555.56$
 $s = 100.00$
 V_{s1} is multiplied by $Col1 = 1.00$
 $s/d = 0.25$
 $V_{s2} = 0.00$ is calculated for core, with:
 $A_v = \sqrt{2} \cdot A_{stirrup} = 78956.835$
 $f_y = 555.56$
 $s = 250.00$
 V_{s2} is multiplied by $Col2 = 0.00$
 $s/d = 1.04167$
 V_f ((11-3)-(11.4), ACI 440) = 308320.00
 $f = 0.95$, for fully-wrapped sections
 $w_f/s_f = 1$ (FRP strips adjacent to one another).
 In (11.3) $\sin \theta + \cos \theta$ is replaced with $(\cot \theta + \csc \theta) \sin \alpha$ which is more a generalised expression,
 where θ is the angle of the crack direction (see KANEPE).
 This later relation, considered as a function $V_f(\theta, \alpha)$, is implemented for every different fiber orientation α_i ,
 as well as for 2 crack directions, $\theta = 45^\circ$ and $\theta = -45^\circ$ to take into consideration the cyclic seismic loading.
 orientation 1: $\theta = b_1 + 90^\circ = 90.00$
 $V_f = \text{Min}(|V_f(45, \theta)|, |V_f(-45, \theta)|)$, with:

total thickness per orientation, $tf1 = NL*t/NoDir = 1.00$
 $dfv = d$ (figure 11.2, ACI 440) = 470.00
 ffe ((11-5), ACI 440) = 328.00
 $Ef = 82000.00$
 $fe = 0.004$, from (11.6a), ACI 440
with $fu = 0.009$
From (11-11), ACI 440: $Vs + Vf \leq 479549.663$
 $bw*d = *d*d/4 = 125663.706$

End Of Calculation of Shear Capacity ratio for element: column JCC1 of floor 1
At local axis: 2

Start Of Calculation of Chord Rotation Capacity for element: column JCC1 of floor 1

At local axis: 3
Integration Section: (b)
Section Type: rcjcs

Constant Properties

Knowledge Factor, = 1.00
Chord Rotation is generally considered as Deformation-Controlled Action according to Table C7-1, ASCE 41-17.
Mean strengths are used for Deformation-Controlled Actions according to 7.5.1.3, ASCE 41-17
Consequently:
Jacket
New material of Primary Member: Concrete Strength, $fc = fcm = 33.00$
New material of Primary Member: Steel Strength, $fs = fsm = 555.56$
Concrete Elasticity, $Ec = 26999.444$
Steel Elasticity, $Es = 200000.00$
Existing Column
New material of Primary Member: Concrete Strength, $fc = fcm = 33.00$
New material of Primary Member: Steel Strength, $fs = fsm = 555.56$
Concrete Elasticity, $Ec = 26999.444$
Steel Elasticity, $Es = 200000.00$
External Diameter, $D = 500.00$
Internal Diameter, $D = 300.00$
Cover Thickness, $c = 25.00$
Element Length, $L = 3000.00$
Primary Member
Ribbed Bars
Ductile Steel
Without Detailing for Earthquake Resistance (including stirrups not closed at 135°)
Longitudinal Bars With Ends Lapped Starting at the End Sections
Inadequate Lap Length with $lb/ld = 0.30$
FRP Wrapping Data
Type: Carbon
Dry properties (design values)
Thickness, $t = 1.00$
Tensile Strength, $ffu = 840.00$
Tensile Modulus, $Ef = 82000.00$
Elongation, $efu = 0.009$
Number of directions, $NoDir = 1$
Fiber orientations, $bi: 0.00^\circ$
Number of layers, $NL = 1$
Radius of rounding corners, $R = 40.00$

Stepwise Properties

Bending Moment, $M = 0.07981876$
Shear Force, $V2 = 4779.203$
Shear Force, $V3 = 2.1566928E-013$
Axial Force, $F = -7387.302$
Longitudinal Reinforcement Area Distribution (in 2 divisions)

-Tension: $As_t = 0.00$

-Compression: $As_c = 3053.628$

Longitudinal Reinforcement Area Distribution (in 3 divisions)

-Tension: $As_{t,ten} = 1017.876$

-Compression: $As_{c,com} = 1017.876$

-Middle: $As_{c,mid} = 1017.876$

Mean Diameter of Tension Reinforcement, $Db_L = 18.00$

New component: From table 7-7, ASCE 41_17: Final chord rotation Capacity $u_{R} = 1.0^* u = 0.00090612$
 $u = y + p = 0.00090612$

- Calculation of y -

$y = (My * L_s / 3) / E_{eff} = 0.00090612$ ((4.29), Biskinis Phd)

$My = 2.2517E+008$

$L_s = M/V$ (with $L_s > 0.1 * L$ and $L_s < 2 * L$) = 300.00

From table 10.5, ASCE 41_17: $E_{eff} = factor * E_c * I_g = 2.4850E+013$

factor = 0.30

$A_g = 196349.541$

Mean concrete strength: $fc' = (fc'_{jacket} * Area_{jacket} + fc'_{core} * Area_{core}) / Area_{section} = 33.00$

$N = 7387.302$

$E_c * I_g = E_{c,jacket} * I_{g,jacket} + E_{c,core} * I_{g,core} = 8.2833E+013$

Calculation of Yielding Moment My

Calculation of y and My according to (7) - (8) in Biskinis and Fardis

$My = \text{Min}(My_{ten}, My_{com}) = 2.2517E+008$

$y = 6.4424840E-006$

My_{ten} (8c) = 2.2517E+008

y_{ten} (7c) = 61.8137

error of function (7c) = 0.00026387

My_{com} (8d) = 8.1922E+008

y_{com} (7d) = 63.67468

error of function (7d) = -0.0087488

with ((10.1), ASCE 41-17) $e_y = \text{Min}(e_y, 1.25 * e_y * (l_b / l_d)^{2/3}) = 0.0027778$

$e_{co} = 0.002$

$a_{pl} = 0.45$ ((9c) in Biskinis and Fardis for FRP Wrap)

$d_1 = 44.00$

$R = 250.00$

$v = 0.00101374$

$N = 7387.302$

$A_c = 196349.541$

((10.1), ASCE 41-17) $e_y = \text{Min}(e_y, 1.25 * e_y * (l_b / l_d)^{2/3}) = 0.23280363$

with fc^* ((12.3), ACI 440) = 37.11312

$fc = 33.00$

$f_l = 1.312$

$k = 1$

Effective FRP thickness, $t_f = NL * t * \text{Cos}(b_1) = 1.00$

e_{fe} ((12.5) and (12.7)) = 0.004

$f_u = 0.009$

$E_f = 82000.00$

Calculation of ratio l_b / l_d

Inadequate Lap Length with $l_b / l_d = 0.30$

- Calculation of p -

From table 10-9: $p = 0.00$

with:

- Columns controlled by inadequate development or splicing along the clear height because $l_b/l_d < 1$

shear control ratio $V_y E / V_{Co} I_{OE} = 0.23017425$

$d = d_{external} = 0.00$

$s = s_{external} = 0.00$

$t = s_1 + s_2 + 2 * t_f / b_w * (f_{fe} / f_s) = 0.00795744$

jacket: $s_1 = A_{v1} * (D_{c1} / 2) / (s_1 * A_g) = 0.0027646$

$A_{v1} = 78.53982$, is the area of stirrup

$D_{c1} = D_{ext} - 2 * cover - External\ Hoop\ Diameter = 440.00$, is the total Length of all stirrups parallel to loading

(shear) direction

$s_1 = 100.00$

core: $s_2 = A_{v2} * (D_{c2} / 2) / (s_2 * A_g) = 0.00046968$

$A_{v2} = 50.26548$, is the area of stirrup

$D_{c2} = D_{int} - Internal\ Hoop\ Diameter = 292.00$, is the total Length of all stirrups parallel to loading (shear)

direction

$s_2 = 250.00$

The term $2 * t_f / b_w * (f_{fe} / f_s)$ is implemented to account for FRP contribution

where $f = 2 * t_f / b_w$ is FRP ratio (EC8 - 3, A.4.4.3(6)) and f_{fe} / f_s normalises f to steel strength

All these variables have already been given in Shear control ratio calculation.

For the normalisation f_s of jacket is used.

$NUD = 7387.302$

$A_g = 196349.541$

$f_{cE} = (f_{c_jacket} * Area_jacket + f_{c_core} * Area_core) / section_area = 33.00$

$f_{yIE} = (f_{y_ext_Long_Reinf} * Area_ext_Long_Reinf + f_{y_int_Long_Reinf} * Area_int_Long_Reinf) / Area_Tot_Long_Rein = 2.1219958E-314$

$f_{yTE} = (f_{y_ext_Trans_Reinf} * Area_ext_Trans_Reinf + f_{y_int_Trans_Reinf} * Area_int_Trans_Reinf) / Area_Tot_Trans_Rein = 555.56$

$p_l = Area_Tot_Long_Rein / (A_g) = 0.015552$

$f_{cE} = 33.00$

End Of Calculation of Chord Rotation Capacity for element: column JCC1 of floor 1

At local axis: 3

Integration Section: (b)

Calculation No. 9

column C1, Floor 1



Limit State: Life Safety (data interpolation between analysis steps 1 and 2)

Analysis: Uniform +X

Check: Shear capacity VRd

Edge: Start

Local Axis: (2)



Start Of Calculation of Shear Capacity for element: column JCC1 of floor 1

At local axis: 2

Integration Section: (a)

Section Type: rcjcs

Constant Properties

Knowledge Factor, $\gamma = 1.00$

Member Shear Force is generally considered as Force-Controlled Action according to Table C7-1, ASCE 41-17.

Lower-bound strengths are used for Force-Controlled Actions according to 7.5.1.3, ASCE 41-17

Consequently:

Jacket

New material of Primary Member: Concrete Strength, $f_c = f_{c_lower_bound} = 25.00$

New material of Primary Member: Steel Strength, $f_s = f_{s_lower_bound} = 500.00$

Concrete Elasticity, $E_c = 26999.444$

Steel Elasticity, $E_s = 200000.00$

Existing Column

New material of Primary Member: Concrete Strength, $f_c = f_{c_lower_bound} = 25.00$

New material of Primary Member: Steel Strength, $f_s = f_{s_lower_bound} = 500.00$

Concrete Elasticity, $E_c = 26999.444$

Steel Elasticity, $E_s = 200000.00$

#####

Note: Especially for the calculation of γ for displacement ductility demand, the expected (mean value) strengths are used (7.5.1.3, ASCE 41-17) because bending is considered as Deformation-Controlled Action (Table C7-1, ASCE 41-17).

Jacket

New material: Concrete Strength, $f_c = f_{cm} = 33.00$

New material: Steel Strength, $f_s = f_{sm} = 555.56$

Existing Column

New material: Concrete Strength, $f_c = f_{cm} = 33.00$

New material: Steel Strength, $f_s = f_{sm} = 555.56$

#####

External Diameter, $D = 500.00$

Internal Diameter, $D = 300.00$

Cover Thickness, $c = 25.00$

Element Length, $L = 3000.00$

Primary Member

Ribbed Bars

Ductile Steel

Without Detailing for Earthquake Resistance (including stirrups not closed at 135°)

Longitudinal Bars With Ends Lapped Starting at the End Sections

Inadequate Lap Length with $l_o/l_{ou,min} = l_b/l_d = 0.30$

FRP Wrapping Data

Type: Carbon

Dry properties (design values)

Thickness, $t = 1.00$

Tensile Strength, $f_{fu} = 840.00$

Tensile Modulus, $E_f = 82000.00$

Elongation, $\epsilon_{fu} = 0.009$

Number of directions, $NoDir = 1$

Fiber orientations, $b_i = 0.00^\circ$

Number of layers, $NL = 1$

Radius of rounding corners, R = 40.00

Stepwise Properties

EDGE -A-

Bending Moment, Ma = -2.2653E+007

Shear Force, Va = -7549.016

EDGE -B-

Bending Moment, Mb = 0.12607815

Shear Force, Vb = 7549.016

BOTH EDGES

Axial Force, F = -7386.194

Longitudinal Reinforcement Area Distribution (in 2 divisions)

-Tension: Aslt = 1272.345

-Compression: Aslc = 1781.283

Longitudinal Reinforcement Area Distribution (in 3 divisions)

-Tension: Asl,ten = 1017.876

-Compression: Asl,com = 1017.876

-Middle: Asl,mid = 1017.876

Mean Diameter of Tension Reinforcement, DbL,ten = 18.00

New component: From table 7-7, ASCE 41_17: Final Shear Capacity VR = 1.0*Vn = 515957.072

Vn ((10.3), ASCE 41-17) = knl*VCol0 = 515957.072

VCol = 515957.072

knl = 1.00

displacement_ductility_demand = 0.02781594

NOTE: In expression (10-3) 'Vs = Av*fy*d/s' is replaced by 'Vs+ f*Vf' where Vf is the contribution of FRPs (11.3), ACI 440).

= 1 (normal-weight concrete)

Mean concrete strength: fc' = (fc'_jacket*Area_jacket + fc'_core*Area_core)/Area_section = 25.00, but fc'^0.5 <= 8.3 MPa (22.5.3.1, ACI 318-14)

M/Vd = 4.00

Mu = 2.2653E+007

Vu = 7549.016

d = 0.8*D = 400.00

Nu = 7386.194

Ag = 196349.541

From (11.5.4.8), ACI 318-14: Vs = Vs1 + Vs2 = 246740.11

Vs1 = 246740.11 is calculated for jacket, with:

Av = /2*A_stirrup = 123370.055

fy = 500.00

s = 100.00

Vs1 is multiplied by Col1 = 1.00

s/d = 0.25

Vs2 = 0.00 is calculated for core, with:

Av = /2*A_stirrup = 78956.835

fy = 500.00

s = 250.00

Vs2 is multiplied by Col2 = 0.00

s/d = 1.04167

Vf ((11-3)-(11.4), ACI 440) = 308320.00

f = 0.95, for fully-wrapped sections

wf/sf = 1 (FRP strips adjacent to one another).

In (11.3) sin + cos is replaced with (cot + cota)sina which is more a generalised expression, where is the angle of the crack direction (see KANEPE).

This later relation, considered as a function Vf(,), is implemented for every different fiber orientation ai, as well as for 2 crack directions, = 45° and = -45° to take into consideration the cyclic seismic loading.

orientation 1: 1 = b1 + 90° = 90.00

Vf = Min(|Vf(45, 1)|, |Vf(-45,a1)|), with:

total thickness per orientation, tf1 = NL*t/NoDir = 1.00

dfv = d (figure 11.2, ACI 440) = 470.00

$f_{fe} ((11-5), ACI 440) = 328.00$
 $E_f = 82000.00$
 $f_e = 0.004$, from (11.6a), ACI 440
with $f_u = 0.009$
From (11-11), ACI 440: $V_s + V_f \leq 417394.406$
 $b_w*d = *d*d/4 = 125663.706$

displacement_ductility_demand is calculated as / y

- Calculation of / y for END A -
for rotation axis 3 and integ. section (a)

From analysis, chord rotation = 0.00025211
 $y = (M_y*L_s/3)/E_{eff} = 0.00906345$ ((4.29), Biskinis Phd)
 $M_y = 2.2517E+008$
 $L_s = M/V$ (with $L_s > 0.1*L$ and $L_s < 2*L$) = 3000.736
From table 10.5, ASCE 41_17: $E_{eff} = factor*E_c*I_g = 2.4850E+013$
factor = 0.30
 $A_g = 196349.541$
Mean concrete strength: $f_c' = (f_c'_{jacket}*Area_{jacket} + f_c'_{core}*Area_{core})/Area_{section} = 33.00$
 $N = 7386.194$
 $E_c*I_g = E_c*_{jacket}*I_g*_{jacket} + E_c*_{core}*I_g*_{core} = 8.2833E+013$

Calculation of Yielding Moment M_y

Calculation of y and M_y according to (7) - (8) in Biskinis and Fardis

$M_y = \text{Min}(M_{y_ten}, M_{y_com}) = 2.2517E+008$
 $y = 6.4424821E-006$
 $M_{y_ten} (8c) = 2.2517E+008$
 $_{ten} (7c) = 61.81367$
error of function (7c) = 0.00026388
 $M_{y_com} (8d) = 8.1922E+008$
 $_{com} (7d) = 63.67467$
error of function (7d) = -0.00874883
with ((10.1), ASCE 41-17) $e_y = \text{Min}(e_y, 1.25*e_y*(l_b/l_d)^{2/3}) = 0.0027778$
 $e_{co} = 0.002$
 $a_{pl} = 0.45$ ((9c) in Biskinis and Fardis for FRP Wrap)
 $d_1 = 44.00$
 $R = 250.00$
 $v = 0.00101359$
 $N = 7386.194$
 $A_c = 196349.541$
((10.1), ASCE 41-17) = $\text{Min}(, 1.25* *(l_b/l_d)^{2/3}) = 0.23280363$
with $f_c' ((12.3), ACI 440) = 37.11312$
 $f_c = 33.00$
 $f_l = 1.312$
 $k = 1$
Effective FRP thickness, $t_f = NL*t*\text{Cos}(b_1) = 1.00$
 $e_{fe} ((12.5) \text{ and } (12.7)) = 0.004$
 $f_u = 0.009$
 $E_f = 82000.00$

Calculation of ratio l_b/l_d

Inadequate Lap Length with $l_b/l_d = 0.30$

End Of Calculation of Shear Capacity for element: column JCC1 of floor 1
At local axis: 2
Integration Section: (a)

Calculation No. 10

column C1, Floor 1


Limit State: Life Safety (data interpolation between analysis steps 1 and 2)

Analysis: Uniform +X

Check: Chord rotation capacity (θ)

Edge: Start

Local Axis: (2)



Start Of Calculation of Shear Capacity ratio for element: column JCC1 of floor 1

At Shear local axis: 3

(Bending local axis: 2)

Section Type: rcjcs

Constant Properties

Knowledge Factor, $\phi = 1.00$

Mean strength values are used for both shear and moment calculations.

Consequently:

Jacket

New material of Primary Member: Concrete Strength, $f_c = f_{cm} = 33.00$

New material of Primary Member: Steel Strength, $f_s = f_{sm} = 555.56$

Concrete Elasticity, $E_c = 26999.444$

Steel Elasticity, $E_s = 200000.00$

Existing Column

New material of Primary Member: Concrete Strength, $f_c = f_{cm} = 33.00$

New material of Primary Member: Steel Strength, $f_s = f_{sm} = 555.56$

Concrete Elasticity, $E_c = 26999.444$

Steel Elasticity, $E_s = 200000.00$

#####

Note: Especially for the calculation of moment strengths,

the above steel re-bar strengths are multiplied by 1.25 according to R18.6.5, ACI 318-14

Jacket

New material: Steel Strength, $f_s = 1.25 \cdot f_{sm} = 694.45$

Existing Column

New material: Steel Strength, $f_s = 1.25 \cdot f_{sm} = 694.45$

#####

External Diameter, D = 500.00
Internal Diameter, D = 300.00
Cover Thickness, c = 25.00
Mean Confinement Factor overall section = 1.51481
Element Length, L = 3000.00
Primary Member
Ribbed Bars
Ductile Steel
Without Detailing for Earthquake Resistance (including stirrups not closed at 135°)
Longitudinal Bars With Ends Lapped Starting at the End Sections
Inadequate Lap Length with $l_o/l_{o,min}$ = 0.30
FRP Wrapping Data
Type: Carbon
Dry properties (design values)
Thickness, t = 1.00
Tensile Strength, f_{fu} = 840.00
Tensile Modulus, E_f = 82000.00
Elongation, $ε_{fu}$ = 0.009
Number of directions, NoDir = 1
Fiber orientations, b_i : 0.00°
Number of layers, NL = 1
Radius of rounding corners, R = 40.00

Stepwise Properties

At local axis: 3
EDGE -A-
Shear Force, V_a = 3.4807814E-030
EDGE -B-
Shear Force, V_b = -3.4807814E-030
BOTH EDGES
Axial Force, F = -7389.214
Longitudinal Reinforcement Area Distribution (in 2 divisions)
-Tension: $A_{sl,t}$ = 0.00
-Compression: $A_{sl,c}$ = 3053.628
Longitudinal Reinforcement Area Distribution (in 3 divisions)
-Tension: $A_{sl,ten}$ = 1017.876
-Compression: $A_{sl,com}$ = 1017.876
-Middle: $A_{sl,mid}$ = 1017.876

Calculation of Shear Capacity ratio, V_e/V_r = 0.23017425

Member Controlled by Flexure ($V_e/V_r < 1$)

Calculation of Shear Demand from fig. R18.6.5, ACI 318-14 $V_e = (M_{pr1} + M_{pr2})/l_n = 162459.651$
with

$M_{pr1} = \text{Max}(M_{u1+}, M_{u1-}) = 2.4369E+008$

$M_{u1+} = 2.4369E+008$, is the ultimate moment strength at the edge 1 of the member in the actual moment direction which is defined for the static loading combination

$M_{u1-} = 2.4369E+008$, is the ultimate moment strength at the edge 1 of the member in the opposite moment direction which is defined for the static loading combination

$M_{pr2} = \text{Max}(M_{u2+}, M_{u2-}) = 2.4369E+008$

$M_{u2+} = 2.4369E+008$, is the ultimate moment strength at the edge 2 of the member in the actual moment direction which is defined for the the static loading combination

$M_{u2-} = 2.4369E+008$, is the ultimate moment strength at the edge 2 of the member in the opposite moment direction which is defined for the the static loading combination

Calculation of M_{u1+}

Calculation of ultimate Moment Strength ((3.67), Biskinis Phd), M_u

$M_u = 2.4369E+008$

= 0.80285146
' = 0.71403327
error of function (3.68), Biskinis Phd = 27987.158
From 5A.2, TBDY: $f_{cc} = f_c \cdot c = 49.98874$
conf. factor $c = 1.51481$
 $f_c = 33.00$
From 10.3.5, ASCE 41-17, Final value of f_y : $f_y \cdot \text{Min}(1, 1.25 \cdot (l_b/l_d)^{2/3}) = 389.0139$
 $l_b/l_d = 0.30$
 $d_1 = 44.00$
 $R = 250.00$
 $v = 0.00100813$
 $N = 7389.214$
 $A_c = 196349.541$
 $= \cdot \text{Min}(1, 1.25 \cdot (l_b/l_d)^{2/3}) = 0.1620683$

Calculation of ratio l_b/l_d

Inadequate Lap Length with $l_b/l_d = 0.30$

Calculation of μ_{1-}

Calculation of ultimate Moment Strength ((3.67), Biskinis Phd), μ
 $\mu = 2.4369E+008$

= 0.80285146
' = 0.71403327
error of function (3.68), Biskinis Phd = 27987.158
From 5A.2, TBDY: $f_{cc} = f_c \cdot c = 49.98874$
conf. factor $c = 1.51481$
 $f_c = 33.00$
From 10.3.5, ASCE 41-17, Final value of f_y : $f_y \cdot \text{Min}(1, 1.25 \cdot (l_b/l_d)^{2/3}) = 389.0139$
 $l_b/l_d = 0.30$
 $d_1 = 44.00$
 $R = 250.00$
 $v = 0.00100813$
 $N = 7389.214$
 $A_c = 196349.541$
 $= \cdot \text{Min}(1, 1.25 \cdot (l_b/l_d)^{2/3}) = 0.1620683$

Calculation of ratio l_b/l_d

Inadequate Lap Length with $l_b/l_d = 0.30$

Calculation of μ_{2+}

Calculation of ultimate Moment Strength ((3.67), Biskinis Phd), μ
 $\mu = 2.4369E+008$

= 0.80285146
' = 0.71403327
error of function (3.68), Biskinis Phd = 27987.158
From 5A.2, TBDY: $f_{cc} = f_c \cdot c = 49.98874$
conf. factor $c = 1.51481$
 $f_c = 33.00$
From 10.3.5, ASCE 41-17, Final value of f_y : $f_y \cdot \text{Min}(1, 1.25 \cdot (l_b/l_d)^{2/3}) = 389.0139$
 $l_b/l_d = 0.30$
 $d_1 = 44.00$

R = 250.00
v = 0.00100813
N = 7389.214
Ac = 196349.541
= *Min(1,1.25*(lb/d)^ 2/3) = 0.1620683

Calculation of ratio lb/d

Inadequate Lap Length with lb/d = 0.30

Calculation of Mu2-

Calculation of ultimate Moment Strength ((3.67), Biskinis Phd), Mu
Mu = 2.4369E+008

= 0.80285146
' = 0.71403327
error of function (3.68), Biskinis Phd = 27987.158
From 5A.2, TBDY: fcc = fc* c = 49.98874
conf. factor c = 1.51481
fc = 33.00
From 10.3.5, ASCE 41-17, Final value of fy: fy*Min(1,1.25*(lb/d)^ 2/3) = 389.0139
lb/d = 0.30
d1 = 44.00
R = 250.00
v = 0.00100813
N = 7389.214
Ac = 196349.541
= *Min(1,1.25*(lb/d)^ 2/3) = 0.1620683

Calculation of ratio lb/d

Inadequate Lap Length with lb/d = 0.30

Calculation of Shear Strength Vr = Min(Vr1,Vr2) = 705811.584

Calculation of Shear Strength at edge 1, Vr1 = 705811.584

Vr1 = VCol ((10.3), ASCE 41-17) = knl*VCol0
VCol0 = 705811.584
knl = 1 (zero step-static loading)

NOTE: In expression (10-3) 'Vs = Av*fy*d/s' is replaced by 'Vs+ f*Vf'
where Vf is the contribution of FRPs (11.3), ACI 440).

= 1 (normal-weight concrete)
Mean concrete strength: fc' = (fc'_jacket*Area_jacket + fc'_core*Area_core)/Area_section = 33.00, but fc'^0.5 <= 8.3
MPa (22.5.3.1, ACI 318-14)
M/Vd = 2.00
Mu = 1.2438899E-011
Vu = 3.4807814E-030
d = 0.8*D = 400.00
Nu = 7389.214
Ag = 196349.541
From (11.5.4.8), ACI 318-14: Vs = Vs1 + Vs2 = 274157.871
Vs1 = 274157.871 is calculated for jacket, with:
Av = /2*A_stirup = 123370.055
fy = 555.56
s = 100.00

Vs1 is multiplied by Col1 = 1.00
s/d = 0.25

Vs2 = 0.00 is calculated for core, with:

$$A_v = \sqrt{2} \cdot A_{\text{stirrup}} = 78956.835$$

$$f_y = 555.56$$

$$s = 250.00$$

Vs2 is multiplied by Col2 = 0.00

$$s/d = 1.04167$$

Vf ((11-3)-(11.4), ACI 440) = 308320.00

$$f = 0.95, \text{ for fully-wrapped sections}$$

wf/sf = 1 (FRP strips adjacent to one another).

In (11.3) $\sin \theta + \cos \theta$ is replaced with $(\cot \theta + \csc \theta) \sin \alpha$ which is more a generalised expression, where θ is the angle of the crack direction (see KANEPE).

This later relation, considered as a function $V_f(\theta, \alpha)$, is implemented for every different fiber orientation α_i , as well as for 2 crack directions, $\theta = 45^\circ$ and $\theta = -45^\circ$ to take into consideration the cyclic seismic loading.

orientation 1: $\theta = b_1 + 90^\circ = 90.00$

$V_f = \text{Min}(|V_f(45, \theta)|, |V_f(-45, \alpha)|)$, with:

total thickness per orientation, $t_{f1} = N_L \cdot t / N_{\text{Dir}} = 1.00$

$d_{fv} = d$ (figure 11.2, ACI 440) = 470.00

$f_{fe}((11-5), \text{ACI 440}) = 328.00$

$$E_f = 82000.00$$

$$f_e = 0.004, \text{ from (11.6a), ACI 440}$$

$$\text{with } f_u = 0.009$$

From (11-11), ACI 440: $V_s + V_f \leq 479549.663$

$$b_w \cdot d = \sqrt{4} \cdot d = 125663.706$$

Calculation of Shear Strength at edge 2, $V_{r2} = 705811.584$

$V_{r2} = V_{\text{Col}}((10.3), \text{ASCE 41-17}) = k_{nl} \cdot V_{\text{ColO}}$

$$V_{\text{ColO}} = 705811.584$$

$k_{nl} = 1$ (zero step-static loading)

NOTE: In expression (10-3) ' $V_s = A_v \cdot f_y \cdot d / s$ ' is replaced by ' $V_s + f \cdot V_f$ ' where V_f is the contribution of FRPs (11.3), ACI 440).

 $\gamma_c = 1$ (normal-weight concrete)

Mean concrete strength: $f'_c = (f'_{c, \text{jacket}} \cdot \text{Area}_{\text{jacket}} + f'_{c, \text{core}} \cdot \text{Area}_{\text{core}}) / \text{Area}_{\text{section}} = 33.00$, but $f'_c^{0.5} \leq 8.3$ MPa (22.5.3.1, ACI 318-14)

$$M / V d = 2.00$$

$$\mu_u = 1.2438899 \text{E-}011$$

$$V_u = 3.4807814 \text{E-}030$$

$$d = 0.8 \cdot D = 400.00$$

$$N_u = 7389.214$$

$$A_g = 196349.541$$

From (11.5.4.8), ACI 318-14: $V_s = V_{s1} + V_{s2} = 274157.871$

$V_{s1} = 274157.871$ is calculated for jacket, with:

$$A_v = \sqrt{2} \cdot A_{\text{stirrup}} = 123370.055$$

$$f_y = 555.56$$

$$s = 100.00$$

V_{s1} is multiplied by Col1 = 1.00

$$s/d = 0.25$$

$V_{s2} = 0.00$ is calculated for core, with:

$$A_v = \sqrt{2} \cdot A_{\text{stirrup}} = 78956.835$$

$$f_y = 555.56$$

$$s = 250.00$$

V_{s2} is multiplied by Col2 = 0.00

$$s/d = 1.04167$$

Vf ((11-3)-(11.4), ACI 440) = 308320.00

$$f = 0.95, \text{ for fully-wrapped sections}$$

wf/sf = 1 (FRP strips adjacent to one another).

In (11.3) $\sin \theta + \cos \theta$ is replaced with $(\cot \theta + \csc \theta) \sin \alpha$ which is more a generalised expression, where θ is the angle of the crack direction (see KANEPE).

This later relation, considered as a function $V_f(\theta, \alpha)$, is implemented for every different fiber orientation α_i , as well as for 2 crack directions, $\theta = 45^\circ$ and $\theta = -45^\circ$ to take into consideration the cyclic seismic loading.

orientation 1: $\theta = b_1 + 90^\circ = 90.00$

$V_f = \text{Min}(|V_f(45, \theta)|, |V_f(-45, \alpha)|)$, with:

total thickness per orientation, $t_{f1} = N_L \cdot t / N_{\text{Dir}} = 1.00$

dfv = d (figure 11.2, ACI 440) = 470.00
ffe ((11-5), ACI 440) = 328.00
Ef = 82000.00
fe = 0.004, from (11.6a), ACI 440
with fu = 0.009
From (11-11), ACI 440: Vs + Vf <= 479549.663
bw*d = *d*d/4 = 125663.706

End Of Calculation of Shear Capacity ratio for element: column JCC1 of floor 1
At local axis: 3

Start Of Calculation of Shear Capacity ratio for element: column JCC1 of floor 1
At Shear local axis: 2
(Bending local axis: 3)
Section Type: rcjcs

Constant Properties

Knowledge Factor, = 1.00
Mean strength values are used for both shear and moment calculations.
Consequently:

Jacket

New material of Primary Member: Concrete Strength, fc = fcm = 33.00

New material of Primary Member: Steel Strength, fs = fsm = 555.56

Concrete Elasticity, Ec = 26999.444

Steel Elasticity, Es = 200000.00

Existing Column

New material of Primary Member: Concrete Strength, fc = fcm = 33.00

New material of Primary Member: Steel Strength, fs = fsm = 555.56

Concrete Elasticity, Ec = 26999.444

Steel Elasticity, Es = 200000.00

#####

Note: Especially for the calculation of moment strengths,
the above steel re-bar strengths are multiplied by 1.25 according to R18.6.5, ACI 318-14

Jacket

New material: Steel Strength, fs = 1.25*fsm = 694.45

Existing Column

New material: Steel Strength, fs = 1.25*fsm = 694.45

#####

External Diameter, D = 500.00

Internal Diameter, D = 300.00

Cover Thickness, c = 25.00

Mean Confinement Factor overall section = 1.51481

Element Length, L = 3000.00

Primary Member

Ribbed Bars

Ductile Steel

Without Detailing for Earthquake Resistance (including stirrups not closed at 135°)

Longitudinal Bars With Ends Lapped Starting at the End Sections

Inadequate Lap Length with lo/lo,min = 0.30

FRP Wrapping Data

Type: Carbon

Dry properties (design values)

Thickness, t = 1.00

Tensile Strength, ffu = 840.00

Tensile Modulus, Ef = 82000.00

Elongation, efu = 0.009

Number of directions, NoDir = 1

Fiber orientations, bi: 0.00°

Number of layers, NL = 1

Radius of rounding corners, R = 40.00

Stepwise Properties

At local axis: 2

EDGE -A-

Shear Force, $V_a = -2.1312935E-046$

EDGE -B-

Shear Force, $V_b = 2.1312935E-046$

BOTH EDGES

Axial Force, $F = -7389.214$

Longitudinal Reinforcement Area Distribution (in 2 divisions)

-Tension: $A_{st} = 0.00$

-Compression: $A_{sc} = 3053.628$

Longitudinal Reinforcement Area Distribution (in 3 divisions)

-Tension: $A_{st,ten} = 1017.876$

-Compression: $A_{sc,com} = 1017.876$

-Middle: $A_{st,mid} = 1017.876$

Calculation of Shear Capacity ratio, $V_e/V_r = 0.23017425$

Member Controlled by Flexure ($V_e/V_r < 1$)

Calculation of Shear Demand from fig. R18.6.5, ACI 318-14 $V_e = (M_{pr1} + M_{pr2})/l_n = 162459.651$
with

$M_{pr1} = \text{Max}(M_{u1+}, M_{u1-}) = 2.4369E+008$

$M_{u1+} = 2.4369E+008$, is the ultimate moment strength at the edge 1 of the member in the actual moment direction which is defined for the static loading combination

$M_{u1-} = 2.4369E+008$, is the ultimate moment strength at the edge 1 of the member in the opposite moment direction which is defined for the static loading combination

$M_{pr2} = \text{Max}(M_{u2+}, M_{u2-}) = 2.4369E+008$

$M_{u2+} = 2.4369E+008$, is the ultimate moment strength at the edge 2 of the member in the actual moment direction which is defined for the the static loading combination

$M_{u2-} = 2.4369E+008$, is the ultimate moment strength at the edge 2 of the member in the opposite moment direction which is defined for the the static loading combination

Calculation of M_{u1+}

Calculation of ultimate Moment Strength ((3.67), Biskinis Phd), M_u

$M_u = 2.4369E+008$

$\phi = 0.80285146$

$\phi' = 0.71403327$

error of function (3.68), Biskinis Phd = 27987.158

From 5A.2, TBDY: $f_{cc} = f_c^* c = 49.98874$

conf. factor $c = 1.51481$

$f_c = 33.00$

From 10.3.5, ASCE 41-17, Final value of f_y : $f_y * \text{Min}(1, 1.25 * (l_b/l_d)^{2/3}) = 389.0139$

$l_b/l_d = 0.30$

$d_1 = 44.00$

$R = 250.00$

$v = 0.00100813$

$N = 7389.214$

$A_c = 196349.541$

$\phi * \text{Min}(1, 1.25 * (l_b/l_d)^{2/3}) = 0.1620683$

Calculation of ratio l_b/l_d

Inadequate Lap Length with $l_b/l_d = 0.30$

Calculation of M_{u1-}

Calculation of ultimate Moment Strength ((3.67), Biskinis Phd), Mu

Mu = 2.4369E+008

= 0.80285146

' = 0.71403327

error of function (3.68), Biskinis Phd = 27987.158

From 5A.2, TBDY: $f_{cc} = f_c \cdot c = 49.98874$

conf. factor $c = 1.51481$

$f_c = 33.00$

From 10.3.5, ASCE 41-17, Final value of fy: $f_y \cdot \text{Min}(1, 1.25 \cdot (l_b/d)^{2/3}) = 389.0139$

$l_b/d = 0.30$

$d_1 = 44.00$

$R = 250.00$

$v = 0.00100813$

$N = 7389.214$

$Ac = 196349.541$

= $\cdot \text{Min}(1, 1.25 \cdot (l_b/d)^{2/3}) = 0.1620683$

Calculation of ratio l_b/d

Inadequate Lap Length with $l_b/d = 0.30$

Calculation of Mu2+

Calculation of ultimate Moment Strength ((3.67), Biskinis Phd), Mu

Mu = 2.4369E+008

= 0.80285146

' = 0.71403327

error of function (3.68), Biskinis Phd = 27987.158

From 5A.2, TBDY: $f_{cc} = f_c \cdot c = 49.98874$

conf. factor $c = 1.51481$

$f_c = 33.00$

From 10.3.5, ASCE 41-17, Final value of fy: $f_y \cdot \text{Min}(1, 1.25 \cdot (l_b/d)^{2/3}) = 389.0139$

$l_b/d = 0.30$

$d_1 = 44.00$

$R = 250.00$

$v = 0.00100813$

$N = 7389.214$

$Ac = 196349.541$

= $\cdot \text{Min}(1, 1.25 \cdot (l_b/d)^{2/3}) = 0.1620683$

Calculation of ratio l_b/d

Inadequate Lap Length with $l_b/d = 0.30$

Calculation of Mu2-

Calculation of ultimate Moment Strength ((3.67), Biskinis Phd), Mu

Mu = 2.4369E+008

= 0.80285146

' = 0.71403327

error of function (3.68), Biskinis Phd = 27987.158

From 5A.2, TBDY: $f_{cc} = f_c \cdot c = 49.98874$

conf. factor $c = 1.51481$

$f_c = 33.00$

From 10.3.5, ASCE 41-17, Final value of f_y : $f_y \cdot \text{Min}(1, 1.25 \cdot (l_b/d)^{2/3}) = 389.0139$

$l_b/d = 0.30$

$d_1 = 44.00$

$R = 250.00$

$v = 0.00100813$

$N = 7389.214$

$A_c = 196349.541$

$= \cdot \text{Min}(1, 1.25 \cdot (l_b/d)^{2/3}) = 0.1620683$

Calculation of ratio l_b/d

Inadequate Lap Length with $l_b/d = 0.30$

Calculation of Shear Strength $V_r = \text{Min}(V_{r1}, V_{r2}) = 705811.584$

Calculation of Shear Strength at edge 1, $V_{r1} = 705811.584$

$V_{r1} = V_{\text{Col}} ((10.3), \text{ASCE 41-17}) = k_{nl} \cdot V_{\text{Col}0}$

$V_{\text{Col}0} = 705811.584$

$k_{nl} = 1$ (zero step-static loading)

NOTE: In expression (10-3) ' $V_s = A_v \cdot f_y \cdot d/s$ ' is replaced by ' $V_s + f \cdot V_f$ ' where V_f is the contribution of FRPs (11.3), ACI 440).

$= 1$ (normal-weight concrete)

Mean concrete strength: $f_c' = (f_c'_{\text{jacket}} \cdot \text{Area}_{\text{jacket}} + f_c'_{\text{core}} \cdot \text{Area}_{\text{core}}) / \text{Area}_{\text{section}} = 33.00$, but $f_c'^{0.5} \leq 8.3$ MPa (22.5.3.1, ACI 318-14)

$M/d = 2.00$

$M_u = 1.5940012\text{E}-011$

$V_u = 2.1312935\text{E}-046$

$d = 0.8 \cdot D = 400.00$

$N_u = 7389.214$

$A_g = 196349.541$

From (11.5.4.8), ACI 318-14: $V_s = V_{s1} + V_{s2} = 274157.871$

$V_{s1} = 274157.871$ is calculated for jacket, with:

$A_v = \frac{1}{2} \cdot A_{\text{stirrup}} = 123370.055$

$f_y = 555.56$

$s = 100.00$

V_{s1} is multiplied by $\text{Col}1 = 1.00$

$s/d = 0.25$

$V_{s2} = 0.00$ is calculated for core, with:

$A_v = \frac{1}{2} \cdot A_{\text{stirrup}} = 78956.835$

$f_y = 555.56$

$s = 250.00$

V_{s2} is multiplied by $\text{Col}2 = 0.00$

$s/d = 1.04167$

$V_f ((11-3)-(11.4), \text{ACI 440}) = 308320.00$

$f = 0.95$, for fully-wrapped sections

$w_f/s_f = 1$ (FRP strips adjacent to one another).

In (11.3) $\sin \theta + \cos \theta$ is replaced with $(\cot \theta + \csc \theta) \sin \alpha$ which is more a generalised expression, where θ is the angle of the crack direction (see KANEPE).

This later relation, considered as a function $V_f(\theta, \alpha)$, is implemented for every different fiber orientation α_i , as well as for 2 crack directions, $\theta = 45^\circ$ and $\theta = -45^\circ$ to take into consideration the cyclic seismic loading.

orientation 1: $\theta = 45^\circ + 90^\circ = 135^\circ$

$V_f = \text{Min}(|V_f(45, \theta)|, |V_f(-45, \alpha)|)$, with:

total thickness per orientation, $t_{f1} = N_L \cdot t / N_{\text{Dir}} = 1.00$

$d_{fv} = d$ (figure 11.2, ACI 440) = 470.00

$f_{fe} ((11-5), \text{ACI 440}) = 328.00$

$E_f = 82000.00$

$f_e = 0.004$, from (11.6a), ACI 440

with $f_u = 0.009$

From (11-11), ACI 440: $V_s + V_f \leq 479549.663$

$$b_w*d = *d*d/4 = 125663.706$$

Calculation of Shear Strength at edge 2, $V_{r2} = 705811.584$

$$V_{r2} = V_{CoI} \text{ ((10.3), ASCE 41-17)} = k_n l * V_{CoI0}$$

$$V_{CoI0} = 705811.584$$

$$k_n l = 1 \text{ (zero step-static loading)}$$

NOTE: In expression (10-3) ' $V_s = A_v * f_y * d / s$ ' is replaced by ' $V_s + f * V_f$ ' where V_f is the contribution of FRPs (11.3), ACI 440).

$$= 1 \text{ (normal-weight concrete)}$$

Mean concrete strength: $f_c' = (f_c'_{\text{jacket}} * \text{Area}_{\text{jacket}} + f_c'_{\text{core}} * \text{Area}_{\text{core}}) / \text{Area}_{\text{section}} = 33.00$, but $f_c'^{0.5} \leq 8.3$ MPa (22.5.3.1, ACI 318-14)

$$M/Vd = 2.00$$

$$\mu_u = 1.5940012E-011$$

$$\nu_u = 2.1312935E-046$$

$$d = 0.8 * D = 400.00$$

$$N_u = 7389.214$$

$$A_g = 196349.541$$

From (11.5.4.8), ACI 318-14: $V_s = V_{s1} + V_{s2} = 274157.871$

$V_{s1} = 274157.871$ is calculated for jacket, with:

$$A_v = /2 * A_{\text{stirrup}} = 123370.055$$

$$f_y = 555.56$$

$$s = 100.00$$

V_{s1} is multiplied by $Col1 = 1.00$

$$s/d = 0.25$$

$V_{s2} = 0.00$ is calculated for core, with:

$$A_v = /2 * A_{\text{stirrup}} = 78956.835$$

$$f_y = 555.56$$

$$s = 250.00$$

V_{s2} is multiplied by $Col2 = 0.00$

$$s/d = 1.04167$$

V_f ((11-3)-(11.4), ACI 440) = 308320.00

$$f = 0.95, \text{ for fully-wrapped sections}$$

$w_f/s_f = 1$ (FRP strips adjacent to one another).

In (11.3) $\sin + \cos$ is replaced with $(\cot + \cot_a) \sin a$ which is more a generalised expression, where a is the angle of the crack direction (see KANEPE).

This later relation, considered as a function $V_f(\theta, a)$, is implemented for every different fiber orientation a_i , as well as for 2 crack directions, $\theta = 45^\circ$ and $\theta = -45^\circ$ to take into consideration the cyclic seismic loading.

orientation 1: $\theta = b1 + 90^\circ = 90.00$

$$V_f = \text{Min}(|V_f(45, \theta)|, |V_f(-45, a1)|), \text{ with:}$$

total thickness per orientation, $t_{f1} = N_L * t / \text{NoDir} = 1.00$

$$d_{fv} = d \text{ (figure 11.2, ACI 440)} = 470.00$$

$$f_{fe} \text{ ((11-5), ACI 440)} = 328.00$$

$$E_f = 82000.00$$

$$f_e = 0.004, \text{ from (11.6a), ACI 440}$$

$$\text{with } f_u = 0.009$$

From (11-11), ACI 440: $V_s + V_f \leq 479549.663$

$$b_w*d = *d*d/4 = 125663.706$$

End Of Calculation of Shear Capacity ratio for element: column JCC1 of floor 1

At local axis: 2

Start Of Calculation of Chord Rotation Capacity for element: column JCC1 of floor 1

At local axis: 2

Integration Section: (a)

Section Type: rcjcs

Constant Properties

Knowledge Factor, $\gamma = 1.00$

Chord Rotation is generally considered as Deformation-Controlled Action according to Table C7-1, ASCE 41-17.

Mean strengths are used for Deformation-Controlled Actions according to 7.5.1.3, ASCE 41-17

Consequently:

Jacket

New material of Primary Member: Concrete Strength, $f_c = f_{cm} = 33.00$

New material of Primary Member: Steel Strength, $f_s = f_{sm} = 555.56$

Concrete Elasticity, $E_c = 26999.444$

Steel Elasticity, $E_s = 200000.00$

Existing Column

New material of Primary Member: Concrete Strength, $f_c = f_{cm} = 33.00$

New material of Primary Member: Steel Strength, $f_s = f_{sm} = 555.56$

Concrete Elasticity, $E_c = 26999.444$

Steel Elasticity, $E_s = 200000.00$

External Diameter, $D = 500.00$

Internal Diameter, $D = 300.00$

Cover Thickness, $c = 25.00$

Element Length, $L = 3000.00$

Primary Member

Ribbed Bars

Ductile Steel

Without Detailing for Earthquake Resistance (including stirrups not closed at 135°)

Longitudinal Bars With Ends Lapped Starting at the End Sections

Inadequate Lap Length with $l_b/l_d = 0.30$

FRP Wrapping Data

Type: Carbon

Dry properties (design values)

Thickness, $t = 1.00$

Tensile Strength, $f_{fu} = 840.00$

Tensile Modulus, $E_f = 82000.00$

Elongation, $e_{fu} = 0.009$

Number of directions, $N_{oDir} = 1$

Fiber orientations, $b_i = 0.00^\circ$

Number of layers, $N_L = 1$

Radius of rounding corners, $R = 40.00$

Stepwise Properties

Bending Moment, $M = 1.1533666E-009$

Shear Force, $V_2 = -7549.016$

Shear Force, $V_3 = -3.4066156E-013$

Axial Force, $F = -7386.194$

Longitudinal Reinforcement Area Distribution (in 2 divisions)

-Tension: $A_{sl,t} = 1272.345$

-Compression: $A_{sl,c} = 1781.283$

Longitudinal Reinforcement Area Distribution (in 3 divisions)

-Tension: $A_{sl,ten} = 1017.876$

-Compression: $A_{sl,com} = 1017.876$

-Middle: $A_{sl,mid} = 1017.876$

Mean Diameter of Tension Reinforcement, $D_{bL} = 18.00$

New component: From table 7-7, ASCE 41_17: Final chord rotation Capacity $u_{,R} = 1.0^*$ $u = 0.03453062$

$u = y + p = 0.03453062$

- Calculation of y -

$y = (M_y * L_s / 3) / E_{leff} = 0.00453062$ ((4.29), Biskinis Phd))

$M_y = 2.2517E+008$

$L_s = M/V$ (with $L_s > 0.1 * L$ and $L_s < 2 * L$) = 1500.00

From table 10.5, ASCE 41_17: $E_{leff} = factor * E_c * I_g = 2.4850E+013$

factor = 0.30

$A_g = 196349.541$

Mean concrete strength: $f_c' = (f_c'_{jacket} * Area_{jacket} + f_c'_{core} * Area_{core}) / Area_{section} = 33.00$

$N = 7386.194$

$$E_c I_g = E_{c_jacket} I_{g_jacket} + E_{c_core} I_{g_core} = 8.2833E+013$$

Calculation of Yielding Moment M_y

Calculation of ρ_y and M_y according to (7) - (8) in Biskinis and Fardis

$$M_y = \min(M_{y_ten}, M_{y_com}) = 2.2517E+008$$

$$y = 6.4424821E-006$$

$$M_{y_ten} (8c) = 2.2517E+008$$

$$\rho_{y_ten} (7c) = 61.81367$$

$$\text{error of function (7c)} = 0.00026388$$

$$M_{y_com} (8d) = 8.1922E+008$$

$$\rho_{y_com} (7d) = 63.67467$$

$$\text{error of function (7d)} = -0.00874883$$

$$\text{with } ((10.1), \text{ASCE 41-17}) \rho_y = \min(\rho_y, 1.25 \rho_y (l_b/l_d)^{2/3}) = 0.0027778$$

$$e_{co} = 0.002$$

$$a_{pl} = 0.45 \text{ ((9c) in Biskinis and Fardis for FRP Wrap)}$$

$$d_1 = 44.00$$

$$R = 250.00$$

$$v = 0.00101359$$

$$N = 7386.194$$

$$A_c = 196349.541$$

$$((10.1), \text{ASCE 41-17}) \rho_y = \min(\rho_y, 1.25 \rho_y (l_b/l_d)^{2/3}) = 0.23280363$$

$$\text{with } f_c \text{ ((12.3), ACI 440)} = 37.11312$$

$$f_c = 33.00$$

$$f_l = 1.312$$

$$k = 1$$

$$\text{Effective FRP thickness, } t_f = N L t \cos(b_1) = 1.00$$

$$e_{fe} \text{ ((12.5) and (12.7))} = 0.004$$

$$f_u = 0.009$$

$$E_f = 82000.00$$

Calculation of ratio l_b/l_d

Inadequate Lap Length with $l_b/l_d = 0.30$

- Calculation of ρ_p -

From table 10-9: $\rho_p = 0.03$

with:

- Columns controlled by inadequate development or splicing along the clear height because $l_b/l_d < 1$

$$\text{shear control ratio } V_y E / V_{CoI} O E = 0.23017425$$

$$d = d_{\text{external}} = 0.00$$

$$s = s_{\text{external}} = 0.00$$

$$t = s_1 + s_2 + 2 t_f / b_w (f_{fe} / f_s) = 0.00795744$$

$$\text{jacket: } s_1 = A_{v1} (f_c D_{c1} / 2) / (s_1 A_g) = 0.0027646$$

$$A_{v1} = 78.53982, \text{ is the area of stirrup}$$

$$D_{c1} = D_{\text{ext}} - 2 \cdot \text{cover} - \text{External Hoop Diameter} = 440.00, \text{ is the total Length of all stirrups parallel to loading}$$

(shear) direction

$$s_1 = 100.00$$

$$\text{core: } s_2 = A_{v2} (f_c D_{c2} / 2) / (s_2 A_g) = 0.00046968$$

$$A_{v2} = 50.26548, \text{ is the area of stirrup}$$

$$D_{c2} = D_{\text{int}} - \text{Internal Hoop Diameter} = 292.00, \text{ is the total Length of all stirrups parallel to loading (shear)}$$

direction

$$s_2 = 250.00$$

The term $2 t_f / b_w (f_{fe} / f_s)$ is implemented to account for FRP contribution

where $f = 2 t_f / b_w$ is FRP ratio (EC8 - 3, A.4.4.3(6)) and f_{fe} / f_s normalises f to steel strength

All these variables have already been given in Shear control ratio calculation.

For the normalisation f_s of jacket is used.

$$N U D = 7386.194$$

$$A_g = 196349.541$$

$$f_{cE} = (f_{c_jacket} \cdot \text{Area}_{\text{jacket}} + f_{c_core} \cdot \text{Area}_{\text{core}}) / \text{section_area} = 33.00$$

$$f_{yE} = (f_{y_ext_Long_Reinf} * Area_ext_Long_Reinf + f_{y_int_Long_Reinf} * Area_int_Long_Reinf) / Area_Tot_Long_Rein = 2.1219958E-314$$

$$f_{tE} = (f_{y_ext_Trans_Reinf} * Area_ext_Trans_Reinf + f_{y_int_Trans_Reinf} * Area_int_Trans_Reinf) / Area_Tot_Trans_Rein = 555.56$$

$$p_l = Area_Tot_Long_Rein / (A_g) = 0.015552$$

$$f_{cE} = 33.00$$

End Of Calculation of Chord Rotation Capacity for element: column JCC1 of floor 1
 At local axis: 2
 Integration Section: (a)

Calculation No. 11

column C1, Floor 1


Limit State: Life Safety (data interpolation between analysis steps 1 and 2)

Analysis: Uniform +X

Check: Shear capacity VRd

Edge: Start

Local Axis: (3)



Start Of Calculation of Shear Capacity for element: column JCC1 of floor 1

At local axis: 3

Integration Section: (a)

Section Type: rcjcs

Constant Properties

Knowledge Factor, = 1.00

Member Shear Force is generally considered as Force-Controlled Action according to Table C7-1, ASCE 41-17.

Lower-bound strengths are used for Force-Controlled Actions according to 7.5.1.3, ASCE 41-17

Consequently:

Jacket

New material of Primary Member: Concrete Strength, $f_c = f_{c_lower_bound} = 25.00$

New material of Primary Member: Steel Strength, $f_s = f_{s_lower_bound} = 500.00$

Concrete Elasticity, $E_c = 26999.444$

Steel Elasticity, $E_s = 200000.00$

```

Existing Column
New material of Primary Member: Concrete Strength, fc = fc_lower_bound = 25.00
New material of Primary Member: Steel Strength, fs = fs_lower_bound = 500.00
Concrete Elasticity, Ec = 26999.444
Steel Elasticity, Es = 200000.00
#####
Note: Especially for the calculation of  $\mu_y$  for displacement ductility demand,
the expected (mean value) strengths are used (7.5.1.3, ASCE 41-17) because bending is considered as
Deformation-Controlled Action (Table C7-1, ASCE 41-17).
Jacket
New material: Concrete Strength, fc = fcm = 33.00
New material: Steel Strength, fs = fsm = 555.56
Existing Column
New material: Concrete Strength, fc = fcm = 33.00
New material: Steel Strength, fs = fsm = 555.56
#####
External Diameter, D = 500.00
Internal Diameter, D = 300.00
Cover Thickness, c = 25.00
Element Length, L = 3000.00
Primary Member
Ribbed Bars
Ductile Steel
Without Detailing for Earthquake Resistance (including stirrups not closed at 135°)
Longitudinal Bars With Ends Lapped Starting at the End Sections
Inadequate Lap Length with  $l_o/l_{ou,min} = l_b/l_d = 0.30$ 
FRP Wrapping Data
Type: Carbon
Dry properties (design values)
Thickness, t = 1.00
Tensile Strength,  $f_{fu} = 840.00$ 
Tensile Modulus,  $E_f = 82000.00$ 
Elongation,  $e_{fu} = 0.009$ 
Number of directions, NoDir = 1
Fiber orientations,  $b_i = 0.00^\circ$ 
Number of layers, NL = 1
Radius of rounding corners, R = 40.00
-----

Stepwise Properties
-----
EDGE -A-
Bending Moment,  $M_a = 1.1533666E-009$ 
Shear Force,  $V_a = -3.4066156E-013$ 
EDGE -B-
Bending Moment,  $M_b = -1.3104847E-010$ 
Shear Force,  $V_b = 3.4066156E-013$ 
BOTH EDGES
Axial Force, F = -7386.194
Longitudinal Reinforcement Area Distribution (in 2 divisions)
-Tension:  $A_{sl,t} = 1272.345$ 
-Compression:  $A_{sl,c} = 1781.283$ 
Longitudinal Reinforcement Area Distribution (in 3 divisions)
-Tension:  $A_{sl,ten} = 1017.876$ 
-Compression:  $A_{sl,com} = 1017.876$ 
-Middle:  $A_{sl,mid} = 1017.876$ 
Mean Diameter of Tension Reinforcement,  $Db_{L,ten} = 18.00$ 
-----
-----

New component: From table 7-7, ASCE 41_17: Final Shear Capacity  $V_R = 1.0 \cdot V_n = 614519.737$ 
 $V_n ((10.3), ASCE 41-17) = knl \cdot V_{CoIO} = 614519.737$ 
 $V_{CoI} = 614519.737$ 
 $knl = 1.00$ 
displacement_ductility_demand = 0.00
-----

```

NOTE: In expression (10-3) ' $V_s = A_v \cdot f_y \cdot d / s$ ' is replaced by ' $V_s + f \cdot V_f$ ' where V_f is the contribution of FRPs (11.3), ACI 440).

= 1 (normal-weight concrete)

Mean concrete strength: $f_c' = (f_c'_{\text{jacket}} \cdot \text{Area}_{\text{jacket}} + f_c'_{\text{core}} \cdot \text{Area}_{\text{core}}) / \text{Area}_{\text{section}} = 25.00$, but $f_c'^{0.5} \leq 8.3$ MPa (22.5.3.1, ACI 318-14)

$M/Vd = 2.00$

$\mu_u = 1.1533666E-009$

$V_u = 3.4066156E-013$

$d = 0.8 \cdot D = 400.00$

$N_u = 7386.194$

$A_g = 196349.541$

From (11.5.4.8), ACI 318-14: $V_s = V_{s1} + V_{s2} = 246740.11$

$V_{s1} = 246740.11$ is calculated for jacket, with:

$A_v = \sqrt{2} \cdot A_{\text{stirrup}} = 123370.055$

$f_y = 500.00$

$s = 100.00$

V_{s1} is multiplied by $\text{Col1} = 1.00$

$s/d = 0.25$

$V_{s2} = 0.00$ is calculated for core, with:

$A_v = \sqrt{2} \cdot A_{\text{stirrup}} = 78956.835$

$f_y = 500.00$

$s = 250.00$

V_{s2} is multiplied by $\text{Col2} = 0.00$

$s/d = 1.04167$

V_f ((11-3)-(11.4), ACI 440) = 308320.00

$f = 0.95$, for fully-wrapped sections

$w_f/s_f = 1$ (FRP strips adjacent to one another).

In (11.3) $\sin + \cos$ is replaced with $(\cot + \csc) \sin \alpha$ which is more a generalised expression, where α is the angle of the crack direction (see KANEPE).

This later relation, considered as a function $V_f(\alpha)$, is implemented for every different fiber orientation α_i , as well as for 2 crack directions, $\alpha = 45^\circ$ and $\alpha = -45^\circ$ to take into consideration the cyclic seismic loading.

orientation 1: $\alpha = b1 + 90^\circ = 90.00$

$V_f = \text{Min}(|V_f(45, 1)|, |V_f(-45, a1)|)$, with:

total thickness per orientation, $t_{f1} = N_L \cdot t / N_{\text{Dir}} = 1.00$

$d_{fv} = d$ (figure 11.2, ACI 440) = 470.00

f_{fe} ((11-5), ACI 440) = 328.00

$E_f = 82000.00$

$f_e = 0.004$, from (11.6a), ACI 440

with $f_u = 0.009$

From (11-11), ACI 440: $V_s + V_f \leq 417394.406$

$b_w \cdot d = \sqrt{4} \cdot d^2 = 125663.706$

displacement ductility demand is calculated as δ / y

- Calculation of δ / y for END A -
for rotation axis 2 and integ. section (a)

From analysis, chord rotation $\theta = 1.5106917E-020$

$y = (M_y \cdot L_s / 3) / E_{\text{eff}} = 0.00453062$ ((4.29), Biskinis Phd)

$M_y = 2.2517E+008$

$L_s = M/V$ (with $L_s > 0.1 \cdot L$ and $L_s < 2 \cdot L$) = 1500.00

From table 10.5, ASCE 41_17: $E_{\text{eff}} = \text{factor} \cdot E_c \cdot I_g = 2.4850E+013$

factor = 0.30

$A_g = 196349.541$

Mean concrete strength: $f_c' = (f_c'_{\text{jacket}} \cdot \text{Area}_{\text{jacket}} + f_c'_{\text{core}} \cdot \text{Area}_{\text{core}}) / \text{Area}_{\text{section}} = 33.00$

$N = 7386.194$

$E_c \cdot I_g = E_{c_{\text{jacket}}} \cdot I_{g_{\text{jacket}}} + E_{c_{\text{core}}} \cdot I_{g_{\text{core}}} = 8.2833E+013$

Calculation of Yielding Moment M_y

Calculation of δ / y and M_y according to (7) - (8) in Biskinis and Fardis

$M_y = \text{Min}(M_{y_ten}, M_{y_com}) = 2.2517E+008$
 $y = 6.4424821E-006$
 $M_{y_ten} (8c) = 2.2517E+008$
 $_{ten} (7c) = 61.81367$
error of function (7c) = 0.00026388
 $M_{y_com} (8d) = 8.1922E+008$
 $_{com} (7d) = 63.67467$
error of function (7d) = -0.00874883
with ((10.1), ASCE 41-17) $e_y = \text{Min}(e_y, 1.25 * e_y * (l_b / l_d)^{2/3}) = 0.0027778$
 $e_{co} = 0.002$
 $a_{pl} = 0.45$ ((9c) in Biskinis and Fardis for FRP Wrap)
 $d_1 = 44.00$
 $R = 250.00$
 $v = 0.00101359$
 $N = 7386.194$
 $A_c = 196349.541$
((10.1), ASCE 41-17) $= \text{Min}(, 1.25 * (l_b / l_d)^{2/3}) = 0.23280363$
with f_c^* ((12.3), ACI 440) = 37.11312
 $f_c = 33.00$
 $f_l = 1.312$
 $k = 1$
Effective FRP thickness, $t_f = N L * t * \text{Cos}(b_1) = 1.00$
 e_{fe} ((12.5) and (12.7)) = 0.004
 $f_u = 0.009$
 $E_f = 82000.00$

Calculation of ratio l_b / l_d

Inadequate Lap Length with $l_b / l_d = 0.30$

End Of Calculation of Shear Capacity for element: column JCC1 of floor 1

At local axis: 3

Integration Section: (a)

Calculation No. 12

column C1, Floor 1


Limit State: Life Safety (data interpolation between analysis steps 1 and 2)

Analysis: Uniform +X

Check: Chord rotation capacity (θ_u)

Edge: Start

Local Axis: (3)



Start Of Calculation of Shear Capacity ratio for element: column JCC1 of floor 1

At Shear local axis: 3
 (Bending local axis: 2)
 Section Type: rcjcs

Constant Properties

Knowledge Factor, $\gamma = 1.00$
 Mean strength values are used for both shear and moment calculations.
 Consequently:

Jacket

New material of Primary Member: Concrete Strength, $f_c = f_{cm} = 33.00$
 New material of Primary Member: Steel Strength, $f_s = f_{sm} = 555.56$
 Concrete Elasticity, $E_c = 26999.444$
 Steel Elasticity, $E_s = 200000.00$

Existing Column

New material of Primary Member: Concrete Strength, $f_c = f_{cm} = 33.00$
 New material of Primary Member: Steel Strength, $f_s = f_{sm} = 555.56$
 Concrete Elasticity, $E_c = 26999.444$
 Steel Elasticity, $E_s = 200000.00$

#####

Note: Especially for the calculation of moment strengths,
 the above steel re-bar strengths are multiplied by 1.25 according to R18.6.5, ACI 318-14

Jacket

New material: Steel Strength, $f_s = 1.25 * f_{sm} = 694.45$

Existing Column

New material: Steel Strength, $f_s = 1.25 * f_{sm} = 694.45$

#####

External Diameter, $D = 500.00$

Internal Diameter, $D = 300.00$

Cover Thickness, $c = 25.00$

Mean Confinement Factor overall section = 1.51481

Element Length, $L = 3000.00$

Primary Member

Ribbed Bars

Ductile Steel

Without Detailing for Earthquake Resistance (including stirrups not closed at 135°)

Longitudinal Bars With Ends Lapped Starting at the End Sections

Inadequate Lap Length with $l_o/l_{ou, min} = 0.30$

FRP Wrapping Data

Type: Carbon

Dry properties (design values)

Thickness, $t = 1.00$

Tensile Strength, $f_{fu} = 840.00$

Tensile Modulus, $E_f = 82000.00$

Elongation, $e_{fu} = 0.009$

Number of directions, $NoDir = 1$

Fiber orientations, $bi = 0.00^\circ$

Number of layers, $NL = 1$

Radius of rounding corners, $R = 40.00$

Stepwise Properties

At local axis: 3

EDGE -A-

Shear Force, $V_a = 3.4807814E-030$

EDGE -B-

Shear Force, $V_b = -3.4807814E-030$

BOTH EDGES

Axial Force, $F = -7389.214$

Longitudinal Reinforcement Area Distribution (in 2 divisions)

-Tension: $A_{st} = 0.00$

-Compression: $A_{sc} = 3053.628$

Longitudinal Reinforcement Area Distribution (in 3 divisions)

-Tension: $A_{st,ten} = 1017.876$

-Compression: $A_{sc,com} = 1017.876$

-Middle: $A_{s,mid} = 1017.876$

Calculation of Shear Capacity ratio, $V_e/V_r = 0.23017425$

Member Controlled by Flexure ($V_e/V_r < 1$)

Calculation of Shear Demand from fig. R18.6.5, ACI 318-14 $V_e = (M_{pr1} + M_{pr2})/l_n = 162459.651$

with

$M_{pr1} = \text{Max}(M_{u1+}, M_{u1-}) = 2.4369E+008$

$M_{u1+} = 2.4369E+008$, is the ultimate moment strength at the edge 1 of the member in the actual moment direction which is defined for the static loading combination

$M_{u1-} = 2.4369E+008$, is the ultimate moment strength at the edge 1 of the member in the opposite moment direction which is defined for the static loading combination

$M_{pr2} = \text{Max}(M_{u2+}, M_{u2-}) = 2.4369E+008$

$M_{u2+} = 2.4369E+008$, is the ultimate moment strength at the edge 2 of the member in the actual moment direction which is defined for the the static loading combination

$M_{u2-} = 2.4369E+008$, is the ultimate moment strength at the edge 2 of the member in the opposite moment direction which is defined for the the static loading combination

Calculation of M_{u1+}

Calculation of ultimate Moment Strength ((3.67), Biskinis Phd), M_u

$M_u = 2.4369E+008$

$\phi = 0.80285146$

$\phi' = 0.71403327$

error of function (3.68), Biskinis Phd = 27987.158

From 5A.2, TBDY: $f_{cc} = f_c^* c = 49.98874$

conf. factor $c = 1.51481$

$f_c = 33.00$

From 10.3.5, ASCE 41-17, Final value of f_y : $f_y \cdot \text{Min}(1, 1.25 \cdot (l_b/d)^{2/3}) = 389.0139$

$l_b/d = 0.30$

$d_1 = 44.00$

$R = 250.00$

$v = 0.00100813$

$N = 7389.214$

$A_c = 196349.541$

$\phi \cdot \text{Min}(1, 1.25 \cdot (l_b/d)^{2/3}) = 0.1620683$

Calculation of ratio l_b/d

Inadequate Lap Length with $l_b/d = 0.30$

Calculation of M_{u1-}

Calculation of ultimate Moment Strength ((3.67), Biskinis Phd), Mu

Mu = 2.4369E+008

= 0.80285146

' = 0.71403327

error of function (3.68), Biskinis Phd = 27987.158

From 5A.2, TBDY: $f_{cc} = f_c \cdot c = 49.98874$

conf. factor $c = 1.51481$

$f_c = 33.00$

From 10.3.5, ASCE 41-17, Final value of fy: $f_y \cdot \text{Min}(1, 1.25 \cdot (l_b/d)^{2/3}) = 389.0139$

$l_b/d = 0.30$

$d_1 = 44.00$

$R = 250.00$

$v = 0.00100813$

$N = 7389.214$

$Ac = 196349.541$

= $\cdot \text{Min}(1, 1.25 \cdot (l_b/d)^{2/3}) = 0.1620683$

Calculation of ratio l_b/d

Inadequate Lap Length with $l_b/d = 0.30$

Calculation of Mu2+

Calculation of ultimate Moment Strength ((3.67), Biskinis Phd), Mu

Mu = 2.4369E+008

= 0.80285146

' = 0.71403327

error of function (3.68), Biskinis Phd = 27987.158

From 5A.2, TBDY: $f_{cc} = f_c \cdot c = 49.98874$

conf. factor $c = 1.51481$

$f_c = 33.00$

From 10.3.5, ASCE 41-17, Final value of fy: $f_y \cdot \text{Min}(1, 1.25 \cdot (l_b/d)^{2/3}) = 389.0139$

$l_b/d = 0.30$

$d_1 = 44.00$

$R = 250.00$

$v = 0.00100813$

$N = 7389.214$

$Ac = 196349.541$

= $\cdot \text{Min}(1, 1.25 \cdot (l_b/d)^{2/3}) = 0.1620683$

Calculation of ratio l_b/d

Inadequate Lap Length with $l_b/d = 0.30$

Calculation of Mu2-

Calculation of ultimate Moment Strength ((3.67), Biskinis Phd), Mu

Mu = 2.4369E+008

= 0.80285146

' = 0.71403327

error of function (3.68), Biskinis Phd = 27987.158

From 5A.2, TBDY: $f_{cc} = f_c \cdot c = 49.98874$

conf. factor $c = 1.51481$

$f_c = 33.00$

From 10.3.5, ASCE 41-17, Final value of f_y : $f_y \cdot \text{Min}(1, 1.25 \cdot (l_b/d)^{2/3}) = 389.0139$

$l_b/d = 0.30$

$d_1 = 44.00$

$R = 250.00$

$v = 0.00100813$

$N = 7389.214$

$A_c = 196349.541$

$= \cdot \text{Min}(1, 1.25 \cdot (l_b/d)^{2/3}) = 0.1620683$

Calculation of ratio l_b/d

Inadequate Lap Length with $l_b/d = 0.30$

Calculation of Shear Strength $V_r = \text{Min}(V_{r1}, V_{r2}) = 705811.584$

Calculation of Shear Strength at edge 1, $V_{r1} = 705811.584$

$V_{r1} = V_{\text{Col}} ((10.3), \text{ASCE 41-17}) = k_{nl} \cdot V_{\text{Col}0}$

$V_{\text{Col}0} = 705811.584$

$k_{nl} = 1$ (zero step-static loading)

NOTE: In expression (10-3) ' $V_s = A_v \cdot f_y \cdot d/s$ ' is replaced by ' $V_s + f \cdot V_f$ ' where V_f is the contribution of FRPs (11.3), ACI 440).

$= 1$ (normal-weight concrete)

Mean concrete strength: $f_c' = (f_c'_{\text{jacket}} \cdot \text{Area}_{\text{jacket}} + f_c'_{\text{core}} \cdot \text{Area}_{\text{core}}) / \text{Area}_{\text{section}} = 33.00$, but $f_c'^{0.5} \leq 8.3$ MPa (22.5.3.1, ACI 318-14)

$M/d = 2.00$

$\mu_u = 1.2438899\text{E-}011$

$\nu_u = 3.4807814\text{E-}030$

$d = 0.8 \cdot D = 400.00$

$N_u = 7389.214$

$A_g = 196349.541$

From (11.5.4.8), ACI 318-14: $V_s = V_{s1} + V_{s2} = 274157.871$

$V_{s1} = 274157.871$ is calculated for jacket, with:

$A_v = \frac{1}{2} \cdot A_{\text{stirrup}} = 123370.055$

$f_y = 555.56$

$s = 100.00$

V_{s1} is multiplied by $\text{Col}1 = 1.00$

$s/d = 0.25$

$V_{s2} = 0.00$ is calculated for core, with:

$A_v = \frac{1}{2} \cdot A_{\text{stirrup}} = 78956.835$

$f_y = 555.56$

$s = 250.00$

V_{s2} is multiplied by $\text{Col}2 = 0.00$

$s/d = 1.04167$

$V_f ((11-3)-(11.4), \text{ACI 440}) = 308320.00$

$f = 0.95$, for fully-wrapped sections

$w_f/s_f = 1$ (FRP strips adjacent to one another).

In (11.3) $\sin \theta + \cos \theta$ is replaced with $(\cot \theta + \csc \theta) \sin \alpha$ which is more a generalised expression, where θ is the angle of the crack direction (see KANEPE).

This later relation, considered as a function $V_f(\theta, \alpha)$, is implemented for every different fiber orientation α_i , as well as for 2 crack directions, $\theta = 45^\circ$ and $\theta = -45^\circ$ to take into consideration the cyclic seismic loading.

orientation 1: $\theta = 45^\circ = 90.00$

$V_f = \text{Min}(|V_f(45, \theta)|, |V_f(-45, \alpha)|)$, with:

total thickness per orientation, $t_{f1} = N_L \cdot t / N_{\text{Dir}} = 1.00$

$d_{fv} = d$ (figure 11.2, ACI 440) = 470.00

$f_{fe} ((11-5), \text{ACI 440}) = 328.00$

$E_f = 82000.00$

$f_e = 0.004$, from (11.6a), ACI 440

with $f_u = 0.009$

From (11-11), ACI 440: $V_s + V_f \leq 479549.663$

$$b_w*d = *d*d/4 = 125663.706$$

Calculation of Shear Strength at edge 2, $V_{r2} = 705811.584$

$$V_{r2} = V_{CoI} \text{ ((10.3), ASCE 41-17)} = k_{nl} * V_{CoI0}$$

$$V_{CoI0} = 705811.584$$

$k_{nl} = 1$ (zero step-static loading)

NOTE: In expression (10-3) ' $V_s = A_v * f_y * d / s$ ' is replaced by ' $V_s + f * V_f$ ' where V_f is the contribution of FRPs (11.3), ACI 440).

$= 1$ (normal-weight concrete)

Mean concrete strength: $f_c' = (f_c'_{jacket} * Area_{jacket} + f_c'_{core} * Area_{core}) / Area_{section} = 33.00$, but $f_c'^{0.5} \leq 8.3$ MPa (22.5.3.1, ACI 318-14)

$$M/Vd = 2.00$$

$$\mu_u = 1.2438899E-011$$

$$V_u = 3.4807814E-030$$

$$d = 0.8 * D = 400.00$$

$$N_u = 7389.214$$

$$A_g = 196349.541$$

From (11.5.4.8), ACI 318-14: $V_s = V_{s1} + V_{s2} = 274157.871$

$V_{s1} = 274157.871$ is calculated for jacket, with:

$$A_v = /2 * A_{stirrup} = 123370.055$$

$$f_y = 555.56$$

$$s = 100.00$$

V_{s1} is multiplied by $Col1 = 1.00$

$$s/d = 0.25$$

$V_{s2} = 0.00$ is calculated for core, with:

$$A_v = /2 * A_{stirrup} = 78956.835$$

$$f_y = 555.56$$

$$s = 250.00$$

V_{s2} is multiplied by $Col2 = 0.00$

$$s/d = 1.04167$$

V_f ((11-3)-(11.4), ACI 440) = 308320.00

$f = 0.95$, for fully-wrapped sections

$w_f/s_f = 1$ (FRP strips adjacent to one another).

In (11.3) $\sin + \cos$ is replaced with $(\cot + \cot_a) \sin a$ which is more a generalised expression, where a is the angle of the crack direction (see KANEPE).

This later relation, considered as a function $V_f(\theta, a)$, is implemented for every different fiber orientation a_i , as well as for 2 crack directions, $\theta = 45^\circ$ and $\theta = -45^\circ$ to take into consideration the cyclic seismic loading.

orientation 1: $\theta = b1 + 90^\circ = 90.00$

$V_f = \text{Min}(|V_f(45, \theta)|, |V_f(-45, a1)|)$, with:

total thickness per orientation, $t_{f1} = N_L * t / \text{NoDir} = 1.00$

$d_{fv} = d$ (figure 11.2, ACI 440) = 470.00

f_{fe} ((11-5), ACI 440) = 328.00

$$E_f = 82000.00$$

$$f_e = 0.004, \text{ from (11.6a), ACI 440}$$

$$\text{with } f_u = 0.009$$

From (11-11), ACI 440: $V_s + V_f \leq 479549.663$

$$b_w*d = *d*d/4 = 125663.706$$

End Of Calculation of Shear Capacity ratio for element: column JCC1 of floor 1

At local axis: 3

Start Of Calculation of Shear Capacity ratio for element: column JCC1 of floor 1

At Shear local axis: 2

(Bending local axis: 3)

Section Type: rcjcs

Constant Properties

Knowledge Factor, $= 1.00$

Mean strength values are used for both shear and moment calculations.

Consequently:

Jacket

New material of Primary Member: Concrete Strength, $f_c = f_{cm} = 33.00$

New material of Primary Member: Steel Strength, $f_s = f_{sm} = 555.56$

Concrete Elasticity, $E_c = 26999.444$

Steel Elasticity, $E_s = 200000.00$

Existing Column

New material of Primary Member: Concrete Strength, $f_c = f_{cm} = 33.00$

New material of Primary Member: Steel Strength, $f_s = f_{sm} = 555.56$

Concrete Elasticity, $E_c = 26999.444$

Steel Elasticity, $E_s = 200000.00$

#####

Note: Especially for the calculation of moment strengths,

the above steel re-bar strengths are multiplied by 1.25 according to R18.6.5, ACI 318-14

Jacket

New material: Steel Strength, $f_s = 1.25 \cdot f_{sm} = 694.45$

Existing Column

New material: Steel Strength, $f_s = 1.25 \cdot f_{sm} = 694.45$

#####

External Diameter, $D = 500.00$

Internal Diameter, $D = 300.00$

Cover Thickness, $c = 25.00$

Mean Confinement Factor overall section = 1.51481

Element Length, $L = 3000.00$

Primary Member

Ribbed Bars

Ductile Steel

Without Detailing for Earthquake Resistance (including stirrups not closed at 135°)

Longitudinal Bars With Ends Lapped Starting at the End Sections

Inadequate Lap Length with $l_o/l_{ou, \min} = 0.30$

FRP Wrapping Data

Type: Carbon

Dry properties (design values)

Thickness, $t = 1.00$

Tensile Strength, $f_{fu} = 840.00$

Tensile Modulus, $E_f = 82000.00$

Elongation, $e_{fu} = 0.009$

Number of directions, $N_{oDir} = 1$

Fiber orientations, $b_i = 0.00^\circ$

Number of layers, $N_L = 1$

Radius of rounding corners, $R = 40.00$

Stepwise Properties

At local axis: 2

EDGE -A-

Shear Force, $V_a = -2.1312935E-046$

EDGE -B-

Shear Force, $V_b = 2.1312935E-046$

BOTH EDGES

Axial Force, $F = -7389.214$

Longitudinal Reinforcement Area Distribution (in 2 divisions)

-Tension: $A_{slt} = 0.00$

-Compression: $A_{slc} = 3053.628$

Longitudinal Reinforcement Area Distribution (in 3 divisions)

-Tension: $A_{sl, \text{ten}} = 1017.876$

-Compression: $A_{sl, \text{com}} = 1017.876$

-Middle: $A_{sl, \text{mid}} = 1017.876$

Calculation of Shear Capacity ratio, $V_e/V_r = 0.23017425$

Member Controlled by Flexure ($V_e/V_r < 1$)

Calculation of Shear Demand from fig. R18.6.5, ACI 318-14 $V_e = (M_{pr1} + M_{pr2})/l_n = 162459.651$

with

$$M_{pr1} = \text{Max}(M_{u1+}, M_{u1-}) = 2.4369E+008$$

$M_{u1+} = 2.4369E+008$, is the ultimate moment strength at the edge 1 of the member in the actual moment direction which is defined for the static loading combination

$M_{u1-} = 2.4369E+008$, is the ultimate moment strength at the edge 1 of the member in the opposite moment direction which is defined for the static loading combination

$$M_{pr2} = \text{Max}(M_{u2+}, M_{u2-}) = 2.4369E+008$$

$M_{u2+} = 2.4369E+008$, is the ultimate moment strength at the edge 2 of the member in the actual moment direction which is defined for the the static loading combination

$M_{u2-} = 2.4369E+008$, is the ultimate moment strength at the edge 2 of the member in the opposite moment direction which is defined for the the static loading combination

Calculation of M_{u1+}

Calculation of ultimate Moment Strength ((3.67), Biskinis Phd), M_u
 $M_u = 2.4369E+008$

$$= 0.80285146$$

$$' = 0.71403327$$

error of function (3.68), Biskinis Phd = 27987.158

From 5A.2, TBDY: $f_{cc} = f_c \cdot c = 49.98874$

conf. factor $c = 1.51481$

$$f_c = 33.00$$

From 10.3.5, ASCE 41-17, Final value of f_y : $f_y \cdot \text{Min}(1, 1.25 \cdot (l_b/d)^{2/3}) = 389.0139$

$$l_b/d = 0.30$$

$$d_1 = 44.00$$

$$R = 250.00$$

$$v = 0.00100813$$

$$N = 7389.214$$

$$A_c = 196349.541$$

$$= \cdot \text{Min}(1, 1.25 \cdot (l_b/d)^{2/3}) = 0.1620683$$

Calculation of ratio l_b/d

Inadequate Lap Length with $l_b/d = 0.30$

Calculation of M_{u1-}

Calculation of ultimate Moment Strength ((3.67), Biskinis Phd), M_u
 $M_u = 2.4369E+008$

$$= 0.80285146$$

$$' = 0.71403327$$

error of function (3.68), Biskinis Phd = 27987.158

From 5A.2, TBDY: $f_{cc} = f_c \cdot c = 49.98874$

conf. factor $c = 1.51481$

$$f_c = 33.00$$

From 10.3.5, ASCE 41-17, Final value of f_y : $f_y \cdot \text{Min}(1, 1.25 \cdot (l_b/d)^{2/3}) = 389.0139$

$$l_b/d = 0.30$$

$$d_1 = 44.00$$

$$R = 250.00$$

$$v = 0.00100813$$

$$N = 7389.214$$

$$A_c = 196349.541$$

$$= \cdot \text{Min}(1, 1.25 \cdot (l_b/d)^{2/3}) = 0.1620683$$

Calculation of ratio l_b/d

Inadequate Lap Length with $l_b/d = 0.30$

Calculation of Mu2+

Calculation of ultimate Moment Strength ((3.67), Biskinis Phd), Mu
Mu = 2.4369E+008

$$= 0.80285146$$

$$' = 0.71403327$$

error of function (3.68), Biskinis Phd = 27987.158

From 5A.2, TBDY: $f_{cc} = f_c \cdot c = 49.98874$

conf. factor $c = 1.51481$

$f_c = 33.00$

From 10.3.5, ASCE 41-17, Final value of f_y : $f_y \cdot \text{Min}(1, 1.25 \cdot (l_b/d)^{2/3}) = 389.0139$

$l_b/d = 0.30$

$d_1 = 44.00$

$R = 250.00$

$v = 0.00100813$

$N = 7389.214$

$Ac = 196349.541$

$= \cdot \text{Min}(1, 1.25 \cdot (l_b/d)^{2/3}) = 0.1620683$

Calculation of ratio l_b/d

Inadequate Lap Length with $l_b/d = 0.30$

Calculation of Mu2-

Calculation of ultimate Moment Strength ((3.67), Biskinis Phd), Mu
Mu = 2.4369E+008

$$= 0.80285146$$

$$' = 0.71403327$$

error of function (3.68), Biskinis Phd = 27987.158

From 5A.2, TBDY: $f_{cc} = f_c \cdot c = 49.98874$

conf. factor $c = 1.51481$

$f_c = 33.00$

From 10.3.5, ASCE 41-17, Final value of f_y : $f_y \cdot \text{Min}(1, 1.25 \cdot (l_b/d)^{2/3}) = 389.0139$

$l_b/d = 0.30$

$d_1 = 44.00$

$R = 250.00$

$v = 0.00100813$

$N = 7389.214$

$Ac = 196349.541$

$= \cdot \text{Min}(1, 1.25 \cdot (l_b/d)^{2/3}) = 0.1620683$

Calculation of ratio l_b/d

Inadequate Lap Length with $l_b/d = 0.30$

Calculation of Shear Strength $V_r = \text{Min}(V_{r1}, V_{r2}) = 705811.584$

Calculation of Shear Strength at edge 1, $V_{r1} = 705811.584$

$V_{r1} = V_{CoI} ((10.3), ASCE 41-17) = k_{nl} \cdot V_{CoIO}$

$V_{CoIO} = 705811.584$

$k_{nl} = 1$ (zero step-static loading)

NOTE: In expression (10-3) ' $V_s = A_v \cdot f_y \cdot d / s$ ' is replaced by ' $V_s + f \cdot V_f$ ' where V_f is the contribution of FRPs (11.3), ACI 440).

$\gamma = 1$ (normal-weight concrete)

Mean concrete strength: $f_c' = (f_c'_{jacket} \cdot Area_{jacket} + f_c'_{core} \cdot Area_{core}) / Area_{section} = 33.00$, but $f_c'^{0.5} \leq 8.3$ MPa (22.5.3.1, ACI 318-14)

$M/Vd = 2.00$

$\mu_u = 1.5940012E-011$

$\nu_u = 2.1312935E-046$

$d = 0.8 \cdot D = 400.00$

$N_u = 7389.214$

$A_g = 196349.541$

From (11.5.4.8), ACI 318-14: $V_s = V_{s1} + V_{s2} = 274157.871$

$V_{s1} = 274157.871$ is calculated for jacket, with:

$A_v = A_{stirrup} / 2 = 123370.055$

$f_y = 555.56$

$s = 100.00$

V_{s1} is multiplied by $Col1 = 1.00$

$s/d = 0.25$

$V_{s2} = 0.00$ is calculated for core, with:

$A_v = A_{stirrup} / 2 = 78956.835$

$f_y = 555.56$

$s = 250.00$

V_{s2} is multiplied by $Col2 = 0.00$

$s/d = 1.04167$

V_f ((11-3)-(11.4), ACI 440) = 308320.00

$f = 0.95$, for fully-wrapped sections

$w_f/s_f = 1$ (FRP strips adjacent to one another).

In (11.3) $\sin^2 + \cos^2$ is replaced with $(\cot^2 + \csc^2) \sin^2 \alpha$ which is more a generalised expression, where α is the angle of the crack direction (see KANEPE).

This later relation, considered as a function $V_f(\alpha)$, is implemented for every different fiber orientation α_i , as well as for 2 crack directions, $\alpha = 45^\circ$ and $\alpha = -45^\circ$ to take into consideration the cyclic seismic loading.

orientation 1: $\alpha = b_1 + 90^\circ = 90.00$

$V_f = \text{Min}(|V_f(45, \alpha)|, |V_f(-45, \alpha)|)$, with:

total thickness per orientation, $t_{f1} = N_L \cdot t / N_{oDir} = 1.00$

$d_{fv} = d$ (figure 11.2, ACI 440) = 470.00

f_{fe} ((11-5), ACI 440) = 328.00

$E_f = 82000.00$

$f_e = 0.004$, from (11.6a), ACI 440

with $f_u = 0.009$

From (11-11), ACI 440: $V_s + V_f \leq 479549.663$

$b_w \cdot d = A_{stirrup} \cdot d / 4 = 125663.706$

Calculation of Shear Strength at edge 2, $V_{r2} = 705811.584$

$V_{r2} = V_{Col}((10.3), ASCE 41-17) = k_{nl} \cdot V_{Col0}$

$V_{Col0} = 705811.584$

$k_{nl} = 1$ (zero step-static loading)

NOTE: In expression (10-3) ' $V_s = A_v \cdot f_y \cdot d / s$ ' is replaced by ' $V_s + f \cdot V_f$ ' where V_f is the contribution of FRPs (11.3), ACI 440).

$\gamma = 1$ (normal-weight concrete)

Mean concrete strength: $f_c' = (f_c'_{jacket} \cdot Area_{jacket} + f_c'_{core} \cdot Area_{core}) / Area_{section} = 33.00$, but $f_c'^{0.5} \leq 8.3$ MPa (22.5.3.1, ACI 318-14)

$M/Vd = 2.00$

$\mu_u = 1.5940012E-011$

$\nu_u = 2.1312935E-046$

$d = 0.8 \cdot D = 400.00$

$N_u = 7389.214$

$A_g = 196349.541$

From (11.5.4.8), ACI 318-14: $V_s = V_{s1} + V_{s2} = 274157.871$

$V_{s1} = 274157.871$ is calculated for jacket, with:

$A_v = A_{stirrup} / 2 = 123370.055$

$f_y = 555.56$

$s = 100.00$
 V_{s1} is multiplied by $Col1 = 1.00$
 $s/d = 0.25$
 $V_{s2} = 0.00$ is calculated for core, with:
 $A_v = \sqrt{2} * A_{stirrup} = 78956.835$
 $f_y = 555.56$
 $s = 250.00$
 V_{s2} is multiplied by $Col2 = 0.00$
 $s/d = 1.04167$
 $V_f ((11-3)-(11.4), ACI 440) = 308320.00$
 $f = 0.95$, for fully-wrapped sections
 $w_f/s_f = 1$ (FRP strips adjacent to one another).
 In (11.3) $\sin \theta + \cos \theta$ is replaced with $(\cot \theta + \csc \theta) \sin \alpha$ which is more a generalised expression,
 where θ is the angle of the crack direction (see KANEPE).
 This later relation, considered as a function $V_f(\theta, \alpha)$, is implemented for every different fiber orientation α_i ,
 as well as for 2 crack directions, $\theta = 45^\circ$ and $\theta = -45^\circ$ to take into consideration the cyclic seismic loading.
 orientation 1: $\theta = b1 + 90^\circ = 90.00$
 $V_f = \text{Min}(|V_f(45, \theta)|, |V_f(-45, \theta)|)$, with:
 total thickness per orientation, $t_{f1} = NL * t / \text{NoDir} = 1.00$
 $d_{fv} = d$ (figure 11.2, ACI 440) = 470.00
 $f_{fe} ((11-5), ACI 440) = 328.00$
 $E_f = 82000.00$
 $f_e = 0.004$, from (11.6a), ACI 440
 with $f_u = 0.009$
 From (11-11), ACI 440: $V_s + V_f \leq 479549.663$
 $b_w * d = \sqrt{V_s * d} / 4 = 125663.706$

 End Of Calculation of Shear Capacity ratio for element: column JCC1 of floor 1
 At local axis: 2

 Start Of Calculation of Chord Rotation Capacity for element: column JCC1 of floor 1
 At local axis: 3
 Integration Section: (a)
 Section Type: rcjcs

Constant Properties

 Knowledge Factor, $\phi = 1.00$
 Chord Rotation is generally considered as Deformation-Controlled Action according to Table C7-1, ASCE 41-17.
 Mean strengths are used for Deformation-Controlled Actions according to 7.5.1.3, ASCE 41-17
 Consequently:
 Jacket
 New material of Primary Member: Concrete Strength, $f_c = f_{cm} = 33.00$
 New material of Primary Member: Steel Strength, $f_s = f_{sm} = 555.56$
 Concrete Elasticity, $E_c = 26999.444$
 Steel Elasticity, $E_s = 200000.00$
 Existing Column
 New material of Primary Member: Concrete Strength, $f_c = f_{cm} = 33.00$
 New material of Primary Member: Steel Strength, $f_s = f_{sm} = 555.56$
 Concrete Elasticity, $E_c = 26999.444$
 Steel Elasticity, $E_s = 200000.00$
 External Diameter, $D = 500.00$
 Internal Diameter, $D = 300.00$
 Cover Thickness, $c = 25.00$
 Element Length, $L = 3000.00$
 Primary Member
 Ribbed Bars
 Ductile Steel
 Without Detailing for Earthquake Resistance (including stirrups not closed at 135°)
 Longitudinal Bars With Ends Lapped Starting at the End Sections
 Inadequate Lap Length with $l_b/l_d = 0.30$
 FRP Wrapping Data
 Type: Carbon

Dry properties (design values)
Thickness, $t = 1.00$
Tensile Strength, $f_{fu} = 840.00$
Tensile Modulus, $E_f = 82000.00$
Elongation, $e_{fu} = 0.009$
Number of directions, $N_{oDir} = 1$
Fiber orientations, $b_i = 0.00^\circ$
Number of layers, $N_L = 1$
Radius of rounding corners, $R = 40.00$

Stepwise Properties

Bending Moment, $M = -2.2653E+007$
Shear Force, $V_2 = -7549.016$
Shear Force, $V_3 = -3.4066156E-013$
Axial Force, $F = -7386.194$
Longitudinal Reinforcement Area Distribution (in 2 divisions)
-Tension: $A_{sl,t} = 1272.345$
-Compression: $A_{sl,c} = 1781.283$
Longitudinal Reinforcement Area Distribution (in 3 divisions)
-Tension: $A_{sl,ten} = 1017.876$
-Compression: $A_{sl,com} = 1017.876$
-Middle: $A_{sl,mid} = 1017.876$
Mean Diameter of Tension Reinforcement, $D_{bL} = 18.00$

New component: From table 7-7, ASCE 41_17: Final chord rotation Capacity $u_{,R} = 1.0^*$ $u = 0.03906345$
 $u = y + p = 0.03906345$

- Calculation of y -

$y = (M_y * L_s / 3) / E_{eff} = 0.00906345$ ((4.29), Biskinis Phd)
 $M_y = 2.2517E+008$
 $L_s = M/V$ (with $L_s > 0.1 * L$ and $L_s < 2 * L$) = 3000.736
From table 10.5, ASCE 41_17: $E_{eff} = factor * E_c * I_g = 2.4850E+013$
 $factor = 0.30$
 $A_g = 196349.541$
Mean concrete strength: $f_c' = (f_c'_{jacket} * Area_{jacket} + f_c'_{core} * Area_{core}) / Area_{section} = 33.00$
 $N = 7386.194$
 $E_c * I_g = E_c_{jacket} * I_{g,jacket} + E_c_{core} * I_{g,core} = 8.2833E+013$

Calculation of Yielding Moment M_y

Calculation of y and M_y according to (7) - (8) in Biskinis and Fardis

$M_y = \min(M_{y,ten}, M_{y,com}) = 2.2517E+008$
 $y = 6.4424821E-006$
 $M_{y,ten}$ (8c) = $2.2517E+008$
 $_{ten}$ (7c) = 61.81367
error of function (7c) = 0.00026388
 $M_{y,com}$ (8d) = $8.1922E+008$
 $_{com}$ (7d) = 63.67467
error of function (7d) = -0.00874883
with ((10.1), ASCE 41-17) $e_y = \min(e_y, 1.25 * e_y * (l_b / l_d)^{2/3}) = 0.0027778$
 $e_{co} = 0.002$
 $a_{pl} = 0.45$ ((9c) in Biskinis and Fardis for FRP Wrap)
 $d_1 = 44.00$
 $R = 250.00$
 $v = 0.00101359$
 $N = 7386.194$
 $A_c = 196349.541$

$((10.1), ASCE 41-17) = \text{Min}(, 1.25 * (lb/ld)^{2/3}) = 0.23280363$
 with f_c ((12.3), ACI 440) = 37.11312
 $f_c = 33.00$
 $\phi_l = 1.312$
 $k = 1$
 Effective FRP thickness, $t_f = NL * t * \text{Cos}(b1) = 1.00$
 e_{fe} ((12.5) and (12.7)) = 0.004
 $f_u = 0.009$
 $E_f = 82000.00$

Calculation of ratio lb/ld

Inadequate Lap Length with $lb/ld = 0.30$

- Calculation of ρ_p -

From table 10-9: $\rho_p = 0.03$

with:

- Columns controlled by inadequate development or splicing along the clear height because $lb/ld < 1$

shear control ratio $V_y E / V_{col} O E = 0.23017425$

$d = d_{\text{external}} = 0.00$

$s = s_{\text{external}} = 0.00$

$t = s_1 + s_2 + 2 * t_f / bw * (f_{fe} / f_s) = 0.00795744$

jacket: $s_1 = A_{v1} * (D_{c1} / 2) / (s_1 * A_g) = 0.0027646$

$A_{v1} = 78.53982$, is the area of stirrup

$D_{c1} = D_{\text{ext}} - 2 * \text{cover} - \text{External Hoop Diameter} = 440.00$, is the total Length of all stirrups parallel to loading

(shear) direction

$s_1 = 100.00$

core: $s_2 = A_{v2} * (D_{c2} / 2) / (s_2 * A_g) = 0.00046968$

$A_{v2} = 50.26548$, is the area of stirrup

$D_{c2} = D_{\text{int}} - \text{Internal Hoop Diameter} = 292.00$, is the total Length of all stirrups parallel to loading (shear)

direction

$s_2 = 250.00$

The term $2 * t_f / bw * (f_{fe} / f_s)$ is implemented to account for FRP contribution

where $f = 2 * t_f / bw$ is FRP ratio (EC8 - 3, A.4.4.3(6)) and f_{fe} / f_s normalises f to steel strength

All these variables have already been given in Shear control ratio calculation.

For the normalisation f_s of jacket is used.

$N_{UD} = 7386.194$

$A_g = 196349.541$

$f_{cE} = (f_{c_{\text{jacket}}} * \text{Area}_{\text{jacket}} + f_{c_{\text{core}}} * \text{Area}_{\text{core}}) / \text{section_area} = 33.00$

$f_{yIE} = (f_{y_{\text{ext_Long_Reinf}}} * \text{Area}_{\text{ext_Long_Reinf}} + f_{y_{\text{int_Long_Reinf}}} * \text{Area}_{\text{int_Long_Reinf}}) / \text{Area}_{\text{Tot_Long_Rein}} = 2.1219958E-314$

$f_{yTE} = (f_{y_{\text{ext_Trans_Reinf}}} * \text{Area}_{\text{ext_Trans_Reinf}} + f_{y_{\text{int_Trans_Reinf}}} * \text{Area}_{\text{int_Trans_Reinf}}) / \text{Area}_{\text{Tot_Trans_Rein}} = 555.56$

$\rho_l = \text{Area}_{\text{Tot_Long_Rein}} / (A_g) = 0.015552$

$f_{cE} = 33.00$

End Of Calculation of Chord Rotation Capacity for element: column JCC1 of floor 1

At local axis: 3

Integration Section: (a)

Calculation No. 13

column C1, Floor 1


Limit State: Life Safety (data interpolation between analysis steps 1 and 2)

Analysis: Uniform +X

Check: Shear capacity VRd

Edge: End

Local Axis: (2)



Start Of Calculation of Shear Capacity for element: column JCC1 of floor 1

At local axis: 2

Integration Section: (b)

Section Type: rcjcs

Constant Properties

Knowledge Factor, $\gamma = 1.00$

Member Shear Force is generally considered as Force-Controlled Action according to Table C7-1, ASCE 41-17.

Lower-bound strengths are used for Force-Controlled Actions according to 7.5.1.3, ASCE 41-17

Consequently:

Jacket

New material of Primary Member: Concrete Strength, $f_c = f_{c_lower_bound} = 25.00$

New material of Primary Member: Steel Strength, $f_s = f_{s_lower_bound} = 500.00$

Concrete Elasticity, $E_c = 26999.444$

Steel Elasticity, $E_s = 200000.00$

Existing Column

New material of Primary Member: Concrete Strength, $f_c = f_{c_lower_bound} = 25.00$

New material of Primary Member: Steel Strength, $f_s = f_{s_lower_bound} = 500.00$

Concrete Elasticity, $E_c = 26999.444$

Steel Elasticity, $E_s = 200000.00$

#####

Note: Especially for the calculation of γ for displacement ductility demand, the expected (mean value) strengths are used (7.5.1.3, ASCE 41-17) because bending is considered as Deformation-Controlled Action (Table C7-1, ASCE 41-17).

Jacket

New material: Concrete Strength, $f_c = f_{cm} = 33.00$

New material: Steel Strength, $f_s = f_{sm} = 555.56$

Existing Column

New material: Concrete Strength, $f_c = f_{cm} = 33.00$

New material: Steel Strength, $f_s = f_{sm} = 555.56$

#####

External Diameter, $D = 500.00$

Internal Diameter, $D = 300.00$

Cover Thickness, $c = 25.00$

Element Length, $L = 3000.00$

Primary Member

Ribbed Bars

Ductile Steel

Without Detailing for Earthquake Resistance (including stirrups not closed at 135°)
Longitudinal Bars With Ends Lapped Starting at the End Sections
Inadequate Lap Length with $l_o/l_{ou,min} = l_b/d = 0.30$
FRP Wrapping Data
Type: Carbon
Dry properties (design values)
Thickness, $t = 1.00$
Tensile Strength, $f_{fu} = 840.00$
Tensile Modulus, $E_f = 82000.00$
Elongation, $e_{fu} = 0.009$
Number of directions, $NoDir = 1$
Fiber orientations, $bi: 0.00^\circ$
Number of layers, $NL = 1$
Radius of rounding corners, $R = 40.00$

Stepwise Properties

EDGE -A-
Bending Moment, $M_a = -2.2653E+007$
Shear Force, $V_a = -7549.016$
EDGE -B-
Bending Moment, $M_b = 0.12607815$
Shear Force, $V_b = 7549.016$
BOTH EDGES
Axial Force, $F = -7386.194$
Longitudinal Reinforcement Area Distribution (in 2 divisions)
-Tension: $As_t = 0.00$
-Compression: $As_c = 3053.628$
Longitudinal Reinforcement Area Distribution (in 3 divisions)
-Tension: $As_{t,ten} = 1017.876$
-Compression: $As_{c,com} = 1017.876$
-Middle: $As_{c,mid} = 1017.876$
Mean Diameter of Tension Reinforcement, $Db_{L,ten} = 18.00$

New component: From table 7-7, ASCE 41_17: Final Shear Capacity $V_R = 1.0 * V_n = 614519.737$
 $V_n ((10.3), ASCE 41-17) = knl * V_{CoI0} = 614519.737$
 $V_{CoI} = 614519.737$
 $knl = 1.00$
 $displacement_ductility_demand = 0.15088713$

NOTE: In expression (10-3) ' $V_s = A_v * f_y * d / s$ ' is replaced by ' $V_s + f * V_f$ '
where V_f is the contribution of FRPs (11.3), ACI 440).

 $= 1$ (normal-weight concrete)
Mean concrete strength: $f'_c = (f'_{c,jacket} * Area_{jacket} + f'_{c,core} * Area_{core}) / Area_{section} = 25.00$, but $f'_c^{0.5} \leq 8.3$
MPa (22.5.3.1, ACI 318-14)
 $M/d = 2.00$
 $M_u = 0.12607815$
 $V_u = 7549.016$
 $d = 0.8 * D = 400.00$
 $N_u = 7386.194$
 $A_g = 196349.541$
From (11.5.4.8), ACI 318-14: $V_s = V_{s1} + V_{s2} = 246740.11$
 $V_{s1} = 246740.11$ is calculated for jacket, with:
 $A_v = /2 * A_{stirrup} = 123370.055$
 $f_y = 500.00$
 $s = 100.00$
 V_{s1} is multiplied by $Col1 = 1.00$
 $s/d = 0.25$
 $V_{s2} = 0.00$ is calculated for core, with:
 $A_v = /2 * A_{stirrup} = 78956.835$
 $f_y = 500.00$
 $s = 250.00$

Vs2 is multiplied by Col2 = 0.00

s/d = 1.04167

Vf ((11-3)-(11.4), ACI 440) = 308320.00

f = 0.95, for fully-wrapped sections

wf/sf = 1 (FRP strips adjacent to one another).

In (11.3) $\sin \theta + \cos \theta$ is replaced with $(\cot \theta + \csc \theta) \sin \alpha$ which is more a generalised expression, where θ is the angle of the crack direction (see KANEPE).

This later relation, considered as a function $V_f(\theta, \alpha)$, is implemented for every different fiber orientation α_i , as well as for 2 crack directions, $\theta = 45^\circ$ and $\theta = -45^\circ$ to take into consideration the cyclic seismic loading.

orientation 1: $\theta = b1 + 90^\circ = 90.00$

$V_f = \text{Min}(|V_f(45, \theta)|, |V_f(-45, \theta)|)$, with:

total thickness per orientation, $t_{f1} = NL * t / \text{NoDir} = 1.00$

$d_{fv} = d$ (figure 11.2, ACI 440) = 470.00

f_{fe} ((11-5), ACI 440) = 328.00

$E_f = 82000.00$

$f_e = 0.004$, from (11.6a), ACI 440

with $f_u = 0.009$

From (11-11), ACI 440: $V_s + V_f \leq 417394.406$

$b_w * d = \rho * d^2 / 4 = 125663.706$

displacement_ductility_demand is calculated as δ / y

- Calculation of δ / y for END B -

for rotation axis 3 and integ. section (b)

From analysis, chord rotation $\theta = 0.00013672$

$y = (M_y * L_s / 3) / E_{eff} = 0.00090612$ ((4.29), Biskinis Phd)

$M_y = 2.2517E+008$

$L_s = M/V$ (with $L_s > 0.1 * L$ and $L_s < 2 * L$) = 300.00

From table 10.5, ASCE 41_17: $E_{eff} = \text{factor} * E_c * I_g = 2.4850E+013$

factor = 0.30

$A_g = 196349.541$

Mean concrete strength: $f'_c = (f'_{c_jacket} * \text{Area}_{jacket} + f'_{c_core} * \text{Area}_{core}) / \text{Area}_{section} = 33.00$

$N = 7386.194$

$E_c * I_g = E_{c_jacket} * I_{g_jacket} + E_{c_core} * I_{g_core} = 8.2833E+013$

Calculation of Yielding Moment M_y

Calculation of δ / y and M_y according to (7) - (8) in Biskinis and Fardis

$M_y = \text{Min}(M_{y_ten}, M_{y_com}) = 2.2517E+008$

$y = 6.4424821E-006$

M_{y_ten} (8c) = 2.2517E+008

δ_{ten} (7c) = 61.81367

error of function (7c) = 0.00026388

M_{y_com} (8d) = 8.1922E+008

δ_{com} (7d) = 63.67467

error of function (7d) = -0.00874883

with ((10.1), ASCE 41-17) $e_y = \text{Min}(e_y, 1.25 * e_y * (I_b / I_d)^{2/3}) = 0.0027778$

$e_{co} = 0.002$

$a_{pl} = 0.45$ ((9c) in Biskinis and Fardis for FRP Wrap)

$d_1 = 44.00$

$R = 250.00$

$v = 0.00101359$

$N = 7386.194$

$A_c = 196349.541$

((10.1), ASCE 41-17) $e_y = \text{Min}(e_y, 1.25 * e_y * (I_b / I_d)^{2/3}) = 0.23280363$

with f'_c ((12.3), ACI 440) = 37.11312

$f_c = 33.00$

$f_l = 1.312$

$k = 1$

Effective FRP thickness, $t_f = NL * t * \text{Cos}(b_1) = 1.00$

e_{fe} ((12.5) and (12.7)) = 0.004

$f_u = 0.009$
 $E_f = 82000.00$

Calculation of ratio I_b/I_d

Inadequate Lap Length with $I_b/I_d = 0.30$

End Of Calculation of Shear Capacity for element: column JCC1 of floor 1

At local axis: 2

Integration Section: (b)

Calculation No. 14

column C1, Floor 1



Limit State: Life Safety (data interpolation between analysis steps 1 and 2)

Analysis: Uniform +X

Check: Chord rotation capacity (u)

Edge: End

Local Axis: (2)



Start Of Calculation of Shear Capacity ratio for element: column JCC1 of floor 1

At Shear local axis: 3

(Bending local axis: 2)

Section Type: rcjcs

Constant Properties

Knowledge Factor, $\gamma = 1.00$

Mean strength values are used for both shear and moment calculations.

Consequently:

Jacket

New material of Primary Member: Concrete Strength, $f_c = f_{cm} = 33.00$

New material of Primary Member: Steel Strength, $f_s = f_{sm} = 555.56$

Concrete Elasticity, $E_c = 26999.444$

Steel Elasticity, $E_s = 200000.00$

Existing Column

New material of Primary Member: Concrete Strength, $f_c = f_{cm} = 33.00$

New material of Primary Member: Steel Strength, $f_s = f_{sm} = 555.56$

Concrete Elasticity, $E_c = 26999.444$

Steel Elasticity, $E_s = 200000.00$

#####

Note: Especially for the calculation of moment strengths,

the above steel re-bar strengths are multiplied by 1.25 according to R18.6.5, ACI 318-14

Jacket

New material: Steel Strength, $f_s = 1.25 \cdot f_{sm} = 694.45$

Existing Column

New material: Steel Strength, $f_s = 1.25 \cdot f_{sm} = 694.45$

#####

External Diameter, $D = 500.00$

Internal Diameter, $D = 300.00$

Cover Thickness, $c = 25.00$

Mean Confinement Factor overall section = 1.51481

Element Length, $L = 3000.00$

Primary Member

Ribbed Bars

Ductile Steel

Without Detailing for Earthquake Resistance (including stirrups not closed at 135°)

Longitudinal Bars With Ends Lapped Starting at the End Sections

Inadequate Lap Length with $l_o/l_{ou,min} = 0.30$

FRP Wrapping Data

Type: Carbon

Dry properties (design values)

Thickness, $t = 1.00$

Tensile Strength, $f_{fu} = 840.00$

Tensile Modulus, $E_f = 82000.00$

Elongation, $e_{fu} = 0.009$

Number of directions, $N_{oDir} = 1$

Fiber orientations, $b_i = 0.00^\circ$

Number of layers, $N_L = 1$

Radius of rounding corners, $R = 40.00$

Stepwise Properties

At local axis: 3

EDGE -A-

Shear Force, $V_a = 3.4807814E-030$

EDGE -B-

Shear Force, $V_b = -3.4807814E-030$

BOTH EDGES

Axial Force, $F = -7389.214$

Longitudinal Reinforcement Area Distribution (in 2 divisions)

-Tension: $A_{sl,t} = 0.00$

-Compression: $A_{sl,c} = 3053.628$

Longitudinal Reinforcement Area Distribution (in 3 divisions)

-Tension: $A_{sl,ten} = 1017.876$

-Compression: $A_{sl,com} = 1017.876$

-Middle: $A_{sl,mid} = 1017.876$

Calculation of Shear Capacity ratio, $V_e/V_r = 0.23017425$

Member Controlled by Flexure ($V_e/V_r < 1$)

Calculation of Shear Demand from fig. R18.6.5, ACI 318-14 $V_e = (M_{pr1} + M_{pr2})/l_n = 162459.651$

with

$M_{pr1} = \text{Max}(M_{u1+}, M_{u1-}) = 2.4369E+008$

$M_{u1+} = 2.4369E+008$, is the ultimate moment strength at the edge 1 of the member in the actual moment direction which is defined for the static loading combination

$M_{u1-} = 2.4369E+008$, is the ultimate moment strength at the edge 1 of the member in the opposite moment direction which is defined for the static loading combination

$M_{pr2} = \text{Max}(M_{u2+}, M_{u2-}) = 2.4369E+008$

Mu2+ = 2.4369E+008, is the ultimate moment strength at the edge 2 of the member in the actual moment direction which is defined for the the static loading combination

Mu2- = 2.4369E+008, is the ultimate moment strength at the edge 2 of the member in the opposite moment direction which is defined for the the static loading combination

Calculation of Mu1+

Calculation of ultimate Moment Strength ((3.67), Biskinis Phd), Mu

Mu = 2.4369E+008

= 0.80285146

' = 0.71403327

error of function (3.68), Biskinis Phd = 27987.158

From 5A.2, TBDY: fcc = fc* c = 49.98874

conf. factor c = 1.51481

fc = 33.00

From 10.3.5, ASCE 41-17, Final value of fy: fy*Min(1,1.25*(lb/d)^ 2/3) = 389.0139

lb/d = 0.30

d1 = 44.00

R = 250.00

v = 0.00100813

N = 7389.214

Ac = 196349.541

= *Min(1,1.25*(lb/d)^ 2/3) = 0.1620683

Calculation of ratio lb/d

Inadequate Lap Length with lb/d = 0.30

Calculation of Mu1-

Calculation of ultimate Moment Strength ((3.67), Biskinis Phd), Mu

Mu = 2.4369E+008

= 0.80285146

' = 0.71403327

error of function (3.68), Biskinis Phd = 27987.158

From 5A.2, TBDY: fcc = fc* c = 49.98874

conf. factor c = 1.51481

fc = 33.00

From 10.3.5, ASCE 41-17, Final value of fy: fy*Min(1,1.25*(lb/d)^ 2/3) = 389.0139

lb/d = 0.30

d1 = 44.00

R = 250.00

v = 0.00100813

N = 7389.214

Ac = 196349.541

= *Min(1,1.25*(lb/d)^ 2/3) = 0.1620683

Calculation of ratio lb/d

Inadequate Lap Length with lb/d = 0.30

Calculation of Mu2+

Calculation of ultimate Moment Strength ((3.67), Biskinis Phd), Mu
Mu = 2.4369E+008

$$= 0.80285146$$

$$' = 0.71403327$$

error of function (3.68), Biskinis Phd = 27987.158

From 5A.2, TBDY: $f_{cc} = f_c \cdot c = 49.98874$

$$\text{conf. factor } c = 1.51481$$

$$f_c = 33.00$$

From 10.3.5, ASCE 41-17, Final value of f_y : $f_y \cdot \text{Min}(1, 1.25 \cdot (l_b/d)^{2/3}) = 389.0139$

$$l_b/d = 0.30$$

$$d_1 = 44.00$$

$$R = 250.00$$

$$v = 0.00100813$$

$$N = 7389.214$$

$$A_c = 196349.541$$

$$= \text{Min}(1, 1.25 \cdot (l_b/d)^{2/3}) = 0.1620683$$

Calculation of ratio l_b/d

Inadequate Lap Length with $l_b/d = 0.30$

Calculation of Mu2-

Calculation of ultimate Moment Strength ((3.67), Biskinis Phd), Mu
Mu = 2.4369E+008

$$= 0.80285146$$

$$' = 0.71403327$$

error of function (3.68), Biskinis Phd = 27987.158

From 5A.2, TBDY: $f_{cc} = f_c \cdot c = 49.98874$

$$\text{conf. factor } c = 1.51481$$

$$f_c = 33.00$$

From 10.3.5, ASCE 41-17, Final value of f_y : $f_y \cdot \text{Min}(1, 1.25 \cdot (l_b/d)^{2/3}) = 389.0139$

$$l_b/d = 0.30$$

$$d_1 = 44.00$$

$$R = 250.00$$

$$v = 0.00100813$$

$$N = 7389.214$$

$$A_c = 196349.541$$

$$= \text{Min}(1, 1.25 \cdot (l_b/d)^{2/3}) = 0.1620683$$

Calculation of ratio l_b/d

Inadequate Lap Length with $l_b/d = 0.30$

Calculation of Shear Strength $V_r = \text{Min}(V_{r1}, V_{r2}) = 705811.584$

Calculation of Shear Strength at edge 1, $V_{r1} = 705811.584$

$V_{r1} = V_{Co1}$ ((10.3), ASCE 41-17) = $k_{nl} \cdot V_{Co1}$

$$V_{Co1} = 705811.584$$

$$k_{nl} = 1 \text{ (zero step-static loading)}$$

NOTE: In expression (10-3) ' $V_s = A_v \cdot f_y \cdot d/s$ ' is replaced by ' $V_s + f \cdot V_f$ ' where V_f is the contribution of FRPs (11.3), ACI 440).

$$= 1 \text{ (normal-weight concrete)}$$

Mean concrete strength: $f_c' = (f_c'_{\text{jacket}} \cdot \text{Area}_{\text{jacket}} + f_c'_{\text{core}} \cdot \text{Area}_{\text{core}}) / \text{Area}_{\text{section}} = 33.00$, but $f_c'^{0.5} \leq 8.3$ MPa (22.5.3.1, ACI 318-14)

$M/Vd = 2.00$

$\mu_u = 1.2438899E-011$

$V_u = 3.4807814E-030$

$d = 0.8 \cdot D = 400.00$

$N_u = 7389.214$

$A_g = 196349.541$

From (11.5.4.8), ACI 318-14: $V_s = V_{s1} + V_{s2} = 274157.871$

$V_{s1} = 274157.871$ is calculated for jacket, with:

$A_v = \sqrt{2} \cdot A_{\text{stirrup}} = 123370.055$

$f_y = 555.56$

$s = 100.00$

V_{s1} is multiplied by $\text{Col1} = 1.00$

$s/d = 0.25$

$V_{s2} = 0.00$ is calculated for core, with:

$A_v = \sqrt{2} \cdot A_{\text{stirrup}} = 78956.835$

$f_y = 555.56$

$s = 250.00$

V_{s2} is multiplied by $\text{Col2} = 0.00$

$s/d = 1.04167$

V_f ((11-3)-(11.4), ACI 440) = 308320.00

$f = 0.95$, for fully-wrapped sections

$w_f/s_f = 1$ (FRP strips adjacent to one another).

In (11.3) $\sin \theta + \cos \theta$ is replaced with $(\cot \theta + \cot \alpha) \sin \alpha$ which is more a generalised expression,

where θ is the angle of the crack direction (see KANEPE).

This later relation, considered as a function $V_f(\theta, \alpha)$, is implemented for every different fiber orientation α_i , as well as for 2 crack directions, $\theta = 45^\circ$ and $\theta = -45^\circ$ to take into consideration the cyclic seismic loading.

orientation 1: $\theta = b_1 + 90^\circ = 90.00$

$V_f = \text{Min}(|V_f(45, \theta)|, |V_f(-45, \theta)|)$, with:

total thickness per orientation, $t_{f1} = N_L \cdot t / N_{\text{Dir}} = 1.00$

$d_{fv} = d$ (figure 11.2, ACI 440) = 470.00

f_{fe} ((11-5), ACI 440) = 328.00

$E_f = 82000.00$

$f_e = 0.004$, from (11.6a), ACI 440

with $f_u = 0.009$

From (11-11), ACI 440: $V_s + V_f \leq 479549.663$

$b_w \cdot d = \sqrt{2} \cdot d^2 / 4 = 125663.706$

Calculation of Shear Strength at edge 2, $V_{r2} = 705811.584$

$V_{r2} = V_{\text{Col}}((10.3), \text{ASCE } 41-17) = k_{nl} \cdot V_{\text{Col}0}$

$V_{\text{Col}0} = 705811.584$

$k_{nl} = 1$ (zero step-static loading)

NOTE: In expression (10-3) ' $V_s = A_v \cdot f_y \cdot d / s$ ' is replaced by ' $V_s + f \cdot V_f$ ' where V_f is the contribution of FRPs (11.3), ACI 440).

$\mu_u = 1$ (normal-weight concrete)

Mean concrete strength: $f_c' = (f_c'_{\text{jacket}} \cdot \text{Area}_{\text{jacket}} + f_c'_{\text{core}} \cdot \text{Area}_{\text{core}}) / \text{Area}_{\text{section}} = 33.00$, but $f_c'^{0.5} \leq 8.3$ MPa (22.5.3.1, ACI 318-14)

$M/Vd = 2.00$

$\mu_u = 1.2438899E-011$

$V_u = 3.4807814E-030$

$d = 0.8 \cdot D = 400.00$

$N_u = 7389.214$

$A_g = 196349.541$

From (11.5.4.8), ACI 318-14: $V_s = V_{s1} + V_{s2} = 274157.871$

$V_{s1} = 274157.871$ is calculated for jacket, with:

$A_v = \sqrt{2} \cdot A_{\text{stirrup}} = 123370.055$

$f_y = 555.56$

$s = 100.00$

V_{s1} is multiplied by $\text{Col1} = 1.00$

$s/d = 0.25$

$V_{s2} = 0.00$ is calculated for core, with:

$A_v = \sqrt{2} \cdot A_{\text{stirrup}} = 78956.835$

$f_y = 555.56$

$s = 250.00$
 V_{s2} is multiplied by $Col2 = 0.00$
 $s/d = 1.04167$
 $V_f((11-3)-(11.4), ACI 440) = 308320.00$
 $f = 0.95$, for fully-wrapped sections
 $w_f/s_f = 1$ (FRP strips adjacent to one another).
 In (11.3) $\sin + \cos$ is replaced with $(\cot + \cot a)\sin a$ which is more a generalised expression,
 where θ is the angle of the crack direction (see KANEPE).
 This later relation, considered as a function $V_f(\theta, a)$, is implemented for every different fiber orientation a_i ,
 as well as for 2 crack directions, $\theta = 45^\circ$ and $\theta = -45^\circ$ to take into consideration the cyclic seismic loading.
 orientation 1: $\theta = b1 + 90^\circ = 90.00$
 $V_f = \text{Min}(|V_f(45, 1)|, |V_f(-45, a1)|)$, with:
 total thickness per orientation, $t_{f1} = NL * t / \text{NoDir} = 1.00$
 $d_{fv} = d$ (figure 11.2, ACI 440) = 470.00
 $f_{fe}((11-5), ACI 440) = 328.00$
 $E_f = 82000.00$
 $f_e = 0.004$, from (11.6a), ACI 440
 with $f_u = 0.009$
 From (11-11), ACI 440: $V_s + V_f \leq 479549.663$
 $b_w * d = \rho * d^2 / 4 = 125663.706$

 End Of Calculation of Shear Capacity ratio for element: column JCC1 of floor 1
 At local axis: 3

 Start Of Calculation of Shear Capacity ratio for element: column JCC1 of floor 1
 At Shear local axis: 2
 (Bending local axis: 3)
 Section Type: rcjcs

Constant Properties

 Knowledge Factor, $\phi = 1.00$
 Mean strength values are used for both shear and moment calculations.
 Consequently:
 Jacket
 New material of Primary Member: Concrete Strength, $f_c = f_{cm} = 33.00$
 New material of Primary Member: Steel Strength, $f_s = f_{sm} = 555.56$
 Concrete Elasticity, $E_c = 26999.444$
 Steel Elasticity, $E_s = 200000.00$
 Existing Column
 New material of Primary Member: Concrete Strength, $f_c = f_{cm} = 33.00$
 New material of Primary Member: Steel Strength, $f_s = f_{sm} = 555.56$
 Concrete Elasticity, $E_c = 26999.444$
 Steel Elasticity, $E_s = 200000.00$
 #####
 Note: Especially for the calculation of moment strengths,
 the above steel re-bar strengths are multiplied by 1.25 according to R18.6.5, ACI 318-14
 Jacket
 New material: Steel Strength, $f_s = 1.25 * f_{sm} = 694.45$
 Existing Column
 New material: Steel Strength, $f_s = 1.25 * f_{sm} = 694.45$
 #####
 External Diameter, $D = 500.00$
 Internal Diameter, $D = 300.00$
 Cover Thickness, $c = 25.00$
 Mean Confinement Factor overall section = 1.51481
 Element Length, $L = 3000.00$
 Primary Member
 Ribbed Bars
 Ductile Steel
 Without Detailing for Earthquake Resistance (including stirrups not closed at 135°)
 Longitudinal Bars With Ends Lapped Starting at the End Sections
 Inadequate Lap Length with $l_o/l_{ou, \text{min}} = 0.30$

FRP Wrapping Data

Type: Carbon

Dry properties (design values)

Thickness, $t = 1.00$

Tensile Strength, $f_{fu} = 840.00$

Tensile Modulus, $E_f = 82000.00$

Elongation, $\epsilon_{fu} = 0.009$

Number of directions, $N_{oDir} = 1$

Fiber orientations, $b_i = 0.00^\circ$

Number of layers, $N_L = 1$

Radius of rounding corners, $R = 40.00$

Stepwise Properties

At local axis: 2

EDGE -A-

Shear Force, $V_a = -2.1312935E-046$

EDGE -B-

Shear Force, $V_b = 2.1312935E-046$

BOTH EDGES

Axial Force, $F = -7389.214$

Longitudinal Reinforcement Area Distribution (in 2 divisions)

-Tension: $A_{sl,t} = 0.00$

-Compression: $A_{sl,c} = 3053.628$

Longitudinal Reinforcement Area Distribution (in 3 divisions)

-Tension: $A_{sl,ten} = 1017.876$

-Compression: $A_{sl,com} = 1017.876$

-Middle: $A_{sl,mid} = 1017.876$

Calculation of Shear Capacity ratio, $V_e/V_r = 0.23017425$

Member Controlled by Flexure ($V_e/V_r < 1$)

Calculation of Shear Demand from fig. R18.6.5, ACI 318-14 $V_e = (M_{pr1} + M_{pr2})/l_n = 162459.651$

with

$M_{pr1} = \text{Max}(M_{u1+}, M_{u1-}) = 2.4369E+008$

$M_{u1+} = 2.4369E+008$, is the ultimate moment strength at the edge 1 of the member in the actual moment direction which is defined for the static loading combination

$M_{u1-} = 2.4369E+008$, is the ultimate moment strength at the edge 1 of the member in the opposite moment direction which is defined for the static loading combination

$M_{pr2} = \text{Max}(M_{u2+}, M_{u2-}) = 2.4369E+008$

$M_{u2+} = 2.4369E+008$, is the ultimate moment strength at the edge 2 of the member in the actual moment direction which is defined for the static loading combination

$M_{u2-} = 2.4369E+008$, is the ultimate moment strength at the edge 2 of the member in the opposite moment direction which is defined for the static loading combination

Calculation of M_{u1+}

Calculation of ultimate Moment Strength ((3.67), Biskinis Phd), M_u

$M_u = 2.4369E+008$

$\lambda = 0.80285146$

$\lambda' = 0.71403327$

error of function (3.68), Biskinis Phd = 27987.158

From 5A.2, TBDY: $f_{cc} = f_c \cdot c = 49.98874$

conf. factor $c = 1.51481$

$f_c = 33.00$

From 10.3.5, ASCE 41-17, Final value of f_y : $f_y \cdot \text{Min}(1, 1.25 \cdot (l_b/l_d)^{2/3}) = 389.0139$

$l_b/l_d = 0.30$

$d_1 = 44.00$

$R = 250.00$

$v = 0.00100813$

$$N = 7389.214$$
$$Ac = 196349.541$$
$$= *Min(1,1.25*(lb/d)^{2/3}) = 0.1620683$$

Calculation of ratio lb/d

Inadequate Lap Length with lb/d = 0.30

Calculation of Mu1-

Calculation of ultimate Moment Strength ((3.67), Biskinis Phd), Mu
Mu = 2.4369E+008

$$= 0.80285146$$
$$' = 0.71403327$$

error of function (3.68), Biskinis Phd = 27987.158

From 5A.2, TBDY: fcc = fc* c = 49.98874
conf. factor c = 1.51481
fc = 33.00

From 10.3.5, ASCE 41-17, Final value of fy: fy*Min(1,1.25*(lb/d)^{2/3}) = 389.0139

lb/d = 0.30
d1 = 44.00
R = 250.00
v = 0.00100813
N = 7389.214
Ac = 196349.541
= *Min(1,1.25*(lb/d)^{2/3}) = 0.1620683

Calculation of ratio lb/d

Inadequate Lap Length with lb/d = 0.30

Calculation of Mu2+

Calculation of ultimate Moment Strength ((3.67), Biskinis Phd), Mu
Mu = 2.4369E+008

$$= 0.80285146$$
$$' = 0.71403327$$

error of function (3.68), Biskinis Phd = 27987.158

From 5A.2, TBDY: fcc = fc* c = 49.98874
conf. factor c = 1.51481
fc = 33.00

From 10.3.5, ASCE 41-17, Final value of fy: fy*Min(1,1.25*(lb/d)^{2/3}) = 389.0139

lb/d = 0.30
d1 = 44.00
R = 250.00
v = 0.00100813
N = 7389.214
Ac = 196349.541
= *Min(1,1.25*(lb/d)^{2/3}) = 0.1620683

Calculation of ratio lb/d

Inadequate Lap Length with lb/d = 0.30

Calculation of Mu2-

Calculation of ultimate Moment Strength ((3.67), Biskinis Phd), Mu
Mu = 2.4369E+008

= 0.80285146
' = 0.71403327
error of function (3.68), Biskinis Phd = 27987.158
From 5A.2, TBDY: $f_{cc} = f_c \cdot c = 49.98874$
conf. factor $c = 1.51481$
 $f_c = 33.00$
From 10.3.5, ASCE 41-17, Final value of f_y : $f_y \cdot \text{Min}(1, 1.25 \cdot (l_b/d)^{2/3}) = 389.0139$
 $l_b/d = 0.30$
 $d_1 = 44.00$
 $R = 250.00$
 $v = 0.00100813$
 $N = 7389.214$
 $A_c = 196349.541$
= $\cdot \text{Min}(1, 1.25 \cdot (l_b/d)^{2/3}) = 0.1620683$

Calculation of ratio l_b/d

Inadequate Lap Length with $l_b/d = 0.30$

Calculation of Shear Strength $V_r = \text{Min}(V_{r1}, V_{r2}) = 705811.584$

Calculation of Shear Strength at edge 1, $V_{r1} = 705811.584$
 $V_{r1} = V_{Col}$ ((10.3), ASCE 41-17) = $k_{nl} \cdot V_{Col0}$
 $V_{Col0} = 705811.584$
 $k_{nl} = 1$ (zero step-static loading)

NOTE: In expression (10-3) ' $V_s = A_v \cdot f_y \cdot d/s$ ' is replaced by ' $V_s + f \cdot V_f$ '
where V_f is the contribution of FRPs (11.3), ACI 440).

= 1 (normal-weight concrete)
Mean concrete strength: $f_c' = (f_c'_{jacket} \cdot \text{Area}_{jacket} + f_c'_{core} \cdot \text{Area}_{core}) / \text{Area}_{section} = 33.00$, but $f_c'^{0.5} \leq 8.3$
MPa (22.5.3.1, ACI 318-14)
 $M/Vd = 2.00$
 $\mu = 1.5940012E-011$
 $\nu = 2.1312935E-046$
 $d = 0.8 \cdot D = 400.00$
 $N_u = 7389.214$
 $A_g = 196349.541$
From (11.5.4.8), ACI 318-14: $V_s = V_{s1} + V_{s2} = 274157.871$
 $V_{s1} = 274157.871$ is calculated for jacket, with:
 $A_v = \sqrt{2} \cdot A_{stirup} = 123370.055$
 $f_y = 555.56$
 $s = 100.00$
 V_{s1} is multiplied by $\text{Col1} = 1.00$
 $s/d = 0.25$
 $V_{s2} = 0.00$ is calculated for core, with:
 $A_v = \sqrt{2} \cdot A_{stirup} = 78956.835$
 $f_y = 555.56$
 $s = 250.00$
 V_{s2} is multiplied by $\text{Col2} = 0.00$
 $s/d = 1.04167$
 V_f ((11-3)-(11.4), ACI 440) = 308320.00
 $f = 0.95$, for fully-wrapped sections
 $w_f/s_f = 1$ (FRP strips adjacent to one another).

In (11.3) $\sin \theta + \cos \theta$ is replaced with $(\cot \theta + \csc \theta) \sin \theta$ which is more a generalised expression, where θ is the angle of the crack direction (see KANEPE). This later relation, considered as a function $V_f(\theta)$, is implemented for every different fiber orientation a_i , as well as for 2 crack directions, $\theta = 45^\circ$ and $\theta = -45^\circ$ to take into consideration the cyclic seismic loading.

orientation 1: $\theta = b_1 + 90^\circ = 90.00$
 $V_f = \text{Min}(|V_f(45, \theta)|, |V_f(-45, a_1)|)$, with:
total thickness per orientation, $t_{f1} = NL \cdot t / \text{NoDir} = 1.00$
 $d_{fv} = d$ (figure 11.2, ACI 440) = 470.00
 f_{fe} ((11-5), ACI 440) = 328.00
 $E_f = 82000.00$
 $f_e = 0.004$, from (11.6a), ACI 440
with $f_u = 0.009$
From (11-11), ACI 440: $V_s + V_f \leq 479549.663$
 $b_w \cdot d = \frac{A_s \cdot d}{4} = 125663.706$

Calculation of Shear Strength at edge 2, $V_{r2} = 705811.584$
 $V_{r2} = V_{Col}$ ((10.3), ASCE 41-17) = $k_{nl} \cdot V_{Col0}$
 $V_{Col0} = 705811.584$
 $k_{nl} = 1$ (zero step-static loading)

NOTE: In expression (10-3) ' $V_s = A_v \cdot f_y \cdot d / s$ ' is replaced by ' $V_s + f \cdot V_f$ ' where V_f is the contribution of FRPs (11.3), ACI 440).

$k_{nl} = 1$ (normal-weight concrete)
Mean concrete strength: $f'_c = (f'_c \cdot \text{Area}_{\text{jacket}} + f'_c \cdot \text{Area}_{\text{core}}) / \text{Area}_{\text{section}} = 33.00$, but $f'_c^{0.5} \leq 8.3$ MPa (22.5.3.1, ACI 318-14)
 $M/Vd = 2.00$
 $\mu_u = 1.5940012E-011$
 $\nu_u = 2.1312935E-046$
 $d = 0.8 \cdot D = 400.00$
 $N_u = 7389.214$
 $A_g = 196349.541$
From (11.5.4.8), ACI 318-14: $V_s = V_{s1} + V_{s2} = 274157.871$
 $V_{s1} = 274157.871$ is calculated for jacket, with:
 $A_v = \frac{A_s}{2} = 123370.055$
 $f_y = 555.56$
 $s = 100.00$
 V_{s1} is multiplied by $\text{Col1} = 1.00$
 $s/d = 0.25$
 $V_{s2} = 0.00$ is calculated for core, with:
 $A_v = \frac{A_s}{2} = 78956.835$
 $f_y = 555.56$
 $s = 250.00$
 V_{s2} is multiplied by $\text{Col2} = 0.00$
 $s/d = 1.04167$
 V_f ((11-3)-(11.4), ACI 440) = 308320.00
 $f = 0.95$, for fully-wrapped sections
 $w_f / s_f = 1$ (FRP strips adjacent to one another).
In (11.3) $\sin \theta + \cos \theta$ is replaced with $(\cot \theta + \csc \theta) \sin \theta$ which is more a generalised expression, where θ is the angle of the crack direction (see KANEPE). This later relation, considered as a function $V_f(\theta)$, is implemented for every different fiber orientation a_i , as well as for 2 crack directions, $\theta = 45^\circ$ and $\theta = -45^\circ$ to take into consideration the cyclic seismic loading.

orientation 1: $\theta = b_1 + 90^\circ = 90.00$
 $V_f = \text{Min}(|V_f(45, \theta)|, |V_f(-45, a_1)|)$, with:
total thickness per orientation, $t_{f1} = NL \cdot t / \text{NoDir} = 1.00$
 $d_{fv} = d$ (figure 11.2, ACI 440) = 470.00
 f_{fe} ((11-5), ACI 440) = 328.00
 $E_f = 82000.00$
 $f_e = 0.004$, from (11.6a), ACI 440
with $f_u = 0.009$
From (11-11), ACI 440: $V_s + V_f \leq 479549.663$
 $b_w \cdot d = \frac{A_s \cdot d}{4} = 125663.706$

End Of Calculation of Shear Capacity ratio for element: column JCC1 of floor 1
At local axis: 2

Start Of Calculation of Chord Rotation Capacity for element: column JCC1 of floor 1

At local axis: 2

Integration Section: (b)

Section Type: rcjcs

Constant Properties

Knowledge Factor, $\gamma = 1.00$

Chord Rotation is generally considered as Deformation-Controlled Action according to Table C7-1, ASCE 41-17.

Mean strengths are used for Deformation-Controlled Actions according to 7.5.1.3, ASCE 41-17

Consequently:

Jacket

New material of Primary Member: Concrete Strength, $f_c = f_{cm} = 33.00$

New material of Primary Member: Steel Strength, $f_s = f_{sm} = 555.56$

Concrete Elasticity, $E_c = 26999.444$

Steel Elasticity, $E_s = 200000.00$

Existing Column

New material of Primary Member: Concrete Strength, $f_c = f_{cm} = 33.00$

New material of Primary Member: Steel Strength, $f_s = f_{sm} = 555.56$

Concrete Elasticity, $E_c = 26999.444$

Steel Elasticity, $E_s = 200000.00$

External Diameter, $D = 500.00$

Internal Diameter, $D = 300.00$

Cover Thickness, $c = 25.00$

Element Length, $L = 3000.00$

Primary Member

Ribbed Bars

Ductile Steel

Without Detailing for Earthquake Resistance (including stirrups not closed at 135°)

Longitudinal Bars With Ends Lapped Starting at the End Sections

Inadequate Lap Length with $l_b/l_d = 0.30$

FRP Wrapping Data

Type: Carbon

Dry properties (design values)

Thickness, $t = 1.00$

Tensile Strength, $f_{fu} = 840.00$

Tensile Modulus, $E_f = 82000.00$

Elongation, $e_{fu} = 0.009$

Number of directions, $N_{oDir} = 1$

Fiber orientations, $b_i = 0.00^\circ$

Number of layers, $N_L = 1$

Radius of rounding corners, $R = 40.00$

Stepwise Properties

Bending Moment, $M = -1.3104847E-010$

Shear Force, $V_2 = 7549.016$

Shear Force, $V_3 = 3.4066156E-013$

Axial Force, $F = -7386.194$

Longitudinal Reinforcement Area Distribution (in 2 divisions)

-Tension: $A_{sl,t} = 0.00$

-Compression: $A_{sl,c} = 3053.628$

Longitudinal Reinforcement Area Distribution (in 3 divisions)

-Tension: $A_{sl,ten} = 1017.876$

-Compression: $A_{sl,com} = 1017.876$

-Middle: $A_{sl,mid} = 1017.876$

Mean Diameter of Tension Reinforcement, $Db_L = 18.00$

New component: From table 7-7, ASCE 41_17: Final chord rotation Capacity $\mu_{,R} = 1.0^*$ $\mu = 0.03453062$

$$u = y + p = 0.03453062$$

- Calculation of y -

$$y = (M_y \cdot L_s / 3) / E_{\text{eff}} = 0.00453062 \text{ ((4.29), Biskinis Phd)}$$

$$M_y = 2.2517E+008$$

$$L_s = M/V \text{ (with } L_s > 0.1 \cdot L \text{ and } L_s < 2 \cdot L) = 1500.00$$

$$\text{From table 10.5, ASCE 41-17: } E_{\text{eff}} = \text{factor} \cdot E_c \cdot I_g = 2.4850E+013$$

$$\text{factor} = 0.30$$

$$A_g = 196349.541$$

$$\text{Mean concrete strength: } f_c' = (f_c'_{\text{jacket}} \cdot \text{Area}_{\text{jacket}} + f_c'_{\text{core}} \cdot \text{Area}_{\text{core}}) / \text{Area}_{\text{section}} = 33.00$$

$$N = 7386.194$$

$$E_c \cdot I_g = E_{c_{\text{jacket}}} \cdot I_{g_{\text{jacket}}} + E_{c_{\text{core}}} \cdot I_{g_{\text{core}}} = 8.2833E+013$$

Calculation of Yielding Moment M_y

Calculation of y and M_y according to (7) - (8) in Biskinis and Fardis

$$M_y = \text{Min}(M_{y_{\text{ten}}}, M_{y_{\text{com}}}) = 2.2517E+008$$

$$y = 6.4424821E-006$$

$$M_{y_{\text{ten}}} \text{ (8c)} = 2.2517E+008$$

$$y_{\text{ten}} \text{ (7c)} = 61.81367$$

$$\text{error of function (7c)} = 0.00026388$$

$$M_{y_{\text{com}}} \text{ (8d)} = 8.1922E+008$$

$$y_{\text{com}} \text{ (7d)} = 63.67467$$

$$\text{error of function (7d)} = -0.00874883$$

$$\text{with ((10.1), ASCE 41-17) } e_y = \text{Min}(e_y, 1.25 \cdot e_y \cdot (l_b / l_d)^{2/3}) = 0.0027778$$

$$e_{c0} = 0.002$$

$$a_{pl} = 0.45 \text{ ((9c) in Biskinis and Fardis for FRP Wrap)}$$

$$d_1 = 44.00$$

$$R = 250.00$$

$$v = 0.00101359$$

$$N = 7386.194$$

$$A_c = 196349.541$$

$$\text{((10.1), ASCE 41-17) } = \text{Min}(, 1.25 \cdot \cdot (l_b / l_d)^{2/3}) = 0.23280363$$

$$\text{with } f_c' \text{ ((12.3), ACI 440)} = 37.11312$$

$$f_c = 33.00$$

$$f_l = 1.312$$

$$k = 1$$

$$\text{Effective FRP thickness, } t_f = N \cdot l \cdot \text{Cos}(b_1) = 1.00$$

$$e_{fe} \text{ ((12.5) and (12.7))} = 0.004$$

$$f_u = 0.009$$

$$E_f = 82000.00$$

Calculation of ratio l_b / l_d

Inadequate Lap Length with $l_b / l_d = 0.30$

- Calculation of p -

From table 10-9: $p = 0.03$

with:

- Columns controlled by inadequate development or splicing along the clear height because $l_b / l_d < 1$

$$\text{shear control ratio } V_y E / V_c O_{E} = 0.23017425$$

$$d = d_{\text{external}} = 0.00$$

$$s = s_{\text{external}} = 0.00$$

$$t = s_1 + s_2 + 2 \cdot t_f / b_w \cdot (f_{fe} / f_s) = 0.00795744$$

$$\text{jacket: } s_1 = A_{v1} \cdot (\cdot D_{c1} / 2) / (s_1 \cdot A_g) = 0.0027646$$

$$A_{v1} = 78.53982, \text{ is the area of stirrup}$$

$D_{c1} = D_{\text{ext}} - 2 \cdot \text{cover} - \text{External Hoop Diameter} = 440.00$, is the total Length of all stirrups parallel to loading (shear) direction

$$s1 = 100.00$$

$$\text{core: } s2 = Av2 * (\pi * Dc2 / 2) / (s2 * Ag) = 0.00046968$$

Av2 = 50.26548, is the area of stirrup

Dc2 = Dint - Internal Hoop Diameter = 292.00, is the total Length of all stirrups parallel to loading (shear)

direction

$$s2 = 250.00$$

The term $2 * t_f / b_w * (f_{fe} / f_s)$ is implemented to account for FRP contribution

where $f = 2 * t_f / b_w$ is FRP ratio (EC8 - 3, A.4.4.3(6)) and f_{fe} / f_s normalises f to steel strength

All these variables have already been given in Shear control ratio calculation.

For the normalisation f_s of jacket is used.

$$NUD = 7386.194$$

$$Ag = 196349.541$$

$$f_{cE} = (f_{c_jacket} * Area_jacket + f_{c_core} * Area_core) / section_area = 33.00$$

$$f_{yIE} = (f_{y_ext_Long_Reinf} * Area_ext_Long_Reinf + f_{y_int_Long_Reinf} * Area_int_Long_Reinf) / Area_Tot_Long_Rein = 2.1219958E-314$$

$$f_{yIE} = (f_{y_ext_Trans_Reinf} * Area_ext_Trans_Reinf + f_{y_int_Trans_Reinf} * Area_int_Trans_Reinf) / Area_Tot_Trans_Rein = 555.56$$

$$p_l = Area_Tot_Long_Rein / (Ag) = 0.015552$$

$$f_{cE} = 33.00$$

End Of Calculation of Chord Rotation Capacity for element: column JCC1 of floor 1

At local axis: 2

Integration Section: (b)

Calculation No. 15

column C1, Floor 1


Limit State: Life Safety (data interpolation between analysis steps 1 and 2)

Analysis: Uniform +X

Check: Shear capacity V_{Rd}

Edge: End

Local Axis: (3)



Start Of Calculation of Shear Capacity for element: column JCC1 of floor 1

At local axis: 3

Integration Section: (b)

Section Type: rcjcs

Constant Properties

Knowledge Factor, $\gamma = 1.00$

Member Shear Force is generally considered as Force-Controlled Action according to Table C7-1, ASCE 41-17.

Lower-bound strengths are used for Force-Controlled Actions according to 7.5.1.3, ASCE 41-17

Consequently:

Jacket

New material of Primary Member: Concrete Strength, $f_c = f_{c_lower_bound} = 25.00$

New material of Primary Member: Steel Strength, $f_s = f_{s_lower_bound} = 500.00$

Concrete Elasticity, $E_c = 26999.444$

Steel Elasticity, $E_s = 200000.00$

Existing Column

New material of Primary Member: Concrete Strength, $f_c = f_{c_lower_bound} = 25.00$

New material of Primary Member: Steel Strength, $f_s = f_{s_lower_bound} = 500.00$

Concrete Elasticity, $E_c = 26999.444$

Steel Elasticity, $E_s = 200000.00$

#####

Note: Especially for the calculation of γ for displacement ductility demand, the expected (mean value) strengths are used (7.5.1.3, ASCE 41-17) because bending is considered as Deformation-Controlled Action (Table C7-1, ASCE 41-17).

Jacket

New material: Concrete Strength, $f_c = f_{cm} = 33.00$

New material: Steel Strength, $f_s = f_{sm} = 555.56$

Existing Column

New material: Concrete Strength, $f_c = f_{cm} = 33.00$

New material: Steel Strength, $f_s = f_{sm} = 555.56$

#####

External Diameter, $D = 500.00$

Internal Diameter, $D = 300.00$

Cover Thickness, $c = 25.00$

Element Length, $L = 3000.00$

Primary Member

Ribbed Bars

Ductile Steel

Without Detailing for Earthquake Resistance (including stirrups not closed at 135°)

Longitudinal Bars With Ends Lapped Starting at the End Sections

Inadequate Lap Length with $l_o/l_{ou,min} = l_b/l_d = 0.30$

FRP Wrapping Data

Type: Carbon

Dry properties (design values)

Thickness, $t = 1.00$

Tensile Strength, $f_{fu} = 840.00$

Tensile Modulus, $E_f = 82000.00$

Elongation, $e_{fu} = 0.009$

Number of directions, $NoDir = 1$

Fiber orientations, $bi = 0.00^\circ$

Number of layers, $NL = 1$

Radius of rounding corners, $R = 40.00$

Stepwise Properties

EDGE -A-

Bending Moment, $M_a = 1.1533666E-009$

Shear Force, $V_a = -3.4066156E-013$

EDGE -B-

Bending Moment, $M_b = -1.3104847E-010$

Shear Force, $V_b = 3.4066156E-013$

BOTH EDGES

Axial Force, $F = -7386.194$

Longitudinal Reinforcement Area Distribution (in 2 divisions)

-Tension: $As_t = 0.00$

-Compression: $As_c = 3053.628$

Longitudinal Reinforcement Area Distribution (in 3 divisions)

-Tension: $As_{t,ten} = 1017.876$

-Compression: $A_{sl,com} = 1017.876$

-Middle: $A_{sl,mid} = 1017.876$

Mean Diameter of Tension Reinforcement, $Db_{L,ten} = 18.00$

New component: From table 7-7, ASCE 41_17: Final Shear Capacity $V_R = 1.0 \cdot V_n = 614519.737$

V_n ((10.3), ASCE 41-17) = $k_n \cdot V_{CoI0} = 614519.737$

$V_{CoI} = 614519.737$

$k_n = 1.00$

$displacement_ductility_demand = 0.00$

NOTE: In expression (10-3) ' $V_s = A_v \cdot f_y \cdot d / s$ ' is replaced by ' $V_s + f \cdot V_f$ ' where V_f is the contribution of FRPs (11.3), ACI 440).

= 1 (normal-weight concrete)

Mean concrete strength: $f_c' = (f_c'_{jacket} \cdot Area_{jacket} + f_c'_{core} \cdot Area_{core}) / Area_{section} = 25.00$, but $f_c'^{0.5} \leq 8.3$ MPa (22.5.3.1, ACI 318-14)

$M/Vd = 2.00$

$\mu_u = 1.3104847E-010$

$V_u = 3.4066156E-013$

$d = 0.8 \cdot D = 400.00$

$N_u = 7386.194$

$A_g = 196349.541$

From (11.5.4.8), ACI 318-14: $V_s = V_{s1} + V_{s2} = 246740.11$

$V_{s1} = 246740.11$ is calculated for jacket, with:

$A_v = \sqrt{2} \cdot A_{stirrup} = 123370.055$

$f_y = 500.00$

$s = 100.00$

V_{s1} is multiplied by $Col1 = 1.00$

$s/d = 0.25$

$V_{s2} = 0.00$ is calculated for core, with:

$A_v = \sqrt{2} \cdot A_{stirrup} = 78956.835$

$f_y = 500.00$

$s = 250.00$

V_{s2} is multiplied by $Col2 = 0.00$

$s/d = 1.04167$

V_f ((11-3)-(11.4), ACI 440) = 308320.00

$f = 0.95$, for fully-wrapped sections

$w_f/s_f = 1$ (FRP strips adjacent to one another).

In (11.3) $\sin + \cos$ is replaced with $(\cot + \cot) \sin \alpha$ which is more a generalised expression, where α is the angle of the crack direction (see KANEPE).

This later relation, considered as a function $V_f(\alpha)$, is implemented for every different fiber orientation α_i , as well as for 2 crack directions, $\alpha = 45^\circ$ and $\alpha = -45^\circ$ to take into consideration the cyclic seismic loading.

orientation 1: $\alpha_1 = b_1 + 90^\circ = 90.00$

$V_f = \text{Min}(|V_f(45, \alpha_1)|, |V_f(-45, \alpha_1)|)$, with:

total thickness per orientation, $t_{f1} = N_L \cdot t / N_{oDir} = 1.00$

$d_{fv} = d$ (figure 11.2, ACI 440) = 470.00

f_{fe} ((11-5), ACI 440) = 328.00

$E_f = 82000.00$

$f_e = 0.004$, from (11.6a), ACI 440

with $f_u = 0.009$

From (11-11), ACI 440: $V_s + V_f \leq 417394.406$

$b_w \cdot d = \sqrt{4} \cdot d = 125663.706$

$displacement_ductility_demand$ is calculated as ϕ / y

- Calculation of ϕ / y for END B -

for rotation axis 2 and integ. section (b)

From analysis, chord rotation $\phi = 8.1346664E-021$

$y = (M_y \cdot L_s / 3) / E_{eff} = 0.00453062$ ((4.29), Biskinis Phd)

$M_y = 2.2517E+008$

$L_s = M/V$ (with $L_s > 0.1 \cdot L$ and $L_s < 2 \cdot L$) = 1500.00

From table 10.5, ASCE 41_17: $E_{eff} = factor * E_c * I_g = 2.4850E+013$

factor = 0.30

$A_g = 196349.541$

Mean concrete strength: $f_c' = (f_c'_{jacket} * Area_{jacket} + f_c'_{core} * Area_{core}) / Area_{section} = 33.00$

$N = 7386.194$

$E_c * I_g = E_c_{jacket} * I_g_{jacket} + E_c_{core} * I_g_{core} = 8.2833E+013$

Calculation of Yielding Moment M_y

Calculation of ϕ_y and M_y according to (7) - (8) in Biskinis and Fardis

$M_y = \text{Min}(M_{y_ten}, M_{y_com}) = 2.2517E+008$

$\phi_y = 6.4424821E-006$

$M_{y_ten} (8c) = 2.2517E+008$

$\phi_{y_ten} (7c) = 61.81367$

error of function (7c) = 0.00026388

$M_{y_com} (8d) = 8.1922E+008$

$\phi_{y_com} (7d) = 63.67467$

error of function (7d) = -0.00874883

with ((10.1), ASCE 41-17) $\phi_y = \text{Min}(\phi_y, 1.25 * \phi_y * (l_b / l_d)^{2/3}) = 0.0027778$

$\phi_{y_com} = 0.002$

$\phi_{y_ten} = 0.45$ ((9c) in Biskinis and Fardis for FRP Wrap)

$d_1 = 44.00$

$R = 250.00$

$v = 0.00101359$

$N = 7386.194$

$A_c = 196349.541$

with ((10.1), ASCE 41-17) $\phi_y = \text{Min}(\phi_y, 1.25 * \phi_y * (l_b / l_d)^{2/3}) = 0.23280363$

with $f_c' ((12.3), ACI 440) = 37.11312$

$f_c = 33.00$

$\beta_1 = 1.312$

$k = 1$

Effective FRP thickness, $t_f = NL * t * \text{Cos}(b_1) = 1.00$

$\phi_{y_com} ((12.5) \text{ and } (12.7)) = 0.004$

$f_u = 0.009$

$E_f = 82000.00$

Calculation of ratio l_b / l_d

Inadequate Lap Length with $l_b / l_d = 0.30$

End Of Calculation of Shear Capacity for element: column JCC1 of floor 1

At local axis: 3

Integration Section: (b)

Calculation No. 16

column C1, Floor 1


Limit State: Life Safety (data interpolation between analysis steps 1 and 2)

Analysis: Uniform +X

Check: Chord rotation capacity (θ_r)

Edge: End

Local Axis: (3)



Start Of Calculation of Shear Capacity ratio for element: column JCC1 of floor 1

At Shear local axis: 3

(Bending local axis: 2)

Section Type: rcjcs

Constant Properties

Knowledge Factor, $\gamma = 1.00$

Mean strength values are used for both shear and moment calculations.

Consequently:

Jacket

New material of Primary Member: Concrete Strength, $f_c = f_{cm} = 33.00$

New material of Primary Member: Steel Strength, $f_s = f_{sm} = 555.56$

Concrete Elasticity, $E_c = 26999.444$

Steel Elasticity, $E_s = 200000.00$

Existing Column

New material of Primary Member: Concrete Strength, $f_c = f_{cm} = 33.00$

New material of Primary Member: Steel Strength, $f_s = f_{sm} = 555.56$

Concrete Elasticity, $E_c = 26999.444$

Steel Elasticity, $E_s = 200000.00$

#####

Note: Especially for the calculation of moment strengths,

the above steel re-bar strengths are multiplied by 1.25 according to R18.6.5, ACI 318-14

Jacket

New material: Steel Strength, $f_s = 1.25 \cdot f_{sm} = 694.45$

Existing Column

New material: Steel Strength, $f_s = 1.25 \cdot f_{sm} = 694.45$

#####

External Diameter, $D = 500.00$

Internal Diameter, $D = 300.00$

Cover Thickness, $c = 25.00$

Mean Confinement Factor overall section = 1.51481

Element Length, $L = 3000.00$

Primary Member

Ribbed Bars

Ductile Steel

Without Detailing for Earthquake Resistance (including stirrups not closed at 135°)

Longitudinal Bars With Ends Lapped Starting at the End Sections

Inadequate Lap Length with $l_o/l_{o,u,min} = 0.30$

FRP Wrapping Data

Type: Carbon

Dry properties (design values)

Thickness, $t = 1.00$

Tensile Strength, $f_{fu} = 840.00$

Tensile Modulus, $E_f = 82000.00$

Elongation, $\epsilon_{fu} = 0.009$

Number of directions, $N_{oDir} = 1$

Fiber orientations, $b_i = 0.00^\circ$

Number of layers, $N_L = 1$

Radius of rounding corners, $R = 40.00$

Stepwise Properties

At local axis: 3

EDGE -A-

Shear Force, $V_a = 3.4807814E-030$

EDGE -B-

Shear Force, $V_b = -3.4807814E-030$

BOTH EDGES

Axial Force, $F = -7389.214$

Longitudinal Reinforcement Area Distribution (in 2 divisions)

-Tension: $A_{sl,t} = 0.00$

-Compression: $A_{sl,c} = 3053.628$

Longitudinal Reinforcement Area Distribution (in 3 divisions)

-Tension: $A_{sl,ten} = 1017.876$

-Compression: $A_{sl,com} = 1017.876$

-Middle: $A_{sl,mid} = 1017.876$

Calculation of Shear Capacity ratio, $V_e/V_r = 0.23017425$

Member Controlled by Flexure ($V_e/V_r < 1$)

Calculation of Shear Demand from fig. R18.6.5, ACI 318-14 $V_e = (M_{pr1} + M_{pr2})/l_n = 162459.651$

with

$M_{pr1} = \text{Max}(M_{u1+}, M_{u1-}) = 2.4369E+008$

$M_{u1+} = 2.4369E+008$, is the ultimate moment strength at the edge 1 of the member in the actual moment direction which is defined for the static loading combination

$M_{u1-} = 2.4369E+008$, is the ultimate moment strength at the edge 1 of the member in the opposite moment direction which is defined for the static loading combination

$M_{pr2} = \text{Max}(M_{u2+}, M_{u2-}) = 2.4369E+008$

$M_{u2+} = 2.4369E+008$, is the ultimate moment strength at the edge 2 of the member in the actual moment direction which is defined for the static loading combination

$M_{u2-} = 2.4369E+008$, is the ultimate moment strength at the edge 2 of the member in the opposite moment direction which is defined for the static loading combination

Calculation of M_{u1+}

Calculation of ultimate Moment Strength ((3.67), Biskinis Phd), M_u

$M_u = 2.4369E+008$

$\lambda = 0.80285146$

$\lambda' = 0.71403327$

error of function (3.68), Biskinis Phd = 27987.158

From 5A.2, TBDY: $f_{cc} = f_c \cdot c = 49.98874$

conf. factor $c = 1.51481$

$f_c = 33.00$

From 10.3.5, ASCE 41-17, Final value of f_y : $f_y \cdot \text{Min}(1, 1.25 \cdot (l_b/l_d)^{2/3}) = 389.0139$

$l_b/l_d = 0.30$

$d_1 = 44.00$

$R = 250.00$

$v = 0.00100813$

$$N = 7389.214$$
$$Ac = 196349.541$$
$$= *Min(1,1.25*(lb/d)^{2/3}) = 0.1620683$$

Calculation of ratio lb/d

Inadequate Lap Length with lb/d = 0.30

Calculation of Mu1-

Calculation of ultimate Moment Strength ((3.67), Biskinis Phd), Mu
Mu = 2.4369E+008

$$= 0.80285146$$
$$' = 0.71403327$$

error of function (3.68), Biskinis Phd = 27987.158

From 5A.2, TBDY: fcc = fc* c = 49.98874
conf. factor c = 1.51481
fc = 33.00

From 10.3.5, ASCE 41-17, Final value of fy: fy*Min(1,1.25*(lb/d)^{2/3}) = 389.0139

lb/d = 0.30
d1 = 44.00
R = 250.00
v = 0.00100813
N = 7389.214
Ac = 196349.541
= *Min(1,1.25*(lb/d)^{2/3}) = 0.1620683

Calculation of ratio lb/d

Inadequate Lap Length with lb/d = 0.30

Calculation of Mu2+

Calculation of ultimate Moment Strength ((3.67), Biskinis Phd), Mu
Mu = 2.4369E+008

$$= 0.80285146$$
$$' = 0.71403327$$

error of function (3.68), Biskinis Phd = 27987.158

From 5A.2, TBDY: fcc = fc* c = 49.98874
conf. factor c = 1.51481
fc = 33.00

From 10.3.5, ASCE 41-17, Final value of fy: fy*Min(1,1.25*(lb/d)^{2/3}) = 389.0139

lb/d = 0.30
d1 = 44.00
R = 250.00
v = 0.00100813
N = 7389.214
Ac = 196349.541
= *Min(1,1.25*(lb/d)^{2/3}) = 0.1620683

Calculation of ratio lb/d

Inadequate Lap Length with lb/d = 0.30

Calculation of Mu2-

Calculation of ultimate Moment Strength ((3.67), Biskinis Phd), Mu
Mu = 2.4369E+008

$$= 0.80285146$$

$$' = 0.71403327$$

error of function (3.68), Biskinis Phd = 27987.158

From 5A.2, TBDY: $f_{cc} = f_c \cdot c = 49.98874$

conf. factor $c = 1.51481$

$f_c = 33.00$

From 10.3.5, ASCE 41-17, Final value of fy: $f_y \cdot \text{Min}(1, 1.25 \cdot (l_b/d)^{2/3}) = 389.0139$

$l_b/d = 0.30$

$d_1 = 44.00$

$R = 250.00$

$v = 0.00100813$

$N = 7389.214$

$A_c = 196349.541$

$= \cdot \text{Min}(1, 1.25 \cdot (l_b/d)^{2/3}) = 0.1620683$

Calculation of ratio l_b/d

Inadequate Lap Length with $l_b/d = 0.30$

Calculation of Shear Strength $V_r = \text{Min}(V_{r1}, V_{r2}) = 705811.584$

Calculation of Shear Strength at edge 1, $V_{r1} = 705811.584$

$V_{r1} = V_{Col}$ ((10.3), ASCE 41-17) = $k_{nl} \cdot V_{Col0}$

$V_{Col0} = 705811.584$

$k_{nl} = 1$ (zero step-static loading)

NOTE: In expression (10-3) ' $V_s = A_v \cdot f_y \cdot d/s$ ' is replaced by ' $V_s + f \cdot V_f$ ' where V_f is the contribution of FRPs (11.3), ACI 440).

$= 1$ (normal-weight concrete)

Mean concrete strength: $f_c' = (f_c'_{jacket} \cdot \text{Area}_{jacket} + f_c'_{core} \cdot \text{Area}_{core}) / \text{Area}_{section} = 33.00$, but $f_c'^{0.5} \leq 8.3$ MPa (22.5.3.1, ACI 318-14)

$M/Vd = 2.00$

$M_u = 1.2438899E-011$

$V_u = 3.4807814E-030$

$d = 0.8 \cdot D = 400.00$

$N_u = 7389.214$

$A_g = 196349.541$

From (11.5.4.8), ACI 318-14: $V_s = V_{s1} + V_{s2} = 274157.871$

$V_{s1} = 274157.871$ is calculated for jacket, with:

$A_v = \sqrt{2} \cdot A_{stirup} = 123370.055$

$f_y = 555.56$

$s = 100.00$

V_{s1} is multiplied by $Col1 = 1.00$

$s/d = 0.25$

$V_{s2} = 0.00$ is calculated for core, with:

$A_v = \sqrt{2} \cdot A_{stirup} = 78956.835$

$f_y = 555.56$

$s = 250.00$

V_{s2} is multiplied by $Col2 = 0.00$

$s/d = 1.04167$

V_f ((11-3)-(11.4), ACI 440) = 308320.00

$f = 0.95$, for fully-wrapped sections

$w_f/s_f = 1$ (FRP strips adjacent to one another).

In (11.3) $\sin \theta + \cos \theta$ is replaced with $(\cot \theta + \csc \theta) \sin \theta$ which is more a generalised expression, where θ is the angle of the crack direction (see KANEPE). This later relation, considered as a function $V_f(\theta)$, is implemented for every different fiber orientation a_i , as well as for 2 crack directions, $\theta = 45^\circ$ and $\theta = -45^\circ$ to take into consideration the cyclic seismic loading.

orientation 1: $\theta = b1 + 90^\circ = 90.00$
 $V_f = \text{Min}(|V_f(45, \theta)|, |V_f(-45, a1)|)$, with:
total thickness per orientation, $t_{f1} = NL \cdot t / \text{NoDir} = 1.00$
 $d_{fv} = d$ (figure 11.2, ACI 440) = 470.00
 f_{fe} ((11-5), ACI 440) = 328.00
 $E_f = 82000.00$
 $f_e = 0.004$, from (11.6a), ACI 440
with $f_u = 0.009$
From (11-11), ACI 440: $V_s + V_f \leq 479549.663$
 $b_w \cdot d = \frac{A_s \cdot d}{4} = 125663.706$

Calculation of Shear Strength at edge 2, $V_{r2} = 705811.584$
 $V_{r2} = V_{Col}$ ((10.3), ASCE 41-17) = $k_{nl} \cdot V_{Col0}$
 $V_{Col0} = 705811.584$
 $k_{nl} = 1$ (zero step-static loading)

NOTE: In expression (10-3) ' $V_s = A_v \cdot f_y \cdot d / s$ ' is replaced by ' $V_s + f \cdot V_f$ ' where V_f is the contribution of FRPs (11.3), ACI 440).

$k_{nl} = 1$ (normal-weight concrete)
Mean concrete strength: $f'_c = (f'_{c,jacket} \cdot \text{Area}_{jacket} + f'_{c,core} \cdot \text{Area}_{core}) / \text{Area}_{section} = 33.00$, but $f'_c^{0.5} \leq 8.3$ MPa (22.5.3.1, ACI 318-14)
 $M/Vd = 2.00$
 $\mu_u = 1.2438899E-011$
 $V_u = 3.4807814E-030$
 $d = 0.8 \cdot D = 400.00$
 $N_u = 7389.214$
 $A_g = 196349.541$
From (11.5.4.8), ACI 318-14: $V_s = V_{s1} + V_{s2} = 274157.871$
 $V_{s1} = 274157.871$ is calculated for jacket, with:
 $A_v = \frac{A_s}{2} = 123370.055$
 $f_y = 555.56$
 $s = 100.00$
 V_{s1} is multiplied by $\text{Col1} = 1.00$
 $s/d = 0.25$
 $V_{s2} = 0.00$ is calculated for core, with:
 $A_v = \frac{A_s}{2} = 78956.835$
 $f_y = 555.56$
 $s = 250.00$
 V_{s2} is multiplied by $\text{Col2} = 0.00$
 $s/d = 1.04167$
 V_f ((11-3)-(11.4), ACI 440) = 308320.00
 $f = 0.95$, for fully-wrapped sections
 $w_f / s_f = 1$ (FRP strips adjacent to one another).
In (11.3) $\sin \theta + \cos \theta$ is replaced with $(\cot \theta + \csc \theta) \sin \theta$ which is more a generalised expression, where θ is the angle of the crack direction (see KANEPE). This later relation, considered as a function $V_f(\theta)$, is implemented for every different fiber orientation a_i , as well as for 2 crack directions, $\theta = 45^\circ$ and $\theta = -45^\circ$ to take into consideration the cyclic seismic loading.

orientation 1: $\theta = b1 + 90^\circ = 90.00$
 $V_f = \text{Min}(|V_f(45, \theta)|, |V_f(-45, a1)|)$, with:
total thickness per orientation, $t_{f1} = NL \cdot t / \text{NoDir} = 1.00$
 $d_{fv} = d$ (figure 11.2, ACI 440) = 470.00
 f_{fe} ((11-5), ACI 440) = 328.00
 $E_f = 82000.00$
 $f_e = 0.004$, from (11.6a), ACI 440
with $f_u = 0.009$
From (11-11), ACI 440: $V_s + V_f \leq 479549.663$
 $b_w \cdot d = \frac{A_s \cdot d}{4} = 125663.706$

End Of Calculation of Shear Capacity ratio for element: column JCC1 of floor 1
At local axis: 3

Start Of Calculation of Shear Capacity ratio for element: column JCC1 of floor 1
At Shear local axis: 2
(Bending local axis: 3)
Section Type: rcjcs

Constant Properties

Knowledge Factor, = 1.00
Mean strength values are used for both shear and moment calculations.
Consequently:

Jacket

New material of Primary Member: Concrete Strength, $f_c = f_{cm} = 33.00$
New material of Primary Member: Steel Strength, $f_s = f_{sm} = 555.56$
Concrete Elasticity, $E_c = 26999.444$
Steel Elasticity, $E_s = 200000.00$

Existing Column

New material of Primary Member: Concrete Strength, $f_c = f_{cm} = 33.00$
New material of Primary Member: Steel Strength, $f_s = f_{sm} = 555.56$
Concrete Elasticity, $E_c = 26999.444$
Steel Elasticity, $E_s = 200000.00$

#####

Note: Especially for the calculation of moment strengths,
the above steel re-bar strengths are multiplied by 1.25 according to R18.6.5, ACI 318-14

Jacket

New material: Steel Strength, $f_s = 1.25 * f_{sm} = 694.45$

Existing Column

New material: Steel Strength, $f_s = 1.25 * f_{sm} = 694.45$

#####

External Diameter, $D = 500.00$

Internal Diameter, $D = 300.00$

Cover Thickness, $c = 25.00$

Mean Confinement Factor overall section = 1.51481

Element Length, $L = 3000.00$

Primary Member

Ribbed Bars

Ductile Steel

Without Detailing for Earthquake Resistance (including stirrups not closed at 135°)

Longitudinal Bars With Ends Lapped Starting at the End Sections

Inadequate Lap Length with $l_o/l_{ou, min} = 0.30$

FRP Wrapping Data

Type: Carbon

Dry properties (design values)

Thickness, $t = 1.00$

Tensile Strength, $f_{fu} = 840.00$

Tensile Modulus, $E_f = 82000.00$

Elongation, $e_{fu} = 0.009$

Number of directions, $N_{oDir} = 1$

Fiber orientations, $b_i: 0.00^\circ$

Number of layers, $N_L = 1$

Radius of rounding corners, $R = 40.00$

Stepwise Properties

At local axis: 2

EDGE -A-

Shear Force, $V_a = -2.1312935E-046$

EDGE -B-

Shear Force, $V_b = 2.1312935E-046$

BOTH EDGES

Axial Force, $F = -7389.214$

Longitudinal Reinforcement Area Distribution (in 2 divisions)

-Tension: $A_{st} = 0.00$

-Compression: $A_{sc} = 3053.628$
Longitudinal Reinforcement Area Distribution (in 3 divisions)
-Tension: $A_{s,ten} = 1017.876$
-Compression: $A_{s,com} = 1017.876$
-Middle: $A_{s,mid} = 1017.876$

Calculation of Shear Capacity ratio, $V_e/V_r = 0.23017425$
Member Controlled by Flexure ($V_e/V_r < 1$)
Calculation of Shear Demand from fig. R18.6.5, ACI 318-14 $V_e = (M_{pr1} + M_{pr2})/l_n = 162459.651$
with

$M_{pr1} = \text{Max}(M_{u1+}, M_{u1-}) = 2.4369E+008$
 $M_{u1+} = 2.4369E+008$, is the ultimate moment strength at the edge 1 of the member in the actual moment direction which is defined for the static loading combination
 $M_{u1-} = 2.4369E+008$, is the ultimate moment strength at the edge 1 of the member in the opposite moment direction which is defined for the static loading combination
 $M_{pr2} = \text{Max}(M_{u2+}, M_{u2-}) = 2.4369E+008$
 $M_{u2+} = 2.4369E+008$, is the ultimate moment strength at the edge 2 of the member in the actual moment direction which is defined for the static loading combination
 $M_{u2-} = 2.4369E+008$, is the ultimate moment strength at the edge 2 of the member in the opposite moment direction which is defined for the static loading combination

Calculation of M_{u1+}

Calculation of ultimate Moment Strength ((3.67), Biskinis Phd), M_u
 $M_u = 2.4369E+008$

= 0.80285146
' = 0.71403327
error of function (3.68), Biskinis Phd = 27987.158
From 5A.2, TBDY: $f_{cc} = f_c^* c = 49.98874$
conf. factor $c = 1.51481$
 $f_c = 33.00$
From 10.3.5, ASCE 41-17, Final value of $f_y: f_y \cdot \text{Min}(1, 1.25 \cdot (l_b/d)^{2/3}) = 389.0139$
 $l_b/d = 0.30$
 $d_1 = 44.00$
 $R = 250.00$
 $v = 0.00100813$
 $N = 7389.214$
 $A_c = 196349.541$
= $\text{Min}(1, 1.25 \cdot (l_b/d)^{2/3}) = 0.1620683$

Calculation of ratio l_b/d

Inadequate Lap Length with $l_b/d = 0.30$

Calculation of M_{u1-}

Calculation of ultimate Moment Strength ((3.67), Biskinis Phd), M_u
 $M_u = 2.4369E+008$

= 0.80285146
' = 0.71403327
error of function (3.68), Biskinis Phd = 27987.158
From 5A.2, TBDY: $f_{cc} = f_c^* c = 49.98874$
conf. factor $c = 1.51481$
 $f_c = 33.00$

From 10.3.5, ASCE 41-17, Final value of f_y : $f_y \cdot \text{Min}(1, 1.25 \cdot (l_b/d)^{2/3}) = 389.0139$

$$l_b/d = 0.30$$

$$d_1 = 44.00$$

$$R = 250.00$$

$$v = 0.00100813$$

$$N = 7389.214$$

$$A_c = 196349.541$$

$$= \text{Min}(1, 1.25 \cdot (l_b/d)^{2/3}) = 0.1620683$$

Calculation of ratio l_b/d

Inadequate Lap Length with $l_b/d = 0.30$

Calculation of μ_{2+}

Calculation of ultimate Moment Strength ((3.67), Biskinis Phd), μ

$$\mu = 2.4369E+008$$

$$= 0.80285146$$

$$' = 0.71403327$$

error of function (3.68), Biskinis Phd = 27987.158

From 5A.2, TBDY: $f_{cc} = f_c \cdot c = 49.98874$

$$\text{conf. factor } c = 1.51481$$

$$f_c = 33.00$$

From 10.3.5, ASCE 41-17, Final value of f_y : $f_y \cdot \text{Min}(1, 1.25 \cdot (l_b/d)^{2/3}) = 389.0139$

$$l_b/d = 0.30$$

$$d_1 = 44.00$$

$$R = 250.00$$

$$v = 0.00100813$$

$$N = 7389.214$$

$$A_c = 196349.541$$

$$= \text{Min}(1, 1.25 \cdot (l_b/d)^{2/3}) = 0.1620683$$

Calculation of ratio l_b/d

Inadequate Lap Length with $l_b/d = 0.30$

Calculation of μ_{2-}

Calculation of ultimate Moment Strength ((3.67), Biskinis Phd), μ

$$\mu = 2.4369E+008$$

$$= 0.80285146$$

$$' = 0.71403327$$

error of function (3.68), Biskinis Phd = 27987.158

From 5A.2, TBDY: $f_{cc} = f_c \cdot c = 49.98874$

$$\text{conf. factor } c = 1.51481$$

$$f_c = 33.00$$

From 10.3.5, ASCE 41-17, Final value of f_y : $f_y \cdot \text{Min}(1, 1.25 \cdot (l_b/d)^{2/3}) = 389.0139$

$$l_b/d = 0.30$$

$$d_1 = 44.00$$

$$R = 250.00$$

$$v = 0.00100813$$

$$N = 7389.214$$

$$A_c = 196349.541$$

$$= \text{Min}(1, 1.25 \cdot (l_b/d)^{2/3}) = 0.1620683$$

Calculation of ratio l_b/l_d

Inadequate Lap Length with $l_b/l_d = 0.30$

Calculation of Shear Strength $V_r = \text{Min}(V_{r1}, V_{r2}) = 705811.584$

Calculation of Shear Strength at edge 1, $V_{r1} = 705811.584$

$V_{r1} = V_{Col}$ ((10.3), ASCE 41-17) = $k_{nl} \cdot V_{Col0}$

$V_{Col0} = 705811.584$

$k_{nl} = 1$ (zero step-static loading)

NOTE: In expression (10-3) ' $V_s = A_v \cdot f_y \cdot d / s$ ' is replaced by ' $V_s + f \cdot V_f$ ' where V_f is the contribution of FRPs (11.3), ACI 440).

= 1 (normal-weight concrete)

Mean concrete strength: $f_c' = (f_c'_{jacket} \cdot \text{Area}_{jacket} + f_c'_{core} \cdot \text{Area}_{core}) / \text{Area}_{section} = 33.00$, but $f_c'^{0.5} \leq 8.3$ MPa (22.5.3.1, ACI 318-14)

$M/Vd = 2.00$

$\mu_u = 1.5940012E-011$

$\nu_u = 2.1312935E-046$

$d = 0.8 \cdot D = 400.00$

$N_u = 7389.214$

$A_g = 196349.541$

From (11.5.4.8), ACI 318-14: $V_s = V_{s1} + V_{s2} = 274157.871$

$V_{s1} = 274157.871$ is calculated for jacket, with:

$A_v = \sqrt{2} \cdot A_{stirrup} = 123370.055$

$f_y = 555.56$

$s = 100.00$

V_{s1} is multiplied by $\text{Col1} = 1.00$

$s/d = 0.25$

$V_{s2} = 0.00$ is calculated for core, with:

$A_v = \sqrt{2} \cdot A_{stirrup} = 78956.835$

$f_y = 555.56$

$s = 250.00$

V_{s2} is multiplied by $\text{Col2} = 0.00$

$s/d = 1.04167$

V_f ((11-3)-(11.4), ACI 440) = 308320.00

$f = 0.95$, for fully-wrapped sections

$w_f/s_f = 1$ (FRP strips adjacent to one another).

In (11.3) $\sin \theta + \cos \theta$ is replaced with $(\cot \theta + \cot \alpha) \sin \alpha$ which is more a generalised expression,

where θ is the angle of the crack direction (see KANEPE).

This later relation, considered as a function $V_f(\theta, \alpha)$, is implemented for every different fiber orientation α_i , as well as for 2 crack directions, $\theta = 45^\circ$ and $\theta = -45^\circ$ to take into consideration the cyclic seismic loading.

orientation 1: $\theta = b1 + 90^\circ = 90.00$

$V_f = \text{Min}(|V_f(45, \theta)|, |V_f(-45, \theta)|)$, with:

total thickness per orientation, $t_{f1} = N_L \cdot t / N_{oDir} = 1.00$

$d_{fv} = d$ (figure 11.2, ACI 440) = 470.00

f_{fe} ((11-5), ACI 440) = 328.00

$E_f = 82000.00$

$f_e = 0.004$, from (11.6a), ACI 440

with $f_u = 0.009$

From (11-11), ACI 440: $V_s + V_f \leq 479549.663$

$b_w \cdot d = \sqrt{2} \cdot d \cdot d / 4 = 125663.706$

Calculation of Shear Strength at edge 2, $V_{r2} = 705811.584$

$V_{r2} = V_{Col}$ ((10.3), ASCE 41-17) = $k_{nl} \cdot V_{Col0}$

$V_{Col0} = 705811.584$

$k_{nl} = 1$ (zero step-static loading)

NOTE: In expression (10-3) ' $V_s = A_v \cdot f_y \cdot d / s$ ' is replaced by ' $V_s + f \cdot V_f$ ' where V_f is the contribution of FRPs (11.3), ACI 440).

= 1 (normal-weight concrete)
Mean concrete strength: $f_c' = (f_c'_{jacket} \cdot Area_{jacket} + f_c'_{core} \cdot Area_{core}) / Area_{section} = 33.00$, but $f_c'^{0.5} \leq 8.3$ MPa (22.5.3.1, ACI 318-14)
 $M/Vd = 2.00$
 $\mu_u = 1.5940012E-011$
 $V_u = 2.1312935E-046$
 $d = 0.8 \cdot D = 400.00$
 $N_u = 7389.214$
 $A_g = 196349.541$
From (11.5.4.8), ACI 318-14: $V_s = V_{s1} + V_{s2} = 274157.871$
 $V_{s1} = 274157.871$ is calculated for jacket, with:
 $A_v = \sqrt{2} \cdot A_{stirrup} = 123370.055$
 $f_y = 555.56$
 $s = 100.00$
 V_{s1} is multiplied by $Col1 = 1.00$
 $s/d = 0.25$
 $V_{s2} = 0.00$ is calculated for core, with:
 $A_v = \sqrt{2} \cdot A_{stirrup} = 78956.835$
 $f_y = 555.56$
 $s = 250.00$
 V_{s2} is multiplied by $Col2 = 0.00$
 $s/d = 1.04167$
 $V_f ((11-3)-(11.4), ACI 440) = 308320.00$
 $f = 0.95$, for fully-wrapped sections
 $w_f/s_f = 1$ (FRP strips adjacent to one another).
In (11.3) $\sin \theta + \cos \theta$ is replaced with $(\cot \theta + \csc \theta) \sin \alpha$ which is more a generalised expression, where θ is the angle of the crack direction (see KANEPE).
This later relation, considered as a function $V_f(\theta, \alpha)$, is implemented for every different fiber orientation α_i , as well as for 2 crack directions, $\theta = 45^\circ$ and $\theta = -45^\circ$ to take into consideration the cyclic seismic loading.
orientation 1: $\theta = 45^\circ + 90^\circ = 135^\circ$
 $V_f = \text{Min}(|V_f(45, 1)|, |V_f(-45, 1)|)$, with:
total thickness per orientation, $t_{f1} = NL \cdot t / N_{oDir} = 1.00$
 $d_{fv} = d$ (figure 11.2, ACI 440) = 470.00
 $f_{fe} ((11-5), ACI 440) = 328.00$
 $E_f = 82000.00$
 $f_e = 0.004$, from (11.6a), ACI 440
with $f_u = 0.009$
From (11-11), ACI 440: $V_s + V_f \leq 479549.663$
 $b_w \cdot d = \sqrt{V_s + V_f} \cdot d / 4 = 125663.706$

End Of Calculation of Shear Capacity ratio for element: column JCC1 of floor 1
At local axis: 2

Start Of Calculation of Chord Rotation Capacity for element: column JCC1 of floor 1
At local axis: 3
Integration Section: (b)
Section Type: rcjcs

Constant Properties

Knowledge Factor, $\phi = 1.00$
Chord Rotation is generally considered as Deformation-Controlled Action according to Table C7-1, ASCE 41-17.
Mean strengths are used for Deformation-Controlled Actions according to 7.5.1.3, ASCE 41-17
Consequently:
Jacket
New material of Primary Member: Concrete Strength, $f_c = f_{cm} = 33.00$
New material of Primary Member: Steel Strength, $f_s = f_{sm} = 555.56$
Concrete Elasticity, $E_c = 26999.444$
Steel Elasticity, $E_s = 200000.00$
Existing Column
New material of Primary Member: Concrete Strength, $f_c = f_{cm} = 33.00$
New material of Primary Member: Steel Strength, $f_s = f_{sm} = 555.56$
Concrete Elasticity, $E_c = 26999.444$

Steel Elasticity, $E_s = 200000.00$
 External Diameter, $D = 500.00$
 Internal Diameter, $D = 300.00$
 Cover Thickness, $c = 25.00$
 Element Length, $L = 3000.00$
 Primary Member
 Ribbed Bars
 Ductile Steel
 Without Detailing for Earthquake Resistance (including stirrups not closed at 135°)
 Longitudinal Bars With Ends Lapped Starting at the End Sections
 Inadequate Lap Length with $l_b/l_d = 0.30$
 FRP Wrapping Data
 Type: Carbon
 Dry properties (design values)
 Thickness, $t = 1.00$
 Tensile Strength, $f_{fu} = 840.00$
 Tensile Modulus, $E_f = 82000.00$
 Elongation, $e_{fu} = 0.009$
 Number of directions, $NoDir = 1$
 Fiber orientations, $bi = 0.00^\circ$
 Number of layers, $NL = 1$
 Radius of rounding corners, $R = 40.00$

Stepwise Properties

Bending Moment, $M = 0.12607815$
 Shear Force, $V_2 = 7549.016$
 Shear Force, $V_3 = 3.4066156E-013$
 Axial Force, $F = -7386.194$
 Longitudinal Reinforcement Area Distribution (in 2 divisions)
 -Tension: $As_t = 0.00$
 -Compression: $As_c = 3053.628$
 Longitudinal Reinforcement Area Distribution (in 3 divisions)
 -Tension: $As_{ten} = 1017.876$
 -Compression: $As_{com} = 1017.876$
 -Middle: $As_{mid} = 1017.876$
 Mean Diameter of Tension Reinforcement, $Db_L = 18.00$

New component: From table 7-7, ASCE 41_17: Final chord rotation Capacity $u_{,R} = 1.0^*$ $u = 0.03090612$
 $u = y + p = 0.03090612$

- Calculation of y -

$y = (M_y * L_s / 3) / E_{eff} = 0.00090612$ ((4.29), Biskinis Phd)
 $M_y = 2.2517E+008$
 $L_s = M/V$ (with $L_s > 0.1 * L$ and $L_s < 2 * L$) = 300.00
 From table 10.5, ASCE 41_17: $E_{eff} = factor * E_c * I_g = 2.4850E+013$
 $factor = 0.30$
 $A_g = 196349.541$
 Mean concrete strength: $f'_c = (f'_{c_jacket} * Area_{jacket} + f'_{c_core} * Area_{core}) / Area_{section} = 33.00$
 $N = 7386.194$
 $E_c * I_g = E_{c_jacket} * I_{g_jacket} + E_{c_core} * I_{g_core} = 8.2833E+013$

Calculation of Yielding Moment M_y

Calculation of y and M_y according to (7) - (8) in Biskinis and Fardis

$M_y = \text{Min}(M_{y_ten}, M_{y_com}) = 2.2517E+008$
 $y = 6.4424821E-006$
 $M_{y_ten} (8c) = 2.2517E+008$

$\rho_{ten}(7c) = 61.81367$
 error of function (7c) = 0.00026388
 $M_{y_com}(8d) = 8.1922E+008$
 $\rho_{com}(7d) = 63.67467$
 error of function (7d) = -0.00874883
 with ((10.1), ASCE 41-17) $e_y = \text{Min}(e_y, 1.25 * e_y * (l_b/l_d)^{2/3}) = 0.0027778$
 $e_{co} = 0.002$
 $a_{pl} = 0.45$ ((9c) in Biskinis and Fardis for FRP Wrap)
 $d_1 = 44.00$
 $R = 250.00$
 $v = 0.00101359$
 $N = 7386.194$
 $A_c = 196349.541$
 ((10.1), ASCE 41-17) $= \text{Min}(, 1.25 * \rho_{com} * (l_b/l_d)^{2/3}) = 0.23280363$
 with f_c^* ((12.3), ACI 440) = 37.11312
 $f_c = 33.00$
 $f_l = 1.312$
 $k = 1$
 Effective FRP thickness, $t_f = N L * t * \text{Cos}(b_1) = 1.00$
 e_{fe} ((12.5) and (12.7)) = 0.004
 $f_u = 0.009$
 $E_f = 82000.00$

 Calculation of ratio l_b/l_d

 Inadequate Lap Length with $l_b/l_d = 0.30$

 - Calculation of ρ_p -

 From table 10-9: $\rho_p = 0.03$

with:

- Columns controlled by inadequate development or splicing along the clear height because $l_b/l_d < 1$
 shear control ratio $V_y E / V_{CoI} O E = 0.23017425$
 $d = d_{external} = 0.00$
 $s = s_{external} = 0.00$
 $t = s_1 + s_2 + 2 * t_f / b_w * (f_{fe} / f_s) = 0.00795744$
 jacket: $s_1 = A_{v1} * (D_{c1} / 2) / (s_1 * A_g) = 0.0027646$
 $A_{v1} = 78.53982$, is the area of stirrup
 $D_{c1} = D_{ext} - 2 * \text{cover} - \text{External Hoop Diameter} = 440.00$, is the total Length of all stirrups parallel to loading (shear) direction
 $s_1 = 100.00$
 core: $s_2 = A_{v2} * (D_{c2} / 2) / (s_2 * A_g) = 0.00046968$
 $A_{v2} = 50.26548$, is the area of stirrup
 $D_{c2} = D_{int} - \text{Internal Hoop Diameter} = 292.00$, is the total Length of all stirrups parallel to loading (shear) direction
 $s_2 = 250.00$

The term $2 * t_f / b_w * (f_{fe} / f_s)$ is implemented to account for FRP contribution
 where $f = 2 * t_f / b_w$ is FRP ratio (EC8 - 3, A.4.4.3(6)) and f_{fe} / f_s normalises f to steel strength
 All these variables have already been given in Shear control ratio calculation.
 For the normalisation f_s of jacket is used.

$N_{UD} = 7386.194$
 $A_g = 196349.541$
 $f_{cE} = (f_{c_jacket} * \text{Area}_{jacket} + f_{c_core} * \text{Area}_{core}) / \text{section_area} = 33.00$
 $f_{yLE} = (f_{y_ext_Long_Reinf} * \text{Area}_{ext_Long_Reinf} + f_{y_int_Long_Reinf} * \text{Area}_{int_Long_Reinf}) / \text{Area}_{Tot_Long_Rein} = 2.1219958E-314$
 $f_{yTE} = (f_{y_ext_Trans_Reinf} * \text{Area}_{ext_Trans_Reinf} + f_{y_int_Trans_Reinf} * \text{Area}_{int_Trans_Reinf}) / \text{Area}_{Tot_Trans_Rein} = 555.56$
 $\rho_l = \text{Area}_{Tot_Long_Rein} / (A_g) = 0.015552$
 $f_{cE} = 33.00$

 End Of Calculation of Chord Rotation Capacity for element: column JCC1 of floor 1

At local axis: 3

Integration Section: (b)

