

Detailed Member Calculations

Units: N&mm

Regulation: ASCE 41-17

Calculation No. 1

- wall W1, Floor 1
- Limit State: Operational Level (data interpolation between analysis steps 1 and 2)
- Analysis: Uniform +X
- Check: Shear capacity V_{Rd}
- Edge: Start
- Local Axis: (2)



- Start Of Calculation of Shear Capacity for element: wall W1 of floor 1
- At local axis: 2
- Integration Section: (a)
- Section Type: rcrws
- Constant Properties
- Knowledge Factor, $\gamma = 1.00$
- Member Shear Force is generally considered as Force-Controlled Action according to Table C7-1, ASCE 41-17.
- Lower-bound strengths are used for Force-Controlled Actions according to 7.5.1.3, ASCE 41-17
- Consequently:
- New material of Secondary Member: Concrete Strength, $f_c = f_{c_lower_bound} = 25.00$
- New material of Secondary Member: Steel Strength, $f_s = f_{s_lower_bound} = 500.00$
- Concrete Elasticity, $E_c = 26999.444$

Steel Elasticity, $E_s = 200000.00$
 Total Height, $H_{tot} = 3000.00$
 Edges Width, $W_{edg} = 250.00$
 Edges Height, $H_{edg} = 600.00$
 Web Width, $W_{web} = 250.00$
 Cover Thickness, $c = 25.00$
 Element Length, $L = 3000.00$
 Secondary Member
 Smooth Bars
 Ductile Steel
 Without Detailing for Earthquake Resistance (including stirrups not closed at 135°)
 Longitudinal Bars With Ends Lapped Starting at the End Sections
 Inadequate Lap Length with $l_o/l_{ou,min} = l_b/l_d = 0.30$
 FRP Wrapping Data
 Type: Carbon
 Cured laminate properties (design values)
 Thickness, $t = 1.016$
 Tensile Strength, $f_{fu} = 1055.00$
 Tensile Modulus, $E_f = 64828.00$
 Elongation, $e_{fu} = 0.01$
 Number of directions, $N_{oDir} = 1$
 Fiber orientations, $b_i: 0.00^\circ$
 Number of layers, $N_L = 1$
 Radius of rounding corners, $R = 40.00$

Stepwise Properties

EDGE -A-
 Bending Moment, $M_a = -3.8068487E-012$
 Shear Force, $V_a = -2.0402016E-014$
 EDGE -B-
 Bending Moment, $M_b = -6.0084169E-011$
 Shear Force, $V_b = 2.0402016E-014$
 BOTH EDGES
 Axial Force, $F = -33005.924$
 Longitudinal Reinforcement Area Distribution (in 2 divisions)
 -Tension: $A_{slt} = 0.00$
 -Compression: $A_{slc} = 7269.645$
 Longitudinal Reinforcement Area Distribution (in 3 divisions)
 -Tension: $A_{sl,ten} = 2830.575$
 -Compression: $A_{sl,com} = 2830.575$
 -Middle: $A_{sl,mid} = 1608.495$
 Mean Diameter of Tension Reinforcement, $Db_{L,ten} = 16.46154$

New component: From table 7-7, ASCE 41_17: Final Shear Capacity $V_R = 1.0 \cdot V_n = 1.0254E+006$
 From (22.5.1.1) and 11.5.4.3, ACI 318-14: $V_n < 0.83 \cdot f_c'^{0.5} \cdot h \cdot d = 1.0254E+006$

NOTE: In expression (22.5.1.1) ' V_w ' is replaced by ' $V_w + f \cdot V_f$ '
 where V_f is the contribution of FRPs (11.3), ACI 440).

From Table (11.5.4.6(d-e)), ACI 318-14: $V_c = 816601.185$
 $M_u/V_u - l_w/2 = 61.59179 > 0$
 = 1 (normal-weight concrete)
 $f_c' = 25.00$, but $f_c'^{0.5} \leq 8.3$ MPa (22.5.3.1, ACI 318-14)
 $h = 3000.00$
 $d = 200.00$
 $l_w = 250.00$
 $M_u = 3.8068487E-012$
 $V_u = 2.0402016E-014$
 $N_u = 33005.924$
 From (11.5.4.8), ACI 318-14: $V_s = V_{s1} + V_{s2} + V_{s3} = 104719.755$
 $V_{s1} = 52359.878$ is calculated for pseudo-Column 1, with:
 $d = 200.00$

$A_v = 157079.633$

$s = 150.00$

$f_y = 500.00$

Vs1 has been multiplied by $2(1-s/d)$ ($s > d/2$, according to ASCE 41-17,10.3.4)

$2(1-s/d) = 0.50$

Vs2 = 52359.878 is calculated for pseudo-Column 2, with:

$d = 200.00$

$A_v = 157079.633$

$s = 150.00$

$f_y = 500.00$

Vs2 has been multiplied by $2(1-s/d)$ ($s > d/2$, according to ASCE 41-17,10.3.4)

$2(1-s/d) = 0.50$

Vs3 = 0.00 is calculated for web, with:

$d = 200.00$

$A_v = 0.00$

$s = 200.00$

$f_y = 500.00$

Vs3 has been multiplied by $2(1-s/d)$ ($s > d/2$, according to ASCE 41-17,10.3.4)

$2(1-s/d) = 0.00$

$V_f ((11-3)-(11.4), \text{ACI 440}) = 109599.773$

$f = 0.95$, for fully-wrapped sections

$w_f/s_f = 1$ (FRP strips adjacent to one another).

In (11.3) $\sin + \cos$ is replaced with $(\cot + \cot a) \sin a$ which is more a generalised expression, where a is the angle of the crack direction (see KANEPE).

This later relation, considered as a function $V_f(,)$, is implemented for every different fiber orientation a_i , as well as for 2 crack directions, $a = 45^\circ$ and $a = -45^\circ$ to take into consideration the cyclic seismic loading.

orientation 1: $a_1 = b_1 + 90^\circ = 90.00$

$V_f = \text{Min}(|V_f(45, 1)|, |V_f(-45, a_1)|)$, with:

total thickness per orientation, $t_{f1} = N_L * t / N_{oDir} = 1.016$

$d_{fv} = d$ (figure 11.2, ACI 440) = 208.00

$f_{fe} ((11-5), \text{ACI 440}) = 259.312$

$E_f = 64828.00$

$f_e = 0.004$, from (11.6a), ACI 440

with $f_u = 0.01$

From (11-11), ACI 440: $V_s + V_f \leq 1.9929E+006$

$b_w = 3000.00$

End Of Calculation of Shear Capacity for element: wall W1 of floor 1

At local axis: 2

Integration Section: (a)

Calculation No. 2

wall W1, Floor 1

Limit State: Operational Level (data interpolation between analysis steps 1 and 2)

Analysis: Uniform +X

Check: Chord rotation capacity (ϕ_u)

Edge: Start

Local Axis: (2)



Start Of Calculation of Shear Capacity ratio for element: wall W1 of floor 1

At Shear local axis: 3

(Bending local axis: 2)

Section Type: rcwrs

Constant Properties

Knowledge Factor, $\gamma = 1.00$

Mean strength values are used for both shear and moment calculations.

Consequently:

New material of Secondary Member: Concrete Strength, $f_c = f_{cm} = 25.00$

New material of Secondary Member: Steel Strength, $f_s = f_{sm} = 500.00$

Concrete Elasticity, $E_c = 26999.444$

Steel Elasticity, $E_s = 200000.00$

#####

Note: Especially for the calculation of moment strengths,

the above steel re-bar strengths are multiplied by 1.25 according to R18.6.5, ACI 318-14

New material: Steel Strength, $f_s = 1.25 \cdot f_{sm} = 625.00$

#####

Total Height, $H_{tot} = 3000.00$

Edges Width, $W_{edg} = 250.00$

Edges Height, $H_{edg} = 600.00$

Web Width, $W_{web} = 250.00$

Cover Thickness, $c = 25.00$

Mean Confinement Factor overall section = 1.00246

Element Length, $L = 3000.00$

Secondary Member

Smooth Bars

Ductile Steel

Without Detailing for Earthquake Resistance (including stirrups not closed at 135°)

Longitudinal Bars With Ends Lapped Starting at the End Sections

Inadequate Lap Length with $l_o/l_{ou,min} = 0.30$

FRP Wrapping Data

Type: Carbon

Cured laminate properties (design values)

Thickness, $t = 1.016$

Tensile Strength, $f_{fu} = 1055.00$

Tensile Modulus, $E_f = 64828.00$

Elongation, $\epsilon_{fu} = 0.01$

Number of directions, $NoDir = 1$

Fiber orientations, $b_i: 0.00^\circ$

Number of layers, $NL = 1$

Radius of rounding corners, $R = 40.00$

Stepwise Properties

At local axis: 3

EDGE -A-

Shear Force, $V_a = 1.0097420E-028$

EDGE -B-

Shear Force, $V_b = -1.0097420E-028$

BOTH EDGES

Axial Force, $F = -27588.841$

Longitudinal Reinforcement Area Distribution (in 2 divisions)

-Tension: $As_t = 0.00$

-Compression: $As_c = 7269.645$

Longitudinal Reinforcement Area Distribution (in 3 divisions)

-Tension: $As_{t,ten} = 2865.133$

-Compression: $As_{c,com} = 2865.133$

-Middle: $As_{mid} = 0.00$

(According to 10.7.2.3 As_{mid} is setted equal to zero)

Calculation of Shear Capacity ratio, $V_e/V_r = 1.02813$

Member Controlled by Shear ($V_e/V_r > 1$)

Calculation of Shear Demand from fig. R18.6.5, ACI 318-14 $V_e = (M_{pr1} + M_{pr2})/l_n = 2.5600E+006$ with

$M_{pr1} = \text{Max}(\mu_{u1+}, \mu_{u1-}) = 3.8401E+009$

$\mu_{u1+} = 3.3585E+009$, is the ultimate moment strength at the edge 1 of the member in the actual moment direction which is defined for the static loading combination

$\mu_{u1-} = 3.8401E+009$, is the ultimate moment strength at the edge 1 of the member in the opposite moment direction which is defined for the static loading combination

$M_{pr2} = \text{Max}(\mu_{u2+}, \mu_{u2-}) = 3.8401E+009$

$\mu_{u2+} = 3.3585E+009$, is the ultimate moment strength at the edge 2 of the member in the actual moment direction which is defined for the static loading combination

$\mu_{u2-} = 3.8401E+009$, is the ultimate moment strength at the edge 2 of the member in the opposite moment direction which is defined for the static loading combination

Calculation of μ_{u1+}

Calculation of ultimate curvature μ_u according to 4.1, Biskinis/Fardis 2013:

$\mu_u = 2.0296703E-006$

$M_u = 3.3585E+009$

with full section properties:

$b = 250.00$

$d = 2957.00$

$d' = 43.00$

$v = 0.0014928$

$N = 27588.841$

$f_c = 25.00$

$\alpha_{co} (5A.5, \text{TBDY}) = 0.002$

Final value of μ_{cu} : $\mu_{cu}^* = \text{shear_factor} * \text{Max}(\mu_{cu}, \mu_{cc}) = 0.0035$

The Shear_factor is considered equal to 1 (pure moment strength)

From (5.4b), TBDY: $\mu_{cu} = 0.0035$

$\mu_{we} ((5.4c), \text{TBDY}) = \alpha_{se} * \mu_{sh,min} * f_{ywe}/f_{ce} + \text{Min}(\mu_{fx}, \mu_{fy}) = 0.00$

where $\mu_f = \alpha_f * \mu_{pf} * f_{fe}/f_{ce}$ is accounting for FRP contribution like EC8-part3 A.4.4.3(6)

$\mu_{fx} = 0.00$

$\mu_{af} = 0.00$

$b = 250.00$

$h = 3000.00$

From EC8 A.4.4.3(6), $\mu_{pf} = 2t_f/b_w = 0.008128$

$b_w = 250.00$

effective stress from (A.35), $f_{fe} = 757.2164$

$\mu_{fy} = 0.00$

$\mu_{af} = 0.00$

$b = 3000.00$

$h = 250.00$

From EC8 A.4.4.3(6), $\mu_{pf} = 2t_f/b_w = 0.00067733$

$b_w = 3000.00$

effective stress from (A.35), $f_{fe} = 954.4864$

$R = 40.00$
 Effective FRP thickness, $t_f = NL \cdot t \cdot \cos(b_1) = 1.016$
 $f_{u,f} = 1055.00$
 $E_f = 64828.00$
 $u_f = 0.015$
 $ase((5.4d), TBDY) = (ase_1 \cdot A_{col1} + ase_2 \cdot A_{col2} + ase_3 \cdot A_{web}) / A_{sec} = 0.00$
 $ase_1 = 0.00$
 $sh_1 = 150.00$
 $bo_1 = 190.00$
 $ho_1 = 540.00$
 $bi2_1 = 655400.00$
 $ase_2 = 0.00$
 $sh_2 = 150.00$
 $bo_2 = 190.00$
 $ho_2 = 540.00$
 $bi2_2 = 655400.00$
 $ase_3 = 0$ (grid does not provide confinement)
 $psh,min = \min(psh,x, psh,y) = 0.00069813$

Expression ((5.4d), TBDY) for psh,min has been multiplied by 0.3 according to 15.7.1.3 for members without earthquake detailing (90° closed stirrups)

$psh,x = ps1,x + ps2,x + ps3,x = 0.00356047$
 $ps1,x$ (column 1) = $(As1 \cdot h1 / s_1) / A_c = 0.00083776$
 $h1 = 600.00$
 $As1 = Astir1 \cdot ns1 = 157.0796$
 No stirrups, $ns1 = 2.00$
 $ps2,x$ (column 2) = $(As2 \cdot h2 / s_2) / A_c = 0.00083776$
 $h2 = 600.00$
 $As2 = Astir2 \cdot ns2 = 157.0796$
 No stirrups, $ns2 = 2.00$
 $ps3,x$ (web) = $(As3 \cdot h3 / s_3) / A_c = 0.00188496$
 $h3 = 1800.00$
 $As3 = Astir3 \cdot ns3 = 0.00$
 No stirrups, $ns3 = 2.00$

$psh,y = ps1,y + ps2,y + ps3,y = 0.00069813$
 $ps1,y$ (column 1) = $(As1 \cdot h1 / s_1) / A_c = 0.00034907$
 $h1 = 250.00$
 $As1 = Astir1 \cdot ns1 = 157.0796$
 No stirrups, $ns1 = 2.00$
 $ps2,y$ (column 2) = $(As2 \cdot h2 / s_2) / A_c = 0.00034907$
 $h2 = 250.00$
 $As2 = Astir2 \cdot ns2 = 157.0796$
 No stirrups, $ns2 = 2.00$
 $ps3,y$ (web) = $(As3 \cdot h3 / s_3) / A_c = 0.00$
 $h3 = 250.00$
 $As3 = Astir3 \cdot ns3 = 157.0796$
 No stirrups, $ns3 = 0.00$

$A_{sec} = 750000.00$
 $s_1 = 150.00$
 $s_2 = 150.00$
 $s_3 = 200.00$

$f_{ywe} = 625.00$
 $f_{ce} = 25.00$

From ((5.A5), TBDY), TBDY: $cc = 0.00202463$
 c = confinement factor = 1.00246

$y1 = 0.00140044$
 $sh1 = 0.0044814$
 $ft1 = 420.1317$
 $fy1 = 350.1097$
 $su1 = 0.00512$

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
 and also multiplied by the shear_factor according to 15.7.1.4, with
 $Shear_factor = 1.00$
 $lo/lo,min = lb/ld = 0.30$

```

su1 = 0.4*esu1_nominal ((5.5), TBDY) = 0.032
From table 5A.1, TBDY: esu1_nominal = 0.08,
For calculation of esu1_nominal and y1, sh1,ft1,fy1, it is considered
characteristic value fsy1 = fs1/1.2, from table 5.1, TBDY.
y1, sh1,ft1,fy1, are also multiplied by Min(1,1.25*(lb/ld)^ 2/3), from 10.3.5, ASCE 41-17.
with fs1 = fs = 350.1097
with Es1 = Es = 200000.00
y2 = 0.00140044
sh2 = 0.0044814
ft2 = 420.1317
fy2 = 350.1097
su2 = 0.00512
using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00
lo/lou,min = lb/lb,min = 0.30
su2 = 0.4*esu2_nominal ((5.5), TBDY) = 0.032
From table 5A.1, TBDY: esu2_nominal = 0.08,
For calculation of esu2_nominal and y2, sh2,ft2,fy2, it is considered
characteristic value fsy2 = fs2/1.2, from table 5.1, TBDY.
y1, sh1,ft1,fy1, are also multiplied by Min(1,1.25*(lb/ld)^ 2/3), from 10.3.5, ASCE 41-17.
with fs2 = fs = 350.1097
with Es2 = Es = 200000.00
yv = 0.00140044
shv = 0.0044814
ftv = 420.1317
fyv = 350.1097
suv = 0.00512
using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00
lo/lou,min = lb/ld = 0.30
suv = 0.4*esuv_nominal ((5.5), TBDY) = 0.032
From table 5A.1, TBDY: esuv_nominal = 0.08,
considering characteristic value fsyv = fsv/1.2, from table 5.1, TBDY
For calculation of esuv_nominal and yv, shv,ftv,fyv, it is considered
characteristic value fsyv = fsv/1.2, from table 5.1, TBDY.
y1, sh1,ft1,fy1, are also multiplied by Min(1,1.25*(lb/ld)^ 2/3), from 10.3.5, ASCE 41-17.
with fsv = fs = 350.1097
with Esv = Es = 200000.00
1 = Asl,ten/(b*d)*(fs1/fc) = 0.05427722
2 = Asl,com/(b*d)*(fs2/fc) = 0.05427722
v = Asl,mid/(b*d)*(fsv/fc) = 0.00

```

and confined core properties:

```

b = 190.00
d = 2927.00
d' = 13.00
fcc (5A.2, TBDY) = 25.06158
cc (5A.5, TBDY) = 0.00202463
c = confinement factor = 1.00246
1 = Asl,ten/(b*d)*(fs1/fc) = 0.07214938
2 = Asl,com/(b*d)*(fs2/fc) = 0.07214938
v = Asl,mid/(b*d)*(fsv/fc) = 0.00

```

Case/Assumption: Unconfined full section - Steel rupture
 ' satisfies Eq. (4.3)

```

--->
v < vs,y2 - LHS eq.(4.5) is satisfied
--->
su (4.9) = 0.14691336
Mu = MRc (4.14) = 3.3585E+009
u = su (4.1) = 2.0296703E-006

```

Calculation of ratio lb/ld

Inadequate Lap Length with lb/ld = 0.30

Calculation of Mu1-

Calculation of ultimate curvature ϕ_u according to 4.1, Biskinis/Fardis 2013:

$$\phi_u = 2.0532423E-006$$

$$M_u = 3.8401E+009$$

with full section properties:

$$b = 250.00$$

$$d = 2957.00$$

$$d' = 43.00$$

$$\nu = 0.0014928$$

$$N = 27588.841$$

$$f_c = 25.00$$

$$\phi_{co} (5A.5, TBDY) = 0.002$$

$$\text{Final value of } \phi_{cu}: \phi_{cu}^* = \text{shear_factor} * \text{Max}(\phi_{cu}, \phi_{co}) = 0.0035$$

The Shear_factor is considered equal to 1 (pure moment strength)

$$\text{From (5.4b), TBDY: } \phi_{cu} = 0.0035$$

$$\phi_{we} ((5.4c), TBDY) = a_{se} * \phi_{sh,min} * f_{ywe} / f_{ce} + \text{Min}(\phi_{fx}, \phi_{fy}) = 0.00$$

where $\phi_f = a_f * \phi_{pf} * f_{fe} / f_{ce}$ is accounting for FRP contribution like EC8-part3 A.4.4.3(6)

$$\phi_{fx} = 0.00$$

$$a_f = 0.00$$

$$b = 250.00$$

$$h = 3000.00$$

$$\text{From EC8 A.4.4.3(6), } \phi_{pf} = 2t_f/b_w = 0.008128$$

$$b_w = 250.00$$

$$\text{effective stress from (A.35), } f_{fe} = 757.2164$$

$$\phi_{fy} = 0.00$$

$$a_f = 0.00$$

$$b = 3000.00$$

$$h = 250.00$$

$$\text{From EC8 A.4.4.3(6), } \phi_{pf} = 2t_f/b_w = 0.00067733$$

$$b_w = 3000.00$$

$$\text{effective stress from (A.35), } f_{fe} = 954.4864$$

$$R = 40.00$$

$$\text{Effective FRP thickness, } t_f = N L * t * \cos(b_1) = 1.016$$

$$f_{u,f} = 1055.00$$

$$E_f = 64828.00$$

$$u_{,f} = 0.015$$

$$a_{se} ((5.4d), TBDY) = (a_{se1} * A_{col1} + a_{se2} * A_{col2} + a_{se3} * A_{web}) / A_{sec} = 0.00$$

$$a_{se1} = 0.00$$

$$sh_1 = 150.00$$

$$bo_1 = 190.00$$

$$ho_1 = 540.00$$

$$bi2_1 = 655400.00$$

$$a_{se2} = 0.00$$

$$sh_2 = 150.00$$

$$bo_2 = 190.00$$

$$ho_2 = 540.00$$

$$bi2_2 = 655400.00$$

$$a_{se3} = 0 \text{ (grid does not provide confinement)}$$

$$\phi_{sh,min} = \text{Min}(\phi_{sh,x}, \phi_{sh,y}) = 0.00069813$$

Expression ((5.4d), TBDY) for $\phi_{sh,min}$ has been multiplied by 0.3 according to 15.7.1.3 for members without earthquake detailing (90° closed stirrups)

$$\phi_{sh,x} = \phi_{s1,x} + \phi_{s2,x} + \phi_{s3,x} = 0.00356047$$

$$\phi_{s1,x} \text{ (column 1)} = (A_{s1} * h_1 / s_1) / A_c = 0.00083776$$

$$h_1 = 600.00$$

$$A_{s1} = A_{stir1} * n_{s1} = 157.0796$$

$$\text{No stirrups, } n_{s1} = 2.00$$

$$\phi_{s2,x} \text{ (column 2)} = (A_{s2} * h_2 / s_2) / A_c = 0.00083776$$

$h_2 = 600.00$
 $As_2 = Astir_2 * ns_2 = 157.0796$
 No stirups, $ns_2 = 2.00$
 $ps_{3,x} (web) = (As_3 * h_3 / s_3) / Ac = 0.00188496$
 $h_3 = 1800.00$
 $As_3 = Astir_3 * ns_3 = 0.00$
 No stirups, $ns_3 = 2.00$

$psh,y = ps_1,y + ps_2,y + ps_3,y = 0.00069813$
 $ps_{1,y} (column\ 1) = (As_1 * h_1 / s_1) / Ac = 0.00034907$
 $h_1 = 250.00$
 $As_1 = Astir_1 * ns_1 = 157.0796$
 No stirups, $ns_1 = 2.00$
 $ps_{2,y} (column\ 2) = (As_2 * h_2 / s_2) / Ac = 0.00034907$
 $h_2 = 250.00$
 $As_2 = Astir_2 * ns_2 = 157.0796$
 No stirups, $ns_2 = 2.00$
 $ps_{3,y} (web) = (As_3 * h_3 / s_3) / Ac = 0.00$
 $h_3 = 250.00$
 $As_3 = Astir_3 * ns_3 = 157.0796$
 No stirups, $ns_3 = 0.00$

$A_{sec} = 750000.00$
 $s_1 = 150.00$
 $s_2 = 150.00$
 $s_3 = 200.00$
 $fy_{we} = 625.00$
 $f_{ce} = 25.00$
 From ((5.A.5), TBDY), TBDY: $cc = 0.00202463$
 $c = \text{confinement factor} = 1.00246$
 $y_1 = 0.00140044$
 $sh_1 = 0.0044814$
 $ft_1 = 420.1317$
 $fy_1 = 350.1097$
 $su_1 = 0.00512$
 using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
 and also multiplied by the shear_factor according to 15.7.1.4, with
 $Shear_factor = 1.00$
 $lo/lou,min = lb/l_d = 0.30$
 $su_1 = 0.4 * esu_{1,nominal} ((5.5), TBDY) = 0.032$
 From table 5A.1, TBDY: $esu_{1,nominal} = 0.08$,
 For calculation of $esu_{1,nominal}$ and y_1, sh_1, ft_1, fy_1 , it is considered
 characteristic value $fsy_1 = fs_1 / 1.2$, from table 5.1, TBDY.
 y_1, sh_1, ft_1, fy_1 , are also multiplied by $Min(1, 1.25 * (lb/l_d)^{2/3})$, from 10.3.5, ASCE 41-17.
 with $fs_1 = fs = 350.1097$
 with $Es_1 = Es = 200000.00$
 $y_2 = 0.00140044$
 $sh_2 = 0.0044814$
 $ft_2 = 420.1317$
 $fy_2 = 350.1097$
 $su_2 = 0.00512$
 using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
 and also multiplied by the shear_factor according to 15.7.1.4, with
 $Shear_factor = 1.00$
 $lo/lou,min = lb/l_b,min = 0.30$
 $su_2 = 0.4 * esu_{2,nominal} ((5.5), TBDY) = 0.032$
 From table 5A.1, TBDY: $esu_{2,nominal} = 0.08$,
 For calculation of $esu_{2,nominal}$ and y_2, sh_2, ft_2, fy_2 , it is considered
 characteristic value $fsy_2 = fs_2 / 1.2$, from table 5.1, TBDY.
 y_1, sh_1, ft_1, fy_1 , are also multiplied by $Min(1, 1.25 * (lb/l_d)^{2/3})$, from 10.3.5, ASCE 41-17.
 with $fs_2 = fs = 350.1097$
 with $Es_2 = Es = 200000.00$
 $y_v = 0.00140044$
 $sh_v = 0.0044814$
 $ft_v = 420.1317$
 $fy_v = 350.1097$
 $suv = 0.00512$

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
 and also multiplied by the shear_factor according to 15.7.1.4, with
 Shear_factor = 1.00
 $l_o/l_{ou,min} = l_b/l_d = 0.30$
 $suv = 0.4 * esuv_{nominal} ((5.5), TBDY) = 0.032$
 From table 5A.1, TBDY: $esuv_{nominal} = 0.08$,
 considering characteristic value $fsyv = fsv/1.2$, from table 5.1, TBDY
 For calculation of $esuv_{nominal}$ and y_v , sh_v, ft_v, fy_v , it is considered
 characteristic value $fsyv = fsv/1.2$, from table 5.1, TBDY.
 y_1, sh_1, ft_1, fy_1 , are also multiplied by $Min(1, 1.25 * (l_b/l_d)^{2/3})$, from 10.3.5, ASCE 41-17.
 with $fsv = fs = 350.1097$
 with $Esv = Es = 200000.00$
 $1 = Asl_{ten}/(b*d) * (fs_1/fc) = 0.05427722$
 $2 = Asl_{com}/(b*d) * (fs_2/fc) = 0.05427722$
 $v = Asl_{mid}/(b*d) * (fsv/fc) = 0.0291621$

and confined core properties:

$b = 190.00$
 $d = 2927.00$
 $d' = 13.00$
 $fcc (5A.2, TBDY) = 25.06158$
 $cc (5A.5, TBDY) = 0.00202463$
 $c = \text{confinement factor} = 1.00246$
 $1 = Asl_{ten}/(b*d) * (fs_1/fc) = 0.07214938$
 $2 = Asl_{com}/(b*d) * (fs_2/fc) = 0.07214938$
 $v = Asl_{mid}/(b*d) * (fsv/fc) = 0.03876447$

Case/Assumption: Unconfined full section - Steel rupture
 ' satisfies Eq. (4.3)

--->
 $v < v_{s,y2}$ - LHS eq.(4.5) is satisfied
 --->
 $su (4.9) = 0.15670711$
 $Mu = MRc (4.14) = 3.8401E+009$
 $u = su (4.1) = 2.0532423E-006$

Calculation of ratio l_b/l_d

Inadequate Lap Length with $l_b/l_d = 0.30$

Calculation of Mu_{2+}

Calculation of ultimate curvature u according to 4.1, Biskinis/Fardis 2013:

$u = 2.0296703E-006$
 $Mu = 3.3585E+009$

with full section properties:

$b = 250.00$
 $d = 2957.00$
 $d' = 43.00$
 $v = 0.0014928$
 $N = 27588.841$
 $fc = 25.00$
 $co (5A.5, TBDY) = 0.002$
 Final value of cu : $cu * = \text{shear_factor} * \text{Max}(cu, cc) = 0.0035$
 The Shear_factor is considered equal to 1 (pure moment strength)
 From (5.4b), TBDY: $cu = 0.0035$
 $we ((5.4c), TBDY) = ase * sh_{min} * fy_{we}/f_{ce} + \text{Min}(fx, fy) = 0.00$
 where $f = af * pf * f_{fe}/f_{ce}$ is accounting for FRP contribution like EC8-part3 A.4.4.3(6)

 $fx = 0.00$
 $af = 0.00$
 $b = 250.00$
 $h = 3000.00$

From EC8 A4.4.3(6), $pf = 2tf/bw = 0.008128$
 $bw = 250.00$
effective stress from (A.35), $ff,e = 757.2164$

$f_y = 0.00$
 $a_f = 0.00$
 $b = 3000.00$
 $h = 250.00$
From EC8 A4.4.3(6), $pf = 2tf/bw = 0.00067733$
 $bw = 3000.00$
effective stress from (A.35), $ff,e = 954.4864$

$R = 40.00$
Effective FRP thickness, $tf = NL*t*Cos(b1) = 1.016$
 $f_{u,f} = 1055.00$
 $E_f = 64828.00$
 $u_f = 0.015$
 $ase((5.4d), TBDY) = (ase1*Acol1 + ase2*Acol2 + ase3*Aweb)/Asec = 0.00$
 $ase1 = 0.00$
 $sh_1 = 150.00$
 $bo_1 = 190.00$
 $ho_1 = 540.00$
 $bi2_1 = 655400.00$
 $ase2 = 0.00$
 $sh_2 = 150.00$
 $bo_2 = 190.00$
 $ho_2 = 540.00$
 $bi2_2 = 655400.00$

$ase3 = 0$ (grid does not provide confinement)
 $psh,min = Min(psh,x, psh,y) = 0.00069813$

Expression ((5.4d), TBDY) for psh,min has been multiplied by 0.3 according to 15.7.1.3 for members without earthquake detailing (90° closed stirrups)

$psh,x = ps1,x + ps2,x + ps3,x = 0.00356047$
 $ps1,x$ (column 1) = $(As1*h1/s_1)/Ac = 0.00083776$
 $h1 = 600.00$
 $As1 = Astir1*ns1 = 157.0796$
No stirrups, $ns1 = 2.00$
 $ps2,x$ (column 2) = $(As2*h2/s_2)/Ac = 0.00083776$
 $h2 = 600.00$
 $As2 = Astir2*ns2 = 157.0796$
No stirrups, $ns2 = 2.00$
 $ps3,x$ (web) = $(As3*h3/s_3)/Ac = 0.00188496$
 $h3 = 1800.00$
 $As3 = Astir3*ns3 = 0.00$
No stirrups, $ns3 = 2.00$

$psh,y = ps1,y + ps2,y + ps3,y = 0.00069813$
 $ps1,y$ (column 1) = $(As1*h1/s_1)/Ac = 0.00034907$
 $h1 = 250.00$
 $As1 = Astir1*ns1 = 157.0796$
No stirrups, $ns1 = 2.00$
 $ps2,y$ (column 2) = $(As2*h2/s_2)/Ac = 0.00034907$
 $h2 = 250.00$
 $As2 = Astir2*ns2 = 157.0796$
No stirrups, $ns2 = 2.00$
 $ps3,y$ (web) = $(As3*h3/s_3)/Ac = 0.00$
 $h3 = 250.00$
 $As3 = Astir3*ns3 = 157.0796$
No stirrups, $ns3 = 0.00$

$Asec = 750000.00$
 $s_1 = 150.00$
 $s_2 = 150.00$
 $s_3 = 200.00$
 $f_{ywe} = 625.00$
 $f_{ce} = 25.00$

From ((5.A.5), TBDY), TBDY: $cc = 0.00202463$
 $c = \text{confinement factor} = 1.00246$
 $y1 = 0.00140044$
 $sh1 = 0.0044814$
 $ft1 = 420.1317$
 $fy1 = 350.1097$
 $su1 = 0.00512$
 using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
 and also multiplied by the shear_factor according to 15.7.1.4, with
 Shear_factor = 1.00
 $lo/lou, \min = lb/ld = 0.30$
 $su1 = 0.4 * esu1_nominal ((5.5), TBDY) = 0.032$
 From table 5A.1, TBDY: $esu1_nominal = 0.08$,
 For calculation of $esu1_nominal$ and $y1, sh1, ft1, fy1$, it is considered
 characteristic value $fsy1 = fs1/1.2$, from table 5.1, TBDY.
 $y1, sh1, ft1, fy1$, are also multiplied by $\text{Min}(1, 1.25 * (lb/ld)^{2/3})$, from 10.3.5, ASCE 41-17.
 with $fs1 = fs = 350.1097$
 with $Es1 = Es = 200000.00$
 $y2 = 0.00140044$
 $sh2 = 0.0044814$
 $ft2 = 420.1317$
 $fy2 = 350.1097$
 $su2 = 0.00512$
 using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
 and also multiplied by the shear_factor according to 15.7.1.4, with
 Shear_factor = 1.00
 $lo/lou, \min = lb/lb, \min = 0.30$
 $su2 = 0.4 * esu2_nominal ((5.5), TBDY) = 0.032$
 From table 5A.1, TBDY: $esu2_nominal = 0.08$,
 For calculation of $esu2_nominal$ and $y2, sh2, ft2, fy2$, it is considered
 characteristic value $fsy2 = fs2/1.2$, from table 5.1, TBDY.
 $y1, sh1, ft1, fy1$, are also multiplied by $\text{Min}(1, 1.25 * (lb/ld)^{2/3})$, from 10.3.5, ASCE 41-17.
 with $fs2 = fs = 350.1097$
 with $Es2 = Es = 200000.00$
 $yv = 0.00140044$
 $shv = 0.0044814$
 $ftv = 420.1317$
 $fyv = 350.1097$
 $suv = 0.00512$
 using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
 and also multiplied by the shear_factor according to 15.7.1.4, with
 Shear_factor = 1.00
 $lo/lou, \min = lb/ld = 0.30$
 $suv = 0.4 * esuv_nominal ((5.5), TBDY) = 0.032$
 From table 5A.1, TBDY: $esuv_nominal = 0.08$,
 considering characteristic value $fsyv = fsv/1.2$, from table 5.1, TBDY
 For calculation of $esuv_nominal$ and yv, shv, ftv, fyv , it is considered
 characteristic value $fsyv = fsv/1.2$, from table 5.1, TBDY.
 $y1, sh1, ft1, fy1$, are also multiplied by $\text{Min}(1, 1.25 * (lb/ld)^{2/3})$, from 10.3.5, ASCE 41-17.
 with $fsv = fs = 350.1097$
 with $Esv = Es = 200000.00$
 $1 = Asl, \text{ten} / (b * d) * (fs1 / fc) = 0.05427722$
 $2 = Asl, \text{com} / (b * d) * (fs2 / fc) = 0.05427722$
 $v = Asl, \text{mid} / (b * d) * (fsv / fc) = 0.00$
 and confined core properties:
 $b = 190.00$
 $d = 2927.00$
 $d' = 13.00$
 $fcc (5A.2, TBDY) = 25.06158$
 $cc (5A.5, TBDY) = 0.00202463$
 $c = \text{confinement factor} = 1.00246$
 $1 = Asl, \text{ten} / (b * d) * (fs1 / fc) = 0.07214938$
 $2 = Asl, \text{com} / (b * d) * (fs2 / fc) = 0.07214938$
 $v = Asl, \text{mid} / (b * d) * (fsv / fc) = 0.00$
 Case/Assumption: Unconfined full section - Steel rupture
 ' satisfies Eq. (4.3)

--->

$v < v_{s,y2}$ - LHS eq.(4.5) is satisfied

---->

$$s_u(4.9) = 0.14691336$$

$$M_u = M_{Rc}(4.14) = 3.3585E+009$$

$$u = s_u(4.1) = 2.0296703E-006$$

Calculation of ratio I_b/I_d

Inadequate Lap Length with $I_b/I_d = 0.30$

Calculation of M_{u2} -

Calculation of ultimate curvature u according to 4.1, Biskinis/Fardis 2013:

$$u = 2.0532423E-006$$

$$M_u = 3.8401E+009$$

with full section properties:

$$b = 250.00$$

$$d = 2957.00$$

$$d' = 43.00$$

$$v = 0.0014928$$

$$N = 27588.841$$

$$f_c = 25.00$$

$$\alpha(5A.5, TBDY) = 0.002$$

$$\text{Final value of } \alpha: \alpha^* = \text{shear_factor} * \text{Max}(\alpha, \alpha_c) = 0.0035$$

The Shear_factor is considered equal to 1 (pure moment strength)

$$\text{From (5.4b), TBDY: } \alpha = 0.0035$$

$$\alpha_{we}((5.4c), TBDY) = \alpha_{se} * \text{sh}_{\min} * f_{ywe}/f_{ce} + \text{Min}(\alpha_x, \alpha_y) = 0.00$$

where $\alpha = \alpha_f * p_f * f_{fe}/f_{ce}$ is accounting for FRP contribution like EC8-part3 A.4.4.3(6)

$$\alpha_x = 0.00$$

$$\alpha_f = 0.00$$

$$b = 250.00$$

$$h = 3000.00$$

$$\text{From EC8 A4.4.3(6), } p_f = 2t_f/bw = 0.008128$$

$$bw = 250.00$$

$$\text{effective stress from (A.35), } f_{fe} = 757.2164$$

$$\alpha_y = 0.00$$

$$\alpha_f = 0.00$$

$$b = 3000.00$$

$$h = 250.00$$

$$\text{From EC8 A4.4.3(6), } p_f = 2t_f/bw = 0.00067733$$

$$bw = 3000.00$$

$$\text{effective stress from (A.35), } f_{fe} = 954.4864$$

$$R = 40.00$$

$$\text{Effective FRP thickness, } t_f = NL * t * \cos(b_1) = 1.016$$

$$f_{u,f} = 1055.00$$

$$E_f = 64828.00$$

$$u_{,f} = 0.015$$

$$\alpha_{se}((5.4d), TBDY) = (\alpha_{se1} * A_{col1} + \alpha_{se2} * A_{col2} + \alpha_{se3} * A_{web}) / A_{sec} = 0.00$$

$$\alpha_{se1} = 0.00$$

$$sh_1 = 150.00$$

$$bo_1 = 190.00$$

$$ho_1 = 540.00$$

$$bi2_1 = 655400.00$$

$$\alpha_{se2} = 0.00$$

$$sh_2 = 150.00$$

$$bo_2 = 190.00$$

$$ho_2 = 540.00$$

$$bi2_2 = 655400.00$$

ase3 = 0 (grid does not provide confinement)
psh,min = Min(psh,x , psh,y) = 0.00069813
Expression ((5.4d), TBDY) for psh,min has been multiplied by 0.3 according to 15.7.1.3 for members without earthquake detailing (90° closed stirrups)

psh,x = ps1,x+ps2,x+ps3,x = 0.00356047
ps1,x (column 1) = (As1*h1/s_1)/Ac = 0.00083776
h1 = 600.00
As1 = Astir1*ns1 = 157.0796
No stirrups, ns1 = 2.00
ps2,x (column 2) = (As2*h2/s_2)/Ac = 0.00083776
h2 = 600.00
As2 = Astir2*ns2 = 157.0796
No stirrups, ns2 = 2.00
ps3,x (web) = (As3*h3/s_3)/Ac = 0.00188496
h3 = 1800.00
As3 = Astir3*ns3 = 0.00
No stirrups, ns3 = 2.00

psh,y = ps1,y+ps2,y+ps3,y = 0.00069813
ps1,y (column 1) = (As1*h1/s_1)/Ac = 0.00034907
h1 = 250.00
As1 = Astir1*ns1 = 157.0796
No stirrups, ns1 = 2.00
ps2,y (column 2) = (As2*h2/s_2)/Ac = 0.00034907
h2 = 250.00
As2 = Astir2*ns2 = 157.0796
No stirrups, ns2 = 2.00
ps3,y (web) = (As3*h3/s_3)/Ac = 0.00
h3 = 250.00
As3 = Astir3*ns3 = 157.0796
No stirrups, ns3 = 0.00

Asec = 750000.00

s_1 = 150.00

s_2 = 150.00

s_3 = 200.00

fywe = 625.00

fce = 25.00

From ((5.A5), TBDY), TBDY: cc = 0.00202463

c = confinement factor = 1.00246

y1 = 0.00140044

sh1 = 0.0044814

ft1 = 420.1317

fy1 = 350.1097

su1 = 0.00512

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with

Shear_factor = 1.00

lo/lou,min = lb/lb = 0.30

su1 = 0.4*esu1_nominal ((5.5), TBDY) = 0.032

From table 5A.1, TBDY: esu1_nominal = 0.08,

For calculation of esu1_nominal and y1, sh1,ft1,fy1, it is considered
characteristic value fsy1 = fs1/1.2, from table 5.1, TBDY.

y1, sh1,ft1,fy1, are also multiplied by Min(1,1.25*(lb/lb)^ 2/3), from 10.3.5, ASCE 41-17.

with fs1 = fs = 350.1097

with Es1 = Es = 200000.00

y2 = 0.00140044

sh2 = 0.0044814

ft2 = 420.1317

fy2 = 350.1097

su2 = 0.00512

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with

Shear_factor = 1.00

lo/lou,min = lb/lb,min = 0.30

su2 = 0.4*esu2_nominal ((5.5), TBDY) = 0.032

From table 5A.1, TBDY: $es_{u2_nominal} = 0.08$,
For calculation of $es_{u2_nominal}$ and y_2 , sh_2 , ft_2 , fy_2 , it is considered
characteristic value $fs_{y2} = fs_2/1.2$, from table 5.1, TBDY.
 y_1 , sh_1 , ft_1 , fy_1 , are also multiplied by $\text{Min}(1, 1.25 \cdot (lb/d)^{2/3})$, from 10.3.5, ASCE 41-17.
with $fs_2 = fs = 350.1097$
with $Es_2 = Es = 200000.00$
 $y_v = 0.00140044$
 $sh_v = 0.0044814$
 $ft_v = 420.1317$
 $fy_v = 350.1097$
 $s_{uv} = 0.00512$
using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00
 $lo/lou, \min = lb/d = 0.30$
 $s_{uv} = 0.4 \cdot es_{uv_nominal} ((5.5), TBDY) = 0.032$
From table 5A.1, TBDY: $es_{uv_nominal} = 0.08$,
considering characteristic value $fs_{yv} = fs_v/1.2$, from table 5.1, TBDY
For calculation of $es_{uv_nominal}$ and y_v , sh_v , ft_v , fy_v , it is considered
characteristic value $fs_{yv} = fs_v/1.2$, from table 5.1, TBDY.
 y_1 , sh_1 , ft_1 , fy_1 , are also multiplied by $\text{Min}(1, 1.25 \cdot (lb/d)^{2/3})$, from 10.3.5, ASCE 41-17.
with $fs_v = fs = 350.1097$
with $Es_v = Es = 200000.00$
 $1 = Asl, \text{ten}/(b \cdot d) \cdot (fs_1/f_c) = 0.05427722$
 $2 = Asl, \text{com}/(b \cdot d) \cdot (fs_2/f_c) = 0.05427722$
 $v = Asl, \text{mid}/(b \cdot d) \cdot (fs_v/f_c) = 0.0291621$
and confined core properties:
 $b = 190.00$
 $d = 2927.00$
 $d' = 13.00$
 $f_{cc} (5A.2, TBDY) = 25.06158$
 $cc (5A.5, TBDY) = 0.00202463$
 $c = \text{confinement factor} = 1.00246$
 $1 = Asl, \text{ten}/(b \cdot d) \cdot (fs_1/f_c) = 0.07214938$
 $2 = Asl, \text{com}/(b \cdot d) \cdot (fs_2/f_c) = 0.07214938$
 $v = Asl, \text{mid}/(b \cdot d) \cdot (fs_v/f_c) = 0.03876447$
Case/Assumption: Unconfined full section - Steel rupture
'satisfies Eq. (4.3)
--->
 $v < v_{s,y2}$ - LHS eq.(4.5) is satisfied
--->
 $su (4.9) = 0.15670711$
 $Mu = MRc (4.14) = 3.8401E+009$
 $u = su (4.1) = 2.0532423E-006$

Calculation of ratio lb/d

Inadequate Lap Length with $lb/d = 0.30$

Calculation of Shear Strength $V_r = \text{Min}(V_{r1}, V_{r2}) = 2.4900E+006$

Calculation of Shear Strength at edge 1, $V_{r1} = 2.4900E+006$
From (22.5.1.1) and 11.5.4.3, ACI 318-14: $V_{r1} = V_n < 0.83 \cdot f_c'^{0.5} \cdot h \cdot d$

NOTE: In expression (22.5.1.1) ' V_w ' is replaced by ' $V_w + f \cdot V_f$ '
where V_f is the contribution of FRPs (11.3), ACI 440).

From Table (11.5.4.6(d-e)), ACI 318-14: $V_c = 815517.768$
 $Mu/V_u - lw/2 = 0.00 \leq 0$
= 1 (normal-weight concrete)
 $f_c' = 25.00$, but $f_c'^{0.5} \leq 8.3 \text{ MPa}$ (22.5.3.1, ACI 318-14)
 $h = 250.00$
 $d = 2400.00$

$l_w = 3000.00$
 $\mu_u = 1.1486927E-009$
 $\mu_u = 1.0097420E-028$
 $\mu_u = 27588.841$
 From (11.5.4.8), ACI 318-14: $V_s = V_{s1} + V_{s2} + V_{s3} = 1.0681E+006$
 $V_{s1} = 251327.412$ is calculated for pseudo-Column 1, with:
 $d = 480.00$
 $A_v = 157079.633$
 $s = 150.00$
 $f_y = 500.00$
 V_{s1} has been multiplied by 1 ($s < d/2$, according to ASCE 41-17,10.3.4)
 $V_{s2} = 251327.412$ is calculated for pseudo-Column 2, with:
 $d = 480.00$
 $A_v = 157079.633$
 $s = 150.00$
 $f_y = 500.00$
 V_{s2} has been multiplied by 1 ($s < d/2$, according to ASCE 41-17,10.3.4)
 $V_{s3} = 565486.678$ is calculated for web, with:
 $d = 1440.00$
 $A_v = 157079.633$
 $s = 200.00$
 $f_y = 500.00$
 V_{s3} has been multiplied by 1 ($s < d/2$, according to ASCE 41-17,10.3.4)
 V_f ((11-3)-(11.4), ACI 440) = $1.5581E+006$
 $f = 0.95$, for fully-wrapped sections
 $w_f/s_f = 1$ (FRP strips adjacent to one another).
 In (11.3) $\sin + \cos$ is replaced with $(\cot + \cot a)\sin a$ which is more a generalised expression,
 where a is the angle of the crack direction (see KANEPE).
 This later relation, considered as a function $V_f(,)$, is implemented for every different fiber orientation a_i ,
 as well as for 2 crack directions, $a = 45^\circ$ and $a = -45^\circ$ to take into consideration the cyclic seismic loading.
 orientation 1: $a_1 = b_1 + 90^\circ = 90.00$
 $V_f = \text{Min}(|V_f(45, 1)|, |V_f(-45, a_1)|)$, with:
 total thickness per orientation, $t_{f1} = N_L \cdot t / N_oDir = 1.016$
 $d_{fv} = d$ (figure 11.2, ACI 440) = 2957.00
 f_{fe} ((11-5), ACI 440) = 259.312
 $E_f = 64828.00$
 $f_e = 0.004$, from (11.6a), ACI 440
 with $f_u = 0.01$
 From (11-11), ACI 440: $V_s + V_f \leq 1.9929E+006$
 $b_w = 250.00$

Calculation of Shear Strength at edge 2, $V_{r2} = 2.4900E+006$
 From (22.5.1.1) and 11.5.4.3, ACI 318-14: $V_{r2} = V_n < 0.83 \cdot f_c'^{0.5} \cdot h \cdot d$

NOTE: In expression (22.5.1.1) ' V_w ' is replaced by ' $V_w + f \cdot V_f$ '
 where V_f is the contribution of FRPs (11.3), ACI 440).

From Table (11.5.4.6(d-e)), ACI 318-14: $V_c = 815517.768$
 $\mu_u / \mu_u - l_w / 2 = 0.00 \leq 0$
 $= 1$ (normal-weight concrete)
 $f_c' = 25.00$, but $f_c'^{0.5} \leq 8.3$ MPa (22.5.3.1, ACI 318-14)
 $h = 250.00$
 $d = 2400.00$
 $l_w = 3000.00$
 $\mu_u = 1.1486927E-009$
 $\mu_u = 1.0097420E-028$
 $\mu_u = 27588.841$
 From (11.5.4.8), ACI 318-14: $V_s = V_{s1} + V_{s2} + V_{s3} = 1.0681E+006$
 $V_{s1} = 251327.412$ is calculated for pseudo-Column 1, with:
 $d = 480.00$
 $A_v = 157079.633$
 $s = 150.00$
 $f_y = 500.00$
 V_{s1} has been multiplied by 1 ($s < d/2$, according to ASCE 41-17,10.3.4)
 $V_{s2} = 251327.412$ is calculated for pseudo-Column 2, with:
 $d = 480.00$
 $A_v = 157079.633$

$s = 150.00$
 $f_y = 500.00$
 V_{s2} has been multiplied by 1 ($s < d/2$, according to ASCE 41-17,10.3.4)
 $V_{s3} = 565486.678$ is calculated for web, with:
 $d = 1440.00$
 $A_v = 157079.633$
 $s = 200.00$
 $f_y = 500.00$
 V_{s3} has been multiplied by 1 ($s < d/2$, according to ASCE 41-17,10.3.4)
 $V_f ((11-3)-(11.4), \text{ACI 440}) = 1.5581\text{E}+006$
 $f = 0.95$, for fully-wrapped sections
 $w_f/s_f = 1$ (FRP strips adjacent to one another).
 In (11.3) $\sin + \cos$ is replaced with $(\cot + \cot a)\sin a$ which is more a generalised expression,
 where a is the angle of the crack direction (see KANEPE).
 This later relation, considered as a function $V_f(,)$, is implemented for every different fiber orientation a_i ,
 as well as for 2 crack directions, $a = 45^\circ$ and $a = -45^\circ$ to take into consideration the cyclic seismic loading.
 orientation 1: $\theta_1 = b_1 + 90^\circ = 90.00$
 $V_f = \text{Min}(|V_f(45, \theta_1)|, |V_f(-45, a_1)|)$, with:
 total thickness per orientation, $t_{f1} = N_L * t / \text{NoDir} = 1.016$
 $d_{fv} = d$ (figure 11.2, ACI 440) = 2957.00
 $f_{fe} ((11-5), \text{ACI 440}) = 259.312$
 $E_f = 64828.00$
 $f_e = 0.004$, from (11.6a), ACI 440
 with $f_u = 0.01$
 From (11-11), ACI 440: $V_s + V_f \leq 1.9929\text{E}+006$
 $b_w = 250.00$

 End Of Calculation of Shear Capacity ratio for element: wall W1 of floor 1
 At local axis: 3

 Start Of Calculation of Shear Capacity ratio for element: wall W1 of floor 1
 At Shear local axis: 2
 (Bending local axis: 3)
 Section Type: rcrcws

Constant Properties

 Knowledge Factor, $K = 1.00$
 Mean strength values are used for both shear and moment calculations.
 Consequently:
 New material of Secondary Member: Concrete Strength, $f_c = f_{cm} = 25.00$
 New material of Secondary Member: Steel Strength, $f_s = f_{sm} = 500.00$
 Concrete Elasticity, $E_c = 26999.444$
 Steel Elasticity, $E_s = 200000.00$
 #####
 Note: Especially for the calculation of moment strengths,
 the above steel re-bar strengths are multiplied by 1.25 according to R18.6.5, ACI 318-14
 New material: Steel Strength, $f_s = 1.25 * f_{sm} = 625.00$
 #####
 Total Height, $H_{tot} = 3000.00$
 Edges Width, $W_{edg} = 250.00$
 Edges Height, $H_{edg} = 600.00$
 Web Width, $W_{web} = 250.00$
 Cover Thickness, $c = 25.00$
 Mean Confinement Factor overall section = 1.00246
 Element Length, $L = 3000.00$
 Secondary Member
 Smooth Bars
 Ductile Steel
 Without Detailing for Earthquake Resistance (including stirrups not closed at 135°)
 Longitudinal Bars With Ends Lapped Starting at the End Sections
 Inadequate Lap Length with $l_o/l_{ou,min} = 0.30$
 FRP Wrapping Data
 Type: Carbon

Cured laminate properties (design values)

Thickness, $t = 1.016$

Tensile Strength, $f_{fu} = 1055.00$

Tensile Modulus, $E_f = 64828.00$

Elongation, $\epsilon_{fu} = 0.01$

Number of directions, $NoDir = 1$

Fiber orientations, $b_i = 0.00^\circ$

Number of layers, $NL = 1$

Radius of rounding corners, $R = 40.00$

Stepwise Properties

At local axis: 2

EDGE -A-

Shear Force, $V_a = 1.7354940E-029$

EDGE -B-

Shear Force, $V_b = -1.7354940E-029$

BOTH EDGES

Axial Force, $F = -27588.841$

Longitudinal Reinforcement Area Distribution (in 2 divisions)

-Tension: $As_t = 0.00$

-Compression: $As_c = 7269.645$

Longitudinal Reinforcement Area Distribution (in 3 divisions)

-Tension: $As_{t,ten} = 2830.575$

-Compression: $As_{l,com} = 2830.575$

-Middle: $As_{l,mid} = 0.00$

(According to 10.7.2.3 $As_{l,mid}$ is setted equal to zero)

Calculation of Shear Capacity ratio, $V_e/V_r = 0.15621236$

Member Controlled by Flexure ($V_e/V_r < 1$)

Calculation of Shear Demand from fig. R18.6.5, ACI 318-14 $V_e = (M_{pr1} + M_{pr2})/l_n = 160017.271$

with

$M_{pr1} = \text{Max}(\mu_{u1+}, \mu_{u1-}) = 2.4003E+008$

$\mu_{u1+} = 2.0658E+008$, is the ultimate moment strength at the edge 1 of the member in the actual moment direction which is defined for the static loading combination

$\mu_{u1-} = 2.4003E+008$, is the ultimate moment strength at the edge 1 of the member in the opposite moment direction which is defined for the static loading combination

$M_{pr2} = \text{Max}(\mu_{u2+}, \mu_{u2-}) = 2.4003E+008$

$\mu_{u2+} = 2.0658E+008$, is the ultimate moment strength at the edge 2 of the member in the actual moment direction which is defined for the static loading combination

$\mu_{u2-} = 2.4003E+008$, is the ultimate moment strength at the edge 2 of the member in the opposite moment direction which is defined for the static loading combination

Calculation of μ_{u1+}

Calculation of ultimate curvature ϕ_u according to 4.1, Biskinis/Fardis 2013:

$\phi_u = 3.0306889E-005$

$\mu_u = 2.0658E+008$

with full section properties:

$b = 3000.00$

$d = 208.00$

$d' = 42.00$

$v = 0.00176852$

$N = 27588.841$

$f_c = 25.00$

ϕ_o (5A.5, TBDY) = 0.002

Final value of ϕ_u : $\phi_u^* = \text{shear_factor} * \text{Max}(\phi_u, \phi_o) = 0.0035$

The Shear_factor is considered equal to 1 (pure moment strength)

From (5.4b), TBDY: $\phi_u = 0.0035$

we ((5.4c), TBDY) = $ase \cdot sh_{min} \cdot fy_{we}/f_{ce} + \text{Min}(f_x, f_y) = 0.00$
where $f = af \cdot pf \cdot f_{fe}/f_{ce}$ is accounting for FRP contribution like EC8-part3 A.4.4.3(6)

$f_x = 0.00$
 $af = 0.00$
 $b = 250.00$
 $h = 3000.00$
From EC8 A.4.4.3(6), $pf = 2tf/bw = 0.008128$
 $bw = 250.00$
effective stress from (A.35), $ff_e = 757.2164$

$f_y = 0.00$
 $af = 0.00$
 $b = 3000.00$
 $h = 250.00$
From EC8 A.4.4.3(6), $pf = 2tf/bw = 0.00067733$
 $bw = 3000.00$
effective stress from (A.35), $ff_e = 954.4864$

$R = 40.00$
Effective FRP thickness, $tf = NL \cdot t \cdot \cos(b_1) = 1.016$
 $f_{u,f} = 1055.00$
 $E_f = 64828.00$
 $u_f = 0.015$
 $ase \text{ ((5.4d), TBDY)} = (ase_1 \cdot A_{col1} + ase_2 \cdot A_{col2} + ase_3 \cdot A_{web})/A_{sec} = 0.00$
 $ase_1 = 0.00$
 $sh_1 = 150.00$
 $bo_1 = 190.00$
 $ho_1 = 540.00$
 $bi2_1 = 655400.00$
 $ase_2 = 0.00$
 $sh_2 = 150.00$
 $bo_2 = 190.00$
 $ho_2 = 540.00$
 $bi2_2 = 655400.00$

$ase_3 = 0$ (grid does not provide confinement)
 $psh_{min} = \text{Min}(psh_x, psh_y) = 0.00069813$

Expression ((5.4d), TBDY) for psh_{min} has been multiplied by 0.3 according to 15.7.1.3 for members without earthquake detailing (90° closed stirrups)

$psh_x = ps1_x + ps2_x + ps3_x = 0.00356047$
 $ps1_x \text{ (column 1)} = (As1 \cdot h1/s_1)/Ac = 0.00083776$
 $h1 = 600.00$
 $As1 = Astir1 \cdot ns1 = 157.0796$
No stirrups, $ns1 = 2.00$
 $ps2_x \text{ (column 2)} = (As2 \cdot h2/s_2)/Ac = 0.00083776$
 $h2 = 600.00$
 $As2 = Astir2 \cdot ns2 = 157.0796$
No stirrups, $ns2 = 2.00$
 $ps3_x \text{ (web)} = (As3 \cdot h3/s_3)/Ac = 0.00188496$
 $h3 = 1800.00$
 $As3 = Astir3 \cdot ns3 = 0.00$
No stirrups, $ns3 = 2.00$

$psh_y = ps1_y + ps2_y + ps3_y = 0.00069813$
 $ps1_y \text{ (column 1)} = (As1 \cdot h1/s_1)/Ac = 0.00034907$
 $h1 = 250.00$
 $As1 = Astir1 \cdot ns1 = 157.0796$
No stirrups, $ns1 = 2.00$
 $ps2_y \text{ (column 2)} = (As2 \cdot h2/s_2)/Ac = 0.00034907$
 $h2 = 250.00$
 $As2 = Astir2 \cdot ns2 = 157.0796$
No stirrups, $ns2 = 2.00$
 $ps3_y \text{ (web)} = (As3 \cdot h3/s_3)/Ac = 0.00$
 $h3 = 250.00$
 $As3 = Astir3 \cdot ns3 = 157.0796$
No stirrups, $ns3 = 0.00$

```

Asec = 750000.00
s_1 = 150.00
s_2 = 150.00
s_3 = 200.00
fywe = 625.00
fce = 25.00
From ((5.A.5), TBDY), TBDY: cc = 0.00202463
c = confinement factor = 1.00246
y1 = 0.00140044
sh1 = 0.0044814
ft1 = 420.1317
fy1 = 350.1097
su1 = 0.00512
using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00
lo/lou,min = lb/lb,min = 0.30
su1 = 0.4*esu1_nominal ((5.5), TBDY) = 0.032
From table 5A.1, TBDY: esu1_nominal = 0.08,
For calculation of esu1_nominal and y1, sh1,ft1,fy1, it is considered
characteristic value fsy1 = fs1/1.2, from table 5.1, TBDY.
y1, sh1,ft1,fy1, are also multiplied by Min(1,1.25*(lb/lb,min)^ 2/3), from 10.3.5, ASCE 41-17.
with fs1 = fs = 350.1097
with Es1 = Es = 200000.00
y2 = 0.00140044
sh2 = 0.0044814
ft2 = 420.1317
fy2 = 350.1097
su2 = 0.00512
using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00
lo/lou,min = lb/lb,min = 0.30
su2 = 0.4*esu2_nominal ((5.5), TBDY) = 0.032
From table 5A.1, TBDY: esu2_nominal = 0.08,
For calculation of esu2_nominal and y2, sh2,ft2,fy2, it is considered
characteristic value fsy2 = fs2/1.2, from table 5.1, TBDY.
y1, sh1,ft1,fy1, are also multiplied by Min(1,1.25*(lb/lb,min)^ 2/3), from 10.3.5, ASCE 41-17.
with fs2 = fs = 350.1097
with Es2 = Es = 200000.00
yv = 0.00140044
shv = 0.0044814
ftv = 420.1317
fyv = 350.1097
suv = 0.00512
using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00
lo/lou,min = lb/lb,min = 0.30
suv = 0.4*esuv_nominal ((5.5), TBDY) = 0.032
From table 5A.1, TBDY: esuv_nominal = 0.08,
considering characteristic value fsyv = fsv/1.2, from table 5.1, TBDY
For calculation of esuv_nominal and yv, shv,ftv,fyv, it is considered
characteristic value fsyv = fsv/1.2, from table 5.1, TBDY.
y1, sh1,ft1,fy1, are also multiplied by Min(1,1.25*(lb/lb,min)^ 2/3), from 10.3.5, ASCE 41-17.
with fsv = fs = 350.1097
with Esv = Es = 200000.00
1 = Asl,ten/(b*d)*(fs1/fc) = 0.0635264
2 = Asl,com/(b*d)*(fs2/fc) = 0.0635264
v = Asl,mid/(b*d)*(fsv/fc) = 0.00
and confined core properties:
b = 2940.00
d = 178.00
d' = 12.00
fcc (5A.2, TBDY) = 25.06158
cc (5A.5, TBDY) = 0.00202463

```

$c = \text{confinement factor} = 1.00246$
 $1 = A_{sl,ten}/(b*d)*(f_{s1}/f_c) = 0.07574806$
 $2 = A_{sl,com}/(b*d)*(f_{s2}/f_c) = 0.07574806$
 $v = A_{sl,mid}/(b*d)*(f_{sv}/f_c) = 0.00$

Case/Assumption: Unconfined full section - Steel rupture
 ' satisfies Eq. (4.3)

--->

$v < v_{s,y2}$ - LHS eq.(4.5) is satisfied

--->

$\mu_u(4.9) = 0.18779572$
 $\mu_u = M_{Rc}(4.14) = 2.0658E+008$
 $u = \mu_u(4.1) = 3.0306889E-005$

Calculation of ratio l_b/l_d

Inadequate Lap Length with $l_b/l_d = 0.30$

Calculation of μ_{u1} -

Calculation of ultimate curvature μ_u according to 4.1, Biskinis/Fardis 2013:

$u = 3.0889637E-005$
 $\mu_u = 2.4003E+008$

with full section properties:

$b = 3000.00$
 $d = 208.00$
 $d' = 42.00$
 $v = 0.00176852$
 $N = 27588.841$
 $f_c = 25.00$
 $\alpha_{co}(5A.5, TBDY) = 0.002$

Final value of μ_{cu} : $\mu_{cu}^* = \text{shear_factor} * \text{Max}(\mu_{cu}, \mu_{cc}) = 0.0035$

The Shear_factor is considered equal to 1 (pure moment strength)

From (5.4b), TBDY: $\mu_{cu} = 0.0035$

$\mu_{we}((5.4c), TBDY) = \alpha_{se} * \text{sh}_{,min} * f_{ywe}/f_{ce} + \text{Min}(f_x, f_y) = 0.00$

where $f = \alpha_f * p_f * f_{fe}/f_{ce}$ is accounting for FRP contribution like EC8-part3 A.4.4.3(6)

$f_x = 0.00$

$\alpha_f = 0.00$

$b = 250.00$

$h = 3000.00$

From EC8 A.4.4.3(6), $p_f = 2t_f/bw = 0.008128$

$bw = 250.00$

effective stress from (A.35), $f_{fe} = 757.2164$

$f_y = 0.00$

$\alpha_f = 0.00$

$b = 3000.00$

$h = 250.00$

From EC8 A.4.4.3(6), $p_f = 2t_f/bw = 0.00067733$

$bw = 3000.00$

effective stress from (A.35), $f_{fe} = 954.4864$

$R = 40.00$

Effective FRP thickness, $t_f = N L * t * \text{Cos}(b_1) = 1.016$

$f_{u,f} = 1055.00$

$E_f = 64828.00$

$u_{,f} = 0.015$

$\alpha_{se}((5.4d), TBDY) = (\alpha_{se1} * A_{col1} + \alpha_{se2} * A_{col2} + \alpha_{se3} * A_{web}) / A_{sec} = 0.00$

$\alpha_{se1} = 0.00$

$sh_{_1} = 150.00$

$bo_{_1} = 190.00$

$ho_1 = 540.00$
 $bi2_1 = 655400.00$
 $ase2 = 0.00$
 $sh_2 = 150.00$
 $bo_2 = 190.00$
 $ho_2 = 540.00$
 $bi2_2 = 655400.00$
 $ase3 = 0$ (grid does not provide confinement)
 $psh,min = \text{Min}(psh,x, psh,y) = 0.00069813$
 Expression ((5.4d), TBDY) for psh,min has been multiplied by 0.3 according to 15.7.1.3 for members without earthquake detailing (90° closed stirrups)

$psh,x = ps1,x + ps2,x + ps3,x = 0.00356047$
 $ps1,x$ (column 1) = $(As1 \cdot h1 / s_1) / Ac = 0.00083776$
 $h1 = 600.00$
 $As1 = Astir1 \cdot ns1 = 157.0796$
 No stirrups, $ns1 = 2.00$
 $ps2,x$ (column 2) = $(As2 \cdot h2 / s_2) / Ac = 0.00083776$
 $h2 = 600.00$
 $As2 = Astir2 \cdot ns2 = 157.0796$
 No stirrups, $ns2 = 2.00$
 $ps3,x$ (web) = $(As3 \cdot h3 / s_3) / Ac = 0.00188496$
 $h3 = 1800.00$
 $As3 = Astir3 \cdot ns3 = 0.00$
 No stirrups, $ns3 = 2.00$

$psh,y = ps1,y + ps2,y + ps3,y = 0.00069813$
 $ps1,y$ (column 1) = $(As1 \cdot h1 / s_1) / Ac = 0.00034907$
 $h1 = 250.00$
 $As1 = Astir1 \cdot ns1 = 157.0796$
 No stirrups, $ns1 = 2.00$
 $ps2,y$ (column 2) = $(As2 \cdot h2 / s_2) / Ac = 0.00034907$
 $h2 = 250.00$
 $As2 = Astir2 \cdot ns2 = 157.0796$
 No stirrups, $ns2 = 2.00$
 $ps3,y$ (web) = $(As3 \cdot h3 / s_3) / Ac = 0.00$
 $h3 = 250.00$
 $As3 = Astir3 \cdot ns3 = 157.0796$
 No stirrups, $ns3 = 0.00$

$Asec = 750000.00$
 $s_1 = 150.00$
 $s_2 = 150.00$
 $s_3 = 200.00$
 $fywe = 625.00$
 $fce = 25.00$

From ((5.A5), TBDY), TBDY: $cc = 0.00202463$
 $c =$ confinement factor = 1.00246

$y1 = 0.00140044$
 $sh1 = 0.0044814$
 $ft1 = 420.1317$
 $fy1 = 350.1097$
 $su1 = 0.00512$

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
 and also multiplied by the shear_factor according to 15.7.1.4, with
 Shear_factor = 1.00

$lo/lo_{u,min} = lb/ld = 0.30$

$su1 = 0.4 \cdot esu1_nominal$ ((5.5), TBDY) = 0.032

From table 5A.1, TBDY: $esu1_nominal = 0.08$,

For calculation of $esu1_nominal$ and $y1, sh1, ft1, fy1$, it is considered
 characteristic value $fsy1 = fs1 / 1.2$, from table 5.1, TBDY.

$y1, sh1, ft1, fy1$, are also multiplied by $\text{Min}(1, 1.25 \cdot (lb/ld)^{2/3})$, from 10.3.5, ASCE 41-17.

with $fs1 = fs = 350.1097$

with $Es1 = Es = 200000.00$

$y2 = 0.00140044$
 $sh2 = 0.0044814$
 $ft2 = 420.1317$

```

fy2 = 350.1097
su2 = 0.00512
    using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
    and also multiplied by the shear_factor according to 15.7.1.4, with
    Shear_factor = 1.00
    lo/lo,min = lb/lb,min = 0.30
    su2 = 0.4*esu2_nominal ((5.5), TBDY) = 0.032
    From table 5A.1, TBDY: esu2_nominal = 0.08,
    For calculation of esu2_nominal and y2, sh2,ft2,fy2, it is considered
    characteristic value fsy2 = fs2/1.2, from table 5.1, TBDY.
    y1, sh1,ft1,fy1, are also multiplied by Min(1,1.25*(lb/ld)^ 2/3), from 10.3.5, ASCE 41-17.
    with fs2 = fs = 350.1097
    with Es2 = Es = 200000.00
    yv = 0.00140044
    shv = 0.0044814
    ftv = 420.1317
    fyv = 350.1097
    suv = 0.00512
    using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
    and also multiplied by the shear_factor according to 15.7.1.4, with
    Shear_factor = 1.00
    lo/lo,min = lb/ld = 0.30
    suv = 0.4*esuv_nominal ((5.5), TBDY) = 0.032
    From table 5A.1, TBDY: esuv_nominal = 0.08,
    considering characteristic value fsyv = fsv/1.2, from table 5.1, TBDY
    For calculation of esuv_nominal and yv, shv,ftv,fyv, it is considered
    characteristic value fsyv = fsv/1.2, from table 5.1, TBDY.
    y1, sh1,ft1,fy1, are also multiplied by Min(1,1.25*(lb/ld)^ 2/3), from 10.3.5, ASCE 41-17.
    with fsv = fs = 350.1097
    with Esv = Es = 200000.00
    1 = Asl,ten/(b*d)*(fs1/fc) = 0.0635264
    2 = Asl,com/(b*d)*(fs2/fc) = 0.0635264
    v = Asl,mid/(b*d)*(fsv/fc) = 0.03609935
and confined core properties:
b = 2940.00
d = 178.00
d' = 12.00
fcc (5A.2, TBDY) = 25.06158
cc (5A.5, TBDY) = 0.00202463
    c = confinement factor = 1.00246
    1 = Asl,ten/(b*d)*(fs1/fc) = 0.07574806
    2 = Asl,com/(b*d)*(fs2/fc) = 0.07574806
    v = Asl,mid/(b*d)*(fsv/fc) = 0.0430444
Case/Assumption: Unconfined full section - Steel rupture
' satisfies Eq. (4.3)
--->
v < vs,y2 - LHS eq.(4.5) is satisfied
--->
su (4.9) = 0.20311835
Mu = MRc (4.14) = 2.4003E+008
u = su (4.1) = 3.0889637E-005

```

Calculation of ratio lb/ld

Inadequate Lap Length with lb/ld = 0.30

Calculation of Mu2+

Calculation of ultimate curvature u according to 4.1, Biskinis/Fardis 2013:

u = 3.0306889E-005

Mu = 2.0658E+008

with full section properties:

$$b = 3000.00$$

$$d = 208.00$$

$$d' = 42.00$$

$$v = 0.00176852$$

$$N = 27588.841$$

$$f_c = 25.00$$

$$\alpha (5A.5, \text{TB DY}) = 0.002$$

$$\text{Final value of } \alpha: \alpha^* = \text{shear_factor} * \text{Max}(\alpha, \alpha_c) = 0.0035$$

The Shear_factor is considered equal to 1 (pure moment strength)

$$\text{From (5.4b), TB DY: } \alpha = 0.0035$$

$$\alpha_e ((5.4c), \text{TB DY}) = \alpha_e * \text{sh}_{\min} * f_{ywe} / f_{ce} + \text{Min}(\alpha_x, \alpha_y) = 0.00$$

where $\alpha = \alpha_f * p_f * f_{fe} / f_{ce}$ is accounting for FRP contribution like EC8-part3 A.4.4.3(6)

$$\alpha_x = 0.00$$

$$\alpha_f = 0.00$$

$$b = 250.00$$

$$h = 3000.00$$

$$\text{From EC8 A4.4.3(6), } p_f = 2t_f/b_w = 0.008128$$

$$b_w = 250.00$$

$$\text{effective stress from (A.35), } f_{fe} = 757.2164$$

$$\alpha_y = 0.00$$

$$\alpha_f = 0.00$$

$$b = 3000.00$$

$$h = 250.00$$

$$\text{From EC8 A4.4.3(6), } p_f = 2t_f/b_w = 0.00067733$$

$$b_w = 3000.00$$

$$\text{effective stress from (A.35), } f_{fe} = 954.4864$$

$$R = 40.00$$

$$\text{Effective FRP thickness, } t_f = N L * t * \cos(\beta_1) = 1.016$$

$$f_{u,f} = 1055.00$$

$$E_f = 64828.00$$

$$u_{,f} = 0.015$$

$$\alpha_e ((5.4d), \text{TB DY}) = (\alpha_e1 * A_{col1} + \alpha_e2 * A_{col2} + \alpha_e3 * A_{web}) / A_{sec} = 0.00$$

$$\alpha_e1 = 0.00$$

$$sh_1 = 150.00$$

$$bo_1 = 190.00$$

$$ho_1 = 540.00$$

$$bi2_1 = 655400.00$$

$$\alpha_e2 = 0.00$$

$$sh_2 = 150.00$$

$$bo_2 = 190.00$$

$$ho_2 = 540.00$$

$$bi2_2 = 655400.00$$

$$\alpha_e3 = 0 \text{ (grid does not provide confinement)}$$

$$p_{sh,\min} = \text{Min}(p_{sh,x}, p_{sh,y}) = 0.00069813$$

Expression ((5.4d), TB DY) for $p_{sh,\min}$ has been multiplied by 0.3 according to 15.7.1.3 for members without earthquake detailing (90° closed stirrups)

$$p_{sh,x} = p_{s1,x} + p_{s2,x} + p_{s3,x} = 0.00356047$$

$$p_{s1,x} \text{ (column 1)} = (A_{s1} * h_1 / s_1) / A_c = 0.00083776$$

$$h_1 = 600.00$$

$$A_{s1} = A_{stir1} * n_{s1} = 157.0796$$

$$\text{No stirrups, } n_{s1} = 2.00$$

$$p_{s2,x} \text{ (column 2)} = (A_{s2} * h_2 / s_2) / A_c = 0.00083776$$

$$h_2 = 600.00$$

$$A_{s2} = A_{stir2} * n_{s2} = 157.0796$$

$$\text{No stirrups, } n_{s2} = 2.00$$

$$p_{s3,x} \text{ (web)} = (A_{s3} * h_3 / s_3) / A_c = 0.00188496$$

$$h_3 = 1800.00$$

$$A_{s3} = A_{stir3} * n_{s3} = 0.00$$

$$\text{No stirrups, } n_{s3} = 2.00$$

$$p_{sh,y} = p_{s1,y} + p_{s2,y} + p_{s3,y} = 0.00069813$$

$$p_{s1,y} \text{ (column 1)} = (A_{s1} * h_1 / s_1) / A_c = 0.00034907$$

$h1 = 250.00$
 $As1 = Astir1 * ns1 = 157.0796$
 No stirups, $ns1 = 2.00$
 $ps2,y \text{ (column 2)} = (As2 * h2 / s_2) / Ac = 0.00034907$
 $h2 = 250.00$
 $As2 = Astir2 * ns2 = 157.0796$
 No stirups, $ns2 = 2.00$
 $ps3,y \text{ (web)} = (As3 * h3 / s_3) / Ac = 0.00$
 $h3 = 250.00$
 $As3 = Astir3 * ns3 = 157.0796$
 No stirups, $ns3 = 0.00$

$Asec = 750000.00$
 $s_1 = 150.00$
 $s_2 = 150.00$
 $s_3 = 200.00$
 $fywe = 625.00$
 $fce = 25.00$
 From ((5.A5), TBDY), TBDY: $cc = 0.00202463$
 $c = \text{confinement factor} = 1.00246$
 $y1 = 0.00140044$
 $sh1 = 0.0044814$
 $ft1 = 420.1317$
 $fy1 = 350.1097$
 $su1 = 0.00512$
 using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
 and also multiplied by the shear_factor according to 15.7.1.4, with
 $Shear_factor = 1.00$
 $lo/lou,min = lb/l_d = 0.30$
 $su1 = 0.4 * esu1_nominal \text{ ((5.5), TBDY)} = 0.032$
 From table 5A.1, TBDY: $esu1_nominal = 0.08$,
 For calculation of $esu1_nominal$ and $y1, sh1, ft1, fy1$, it is considered
 characteristic value $fsy1 = fs1 / 1.2$, from table 5.1, TBDY.
 $y1, sh1, ft1, fy1$, are also multiplied by $\text{Min}(1, 1.25 * (lb/l_d)^{2/3})$, from 10.3.5, ASCE 41-17.
 with $fs1 = fs = 350.1097$
 with $Es1 = Es = 200000.00$
 $y2 = 0.00140044$
 $sh2 = 0.0044814$
 $ft2 = 420.1317$
 $fy2 = 350.1097$
 $su2 = 0.00512$
 using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
 and also multiplied by the shear_factor according to 15.7.1.4, with
 $Shear_factor = 1.00$
 $lo/lou,min = lb/l_b,min = 0.30$
 $su2 = 0.4 * esu2_nominal \text{ ((5.5), TBDY)} = 0.032$
 From table 5A.1, TBDY: $esu2_nominal = 0.08$,
 For calculation of $esu2_nominal$ and $y2, sh2, ft2, fy2$, it is considered
 characteristic value $fsy2 = fs2 / 1.2$, from table 5.1, TBDY.
 $y1, sh1, ft1, fy1$, are also multiplied by $\text{Min}(1, 1.25 * (lb/l_d)^{2/3})$, from 10.3.5, ASCE 41-17.
 with $fs2 = fs = 350.1097$
 with $Es2 = Es = 200000.00$
 $yv = 0.00140044$
 $shv = 0.0044814$
 $ftv = 420.1317$
 $fyv = 350.1097$
 $suv = 0.00512$
 using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
 and also multiplied by the shear_factor according to 15.7.1.4, with
 $Shear_factor = 1.00$
 $lo/lou,min = lb/l_d = 0.30$
 $suv = 0.4 * esuv_nominal \text{ ((5.5), TBDY)} = 0.032$
 From table 5A.1, TBDY: $esuv_nominal = 0.08$,
 considering characteristic value $fsyv = fsv / 1.2$, from table 5.1, TBDY
 For calculation of $esuv_nominal$ and yv, shv, ftv, fyv , it is considered
 characteristic value $fsyv = fsv / 1.2$, from table 5.1, TBDY.
 $y1, sh1, ft1, fy1$, are also multiplied by $\text{Min}(1, 1.25 * (lb/l_d)^{2/3})$, from 10.3.5, ASCE 41-17.

```

with fsv = fs = 350.1097
with Esv = Es = 200000.00
1 = Asl,ten/(b*d)*(fs1/fc) = 0.0635264
2 = Asl,com/(b*d)*(fs2/fc) = 0.0635264
v = Asl,mid/(b*d)*(fsv/fc) = 0.00
and confined core properties:
b = 2940.00
d = 178.00
d' = 12.00
fcc (5A.2, TBDY) = 25.06158
cc (5A.5, TBDY) = 0.00202463
c = confinement factor = 1.00246
1 = Asl,ten/(b*d)*(fs1/fc) = 0.07574806
2 = Asl,com/(b*d)*(fs2/fc) = 0.07574806
v = Asl,mid/(b*d)*(fsv/fc) = 0.00
Case/Assumption: Unconfined full section - Steel rupture
'satisfies Eq. (4.3)

```

```

--->
v < vs,y2 - LHS eq.(4.5) is satisfied
--->
su (4.9) = 0.18779572
Mu = MRc (4.14) = 2.0658E+008
u = su (4.1) = 3.0306889E-005

```

Calculation of ratio lb/d

Inadequate Lap Length with lb/d = 0.30

Calculation of Mu2-

Calculation of ultimate curvature ϕ_u according to 4.1, Biskinis/Fardis 2013:
 $\phi_u = 3.0889637E-005$
 $M_u = 2.4003E+008$

with full section properties:

```

b = 3000.00
d = 208.00
d' = 42.00
v = 0.00176852
N = 27588.841
fc = 25.00
co (5A.5, TBDY) = 0.002
Final value of  $\phi_u$ :  $\phi_u^* = \text{shear\_factor} * \text{Max}(\phi_u, \phi_c) = 0.0035$ 
The Shear_factor is considered equal to 1 (pure moment strength)
From (5.4b), TBDY:  $\phi_u = 0.0035$ 
 $\phi_{we}$  ((5.4c), TBDY) =  $\text{ase} * \text{sh,min} * f_{ywe}/f_{ce} + \text{Min}(\phi_x, \phi_y) = 0.00$ 
where  $\phi_f = \text{af} * \text{pf} * f_{fe}/f_{ce}$  is accounting for FRP contribution like EC8-part3 A.4.4.3(6)

```

```

fx = 0.00
af = 0.00
b = 250.00
h = 3000.00
From EC8 A.4.4.3(6), pf = 2tf/bw = 0.008128
bw = 250.00
effective stress from (A.35),  $f_{fe} = 757.2164$ 

```

```

fy = 0.00
af = 0.00
b = 3000.00
h = 250.00
From EC8 A.4.4.3(6), pf = 2tf/bw = 0.00067733
bw = 3000.00

```

effective stress from (A.35), $f_{f,e} = 954.4864$

$R = 40.00$

Effective FRP thickness, $t_f = NL \cdot t \cdot \cos(b_1) = 1.016$

$f_{u,f} = 1055.00$

$E_f = 64828.00$

$u_{f,e} = 0.015$

$a_{se}((5.4d), TBDY) = (a_{se1} \cdot A_{col1} + a_{se2} \cdot A_{col2} + a_{se3} \cdot A_{web}) / A_{sec} = 0.00$

$a_{se1} = 0.00$

$sh_1 = 150.00$

$bo_1 = 190.00$

$ho_1 = 540.00$

$bi2_1 = 655400.00$

$a_{se2} = 0.00$

$sh_2 = 150.00$

$bo_2 = 190.00$

$ho_2 = 540.00$

$bi2_2 = 655400.00$

$a_{se3} = 0$ (grid does not provide confinement)

$p_{sh,min} = \min(p_{sh,x}, p_{sh,y}) = 0.00069813$

Expression ((5.4d), TBDY) for $p_{sh,min}$ has been multiplied by 0.3 according to 15.7.1.3 for members without earthquake detailing (90° closed stirrups)

$p_{sh,x} = p_{s1,x} + p_{s2,x} + p_{s3,x} = 0.00356047$

$p_{s1,x}$ (column 1) = $(A_{s1} \cdot h_1 / s_1) / A_c = 0.00083776$

$h_1 = 600.00$

$A_{s1} = A_{stir1} \cdot n_{s1} = 157.0796$

No stirrups, $n_{s1} = 2.00$

$p_{s2,x}$ (column 2) = $(A_{s2} \cdot h_2 / s_2) / A_c = 0.00083776$

$h_2 = 600.00$

$A_{s2} = A_{stir2} \cdot n_{s2} = 157.0796$

No stirrups, $n_{s2} = 2.00$

$p_{s3,x}$ (web) = $(A_{s3} \cdot h_3 / s_3) / A_c = 0.00188496$

$h_3 = 1800.00$

$A_{s3} = A_{stir3} \cdot n_{s3} = 0.00$

No stirrups, $n_{s3} = 2.00$

$p_{sh,y} = p_{s1,y} + p_{s2,y} + p_{s3,y} = 0.00069813$

$p_{s1,y}$ (column 1) = $(A_{s1} \cdot h_1 / s_1) / A_c = 0.00034907$

$h_1 = 250.00$

$A_{s1} = A_{stir1} \cdot n_{s1} = 157.0796$

No stirrups, $n_{s1} = 2.00$

$p_{s2,y}$ (column 2) = $(A_{s2} \cdot h_2 / s_2) / A_c = 0.00034907$

$h_2 = 250.00$

$A_{s2} = A_{stir2} \cdot n_{s2} = 157.0796$

No stirrups, $n_{s2} = 2.00$

$p_{s3,y}$ (web) = $(A_{s3} \cdot h_3 / s_3) / A_c = 0.00$

$h_3 = 250.00$

$A_{s3} = A_{stir3} \cdot n_{s3} = 157.0796$

No stirrups, $n_{s3} = 0.00$

$A_{sec} = 750000.00$

$s_1 = 150.00$

$s_2 = 150.00$

$s_3 = 200.00$

$f_{ywe} = 625.00$

$f_{ce} = 25.00$

From ((5.A5), TBDY), TBDY: $cc = 0.00202463$

c = confinement factor = 1.00246

$y_1 = 0.00140044$

$sh_1 = 0.0044814$

$ft_1 = 420.1317$

$fy_1 = 350.1097$

$su_1 = 0.00512$

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00

$l_o/l_{ou,min} = l_b/l_d = 0.30$
 $su_1 = 0.4 \cdot esu_{1,nominal} ((5.5), TBDY) = 0.032$
 From table 5A.1, TBDY: $esu_{1,nominal} = 0.08$,
 For calculation of $esu_{1,nominal}$ and y_1, sh_1, ft_1, fy_1 , it is considered
 characteristic value $fsy_1 = fs_1/1.2$, from table 5.1, TBDY.
 y_1, sh_1, ft_1, fy_1 , are also multiplied by $\text{Min}(1, 1.25 \cdot (l_b/l_d)^{2/3})$, from 10.3.5, ASCE 41-17.
 with $fs_1 = fs = 350.1097$
 with $Es_1 = Es = 200000.00$
 $y_2 = 0.00140044$
 $sh_2 = 0.0044814$
 $ft_2 = 420.1317$
 $fy_2 = 350.1097$
 $su_2 = 0.00512$
 using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
 and also multiplied by the shear_factor according to 15.7.1.4, with
 Shear_factor = 1.00
 $l_o/l_{ou,min} = l_b/l_{b,min} = 0.30$
 $su_2 = 0.4 \cdot esu_{2,nominal} ((5.5), TBDY) = 0.032$
 From table 5A.1, TBDY: $esu_{2,nominal} = 0.08$,
 For calculation of $esu_{2,nominal}$ and y_2, sh_2, ft_2, fy_2 , it is considered
 characteristic value $fsy_2 = fs_2/1.2$, from table 5.1, TBDY.
 y_1, sh_1, ft_1, fy_1 , are also multiplied by $\text{Min}(1, 1.25 \cdot (l_b/l_d)^{2/3})$, from 10.3.5, ASCE 41-17.
 with $fs_2 = fs = 350.1097$
 with $Es_2 = Es = 200000.00$
 $y_v = 0.00140044$
 $sh_v = 0.0044814$
 $ft_v = 420.1317$
 $fy_v = 350.1097$
 $suv = 0.00512$
 using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
 and also multiplied by the shear_factor according to 15.7.1.4, with
 Shear_factor = 1.00
 $l_o/l_{ou,min} = l_b/l_d = 0.30$
 $suv = 0.4 \cdot esuv_{nominal} ((5.5), TBDY) = 0.032$
 From table 5A.1, TBDY: $esuv_{nominal} = 0.08$,
 considering characteristic value $fsyv = fsv/1.2$, from table 5.1, TBDY
 For calculation of $esuv_{nominal}$ and y_v, sh_v, ft_v, fy_v , it is considered
 characteristic value $fsyv = fsv/1.2$, from table 5.1, TBDY.
 y_1, sh_1, ft_1, fy_1 , are also multiplied by $\text{Min}(1, 1.25 \cdot (l_b/l_d)^{2/3})$, from 10.3.5, ASCE 41-17.
 with $fsv = fs = 350.1097$
 with $Es_v = Es = 200000.00$
 $1 = A_{sl,ten}/(b \cdot d) \cdot (fs_1/f_c) = 0.0635264$
 $2 = A_{sl,com}/(b \cdot d) \cdot (fs_2/f_c) = 0.0635264$
 $v = A_{sl,mid}/(b \cdot d) \cdot (fsv/f_c) = 0.03609935$

and confined core properties:

$b = 2940.00$
 $d = 178.00$
 $d' = 12.00$
 $f_{cc} (5A.2, TBDY) = 25.06158$
 $cc (5A.5, TBDY) = 0.00202463$
 $c = \text{confinement factor} = 1.00246$
 $1 = A_{sl,ten}/(b \cdot d) \cdot (fs_1/f_c) = 0.07574806$
 $2 = A_{sl,com}/(b \cdot d) \cdot (fs_2/f_c) = 0.07574806$
 $v = A_{sl,mid}/(b \cdot d) \cdot (fsv/f_c) = 0.0430444$

Case/Assumption: Unconfined full section - Steel rupture

' satisfies Eq. (4.3)

--->

$v < v_{s,y2}$ - LHS eq.(4.5) is satisfied

--->

$su (4.9) = 0.20311835$
 $Mu = MRc (4.14) = 2.4003E+008$
 $u = su (4.1) = 3.0889637E-005$

Calculation of ratio l_b/l_d

Inadequate Lap Length with $l_b/l_d = 0.30$

Calculation of Shear Strength $V_r = \text{Min}(V_{r1}, V_{r2}) = 1.0244\text{E}+006$

Calculation of Shear Strength at edge 1, $V_{r1} = 1.0244\text{E}+006$

From (22.5.1.1) and 11.5.4.3, ACI 318-14: $V_{r1} = V_n < 0.83 \cdot f_c' \cdot 0.5 \cdot h \cdot d$

NOTE: In expression (22.5.1.1) 'Vw' is replaced by 'Vw + f * Vf' where Vf is the contribution of FRPs (11.3), ACI 440).

From Table (11.5.4.6(d-e)), ACI 318-14: $V_c = 815517.768$

$\mu_u / \mu_u - l_w / 2 = 0.00 \leq 0$

= 1 (normal-weight concrete)

$f_c' = 25.00$, but $f_c'^{0.5} \leq 8.3$ MPa (22.5.3.1, ACI 318-14)

$h = 3000.00$

$d = 200.00$

$l_w = 250.00$

$\mu_u = 3.7289358\text{E}-011$

$V_u = 1.7354940\text{E}-029$

$N_u = 27588.841$

From (11.5.4.8), ACI 318-14: $V_s = V_{s1} + V_{s2} + V_{s3} = 104719.755$

$V_{s1} = 52359.878$ is calculated for pseudo-Column 1, with:

$d = 200.00$

$A_v = 157079.633$

$s = 150.00$

$f_y = 500.00$

V_{s1} has been multiplied by $2(1-s/d)$ ($s > d/2$, according to ASCE 41-17,10.3.4)

$2(1-s/d) = 0.50$

$V_{s2} = 52359.878$ is calculated for pseudo-Column 2, with:

$d = 200.00$

$A_v = 157079.633$

$s = 150.00$

$f_y = 500.00$

V_{s2} has been multiplied by $2(1-s/d)$ ($s > d/2$, according to ASCE 41-17,10.3.4)

$2(1-s/d) = 0.50$

$V_{s3} = 0.00$ is calculated for web, with:

$d = 200.00$

$A_v = 0.00$

$s = 200.00$

$f_y = 500.00$

V_{s3} has been multiplied by $2(1-s/d)$ ($s > d/2$, according to ASCE 41-17,10.3.4)

$2(1-s/d) = 0.00$

V_f ((11-3)-(11.4), ACI 440) = 109599.773

$f = 0.95$, for fully-wrapped sections

$w_f / s_f = 1$ (FRP strips adjacent to one another).

In (11.3) $\sin + \cos$ is replaced with $(\cot + \cot a) \sin a$ which is more a generalised expression,

where a is the angle of the crack direction (see KANEPE).

This later relation, considered as a function $V_f(\theta)$, is implemented for every different fiber orientation a_i , as well as for 2 crack directions, $\theta = 45^\circ$ and $\theta = -45^\circ$ to take into consideration the cyclic seismic loading.

orientation 1: $\theta_1 = \theta_1 + 90^\circ = 90.00$

$V_f = \text{Min}(|V_f(45, \theta_1)|, |V_f(-45, \theta_1)|)$, with:

total thickness per orientation, $t_{f1} = N_L \cdot t / N_{oDir} = 1.016$

$d_{fv} = d$ (figure 11.2, ACI 440) = 208.00

f_{fe} ((11-5), ACI 440) = 259.312

$E_f = 64828.00$

$f_e = 0.004$, from (11.6a), ACI 440

with $f_u = 0.01$

From (11-11), ACI 440: $V_s + V_f \leq 1.9929\text{E}+006$

$b_w = 3000.00$

Calculation of Shear Strength at edge 2, $V_{r2} = 1.0244\text{E}+006$

From (22.5.1.1) and 11.5.4.3, ACI 318-14: $V_{r2} = V_n < 0.83 \cdot f_c' \cdot 0.5 \cdot h \cdot d$

NOTE: In expression (22.5.1.1) 'Vw' is replaced by 'Vw + f * Vf' where Vf is the contribution of FRPs (11.3), ACI 440).

From Table (11.5.4.6(d-e)), ACI 318-14: $V_c = 815517.768$

$M_u/V_u - l_w/2 = 0.00 \leq 0$

= 1 (normal-weight concrete)

$f'_c = 25.00$, but $f_c^{0.5} \leq 8.3$ MPa (22.5.3.1, ACI 318-14)

$h = 3000.00$

$d = 200.00$

$l_w = 250.00$

$M_u = 3.7289358E-011$

$V_u = 1.7354940E-029$

$N_u = 27588.841$

From (11.5.4.8), ACI 318-14: $V_s = V_{s1} + V_{s2} + V_{s3} = 104719.755$

$V_{s1} = 52359.878$ is calculated for pseudo-Column 1, with:

$d = 200.00$

$A_v = 157079.633$

$s = 150.00$

$f_y = 500.00$

V_{s1} has been multiplied by $2(1-s/d)$ ($s > d/2$, according to ASCE 41-17,10.3.4)

$2(1-s/d) = 0.50$

$V_{s2} = 52359.878$ is calculated for pseudo-Column 2, with:

$d = 200.00$

$A_v = 157079.633$

$s = 150.00$

$f_y = 500.00$

V_{s2} has been multiplied by $2(1-s/d)$ ($s > d/2$, according to ASCE 41-17,10.3.4)

$2(1-s/d) = 0.50$

$V_{s3} = 0.00$ is calculated for web, with:

$d = 200.00$

$A_v = 0.00$

$s = 200.00$

$f_y = 500.00$

V_{s3} has been multiplied by $2(1-s/d)$ ($s > d/2$, according to ASCE 41-17,10.3.4)

$2(1-s/d) = 0.00$

V_f ((11-3)-(11.4), ACI 440) = 109599.773

$f = 0.95$, for fully-wrapped sections

$w_f/s_f = 1$ (FRP strips adjacent to one another).

In (11.3) $\sin + \cos$ is replaced with $(\cot + \cot a)\sin a$ which is more a generalised expression,

where a is the angle of the crack direction (see KANEPE).

This later relation, considered as a function $V_f(\theta, a)$, is implemented for every different fiber orientation a_i , as well as for 2 crack directions, $\theta = 45^\circ$ and $\theta = -45^\circ$ to take into consideration the cyclic seismic loading.

orientation 1: $\theta = \theta_1 + 90^\circ = 90.00$

$V_f = \text{Min}(|V_f(45, \theta_1)|, |V_f(-45, a_1)|)$, with:

total thickness per orientation, $t_{f1} = N_L \cdot t / N_{\text{Dir}} = 1.016$

$d_{fv} = d$ (figure 11.2, ACI 440) = 208.00

f_{fe} ((11-5), ACI 440) = 259.312

$E_f = 64828.00$

$f_e = 0.004$, from (11.6a), ACI 440

with $f_u = 0.01$

From (11-11), ACI 440: $V_s + V_f \leq 1.9929E+006$

$b_w = 3000.00$

End Of Calculation of Shear Capacity ratio for element: wall W1 of floor 1

At local axis: 2

Start Of Calculation of Chord Rotation Capacity for element: wall W1 of floor 1

At local axis: 2

Integration Section: (a)

Section Type: rcrcws

Constant Properties

Knowledge Factor, $\gamma = 1.00$

According to 10.7.2.3, ASCE 41-17, shear walls with
transverse reinforcement percentage, $\rho_n < 0.0015$

are considered Force-Controlled and lower-bound strengths are used according to 7.5.1.3, ASCE 41-17
 $n = 0.00069813$

with $n = ps1 + ps2 + ps3$, being the shear reinf. ratio in a plane perpendicular to the shear axis 3
(pseudo-col.1 $ps1 = As1*b1/s1 = (As1*h1/s1) / Ac = 0.00034907$
 $h1 = 250.00$
 $s1 = 150.00$
total area of hoops perpendicular to shear axis, $As1 = 157.0796$
(pseudo-col.2 $ps2 = As2*b2/s2 = (As2*h2/s2) / Ac = 0.00034907$
 $h2 = 250.00$
 $s2 = 150.00$
total area of hoops perpendicular to shear axis, $As2 = 157.0796$
(grid $ps3 = As3*b3/s3 = (As3*h3/s3) / Ac = 0.00$
 $h3 = 250.00$
 $s3 = 200.00$
total area of hoops perpendicular to shear axis, $As3 = 0.00$
total section area, $Ac = 750000.00$

Consequently:

New material of Secondary Member: Concrete Strength, $fc = fc_lower_bound = 25.00$
New material of Secondary Member: Steel Strength, $fs = fs_lower_bound = 500.00$
Concrete Elasticity, $Ec = 26999.444$
Steel Elasticity, $Es = 200000.00$
Total Height, $H_{tot} = 3000.00$
Edges Width, $W_{edg} = 250.00$
Edges Height, $H_{edg} = 600.00$
Web Width, $W_{web} = 250.00$
Cover Thickness, $c = 25.00$
Element Length, $L = 3000.00$
Secondary Member
Smooth Bars
Ductile Steel
Without Detailing for Earthquake Resistance (including stirrups not closed at 135°)
Longitudinal Bars With Ends Lapped Starting at the End Sections
Inadequate Lap Length with $lb/ld = 0.30$
FRP Wrapping Data
Type: Carbon
Cured laminate properties (design values)
Thickness, $t = 1.016$
Tensile Strength, $ffu = 1055.00$
Tensile Modulus, $E_f = 64828.00$
Elongation, $efu = 0.01$
Number of directions, $NoDir = 1$
Fiber orientations, $bi: 0.00^\circ$
Number of layers, $NL = 1$
Radius of rounding corners, $R = 40.00$

Stepwise Properties

Axial Force, $F = -33005.924$
Longitudinal Reinforcement Area Distribution (in 2 divisions)
-Tension: $As_{lt} = 0.00$
-Compression: $As_{lc} = 7269.645$
Longitudinal Reinforcement Area Distribution (in 3 divisions)
-Tension: $As_{l,ten} = 2865.133$
-Compression: $As_{l,com} = 2865.133$
-Middle: $As_{l,mid} = 1539.38$
Mean Diameter of Tension Reinforcement, $DbL = 17.33333$

Considering wall controlled by Shear (shear control ratio > 1),
interstorey drift provided values are calculated
New component: From table 7-7, ASCE 41_17: Final chord rotation Capacity $u_R = 1.0^*$ $u = 0.004$
from table 10-20: $u = 0.004$

with:

- Condition i (shear wall and wall segments)
- $(A_s - A_s') \cdot f_y + P) / (t_w \cdot l_w \cdot f_c') = -0.19209689$
 - $A_s = 0.00$
 - $A_s' = 7269.645$
 - $f_y = 500.00$
 - $P = 33005.924$
 - $t_w = 250.00$
 - $l_w = 3000.00$
 - $f_c = 25.00$

End Of Calculation of Chord Rotation Capacity for element: wall W1 of floor 1

At local axis: 2

Integration Section: (a)

Calculation No. 3

wall W1, Floor 1


Limit State: Operational Level (data interpolation between analysis steps 1 and 2)

Analysis: Uniform +X

Check: Shear capacity VR_d

Edge: Start

Local Axis: (3)



Start Of Calculation of Shear Capacity for element: wall W1 of floor 1

At local axis: 3

Integration Section: (a)

Section Type: rcrws

Constant Properties

Knowledge Factor, = 1.00

Member Shear Force is generally considered as Force-Controlled Action according to Table C7-1, ASCE 41-17.

Lower-bound strengths are used for Force-Controlled Actions according to 7.5.1.3, ASCE 41-17

Consequently:

New material of Secondary Member: Concrete Strength, $f_c = f_{c_lower_bound} = 25.00$

New material of Secondary Member: Steel Strength, $f_s = f_{s_lower_bound} = 500.00$

Concrete Elasticity, $E_c = 26999.444$

Steel Elasticity, $E_s = 200000.00$

Total Height, $H_{tot} = 3000.00$

Edges Width, $W_{edg} = 250.00$

Edges Height, $H_{edg} = 600.00$

Web Width, $W_{web} = 250.00$

Cover Thickness, $c = 25.00$

Element Length, $L = 3000.00$

Secondary Member

Smooth Bars

Ductile Steel

Without Detailing for Earthquake Resistance (including stirrups not closed at 135°)

Longitudinal Bars With Ends Lapped Starting at the End Sections

Inadequate Lap Length with $l_o/l_{o,min} = l_b/l_d = 0.30$

FRP Wrapping Data

Type: Carbon

Cured laminate properties (design values)

Thickness, $t = 1.016$

Tensile Strength, $f_{fu} = 1055.00$

Tensile Modulus, $E_f = 64828.00$

Elongation, $\epsilon_{fu} = 0.01$

Number of directions, $N_{oDir} = 1$

Fiber orientations, $b_i: 0.00^\circ$

Number of layers, $N_L = 1$

Radius of rounding corners, $R = 40.00$

Stepwise Properties

EDGE -A-

Bending Moment, $M_a = 9.7363E+007$

Shear Force, $V_a = -32914.791$

EDGE -B-

Bending Moment, $M_b = 1.4016E+006$

Shear Force, $V_b = 32914.791$

BOTH EDGES

Axial Force, $F = -33005.924$

Longitudinal Reinforcement Area Distribution (in 2 divisions)

-Tension: $A_{sl,t} = 0.00$

-Compression: $A_{sl,c} = 7269.645$

Longitudinal Reinforcement Area Distribution (in 3 divisions)

-Tension: $A_{sl,ten} = 2865.133$

-Compression: $A_{sl,com} = 2865.133$

-Middle: $A_{sl,mid} = 1539.38$

Mean Diameter of Tension Reinforcement, $D_{bL,ten} = 17.33333$

New component: From table 7-7, ASCE 41_17: Final Shear Capacity $V_R = 1.0 \cdot V_n = 2.4900E+006$

From (22.5.1.1) and 11.5.4.3, ACI 318-14: $V_n < 0.83 \cdot f_c'^{0.5} \cdot h \cdot d = 2.4900E+006$

NOTE: In expression (22.5.1.1) ' V_w ' is replaced by ' $V_w + f \cdot V_f$ '
where V_f is the contribution of FRPs (11.3), ACI 440).

From Table (11.5.4.6(d-e)), ACI 318-14: $V_c = 778130.169$

$\mu_u / \mu_u - l_w / 2 = 1458.046 > 0$

= 1 (normal-weight concrete)

$f_c' = 25.00$, but $f_c'^{0.5} \leq 8.3$ MPa (22.5.3.1, ACI 318-14)

$h = 250.00$

$d = 2400.00$

$l_w = 3000.00$

$\mu_u = 9.7363E+007$

$V_u = 32914.791$
 $N_u = 33005.924$
 From (11.5.4.8), ACI 318-14: $V_s = V_{s1} + V_{s2} + V_{s3} = 1.0681E+006$
 $V_{s1} = 251327.412$ is calculated for pseudo-Column 1, with:
 $d = 480.00$
 $A_v = 157079.633$
 $s = 150.00$
 $f_y = 500.00$
 V_{s1} has been multiplied by 1 ($s < d/2$, according to ASCE 41-17,10.3.4)
 $V_{s2} = 251327.412$ is calculated for pseudo-Column 2, with:
 $d = 480.00$
 $A_v = 157079.633$
 $s = 150.00$
 $f_y = 500.00$
 V_{s2} has been multiplied by 1 ($s < d/2$, according to ASCE 41-17,10.3.4)
 $V_{s3} = 565486.678$ is calculated for web, with:
 $d = 1440.00$
 $A_v = 157079.633$
 $s = 200.00$
 $f_y = 500.00$
 V_{s3} has been multiplied by 1 ($s < d/2$, according to ASCE 41-17,10.3.4)
 $V_f ((11-3)-(11.4), ACI 440) = 1.5581E+006$
 $f = 0.95$, for fully-wrapped sections
 $w_f/s_f = 1$ (FRP strips adjacent to one another).
 In (11.3) $\sin + \cos$ is replaced with $(\cot + \cot a) \sin a$ which is more a generalised expression,
 where a is the angle of the crack direction (see KANEPE).
 This later relation, considered as a function $V_f(a_i)$, is implemented for every different fiber orientation a_i ,
 as well as for 2 crack directions, $a = 45^\circ$ and $a = -45^\circ$ to take into consideration the cyclic seismic loading.
 orientation 1: $a_1 = b_1 + 90^\circ = 90.00$
 $V_f = \text{Min}(|V_f(45, a_1)|, |V_f(-45, a_1)|)$, with:
 total thickness per orientation, $t_{f1} = NL \cdot t / \text{NoDir} = 1.016$
 $d_{fv} = d$ (figure 11.2, ACI 440) = 2957.00
 $f_{fe} ((11-5), ACI 440) = 259.312$
 $E_f = 64828.00$
 $f_e = 0.004$, from (11.6a), ACI 440
 with $f_u = 0.01$
 From (11-11), ACI 440: $V_s + V_f \leq 1.9929E+006$
 $b_w = 250.00$

 End Of Calculation of Shear Capacity for element: wall W1 of floor 1
 At local axis: 3
 Integration Section: (a)

Calculation No. 4

wall W1, Floor 1
 Limit State: Operational Level (data interpolation between analysis steps 1 and 2)
 Analysis: Uniform +X
 Check: Chord rotation capacity (θ_u)
 Edge: Start
 Local Axis: (3)



Start Of Calculation of Shear Capacity ratio for element: wall W1 of floor 1

At Shear local axis: 3

(Bending local axis: 2)

Section Type: rcwrs

Constant Properties

Knowledge Factor, $\gamma = 1.00$

Mean strength values are used for both shear and moment calculations.

Consequently:

New material of Secondary Member: Concrete Strength, $f_c = f_{cm} = 25.00$

New material of Secondary Member: Steel Strength, $f_s = f_{sm} = 500.00$

Concrete Elasticity, $E_c = 26999.444$

Steel Elasticity, $E_s = 200000.00$

#####

Note: Especially for the calculation of moment strengths,

the above steel re-bar strengths are multiplied by 1.25 according to R18.6.5, ACI 318-14

New material: Steel Strength, $f_s = 1.25 \cdot f_{sm} = 625.00$

#####

Total Height, $H_{tot} = 3000.00$

Edges Width, $W_{edg} = 250.00$

Edges Height, $H_{edg} = 600.00$

Web Width, $W_{web} = 250.00$

Cover Thickness, $c = 25.00$

Mean Confinement Factor overall section = 1.00246

Element Length, $L = 3000.00$

Secondary Member

Smooth Bars

Ductile Steel

Without Detailing for Earthquake Resistance (including stirrups not closed at 135°)

Longitudinal Bars With Ends Lapped Starting at the End Sections

Inadequate Lap Length with $l_o/l_{o,min} = 0.30$

FRP Wrapping Data

Type: Carbon

Cured laminate properties (design values)

Thickness, $t = 1.016$

Tensile Strength, $f_{fu} = 1055.00$

Tensile Modulus, $E_f = 64828.00$

Elongation, $\epsilon_{fu} = 0.01$

Number of directions, $NoDir = 1$

Fiber orientations, $b_i: 0.00^\circ$

Number of layers, $NL = 1$

Radius of rounding corners, $R = 40.00$

Stepwise Properties

At local axis: 3

EDGE -A-

Shear Force, $V_a = 1.0097420E-028$

EDGE -B-

Shear Force, $V_b = -1.0097420E-028$

BOTH EDGES

Axial Force, $F = -27588.841$

Longitudinal Reinforcement Area Distribution (in 2 divisions)

-Tension: $As_t = 0.00$

-Compression: $As_c = 7269.645$

Longitudinal Reinforcement Area Distribution (in 3 divisions)

-Tension: $As_{t,ten} = 2865.133$

-Compression: $As_{c,com} = 2865.133$

-Middle: $As_{mid} = 0.00$

(According to 10.7.2.3 As_{mid} is setted equal to zero)

Calculation of Shear Capacity ratio, $V_e/V_r = 1.02813$

Member Controlled by Shear ($V_e/V_r > 1$)

Calculation of Shear Demand from fig. R18.6.5, ACI 318-14 $V_e = (M_{pr1} + M_{pr2})/l_n = 2.5600E+006$ with

$M_{pr1} = \text{Max}(Mu_{1+}, Mu_{1-}) = 3.8401E+009$

$Mu_{1+} = 3.3585E+009$, is the ultimate moment strength at the edge 1 of the member in the actual moment direction which is defined for the static loading combination

$Mu_{1-} = 3.8401E+009$, is the ultimate moment strength at the edge 1 of the member in the opposite moment direction which is defined for the static loading combination

$M_{pr2} = \text{Max}(Mu_{2+}, Mu_{2-}) = 3.8401E+009$

$Mu_{2+} = 3.3585E+009$, is the ultimate moment strength at the edge 2 of the member in the actual moment direction which is defined for the static loading combination

$Mu_{2-} = 3.8401E+009$, is the ultimate moment strength at the edge 2 of the member in the opposite moment direction which is defined for the static loading combination

Calculation of Mu_{1+}

Calculation of ultimate curvature ϕ_u according to 4.1, Biskinis/Fardis 2013:

$\phi_u = 2.0296703E-006$

$M_u = 3.3585E+009$

with full section properties:

$b = 250.00$

$d = 2957.00$

$d' = 43.00$

$v = 0.0014928$

$N = 27588.841$

$f_c = 25.00$

ϕ_c (5A.5, TBDY) = 0.002

Final value of ϕ_u : $\phi_u^* = \text{shear_factor} * \text{Max}(\phi_u, \phi_c) = 0.0035$

The Shear_factor is considered equal to 1 (pure moment strength)

From (5.4b), TBDY: $\phi_u = 0.0035$

ϕ_{we} ((5.4c), TBDY) = $a s_e * \phi_{sh,min} * f_{ywe} / f_{ce} + \text{Min}(\phi_x, \phi_y) = 0.00$

where $\phi = a f * \phi_f * f_{fe} / f_{ce}$ is accounting for FRP contribution like EC8-part3 A.4.4.3(6)

$\phi_x = 0.00$

$a f = 0.00$

$b = 250.00$

$h = 3000.00$

From EC8 A.4.4.3(6), $\phi_f = 2 t_f / b_w = 0.008128$

$b_w = 250.00$

effective stress from (A.35), $f_{fe} = 757.2164$

$\phi_y = 0.00$

$a f = 0.00$

$b = 3000.00$

$h = 250.00$

From EC8 A.4.4.3(6), $\phi_f = 2 t_f / b_w = 0.00067733$

$b_w = 3000.00$

effective stress from (A.35), $f_{fe} = 954.4864$

$R = 40.00$
 Effective FRP thickness, $t_f = NL \cdot t \cdot \cos(b_1) = 1.016$
 $f_{u,f} = 1055.00$
 $E_f = 64828.00$
 $u_f = 0.015$
 $ase((5.4d), TBDY) = (ase_1 \cdot A_{col1} + ase_2 \cdot A_{col2} + ase_3 \cdot A_{web}) / A_{sec} = 0.00$
 $ase_1 = 0.00$
 $sh_1 = 150.00$
 $bo_1 = 190.00$
 $ho_1 = 540.00$
 $bi2_1 = 655400.00$
 $ase_2 = 0.00$
 $sh_2 = 150.00$
 $bo_2 = 190.00$
 $ho_2 = 540.00$
 $bi2_2 = 655400.00$
 $ase_3 = 0$ (grid does not provide confinement)
 $psh,min = \min(psh,x, psh,y) = 0.00069813$

Expression ((5.4d), TBDY) for psh,min has been multiplied by 0.3 according to 15.7.1.3 for members without earthquake detailing (90° closed stirrups)

$psh,x = ps1,x + ps2,x + ps3,x = 0.00356047$
 $ps1,x$ (column 1) = $(As1 \cdot h1 / s_1) / A_c = 0.00083776$
 $h1 = 600.00$
 $As1 = Astir1 \cdot ns1 = 157.0796$
 No stirrups, $ns1 = 2.00$
 $ps2,x$ (column 2) = $(As2 \cdot h2 / s_2) / A_c = 0.00083776$
 $h2 = 600.00$
 $As2 = Astir2 \cdot ns2 = 157.0796$
 No stirrups, $ns2 = 2.00$
 $ps3,x$ (web) = $(As3 \cdot h3 / s_3) / A_c = 0.00188496$
 $h3 = 1800.00$
 $As3 = Astir3 \cdot ns3 = 0.00$
 No stirrups, $ns3 = 2.00$

$psh,y = ps1,y + ps2,y + ps3,y = 0.00069813$
 $ps1,y$ (column 1) = $(As1 \cdot h1 / s_1) / A_c = 0.00034907$
 $h1 = 250.00$
 $As1 = Astir1 \cdot ns1 = 157.0796$
 No stirrups, $ns1 = 2.00$
 $ps2,y$ (column 2) = $(As2 \cdot h2 / s_2) / A_c = 0.00034907$
 $h2 = 250.00$
 $As2 = Astir2 \cdot ns2 = 157.0796$
 No stirrups, $ns2 = 2.00$
 $ps3,y$ (web) = $(As3 \cdot h3 / s_3) / A_c = 0.00$
 $h3 = 250.00$
 $As3 = Astir3 \cdot ns3 = 157.0796$
 No stirrups, $ns3 = 0.00$

$A_{sec} = 750000.00$
 $s_1 = 150.00$
 $s_2 = 150.00$
 $s_3 = 200.00$

$f_{ywe} = 625.00$
 $f_{ce} = 25.00$

From ((5.A5), TBDY), TBDY: $cc = 0.00202463$
 c = confinement factor = 1.00246

$y1 = 0.00140044$
 $sh1 = 0.0044814$
 $ft1 = 420.1317$
 $fy1 = 350.1097$
 $su1 = 0.00512$

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
 and also multiplied by the shear_factor according to 15.7.1.4, with
 $Shear_factor = 1.00$
 $lo/lo,min = lb/ld = 0.30$

```

su1 = 0.4*esu1_nominal ((5.5), TBDY) = 0.032
From table 5A.1, TBDY: esu1_nominal = 0.08,
For calculation of esu1_nominal and y1, sh1,ft1,fy1, it is considered
characteristic value fsy1 = fs1/1.2, from table 5.1, TBDY.
y1, sh1,ft1,fy1, are also multiplied by Min(1,1.25*(lb/ld)^ 2/3), from 10.3.5, ASCE 41-17.
with fs1 = fs = 350.1097
with Es1 = Es = 200000.00
y2 = 0.00140044
sh2 = 0.0044814
ft2 = 420.1317
fy2 = 350.1097
su2 = 0.00512
using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00
lo/lou,min = lb/lb,min = 0.30
su2 = 0.4*esu2_nominal ((5.5), TBDY) = 0.032
From table 5A.1, TBDY: esu2_nominal = 0.08,
For calculation of esu2_nominal and y2, sh2,ft2,fy2, it is considered
characteristic value fsy2 = fs2/1.2, from table 5.1, TBDY.
y1, sh1,ft1,fy1, are also multiplied by Min(1,1.25*(lb/ld)^ 2/3), from 10.3.5, ASCE 41-17.
with fs2 = fs = 350.1097
with Es2 = Es = 200000.00
yv = 0.00140044
shv = 0.0044814
ftv = 420.1317
fyv = 350.1097
suv = 0.00512
using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00
lo/lou,min = lb/ld = 0.30
suv = 0.4*esuv_nominal ((5.5), TBDY) = 0.032
From table 5A.1, TBDY: esuv_nominal = 0.08,
considering characteristic value fsyv = fsv/1.2, from table 5.1, TBDY
For calculation of esuv_nominal and yv, shv,ftv,fyv, it is considered
characteristic value fsyv = fsv/1.2, from table 5.1, TBDY.
y1, sh1,ft1,fy1, are also multiplied by Min(1,1.25*(lb/ld)^ 2/3), from 10.3.5, ASCE 41-17.
with fsv = fs = 350.1097
with Esv = Es = 200000.00
1 = Asl,ten/(b*d)*(fs1/fc) = 0.05427722
2 = Asl,com/(b*d)*(fs2/fc) = 0.05427722
v = Asl,mid/(b*d)*(fsv/fc) = 0.00

```

and confined core properties:

```

b = 190.00
d = 2927.00
d' = 13.00
fcc (5A.2, TBDY) = 25.06158
cc (5A.5, TBDY) = 0.00202463
c = confinement factor = 1.00246
1 = Asl,ten/(b*d)*(fs1/fc) = 0.07214938
2 = Asl,com/(b*d)*(fs2/fc) = 0.07214938
v = Asl,mid/(b*d)*(fsv/fc) = 0.00

```

Case/Assumption: Unconfined full section - Steel rupture
 ' satisfies Eq. (4.3)

```

--->
v < vs,y2 - LHS eq.(4.5) is satisfied
--->
su (4.9) = 0.14691336
Mu = MRc (4.14) = 3.3585E+009
u = su (4.1) = 2.0296703E-006

```

Calculation of ratio lb/ld

Inadequate Lap Length with lb/ld = 0.30

Calculation of Mu1-

Calculation of ultimate curvature ϕ_u according to 4.1, Biskinis/Fardis 2013:

$$\phi_u = 2.0532423E-006$$

$$M_u = 3.8401E+009$$

with full section properties:

$$b = 250.00$$

$$d = 2957.00$$

$$d' = 43.00$$

$$v = 0.0014928$$

$$N = 27588.841$$

$$f_c = 25.00$$

$$\phi_c \text{ (5A.5, TBDY)} = 0.002$$

$$\text{Final value of } \phi_u: \phi_u^* = \text{shear_factor} * \text{Max}(\phi_u, \phi_c) = 0.0035$$

The Shear_factor is considered equal to 1 (pure moment strength)

$$\text{From (5.4b), TBDY: } \phi_u = 0.0035$$

$$\phi_{ue} \text{ ((5.4c), TBDY)} = a_{se} * \phi_{u,min} * f_{ywe}/f_{ce} + \text{Min}(\phi_{fx}, \phi_{fy}) = 0.00$$

where $\phi_{fx} = a_f * \phi_f * f_{fe}/f_{ce}$ is accounting for FRP contribution like EC8-part3 A.4.4.3(6)

$$\phi_{fx} = 0.00$$

$$a_f = 0.00$$

$$b = 250.00$$

$$h = 3000.00$$

$$\text{From EC8 A.4.4.3(6), } \phi_f = 2t_f/bw = 0.008128$$

$$bw = 250.00$$

$$\text{effective stress from (A.35), } f_{fe} = 757.2164$$

$$\phi_{fy} = 0.00$$

$$a_f = 0.00$$

$$b = 3000.00$$

$$h = 250.00$$

$$\text{From EC8 A.4.4.3(6), } \phi_f = 2t_f/bw = 0.00067733$$

$$bw = 3000.00$$

$$\text{effective stress from (A.35), } f_{fe} = 954.4864$$

$$R = 40.00$$

$$\text{Effective FRP thickness, } t_f = NL * t * \cos(b_1) = 1.016$$

$$f_{u,f} = 1055.00$$

$$E_f = 64828.00$$

$$u_{f} = 0.015$$

$$a_{se} \text{ ((5.4d), TBDY)} = (a_{se1} * A_{col1} + a_{se2} * A_{col2} + a_{se3} * A_{web}) / A_{sec} = 0.00$$

$$a_{se1} = 0.00$$

$$sh_1 = 150.00$$

$$bo_1 = 190.00$$

$$ho_1 = 540.00$$

$$bi2_1 = 655400.00$$

$$a_{se2} = 0.00$$

$$sh_2 = 150.00$$

$$bo_2 = 190.00$$

$$ho_2 = 540.00$$

$$bi2_2 = 655400.00$$

$$a_{se3} = 0 \text{ (grid does not provide confinement)}$$

$$\phi_{psh,min} = \text{Min}(\phi_{psh,x}, \phi_{psh,y}) = 0.00069813$$

Expression ((5.4d), TBDY) for $\phi_{psh,min}$ has been multiplied by 0.3 according to 15.7.1.3 for members without earthquake detailing (90° closed stirrups)

$$\phi_{psh,x} = \phi_{s1,x} + \phi_{s2,x} + \phi_{s3,x} = 0.00356047$$

$$\phi_{s1,x} \text{ (column 1)} = (A_{s1} * h_1 / s_1) / A_c = 0.00083776$$

$$h_1 = 600.00$$

$$A_{s1} = A_{stir1} * n_{s1} = 157.0796$$

$$\text{No stirrups, } n_{s1} = 2.00$$

$$\phi_{s2,x} \text{ (column 2)} = (A_{s2} * h_2 / s_2) / A_c = 0.00083776$$

$h_2 = 600.00$
 $As_2 = Astir_2 * ns_2 = 157.0796$
 No stirups, $ns_2 = 2.00$
 $ps_{3,x} (web) = (As_3 * h_3 / s_3) / A_c = 0.00188496$
 $h_3 = 1800.00$
 $As_3 = Astir_3 * ns_3 = 0.00$
 No stirups, $ns_3 = 2.00$

$psh,y = ps_1,y + ps_2,y + ps_3,y = 0.00069813$
 $ps_{1,y} (column\ 1) = (As_1 * h_1 / s_1) / A_c = 0.00034907$
 $h_1 = 250.00$
 $As_1 = Astir_1 * ns_1 = 157.0796$
 No stirups, $ns_1 = 2.00$
 $ps_{2,y} (column\ 2) = (As_2 * h_2 / s_2) / A_c = 0.00034907$
 $h_2 = 250.00$
 $As_2 = Astir_2 * ns_2 = 157.0796$
 No stirups, $ns_2 = 2.00$
 $ps_{3,y} (web) = (As_3 * h_3 / s_3) / A_c = 0.00$
 $h_3 = 250.00$
 $As_3 = Astir_3 * ns_3 = 157.0796$
 No stirups, $ns_3 = 0.00$

$A_{sec} = 750000.00$
 $s_1 = 150.00$
 $s_2 = 150.00$
 $s_3 = 200.00$
 $fy_{we} = 625.00$
 $f_{ce} = 25.00$
 From ((5.A.5), TBDY), TBDY: $cc = 0.00202463$
 $c = \text{confinement factor} = 1.00246$
 $y_1 = 0.00140044$
 $sh_1 = 0.0044814$
 $ft_1 = 420.1317$
 $fy_1 = 350.1097$
 $su_1 = 0.00512$
 using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
 and also multiplied by the shear_factor according to 15.7.1.4, with
 $Shear_factor = 1.00$
 $lo/lou,min = lb/l_d = 0.30$
 $su_1 = 0.4 * esu_{1_nominal} ((5.5), TBDY) = 0.032$
 From table 5A.1, TBDY: $esu_{1_nominal} = 0.08$,
 For calculation of $esu_{1_nominal}$ and y_1, sh_1, ft_1, fy_1 , it is considered
 characteristic value $fsy_1 = fs_1 / 1.2$, from table 5.1, TBDY.
 y_1, sh_1, ft_1, fy_1 , are also multiplied by $\text{Min}(1, 1.25 * (lb/l_d)^{2/3})$, from 10.3.5, ASCE 41-17.
 with $fs_1 = fs = 350.1097$
 with $Es_1 = Es = 200000.00$
 $y_2 = 0.00140044$
 $sh_2 = 0.0044814$
 $ft_2 = 420.1317$
 $fy_2 = 350.1097$
 $su_2 = 0.00512$
 using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
 and also multiplied by the shear_factor according to 15.7.1.4, with
 $Shear_factor = 1.00$
 $lo/lou,min = lb/l_b,min = 0.30$
 $su_2 = 0.4 * esu_{2_nominal} ((5.5), TBDY) = 0.032$
 From table 5A.1, TBDY: $esu_{2_nominal} = 0.08$,
 For calculation of $esu_{2_nominal}$ and y_2, sh_2, ft_2, fy_2 , it is considered
 characteristic value $fsy_2 = fs_2 / 1.2$, from table 5.1, TBDY.
 y_1, sh_1, ft_1, fy_1 , are also multiplied by $\text{Min}(1, 1.25 * (lb/l_d)^{2/3})$, from 10.3.5, ASCE 41-17.
 with $fs_2 = fs = 350.1097$
 with $Es_2 = Es = 200000.00$
 $y_v = 0.00140044$
 $sh_v = 0.0044814$
 $ft_v = 420.1317$
 $fy_v = 350.1097$
 $suv = 0.00512$

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
 and also multiplied by the shear_factor according to 15.7.1.4, with
 Shear_factor = 1.00
 $l_o/l_{ou,min} = l_b/l_d = 0.30$
 $suv = 0.4 * esuv_{nominal} ((5.5), TBDY) = 0.032$
 From table 5A.1, TBDY: $esuv_{nominal} = 0.08$,
 considering characteristic value $fsyv = fsv/1.2$, from table 5.1, TBDY
 For calculation of $esuv_{nominal}$ and y_v , sh_v, ft_v, fy_v , it is considered
 characteristic value $fsyv = fsv/1.2$, from table 5.1, TBDY.
 y_1, sh_1, ft_1, fy_1 , are also multiplied by $Min(1, 1.25 * (l_b/l_d)^{2/3})$, from 10.3.5, ASCE 41-17.
 with $fsv = fs = 350.1097$
 with $Esv = Es = 200000.00$
 $1 = Asl_{ten}/(b*d) * (fs_1/fc) = 0.05427722$
 $2 = Asl_{com}/(b*d) * (fs_2/fc) = 0.05427722$
 $v = Asl_{mid}/(b*d) * (fsv/fc) = 0.0291621$

and confined core properties:

$b = 190.00$
 $d = 2927.00$
 $d' = 13.00$
 $fcc (5A.2, TBDY) = 25.06158$
 $cc (5A.5, TBDY) = 0.00202463$
 $c = \text{confinement factor} = 1.00246$
 $1 = Asl_{ten}/(b*d) * (fs_1/fc) = 0.07214938$
 $2 = Asl_{com}/(b*d) * (fs_2/fc) = 0.07214938$
 $v = Asl_{mid}/(b*d) * (fsv/fc) = 0.03876447$

Case/Assumption: Unconfined full section - Steel rupture
 ' satisfies Eq. (4.3)

--->
 $v < v_{s,y2}$ - LHS eq.(4.5) is satisfied
 --->
 $su (4.9) = 0.15670711$
 $Mu = MRc (4.14) = 3.8401E+009$
 $u = su (4.1) = 2.0532423E-006$

Calculation of ratio l_b/l_d

Inadequate Lap Length with $l_b/l_d = 0.30$

Calculation of Mu_{2+}

Calculation of ultimate curvature u according to 4.1, Biskinis/Fardis 2013:

$u = 2.0296703E-006$
 $Mu = 3.3585E+009$

with full section properties:

$b = 250.00$
 $d = 2957.00$
 $d' = 43.00$
 $v = 0.0014928$
 $N = 27588.841$
 $fc = 25.00$
 $co (5A.5, TBDY) = 0.002$
 Final value of cu : $cu * = \text{shear_factor} * \text{Max}(cu, cc) = 0.0035$
 The Shear_factor is considered equal to 1 (pure moment strength)
 From (5.4b), TBDY: $cu = 0.0035$
 $we ((5.4c), TBDY) = ase * sh_{min} * fy_{we}/f_{ce} + \text{Min}(fx, fy) = 0.00$
 where $f = af * pf * f_{fe}/f_{ce}$ is accounting for FRP contribution like EC8-part3 A.4.4.3(6)

 $fx = 0.00$
 $af = 0.00$
 $b = 250.00$
 $h = 3000.00$

From EC8 A4.4.3(6), $pf = 2tf/bw = 0.008128$
 $bw = 250.00$
effective stress from (A.35), $ff,e = 757.2164$

$f_y = 0.00$
 $a_f = 0.00$
 $b = 3000.00$
 $h = 250.00$
From EC8 A4.4.3(6), $pf = 2tf/bw = 0.00067733$
 $bw = 3000.00$
effective stress from (A.35), $ff,e = 954.4864$

$R = 40.00$
Effective FRP thickness, $tf = NL*t*Cos(b1) = 1.016$
 $f_{u,f} = 1055.00$
 $E_f = 64828.00$
 $u_f = 0.015$
 $ase((5.4d), TBDY) = (ase1*A_{col1} + ase2*A_{col2} + ase3*A_{web})/A_{sec} = 0.00$
 $ase1 = 0.00$
 $sh_1 = 150.00$
 $bo_1 = 190.00$
 $ho_1 = 540.00$
 $bi2_1 = 655400.00$
 $ase2 = 0.00$
 $sh_2 = 150.00$
 $bo_2 = 190.00$
 $ho_2 = 540.00$
 $bi2_2 = 655400.00$

$ase3 = 0$ (grid does not provide confinement)
 $psh,min = Min(psh,x, psh,y) = 0.00069813$

Expression ((5.4d), TBDY) for psh,min has been multiplied by 0.3 according to 15.7.1.3 for members without earthquake detailing (90° closed stirrups)

$psh,x = ps1,x + ps2,x + ps3,x = 0.00356047$
 $ps1,x$ (column 1) = $(As1*h1/s_1)/Ac = 0.00083776$
 $h1 = 600.00$
 $As1 = Astir1*ns1 = 157.0796$
No stirrups, $ns1 = 2.00$
 $ps2,x$ (column 2) = $(As2*h2/s_2)/Ac = 0.00083776$
 $h2 = 600.00$
 $As2 = Astir2*ns2 = 157.0796$
No stirrups, $ns2 = 2.00$
 $ps3,x$ (web) = $(As3*h3/s_3)/Ac = 0.00188496$
 $h3 = 1800.00$
 $As3 = Astir3*ns3 = 0.00$
No stirrups, $ns3 = 2.00$

$psh,y = ps1,y + ps2,y + ps3,y = 0.00069813$
 $ps1,y$ (column 1) = $(As1*h1/s_1)/Ac = 0.00034907$
 $h1 = 250.00$
 $As1 = Astir1*ns1 = 157.0796$
No stirrups, $ns1 = 2.00$
 $ps2,y$ (column 2) = $(As2*h2/s_2)/Ac = 0.00034907$
 $h2 = 250.00$
 $As2 = Astir2*ns2 = 157.0796$
No stirrups, $ns2 = 2.00$
 $ps3,y$ (web) = $(As3*h3/s_3)/Ac = 0.00$
 $h3 = 250.00$
 $As3 = Astir3*ns3 = 157.0796$
No stirrups, $ns3 = 0.00$

$A_{sec} = 750000.00$
 $s_1 = 150.00$
 $s_2 = 150.00$
 $s_3 = 200.00$
 $f_{ywe} = 625.00$
 $f_{ce} = 25.00$

From ((5.A.5), TBDY), TBDY: $cc = 0.00202463$
 $c = \text{confinement factor} = 1.00246$
 $y1 = 0.00140044$
 $sh1 = 0.0044814$
 $ft1 = 420.1317$
 $fy1 = 350.1097$
 $su1 = 0.00512$
 using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
 and also multiplied by the shear_factor according to 15.7.1.4, with
 Shear_factor = 1.00
 $lo/lou,min = lb/ld = 0.30$
 $su1 = 0.4 * esu1_nominal ((5.5), TBDY) = 0.032$
 From table 5A.1, TBDY: $esu1_nominal = 0.08$,
 For calculation of $esu1_nominal$ and $y1, sh1, ft1, fy1$, it is considered
 characteristic value $fsy1 = fs1/1.2$, from table 5.1, TBDY.
 $y1, sh1, ft1, fy1$, are also multiplied by $\text{Min}(1, 1.25 * (lb/ld)^{2/3})$, from 10.3.5, ASCE 41-17.
 with $fs1 = fs = 350.1097$
 with $Es1 = Es = 200000.00$
 $y2 = 0.00140044$
 $sh2 = 0.0044814$
 $ft2 = 420.1317$
 $fy2 = 350.1097$
 $su2 = 0.00512$
 using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
 and also multiplied by the shear_factor according to 15.7.1.4, with
 Shear_factor = 1.00
 $lo/lou,min = lb/lb,min = 0.30$
 $su2 = 0.4 * esu2_nominal ((5.5), TBDY) = 0.032$
 From table 5A.1, TBDY: $esu2_nominal = 0.08$,
 For calculation of $esu2_nominal$ and $y2, sh2, ft2, fy2$, it is considered
 characteristic value $fsy2 = fs2/1.2$, from table 5.1, TBDY.
 $y1, sh1, ft1, fy1$, are also multiplied by $\text{Min}(1, 1.25 * (lb/ld)^{2/3})$, from 10.3.5, ASCE 41-17.
 with $fs2 = fs = 350.1097$
 with $Es2 = Es = 200000.00$
 $yv = 0.00140044$
 $shv = 0.0044814$
 $ftv = 420.1317$
 $fyv = 350.1097$
 $suv = 0.00512$
 using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
 and also multiplied by the shear_factor according to 15.7.1.4, with
 Shear_factor = 1.00
 $lo/lou,min = lb/ld = 0.30$
 $suv = 0.4 * esuv_nominal ((5.5), TBDY) = 0.032$
 From table 5A.1, TBDY: $esuv_nominal = 0.08$,
 considering characteristic value $fsyv = fsv/1.2$, from table 5.1, TBDY
 For calculation of $esuv_nominal$ and yv, shv, ftv, fyv , it is considered
 characteristic value $fsyv = fsv/1.2$, from table 5.1, TBDY.
 $y1, sh1, ft1, fy1$, are also multiplied by $\text{Min}(1, 1.25 * (lb/ld)^{2/3})$, from 10.3.5, ASCE 41-17.
 with $fsv = fs = 350.1097$
 with $Esv = Es = 200000.00$
 $1 = Asl,ten/(b*d)*(fs1/fc) = 0.05427722$
 $2 = Asl,com/(b*d)*(fs2/fc) = 0.05427722$
 $v = Asl,mid/(b*d)*(fsv/fc) = 0.00$
 and confined core properties:
 $b = 190.00$
 $d = 2927.00$
 $d' = 13.00$
 $fcc (5A.2, TBDY) = 25.06158$
 $cc (5A.5, TBDY) = 0.00202463$
 $c = \text{confinement factor} = 1.00246$
 $1 = Asl,ten/(b*d)*(fs1/fc) = 0.07214938$
 $2 = Asl,com/(b*d)*(fs2/fc) = 0.07214938$
 $v = Asl,mid/(b*d)*(fsv/fc) = 0.00$
 Case/Assumption: Unconfined full section - Steel rupture
 ' satisfies Eq. (4.3)

--->

$v < v_{s,y2}$ - LHS eq.(4.5) is satisfied

---->

$$s_u(4.9) = 0.14691336$$

$$M_u = M_{Rc}(4.14) = 3.3585E+009$$

$$u = s_u(4.1) = 2.0296703E-006$$

Calculation of ratio I_b/I_d

Inadequate Lap Length with $I_b/I_d = 0.30$

Calculation of M_{u2} -

Calculation of ultimate curvature u according to 4.1, Biskinis/Fardis 2013:

$$u = 2.0532423E-006$$

$$M_u = 3.8401E+009$$

with full section properties:

$$b = 250.00$$

$$d = 2957.00$$

$$d' = 43.00$$

$$v = 0.0014928$$

$$N = 27588.841$$

$$f_c = 25.00$$

$$\alpha(5A.5, TBDY) = 0.002$$

$$\text{Final value of } \alpha: \alpha^* = \text{shear_factor} * \text{Max}(\alpha, \alpha_c) = 0.0035$$

The Shear_factor is considered equal to 1 (pure moment strength)

$$\text{From (5.4b), TBDY: } \alpha = 0.0035$$

$$\alpha_e((5.4c), TBDY) = \alpha_{se} * \text{sh}_{\min} * f_{ywe}/f_{ce} + \text{Min}(\alpha_x, \alpha_y) = 0.00$$

where $\alpha = \alpha_f * p_f * f_{fe}/f_{ce}$ is accounting for FRP contribution like EC8-part3 A.4.4.3(6)

$$\alpha_x = 0.00$$

$$\alpha_f = 0.00$$

$$b = 250.00$$

$$h = 3000.00$$

$$\text{From EC8 A4.4.3(6), } p_f = 2t_f/bw = 0.008128$$

$$bw = 250.00$$

$$\text{effective stress from (A.35), } f_{fe} = 757.2164$$

$$\alpha_y = 0.00$$

$$\alpha_f = 0.00$$

$$b = 3000.00$$

$$h = 250.00$$

$$\text{From EC8 A4.4.3(6), } p_f = 2t_f/bw = 0.00067733$$

$$bw = 3000.00$$

$$\text{effective stress from (A.35), } f_{fe} = 954.4864$$

$$R = 40.00$$

$$\text{Effective FRP thickness, } t_f = NL * t * \cos(\beta_1) = 1.016$$

$$f_{u,f} = 1055.00$$

$$E_f = 64828.00$$

$$u_{,f} = 0.015$$

$$\alpha_{se}((5.4d), TBDY) = (\alpha_{se1} * A_{col1} + \alpha_{se2} * A_{col2} + \alpha_{se3} * A_{web}) / A_{sec} = 0.00$$

$$\alpha_{se1} = 0.00$$

$$sh_1 = 150.00$$

$$bo_1 = 190.00$$

$$ho_1 = 540.00$$

$$bi2_1 = 655400.00$$

$$\alpha_{se2} = 0.00$$

$$sh_2 = 150.00$$

$$bo_2 = 190.00$$

$$ho_2 = 540.00$$

$$bi2_2 = 655400.00$$

ase3 = 0 (grid does not provide confinement)
 psh,min = Min(psh,x , psh,y) = 0.00069813
 Expression ((5.4d), TBDY) for psh,min has been multiplied by 0.3 according to 15.7.1.3 for members without earthquake detailing (90° closed stirrups)

psh,x = ps1,x+ps2,x+ps3,x = 0.00356047
 ps1,x (column 1) = (As1*h1/s_1)/Ac = 0.00083776
 h1 = 600.00
 As1 = Astir1*ns1 = 157.0796
 No stirrups, ns1 = 2.00
 ps2,x (column 2) = (As2*h2/s_2)/Ac = 0.00083776
 h2 = 600.00
 As2 = Astir2*ns2 = 157.0796
 No stirrups, ns2 = 2.00
 ps3,x (web) = (As3*h3/s_3)/Ac = 0.00188496
 h3 = 1800.00
 As3 = Astir3*ns3 = 0.00
 No stirrups, ns3 = 2.00

psh,y = ps1,y+ps2,y+ps3,y = 0.00069813
 ps1,y (column 1) = (As1*h1/s_1)/Ac = 0.00034907
 h1 = 250.00
 As1 = Astir1*ns1 = 157.0796
 No stirrups, ns1 = 2.00
 ps2,y (column 2) = (As2*h2/s_2)/Ac = 0.00034907
 h2 = 250.00
 As2 = Astir2*ns2 = 157.0796
 No stirrups, ns2 = 2.00
 ps3,y (web) = (As3*h3/s_3)/Ac = 0.00
 h3 = 250.00
 As3 = Astir3*ns3 = 157.0796
 No stirrups, ns3 = 0.00

Asec = 750000.00
 s_1 = 150.00
 s_2 = 150.00
 s_3 = 200.00
 fywe = 625.00
 fce = 25.00
 From ((5.A5), TBDY), TBDY: cc = 0.00202463
 c = confinement factor = 1.00246
 y1 = 0.00140044
 sh1 = 0.0044814
 ft1 = 420.1317
 fy1 = 350.1097
 su1 = 0.00512
 using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
 and also multiplied by the shear_factor according to 15.7.1.4, with
 Shear_factor = 1.00
 lo/lou,min = lb/lb = 0.30
 su1 = 0.4*esu1_nominal ((5.5), TBDY) = 0.032
 From table 5A.1, TBDY: esu1_nominal = 0.08,
 For calculation of esu1_nominal and y1, sh1,ft1,fy1, it is considered
 characteristic value fsy1 = fs1/1.2, from table 5.1, TBDY.
 y1, sh1,ft1,fy1, are also multiplied by Min(1,1.25*(lb/lb)^ 2/3), from 10.3.5, ASCE 41-17.
 with fs1 = fs = 350.1097
 with Es1 = Es = 200000.00
 y2 = 0.00140044
 sh2 = 0.0044814
 ft2 = 420.1317
 fy2 = 350.1097
 su2 = 0.00512
 using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
 and also multiplied by the shear_factor according to 15.7.1.4, with
 Shear_factor = 1.00
 lo/lou,min = lb/lb,min = 0.30
 su2 = 0.4*esu2_nominal ((5.5), TBDY) = 0.032

From table 5A.1, TBDY: $es_{u2_nominal} = 0.08$,
 For calculation of $es_{u2_nominal}$ and y_2 , sh_2 , ft_2 , fy_2 , it is considered
 characteristic value $fs_{y2} = fs_2/1.2$, from table 5.1, TBDY.
 y_1 , sh_1 , ft_1 , fy_1 , are also multiplied by $\text{Min}(1, 1.25 \cdot (lb/d)^{2/3})$, from 10.3.5, ASCE 41-17.
 with $fs_2 = fs = 350.1097$
 with $Es_2 = Es = 200000.00$
 $y_v = 0.00140044$
 $sh_v = 0.0044814$
 $ft_v = 420.1317$
 $fy_v = 350.1097$
 $suv = 0.00512$
 using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
 and also multiplied by the shear_factor according to 15.7.1.4, with
 Shear_factor = 1.00
 $lo/lou, \min = lb/d = 0.30$
 $suv = 0.4 \cdot es_{u2_nominal} \cdot ((5.5), TBDY) = 0.032$
 From table 5A.1, TBDY: $es_{uv_nominal} = 0.08$,
 considering characteristic value $fs_{yv} = fs_v/1.2$, from table 5.1, TBDY
 For calculation of $es_{uv_nominal}$ and y_v , sh_v , ft_v , fy_v , it is considered
 characteristic value $fs_{yv} = fs_v/1.2$, from table 5.1, TBDY.
 y_1 , sh_1 , ft_1 , fy_1 , are also multiplied by $\text{Min}(1, 1.25 \cdot (lb/d)^{2/3})$, from 10.3.5, ASCE 41-17.
 with $fs_v = fs = 350.1097$
 with $Es_v = Es = 200000.00$
 $1 = Asl, \text{ten} / (b \cdot d) \cdot (fs_1 / fc) = 0.05427722$
 $2 = Asl, \text{com} / (b \cdot d) \cdot (fs_2 / fc) = 0.05427722$
 $v = Asl, \text{mid} / (b \cdot d) \cdot (fs_v / fc) = 0.0291621$
 and confined core properties:
 $b = 190.00$
 $d = 2927.00$
 $d' = 13.00$
 fcc (5A.2, TBDY) = 25.06158
 cc (5A.5, TBDY) = 0.00202463
 c = confinement factor = 1.00246
 $1 = Asl, \text{ten} / (b \cdot d) \cdot (fs_1 / fc) = 0.07214938$
 $2 = Asl, \text{com} / (b \cdot d) \cdot (fs_2 / fc) = 0.07214938$
 $v = Asl, \text{mid} / (b \cdot d) \cdot (fs_v / fc) = 0.03876447$
 Case/Assumption: Unconfined full section - Steel rupture
 ' satisfies Eq. (4.3)
 --->
 $v < v_{s,y2}$ - LHS eq.(4.5) is satisfied
 --->
 su (4.9) = 0.15670711
 $Mu = MRc$ (4.14) = 3.8401E+009
 $u = su$ (4.1) = 2.0532423E-006

 Calculation of ratio lb/d

Inadequate Lap Length with $lb/d = 0.30$

 Calculation of Shear Strength $V_r = \text{Min}(V_{r1}, V_{r2}) = 2.4900E+006$

Calculation of Shear Strength at edge 1, $V_{r1} = 2.4900E+006$
 From (22.5.1.1) and 11.5.4.3, ACI 318-14: $V_{r1} = V_n < 0.83 \cdot fc' \cdot 0.5 \cdot h \cdot d$

NOTE: In expression (22.5.1.1) ' V_w ' is replaced by ' $V_w + f \cdot V_f$ '
 where V_f is the contribution of FRPs (11.3), ACI 440).

From Table (11.5.4.6(d-e)), ACI 318-14: $V_c = 815517.768$
 $Mu / Vu - lw / 2 = 0.00 \leq 0$
 = 1 (normal-weight concrete)
 $fc' = 25.00$, but $fc' \cdot 0.5 \leq 8.3$ MPa (22.5.3.1, ACI 318-14)
 $h = 250.00$
 $d = 2400.00$

lw = 3000.00

Mu = 1.1486927E-009

Vu = 1.0097420E-028

Nu = 27588.841

From (11.5.4.8), ACI 318-14: $V_s = V_{s1} + V_{s2} + V_{s3} = 1.0681E+006$

$V_{s1} = 251327.412$ is calculated for pseudo-Column 1, with:

d = 480.00

$A_v = 157079.633$

s = 150.00

$f_y = 500.00$

V_{s1} has been multiplied by 1 ($s < d/2$, according to ASCE 41-17,10.3.4)

$V_{s2} = 251327.412$ is calculated for pseudo-Column 2, with:

d = 480.00

$A_v = 157079.633$

s = 150.00

$f_y = 500.00$

V_{s2} has been multiplied by 1 ($s < d/2$, according to ASCE 41-17,10.3.4)

$V_{s3} = 565486.678$ is calculated for web, with:

d = 1440.00

$A_v = 157079.633$

s = 200.00

$f_y = 500.00$

V_{s3} has been multiplied by 1 ($s < d/2$, according to ASCE 41-17,10.3.4)

V_f ((11-3)-(11.4), ACI 440) = 1.5581E+006

f = 0.95, for fully-wrapped sections

$w_f/s_f = 1$ (FRP strips adjacent to one another).

In (11.3) $\sin + \cos$ is replaced with $(\cot + \cot a)\sin a$ which is more a generalised expression, where a is the angle of the crack direction (see KANEPE).

This later relation, considered as a function $V_f(,)$, is implemented for every different fiber orientation a_i , as well as for 2 crack directions, $a = 45^\circ$ and $a = -45^\circ$ to take into consideration the cyclic seismic loading.

orientation 1: $a_1 = b_1 + 90^\circ = 90.00$

$V_f = \text{Min}(|V_f(45, a_1)|, |V_f(-45, a_1)|)$, with:

total thickness per orientation, $t_{f1} = N_L * t / N_{oDir} = 1.016$

$d_{fv} = d$ (figure 11.2, ACI 440) = 2957.00

f_{fe} ((11-5), ACI 440) = 259.312

$E_f = 64828.00$

$f_e = 0.004$, from (11.6a), ACI 440

with $f_u = 0.01$

From (11-11), ACI 440: $V_s + V_f \leq 1.9929E+006$

bw = 250.00

Calculation of Shear Strength at edge 2, $V_{r2} = 2.4900E+006$

From (22.5.1.1) and 11.5.4.3, ACI 318-14: $V_{r2} = V_n < 0.83 * f_c'^{0.5} * h * d$

NOTE: In expression (22.5.1.1) ' V_w ' is replaced by ' $V_w + f * V_f$ ' where V_f is the contribution of FRPs (11.3), ACI 440).

From Table (11.5.4.6(d-e)), ACI 318-14: $V_c = 815517.768$

$\mu_u / \mu_u - l_w / 2 = 0.00 \leq 0$

= 1 (normal-weight concrete)

$f_c' = 25.00$, but $f_c'^{0.5} \leq 8.3$ MPa (22.5.3.1, ACI 318-14)

h = 250.00

d = 2400.00

lw = 3000.00

Mu = 1.1486927E-009

Vu = 1.0097420E-028

Nu = 27588.841

From (11.5.4.8), ACI 318-14: $V_s = V_{s1} + V_{s2} + V_{s3} = 1.0681E+006$

$V_{s1} = 251327.412$ is calculated for pseudo-Column 1, with:

d = 480.00

$A_v = 157079.633$

s = 150.00

$f_y = 500.00$

V_{s1} has been multiplied by 1 ($s < d/2$, according to ASCE 41-17,10.3.4)

$V_{s2} = 251327.412$ is calculated for pseudo-Column 2, with:

d = 480.00

$A_v = 157079.633$

$s = 150.00$
 $f_y = 500.00$
 V_{s2} has been multiplied by 1 ($s < d/2$, according to ASCE 41-17,10.3.4)
 $V_{s3} = 565486.678$ is calculated for web, with:
 $d = 1440.00$
 $A_v = 157079.633$
 $s = 200.00$
 $f_y = 500.00$
 V_{s3} has been multiplied by 1 ($s < d/2$, according to ASCE 41-17,10.3.4)
 $V_f ((11-3)-(11.4), \text{ACI 440}) = 1.5581\text{E}+006$
 $f = 0.95$, for fully-wrapped sections
 $w_f/s_f = 1$ (FRP strips adjacent to one another).
In (11.3) $\sin + \cos$ is replaced with $(\cot + \cot a)\sin a$ which is more a generalised expression,
where a is the angle of the crack direction (see KANEPE).
This later relation, considered as a function $V_f(,)$, is implemented for every different fiber orientation a_i ,
as well as for 2 crack directions, $a = 45^\circ$ and $a = -45^\circ$ to take into consideration the cyclic seismic loading.
orientation 1: $\theta_1 = b_1 + 90^\circ = 90.00$
 $V_f = \text{Min}(|V_f(45, \theta_1)|, |V_f(-45, a_1)|)$, with:
total thickness per orientation, $t_{f1} = N_L * t / \text{NoDir} = 1.016$
 $d_{fv} = d$ (figure 11.2, ACI 440) = 2957.00
 $f_{fe} ((11-5), \text{ACI 440}) = 259.312$
 $E_f = 64828.00$
 $f_e = 0.004$, from (11.6a), ACI 440
with $f_u = 0.01$
From (11-11), ACI 440: $V_s + V_f \leq 1.9929\text{E}+006$
 $b_w = 250.00$

End Of Calculation of Shear Capacity ratio for element: wall W1 of floor 1
At local axis: 3

Start Of Calculation of Shear Capacity ratio for element: wall W1 of floor 1
At Shear local axis: 2
(Bending local axis: 3)
Section Type: rcrcws

Constant Properties

Knowledge Factor, $K = 1.00$
Mean strength values are used for both shear and moment calculations.
Consequently:
New material of Secondary Member: Concrete Strength, $f_c = f_{cm} = 25.00$
New material of Secondary Member: Steel Strength, $f_s = f_{sm} = 500.00$
Concrete Elasticity, $E_c = 26999.444$
Steel Elasticity, $E_s = 200000.00$

Note: Especially for the calculation of moment strengths,
the above steel re-bar strengths are multiplied by 1.25 according to R18.6.5, ACI 318-14
New material: Steel Strength, $f_s = 1.25 * f_{sm} = 625.00$

Total Height, $H_{tot} = 3000.00$
Edges Width, $W_{edg} = 250.00$
Edges Height, $H_{edg} = 600.00$
Web Width, $W_{web} = 250.00$
Cover Thickness, $c = 25.00$
Mean Confinement Factor overall section = 1.00246
Element Length, $L = 3000.00$
Secondary Member
Smooth Bars
Ductile Steel
Without Detailing for Earthquake Resistance (including stirrups not closed at 135°)
Longitudinal Bars With Ends Lapped Starting at the End Sections
Inadequate Lap Length with $l_o/l_{ou,min} = 0.30$
FRP Wrapping Data
Type: Carbon

Cured laminate properties (design values)

Thickness, $t = 1.016$

Tensile Strength, $f_{fu} = 1055.00$

Tensile Modulus, $E_f = 64828.00$

Elongation, $\epsilon_{fu} = 0.01$

Number of directions, $NoDir = 1$

Fiber orientations, $b_i = 0.00^\circ$

Number of layers, $NL = 1$

Radius of rounding corners, $R = 40.00$

Stepwise Properties

At local axis: 2

EDGE -A-

Shear Force, $V_a = 1.7354940E-029$

EDGE -B-

Shear Force, $V_b = -1.7354940E-029$

BOTH EDGES

Axial Force, $F = -27588.841$

Longitudinal Reinforcement Area Distribution (in 2 divisions)

-Tension: $As_t = 0.00$

-Compression: $As_c = 7269.645$

Longitudinal Reinforcement Area Distribution (in 3 divisions)

-Tension: $As_{t,ten} = 2830.575$

-Compression: $As_{l,com} = 2830.575$

-Middle: $As_{l,mid} = 0.00$

(According to 10.7.2.3 $As_{l,mid}$ is setted equal to zero)

Calculation of Shear Capacity ratio, $V_e/V_r = 0.15621236$

Member Controlled by Flexure ($V_e/V_r < 1$)

Calculation of Shear Demand from fig. R18.6.5, ACI 318-14 $V_e = (M_{pr1} + M_{pr2})/l_n = 160017.271$

with

$M_{pr1} = \max(\mu_{u1+}, \mu_{u1-}) = 2.4003E+008$

$\mu_{u1+} = 2.0658E+008$, is the ultimate moment strength at the edge 1 of the member in the actual moment direction which is defined for the static loading combination

$\mu_{u1-} = 2.4003E+008$, is the ultimate moment strength at the edge 1 of the member in the opposite moment direction which is defined for the static loading combination

$M_{pr2} = \max(\mu_{u2+}, \mu_{u2-}) = 2.4003E+008$

$\mu_{u2+} = 2.0658E+008$, is the ultimate moment strength at the edge 2 of the member in the actual moment direction which is defined for the static loading combination

$\mu_{u2-} = 2.4003E+008$, is the ultimate moment strength at the edge 2 of the member in the opposite moment direction which is defined for the static loading combination

Calculation of μ_{u1+}

Calculation of ultimate curvature ϕ_u according to 4.1, Biskinis/Fardis 2013:

$\phi_u = 3.0306889E-005$

$\mu_u = 2.0658E+008$

with full section properties:

$b = 3000.00$

$d = 208.00$

$d' = 42.00$

$v = 0.00176852$

$N = 27588.841$

$f_c = 25.00$

ϕ_o (5A.5, TBDY) = 0.002

Final value of ϕ_u : $\phi_u^* = \text{shear_factor} * \max(\phi_u, \phi_o) = 0.0035$

The Shear_factor is considered equal to 1 (pure moment strength)

From (5.4b), TBDY: $\phi_u = 0.0035$

$w_e ((5.4c), TBDY) = a_{se} \cdot sh_{min} \cdot f_{ywe}/f_{ce} + \text{Min}(f_x, f_y) = 0.00$
where $f = a_f \cdot p_f \cdot f_{fe}/f_{ce}$ is accounting for FRP contribution like EC8-part3 A.4.4.3(6)

$f_x = 0.00$
 $a_f = 0.00$
 $b = 250.00$
 $h = 3000.00$
From EC8 A.4.4.3(6), $p_f = 2t_f/bw = 0.008128$
 $bw = 250.00$
effective stress from (A.35), $f_{fe} = 757.2164$

$f_y = 0.00$
 $a_f = 0.00$
 $b = 3000.00$
 $h = 250.00$
From EC8 A.4.4.3(6), $p_f = 2t_f/bw = 0.00067733$
 $bw = 3000.00$
effective stress from (A.35), $f_{fe} = 954.4864$

$R = 40.00$
Effective FRP thickness, $t_f = NL \cdot t \cdot \cos(b_1) = 1.016$
 $f_{u,f} = 1055.00$
 $E_f = 64828.00$
 $u_{,f} = 0.015$
 $a_{se} ((5.4d), TBDY) = (a_{se1} \cdot A_{col1} + a_{se2} \cdot A_{col2} + a_{se3} \cdot A_{web})/A_{sec} = 0.00$
 $a_{se1} = 0.00$
 $sh_1 = 150.00$
 $bo_1 = 190.00$
 $ho_1 = 540.00$
 $bi2_1 = 655400.00$
 $a_{se2} = 0.00$
 $sh_2 = 150.00$
 $bo_2 = 190.00$
 $ho_2 = 540.00$
 $bi2_2 = 655400.00$

$a_{se3} = 0$ (grid does not provide confinement)
 $p_{sh,min} = \text{Min}(p_{sh,x}, p_{sh,y}) = 0.00069813$

Expression ((5.4d), TBDY) for $p_{sh,min}$ has been multiplied by 0.3 according to 15.7.1.3 for members without earthquake detailing (90° closed stirrups)

$p_{sh,x} = p_{s1,x} + p_{s2,x} + p_{s3,x} = 0.00356047$
 $p_{s1,x} \text{ (column 1)} = (A_{s1} \cdot h_1/s_1)/A_c = 0.00083776$
 $h_1 = 600.00$
 $A_{s1} = A_{stir1} \cdot n_{s1} = 157.0796$
No stirrups, $n_{s1} = 2.00$
 $p_{s2,x} \text{ (column 2)} = (A_{s2} \cdot h_2/s_2)/A_c = 0.00083776$
 $h_2 = 600.00$
 $A_{s2} = A_{stir2} \cdot n_{s2} = 157.0796$
No stirrups, $n_{s2} = 2.00$
 $p_{s3,x} \text{ (web)} = (A_{s3} \cdot h_3/s_3)/A_c = 0.00188496$
 $h_3 = 1800.00$
 $A_{s3} = A_{stir3} \cdot n_{s3} = 0.00$
No stirrups, $n_{s3} = 2.00$

$p_{sh,y} = p_{s1,y} + p_{s2,y} + p_{s3,y} = 0.00069813$
 $p_{s1,y} \text{ (column 1)} = (A_{s1} \cdot h_1/s_1)/A_c = 0.00034907$
 $h_1 = 250.00$
 $A_{s1} = A_{stir1} \cdot n_{s1} = 157.0796$
No stirrups, $n_{s1} = 2.00$
 $p_{s2,y} \text{ (column 2)} = (A_{s2} \cdot h_2/s_2)/A_c = 0.00034907$
 $h_2 = 250.00$
 $A_{s2} = A_{stir2} \cdot n_{s2} = 157.0796$
No stirrups, $n_{s2} = 2.00$
 $p_{s3,y} \text{ (web)} = (A_{s3} \cdot h_3/s_3)/A_c = 0.00$
 $h_3 = 250.00$
 $A_{s3} = A_{stir3} \cdot n_{s3} = 157.0796$
No stirrups, $n_{s3} = 0.00$

```

Asec = 750000.00
s_1 = 150.00
s_2 = 150.00
s_3 = 200.00
fywe = 625.00
fce = 25.00
From ((5.A.5), TBDY), TBDY: cc = 0.00202463
c = confinement factor = 1.00246
y1 = 0.00140044
sh1 = 0.0044814
ft1 = 420.1317
fy1 = 350.1097
su1 = 0.00512
using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00
lo/lou,min = lb/lb,min = 0.30
su1 = 0.4*esu1_nominal ((5.5), TBDY) = 0.032
From table 5A.1, TBDY: esu1_nominal = 0.08,
For calculation of esu1_nominal and y1, sh1,ft1,fy1, it is considered
characteristic value fsy1 = fs1/1.2, from table 5.1, TBDY.
y1, sh1,ft1,fy1, are also multiplied by Min(1,1.25*(lb/lb,min)^ 2/3), from 10.3.5, ASCE 41-17.
with fs1 = fs = 350.1097
with Es1 = Es = 200000.00
y2 = 0.00140044
sh2 = 0.0044814
ft2 = 420.1317
fy2 = 350.1097
su2 = 0.00512
using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00
lo/lou,min = lb/lb,min = 0.30
su2 = 0.4*esu2_nominal ((5.5), TBDY) = 0.032
From table 5A.1, TBDY: esu2_nominal = 0.08,
For calculation of esu2_nominal and y2, sh2,ft2,fy2, it is considered
characteristic value fsy2 = fs2/1.2, from table 5.1, TBDY.
y1, sh1,ft1,fy1, are also multiplied by Min(1,1.25*(lb/lb,min)^ 2/3), from 10.3.5, ASCE 41-17.
with fs2 = fs = 350.1097
with Es2 = Es = 200000.00
yv = 0.00140044
shv = 0.0044814
ftv = 420.1317
fyv = 350.1097
suv = 0.00512
using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00
lo/lou,min = lb/lb,min = 0.30
suv = 0.4*esuv_nominal ((5.5), TBDY) = 0.032
From table 5A.1, TBDY: esuv_nominal = 0.08,
considering characteristic value fsyv = fsv/1.2, from table 5.1, TBDY
For calculation of esuv_nominal and yv, shv,ftv,fyv, it is considered
characteristic value fsyv = fsv/1.2, from table 5.1, TBDY.
y1, sh1,ft1,fy1, are also multiplied by Min(1,1.25*(lb/lb,min)^ 2/3), from 10.3.5, ASCE 41-17.
with fsv = fs = 350.1097
with Esv = Es = 200000.00
1 = Asl,ten/(b*d)*(fs1/fc) = 0.0635264
2 = Asl,com/(b*d)*(fs2/fc) = 0.0635264
v = Asl,mid/(b*d)*(fsv/fc) = 0.00
and confined core properties:
b = 2940.00
d = 178.00
d' = 12.00
fcc (5A.2, TBDY) = 25.06158
cc (5A.5, TBDY) = 0.00202463

```

$c = \text{confinement factor} = 1.00246$
 $1 = A_{sl,ten}/(b*d)*(f_{s1}/f_c) = 0.07574806$
 $2 = A_{sl,com}/(b*d)*(f_{s2}/f_c) = 0.07574806$
 $v = A_{sl,mid}/(b*d)*(f_{sv}/f_c) = 0.00$

Case/Assumption: Unconfined full section - Steel rupture
 ' satisfies Eq. (4.3)

--->

$v < v_{s,y2}$ - LHS eq.(4.5) is satisfied

--->

$\mu_u(4.9) = 0.18779572$
 $\mu_u = M_{Rc}(4.14) = 2.0658E+008$
 $u = \mu_u(4.1) = 3.0306889E-005$

Calculation of ratio l_b/l_d

Inadequate Lap Length with $l_b/l_d = 0.30$

Calculation of μ_{u1} -

Calculation of ultimate curvature μ_u according to 4.1, Biskinis/Fardis 2013:

$u = 3.0889637E-005$
 $\mu_u = 2.4003E+008$

with full section properties:

$b = 3000.00$
 $d = 208.00$
 $d' = 42.00$
 $v = 0.00176852$
 $N = 27588.841$
 $f_c = 25.00$
 $\alpha_{co}(5A.5, TBDY) = 0.002$

Final value of μ_u : $\mu_u^* = \text{shear_factor} * \text{Max}(\mu_u, \mu_{cc}) = 0.0035$

The Shear_factor is considered equal to 1 (pure moment strength)

From (5.4b), TBDY: $\mu_u = 0.0035$

$\mu_{we}((5.4c), TBDY) = \alpha_{se} * \text{sh}_{,min} * f_{ywe}/f_{ce} + \text{Min}(f_x, f_y) = 0.00$

where $f = \alpha_f * p_f * f_{fe}/f_{ce}$ is accounting for FRP contribution like EC8-part3 A.4.4.3(6)

$f_x = 0.00$

$\alpha_f = 0.00$

$b = 250.00$

$h = 3000.00$

From EC8 A.4.4.3(6), $p_f = 2t_f/bw = 0.008128$

$bw = 250.00$

effective stress from (A.35), $f_{fe} = 757.2164$

$f_y = 0.00$

$\alpha_f = 0.00$

$b = 3000.00$

$h = 250.00$

From EC8 A.4.4.3(6), $p_f = 2t_f/bw = 0.00067733$

$bw = 3000.00$

effective stress from (A.35), $f_{fe} = 954.4864$

$R = 40.00$

Effective FRP thickness, $t_f = N L * t * \cos(b_1) = 1.016$

$f_{u,f} = 1055.00$

$E_f = 64828.00$

$u_{,f} = 0.015$

$\alpha_{se}((5.4d), TBDY) = (\alpha_{se1} * A_{col1} + \alpha_{se2} * A_{col2} + \alpha_{se3} * A_{web}) / A_{sec} = 0.00$

$\alpha_{se1} = 0.00$

$sh_{,1} = 150.00$

$bo_{,1} = 190.00$

$ho_1 = 540.00$
 $bi2_1 = 655400.00$
 $ase2 = 0.00$
 $sh_2 = 150.00$
 $bo_2 = 190.00$
 $ho_2 = 540.00$
 $bi2_2 = 655400.00$
 $ase3 = 0$ (grid does not provide confinement)
 $psh,min = \text{Min}(psh,x, psh,y) = 0.00069813$
 Expression ((5.4d), TBDY) for psh,min has been multiplied by 0.3 according to 15.7.1.3 for members without earthquake detailing (90° closed stirrups)

$psh,x = ps1,x + ps2,x + ps3,x = 0.00356047$
 $ps1,x$ (column 1) = $(As1 \cdot h1 / s_1) / Ac = 0.00083776$
 $h1 = 600.00$
 $As1 = Astir1 \cdot ns1 = 157.0796$
 No stirrups, $ns1 = 2.00$
 $ps2,x$ (column 2) = $(As2 \cdot h2 / s_2) / Ac = 0.00083776$
 $h2 = 600.00$
 $As2 = Astir2 \cdot ns2 = 157.0796$
 No stirrups, $ns2 = 2.00$
 $ps3,x$ (web) = $(As3 \cdot h3 / s_3) / Ac = 0.00188496$
 $h3 = 1800.00$
 $As3 = Astir3 \cdot ns3 = 0.00$
 No stirrups, $ns3 = 2.00$

$psh,y = ps1,y + ps2,y + ps3,y = 0.00069813$
 $ps1,y$ (column 1) = $(As1 \cdot h1 / s_1) / Ac = 0.00034907$
 $h1 = 250.00$
 $As1 = Astir1 \cdot ns1 = 157.0796$
 No stirrups, $ns1 = 2.00$
 $ps2,y$ (column 2) = $(As2 \cdot h2 / s_2) / Ac = 0.00034907$
 $h2 = 250.00$
 $As2 = Astir2 \cdot ns2 = 157.0796$
 No stirrups, $ns2 = 2.00$
 $ps3,y$ (web) = $(As3 \cdot h3 / s_3) / Ac = 0.00$
 $h3 = 250.00$
 $As3 = Astir3 \cdot ns3 = 157.0796$
 No stirrups, $ns3 = 0.00$

$Asec = 750000.00$
 $s_1 = 150.00$
 $s_2 = 150.00$
 $s_3 = 200.00$
 $fywe = 625.00$
 $fce = 25.00$

From ((5.A5), TBDY), TBDY: $cc = 0.00202463$
 $c =$ confinement factor = 1.00246

$y1 = 0.00140044$
 $sh1 = 0.0044814$
 $ft1 = 420.1317$
 $fy1 = 350.1097$
 $su1 = 0.00512$

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
 and also multiplied by the shear_factor according to 15.7.1.4, with
 Shear_factor = 1.00

$lo/lo_{u,min} = lb/ld = 0.30$

$su1 = 0.4 \cdot esu1_nominal$ ((5.5), TBDY) = 0.032

From table 5A.1, TBDY: $esu1_nominal = 0.08$,

For calculation of $esu1_nominal$ and $y1, sh1, ft1, fy1$, it is considered
 characteristic value $fsy1 = fs1 / 1.2$, from table 5.1, TBDY.

$y1, sh1, ft1, fy1$, are also multiplied by $\text{Min}(1, 1.25 \cdot (lb/ld)^{2/3})$, from 10.3.5, ASCE 41-17.

with $fs1 = fs = 350.1097$

with $Es1 = Es = 200000.00$

$y2 = 0.00140044$
 $sh2 = 0.0044814$
 $ft2 = 420.1317$

```

fy2 = 350.1097
su2 = 0.00512
    using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
    and also multiplied by the shear_factor according to 15.7.1.4, with
    Shear_factor = 1.00
    lo/lo,min = lb/lb,min = 0.30
    su2 = 0.4*esu2_nominal ((5.5), TBDY) = 0.032
    From table 5A.1, TBDY: esu2_nominal = 0.08,
    For calculation of esu2_nominal and y2, sh2,ft2,fy2, it is considered
    characteristic value fsy2 = fs2/1.2, from table 5.1, TBDY.
    y1, sh1,ft1,fy1, are also multiplied by Min(1,1.25*(lb/ld)^ 2/3), from 10.3.5, ASCE 41-17.
    with fs2 = fs = 350.1097
    with Es2 = Es = 200000.00
    yv = 0.00140044
    shv = 0.0044814
    ftv = 420.1317
    fyv = 350.1097
    suv = 0.00512
    using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
    and also multiplied by the shear_factor according to 15.7.1.4, with
    Shear_factor = 1.00
    lo/lo,min = lb/ld = 0.30
    suv = 0.4*esuv_nominal ((5.5), TBDY) = 0.032
    From table 5A.1, TBDY: esuv_nominal = 0.08,
    considering characteristic value fsyv = fsv/1.2, from table 5.1, TBDY
    For calculation of esuv_nominal and yv, shv,ftv,fyv, it is considered
    characteristic value fsyv = fsv/1.2, from table 5.1, TBDY.
    y1, sh1,ft1,fy1, are also multiplied by Min(1,1.25*(lb/ld)^ 2/3), from 10.3.5, ASCE 41-17.
    with fsv = fs = 350.1097
    with Esv = Es = 200000.00
    1 = Asl,ten/(b*d)*(fs1/fc) = 0.0635264
    2 = Asl,com/(b*d)*(fs2/fc) = 0.0635264
    v = Asl,mid/(b*d)*(fsv/fc) = 0.03609935
and confined core properties:
b = 2940.00
d = 178.00
d' = 12.00
fcc (5A.2, TBDY) = 25.06158
cc (5A.5, TBDY) = 0.00202463
    c = confinement factor = 1.00246
    1 = Asl,ten/(b*d)*(fs1/fc) = 0.07574806
    2 = Asl,com/(b*d)*(fs2/fc) = 0.07574806
    v = Asl,mid/(b*d)*(fsv/fc) = 0.0430444
Case/Assumption: Unconfined full section - Steel rupture
' satisfies Eq. (4.3)
--->
v < vs,y2 - LHS eq.(4.5) is satisfied
--->
su (4.9) = 0.20311835
Mu = MRc (4.14) = 2.4003E+008
u = su (4.1) = 3.0889637E-005

```

Calculation of ratio lb/ld

Inadequate Lap Length with lb/ld = 0.30

Calculation of Mu2+

Calculation of ultimate curvature u according to 4.1, Biskinis/Fardis 2013:

u = 3.0306889E-005

Mu = 2.0658E+008

with full section properties:

$$b = 3000.00$$

$$d = 208.00$$

$$d' = 42.00$$

$$v = 0.00176852$$

$$N = 27588.841$$

$$f_c = 25.00$$

$$\alpha (5A.5, \text{TB DY}) = 0.002$$

$$\text{Final value of } \alpha: \alpha = \text{shear_factor} * \text{Max}(\alpha_c, \alpha_c) = 0.0035$$

The Shear_factor is considered equal to 1 (pure moment strength)

$$\text{From (5.4b), TB DY: } \alpha_c = 0.0035$$

$$\alpha_{ve} ((5.4c), \text{TB DY}) = \alpha_{se} * \text{sh}_{\min} * f_{yve} / f_{ce} + \text{Min}(\alpha_{fx}, \alpha_{fy}) = 0.00$$

where $\alpha_{fx} = \alpha_{fy} * p_f * f_{fe} / f_{ce}$ is accounting for FRP contribution like EC8-part3 A.4.4.3(6)

$$\alpha_{fx} = 0.00$$

$$\alpha_{fy} = 0.00$$

$$b = 250.00$$

$$h = 3000.00$$

$$\text{From EC8 A4.4.3(6), } p_f = 2t_f / b_w = 0.008128$$

$$b_w = 250.00$$

$$\text{effective stress from (A.35), } f_{fe} = 757.2164$$

$$\alpha_{fy} = 0.00$$

$$\alpha_{fx} = 0.00$$

$$b = 3000.00$$

$$h = 250.00$$

$$\text{From EC8 A4.4.3(6), } p_f = 2t_f / b_w = 0.00067733$$

$$b_w = 3000.00$$

$$\text{effective stress from (A.35), } f_{fe} = 954.4864$$

$$R = 40.00$$

$$\text{Effective FRP thickness, } t_f = N L * t * \cos(\beta_1) = 1.016$$

$$f_{u,f} = 1055.00$$

$$E_f = 64828.00$$

$$\alpha_{u,f} = 0.015$$

$$\alpha_{se} ((5.4d), \text{TB DY}) = (\alpha_{se1} * A_{col1} + \alpha_{se2} * A_{col2} + \alpha_{se3} * A_{web}) / A_{sec} = 0.00$$

$$\alpha_{se1} = 0.00$$

$$\text{sh}_1 = 150.00$$

$$\text{bo}_1 = 190.00$$

$$\text{ho}_1 = 540.00$$

$$\text{bi2}_1 = 655400.00$$

$$\alpha_{se2} = 0.00$$

$$\text{sh}_2 = 150.00$$

$$\text{bo}_2 = 190.00$$

$$\text{ho}_2 = 540.00$$

$$\text{bi2}_2 = 655400.00$$

$$\alpha_{se3} = 0 \text{ (grid does not provide confinement)}$$

$$p_{sh,\min} = \text{Min}(p_{sh,x}, p_{sh,y}) = 0.00069813$$

Expression ((5.4d), TB DY) for $p_{sh,\min}$ has been multiplied by 0.3 according to 15.7.1.3 for members without earthquake detailing (90° closed stirrups)

$$p_{sh,x} = p_{s1,x} + p_{s2,x} + p_{s3,x} = 0.00356047$$

$$p_{s1,x} \text{ (column 1)} = (A_{s1} * h_1 / s_1) / A_c = 0.00083776$$

$$h_1 = 600.00$$

$$A_{s1} = A_{stir1} * n_{s1} = 157.0796$$

$$\text{No stirrups, } n_{s1} = 2.00$$

$$p_{s2,x} \text{ (column 2)} = (A_{s2} * h_2 / s_2) / A_c = 0.00083776$$

$$h_2 = 600.00$$

$$A_{s2} = A_{stir2} * n_{s2} = 157.0796$$

$$\text{No stirrups, } n_{s2} = 2.00$$

$$p_{s3,x} \text{ (web)} = (A_{s3} * h_3 / s_3) / A_c = 0.00188496$$

$$h_3 = 1800.00$$

$$A_{s3} = A_{stir3} * n_{s3} = 0.00$$

$$\text{No stirrups, } n_{s3} = 2.00$$

$$p_{sh,y} = p_{s1,y} + p_{s2,y} + p_{s3,y} = 0.00069813$$

$$p_{s1,y} \text{ (column 1)} = (A_{s1} * h_1 / s_1) / A_c = 0.00034907$$

$h1 = 250.00$
 $As1 = Astir1 * ns1 = 157.0796$
 No stirups, $ns1 = 2.00$
 $ps2,y \text{ (column 2)} = (As2 * h2 / s_2) / Ac = 0.00034907$
 $h2 = 250.00$
 $As2 = Astir2 * ns2 = 157.0796$
 No stirups, $ns2 = 2.00$
 $ps3,y \text{ (web)} = (As3 * h3 / s_3) / Ac = 0.00$
 $h3 = 250.00$
 $As3 = Astir3 * ns3 = 157.0796$
 No stirups, $ns3 = 0.00$

$Asec = 750000.00$
 $s_1 = 150.00$
 $s_2 = 150.00$
 $s_3 = 200.00$
 $fywe = 625.00$
 $fce = 25.00$
 From ((5.A5), TBDY), TBDY: $cc = 0.00202463$
 $c = \text{confinement factor} = 1.00246$
 $y1 = 0.00140044$
 $sh1 = 0.0044814$
 $ft1 = 420.1317$
 $fy1 = 350.1097$
 $su1 = 0.00512$
 using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
 and also multiplied by the shear_factor according to 15.7.1.4, with
 $Shear_factor = 1.00$
 $lo/lou,min = lb/ld = 0.30$
 $su1 = 0.4 * esu1_nominal \text{ ((5.5), TBDY)} = 0.032$
 From table 5A.1, TBDY: $esu1_nominal = 0.08$,
 For calculation of $esu1_nominal$ and $y1, sh1, ft1, fy1$, it is considered
 characteristic value $fsy1 = fs1 / 1.2$, from table 5.1, TBDY.
 $y1, sh1, ft1, fy1$, are also multiplied by $\text{Min}(1, 1.25 * (lb/ld)^{2/3})$, from 10.3.5, ASCE 41-17.
 with $fs1 = fs = 350.1097$
 with $Es1 = Es = 200000.00$
 $y2 = 0.00140044$
 $sh2 = 0.0044814$
 $ft2 = 420.1317$
 $fy2 = 350.1097$
 $su2 = 0.00512$
 using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
 and also multiplied by the shear_factor according to 15.7.1.4, with
 $Shear_factor = 1.00$
 $lo/lou,min = lb/lb,min = 0.30$
 $su2 = 0.4 * esu2_nominal \text{ ((5.5), TBDY)} = 0.032$
 From table 5A.1, TBDY: $esu2_nominal = 0.08$,
 For calculation of $esu2_nominal$ and $y2, sh2, ft2, fy2$, it is considered
 characteristic value $fsy2 = fs2 / 1.2$, from table 5.1, TBDY.
 $y1, sh1, ft1, fy1$, are also multiplied by $\text{Min}(1, 1.25 * (lb/ld)^{2/3})$, from 10.3.5, ASCE 41-17.
 with $fs2 = fs = 350.1097$
 with $Es2 = Es = 200000.00$
 $yv = 0.00140044$
 $shv = 0.0044814$
 $ftv = 420.1317$
 $fyv = 350.1097$
 $suv = 0.00512$
 using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
 and also multiplied by the shear_factor according to 15.7.1.4, with
 $Shear_factor = 1.00$
 $lo/lou,min = lb/ld = 0.30$
 $suv = 0.4 * esuv_nominal \text{ ((5.5), TBDY)} = 0.032$
 From table 5A.1, TBDY: $esuv_nominal = 0.08$,
 considering characteristic value $fsyv = fsv / 1.2$, from table 5.1, TBDY
 For calculation of $esuv_nominal$ and yv, shv, ftv, fyv , it is considered
 characteristic value $fsyv = fsv / 1.2$, from table 5.1, TBDY.
 $y1, sh1, ft1, fy1$, are also multiplied by $\text{Min}(1, 1.25 * (lb/ld)^{2/3})$, from 10.3.5, ASCE 41-17.

with $f_{sv} = f_s = 350.1097$
 with $E_{sv} = E_s = 200000.00$
 $1 = A_{sl,ten}/(b*d)*(f_{s1}/f_c) = 0.0635264$
 $2 = A_{sl,com}/(b*d)*(f_{s2}/f_c) = 0.0635264$
 $v = A_{sl,mid}/(b*d)*(f_{sv}/f_c) = 0.00$
 and confined core properties:
 $b = 2940.00$
 $d = 178.00$
 $d' = 12.00$
 $f_{cc} (5A.2, TBDY) = 25.06158$
 $cc (5A.5, TBDY) = 0.00202463$
 $c = \text{confinement factor} = 1.00246$
 $1 = A_{sl,ten}/(b*d)*(f_{s1}/f_c) = 0.07574806$
 $2 = A_{sl,com}/(b*d)*(f_{s2}/f_c) = 0.07574806$
 $v = A_{sl,mid}/(b*d)*(f_{sv}/f_c) = 0.00$
 Case/Assumption: Unconfined full section - Steel rupture
 ' satisfies Eq. (4.3)

--->
 $v < v_{s,y2}$ - LHS eq.(4.5) is satisfied
 --->
 $su (4.9) = 0.18779572$
 $Mu = MRc (4.14) = 2.0658E+008$
 $u = su (4.1) = 3.0306889E-005$

Calculation of ratio l_b/l_d

Inadequate Lap Length with $l_b/l_d = 0.30$

Calculation of Mu_2 -

Calculation of ultimate curvature u according to 4.1, Biskinis/Fardis 2013:
 $u = 3.0889637E-005$
 $Mu = 2.4003E+008$

with full section properties:

$b = 3000.00$
 $d = 208.00$
 $d' = 42.00$
 $v = 0.00176852$
 $N = 27588.841$
 $f_c = 25.00$
 $co (5A.5, TBDY) = 0.002$
 Final value of cu : $cu^* = \text{shear_factor} * \text{Max}(cu, cc) = 0.0035$
 The Shear_factor is considered equal to 1 (pure moment strength)
 From (5.4b), TBDY: $cu = 0.0035$
 $w_e ((5.4c), TBDY) = a_{se} * sh_{,min} * f_{ywe}/f_{ce} + \text{Min}(f_x, f_y) = 0.00$
 where $f = a_f * p_f * f_{fe}/f_{ce}$ is accounting for FRP contribution like EC8-part3 A.4.4.3(6)

$f_x = 0.00$
 $a_f = 0.00$
 $b = 250.00$
 $h = 3000.00$
 From EC8 A.4.4.3(6), $p_f = 2t_f/bw = 0.008128$
 $bw = 250.00$
 effective stress from (A.35), $f_{f,e} = 757.2164$

$f_y = 0.00$
 $a_f = 0.00$
 $b = 3000.00$
 $h = 250.00$
 From EC8 A.4.4.3(6), $p_f = 2t_f/bw = 0.00067733$
 $bw = 3000.00$

effective stress from (A.35), $f_{f,e} = 954.4864$

$R = 40.00$

Effective FRP thickness, $t_f = NL \cdot t \cdot \cos(b_1) = 1.016$

$f_{u,f} = 1055.00$

$E_f = 64828.00$

$u_{f,f} = 0.015$

$a_{se}((5.4d), TBDY) = (a_{se1} \cdot A_{col1} + a_{se2} \cdot A_{col2} + a_{se3} \cdot A_{web}) / A_{sec} = 0.00$

$a_{se1} = 0.00$

$sh_1 = 150.00$

$bo_1 = 190.00$

$ho_1 = 540.00$

$bi2_1 = 655400.00$

$a_{se2} = 0.00$

$sh_2 = 150.00$

$bo_2 = 190.00$

$ho_2 = 540.00$

$bi2_2 = 655400.00$

$a_{se3} = 0$ (grid does not provide confinement)

$p_{sh,min} = \min(p_{sh,x}, p_{sh,y}) = 0.00069813$

Expression ((5.4d), TBDY) for $p_{sh,min}$ has been multiplied by 0.3 according to 15.7.1.3 for members without earthquake detailing (90° closed stirrups)

$p_{sh,x} = p_{s1,x} + p_{s2,x} + p_{s3,x} = 0.00356047$

$p_{s1,x}$ (column 1) = $(A_{s1} \cdot h_1 / s_1) / A_c = 0.00083776$

$h_1 = 600.00$

$A_{s1} = A_{stir1} \cdot n_{s1} = 157.0796$

No stirrups, $n_{s1} = 2.00$

$p_{s2,x}$ (column 2) = $(A_{s2} \cdot h_2 / s_2) / A_c = 0.00083776$

$h_2 = 600.00$

$A_{s2} = A_{stir2} \cdot n_{s2} = 157.0796$

No stirrups, $n_{s2} = 2.00$

$p_{s3,x}$ (web) = $(A_{s3} \cdot h_3 / s_3) / A_c = 0.00188496$

$h_3 = 1800.00$

$A_{s3} = A_{stir3} \cdot n_{s3} = 0.00$

No stirrups, $n_{s3} = 2.00$

$p_{sh,y} = p_{s1,y} + p_{s2,y} + p_{s3,y} = 0.00069813$

$p_{s1,y}$ (column 1) = $(A_{s1} \cdot h_1 / s_1) / A_c = 0.00034907$

$h_1 = 250.00$

$A_{s1} = A_{stir1} \cdot n_{s1} = 157.0796$

No stirrups, $n_{s1} = 2.00$

$p_{s2,y}$ (column 2) = $(A_{s2} \cdot h_2 / s_2) / A_c = 0.00034907$

$h_2 = 250.00$

$A_{s2} = A_{stir2} \cdot n_{s2} = 157.0796$

No stirrups, $n_{s2} = 2.00$

$p_{s3,y}$ (web) = $(A_{s3} \cdot h_3 / s_3) / A_c = 0.00$

$h_3 = 250.00$

$A_{s3} = A_{stir3} \cdot n_{s3} = 157.0796$

No stirrups, $n_{s3} = 0.00$

$A_{sec} = 750000.00$

$s_1 = 150.00$

$s_2 = 150.00$

$s_3 = 200.00$

$f_{ywe} = 625.00$

$f_{ce} = 25.00$

From ((5.A5), TBDY), TBDY: $cc = 0.00202463$

c = confinement factor = 1.00246

$y_1 = 0.00140044$

$sh_1 = 0.0044814$

$ft_1 = 420.1317$

$fy_1 = 350.1097$

$su_1 = 0.00512$

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00

```

lo/lou,min = lb/d = 0.30
su1 = 0.4*esu1_nominal ((5.5), TBDY) = 0.032
From table 5A.1, TBDY: esu1_nominal = 0.08,
For calculation of esu1_nominal and y1, sh1,ft1,fy1, it is considered
characteristic value fsy1 = fs1/1.2, from table 5.1, TBDY.
y1, sh1,ft1,fy1, are also multiplied by Min(1,1.25*(lb/d)^ 2/3), from 10.3.5, ASCE 41-17.
with fs1 = fs = 350.1097
with Es1 = Es = 200000.00
y2 = 0.00140044
sh2 = 0.0044814
ft2 = 420.1317
fy2 = 350.1097
su2 = 0.00512
using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00
lo/lou,min = lb/lb,min = 0.30
su2 = 0.4*esu2_nominal ((5.5), TBDY) = 0.032
From table 5A.1, TBDY: esu2_nominal = 0.08,
For calculation of esu2_nominal and y2, sh2,ft2,fy2, it is considered
characteristic value fsy2 = fs2/1.2, from table 5.1, TBDY.
y1, sh1,ft1,fy1, are also multiplied by Min(1,1.25*(lb/d)^ 2/3), from 10.3.5, ASCE 41-17.
with fs2 = fs = 350.1097
with Es2 = Es = 200000.00
yv = 0.00140044
shv = 0.0044814
ftv = 420.1317
fyv = 350.1097
suv = 0.00512
using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00
lo/lou,min = lb/d = 0.30
suv = 0.4*esuv_nominal ((5.5), TBDY) = 0.032
From table 5A.1, TBDY: esuv_nominal = 0.08,
considering characteristic value fsyv = fsv/1.2, from table 5.1, TBDY
For calculation of esuv_nominal and yv, shv,ftv,fyv, it is considered
characteristic value fsyv = fsv/1.2, from table 5.1, TBDY.
y1, sh1,ft1,fy1, are also multiplied by Min(1,1.25*(lb/d)^ 2/3), from 10.3.5, ASCE 41-17.
with fsv = fs = 350.1097
with Esv = Es = 200000.00
1 = Asl,ten/(b*d)*(fs1/fc) = 0.0635264
2 = Asl,com/(b*d)*(fs2/fc) = 0.0635264
v = Asl,mid/(b*d)*(fsv/fc) = 0.03609935
and confined core properties:
b = 2940.00
d = 178.00
d' = 12.00
fcc (5A.2, TBDY) = 25.06158
cc (5A.5, TBDY) = 0.00202463
c = confinement factor = 1.00246
1 = Asl,ten/(b*d)*(fs1/fc) = 0.07574806
2 = Asl,com/(b*d)*(fs2/fc) = 0.07574806
v = Asl,mid/(b*d)*(fsv/fc) = 0.0430444
Case/Assumption: Unconfined full section - Steel rupture
' satisfies Eq. (4.3)
--->
v < vs,y2 - LHS eq.(4.5) is satisfied
--->
su (4.9) = 0.20311835
Mu = MRc (4.14) = 2.4003E+008
u = su (4.1) = 3.0889637E-005

```

Calculation of ratio lb/d

Inadequate Lap Length with lb/d = 0.30

Calculation of Shear Strength $V_r = \text{Min}(V_{r1}, V_{r2}) = 1.0244\text{E}+006$

Calculation of Shear Strength at edge 1, $V_{r1} = 1.0244\text{E}+006$

From (22.5.1.1) and 11.5.4.3, ACI 318-14: $V_{r1} = V_n < 0.83 \cdot f_c' \cdot h \cdot d$

NOTE: In expression (22.5.1.1) ' V_w ' is replaced by ' $V_w + f \cdot V_f$ ' where V_f is the contribution of FRPs (11.3), ACI 440).

From Table (11.5.4.6(d-e)), ACI 318-14: $V_c = 815517.768$

$\mu_u / \mu_u - l_w / 2 = 0.00 \leq 0$

= 1 (normal-weight concrete)

$f_c' = 25.00$, but $f_c'^{0.5} \leq 8.3$ MPa (22.5.3.1, ACI 318-14)

$h = 3000.00$

$d = 200.00$

$l_w = 250.00$

$\mu_u = 3.7289358\text{E}-011$

$V_u = 1.7354940\text{E}-029$

$N_u = 27588.841$

From (11.5.4.8), ACI 318-14: $V_s = V_{s1} + V_{s2} + V_{s3} = 104719.755$

$V_{s1} = 52359.878$ is calculated for pseudo-Column 1, with:

$d = 200.00$

$A_v = 157079.633$

$s = 150.00$

$f_y = 500.00$

V_{s1} has been multiplied by $2(1-s/d)$ ($s > d/2$, according to ASCE 41-17,10.3.4)

$2(1-s/d) = 0.50$

$V_{s2} = 52359.878$ is calculated for pseudo-Column 2, with:

$d = 200.00$

$A_v = 157079.633$

$s = 150.00$

$f_y = 500.00$

V_{s2} has been multiplied by $2(1-s/d)$ ($s > d/2$, according to ASCE 41-17,10.3.4)

$2(1-s/d) = 0.50$

$V_{s3} = 0.00$ is calculated for web, with:

$d = 200.00$

$A_v = 0.00$

$s = 200.00$

$f_y = 500.00$

V_{s3} has been multiplied by $2(1-s/d)$ ($s > d/2$, according to ASCE 41-17,10.3.4)

$2(1-s/d) = 0.00$

V_f ((11-3)-(11.4), ACI 440) = 109599.773

$f = 0.95$, for fully-wrapped sections

$w_f / s_f = 1$ (FRP strips adjacent to one another).

In (11.3) $\sin + \cos$ is replaced with $(\cot + \cot a) \sin a$ which is more a generalised expression,

where a is the angle of the crack direction (see KANEPE).

This later relation, considered as a function $V_f(\theta)$, is implemented for every different fiber orientation a_i , as well as for 2 crack directions, $\theta = 45^\circ$ and $\theta = -45^\circ$ to take into consideration the cyclic seismic loading.

orientation 1: $\theta_1 = \theta_1 + 90^\circ = 90.00$

$V_f = \text{Min}(|V_f(45, \theta_1)|, |V_f(-45, \theta_1)|)$, with:

total thickness per orientation, $t_{f1} = N_L \cdot t / N_{oDir} = 1.016$

$d_{fv} = d$ (figure 11.2, ACI 440) = 208.00

f_{fe} ((11-5), ACI 440) = 259.312

$E_f = 64828.00$

$f_e = 0.004$, from (11.6a), ACI 440

with $f_u = 0.01$

From (11-11), ACI 440: $V_s + V_f \leq 1.9929\text{E}+006$

$b_w = 3000.00$

Calculation of Shear Strength at edge 2, $V_{r2} = 1.0244\text{E}+006$

From (22.5.1.1) and 11.5.4.3, ACI 318-14: $V_{r2} = V_n < 0.83 \cdot f_c' \cdot h \cdot d$

NOTE: In expression (22.5.1.1) ' V_w ' is replaced by ' $V_w + f \cdot V_f$ ' where V_f is the contribution of FRPs (11.3), ACI 440).

From Table (11.5.4.6(d-e)), ACI 318-14: $V_c = 815517.768$

$M_u/V_u - l_w/2 = 0.00 \leq 0$

$= 1$ (normal-weight concrete)

$f'_c = 25.00$, but $f_c^{0.5} \leq 8.3$ MPa (22.5.3.1, ACI 318-14)

$h = 3000.00$

$d = 200.00$

$l_w = 250.00$

$M_u = 3.7289358E-011$

$V_u = 1.7354940E-029$

$N_u = 27588.841$

From (11.5.4.8), ACI 318-14: $V_s = V_{s1} + V_{s2} + V_{s3} = 104719.755$

$V_{s1} = 52359.878$ is calculated for pseudo-Column 1, with:

$d = 200.00$

$A_v = 157079.633$

$s = 150.00$

$f_y = 500.00$

V_{s1} has been multiplied by $2(1-s/d)$ ($s > d/2$, according to ASCE 41-17,10.3.4)

$2(1-s/d) = 0.50$

$V_{s2} = 52359.878$ is calculated for pseudo-Column 2, with:

$d = 200.00$

$A_v = 157079.633$

$s = 150.00$

$f_y = 500.00$

V_{s2} has been multiplied by $2(1-s/d)$ ($s > d/2$, according to ASCE 41-17,10.3.4)

$2(1-s/d) = 0.50$

$V_{s3} = 0.00$ is calculated for web, with:

$d = 200.00$

$A_v = 0.00$

$s = 200.00$

$f_y = 500.00$

V_{s3} has been multiplied by $2(1-s/d)$ ($s > d/2$, according to ASCE 41-17,10.3.4)

$2(1-s/d) = 0.00$

V_f ((11-3)-(11.4), ACI 440) = 109599.773

$f = 0.95$, for fully-wrapped sections

$w_f/s_f = 1$ (FRP strips adjacent to one another).

In (11.3) $\sin + \cos$ is replaced with $(\cot + \cot a)\sin a$ which is more a generalised expression,

where a is the angle of the crack direction (see KANEPE).

This later relation, considered as a function $V_f(\theta, a)$, is implemented for every different fiber orientation a_i , as well as for 2 crack directions, $\theta = 45^\circ$ and $\theta = -45^\circ$ to take into consideration the cyclic seismic loading.

orientation 1: $\theta = \theta_1 + 90^\circ = 90.00$

$V_f = \text{Min}(|V_f(45, \theta_1)|, |V_f(-45, a_1)|)$, with:

total thickness per orientation, $t_{f1} = N_L \cdot t / N_{\text{Dir}} = 1.016$

$d_{fv} = d$ (figure 11.2, ACI 440) = 208.00

f_{fe} ((11-5), ACI 440) = 259.312

$E_f = 64828.00$

$f_e = 0.004$, from (11.6a), ACI 440

with $f_u = 0.01$

From (11-11), ACI 440: $V_s + V_f \leq 1.9929E+006$

$b_w = 3000.00$

End Of Calculation of Shear Capacity ratio for element: wall W1 of floor 1

At local axis: 2

Start Of Calculation of Chord Rotation Capacity for element: wall W1 of floor 1

At local axis: 3

Integration Section: (a)

Section Type: rcrcws

Constant Properties

Knowledge Factor, $\gamma = 1.00$

According to 10.7.2.3, ASCE 41-17, shear walls with
transverse reinforcement percentage, $\rho_n < 0.0015$

are considered Force-Controlled and lower-bound strengths are used according to 7.5.1.3, ASCE 41-17
 $n = 0.00069813$

with $n = ps1 + ps2 + ps3$, being the shear reinf. ratio in a plane perpendicular to the shear axis 2
(pseudo-col.1 $ps1 = As1*b1/s1 = (As1*h1/s1) / Ac = 0.00034907$
 $h1 = 250.00$
 $s1 = 150.00$
total area of hoops perpendicular to shear axis, $As1 = 157.0796$
(pseudo-col.2 $ps2 = As2*b2/s2 = (As2*h2/s2) / Ac = 0.00034907$
 $h2 = 250.00$
 $s2 = 150.00$
total area of hoops perpendicular to shear axis, $As2 = 157.0796$
(grid $ps3 = As3*b3/s3 = (As3*h3/s3) / Ac = 0.00$
 $h3 = 250.00$
 $s3 = 200.00$
total area of hoops perpendicular to shear axis, $As3 = 0.00$
total section area, $Ac = 750000.00$

Consequently:

New material of Secondary Member: Concrete Strength, $fc = fc_lower_bound = 25.00$
New material of Secondary Member: Steel Strength, $fs = fs_lower_bound = 500.00$
Concrete Elasticity, $Ec = 26999.444$
Steel Elasticity, $Es = 200000.00$
Total Height, $H_{tot} = 3000.00$
Edges Width, $W_{edg} = 250.00$
Edges Height, $H_{edg} = 600.00$
Web Width, $W_{web} = 250.00$
Cover Thickness, $c = 25.00$
Element Length, $L = 3000.00$
Secondary Member
Smooth Bars
Ductile Steel
Without Detailing for Earthquake Resistance (including stirrups not closed at 135°)
Longitudinal Bars With Ends Lapped Starting at the End Sections
Inadequate Lap Length with $lb/ld = 0.30$
FRP Wrapping Data
Type: Carbon
Cured laminate properties (design values)
Thickness, $t = 1.016$
Tensile Strength, $ffu = 1055.00$
Tensile Modulus, $E_f = 64828.00$
Elongation, $efu = 0.01$
Number of directions, $NoDir = 1$
Fiber orientations, $bi: 0.00^\circ$
Number of layers, $NL = 1$
Radius of rounding corners, $R = 40.00$

Stepwise Properties

Bending Moment, $M = -3.8068487E-012$
Shear Force, $V2 = -2.0402016E-014$
Shear Force, $V3 = -32914.791$
Axial Force, $F = -33005.924$
Longitudinal Reinforcement Area Distribution (in 2 divisions)
-Tension: $As_t = 0.00$
-Compression: $As_c = 7269.645$
Longitudinal Reinforcement Area Distribution (in 3 divisions)
-Tension: $As_{t,ten} = 2830.575$
-Compression: $As_{c,com} = 2830.575$
-Middle: $As_{l,mid} = 1608.495$
Mean Diameter of Tension Reinforcement, $DbL = 16.46154$

New component: From table 7-7, ASCE 41_17: Final chord rotation Capacity $u_R = 1.0^* u = 0.00318826$

$$u = y + p = 0.00318826$$

- Calculation of y -

$$y = (M_y \cdot I_p) / (E I)_{\text{Eff}} = 0.00118826 \text{ ((10-5), ASCE 41-17)}$$

$$M_y = 1.8276 \text{E}+008$$

$$(E I)_{\text{Eff}} = 0.35 \cdot E_c \cdot I \text{ (table 10-5)}$$

$$E_c \cdot I = 1.0547 \text{E}+014$$

$$I_p = 0.5 \cdot d = 0.5 \cdot (0.8 \cdot h) = 240.00$$

Calculation of Yielding Moment M_y

Calculation of y and M_y according to Annex 7 -

$$y = \text{Min}(y_{\text{ten}}, y_{\text{com}})$$

$$y_{\text{ten}} = 8.9802449 \text{E}-006$$

$$\text{with } ((10.1), \text{ASCE 41-17}) \quad f_y = \text{Min}(f_y, 1.25 \cdot f_y \cdot (I_b / I_d)^{2/3}) = 280.0878$$

$$d = 208.00$$

$$y = 0.25025656$$

$$A = 0.01183892$$

$$B = 0.00719009$$

$$\text{with } p_t = 0.00453618$$

$$p_c = 0.00453618$$

$$p_v = 0.00257772$$

$$N = 33005.924$$

$$b = 3000.00$$

$$" = 0.20192308$$

$$y_{\text{comp}} = 3.2313175 \text{E}-005$$

$$\text{with } f_c' (12.3, \text{ACI 440}) = 25.002$$

$$f_c = 25.00$$

$$f_l = 0.17503396$$

$$b = 3000.00$$

$$h = 250.00$$

$$A_g = 750000.00$$

$$\text{From } (12.9), \text{ACI 440: } k_a = 0.0036426$$

$$g = p_t + p_c + p_v = 0.01165007$$

$$r_c = 40.00$$

$$A_e / A_c = 0.52453487$$

$$\text{Effective FRP thickness, } t_f = N L \cdot t \cdot \cos(b_1) = 1.016$$

$$\text{effective strain from (12.5) and (12.12), } \epsilon_{fe} = 0.004$$

$$f_u = 0.01$$

$$E_f = 64828.00$$

$$E_c = 26999.444$$

$$y = 0.24799872$$

$$A = 0.01149141$$

$$B = 0.00700125$$

$$\text{with } E_s = 200000.00$$

Calculation of ratio I_b / I_d

Inadequate Lap Length with $I_b / I_d = 0.30$

- Calculation of p -

Considering wall controlled by flexure (shear control ratio ≤ 1),

from table 10-19: $p = 0.002$

with:

- Condition i (shear wall and wall segments)

$$-(A_s - A_s') \cdot f_y + P / (t_w \cdot I_w \cdot f_c') = -0.19209689$$

$$A_s = 0.00$$

$$A_s' = 7269.645$$

$f_y = 500.00$

$P = 33005.924$

$t_w = 3000.00$

$l_w = 250.00$

$f_c = 25.00$

- $V/(t_w \cdot l_w \cdot f_c^{0.5}) = 6.5518667E-020$, NOTE: units in lb & in

- Confined Boundary: No

Boundary hoops spacing exceed $8d_b$ ($s_1 > 8 \cdot d_b$ or $s_2 > 8 \cdot d_b$)

Boundary Trans. Reinf. does not exceed 50% of ACI 318 provision ($V_{w1} + V_{w2} > 0.50 \cdot (V - V_c - V_{w3})$)

With

Boundary Element 1:

$V_{w1} = 104719.755$

$s_1 = 150.00$

Boundary Element 2:

$V_{w2} = 104719.755$

$s_2 = 150.00$

Grid Shear Force, $V_{w3} = 0.00$

Concrete Shear Force, $V_c = 816601.185$

(The variables above have already been given in Shear control ratio calculation)

Mean diameter of all bars, $d_b = 17.33333$

Design Shear Force, $V = 2.0402016E-014$

End Of Calculation of Chord Rotation Capacity for element: wall W1 of floor 1

At local axis: 3

Integration Section: (a)

Calculation No. 5

wall W1, Floor 1


Limit State: Operational Level (data interpolation between analysis steps 1 and 2)

Analysis: Uniform +X

Check: Shear capacity V_{Rd}

Edge: End

Local Axis: (2)



Start Of Calculation of Shear Capacity for element: wall W1 of floor 1

At local axis: 2

Integration Section: (d)

Section Type: rcwrs

Constant Properties

Knowledge Factor, $\phi = 1.00$

Member Shear Force is generally considered as Force-Controlled Action according to Table C7-1, ASCE 41-17.

Lower-bound strengths are used for Force-Controlled Actions according to 7.5.1.3, ASCE 41-17

Consequently:

New material of Secondary Member: Concrete Strength, $f_c = f_{c_lower_bound} = 25.00$

New material of Secondary Member: Steel Strength, $f_s = f_{s_lower_bound} = 500.00$

Concrete Elasticity, $E_c = 26999.444$

Steel Elasticity, $E_s = 200000.00$

Total Height, $H_{tot} = 3000.00$

Edges Width, $W_{edg} = 250.00$

Edges Height, $H_{edg} = 600.00$

Web Width, $W_{web} = 250.00$

Cover Thickness, $c = 25.00$

Element Length, $L = 3000.00$

Secondary Member

Smooth Bars

Ductile Steel

Without Detailing for Earthquake Resistance (including stirrups not closed at 135°)

Longitudinal Bars With Ends Lapped Starting at the End Sections

Inadequate Lap Length with $l_o/l_{ou,min} = l_b/l_d = 0.30$

FRP Wrapping Data

Type: Carbon

Cured laminate properties (design values)

Thickness, $t = 1.016$

Tensile Strength, $f_{fu} = 1055.00$

Tensile Modulus, $E_f = 64828.00$

Elongation, $\epsilon_{fu} = 0.01$

Number of directions, $N_{oDir} = 1$

Fiber orientations, $b_i: 0.00^\circ$

Number of layers, $N_L = 1$

Radius of rounding corners, $R = 40.00$

Stepwise Properties

EDGE -A-

Bending Moment, $M_a = -3.8068487E-012$

Shear Force, $V_a = -2.0402016E-014$

EDGE -B-

Bending Moment, $M_b = -6.0084169E-011$

Shear Force, $V_b = 2.0402016E-014$

BOTH EDGES

Axial Force, $F = -33005.924$

Longitudinal Reinforcement Area Distribution (in 2 divisions)

-Tension: $A_{slt} = 0.00$

-Compression: $A_{slc} = 7269.645$

Longitudinal Reinforcement Area Distribution (in 3 divisions)

-Tension: $A_{sl,ten} = 2830.575$

-Compression: $A_{sl,com} = 2830.575$

-Middle: $A_{sl,mid} = 1608.495$

Mean Diameter of Tension Reinforcement, $Db_{L,ten} = 16.46154$

New component: From table 7-7, ASCE 41_17: Final Shear Capacity $V_R = 1.0 \cdot V_n = 385903.344$

From (22.5.1.1) and 11.5.4.3, ACI 318-14: $V_n < 0.83 \cdot f_c' \cdot 0.5 \cdot h \cdot d = 385903.344$

NOTE: In expression (22.5.1.1) 'Vw' is replaced by 'Vw+ f*Vf'
where Vf is the contribution of FRPs (11.3), ACI 440).

From Table (11.5.4.6(d-e)), ACI 318-14: $V_c = 177063.805$

$M_u/V_u - l_w/2 = 2820.011 > 0$

= 1 (normal-weight concrete)

$f_c' = 25.00$, but $f_c'^{0.5} \leq 8.3$ MPa (22.5.3.1, ACI 318-14)

$h = 3000.00$

$d = 200.00$

$l_w = 250.00$

$M_u = 6.0084169E-011$

$V_u = 2.0402016E-014$

$N_u = 33005.924$

From (11.5.4.8), ACI 318-14: $V_s = V_{s1} + V_{s2} + V_{s3} = 104719.755$

$V_{s1} = 52359.878$ is calculated for pseudo-Column 1, with:

$d = 200.00$

$A_v = 157079.633$

$s = 150.00$

$f_y = 500.00$

V_{s1} has been multiplied by $2(1-s/d)$ ($s > d/2$, according to ASCE 41-17,10.3.4)

$2(1-s/d) = 0.50$

$V_{s2} = 52359.878$ is calculated for pseudo-Column 2, with:

$d = 200.00$

$A_v = 157079.633$

$s = 150.00$

$f_y = 500.00$

V_{s2} has been multiplied by $2(1-s/d)$ ($s > d/2$, according to ASCE 41-17,10.3.4)

$2(1-s/d) = 0.50$

$V_{s3} = 0.00$ is calculated for web, with:

$d = 200.00$

$A_v = 0.00$

$s = 200.00$

$f_y = 500.00$

V_{s3} has been multiplied by $2(1-s/d)$ ($s > d/2$, according to ASCE 41-17,10.3.4)

$2(1-s/d) = 0.00$

V_f ((11-3)-(11.4), ACI 440) = 109599.773

$f = 0.95$, for fully-wrapped sections

$w_f/s_f = 1$ (FRP strips adjacent to one another).

In (11.3) $\sin + \cos$ is replaced with $(\cot + \cot a)\sin a$ which is more a generalised expression,

where a is the angle of the crack direction (see KANEPE).

This later relation, considered as a function $V_f(a)$, is implemented for every different fiber orientation a_i , as well as for 2 crack directions, $a = 45^\circ$ and $a = -45^\circ$ to take into consideration the cyclic seismic loading.

orientation 1: $a_1 = b_1 + 90^\circ = 90.00$

$V_f = \text{Min}(|V_f(45, a_1)|, |V_f(-45, a_1)|)$, with:

total thickness per orientation, $t_{f1} = N_L * t / N_{oDir} = 1.016$

$d_{fv} = d$ (figure 11.2, ACI 440) = 208.00

f_{fe} ((11-5), ACI 440) = 259.312

$E_f = 64828.00$

$f_e = 0.004$, from (11.6a), ACI 440

with $f_u = 0.01$

From (11-11), ACI 440: $V_s + V_f \leq 1.9929E+006$

$b_w = 3000.00$

End Of Calculation of Shear Capacity for element: wall W1 of floor 1

At local axis: 2

Integration Section: (d)

Calculation No. 6

wall W1, Floor 1

Limit State: Operational Level (data interpolation between analysis steps 1 and 2)

Analysis: Uniform +X

Check: Chord rotation capacity (ϕ_u)

Edge: End

Local Axis: (2)



Start Of Calculation of Shear Capacity ratio for element: wall W1 of floor 1

At Shear local axis: 3

(Bending local axis: 2)

Section Type: rcwrs

Constant Properties

Knowledge Factor, $\gamma = 1.00$

Mean strength values are used for both shear and moment calculations.

Consequently:

New material of Secondary Member: Concrete Strength, $f_c = f_{cm} = 25.00$

New material of Secondary Member: Steel Strength, $f_s = f_{sm} = 500.00$

Concrete Elasticity, $E_c = 26999.444$

Steel Elasticity, $E_s = 200000.00$

#####

Note: Especially for the calculation of moment strengths,

the above steel re-bar strengths are multiplied by 1.25 according to R18.6.5, ACI 318-14

New material: Steel Strength, $f_s = 1.25 \cdot f_{sm} = 625.00$

#####

Total Height, $H_{tot} = 3000.00$

Edges Width, $W_{edg} = 250.00$

Edges Height, $H_{edg} = 600.00$

Web Width, $W_{web} = 250.00$

Cover Thickness, $c = 25.00$

Mean Confinement Factor overall section = 1.00246

Element Length, $L = 3000.00$

Secondary Member

Smooth Bars

Ductile Steel

Without Detailing for Earthquake Resistance (including stirrups not closed at 135°)

Longitudinal Bars With Ends Lapped Starting at the End Sections

Inadequate Lap Length with $l_o/l_{ou,min} = 0.30$

FRP Wrapping Data

Type: Carbon

Cured laminate properties (design values)

Thickness, $t = 1.016$

Tensile Strength, $f_{fu} = 1055.00$

Tensile Modulus, $E_f = 64828.00$

Elongation, $\epsilon_{fu} = 0.01$

Number of directions, $N_{oDir} = 1$

Fiber orientations, $b_i = 0.00^\circ$

Number of layers, $N_L = 1$

Radius of rounding corners, $R = 40.00$

Stepwise Properties

At local axis: 3

EDGE -A-

Shear Force, $V_a = 1.0097420E-028$

EDGE -B-

Shear Force, $V_b = -1.0097420E-028$

BOTH EDGES

Axial Force, $F = -27588.841$

Longitudinal Reinforcement Area Distribution (in 2 divisions)

-Tension: $A_{sl,t} = 0.00$

-Compression: $A_{sl,c} = 7269.645$

Longitudinal Reinforcement Area Distribution (in 3 divisions)

-Tension: $A_{sl,ten} = 2865.133$

-Compression: $A_{sl,com} = 2865.133$

-Middle: $A_{sl,mid} = 0.00$

(According to 10.7.2.3 $A_{sl,mid}$ is setted equal to zero)

Calculation of Shear Capacity ratio, $V_e/V_r = 1.02813$

Member Controlled by Shear ($V_e/V_r > 1$)

Calculation of Shear Demand from fig. R18.6.5, ACI 318-14 $V_e = (M_{pr1} + M_{pr2})/l_n = 2.5600E+006$ with

$M_{pr1} = \max(\mu_{u1+}, \mu_{u1-}) = 3.8401E+009$

$\mu_{u1+} = 3.3585E+009$, is the ultimate moment strength at the edge 1 of the member in the actual moment direction which is defined for the static loading combination

$\mu_{u1-} = 3.8401E+009$, is the ultimate moment strength at the edge 1 of the member in the opposite moment direction which is defined for the static loading combination

$M_{pr2} = \max(\mu_{u2+}, \mu_{u2-}) = 3.8401E+009$

$\mu_{u2+} = 3.3585E+009$, is the ultimate moment strength at the edge 2 of the member in the actual moment direction which is defined for the static loading combination

$\mu_{u2-} = 3.8401E+009$, is the ultimate moment strength at the edge 2 of the member in the opposite moment direction which is defined for the static loading combination

Calculation of μ_{u1+}

Calculation of ultimate curvature ϕ_u according to 4.1, Biskinis/Fardis 2013:

$\phi_u = 2.0296703E-006$

$M_u = 3.3585E+009$

with full section properties:

$b = 250.00$

$d = 2957.00$

$d' = 43.00$

$v = 0.0014928$

$N = 27588.841$

$f_c = 25.00$

ϕ_o (5A.5, TBDY) = 0.002

Final value of ϕ_u : $\phi_u^* = \text{shear_factor} * \max(\phi_u, \phi_o) = 0.0035$

The Shear_factor is considered equal to 1 (pure moment strength)

From (5.4b), TBDY: $c_u = 0.0035$

$w_e ((5.4c), TBDY) = a_{se} * sh_{min} * f_{ywe} / f_{ce} + \text{Min}(f_x, f_y) = 0.00$

where $f = a_f * p_f * f_{fe} / f_{ce}$ is accounting for FRP contribution like EC8-part3 A.4.4.3(6)

$f_x = 0.00$

$a_f = 0.00$

$b = 250.00$

$h = 3000.00$

From EC8 A4.4.3(6), $p_f = 2t_f/bw = 0.008128$

$bw = 250.00$

effective stress from (A.35), $f_{fe} = 757.2164$

$f_y = 0.00$

$a_f = 0.00$

$b = 3000.00$

$h = 250.00$

From EC8 A4.4.3(6), $p_f = 2t_f/bw = 0.00067733$

$bw = 3000.00$

effective stress from (A.35), $f_{fe} = 954.4864$

$R = 40.00$

Effective FRP thickness, $t_f = NL * t * \text{Cos}(b_1) = 1.016$

$f_{u,f} = 1055.00$

$E_f = 64828.00$

$u_f = 0.015$

$a_{se} ((5.4d), TBDY) = (a_{se1} * A_{col1} + a_{se2} * A_{col2} + a_{se3} * A_{web}) / A_{sec} = 0.00$

$a_{se1} = 0.00$

$sh_1 = 150.00$

$bo_1 = 190.00$

$ho_1 = 540.00$

$bi2_1 = 655400.00$

$a_{se2} = 0.00$

$sh_2 = 150.00$

$bo_2 = 190.00$

$ho_2 = 540.00$

$bi2_2 = 655400.00$

$a_{se3} = 0$ (grid does not provide confinement)

$p_{sh,min} = \text{Min}(p_{sh,x}, p_{sh,y}) = 0.00069813$

Expression ((5.4d), TBDY) for $p_{sh,min}$ has been multiplied by 0.3 according to 15.7.1.3 for members without earthquake detailing (90° closed stirrups)

$p_{sh,x} = p_{s1,x} + p_{s2,x} + p_{s3,x} = 0.00356047$

$p_{s1,x}$ (column 1) = $(A_{s1} * h_1 / s_1) / A_c = 0.00083776$

$h_1 = 600.00$

$A_{s1} = A_{stir1} * n_{s1} = 157.0796$

No stirrups, $n_{s1} = 2.00$

$p_{s2,x}$ (column 2) = $(A_{s2} * h_2 / s_2) / A_c = 0.00083776$

$h_2 = 600.00$

$A_{s2} = A_{stir2} * n_{s2} = 157.0796$

No stirrups, $n_{s2} = 2.00$

$p_{s3,x}$ (web) = $(A_{s3} * h_3 / s_3) / A_c = 0.00188496$

$h_3 = 1800.00$

$A_{s3} = A_{stir3} * n_{s3} = 0.00$

No stirrups, $n_{s3} = 2.00$

$p_{sh,y} = p_{s1,y} + p_{s2,y} + p_{s3,y} = 0.00069813$

$p_{s1,y}$ (column 1) = $(A_{s1} * h_1 / s_1) / A_c = 0.00034907$

$h_1 = 250.00$

$A_{s1} = A_{stir1} * n_{s1} = 157.0796$

No stirrups, $n_{s1} = 2.00$

$p_{s2,y}$ (column 2) = $(A_{s2} * h_2 / s_2) / A_c = 0.00034907$

$h_2 = 250.00$

$A_{s2} = A_{stir2} * n_{s2} = 157.0796$

No stirrups, $n_{s2} = 2.00$

$p_{s3,y}$ (web) = $(A_{s3} * h_3 / s_3) / A_c = 0.00$

$h_3 = 250.00$

$$As_3 = Astir_3 * ns_3 = 157.0796$$

$$\text{No stirups, } ns_3 = 0.00$$

$$A_{sec} = 750000.00$$

$$s_1 = 150.00$$

$$s_2 = 150.00$$

$$s_3 = 200.00$$

$$f_{ywe} = 625.00$$

$$f_{ce} = 25.00$$

$$\text{From } ((5.A.5), \text{TB DY}), \text{TB DY: } cc = 0.00202463$$

$$c = \text{confinement factor} = 1.00246$$

$$y_1 = 0.00140044$$

$$sh_1 = 0.0044814$$

$$ft_1 = 420.1317$$

$$fy_1 = 350.1097$$

$$su_1 = 0.00512$$

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00

$$lo/lou, \min = lb/ld = 0.30$$

$$su_1 = 0.4 * esu_1_{nominal} ((5.5), \text{TB DY}) = 0.032$$

From table 5A.1, TB DY: $esu_1_{nominal} = 0.08$,

For calculation of $esu_1_{nominal}$ and y_1, sh_1, ft_1, fy_1 , it is considered
characteristic value $fsy_1 = fs_1/1.2$, from table 5.1, TB DY.

y_1, sh_1, ft_1, fy_1 , are also multiplied by $\text{Min}(1, 1.25 * (lb/ld)^{2/3})$, from 10.3.5, ASCE 41-17.

$$\text{with } fs_1 = fs = 350.1097$$

$$\text{with } Es_1 = Es = 200000.00$$

$$y_2 = 0.00140044$$

$$sh_2 = 0.0044814$$

$$ft_2 = 420.1317$$

$$fy_2 = 350.1097$$

$$su_2 = 0.00512$$

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00

$$lo/lou, \min = lb/lb, \min = 0.30$$

$$su_2 = 0.4 * esu_2_{nominal} ((5.5), \text{TB DY}) = 0.032$$

From table 5A.1, TB DY: $esu_2_{nominal} = 0.08$,

For calculation of $esu_2_{nominal}$ and y_2, sh_2, ft_2, fy_2 , it is considered
characteristic value $fsy_2 = fs_2/1.2$, from table 5.1, TB DY.

y_1, sh_1, ft_1, fy_1 , are also multiplied by $\text{Min}(1, 1.25 * (lb/ld)^{2/3})$, from 10.3.5, ASCE 41-17.

$$\text{with } fs_2 = fs = 350.1097$$

$$\text{with } Es_2 = Es = 200000.00$$

$$y_v = 0.00140044$$

$$sh_v = 0.0044814$$

$$ft_v = 420.1317$$

$$fy_v = 350.1097$$

$$su_v = 0.00512$$

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00

$$lo/lou, \min = lb/ld = 0.30$$

$$su_v = 0.4 * esuv_{nominal} ((5.5), \text{TB DY}) = 0.032$$

From table 5A.1, TB DY: $esuv_{nominal} = 0.08$,

considering characteristic value $fsyv = fsv/1.2$, from table 5.1, TB DY

For calculation of $esuv_{nominal}$ and y_v, sh_v, ft_v, fy_v , it is considered
characteristic value $fsyv = fsv/1.2$, from table 5.1, TB DY.

y_1, sh_1, ft_1, fy_1 , are also multiplied by $\text{Min}(1, 1.25 * (lb/ld)^{2/3})$, from 10.3.5, ASCE 41-17.

$$\text{with } fsv = fs = 350.1097$$

$$\text{with } Es_v = Es = 200000.00$$

$$1 = Asl, \text{ten} / (b * d) * (fs_1 / f_c) = 0.05427722$$

$$2 = Asl, \text{com} / (b * d) * (fs_2 / f_c) = 0.05427722$$

$$v = Asl, \text{mid} / (b * d) * (fsv / f_c) = 0.00$$

and confined core properties:

$$b = 190.00$$

$$d = 2927.00$$

$$d' = 13.00$$

f_{cc} (5A.2, TBDY) = 25.06158
 c_c (5A.5, TBDY) = 0.00202463
 c = confinement factor = 1.00246
 $1 = A_{sl,ten}/(b*d)*(f_{s1}/f_c) = 0.07214938$
 $2 = A_{sl,com}/(b*d)*(f_{s2}/f_c) = 0.07214938$
 $v = A_{sl,mid}/(b*d)*(f_{sv}/f_c) = 0.00$
 Case/Assumption: Unconfined full section - Steel rupture
 ' satisfies Eq. (4.3)

--->
 $v < v_{s,y2}$ - LHS eq.(4.5) is satisfied

--->
 μ_u (4.9) = 0.14691336
 $\mu_u = M_{Rc}$ (4.14) = 3.3585E+009
 $u = \mu_u$ (4.1) = 2.0296703E-006

Calculation of ratio l_b/l_d

Inadequate Lap Length with $l_b/l_d = 0.30$

Calculation of μ_{u1} -

Calculation of ultimate curvature μ_u according to 4.1, Biskinis/Fardis 2013:

$u = 2.0532423E-006$
 $\mu_u = 3.8401E+009$

with full section properties:

$b = 250.00$
 $d = 2957.00$
 $d' = 43.00$
 $v = 0.0014928$
 $N = 27588.841$
 $f_c = 25.00$
 c_c (5A.5, TBDY) = 0.002
 Final value of μ_u : $\mu_u^* = \text{shear_factor} * \text{Max}(\mu_u, c_c) = 0.0035$
 The Shear_factor is considered equal to 1 (pure moment strength)
 From (5.4b), TBDY: $\mu_u = 0.0035$
 μ_{ue} ((5.4c), TBDY) = $a_{se} * \text{sh}_{,min} * f_{ywe}/f_{ce} + \text{Min}(f_x, f_y) = 0.00$
 where $f = a_f * p_f * f_{fe}/f_{ce}$ is accounting for FRP contribution like EC8-part3 A.4.4.3(6)

$f_x = 0.00$
 $a_f = 0.00$
 $b = 250.00$
 $h = 3000.00$
 From EC8 A4.4.3(6), $p_f = 2t_f/bw = 0.008128$
 $bw = 250.00$
 effective stress from (A.35), $f_{fe} = 757.2164$

$f_y = 0.00$
 $a_f = 0.00$
 $b = 3000.00$
 $h = 250.00$
 From EC8 A4.4.3(6), $p_f = 2t_f/bw = 0.00067733$
 $bw = 3000.00$
 effective stress from (A.35), $f_{fe} = 954.4864$

$R = 40.00$
 Effective FRP thickness, $t_f = N L * t * \text{Cos}(b_1) = 1.016$
 $f_{u,f} = 1055.00$
 $E_f = 64828.00$
 $u_{,f} = 0.015$
 a_{se} ((5.4d), TBDY) = $(a_{se1} * A_{col1} + a_{se2} * A_{col2} + a_{se3} * A_{web})/A_{sec} = 0.00$
 $a_{se1} = 0.00$

$sh_1 = 150.00$
 $bo_1 = 190.00$
 $ho_1 = 540.00$
 $bi2_1 = 655400.00$
 $ase2 = 0.00$
 $sh_2 = 150.00$
 $bo_2 = 190.00$
 $ho_2 = 540.00$
 $bi2_2 = 655400.00$
 $ase3 = 0$ (grid does not provide confinement)
 $psh,min = \text{Min}(psh,x, psh,y) = 0.00069813$
 Expression ((5.4d), TBDY) for psh,min has been multiplied by 0.3 according to 15.7.1.3 for members without earthquake detailing (90° closed stirrups)

$psh,x = ps1,x + ps2,x + ps3,x = 0.00356047$
 $ps1,x$ (column 1) = $(As1 \cdot h1 / s_1) / Ac = 0.00083776$
 $h1 = 600.00$
 $As1 = Astir1 \cdot ns1 = 157.0796$
 No stirrups, $ns1 = 2.00$
 $ps2,x$ (column 2) = $(As2 \cdot h2 / s_2) / Ac = 0.00083776$
 $h2 = 600.00$
 $As2 = Astir2 \cdot ns2 = 157.0796$
 No stirrups, $ns2 = 2.00$
 $ps3,x$ (web) = $(As3 \cdot h3 / s_3) / Ac = 0.00188496$
 $h3 = 1800.00$
 $As3 = Astir3 \cdot ns3 = 0.00$
 No stirrups, $ns3 = 2.00$

$psh,y = ps1,y + ps2,y + ps3,y = 0.00069813$
 $ps1,y$ (column 1) = $(As1 \cdot h1 / s_1) / Ac = 0.00034907$
 $h1 = 250.00$
 $As1 = Astir1 \cdot ns1 = 157.0796$
 No stirrups, $ns1 = 2.00$
 $ps2,y$ (column 2) = $(As2 \cdot h2 / s_2) / Ac = 0.00034907$
 $h2 = 250.00$
 $As2 = Astir2 \cdot ns2 = 157.0796$
 No stirrups, $ns2 = 2.00$
 $ps3,y$ (web) = $(As3 \cdot h3 / s_3) / Ac = 0.00$
 $h3 = 250.00$
 $As3 = Astir3 \cdot ns3 = 157.0796$
 No stirrups, $ns3 = 0.00$

$Asec = 750000.00$
 $s_1 = 150.00$
 $s_2 = 150.00$
 $s_3 = 200.00$
 $fywe = 625.00$
 $fce = 25.00$
 From ((5.A5), TBDY), TBDY: $cc = 0.00202463$
 $c = \text{confinement factor} = 1.00246$
 $y1 = 0.00140044$
 $sh1 = 0.0044814$
 $ft1 = 420.1317$
 $fy1 = 350.1097$
 $su1 = 0.00512$
 using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
 and also multiplied by the shear_factor according to 15.7.1.4, with
 $\text{Shear_factor} = 1.00$
 $lo/lou,min = lb/ld = 0.30$
 $su1 = 0.4 \cdot esu1_nominal$ ((5.5), TBDY) = 0.032
 From table 5A.1, TBDY: $esu1_nominal = 0.08$,
 For calculation of $esu1_nominal$ and $y1, sh1, ft1, fy1$, it is considered
 characteristic value $fsy1 = fs1 / 1.2$, from table 5.1, TBDY.
 $y1, sh1, ft1, fy1$, are also multiplied by $\text{Min}(1, 1.25 \cdot (lb/ld)^{2/3})$, from 10.3.5, ASCE 41-17.
 with $fs1 = fs = 350.1097$
 with $Es1 = Es = 200000.00$
 $y2 = 0.00140044$


```

sh2 = 0.0044814
ft2 = 420.1317
fy2 = 350.1097
su2 = 0.00512
    using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
    and also multiplied by the shear_factor according to 15.7.1.4, with
    Shear_factor = 1.00
    lo/lo,min = lb/lb,min = 0.30
    su2 = 0.4*esu2_nominal ((5.5), TBDY) = 0.032
    From table 5A.1, TBDY: esu2_nominal = 0.08,
    For calculation of esu2_nominal and y2, sh2,ft2,fy2, it is considered
    characteristic value fsy2 = fs2/1.2, from table 5.1, TBDY.
    y1, sh1,ft1,fy1, are also multiplied by Min(1,1.25*(lb/lb)^ 2/3), from 10.3.5, ASCE 41-17.
    with fs2 = fs = 350.1097
    with Es2 = Es = 200000.00
yv = 0.00140044
shv = 0.0044814
ftv = 420.1317
fyv = 350.1097
suv = 0.00512
    using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
    and also multiplied by the shear_factor according to 15.7.1.4, with
    Shear_factor = 1.00
    lo/lo,min = lb/lb = 0.30
    suv = 0.4*esuv_nominal ((5.5), TBDY) = 0.032
    From table 5A.1, TBDY: esuv_nominal = 0.08,
    considering characteristic value fsyv = fsv/1.2, from table 5.1, TBDY
    For calculation of esuv_nominal and yv, shv,ftv,fyv, it is considered
    characteristic value fsyv = fsv/1.2, from table 5.1, TBDY.
    y1, sh1,ft1,fy1, are also multiplied by Min(1,1.25*(lb/lb)^ 2/3), from 10.3.5, ASCE 41-17.
    with fsv = fs = 350.1097
    with Esv = Es = 200000.00
1 = Asl,ten/(b*d)*(fs1/fc) = 0.05427722
2 = Asl,com/(b*d)*(fs2/fc) = 0.05427722
v = Asl,mid/(b*d)*(fsv/fc) = 0.0291621
and confined core properties:
b = 190.00
d = 2927.00
d' = 13.00
fcc (5A.2, TBDY) = 25.06158
cc (5A.5, TBDY) = 0.00202463
c = confinement factor = 1.00246
1 = Asl,ten/(b*d)*(fs1/fc) = 0.07214938
2 = Asl,com/(b*d)*(fs2/fc) = 0.07214938
v = Asl,mid/(b*d)*(fsv/fc) = 0.03876447
Case/Assumption: Unconfined full section - Steel rupture
' satisfies Eq. (4.3)
--->
v < vs,y2 - LHS eq.(4.5) is satisfied
--->
su (4.9) = 0.15670711
Mu = MRc (4.14) = 3.8401E+009
u = su (4.1) = 2.0532423E-006

```

Calculation of ratio lb/lb

Inadequate Lap Length with lb/lb = 0.30

Calculation of Mu2+

Calculation of ultimate curvature u according to 4.1, Biskinis/Fardis 2013:

u = 2.0296703E-006

$$\mu = 3.3585E+009$$

with full section properties:

$$b = 250.00$$

$$d = 2957.00$$

$$d' = 43.00$$

$$v = 0.0014928$$

$$N = 27588.841$$

$$f_c = 25.00$$

$$\alpha (5A.5, \text{TB DY}) = 0.002$$

$$\text{Final value of } \mu: \mu^* = \text{shear_factor} * \text{Max}(\mu, \alpha) = 0.0035$$

The Shear_factor is considered equal to 1 (pure moment strength)

$$\text{From (5.4b), TB DY: } \mu = 0.0035$$

$$\text{we ((5.4c), TB DY) } = \alpha * \text{sh}_{\min} * f_{ywe} / f_{ce} + \text{Min}(f_x, f_y) = 0.00$$

where $f = \alpha * \mu * f_{fe} / f_{ce}$ is accounting for FRP contribution like EC8-part3 A.4.4.3(6)

$$f_x = 0.00$$

$$\alpha_f = 0.00$$

$$b = 250.00$$

$$h = 3000.00$$

$$\text{From EC8 A4.4.3(6), } \mu_f = 2t_f/bw = 0.008128$$

$$bw = 250.00$$

$$\text{effective stress from (A.35), } f_{fe} = 757.2164$$

$$f_y = 0.00$$

$$\alpha_f = 0.00$$

$$b = 3000.00$$

$$h = 250.00$$

$$\text{From EC8 A4.4.3(6), } \mu_f = 2t_f/bw = 0.00067733$$

$$bw = 3000.00$$

$$\text{effective stress from (A.35), } f_{fe} = 954.4864$$

$$R = 40.00$$

$$\text{Effective FRP thickness, } t_f = NL * t * \cos(b_1) = 1.016$$

$$f_{u,f} = 1055.00$$

$$E_f = 64828.00$$

$$u_{f,f} = 0.015$$

$$\alpha_{se} ((5.4d), \text{TB DY}) = (\alpha_{se1} * A_{col1} + \alpha_{se2} * A_{col2} + \alpha_{se3} * A_{web}) / A_{sec} = 0.00$$

$$\alpha_{se1} = 0.00$$

$$\text{sh}_1 = 150.00$$

$$\text{bo}_1 = 190.00$$

$$\text{ho}_1 = 540.00$$

$$\text{bi}_{2,1} = 655400.00$$

$$\alpha_{se2} = 0.00$$

$$\text{sh}_2 = 150.00$$

$$\text{bo}_2 = 190.00$$

$$\text{ho}_2 = 540.00$$

$$\text{bi}_{2,2} = 655400.00$$

$$\alpha_{se3} = 0 \text{ (grid does not provide confinement)}$$

$$\mu_{sh,\min} = \text{Min}(\mu_{sh,x}, \mu_{sh,y}) = 0.00069813$$

Expression ((5.4d), TB DY) for $\mu_{sh,\min}$ has been multiplied by 0.3 according to 15.7.1.3 for members without earthquake detailing (90° closed stirrups)

$$\mu_{sh,x} = \mu_{s1,x} + \mu_{s2,x} + \mu_{s3,x} = 0.00356047$$

$$\mu_{s1,x} \text{ (column 1)} = (A_{s1} * h_1 / s_1) / A_c = 0.00083776$$

$$h_1 = 600.00$$

$$A_{s1} = A_{stir1} * n_{s1} = 157.0796$$

$$\text{No stirrups, } n_{s1} = 2.00$$

$$\mu_{s2,x} \text{ (column 2)} = (A_{s2} * h_2 / s_2) / A_c = 0.00083776$$

$$h_2 = 600.00$$

$$A_{s2} = A_{stir2} * n_{s2} = 157.0796$$

$$\text{No stirrups, } n_{s2} = 2.00$$

$$\mu_{s3,x} \text{ (web)} = (A_{s3} * h_3 / s_3) / A_c = 0.00188496$$

$$h_3 = 1800.00$$

$$A_{s3} = A_{stir3} * n_{s3} = 0.00$$

$$\text{No stirrups, } n_{s3} = 2.00$$

$psh,y = ps1,y + ps2,y + ps3,y = 0.00069813$
 $ps1,y \text{ (column 1)} = (As1 \cdot h1 / s_1) / Ac = 0.00034907$
 $h1 = 250.00$
 $As1 = Astir1 \cdot ns1 = 157.0796$
 No stirups, $ns1 = 2.00$
 $ps2,y \text{ (column 2)} = (As2 \cdot h2 / s_2) / Ac = 0.00034907$
 $h2 = 250.00$
 $As2 = Astir2 \cdot ns2 = 157.0796$
 No stirups, $ns2 = 2.00$
 $ps3,y \text{ (web)} = (As3 \cdot h3 / s_3) / Ac = 0.00$
 $h3 = 250.00$
 $As3 = Astir3 \cdot ns3 = 157.0796$
 No stirups, $ns3 = 0.00$

Asec = 750000.00

$s_1 = 150.00$

$s_2 = 150.00$

$s_3 = 200.00$

$fywe = 625.00$

$fce = 25.00$

From ((5.A5), TBDY), TBDY: $cc = 0.00202463$

$c = \text{confinement factor} = 1.00246$

$y1 = 0.00140044$

$sh1 = 0.0044814$

$ft1 = 420.1317$

$fy1 = 350.1097$

$su1 = 0.00512$

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00

$lo/lou,min = lb/ld = 0.30$

$su1 = 0.4 \cdot esu1_nominal \text{ ((5.5), TBDY)} = 0.032$

From table 5A.1, TBDY: $esu1_nominal = 0.08$,

For calculation of $esu1_nominal$ and $y1, sh1, ft1, fy1$, it is considered
characteristic value $fsy1 = fs1/1.2$, from table 5.1, TBDY.

$y1, sh1, ft1, fy1$, are also multiplied by $\text{Min}(1, 1.25 \cdot (lb/ld)^{2/3})$, from 10.3.5, ASCE 41-17.

with $fs1 = fs = 350.1097$

with $Es1 = Es = 200000.00$

$y2 = 0.00140044$

$sh2 = 0.0044814$

$ft2 = 420.1317$

$fy2 = 350.1097$

$su2 = 0.00512$

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00

$lo/lou,min = lb/lb,min = 0.30$

$su2 = 0.4 \cdot esu2_nominal \text{ ((5.5), TBDY)} = 0.032$

From table 5A.1, TBDY: $esu2_nominal = 0.08$,

For calculation of $esu2_nominal$ and $y2, sh2, ft2, fy2$, it is considered
characteristic value $fsy2 = fs2/1.2$, from table 5.1, TBDY.

$y2, sh2, ft2, fy2$, are also multiplied by $\text{Min}(1, 1.25 \cdot (lb/ld)^{2/3})$, from 10.3.5, ASCE 41-17.

with $fs2 = fs = 350.1097$

with $Es2 = Es = 200000.00$

$yv = 0.00140044$

$shv = 0.0044814$

$ftv = 420.1317$

$fyv = 350.1097$

$suv = 0.00512$

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00

$lo/lou,min = lb/ld = 0.30$

$suv = 0.4 \cdot esuv_nominal \text{ ((5.5), TBDY)} = 0.032$

From table 5A.1, TBDY: $esuv_nominal = 0.08$,

considering characteristic value $fsyv = fsv/1.2$, from table 5.1, TBDY
For calculation of $esuv_nominal$ and yv, shv, ftv, fyv , it is considered

characteristic value $f_{sv} = f_{sv}/1.2$, from table 5.1, TBDY.
 y_1, sh_1, ft_1, fy_1 , are also multiplied by $\text{Min}(1, 1.25 \cdot (l_b/l_d)^{2/3})$, from 10.3.5, ASCE 41-17.
 with $f_{sv} = f_s = 350.1097$
 with $E_{sv} = E_s = 200000.00$
 $1 = A_{sl,ten}/(b \cdot d) \cdot (f_{s1}/f_c) = 0.05427722$
 $2 = A_{sl,com}/(b \cdot d) \cdot (f_{s2}/f_c) = 0.05427722$
 $v = A_{sl,mid}/(b \cdot d) \cdot (f_{sv}/f_c) = 0.00$

and confined core properties:

$b = 190.00$
 $d = 2927.00$
 $d' = 13.00$
 $f_{cc} \text{ (5A.2, TBDY)} = 25.06158$
 $cc \text{ (5A.5, TBDY)} = 0.00202463$
 $c = \text{confinement factor} = 1.00246$
 $1 = A_{sl,ten}/(b \cdot d) \cdot (f_{s1}/f_c) = 0.07214938$
 $2 = A_{sl,com}/(b \cdot d) \cdot (f_{s2}/f_c) = 0.07214938$
 $v = A_{sl,mid}/(b \cdot d) \cdot (f_{sv}/f_c) = 0.00$

Case/Assumption: Unconfined full section - Steel rupture
 ' satisfies Eq. (4.3)

--->

$v < v_{s,y2}$ - LHS eq.(4.5) is satisfied

--->

$su \text{ (4.9)} = 0.14691336$
 $Mu = MR_c \text{ (4.14)} = 3.3585E+009$
 $u = su \text{ (4.1)} = 2.0296703E-006$

Calculation of ratio l_b/l_d

Inadequate Lap Length with $l_b/l_d = 0.30$

Calculation of Mu_2 -

Calculation of ultimate curvature u according to 4.1, Biskinis/Fardis 2013:

$u = 2.0532423E-006$
 $Mu = 3.8401E+009$

with full section properties:

$b = 250.00$
 $d = 2957.00$
 $d' = 43.00$
 $v = 0.0014928$
 $N = 27588.841$
 $f_c = 25.00$
 $co \text{ (5A.5, TBDY)} = 0.002$
 Final value of cu : $cu^* = \text{shear_factor} \cdot \text{Max}(cu, cc) = 0.0035$
 The Shear_factor is considered equal to 1 (pure moment strength)
 From (5.4b), TBDY: $cu = 0.0035$
 $w_e \text{ ((5.4c), TBDY)} = a_{se} \cdot sh_{,min} \cdot f_{ywe}/f_{ce} + \text{Min}(f_x, f_y) = 0.00$
 where $f = a_f \cdot p_f \cdot f_{fe}/f_{ce}$ is accounting for FRP contribution like EC8-part3 A.4.4.3(6)

$f_x = 0.00$
 $a_f = 0.00$
 $b = 250.00$
 $h = 3000.00$
 From EC8 A.4.4.3(6), $p_f = 2t_f/bw = 0.008128$
 $bw = 250.00$
 effective stress from (A.35), $f_{fe} = 757.2164$

$f_y = 0.00$
 $a_f = 0.00$
 $b = 3000.00$
 $h = 250.00$

From EC8 A4.4.3(6), $pf = 2tf/bw = 0.00067733$
 $bw = 3000.00$
effective stress from (A.35), $ff,e = 954.4864$

$R = 40.00$
Effective FRP thickness, $tf = NL*t*Cos(b1) = 1.016$
 $f_{u,f} = 1055.00$
 $E_f = 64828.00$
 $u_{,f} = 0.015$
 $ase((5.4d), TBDY) = (ase1*Acol1 + ase2*Acol2 + ase3*Aweb)/Asec = 0.00$
 $ase1 = 0.00$
 $sh_1 = 150.00$
 $bo_1 = 190.00$
 $ho_1 = 540.00$
 $bi2_1 = 655400.00$
 $ase2 = 0.00$
 $sh_2 = 150.00$
 $bo_2 = 190.00$
 $ho_2 = 540.00$
 $bi2_2 = 655400.00$
 $ase3 = 0$ (grid does not provide confinement)
 $psh,min = Min(psh,x, psh,y) = 0.00069813$

Expression ((5.4d), TBDY) for psh,min has been multiplied by 0.3 according to 15.7.1.3 for members without earthquake detailing (90° closed stirrups)

$psh,x = ps1,x + ps2,x + ps3,x = 0.00356047$
 $ps1,x$ (column 1) = $(As1*h1/s_1)/Ac = 0.00083776$
 $h1 = 600.00$
 $As1 = Astir1*ns1 = 157.0796$
No stirrups, $ns1 = 2.00$
 $ps2,x$ (column 2) = $(As2*h2/s_2)/Ac = 0.00083776$
 $h2 = 600.00$
 $As2 = Astir2*ns2 = 157.0796$
No stirrups, $ns2 = 2.00$
 $ps3,x$ (web) = $(As3*h3/s_3)/Ac = 0.00188496$
 $h3 = 1800.00$
 $As3 = Astir3*ns3 = 0.00$
No stirrups, $ns3 = 2.00$

$psh,y = ps1,y + ps2,y + ps3,y = 0.00069813$
 $ps1,y$ (column 1) = $(As1*h1/s_1)/Ac = 0.00034907$
 $h1 = 250.00$
 $As1 = Astir1*ns1 = 157.0796$
No stirrups, $ns1 = 2.00$
 $ps2,y$ (column 2) = $(As2*h2/s_2)/Ac = 0.00034907$
 $h2 = 250.00$
 $As2 = Astir2*ns2 = 157.0796$
No stirrups, $ns2 = 2.00$
 $ps3,y$ (web) = $(As3*h3/s_3)/Ac = 0.00$
 $h3 = 250.00$
 $As3 = Astir3*ns3 = 157.0796$
No stirrups, $ns3 = 0.00$

$Asec = 750000.00$
 $s_1 = 150.00$
 $s_2 = 150.00$
 $s_3 = 200.00$
 $fywe = 625.00$
 $fce = 25.00$

From ((5.A5), TBDY), TBDY: $cc = 0.00202463$
 $c =$ confinement factor = 1.00246

$y1 = 0.00140044$
 $sh1 = 0.0044814$
 $ft1 = 420.1317$
 $fy1 = 350.1097$
 $su1 = 0.00512$

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor

and also multiplied by the shear_factor according to 15.7.1.4, with
 Shear_factor = 1.00
 $l_o/l_{ou,min} = l_b/l_d = 0.30$
 $su_1 = 0.4 * esu_{1,nominal} ((5.5), TBDY) = 0.032$
 From table 5A.1, TBDY: $esu_{1,nominal} = 0.08$,
 For calculation of $esu_{1,nominal}$ and y_1, sh_1, ft_1, fy_1 , it is considered
 characteristic value $fsy_1 = fs_1/1.2$, from table 5.1, TBDY.
 y_1, sh_1, ft_1, fy_1 , are also multiplied by $Min(1, 1.25 * (l_b/l_d)^{2/3})$, from 10.3.5, ASCE 41-17.
 with $fs_1 = fs = 350.1097$
 with $Es_1 = Es = 200000.00$
 $y_2 = 0.00140044$
 $sh_2 = 0.0044814$
 $ft_2 = 420.1317$
 $fy_2 = 350.1097$
 $su_2 = 0.00512$
 using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
 and also multiplied by the shear_factor according to 15.7.1.4, with
 Shear_factor = 1.00
 $l_o/l_{ou,min} = l_b/l_{b,min} = 0.30$
 $su_2 = 0.4 * esu_{2,nominal} ((5.5), TBDY) = 0.032$
 From table 5A.1, TBDY: $esu_{2,nominal} = 0.08$,
 For calculation of $esu_{2,nominal}$ and y_2, sh_2, ft_2, fy_2 , it is considered
 characteristic value $fsy_2 = fs_2/1.2$, from table 5.1, TBDY.
 y_1, sh_1, ft_1, fy_1 , are also multiplied by $Min(1, 1.25 * (l_b/l_d)^{2/3})$, from 10.3.5, ASCE 41-17.
 with $fs_2 = fs = 350.1097$
 with $Es_2 = Es = 200000.00$
 $y_v = 0.00140044$
 $sh_v = 0.0044814$
 $ft_v = 420.1317$
 $fy_v = 350.1097$
 $suv = 0.00512$
 using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
 and also multiplied by the shear_factor according to 15.7.1.4, with
 Shear_factor = 1.00
 $l_o/l_{ou,min} = l_b/l_d = 0.30$
 $suv = 0.4 * esuv_{nominal} ((5.5), TBDY) = 0.032$
 From table 5A.1, TBDY: $esuv_{nominal} = 0.08$,
 considering characteristic value $fsyv = fsv/1.2$, from table 5.1, TBDY
 For calculation of $esuv_{nominal}$ and y_v, sh_v, ft_v, fy_v , it is considered
 characteristic value $fsyv = fsv/1.2$, from table 5.1, TBDY.
 y_1, sh_1, ft_1, fy_1 , are also multiplied by $Min(1, 1.25 * (l_b/l_d)^{2/3})$, from 10.3.5, ASCE 41-17.
 with $fsv = fs = 350.1097$
 with $Esv = Es = 200000.00$
 $1 = Asl_{ten}/(b * d) * (fs_1/fc) = 0.05427722$
 $2 = Asl_{com}/(b * d) * (fs_2/fc) = 0.05427722$
 $v = Asl_{mid}/(b * d) * (fsv/fc) = 0.0291621$
 and confined core properties:
 $b = 190.00$
 $d = 2927.00$
 $d' = 13.00$
 $f_{cc} (5A.2, TBDY) = 25.06158$
 $cc (5A.5, TBDY) = 0.00202463$
 $c = \text{confinement factor} = 1.00246$
 $1 = Asl_{ten}/(b * d) * (fs_1/fc) = 0.07214938$
 $2 = Asl_{com}/(b * d) * (fs_2/fc) = 0.07214938$
 $v = Asl_{mid}/(b * d) * (fsv/fc) = 0.03876447$
 Case/Assumption: Unconfined full section - Steel rupture
 ' satisfies Eq. (4.3)
 --->
 $v < v_{s,y2}$ - LHS eq.(4.5) is satisfied
 --->
 $su (4.9) = 0.15670711$
 $Mu = MRc (4.14) = 3.8401E+009$
 $u = su (4.1) = 2.0532423E-006$

 Calculation of ratio l_b/l_d

Inadequate Lap Length with $l_b/l_d = 0.30$

Calculation of Shear Strength $V_r = \text{Min}(V_{r1}, V_{r2}) = 2.4900\text{E}+006$

Calculation of Shear Strength at edge 1, $V_{r1} = 2.4900\text{E}+006$
From (22.5.1.1) and 11.5.4.3, ACI 318-14: $V_{r1} = V_n < 0.83 \cdot f_c' \cdot h \cdot d$

NOTE: In expression (22.5.1.1) ' V_w ' is replaced by ' $V_w + f \cdot V_f$ '
where V_f is the contribution of FRPs (11.3), ACI 440).

From Table (11.5.4.6(d-e)), ACI 318-14: $V_c = 815517.768$

$\mu_u/\mu_u - l_w/2 = 0.00 \leq 0$

= 1 (normal-weight concrete)

$f_c' = 25.00$, but $f_c'^{0.5} \leq 8.3$ MPa (22.5.3.1, ACI 318-14)

$h = 250.00$

$d = 240.00$

$l_w = 3000.00$

$\mu_u = 1.1486927\text{E}-009$

$V_u = 1.0097420\text{E}-028$

$N_u = 27588.841$

From (11.5.4.8), ACI 318-14: $V_s = V_{s1} + V_{s2} + V_{s3} = 1.0681\text{E}+006$

$V_{s1} = 251327.412$ is calculated for pseudo-Column 1, with:

$d = 480.00$

$A_v = 157079.633$

$s = 150.00$

$f_y = 500.00$

V_{s1} has been multiplied by 1 ($s < d/2$, according to ASCE 41-17,10.3.4)

$V_{s2} = 251327.412$ is calculated for pseudo-Column 2, with:

$d = 480.00$

$A_v = 157079.633$

$s = 150.00$

$f_y = 500.00$

V_{s2} has been multiplied by 1 ($s < d/2$, according to ASCE 41-17,10.3.4)

$V_{s3} = 565486.678$ is calculated for web, with:

$d = 1440.00$

$A_v = 157079.633$

$s = 200.00$

$f_y = 500.00$

V_{s3} has been multiplied by 1 ($s < d/2$, according to ASCE 41-17,10.3.4)

V_f ((11-3)-(11.4), ACI 440) = $1.5581\text{E}+006$

$f = 0.95$, for fully-wrapped sections

$w_f/s_f = 1$ (FRP strips adjacent to one another).

In (11.3) $\sin + \cos$ is replaced with $(\cot + \cot a) \sin a$ which is more a generalised expression,
where a is the angle of the crack direction (see KANEPE).

This later relation, considered as a function $V_f(,)$, is implemented for every different fiber orientation a_i ,
as well as for 2 crack directions, $a = 45^\circ$ and $a = -45^\circ$ to take into consideration the cyclic seismic loading.

orientation 1: $\theta = b_1 + 90^\circ = 90.00$

$V_f = \text{Min}(|V_f(45, \theta)|, |V_f(-45, a_1)|)$, with:

total thickness per orientation, $t_{f1} = N_L \cdot t / N_{oDir} = 1.016$

$d_{fv} = d$ (figure 11.2, ACI 440) = 2957.00

f_{fe} ((11-5), ACI 440) = 259.312

$E_f = 64828.00$

$f_e = 0.004$, from (11.6a), ACI 440

with $f_u = 0.01$

From (11-11), ACI 440: $V_s + V_f \leq 1.9929\text{E}+006$

$b_w = 250.00$

Calculation of Shear Strength at edge 2, $V_{r2} = 2.4900\text{E}+006$

From (22.5.1.1) and 11.5.4.3, ACI 318-14: $V_{r2} = V_n < 0.83 \cdot f_c' \cdot h \cdot d$

NOTE: In expression (22.5.1.1) ' V_w ' is replaced by ' $V_w + f \cdot V_f$ '
where V_f is the contribution of FRPs (11.3), ACI 440).

From Table (11.5.4.6(d-e)), ACI 318-14: $V_c = 815517.768$

$M_u/V_u - l_w/2 = 0.00 \leq 0$

= 1 (normal-weight concrete)

$f_c' = 25.00$, but $f_c'^{0.5} \leq 8.3$ MPa (22.5.3.1, ACI 318-14)

$h = 250.00$

$d = 2400.00$

$l_w = 3000.00$

$M_u = 1.1486927E+009$

$V_u = 1.0097420E+028$

$N_u = 27588.841$

From (11.5.4.8), ACI 318-14: $V_s = V_{s1} + V_{s2} + V_{s3} = 1.0681E+006$

$V_{s1} = 251327.412$ is calculated for pseudo-Column 1, with:

$d = 480.00$

$A_v = 157079.633$

$s = 150.00$

$f_y = 500.00$

V_{s1} has been multiplied by 1 ($s < d/2$, according to ASCE 41-17,10.3.4)

$V_{s2} = 251327.412$ is calculated for pseudo-Column 2, with:

$d = 480.00$

$A_v = 157079.633$

$s = 150.00$

$f_y = 500.00$

V_{s2} has been multiplied by 1 ($s < d/2$, according to ASCE 41-17,10.3.4)

$V_{s3} = 565486.678$ is calculated for web, with:

$d = 1440.00$

$A_v = 157079.633$

$s = 200.00$

$f_y = 500.00$

V_{s3} has been multiplied by 1 ($s < d/2$, according to ASCE 41-17,10.3.4)

V_f ((11-3)-(11.4), ACI 440) = $1.5581E+006$

$f = 0.95$, for fully-wrapped sections

$w_f/s_f = 1$ (FRP strips adjacent to one another).

In (11.3) $\sin + \cos$ is replaced with $(\cot + \cot a)\sin a$ which is more a generalised expression,

where a is the angle of the crack direction (see KANEPE).

This later relation, considered as a function $V_f(\theta)$, is implemented for every different fiber orientation a_i , as well as for 2 crack directions, $\theta = 45^\circ$ and $\theta = -45^\circ$ to take into consideration the cyclic seismic loading.

orientation 1: $\theta_1 = b_1 + 90^\circ = 90.00$

$V_f = \text{Min}(|V_f(45, \theta_1)|, |V_f(-45, a_1)|)$, with:

total thickness per orientation, $t_{f1} = N_L * t / N_{\text{Dir}} = 1.016$

$d_{fv} = d$ (figure 11.2, ACI 440) = 2957.00

f_{fe} ((11-5), ACI 440) = 259.312

$E_f = 64828.00$

$f_e = 0.004$, from (11.6a), ACI 440

with $f_u = 0.01$

From (11-11), ACI 440: $V_s + V_f \leq 1.9929E+006$

$b_w = 250.00$

End Of Calculation of Shear Capacity ratio for element: wall W1 of floor 1

At local axis: 3

Start Of Calculation of Shear Capacity ratio for element: wall W1 of floor 1

At Shear local axis: 2

(Bending local axis: 3)

Section Type: rcrrws

Constant Properties

Knowledge Factor, $\phi = 1.00$

Mean strength values are used for both shear and moment calculations.

Consequently:

New material of Secondary Member: Concrete Strength, $f_c = f_{cm} = 25.00$

New material of Secondary Member: Steel Strength, $f_s = f_{sm} = 500.00$

Concrete Elasticity, $E_c = 26999.444$

Steel Elasticity, $E_s = 200000.00$

#####

Note: Especially for the calculation of moment strengths,
the above steel re-bar strengths are multiplied by 1.25 according to R18.6.5, ACI 318-14

New material: Steel Strength, $f_s = 1.25 \cdot f_{sm} = 625.00$

#####

Total Height, $H_{tot} = 3000.00$

Edges Width, $W_{edg} = 250.00$

Edges Height, $H_{edg} = 600.00$

Web Width, $W_{web} = 250.00$

Cover Thickness, $c = 25.00$

Mean Confinement Factor overall section = 1.00246

Element Length, $L = 3000.00$

Secondary Member

Smooth Bars

Ductile Steel

Without Detailing for Earthquake Resistance (including stirrups not closed at 135°)

Longitudinal Bars With Ends Lapped Starting at the End Sections

Inadequate Lap Length with $l_o/l_{ou,min} = 0.30$

FRP Wrapping Data

Type: Carbon

Cured laminate properties (design values)

Thickness, $t = 1.016$

Tensile Strength, $f_{fu} = 1055.00$

Tensile Modulus, $E_f = 64828.00$

Elongation, $\epsilon_{fu} = 0.01$

Number of directions, $N_{oDir} = 1$

Fiber orientations, $b_i: 0.00^\circ$

Number of layers, $N_L = 1$

Radius of rounding corners, $R = 40.00$

Stepwise Properties

At local axis: 2

EDGE -A-

Shear Force, $V_a = 1.7354940E-029$

EDGE -B-

Shear Force, $V_b = -1.7354940E-029$

BOTH EDGES

Axial Force, $F = -27588.841$

Longitudinal Reinforcement Area Distribution (in 2 divisions)

-Tension: $As_t = 0.00$

-Compression: $As_c = 7269.645$

Longitudinal Reinforcement Area Distribution (in 3 divisions)

-Tension: $As_{l,ten} = 2830.575$

-Compression: $As_{l,com} = 2830.575$

-Middle: $As_{l,mid} = 0.00$

(According to 10.7.2.3 $As_{l,mid}$ is setted equal to zero)

Calculation of Shear Capacity ratio , $V_e/V_r = 0.15621236$

Member Controlled by Flexure ($V_e/V_r < 1$)

Calculation of Shear Demand from fig. R18.6.5, ACI 318-14 $V_e = (M_{pr1} + M_{pr2})/l_n = 160017.271$

with

$M_{pr1} = \max(\mu_{u1+}, \mu_{u1-}) = 2.4003E+008$

$\mu_{u1+} = 2.0658E+008$, is the ultimate moment strength at the edge 1 of the member in the actual moment direction
which is defined for the static loading combination

$\mu_{u1-} = 2.4003E+008$, is the ultimate moment strength at the edge 1 of the member in the opposite moment
direction which is defined for the static loading combination

$M_{pr2} = \max(\mu_{u2+}, \mu_{u2-}) = 2.4003E+008$

$\mu_{u2+} = 2.0658E+008$, is the ultimate moment strength at the edge 2 of the member in the actual moment direction
which is defined for the the static loading combination

$\mu_{u2-} = 2.4003E+008$, is the ultimate moment strength at the edge 2 of the member in the opposite moment
direction which is defined for the the static loading combination

Calculation of Mu1+

Calculation of ultimate curvature ϕ_u according to 4.1, Biskinis/Fardis 2013:

$$u = 3.0306889E-005$$

$$Mu = 2.0658E+008$$

with full section properties:

$$b = 3000.00$$

$$d = 208.00$$

$$d' = 42.00$$

$$v = 0.00176852$$

$$N = 27588.841$$

$$f_c = 25.00$$

$$c_o \text{ (5A.5, TBDY)} = 0.002$$

$$\text{Final value of } \phi_u: \phi_u^* = \text{shear_factor} * \text{Max}(\phi_u, \phi_c) = 0.0035$$

The Shear_factor is considered equal to 1 (pure moment strength)

$$\text{From (5.4b), TBDY: } \phi_u = 0.0035$$

$$\phi_{ue} \text{ ((5.4c), TBDY)} = a_{se} * \phi_{u,min} * f_{ywe}/f_{ce} + \text{Min}(\phi_{fx}, \phi_{fy}) = 0.00$$

where $\phi_{fx} = a_f * \phi_{pf} * f_{fe}/f_{ce}$ is accounting for FRP contribution like EC8-part3 A.4.4.3(6)

$$\phi_{fx} = 0.00$$

$$a_f = 0.00$$

$$b = 250.00$$

$$h = 3000.00$$

$$\text{From EC8 A.4.4.3(6), } \phi_{pf} = 2t_f/bw = 0.008128$$

$$bw = 250.00$$

$$\text{effective stress from (A.35), } f_{fe} = 757.2164$$

$$\phi_{fy} = 0.00$$

$$a_f = 0.00$$

$$b = 3000.00$$

$$h = 250.00$$

$$\text{From EC8 A.4.4.3(6), } \phi_{pf} = 2t_f/bw = 0.00067733$$

$$bw = 3000.00$$

$$\text{effective stress from (A.35), } f_{fe} = 954.4864$$

$$R = 40.00$$

$$\text{Effective FRP thickness, } t_f = NL * t * \cos(b_1) = 1.016$$

$$f_{u,f} = 1055.00$$

$$E_f = 64828.00$$

$$u_{f} = 0.015$$

$$a_{se} \text{ ((5.4d), TBDY)} = (a_{se1} * A_{col1} + a_{se2} * A_{col2} + a_{se3} * A_{web}) / A_{sec} = 0.00$$

$$a_{se1} = 0.00$$

$$sh_1 = 150.00$$

$$bo_1 = 190.00$$

$$ho_1 = 540.00$$

$$bi2_1 = 655400.00$$

$$a_{se2} = 0.00$$

$$sh_2 = 150.00$$

$$bo_2 = 190.00$$

$$ho_2 = 540.00$$

$$bi2_2 = 655400.00$$

$$a_{se3} = 0 \text{ (grid does not provide confinement)}$$

$$\phi_{psh,min} = \text{Min}(\phi_{psh,x}, \phi_{psh,y}) = 0.00069813$$

Expression ((5.4d), TBDY) for $\phi_{psh,min}$ has been multiplied by 0.3 according to 15.7.1.3 for members without earthquake detailing (90° closed stirrups)

$$\phi_{psh,x} = \phi_{ps1,x} + \phi_{ps2,x} + \phi_{ps3,x} = 0.00356047$$

$$\phi_{ps1,x} \text{ (column 1)} = (A_{s1} * h_1 / s_1) / A_c = 0.00083776$$

$$h_1 = 600.00$$

$$A_{s1} = A_{stir1} * n_{s1} = 157.0796$$

$$\text{No stirrups, } n_{s1} = 2.00$$

$$\phi_{ps2,x} \text{ (column 2)} = (A_{s2} * h_2 / s_2) / A_c = 0.00083776$$

$$h_2 = 600.00$$

$As2 = Astir2 * ns2 = 157.0796$
 No stirups, $ns2 = 2.00$
 $ps3,x \text{ (web)} = (As3 * h3 / s_3) / Ac = 0.00188496$
 $h3 = 1800.00$
 $As3 = Astir3 * ns3 = 0.00$
 No stirups, $ns3 = 2.00$

$psh,y = ps1,y + ps2,y + ps3,y = 0.00069813$
 $ps1,y \text{ (column 1)} = (As1 * h1 / s_1) / Ac = 0.00034907$
 $h1 = 250.00$
 $As1 = Astir1 * ns1 = 157.0796$
 No stirups, $ns1 = 2.00$
 $ps2,y \text{ (column 2)} = (As2 * h2 / s_2) / Ac = 0.00034907$
 $h2 = 250.00$
 $As2 = Astir2 * ns2 = 157.0796$
 No stirups, $ns2 = 2.00$
 $ps3,y \text{ (web)} = (As3 * h3 / s_3) / Ac = 0.00$
 $h3 = 250.00$
 $As3 = Astir3 * ns3 = 157.0796$
 No stirups, $ns3 = 0.00$

$Asec = 750000.00$
 $s_1 = 150.00$
 $s_2 = 150.00$
 $s_3 = 200.00$
 $fywe = 625.00$
 $fce = 25.00$
 From ((5.A5), TBDY), TBDY: $cc = 0.00202463$
 $c = \text{confinement factor} = 1.00246$
 $y1 = 0.00140044$
 $sh1 = 0.0044814$
 $ft1 = 420.1317$
 $fy1 = 350.1097$
 $su1 = 0.00512$
 using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
 and also multiplied by the shear_factor according to 15.7.1.4, with
 $\text{Shear_factor} = 1.00$
 $lo/lou,min = lb/l_d = 0.30$
 $su1 = 0.4 * esu1_nominal \text{ ((5.5), TBDY)} = 0.032$
 From table 5A.1, TBDY: $esu1_nominal = 0.08$,
 For calculation of $esu1_nominal$ and $y1, sh1, ft1, fy1$, it is considered
 characteristic value $fsy1 = fs1 / 1.2$, from table 5.1, TBDY.
 $y1, sh1, ft1, fy1$, are also multiplied by $\text{Min}(1, 1.25 * (lb/l_d)^{2/3})$, from 10.3.5, ASCE 41-17.
 with $fs1 = fs = 350.1097$
 with $Es1 = Es = 200000.00$
 $y2 = 0.00140044$
 $sh2 = 0.0044814$
 $ft2 = 420.1317$
 $fy2 = 350.1097$
 $su2 = 0.00512$
 using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
 and also multiplied by the shear_factor according to 15.7.1.4, with
 $\text{Shear_factor} = 1.00$
 $lo/lou,min = lb/l_b,min = 0.30$
 $su2 = 0.4 * esu2_nominal \text{ ((5.5), TBDY)} = 0.032$
 From table 5A.1, TBDY: $esu2_nominal = 0.08$,
 For calculation of $esu2_nominal$ and $y2, sh2, ft2, fy2$, it is considered
 characteristic value $fsy2 = fs2 / 1.2$, from table 5.1, TBDY.
 $y1, sh1, ft1, fy1$, are also multiplied by $\text{Min}(1, 1.25 * (lb/l_d)^{2/3})$, from 10.3.5, ASCE 41-17.
 with $fs2 = fs = 350.1097$
 with $Es2 = Es = 200000.00$
 $yv = 0.00140044$
 $shv = 0.0044814$
 $ftv = 420.1317$
 $fyv = 350.1097$
 $suv = 0.00512$
 using (30) in Biskinis/Fardis (2013) multiplied with shear_factor

and also multiplied by the shear_factor according to 15.7.1.4, with
 Shear_factor = 1.00
 $l_o/l_{ou,min} = l_b/l_d = 0.30$
 $suv = 0.4 * esuv_{nominal} ((5.5), TBDY) = 0.032$
 From table 5A.1, TBDY: $esuv_{nominal} = 0.08$,
 considering characteristic value $fsyv = fsv/1.2$, from table 5.1, TBDY
 For calculation of $esuv_{nominal}$ and yv, shv,ftv,fyv , it is considered
 characteristic value $fsyv = fsv/1.2$, from table 5.1, TBDY.
 $y1, sh1,ft1,fy1$, are also multiplied by $Min(1,1.25*(l_b/l_d)^{2/3})$, from 10.3.5, ASCE 41-17.
 with $fsv = fs = 350.1097$
 with $Esv = Es = 200000.00$
 $1 = Asl_{ten}/(b*d)*(fs1/fc) = 0.0635264$
 $2 = Asl_{com}/(b*d)*(fs2/fc) = 0.0635264$
 $v = Asl_{mid}/(b*d)*(fsv/fc) = 0.00$
 and confined core properties:
 $b = 2940.00$
 $d = 178.00$
 $d' = 12.00$
 $fcc (5A.2, TBDY) = 25.06158$
 $cc (5A.5, TBDY) = 0.00202463$
 $c = \text{confinement factor} = 1.00246$
 $1 = Asl_{ten}/(b*d)*(fs1/fc) = 0.07574806$
 $2 = Asl_{com}/(b*d)*(fs2/fc) = 0.07574806$
 $v = Asl_{mid}/(b*d)*(fsv/fc) = 0.00$
 Case/Assumption: Unconfined full section - Steel rupture
 ' satisfies Eq. (4.3)
 --->
 $v < v_{s,y2}$ - LHS eq.(4.5) is satisfied
 --->
 $su (4.9) = 0.18779572$
 $Mu = MRc (4.14) = 2.0658E+008$
 $u = su (4.1) = 3.0306889E-005$

Calculation of ratio l_b/l_d

Inadequate Lap Length with $l_b/l_d = 0.30$

Calculation of $Mu1$ -

Calculation of ultimate curvature u according to 4.1, Biskinis/Fardis 2013:

$u = 3.0889637E-005$
 $Mu = 2.4003E+008$

with full section properties:

$b = 3000.00$
 $d = 208.00$
 $d' = 42.00$
 $v = 0.00176852$
 $N = 27588.841$
 $fc = 25.00$
 $co (5A.5, TBDY) = 0.002$
 Final value of cu : $cu^* = \text{shear_factor} * \text{Max}(cu, cc) = 0.0035$
 The Shear_factor is considered equal to 1 (pure moment strength)
 From (5.4b), TBDY: $cu = 0.0035$
 $we ((5.4c), TBDY) = ase * sh_{min} * fy_{we}/f_{ce} + \text{Min}(fx, fy) = 0.00$
 where $f = af * pf * f_{fe}/f_{ce}$ is accounting for FRP contribution like EC8-part3 A.4.4.3(6)

 $fx = 0.00$
 $af = 0.00$
 $b = 250.00$
 $h = 3000.00$
 From EC8 A.4.4.3(6), $pf = 2tf/bw = 0.008128$

bw = 250.00
effective stress from (A.35), $f_{f,e} = 757.2164$

fy = 0.00
af = 0.00
b = 3000.00
h = 250.00
From EC8 A4.4.3(6), $p_f = 2t_f/bw = 0.00067733$
bw = 3000.00
effective stress from (A.35), $f_{f,e} = 954.4864$

R = 40.00
Effective FRP thickness, $t_f = NL \cdot t \cdot \cos(b_1) = 1.016$
fu,f = 1055.00
Ef = 64828.00
u,f = 0.015
ase ((5.4d), TBDY) = $(ase_1 \cdot A_{col1} + ase_2 \cdot A_{col2} + ase_3 \cdot A_{web}) / A_{sec} = 0.00$

ase1 = 0.00
sh_1 = 150.00
bo_1 = 190.00
ho_1 = 540.00
bi2_1 = 655400.00

ase2 = 0.00
sh_2 = 150.00
bo_2 = 190.00
ho_2 = 540.00
bi2_2 = 655400.00

ase3 = 0 (grid does not provide confinement)

psh,min = Min(psh,x , psh,y) = 0.00069813

Expression ((5.4d), TBDY) for psh,min has been multiplied by 0.3 according to 15.7.1.3 for members without earthquake detailing (90° closed stirrups)

psh,x = $ps_{1,x} + ps_{2,x} + ps_{3,x} = 0.00356047$
 $ps_{1,x}$ (column 1) = $(As_1 \cdot h_1 / s_1) / A_c = 0.00083776$
h1 = 600.00
 $As_1 = Astir_1 \cdot ns_1 = 157.0796$
No stirrups, ns1 = 2.00
 $ps_{2,x}$ (column 2) = $(As_2 \cdot h_2 / s_2) / A_c = 0.00083776$
h2 = 600.00
 $As_2 = Astir_2 \cdot ns_2 = 157.0796$
No stirrups, ns2 = 2.00
 $ps_{3,x}$ (web) = $(As_3 \cdot h_3 / s_3) / A_c = 0.00188496$
h3 = 1800.00
 $As_3 = Astir_3 \cdot ns_3 = 0.00$
No stirrups, ns3 = 2.00

psh,y = $ps_{1,y} + ps_{2,y} + ps_{3,y} = 0.00069813$
 $ps_{1,y}$ (column 1) = $(As_1 \cdot h_1 / s_1) / A_c = 0.00034907$
h1 = 250.00
 $As_1 = Astir_1 \cdot ns_1 = 157.0796$
No stirrups, ns1 = 2.00
 $ps_{2,y}$ (column 2) = $(As_2 \cdot h_2 / s_2) / A_c = 0.00034907$
h2 = 250.00
 $As_2 = Astir_2 \cdot ns_2 = 157.0796$
No stirrups, ns2 = 2.00
 $ps_{3,y}$ (web) = $(As_3 \cdot h_3 / s_3) / A_c = 0.00$
h3 = 250.00
 $As_3 = Astir_3 \cdot ns_3 = 157.0796$
No stirrups, ns3 = 0.00

Asec = 750000.00
s_1 = 150.00
s_2 = 150.00
s_3 = 200.00

fywe = 625.00
fce = 25.00

From ((5.A5), TBDY), TBDY: cc = 0.00202463

```

c = confinement factor = 1.00246
y1 = 0.00140044
sh1 = 0.0044814
ft1 = 420.1317
fy1 = 350.1097
su1 = 0.00512
using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00
lo/lou,min = lb/ld = 0.30
su1 = 0.4*esu1_nominal ((5.5), TBDY) = 0.032
From table 5A.1, TBDY: esu1_nominal = 0.08,
For calculation of esu1_nominal and y1, sh1,ft1,fy1, it is considered
characteristic value fsy1 = fs1/1.2, from table 5.1, TBDY.
y1, sh1,ft1,fy1, are also multiplied by Min(1,1.25*(lb/ld)^ 2/3), from 10.3.5, ASCE 41-17.
with fs1 = fs = 350.1097
with Es1 = Es = 200000.00
y2 = 0.00140044
sh2 = 0.0044814
ft2 = 420.1317
fy2 = 350.1097
su2 = 0.00512
using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00
lo/lou,min = lb/lb,min = 0.30
su2 = 0.4*esu2_nominal ((5.5), TBDY) = 0.032
From table 5A.1, TBDY: esu2_nominal = 0.08,
For calculation of esu2_nominal and y2, sh2,ft2,fy2, it is considered
characteristic value fsy2 = fs2/1.2, from table 5.1, TBDY.
y1, sh1,ft1,fy1, are also multiplied by Min(1,1.25*(lb/ld)^ 2/3), from 10.3.5, ASCE 41-17.
with fs2 = fs = 350.1097
with Es2 = Es = 200000.00
yv = 0.00140044
shv = 0.0044814
ftv = 420.1317
fyv = 350.1097
suv = 0.00512
using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00
lo/lou,min = lb/ld = 0.30
suv = 0.4*esuv_nominal ((5.5), TBDY) = 0.032
From table 5A.1, TBDY: esuv_nominal = 0.08,
considering characteristic value fsyv = fsv/1.2, from table 5.1, TBDY
For calculation of esuv_nominal and yv, shv,ftv,fyv, it is considered
characteristic value fsyv = fsv/1.2, from table 5.1, TBDY.
y1, sh1,ft1,fy1, are also multiplied by Min(1,1.25*(lb/ld)^ 2/3), from 10.3.5, ASCE 41-17.
with fsv = fs = 350.1097
with Esv = Es = 200000.00
1 = Asl,ten/(b*d)*(fs1/fc) = 0.0635264
2 = Asl,com/(b*d)*(fs2/fc) = 0.0635264
v = Asl,mid/(b*d)*(fsv/fc) = 0.03609935
and confined core properties:
b = 2940.00
d = 178.00
d' = 12.00
fcc (5A.2, TBDY) = 25.06158
cc (5A.5, TBDY) = 0.00202463
c = confinement factor = 1.00246
1 = Asl,ten/(b*d)*(fs1/fc) = 0.07574806
2 = Asl,com/(b*d)*(fs2/fc) = 0.07574806
v = Asl,mid/(b*d)*(fsv/fc) = 0.0430444
Case/Assumption: Unconfined full section - Steel rupture
'satisfies Eq. (4.3)
--->
v < vs,y2 - LHS eq.(4.5) is satisfied

```

--->

$$su(4.9) = 0.20311835$$

$$Mu = MRc(4.14) = 2.4003E+008$$

$$u = su(4.1) = 3.0889637E-005$$

Calculation of ratio lb/ld

Inadequate Lap Length with $lb/ld = 0.30$

Calculation of Mu_{2+}

Calculation of ultimate curvature u according to 4.1, Biskinis/Fardis 2013:

$$u = 3.0306889E-005$$

$$Mu = 2.0658E+008$$

with full section properties:

$$b = 3000.00$$

$$d = 208.00$$

$$d' = 42.00$$

$$v = 0.00176852$$

$$N = 27588.841$$

$$f_c = 25.00$$

$$\alpha(5A.5, TBDY) = 0.002$$

$$\text{Final value of } cu: cu^* = \text{shear_factor} * \text{Max}(cu, cc) = 0.0035$$

The Shear_factor is considered equal to 1 (pure moment strength)

$$\text{From (5.4b), TBDY: } cu = 0.0035$$

$$w_e((5.4c), TBDY) = \alpha * sh_{min} * f_{ywe} / f_{ce} + \text{Min}(f_x, f_y) = 0.00$$

where $f = \alpha * p_f * f_{fe} / f_{ce}$ is accounting for FRP contribution like EC8-part3 A.4.4.3(6)

$$f_x = 0.00$$

$$\alpha_f = 0.00$$

$$b = 250.00$$

$$h = 3000.00$$

$$\text{From EC8 A.4.4.3(6), } p_f = 2t_f/bw = 0.008128$$

$$bw = 250.00$$

$$\text{effective stress from (A.35), } f_{fe} = 757.2164$$

$$f_y = 0.00$$

$$\alpha_f = 0.00$$

$$b = 3000.00$$

$$h = 250.00$$

$$\text{From EC8 A.4.4.3(6), } p_f = 2t_f/bw = 0.00067733$$

$$bw = 3000.00$$

$$\text{effective stress from (A.35), } f_{fe} = 954.4864$$

$$R = 40.00$$

$$\text{Effective FRP thickness, } t_f = NL * t * \cos(b_1) = 1.016$$

$$f_{u,f} = 1055.00$$

$$E_f = 64828.00$$

$$u_{f,f} = 0.015$$

$$\alpha se((5.4d), TBDY) = (\alpha se_1 * A_{col1} + \alpha se_2 * A_{col2} + \alpha se_3 * A_{web}) / A_{sec} = 0.00$$

$$\alpha se_1 = 0.00$$

$$sh_1 = 150.00$$

$$bo_1 = 190.00$$

$$ho_1 = 540.00$$

$$bi_{2,1} = 655400.00$$

$$\alpha se_2 = 0.00$$

$$sh_2 = 150.00$$

$$bo_2 = 190.00$$

$$ho_2 = 540.00$$

$$bi_{2,2} = 655400.00$$

$$\alpha se_3 = 0 \text{ (grid does not provide confinement)}$$

$psh,min = \text{Min}(psh,x, psh,y) = 0.00069813$
 Expression ((5.4d), TBDY) for psh,min has been multiplied by 0.3 according to 15.7.1.3 for members without earthquake detailing (90° closed stirrups)

$psh,x = ps1,x + ps2,x + ps3,x = 0.00356047$
 $ps1,x$ (column 1) = $(As1 \cdot h1 / s_1) / Ac = 0.00083776$
 $h1 = 600.00$
 $As1 = Astir1 \cdot ns1 = 157.0796$
 No stirrups, $ns1 = 2.00$
 $ps2,x$ (column 2) = $(As2 \cdot h2 / s_2) / Ac = 0.00083776$
 $h2 = 600.00$
 $As2 = Astir2 \cdot ns2 = 157.0796$
 No stirrups, $ns2 = 2.00$
 $ps3,x$ (web) = $(As3 \cdot h3 / s_3) / Ac = 0.00188496$
 $h3 = 1800.00$
 $As3 = Astir3 \cdot ns3 = 0.00$
 No stirrups, $ns3 = 2.00$

$psh,y = ps1,y + ps2,y + ps3,y = 0.00069813$
 $ps1,y$ (column 1) = $(As1 \cdot h1 / s_1) / Ac = 0.00034907$
 $h1 = 250.00$
 $As1 = Astir1 \cdot ns1 = 157.0796$
 No stirrups, $ns1 = 2.00$
 $ps2,y$ (column 2) = $(As2 \cdot h2 / s_2) / Ac = 0.00034907$
 $h2 = 250.00$
 $As2 = Astir2 \cdot ns2 = 157.0796$
 No stirrups, $ns2 = 2.00$
 $ps3,y$ (web) = $(As3 \cdot h3 / s_3) / Ac = 0.00$
 $h3 = 250.00$
 $As3 = Astir3 \cdot ns3 = 157.0796$
 No stirrups, $ns3 = 0.00$

$Asec = 750000.00$
 $s_1 = 150.00$
 $s_2 = 150.00$
 $s_3 = 200.00$
 $fywe = 625.00$
 $fce = 25.00$

From ((5.A5), TBDY), TBDY: $cc = 0.00202463$
 $c = \text{confinement factor} = 1.00246$

$y1 = 0.00140044$
 $sh1 = 0.0044814$
 $ft1 = 420.1317$
 $fy1 = 350.1097$
 $su1 = 0.00512$

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
 and also multiplied by the shear_factor according to 15.7.1.4, with
 $\text{Shear_factor} = 1.00$

$lo/lou,min = lb/ld = 0.30$

$su1 = 0.4 \cdot esu1_nominal$ ((5.5), TBDY) = 0.032

From table 5A.1, TBDY: $esu1_nominal = 0.08$,

For calculation of $esu1_nominal$ and $y1, sh1, ft1, fy1$, it is considered
 characteristic value $fsy1 = fs1/1.2$, from table 5.1, TBDY.

$y1, sh1, ft1, fy1$, are also multiplied by $\text{Min}(1, 1.25 \cdot (lb/ld)^{2/3})$, from 10.3.5, ASCE 41-17.

with $fs1 = fs = 350.1097$

with $Es1 = Es = 200000.00$

$y2 = 0.00140044$
 $sh2 = 0.0044814$
 $ft2 = 420.1317$
 $fy2 = 350.1097$
 $su2 = 0.00512$

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
 and also multiplied by the shear_factor according to 15.7.1.4, with
 $\text{Shear_factor} = 1.00$

$lo/lou,min = lb/lb,min = 0.30$

$su2 = 0.4 \cdot esu2_nominal$ ((5.5), TBDY) = 0.032

From table 5A.1, TBDY: $esu2_nominal = 0.08$,

For calculation of $es_{u2_nominal}$ and y_2 , $sh_{2,ft2,fy2}$, it is considered characteristic value $fs_{y2} = fs_2/1.2$, from table 5.1, TBDY.
 y_1 , $sh_{1,ft1,fy1}$, are also multiplied by $\text{Min}(1, 1.25 \cdot (l_b/l_d)^{2/3})$, from 10.3.5, ASCE 41-17.
 with $fs_2 = fs = 350.1097$
 with $Es_2 = Es = 200000.00$
 $y_v = 0.00140044$
 $sh_v = 0.0044814$
 $ft_v = 420.1317$
 $fy_v = 350.1097$
 $s_{uv} = 0.00512$
 using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
 and also multiplied by the shear_factor according to 15.7.1.4, with
 Shear_factor = 1.00
 $l_o/l_{ou,min} = l_b/l_d = 0.30$
 $s_{uv} = 0.4 \cdot es_{uv_nominal} ((5.5), TBDY) = 0.032$
 From table 5A.1, TBDY: $es_{uv_nominal} = 0.08$,
 considering characteristic value $fs_{yv} = f_{sv}/1.2$, from table 5.1, TBDY
 For calculation of $es_{uv_nominal}$ and y_v , sh_v , ft_v , fy_v , it is considered characteristic value $fs_{yv} = f_{sv}/1.2$, from table 5.1, TBDY.
 y_1 , $sh_{1,ft1,fy1}$, are also multiplied by $\text{Min}(1, 1.25 \cdot (l_b/l_d)^{2/3})$, from 10.3.5, ASCE 41-17.
 with $f_{sv} = fs = 350.1097$
 with $Es_v = Es = 200000.00$
 $1 = A_{sl,ten}/(b \cdot d) \cdot (f_{s1}/f_c) = 0.0635264$
 $2 = A_{sl,com}/(b \cdot d) \cdot (f_{s2}/f_c) = 0.0635264$
 $v = A_{sl,mid}/(b \cdot d) \cdot (f_{sv}/f_c) = 0.00$
 and confined core properties:
 $b = 2940.00$
 $d = 178.00$
 $d' = 12.00$
 $f_{cc} (5A.2, TBDY) = 25.06158$
 $cc (5A.5, TBDY) = 0.00202463$
 $c = \text{confinement factor} = 1.00246$
 $1 = A_{sl,ten}/(b \cdot d) \cdot (f_{s1}/f_c) = 0.07574806$
 $2 = A_{sl,com}/(b \cdot d) \cdot (f_{s2}/f_c) = 0.07574806$
 $v = A_{sl,mid}/(b \cdot d) \cdot (f_{sv}/f_c) = 0.00$
 Case/Assumption: Unconfined full section - Steel rupture
 ' satisfies Eq. (4.3)

--->
 $v < v_{s,y2}$ - LHS eq.(4.5) is satisfied
 --->
 $su (4.9) = 0.18779572$
 $Mu = MR_c (4.14) = 2.0658E+008$
 $u = su (4.1) = 3.0306889E-005$

 Calculation of ratio l_b/l_d

 Inadequate Lap Length with $l_b/l_d = 0.30$

Calculation of Mu_2 -

 Calculation of ultimate curvature u according to 4.1, Biskinis/Fardis 2013:

$u = 3.0889637E-005$
 $Mu = 2.4003E+008$

with full section properties:

$b = 3000.00$
 $d = 208.00$
 $d' = 42.00$
 $v = 0.00176852$
 $N = 27588.841$
 $f_c = 25.00$
 $co (5A.5, TBDY) = 0.002$

Final value of cu : $\text{cu}^* = \text{shear_factor} * \text{Max}(\text{cu}, \text{cc}) = 0.0035$

The Shear_factor is considered equal to 1 (pure moment strength)

From (5.4b), TBDY: $\text{cu} = 0.0035$

$\text{we} ((5.4c), \text{TBDY}) = \text{ase} * \text{sh}_{\min} * \text{fy}_{\text{we}} / \text{f}_{\text{ce}} + \text{Min}(\text{fx}, \text{fy}) = 0.00$

where $\text{f} = \text{af} * \text{pf} * \text{ffe} / \text{f}_{\text{ce}}$ is accounting for FRP contribution like EC8-part3 A.4.4.3(6)

 $\text{fx} = 0.00$

$\text{af} = 0.00$

$\text{b} = 250.00$

$\text{h} = 3000.00$

From EC8 A4.4.3(6), $\text{pf} = 2\text{tf}/\text{bw} = 0.008128$

$\text{bw} = 250.00$

effective stress from (A.35), $\text{ff}_{\text{e}} = 757.2164$

 $\text{fy} = 0.00$

$\text{af} = 0.00$

$\text{b} = 3000.00$

$\text{h} = 250.00$

From EC8 A4.4.3(6), $\text{pf} = 2\text{tf}/\text{bw} = 0.00067733$

$\text{bw} = 3000.00$

effective stress from (A.35), $\text{ff}_{\text{e}} = 954.4864$

 $\text{R} = 40.00$

Effective FRP thickness, $\text{tf} = \text{NL} * \text{t} * \text{Cos}(\text{b}_1) = 1.016$

$\text{fu}_{\text{f}} = 1055.00$

$\text{Ef} = 64828.00$

$\text{u}_{\text{f}} = 0.015$

$\text{ase} ((5.4d), \text{TBDY}) = (\text{ase}_1 * \text{A}_{\text{col1}} + \text{ase}_2 * \text{A}_{\text{col2}} + \text{ase}_3 * \text{A}_{\text{web}}) / \text{A}_{\text{sec}} = 0.00$

$\text{ase}_1 = 0.00$

$\text{sh}_1 = 150.00$

$\text{bo}_1 = 190.00$

$\text{ho}_1 = 540.00$

$\text{bi}_{2,1} = 655400.00$

$\text{ase}_2 = 0.00$

$\text{sh}_2 = 150.00$

$\text{bo}_2 = 190.00$

$\text{ho}_2 = 540.00$

$\text{bi}_{2,2} = 655400.00$

$\text{ase}_3 = 0$ (grid does not provide confinement)

$\text{psh}_{\min} = \text{Min}(\text{psh}_x, \text{psh}_y) = 0.00069813$

Expression ((5.4d), TBDY) for psh_{\min} has been multiplied by 0.3 according to 15.7.1.3 for members without earthquake detailing (90° closed stirrups)

 $\text{psh}_x = \text{ps}_{1,x} + \text{ps}_{2,x} + \text{ps}_{3,x} = 0.00356047$

$\text{ps}_{1,x}$ (column 1) = $(\text{As}_1 * \text{h}_1 / \text{s}_1) / \text{Ac} = 0.00083776$

$\text{h}_1 = 600.00$

$\text{As}_1 = \text{Astir}_1 * \text{ns}_1 = 157.0796$

No stirrups, $\text{ns}_1 = 2.00$

$\text{ps}_{2,x}$ (column 2) = $(\text{As}_2 * \text{h}_2 / \text{s}_2) / \text{Ac} = 0.00083776$

$\text{h}_2 = 600.00$

$\text{As}_2 = \text{Astir}_2 * \text{ns}_2 = 157.0796$

No stirrups, $\text{ns}_2 = 2.00$

$\text{ps}_{3,x}$ (web) = $(\text{As}_3 * \text{h}_3 / \text{s}_3) / \text{Ac} = 0.00188496$

$\text{h}_3 = 1800.00$

$\text{As}_3 = \text{Astir}_3 * \text{ns}_3 = 0.00$

No stirrups, $\text{ns}_3 = 2.00$

 $\text{psh}_y = \text{ps}_{1,y} + \text{ps}_{2,y} + \text{ps}_{3,y} = 0.00069813$

$\text{ps}_{1,y}$ (column 1) = $(\text{As}_1 * \text{h}_1 / \text{s}_1) / \text{Ac} = 0.00034907$

$\text{h}_1 = 250.00$

$\text{As}_1 = \text{Astir}_1 * \text{ns}_1 = 157.0796$

No stirrups, $\text{ns}_1 = 2.00$

$\text{ps}_{2,y}$ (column 2) = $(\text{As}_2 * \text{h}_2 / \text{s}_2) / \text{Ac} = 0.00034907$

$\text{h}_2 = 250.00$

$\text{As}_2 = \text{Astir}_2 * \text{ns}_2 = 157.0796$

No stirrups, $\text{ns}_2 = 2.00$

$\text{ps}_{3,y}$ (web) = $(\text{As}_3 * \text{h}_3 / \text{s}_3) / \text{Ac} = 0.00$

h3 = 250.00
As3 = Astir3*ns3 = 157.0796
No stirups, ns3 = 0.00

Asec = 750000.00

s_1 = 150.00

s_2 = 150.00

s_3 = 200.00

fywe = 625.00

fce = 25.00

From ((5.A5), TBDY), TBDY: cc = 0.00202463

c = confinement factor = 1.00246

y1 = 0.00140044

sh1 = 0.0044814

ft1 = 420.1317

fy1 = 350.1097

su1 = 0.00512

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00

lo/lou,min = lb/ld = 0.30

su1 = 0.4*esu1_nominal ((5.5), TBDY) = 0.032

From table 5A.1, TBDY: esu1_nominal = 0.08,

For calculation of esu1_nominal and y1, sh1,ft1,fy1, it is considered
characteristic value fsy1 = fs1/1.2, from table 5.1, TBDY.

y1, sh1,ft1,fy1, are also multiplied by $\text{Min}(1, 1.25 \cdot (lb/ld)^{2/3})$, from 10.3.5, ASCE 41-17.

with fs1 = fs = 350.1097

with Es1 = Es = 200000.00

y2 = 0.00140044

sh2 = 0.0044814

ft2 = 420.1317

fy2 = 350.1097

su2 = 0.00512

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00

lo/lou,min = lb/lb,min = 0.30

su2 = 0.4*esu2_nominal ((5.5), TBDY) = 0.032

From table 5A.1, TBDY: esu2_nominal = 0.08,

For calculation of esu2_nominal and y2, sh2,ft2,fy2, it is considered
characteristic value fsy2 = fs2/1.2, from table 5.1, TBDY.

y1, sh1,ft1,fy1, are also multiplied by $\text{Min}(1, 1.25 \cdot (lb/ld)^{2/3})$, from 10.3.5, ASCE 41-17.

with fs2 = fs = 350.1097

with Es2 = Es = 200000.00

yv = 0.00140044

shv = 0.0044814

ftv = 420.1317

fyv = 350.1097

suv = 0.00512

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00

lo/lou,min = lb/ld = 0.30

suv = 0.4*esuv_nominal ((5.5), TBDY) = 0.032

From table 5A.1, TBDY: esuv_nominal = 0.08,

considering characteristic value fsyv = fsv/1.2, from table 5.1, TBDY

For calculation of esuv_nominal and yv, shv,ftv,fyv, it is considered
characteristic value fsyv = fsv/1.2, from table 5.1, TBDY.

y1, sh1,ft1,fy1, are also multiplied by $\text{Min}(1, 1.25 \cdot (lb/ld)^{2/3})$, from 10.3.5, ASCE 41-17.

with fsv = fs = 350.1097

with Esv = Es = 200000.00

1 = Asl,ten/(b*d)*(fs1/fc) = 0.0635264

2 = Asl,com/(b*d)*(fs2/fc) = 0.0635264

v = Asl,mid/(b*d)*(fsv/fc) = 0.03609935

and confined core properties:

b = 2940.00

d = 178.00

$d' = 12.00$
 $f_{cc} (5A.2, TBDY) = 25.06158$
 $cc (5A.5, TBDY) = 0.00202463$
 $c = \text{confinement factor} = 1.00246$
 $1 = A_{sl,ten}/(b*d)*(f_{s1}/f_c) = 0.07574806$
 $2 = A_{sl,com}/(b*d)*(f_{s2}/f_c) = 0.07574806$
 $v = A_{sl,mid}/(b*d)*(f_{sv}/f_c) = 0.0430444$
 Case/Assumption: Unconfined full section - Steel rupture
 ' satisfies Eq. (4.3)

--->
 $v < v_{s,y2}$ - LHS eq.(4.5) is satisfied
 --->

$\mu (4.9) = 0.20311835$
 $\mu_u = M_{Rc} (4.14) = 2.4003E+008$
 $u = \mu (4.1) = 3.0889637E-005$

Calculation of ratio l_b/d

Inadequate Lap Length with $l_b/d = 0.30$

Calculation of Shear Strength $V_r = \text{Min}(V_{r1}, V_{r2}) = 1.0244E+006$

Calculation of Shear Strength at edge 1, $V_{r1} = 1.0244E+006$
 From (22.5.1.1) and 11.5.4.3, ACI 318-14: $V_{r1} = V_n < 0.83*f'_c^{0.5}*h*d$

NOTE: In expression (22.5.1.1) ' V_w ' is replaced by ' $V_w + f*V_f$ '
 where V_f is the contribution of FRPs (11.3), ACI 440).

From Table (11.5.4.6(d-e)), ACI 318-14: $V_c = 815517.768$
 $\mu_u/V_u - l_w/2 = 0.00 \leq 0$
 $= 1$ (normal-weight concrete)
 $f'_c = 25.00$, but $f'_c^{0.5} \leq 8.3$ MPa (22.5.3.1, ACI 318-14)
 $h = 3000.00$
 $d = 200.00$
 $l_w = 250.00$
 $\mu_u = 3.7289358E-011$
 $V_u = 1.7354940E-029$
 $N_u = 27588.841$

From (11.5.4.8), ACI 318-14: $V_s = V_{s1} + V_{s2} + V_{s3} = 104719.755$
 $V_{s1} = 52359.878$ is calculated for pseudo-Column 1, with:
 $d = 200.00$
 $A_v = 157079.633$
 $s = 150.00$
 $f_y = 500.00$
 V_{s1} has been multiplied by $2(1-s/d)$ ($s > d/2$, according to ASCE 41-17,10.3.4)

$2(1-s/d) = 0.50$
 $V_{s2} = 52359.878$ is calculated for pseudo-Column 2, with:
 $d = 200.00$
 $A_v = 157079.633$
 $s = 150.00$
 $f_y = 500.00$
 V_{s2} has been multiplied by $2(1-s/d)$ ($s > d/2$, according to ASCE 41-17,10.3.4)

$2(1-s/d) = 0.50$
 $V_{s3} = 0.00$ is calculated for web, with:
 $d = 200.00$
 $A_v = 0.00$
 $s = 200.00$
 $f_y = 500.00$
 V_{s3} has been multiplied by $2(1-s/d)$ ($s > d/2$, according to ASCE 41-17,10.3.4)

$2(1-s/d) = 0.00$
 $V_f ((11-3)-(11.4), ACI 440) = 109599.773$
 $f = 0.95$, for fully-wrapped sections
 $w_f/s_f = 1$ (FRP strips adjacent to one another).

In (11.3) $\sin \theta + \cos \theta$ is replaced with $(\cot \theta + \cot \alpha) \sin \alpha$ which is more a generalised expression, where θ is the angle of the crack direction (see KANEPE).
 This later relation, considered as a function $V_f(\theta, \alpha)$, is implemented for every different fiber orientation α_i , as well as for 2 crack directions, $\theta = 45^\circ$ and $\theta = -45^\circ$ to take into consideration the cyclic seismic loading.
 orientation 1: $\theta_1 = \theta_1 + 90^\circ = 90.00$
 $V_f = \text{Min}(|V_f(45, \theta_1)|, |V_f(-45, \alpha_1)|)$, with:
 total thickness per orientation, $t_{f1} = N_L \cdot t / N_{\text{Dir}} = 1.016$
 $d_{fv} = d$ (figure 11.2, ACI 440) = 208.00
 $f_{fe}((11-5), \text{ACI 440}) = 259.312$
 $E_f = 64828.00$
 $f_e = 0.004$, from (11.6a), ACI 440
 with $f_u = 0.01$
 From (11-11), ACI 440: $V_s + V_f \leq 1.9929E+006$
 $b_w = 3000.00$

Calculation of Shear Strength at edge 2, $V_{r2} = 1.0244E+006$
 From (22.5.1.1) and 11.5.4.3, ACI 318-14: $V_{r2} = V_n < 0.83 \cdot f_c' \cdot h \cdot d$

NOTE: In expression (22.5.1.1) ' V_w ' is replaced by ' $V_w + f \cdot V_f$ '
 where V_f is the contribution of FRPs (11.3), ACI 440).

From Table (11.5.4.6(d-e)), ACI 318-14: $V_c = 815517.768$
 $\mu_u / V_u - l_w / 2 = 0.00 \leq 0$
 $= 1$ (normal-weight concrete)
 $f_c' = 25.00$, but $f_c' \cdot 0.5 \leq 8.3$ MPa (22.5.3.1, ACI 318-14)
 $h = 3000.00$
 $d = 200.00$
 $l_w = 250.00$
 $\mu_u = 3.7289358E-011$
 $V_u = 1.7354940E-029$
 $N_u = 27588.841$
 From (11.5.4.8), ACI 318-14: $V_s = V_{s1} + V_{s2} + V_{s3} = 104719.755$
 $V_{s1} = 52359.878$ is calculated for pseudo-Column 1, with:
 $d = 200.00$
 $A_v = 157079.633$
 $s = 150.00$
 $f_y = 500.00$
 V_{s1} has been multiplied by $2(1-s/d)$ ($s > d/2$, according to ASCE 41-17,10.3.4)
 $2(1-s/d) = 0.50$
 $V_{s2} = 52359.878$ is calculated for pseudo-Column 2, with:
 $d = 200.00$
 $A_v = 157079.633$
 $s = 150.00$
 $f_y = 500.00$
 V_{s2} has been multiplied by $2(1-s/d)$ ($s > d/2$, according to ASCE 41-17,10.3.4)
 $2(1-s/d) = 0.50$
 $V_{s3} = 0.00$ is calculated for web, with:
 $d = 200.00$
 $A_v = 0.00$
 $s = 200.00$
 $f_y = 500.00$
 V_{s3} has been multiplied by $2(1-s/d)$ ($s > d/2$, according to ASCE 41-17,10.3.4)
 $2(1-s/d) = 0.00$
 $V_f((11-3)-(11.4), \text{ACI 440}) = 109599.773$
 $f = 0.95$, for fully-wrapped sections
 $w_f / s_f = 1$ (FRP strips adjacent to one another).
 In (11.3) $\sin \theta + \cos \theta$ is replaced with $(\cot \theta + \cot \alpha) \sin \alpha$ which is more a generalised expression, where θ is the angle of the crack direction (see KANEPE).
 This later relation, considered as a function $V_f(\theta, \alpha)$, is implemented for every different fiber orientation α_i , as well as for 2 crack directions, $\theta = 45^\circ$ and $\theta = -45^\circ$ to take into consideration the cyclic seismic loading.
 orientation 1: $\theta_1 = \theta_1 + 90^\circ = 90.00$
 $V_f = \text{Min}(|V_f(45, \theta_1)|, |V_f(-45, \alpha_1)|)$, with:
 total thickness per orientation, $t_{f1} = N_L \cdot t / N_{\text{Dir}} = 1.016$
 $d_{fv} = d$ (figure 11.2, ACI 440) = 208.00
 $f_{fe}((11-5), \text{ACI 440}) = 259.312$
 $E_f = 64828.00$
 $f_e = 0.004$, from (11.6a), ACI 440

with $f_u = 0.01$
From (11-11), ACI 440: $V_s + V_f \leq 1.9929E+006$
 $b_w = 3000.00$

End Of Calculation of Shear Capacity ratio for element: wall W1 of floor 1
At local axis: 2

Start Of Calculation of Chord Rotation Capacity for element: wall W1 of floor 1
At local axis: 2
Integration Section: (a)
Section Type: rcrrws

Constant Properties

Knowledge Factor, $\gamma = 1.00$
According to 10.7.2.3, ASCE 41-17, shear walls with
transverse reinforcement percentage, $n < 0.0015$
are considered Force-Controlled and lower-bound strengths are used according to 7.5.1.3, ASCE 41-17
 $n = 0.00069813$

with $n = ps1 + ps2 + ps3$, being the shear reinf. ratio in a plane perpendicular to the shear axis 3
(pseudo-col.1 $ps1 = A_{s1} \cdot b1/s1 = (A_{s1} \cdot h1/s1) / A_c = 0.00034907$
 $h1 = 250.00$
 $s1 = 150.00$
total area of hoops perpendicular to shear axis, $A_{s1} = 157.0796$
(pseudo-col.2 $ps2 = A_{s2} \cdot b2/s2 = (A_{s2} \cdot h2/s2) / A_c = 0.00034907$
 $h2 = 250.00$
 $s2 = 150.00$
total area of hoops perpendicular to shear axis, $A_{s2} = 157.0796$
(grid $ps3 = A_{s3} \cdot b3/s3 = (A_{s3} \cdot h3/s3) / A_c = 0.00$
 $h3 = 250.00$
 $s3 = 200.00$
total area of hoops perpendicular to shear axis, $A_{s3} = 0.00$
total section area, $A_c = 750000.00$

Consequently:

New material of Secondary Member: Concrete Strength, $f_c = f_{c_lower_bound} = 25.00$
New material of Secondary Member: Steel Strength, $f_s = f_{s_lower_bound} = 500.00$
Concrete Elasticity, $E_c = 26999.444$
Steel Elasticity, $E_s = 200000.00$
Total Height, $H_{tot} = 3000.00$
Edges Width, $W_{edg} = 250.00$
Edges Height, $H_{edg} = 600.00$
Web Width, $W_{web} = 250.00$
Cover Thickness, $c = 25.00$
Element Length, $L = 3000.00$
Secondary Member
Smooth Bars
Ductile Steel
Without Detailing for Earthquake Resistance (including stirrups not closed at 135°)
Longitudinal Bars With Ends Lapped Starting at the End Sections
Inadequate Lap Length with $l_b/l_d = 0.30$
FRP Wrapping Data
Type: Carbon
Cured laminate properties (design values)
Thickness, $t = 1.016$
Tensile Strength, $f_{fu} = 1055.00$
Tensile Modulus, $E_f = 64828.00$
Elongation, $efu = 0.01$
Number of directions, $NoDir = 1$
Fiber orientations, $bi: 0.00^\circ$
Number of layers, $NL = 1$
Radius of rounding corners, $R = 40.00$

Stepwise Properties

Axial Force, $F = -33005.924$

Longitudinal Reinforcement Area Distribution (in 2 divisions)

-Tension: $As_t = 0.00$

-Compression: $As_c = 7269.645$

Longitudinal Reinforcement Area Distribution (in 3 divisions)

-Tension: $As_{t,ten} = 2865.133$

-Compression: $As_{c,com} = 2865.133$

-Middle: $As_{mid} = 1539.38$

Mean Diameter of Tension Reinforcement, $Db_L = 17.33333$

Considering wall controlled by Shear (shear control ratio > 1),
interstorey drift provided values are calculated

New component: From table 7-7, ASCE 41_17: Final chord rotation Capacity $u_R = 1.0^*$ $u = 0.004$

from table 10-20: $u = 0.004$

with:

- Condition i (shear wall and wall segments)

- $(As - As') \cdot f_y + P / (t_w \cdot l_w \cdot f_c') = -0.19209689$

$As = 0.00$

$As' = 7269.645$

$f_y = 500.00$

$P = 33005.924$

$t_w = 250.00$

$l_w = 3000.00$

$f_c = 25.00$

End Of Calculation of Chord Rotation Capacity for element: wall W1 of floor 1

At local axis: 2

Integration Section: (a)

Calculation No. 7

wall W1, Floor 1

Limit State: Operational Level (data interpolation between analysis steps 1 and 2)

Analysis: Uniform +X

Check: Shear capacity VR_d

Edge: End

Local Axis: (3)



Start Of Calculation of Shear Capacity for element: wall W1 of floor 1

At local axis: 3

Integration Section: (d)

Section Type: rcrws

Constant Properties

Knowledge Factor, $\gamma = 1.00$

Member Shear Force is generally considered as Force-Controlled Action according to Table C7-1, ASCE 41-17.

Lower-bound strengths are used for Force-Controlled Actions according to 7.5.1.3, ASCE 41-17

Consequently:

New material of Secondary Member: Concrete Strength, $f_c = f_{c_lower_bound} = 25.00$

New material of Secondary Member: Steel Strength, $f_s = f_{s_lower_bound} = 500.00$

Concrete Elasticity, $E_c = 26999.444$

Steel Elasticity, $E_s = 200000.00$

Total Height, $H_{tot} = 3000.00$

Edges Width, $W_{edg} = 250.00$

Edges Height, $H_{edg} = 600.00$

Web Width, $W_{web} = 250.00$

Cover Thickness, $c = 25.00$

Element Length, $L = 3000.00$

Secondary Member

Smooth Bars

Ductile Steel

Without Detailing for Earthquake Resistance (including stirrups not closed at 135°)

Longitudinal Bars With Ends Lapped Starting at the End Sections

Inadequate Lap Length with $l_o/l_{ou,min} = l_b/l_d = 0.30$

FRP Wrapping Data

Type: Carbon

Cured laminate properties (design values)

Thickness, $t = 1.016$

Tensile Strength, $f_{fu} = 1055.00$

Tensile Modulus, $E_f = 64828.00$

Elongation, $\epsilon_{fu} = 0.01$

Number of directions, $N_{oDir} = 1$

Fiber orientations, $b_i: 0.00^\circ$

Number of layers, $N_L = 1$

Radius of rounding corners, $R = 40.00$

Stepwise Properties

EDGE -A-

Bending Moment, $M_a = 9.7363E+007$

Shear Force, $V_a = -32914.791$

EDGE -B-

Bending Moment, $M_b = 1.4016E+006$

Shear Force, $V_b = 32914.791$

BOTH EDGES

Axial Force, $F = -33005.924$

Longitudinal Reinforcement Area Distribution (in 2 divisions)

-Tension: $As_t = 0.00$

-Compression: $Asl_{com} = 7269.645$
 Longitudinal Reinforcement Area Distribution (in 3 divisions)
 -Tension: $Asl_{ten} = 2865.133$
 -Compression: $Asl_{com} = 2865.133$
 -Middle: $Asl_{mid} = 1539.38$
 Mean Diameter of Tension Reinforcement, $DbL_{ten} = 17.33333$

New component: From table 7-7, ASCE 41_17: Final Shear Capacity $V_R = 1.0 \cdot V_n = 2.4900E+006$
 From (22.5.1.1) and 11.5.4.3, ACI 318-14: $V_n < 0.83 \cdot f_c' \cdot 0.5 \cdot h \cdot d = 2.4900E+006$

NOTE: In expression (22.5.1.1) ' V_w ' is replaced by ' $V_w + f \cdot V_f$ '
 where V_f is the contribution of FRPs (11.3), ACI 440).

From Table (11.5.4.6(d-e)), ACI 318-14: $V_c = 816601.185$
 $M_u/V_u - l_w/2 = -1457.417 \leq 0$
 $= 1$ (normal-weight concrete)
 $f_c' = 25.00$, but $f_c' \cdot 0.5 \leq 8.3$ MPa (22.5.3.1, ACI 318-14)
 $h = 250.00$
 $d = 2400.00$
 $l_w = 3000.00$
 $M_u = 1.4016E+006$
 $V_u = 32914.791$
 $N_u = 33005.924$
 From (11.5.4.8), ACI 318-14: $V_s = V_{s1} + V_{s2} + V_{s3} = 1.0681E+006$
 $V_{s1} = 251327.412$ is calculated for pseudo-Column 1, with:
 $d = 480.00$
 $A_v = 157079.633$
 $s = 150.00$
 $f_y = 500.00$
 V_{s1} has been multiplied by 1 ($s < d/2$, according to ASCE 41-17,10.3.4)
 $V_{s2} = 251327.412$ is calculated for pseudo-Column 2, with:
 $d = 480.00$
 $A_v = 157079.633$
 $s = 150.00$
 $f_y = 500.00$
 V_{s2} has been multiplied by 1 ($s < d/2$, according to ASCE 41-17,10.3.4)
 $V_{s3} = 565486.678$ is calculated for web, with:
 $d = 1440.00$
 $A_v = 157079.633$
 $s = 200.00$
 $f_y = 500.00$
 V_{s3} has been multiplied by 1 ($s < d/2$, according to ASCE 41-17,10.3.4)
 V_f ((11-3)-(11.4), ACI 440) = $1.5581E+006$
 $f = 0.95$, for fully-wrapped sections
 $w_f/s_f = 1$ (FRP strips adjacent to one another).
 In (11.3) $\sin + \cos$ is replaced with $(\cot + \cot a) \sin a$ which is more a generalised expression,
 where a is the angle of the crack direction (see KANEPE).
 This later relation, considered as a function $V_f(\theta)$, is implemented for every different fiber orientation a_i ,
 as well as for 2 crack directions, $\theta = 45^\circ$ and $\theta = -45^\circ$ to take into consideration the cyclic seismic loading.
 orientation 1: $\theta = b1 + 90^\circ = 90.00$
 $V_f = \text{Min}(|V_f(45, \theta)|, |V_f(-45, a1)|)$, with:
 total thickness per orientation, $t_{f1} = N_L \cdot t / N_{oDir} = 1.016$
 $d_{fv} = d$ (figure 11.2, ACI 440) = 2957.00
 f_{fe} ((11-5), ACI 440) = 259.312
 $E_f = 64828.00$
 $f_{fe} = 0.004$, from (11.6a), ACI 440
 with $f_u = 0.01$
 From (11-11), ACI 440: $V_s + V_f \leq 1.9929E+006$
 $b_w = 250.00$

End Of Calculation of Shear Capacity for element: wall W1 of floor 1
 At local axis: 3
 Integration Section: (d)

Calculation No. 8

wall W1, Floor 1

Limit State: Operational Level (data interpolation between analysis steps 1 and 2)

Analysis: Uniform +X

Check: Chord rotation capacity (ϕ)

Edge: End

Local Axis: (3)



Start Of Calculation of Shear Capacity ratio for element: wall W1 of floor 1

At Shear local axis: 3

(Bending local axis: 2)

Section Type: rcwls

Constant Properties

Knowledge Factor, $\gamma = 1.00$

Mean strength values are used for both shear and moment calculations.

Consequently:

New material of Secondary Member: Concrete Strength, $f_c = f_{cm} = 25.00$

New material of Secondary Member: Steel Strength, $f_s = f_{sm} = 500.00$

Concrete Elasticity, $E_c = 26999.444$

Steel Elasticity, $E_s = 200000.00$

#####

Note: Especially for the calculation of moment strengths,

the above steel re-bar strengths are multiplied by 1.25 according to R18.6.5, ACI 318-14

New material: Steel Strength, $f_s = 1.25 \cdot f_{sm} = 625.00$

#####

Total Height, $H_{tot} = 3000.00$

Edges Width, $W_{edg} = 250.00$

Edges Height, $H_{edg} = 600.00$

Web Width, $W_{web} = 250.00$

Cover Thickness, $c = 25.00$

Mean Confinement Factor overall section = 1.00246

Element Length, $L = 3000.00$

Secondary Member

Smooth Bars

Ductile Steel

Without Detailing for Earthquake Resistance (including stirrups not closed at 135°)
Longitudinal Bars With Ends Lapped Starting at the End Sections
Inadequate Lap Length with $l_o/l_{ou,min} = 0.30$
FRP Wrapping Data
Type: Carbon
Cured laminate properties (design values)
Thickness, $t = 1.016$
Tensile Strength, $f_{fu} = 1055.00$
Tensile Modulus, $E_f = 64828.00$
Elongation, $\epsilon_{fu} = 0.01$
Number of directions, $NoDir = 1$
Fiber orientations, $b_i: 0.00^\circ$
Number of layers, $NL = 1$
Radius of rounding corners, $R = 40.00$

Stepwise Properties

At local axis: 3
EDGE -A-
Shear Force, $V_a = 1.0097420E-028$
EDGE -B-
Shear Force, $V_b = -1.0097420E-028$
BOTH EDGES
Axial Force, $F = -27588.841$
Longitudinal Reinforcement Area Distribution (in 2 divisions)
-Tension: $As_t = 0.00$
-Compression: $As_c = 7269.645$
Longitudinal Reinforcement Area Distribution (in 3 divisions)
-Tension: $As_{t,ten} = 2865.133$
-Compression: $As_{c,com} = 2865.133$
-Middle: $As_{mid} = 0.00$
(According to 10.7.2.3 As_{mid} is setted equal to zero)

Calculation of Shear Capacity ratio, $V_e/V_r = 1.02813$
Member Controlled by Shear ($V_e/V_r > 1$)
Calculation of Shear Demand from fig. R18.6.5, ACI 318-14 $V_e = (M_{pr1} + M_{pr2})/l_n = 2.5600E+006$
with
 $M_{pr1} = \text{Max}(Mu_{1+}, Mu_{1-}) = 3.8401E+009$
 $Mu_{1+} = 3.3585E+009$, is the ultimate moment strength at the edge 1 of the member in the actual moment direction
which is defined for the static loading combination
 $Mu_{1-} = 3.8401E+009$, is the ultimate moment strength at the edge 1 of the member in the opposite moment
direction which is defined for the static loading combination
 $M_{pr2} = \text{Max}(Mu_{2+}, Mu_{2-}) = 3.8401E+009$
 $Mu_{2+} = 3.3585E+009$, is the ultimate moment strength at the edge 2 of the member in the actual moment direction
which is defined for the the static loading combination
 $Mu_{2-} = 3.8401E+009$, is the ultimate moment strength at the edge 2 of the member in the opposite moment
direction which is defined for the the static loading combination

Calculation of Mu_{1+}

Calculation of ultimate curvature ϕ_u according to 4.1, Biskinis/Fardis 2013:
 $\phi_u = 2.0296703E-006$
 $M_u = 3.3585E+009$

with full section properties:

$b = 250.00$
 $d = 2957.00$
 $d' = 43.00$
 $v = 0.0014928$
 $N = 27588.841$

$$f_c = 25.00$$

$$\alpha (5A.5, \text{TB DY}) = 0.002$$

$$\text{Final value of } \alpha: \alpha^* = \text{shear_factor} * \text{Max}(\alpha, \alpha_c) = 0.0035$$

The Shear_factor is considered equal to 1 (pure moment strength)

$$\text{From (5.4b), TB DY: } \alpha = 0.0035$$

$$\alpha_e ((5.4c), \text{TB DY}) = \alpha * \text{sh_min} * f_{ywe} / f_{ce} + \text{Min}(\alpha_x, \alpha_y) = 0.00$$

where $\alpha = \alpha_f * \rho_f * f_{fe} / f_{ce}$ is accounting for FRP contribution like EC8-part3 A.4.4.3(6)

$$\alpha_x = 0.00$$

$$\alpha_f = 0.00$$

$$b = 250.00$$

$$h = 3000.00$$

$$\text{From EC8 A4.4.3(6), } \rho_f = 2t_f / b_w = 0.008128$$

$$b_w = 250.00$$

$$\text{effective stress from (A.35), } f_{fe} = 757.2164$$

$$\alpha_y = 0.00$$

$$\alpha_f = 0.00$$

$$b = 3000.00$$

$$h = 250.00$$

$$\text{From EC8 A4.4.3(6), } \rho_f = 2t_f / b_w = 0.00067733$$

$$b_w = 3000.00$$

$$\text{effective stress from (A.35), } f_{fe} = 954.4864$$

$$R = 40.00$$

$$\text{Effective FRP thickness, } t_f = N L * t * \cos(b_1) = 1.016$$

$$f_{u,f} = 1055.00$$

$$E_f = 64828.00$$

$$u_{f,f} = 0.015$$

$$\alpha_e ((5.4d), \text{TB DY}) = (\alpha_{e1} * A_{col1} + \alpha_{e2} * A_{col2} + \alpha_{e3} * A_{web}) / A_{sec} = 0.00$$

$$\alpha_{e1} = 0.00$$

$$sh_1 = 150.00$$

$$bo_1 = 190.00$$

$$ho_1 = 540.00$$

$$bi2_1 = 655400.00$$

$$\alpha_{e2} = 0.00$$

$$sh_2 = 150.00$$

$$bo_2 = 190.00$$

$$ho_2 = 540.00$$

$$bi2_2 = 655400.00$$

$\alpha_{e3} = 0$ (grid does not provide confinement)

$$\rho_{sh,min} = \text{Min}(\rho_{sh,x}, \rho_{sh,y}) = 0.00069813$$

Expression ((5.4d), TB DY) for $\rho_{sh,min}$ has been multiplied by 0.3 according to 15.7.1.3 for members without earthquake detailing (90° closed stirrups)

$$\rho_{sh,x} = \rho_{s1,x} + \rho_{s2,x} + \rho_{s3,x} = 0.00356047$$

$$\rho_{s1,x} (\text{column 1}) = (A_{s1} * h_1 / s_1) / A_c = 0.00083776$$

$$h_1 = 600.00$$

$$A_{s1} = A_{stir1} * n_{s1} = 157.0796$$

No stirrups, $n_{s1} = 2.00$

$$\rho_{s2,x} (\text{column 2}) = (A_{s2} * h_2 / s_2) / A_c = 0.00083776$$

$$h_2 = 600.00$$

$$A_{s2} = A_{stir2} * n_{s2} = 157.0796$$

No stirrups, $n_{s2} = 2.00$

$$\rho_{s3,x} (\text{web}) = (A_{s3} * h_3 / s_3) / A_c = 0.00188496$$

$$h_3 = 1800.00$$

$$A_{s3} = A_{stir3} * n_{s3} = 0.00$$

No stirrups, $n_{s3} = 2.00$

$$\rho_{sh,y} = \rho_{s1,y} + \rho_{s2,y} + \rho_{s3,y} = 0.00069813$$

$$\rho_{s1,y} (\text{column 1}) = (A_{s1} * h_1 / s_1) / A_c = 0.00034907$$

$$h_1 = 250.00$$

$$A_{s1} = A_{stir1} * n_{s1} = 157.0796$$

No stirrups, $n_{s1} = 2.00$

$$\rho_{s2,y} (\text{column 2}) = (A_{s2} * h_2 / s_2) / A_c = 0.00034907$$

$$h_2 = 250.00$$

$$A_{s2} = A_{stir2} * n_{s2} = 157.0796$$

No stirups, ns2 = 2.00
 $ps3,y \text{ (web)} = (As3 \cdot h3 / s_3) / A_c = 0.00$
 $h3 = 250.00$
 $As3 = Astir3 \cdot ns3 = 157.0796$
 No stirups, ns3 = 0.00

 $A_{sec} = 750000.00$
 $s_1 = 150.00$
 $s_2 = 150.00$
 $s_3 = 200.00$

$fy_{we} = 625.00$
 $f_{ce} = 25.00$

From ((5.A5), TBDY), TBDY: $cc = 0.00202463$
 $c = \text{confinement factor} = 1.00246$

$y1 = 0.00140044$
 $sh1 = 0.0044814$

$ft1 = 420.1317$

$fy1 = 350.1097$

$su1 = 0.00512$

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
 and also multiplied by the shear_factor according to 15.7.1.4, with
 $\text{Shear_factor} = 1.00$

$lo/lou, \min = lb/ld = 0.30$

$su1 = 0.4 \cdot esu1_nominal \text{ ((5.5), TBDY)} = 0.032$

From table 5A.1, TBDY: $esu1_nominal = 0.08$,

For calculation of $esu1_nominal$ and $y1, sh1, ft1, fy1$, it is considered
 characteristic value $fsy1 = fs1/1.2$, from table 5.1, TBDY.

$y1, sh1, ft1, fy1$, are also multiplied by $\text{Min}(1, 1.25 \cdot (lb/ld)^{2/3})$, from 10.3.5, ASCE 41-17.

with $fs1 = fs = 350.1097$

with $Es1 = Es = 200000.00$

$y2 = 0.00140044$

$sh2 = 0.0044814$

$ft2 = 420.1317$

$fy2 = 350.1097$

$su2 = 0.00512$

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
 and also multiplied by the shear_factor according to 15.7.1.4, with
 $\text{Shear_factor} = 1.00$

$lo/lou, \min = lb/lb, \min = 0.30$

$su2 = 0.4 \cdot esu2_nominal \text{ ((5.5), TBDY)} = 0.032$

From table 5A.1, TBDY: $esu2_nominal = 0.08$,

For calculation of $esu2_nominal$ and $y2, sh2, ft2, fy2$, it is considered
 characteristic value $fsy2 = fs2/1.2$, from table 5.1, TBDY.

$y1, sh1, ft1, fy1$, are also multiplied by $\text{Min}(1, 1.25 \cdot (lb/ld)^{2/3})$, from 10.3.5, ASCE 41-17.

with $fs2 = fs = 350.1097$

with $Es2 = Es = 200000.00$

$yv = 0.00140044$

$shv = 0.0044814$

$ftv = 420.1317$

$fyv = 350.1097$

$suv = 0.00512$

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
 and also multiplied by the shear_factor according to 15.7.1.4, with
 $\text{Shear_factor} = 1.00$

$lo/lou, \min = lb/ld = 0.30$

$suv = 0.4 \cdot esuv_nominal \text{ ((5.5), TBDY)} = 0.032$

From table 5A.1, TBDY: $esuv_nominal = 0.08$,

considering characteristic value $fsyv = fsv/1.2$, from table 5.1, TBDY

For calculation of $esuv_nominal$ and yv, shv, ftv, fyv , it is considered
 characteristic value $fsyv = fsv/1.2$, from table 5.1, TBDY.

$y1, sh1, ft1, fy1$, are also multiplied by $\text{Min}(1, 1.25 \cdot (lb/ld)^{2/3})$, from 10.3.5, ASCE 41-17.

with $fsv = fs = 350.1097$

with $Esv = Es = 200000.00$

$1 = Asl, \text{ten} / (b \cdot d) \cdot (fs1 / f_c) = 0.05427722$

$2 = Asl, \text{com} / (b \cdot d) \cdot (fs2 / f_c) = 0.05427722$

$v = Asl, \text{mid} / (b \cdot d) \cdot (fsv / f_c) = 0.00$

and confined core properties:

$b = 190.00$
 $d = 2927.00$
 $d' = 13.00$
 $f_{cc} (5A.2, TBDY) = 25.06158$
 $cc (5A.5, TBDY) = 0.00202463$
 $c = \text{confinement factor} = 1.00246$
 $1 = A_{sl,ten}/(b*d)*(f_{s1}/f_c) = 0.07214938$
 $2 = A_{sl,com}/(b*d)*(f_{s2}/f_c) = 0.07214938$
 $v = A_{sl,mid}/(b*d)*(f_{sv}/f_c) = 0.00$
 Case/Assumption: Unconfined full section - Steel rupture
 ' satisfies Eq. (4.3)

--->
 $v < v_{s,y2}$ - LHS eq.(4.5) is satisfied
 --->
 $su (4.9) = 0.14691336$
 $Mu = MR_c (4.14) = 3.3585E+009$
 $u = su (4.1) = 2.0296703E-006$

Calculation of ratio l_b/l_d

Inadequate Lap Length with $l_b/l_d = 0.30$

Calculation of $Mu1$ -

Calculation of ultimate curvature u according to 4.1, Biskinis/Fardis 2013:
 $u = 2.0532423E-006$
 $Mu = 3.8401E+009$

with full section properties:

$b = 250.00$
 $d = 2957.00$
 $d' = 43.00$
 $v = 0.0014928$
 $N = 27588.841$
 $f_c = 25.00$
 $co (5A.5, TBDY) = 0.002$
 Final value of cu : $cu^* = \text{shear_factor} * \text{Max}(cu, cc) = 0.0035$
 The Shear_factor is considered equal to 1 (pure moment strength)
 From (5.4b), TBDY: $cu = 0.0035$
 $w_e ((5.4c), TBDY) = a_{se} * sh_{min} * f_{ywe}/f_{ce} + \text{Min}(f_x, f_y) = 0.00$
 where $f = a_f * p_f * f_{fe}/f_{ce}$ is accounting for FRP contribution like EC8-part3 A.4.4.3(6)

$f_x = 0.00$
 $a_f = 0.00$
 $b = 250.00$
 $h = 3000.00$
 From EC8 A4.4.3(6), $p_f = 2t_f/bw = 0.008128$
 $bw = 250.00$
 effective stress from (A.35), $f_{fe} = 757.2164$

$f_y = 0.00$
 $a_f = 0.00$
 $b = 3000.00$
 $h = 250.00$
 From EC8 A4.4.3(6), $p_f = 2t_f/bw = 0.00067733$
 $bw = 3000.00$
 effective stress from (A.35), $f_{fe} = 954.4864$

$R = 40.00$
 Effective FRP thickness, $t_f = NL * t * \text{Cos}(b1) = 1.016$
 $f_{u,f} = 1055.00$
 $E_f = 64828.00$

$u, f = 0.015$
 $ase((5.4d), TBDY) = (ase1 \cdot Acol1 + ase2 \cdot Acol2 + ase3 \cdot Aweb) / Asec = 0.00$
 $ase1 = 0.00$
 $sh_1 = 150.00$
 $bo_1 = 190.00$
 $ho_1 = 540.00$
 $bi2_1 = 655400.00$
 $ase2 = 0.00$
 $sh_2 = 150.00$
 $bo_2 = 190.00$
 $ho_2 = 540.00$
 $bi2_2 = 655400.00$
 $ase3 = 0$ (grid does not provide confinement)
 $psh, min = \text{Min}(psh, x, psh, y) = 0.00069813$
 Expression ((5.4d), TBDY) for psh, min has been multiplied by 0.3 according to 15.7.1.3 for members without earthquake detailing (90° closed stirrups)

$psh, x = ps1, x + ps2, x + ps3, x = 0.00356047$
 $ps1, x$ (column 1) = $(As1 \cdot h1 / s_1) / Ac = 0.00083776$
 $h1 = 600.00$
 $As1 = Astir1 \cdot ns1 = 157.0796$
 No stirrups, $ns1 = 2.00$
 $ps2, x$ (column 2) = $(As2 \cdot h2 / s_2) / Ac = 0.00083776$
 $h2 = 600.00$
 $As2 = Astir2 \cdot ns2 = 157.0796$
 No stirrups, $ns2 = 2.00$
 $ps3, x$ (web) = $(As3 \cdot h3 / s_3) / Ac = 0.00188496$
 $h3 = 1800.00$
 $As3 = Astir3 \cdot ns3 = 0.00$
 No stirrups, $ns3 = 2.00$

$psh, y = ps1, y + ps2, y + ps3, y = 0.00069813$
 $ps1, y$ (column 1) = $(As1 \cdot h1 / s_1) / Ac = 0.00034907$
 $h1 = 250.00$
 $As1 = Astir1 \cdot ns1 = 157.0796$
 No stirrups, $ns1 = 2.00$
 $ps2, y$ (column 2) = $(As2 \cdot h2 / s_2) / Ac = 0.00034907$
 $h2 = 250.00$
 $As2 = Astir2 \cdot ns2 = 157.0796$
 No stirrups, $ns2 = 2.00$
 $ps3, y$ (web) = $(As3 \cdot h3 / s_3) / Ac = 0.00$
 $h3 = 250.00$
 $As3 = Astir3 \cdot ns3 = 157.0796$
 No stirrups, $ns3 = 0.00$

$Asec = 750000.00$
 $s_1 = 150.00$
 $s_2 = 150.00$
 $s_3 = 200.00$
 $fywe = 625.00$
 $fce = 25.00$
 From ((5.A5), TBDY), TBDY: $cc = 0.00202463$
 $c = \text{confinement factor} = 1.00246$
 $y1 = 0.00140044$
 $sh1 = 0.0044814$
 $ft1 = 420.1317$
 $fy1 = 350.1097$
 $su1 = 0.00512$
 using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
 and also multiplied by the shear_factor according to 15.7.1.4, with
 $\text{Shear_factor} = 1.00$
 $lo/lo, min = lb/ld = 0.30$
 $su1 = 0.4 \cdot esu1_nominal((5.5), TBDY) = 0.032$
 From table 5A.1, TBDY: $esu1_nominal = 0.08$,
 For calculation of $esu1_nominal$ and $y1, sh1, ft1, fy1$, it is considered
 characteristic value $fsy1 = fs1/1.2$, from table 5.1, TBDY.
 $y1, sh1, ft1, fy1$, are also multiplied by $\text{Min}(1, 1.25 \cdot (lb/ld)^{2/3})$, from 10.3.5, ASCE 41-17.

```

with fs1 = fs = 350.1097
with Es1 = Es = 200000.00
y2 = 0.00140044
sh2 = 0.0044814
ft2 = 420.1317
fy2 = 350.1097
su2 = 0.00512
using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00
lo/lou,min = lb/lb,min = 0.30
su2 = 0.4*esu2_nominal ((5.5), TBDY) = 0.032
From table 5A.1, TBDY: esu2_nominal = 0.08,
For calculation of esu2_nominal and y2, sh2,ft2,fy2, it is considered
characteristic value fsy2 = fs2/1.2, from table 5.1, TBDY.
y1, sh1,ft1,fy1, are also multiplied by Min(1,1.25*(lb/lb)^2/3), from 10.3.5, ASCE 41-17.
with fs2 = fs = 350.1097
with Es2 = Es = 200000.00
yv = 0.00140044
shv = 0.0044814
ftv = 420.1317
fyv = 350.1097
suv = 0.00512
using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00
lo/lou,min = lb/lb = 0.30
suv = 0.4*esuv_nominal ((5.5), TBDY) = 0.032
From table 5A.1, TBDY: esuv_nominal = 0.08,
considering characteristic value fsyv = fsv/1.2, from table 5.1, TBDY
For calculation of esuv_nominal and yv, shv,ftv,fyv, it is considered
characteristic value fsyv = fsv/1.2, from table 5.1, TBDY.
y1, sh1,ft1,fy1, are also multiplied by Min(1,1.25*(lb/lb)^2/3), from 10.3.5, ASCE 41-17.
with fsv = fs = 350.1097
with Esv = Es = 200000.00
1 = Asl,ten/(b*d)*(fs1/fc) = 0.05427722
2 = Asl,com/(b*d)*(fs2/fc) = 0.05427722
v = Asl,mid/(b*d)*(fsv/fc) = 0.0291621
and confined core properties:
b = 190.00
d = 2927.00
d' = 13.00
fcc (5A.2, TBDY) = 25.06158
cc (5A.5, TBDY) = 0.00202463
c = confinement factor = 1.00246
1 = Asl,ten/(b*d)*(fs1/fc) = 0.07214938
2 = Asl,com/(b*d)*(fs2/fc) = 0.07214938
v = Asl,mid/(b*d)*(fsv/fc) = 0.03876447
Case/Assumption: Unconfined full section - Steel rupture
'satisfies Eq. (4.3)
--->
v < vs,y2 - LHS eq.(4.5) is satisfied
--->
su (4.9) = 0.15670711
Mu = MRc (4.14) = 3.8401E+009
u = su (4.1) = 2.0532423E-006

```

Calculation of ratio lb/lb

Inadequate Lap Length with lb/lb = 0.30

Calculation of Mu2+

Calculation of ultimate curvature ϕ_u according to 4.1, Biskinis/Fardis 2013:

$$u = 2.0296703E-006$$

$$Mu = 3.3585E+009$$

with full section properties:

$$b = 250.00$$

$$d = 2957.00$$

$$d' = 43.00$$

$$v = 0.0014928$$

$$N = 27588.841$$

$$f_c = 25.00$$

$$\omega (5A.5, TBDY) = 0.002$$

$$\text{Final value of } \phi_u: \phi_u^* = \text{shear_factor} * \text{Max}(\phi_u, \phi_c) = 0.0035$$

The Shear_factor is considered equal to 1 (pure moment strength)

$$\text{From (5.4b), TBDY: } \phi_u = 0.0035$$

$$\omega_e ((5.4c), TBDY) = a_{se} * \frac{\min(f_{ywe}/f_{ce}, \min(f_x, f_y))}{f_{ce}} = 0.00$$

where $f = a_f * p_f * f_{fe}/f_{ce}$ is accounting for FRP contribution like EC8-part3 A.4.4.3(6)

$$f_x = 0.00$$

$$a_f = 0.00$$

$$b = 250.00$$

$$h = 3000.00$$

$$\text{From EC8 A.4.4.3(6), } p_f = 2t_f/bw = 0.008128$$

$$bw = 250.00$$

$$\text{effective stress from (A.35), } f_{fe} = 757.2164$$

$$f_y = 0.00$$

$$a_f = 0.00$$

$$b = 3000.00$$

$$h = 250.00$$

$$\text{From EC8 A.4.4.3(6), } p_f = 2t_f/bw = 0.00067733$$

$$bw = 3000.00$$

$$\text{effective stress from (A.35), } f_{fe} = 954.4864$$

$$R = 40.00$$

$$\text{Effective FRP thickness, } t_f = NL * t * \cos(b_1) = 1.016$$

$$f_{u,f} = 1055.00$$

$$E_f = 64828.00$$

$$u_{f} = 0.015$$

$$a_{se} ((5.4d), TBDY) = (a_{se1} * A_{col1} + a_{se2} * A_{col2} + a_{se3} * A_{web}) / A_{sec} = 0.00$$

$$a_{se1} = 0.00$$

$$sh_1 = 150.00$$

$$bo_1 = 190.00$$

$$ho_1 = 540.00$$

$$bi2_1 = 655400.00$$

$$a_{se2} = 0.00$$

$$sh_2 = 150.00$$

$$bo_2 = 190.00$$

$$ho_2 = 540.00$$

$$bi2_2 = 655400.00$$

$$a_{se3} = 0 \text{ (grid does not provide confinement)}$$

$$p_{sh,min} = \min(p_{sh,x}, p_{sh,y}) = 0.00069813$$

Expression ((5.4d), TBDY) for $p_{sh,min}$ has been multiplied by 0.3 according to 15.7.1.3 for members without earthquake detailing (90° closed stirrups)

$$p_{sh,x} = p_{s1,x} + p_{s2,x} + p_{s3,x} = 0.00356047$$

$$p_{s1,x} \text{ (column 1)} = (A_{s1} * h_1 / s_1) / A_c = 0.00083776$$

$$h_1 = 600.00$$

$$A_{s1} = A_{stir1} * n_{s1} = 157.0796$$

$$\text{No stirrups, } n_{s1} = 2.00$$

$$p_{s2,x} \text{ (column 2)} = (A_{s2} * h_2 / s_2) / A_c = 0.00083776$$

$$h_2 = 600.00$$

$$A_{s2} = A_{stir2} * n_{s2} = 157.0796$$

$$\text{No stirrups, } n_{s2} = 2.00$$

$$p_{s3,x} \text{ (web)} = (A_{s3} * h_3 / s_3) / A_c = 0.00188496$$

$$h_3 = 1800.00$$

As3 = Astir3*ns3 = 0.00
No stirups, ns3 = 2.00

psh,y = ps1,y+ps2,y+ps3,y = 0.00069813
ps1,y (column 1) = (As1*h1/s_1)/Ac = 0.00034907
h1 = 250.00
As1 = Astir1*ns1 = 157.0796
No stirups, ns1 = 2.00
ps2,y (column 2) = (As2*h2/s_2)/Ac = 0.00034907
h2 = 250.00
As2 = Astir2*ns2 = 157.0796
No stirups, ns2 = 2.00
ps3,y (web) = (As3*h3/s_3)/Ac = 0.00
h3 = 250.00
As3 = Astir3*ns3 = 157.0796
No stirups, ns3 = 0.00

Asec = 750000.00
s_1 = 150.00
s_2 = 150.00
s_3 = 200.00
fywe = 625.00
fce = 25.00

From ((5.A.5), TBDY), TBDY: cc = 0.00202463
c = confinement factor = 1.00246

y1 = 0.00140044
sh1 = 0.0044814
ft1 = 420.1317
fy1 = 350.1097
su1 = 0.00512

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00

lo/lou,min = lb/ld = 0.30

su1 = 0.4*esu1_nominal ((5.5), TBDY) = 0.032

From table 5A.1, TBDY: esu1_nominal = 0.08,

For calculation of esu1_nominal and y1, sh1,ft1,fy1, it is considered
characteristic value fsy1 = fs1/1.2, from table 5.1, TBDY.

y1, sh1,ft1,fy1, are also multiplied by $\text{Min}(1, 1.25 \cdot (lb/ld)^{2/3})$, from 10.3.5, ASCE 41-17.

with fs1 = fs = 350.1097

with Es1 = Es = 200000.00

y2 = 0.00140044
sh2 = 0.0044814
ft2 = 420.1317
fy2 = 350.1097
su2 = 0.00512

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00

lo/lou,min = lb/lb,min = 0.30

su2 = 0.4*esu2_nominal ((5.5), TBDY) = 0.032

From table 5A.1, TBDY: esu2_nominal = 0.08,

For calculation of esu2_nominal and y2, sh2,ft2,fy2, it is considered
characteristic value fsy2 = fs2/1.2, from table 5.1, TBDY.

y1, sh1,ft1,fy1, are also multiplied by $\text{Min}(1, 1.25 \cdot (lb/ld)^{2/3})$, from 10.3.5, ASCE 41-17.

with fs2 = fs = 350.1097

with Es2 = Es = 200000.00

yv = 0.00140044
shv = 0.0044814
ftv = 420.1317
fyv = 350.1097
suv = 0.00512

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00

lo/lou,min = lb/ld = 0.30

suv = 0.4*esuv_nominal ((5.5), TBDY) = 0.032

From table 5A.1, TBDY: $esuv_nominal = 0.08$,
 considering characteristic value $fsv = fsv/1.2$, from table 5.1, TBDY
 For calculation of $esuv_nominal$ and yv, shv, ftv, fyv , it is considered
 characteristic value $fsv = fsv/1.2$, from table 5.1, TBDY.
 $y1, sh1, ft1, fy1$, are also multiplied by $Min(1, 1.25 * (lb/ld)^{2/3})$, from 10.3.5, ASCE 41-17.
 with $fsv = fs = 350.1097$
 with $Esv = Es = 200000.00$
 $1 = Asl,ten/(b*d)*(fs1/fc) = 0.05427722$
 $2 = Asl,com/(b*d)*(fs2/fc) = 0.05427722$
 $v = Asl,mid/(b*d)*(fsv/fc) = 0.00$

and confined core properties:

$b = 190.00$
 $d = 2927.00$
 $d' = 13.00$
 $fcc (5A.2, TBDY) = 25.06158$
 $cc (5A.5, TBDY) = 0.00202463$
 $c = \text{confinement factor} = 1.00246$
 $1 = Asl,ten/(b*d)*(fs1/fc) = 0.07214938$
 $2 = Asl,com/(b*d)*(fs2/fc) = 0.07214938$
 $v = Asl,mid/(b*d)*(fsv/fc) = 0.00$

Case/Assumption: Unconfined full section - Steel rupture
 ' satisfies Eq. (4.3)

---->
 $v < vs,y2$ - LHS eq.(4.5) is satisfied

---->
 $su (4.9) = 0.14691336$
 $Mu = MRc (4.14) = 3.3585E+009$
 $u = su (4.1) = 2.0296703E-006$

Calculation of ratio lb/ld

Inadequate Lap Length with $lb/ld = 0.30$

Calculation of $Mu2$ -

Calculation of ultimate curvature u according to 4.1, Biskinis/Fardis 2013:

$u = 2.0532423E-006$
 $Mu = 3.8401E+009$

with full section properties:

$b = 250.00$
 $d = 2957.00$
 $d' = 43.00$
 $v = 0.0014928$
 $N = 27588.841$

$fc = 25.00$
 $co (5A.5, TBDY) = 0.002$

Final value of cu : $cu^* = \text{shear_factor} * \text{Max}(cu, cc) = 0.0035$

The Shear_factor is considered equal to 1 (pure moment strength)

From (5.4b), TBDY: $cu = 0.0035$

$we ((5.4c), TBDY) = ase * sh,min * fywe / fce + Min(fx, fy) = 0.00$

where $f = af * pf * ffe / fce$ is accounting for FRP contribution like EC8-part3 A.4.4.3(6)

$fx = 0.00$

$af = 0.00$

$b = 250.00$

$h = 3000.00$

From EC8 A.4.4.3(6), $pf = 2tf/bw = 0.008128$

$bw = 250.00$

effective stress from (A.35), $ffe = 757.2164$

$fy = 0.00$

af = 0.00
b = 3000.00
h = 250.00
From EC8 A.4.4.3(6), pf = $2t_f/bw = 0.00067733$
bw = 3000.00
effective stress from (A.35), ff,e = 954.4864

R = 40.00
Effective FRP thickness, tf = $NL \cdot t \cdot \cos(b_1) = 1.016$
fu,f = 1055.00
Ef = 64828.00
u,f = 0.015
ase ((5.4d), TBDY) = $(ase1 \cdot A_{col1} + ase2 \cdot A_{col2} + ase3 \cdot A_{web}) / A_{sec} = 0.00$

ase1 = 0.00
sh_1 = 150.00
bo_1 = 190.00
ho_1 = 540.00
bi2_1 = 655400.00

ase2 = 0.00
sh_2 = 150.00
bo_2 = 190.00
ho_2 = 540.00
bi2_2 = 655400.00

ase3 = 0 (grid does not provide confinement)
psh,min = $\min(psh,x, psh,y) = 0.00069813$

Expression ((5.4d), TBDY) for psh,min has been multiplied by 0.3 according to 15.7.1.3 for members without earthquake detailing (90° closed stirrups)

psh,x = $ps1,x + ps2,x + ps3,x = 0.00356047$
ps1,x (column 1) = $(As1 \cdot h1 / s_1) / Ac = 0.00083776$
h1 = 600.00
As1 = $A_{stir1} \cdot ns1 = 157.0796$
No stirrups, ns1 = 2.00
ps2,x (column 2) = $(As2 \cdot h2 / s_2) / Ac = 0.00083776$
h2 = 600.00
As2 = $A_{stir2} \cdot ns2 = 157.0796$
No stirrups, ns2 = 2.00
ps3,x (web) = $(As3 \cdot h3 / s_3) / Ac = 0.00188496$
h3 = 1800.00
As3 = $A_{stir3} \cdot ns3 = 0.00$
No stirrups, ns3 = 2.00

psh,y = $ps1,y + ps2,y + ps3,y = 0.00069813$
ps1,y (column 1) = $(As1 \cdot h1 / s_1) / Ac = 0.00034907$
h1 = 250.00
As1 = $A_{stir1} \cdot ns1 = 157.0796$
No stirrups, ns1 = 2.00
ps2,y (column 2) = $(As2 \cdot h2 / s_2) / Ac = 0.00034907$
h2 = 250.00
As2 = $A_{stir2} \cdot ns2 = 157.0796$
No stirrups, ns2 = 2.00
ps3,y (web) = $(As3 \cdot h3 / s_3) / Ac = 0.00$
h3 = 250.00
As3 = $A_{stir3} \cdot ns3 = 157.0796$
No stirrups, ns3 = 0.00

Asec = 750000.00
s_1 = 150.00
s_2 = 150.00
s_3 = 200.00

fywe = 625.00
fce = 25.00

From ((5.A5), TBDY), TBDY: cc = 0.00202463
c = confinement factor = 1.00246

y1 = 0.00140044
sh1 = 0.0044814
ft1 = 420.1317

```

fy1 = 350.1097
su1 = 0.00512
    using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
    and also multiplied by the shear_factor according to 15.7.1.4, with
    Shear_factor = 1.00
    lo/lou,min = lb/lb = 0.30
    su1 = 0.4*esu1_nominal ((5.5), TBDY) = 0.032
    From table 5A.1, TBDY: esu1_nominal = 0.08,
    For calculation of esu1_nominal and y1, sh1,ft1,fy1, it is considered
    characteristic value fsy1 = fs1/1.2, from table 5.1, TBDY.
    y1, sh1,ft1,fy1, are also multiplied by Min(1,1.25*(lb/lb)^ 2/3), from 10.3.5, ASCE 41-17.
    with fs1 = fs = 350.1097
    with Es1 = Es = 200000.00
y2 = 0.00140044
sh2 = 0.0044814
ft2 = 420.1317
fy2 = 350.1097
su2 = 0.00512
    using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
    and also multiplied by the shear_factor according to 15.7.1.4, with
    Shear_factor = 1.00
    lo/lou,min = lb/lb,min = 0.30
    su2 = 0.4*esu2_nominal ((5.5), TBDY) = 0.032
    From table 5A.1, TBDY: esu2_nominal = 0.08,
    For calculation of esu2_nominal and y2, sh2,ft2,fy2, it is considered
    characteristic value fsy2 = fs2/1.2, from table 5.1, TBDY.
    y1, sh1,ft1,fy1, are also multiplied by Min(1,1.25*(lb/lb)^ 2/3), from 10.3.5, ASCE 41-17.
    with fs2 = fs = 350.1097
    with Es2 = Es = 200000.00
yv = 0.00140044
shv = 0.0044814
ftv = 420.1317
fyv = 350.1097
suv = 0.00512
    using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
    and also multiplied by the shear_factor according to 15.7.1.4, with
    Shear_factor = 1.00
    lo/lou,min = lb/lb = 0.30
    suv = 0.4*esuv_nominal ((5.5), TBDY) = 0.032
    From table 5A.1, TBDY: esuv_nominal = 0.08,
    considering characteristic value fsyv = fsv/1.2, from table 5.1, TBDY
    For calculation of esuv_nominal and yv, shv,ftv,fyv, it is considered
    characteristic value fsyv = fsv/1.2, from table 5.1, TBDY.
    y1, sh1,ft1,fy1, are also multiplied by Min(1,1.25*(lb/lb)^ 2/3), from 10.3.5, ASCE 41-17.
    with fsv = fs = 350.1097
    with Esv = Es = 200000.00
1 = Asl,ten/(b*d)*(fs1/fc) = 0.05427722
2 = Asl,com/(b*d)*(fs2/fc) = 0.05427722
v = Asl,mid/(b*d)*(fsv/fc) = 0.0291621
and confined core properties:
b = 190.00
d = 2927.00
d' = 13.00
fcc (5A.2, TBDY) = 25.06158
cc (5A.5, TBDY) = 0.00202463
    c = confinement factor = 1.00246
1 = Asl,ten/(b*d)*(fs1/fc) = 0.07214938
2 = Asl,com/(b*d)*(fs2/fc) = 0.07214938
v = Asl,mid/(b*d)*(fsv/fc) = 0.03876447
Case/Assumption: Unconfined full section - Steel rupture
' satisfies Eq. (4.3)
--->
v < vs,y2 - LHS eq.(4.5) is satisfied
--->
su (4.9) = 0.15670711
Mu = MRc (4.14) = 3.8401E+009
u = su (4.1) = 2.0532423E-006

```

Calculation of ratio l_b/l_d

Inadequate Lap Length with $l_b/l_d = 0.30$

Calculation of Shear Strength $V_r = \text{Min}(V_{r1}, V_{r2}) = 2.4900\text{E}+006$

Calculation of Shear Strength at edge 1, $V_{r1} = 2.4900\text{E}+006$

From (22.5.1.1) and 11.5.4.3, ACI 318-14: $V_{r1} = V_n < 0.83 \cdot f_c'^{0.5} \cdot h \cdot d$

NOTE: In expression (22.5.1.1) ' V_w ' is replaced by ' $V_w + f \cdot V_f$ ' where V_f is the contribution of FRPs (11.3), ACI 440).

From Table (11.5.4.6(d-e)), ACI 318-14: $V_c = 815517.768$

$M_u/V_u - l_w/2 = 0.00 \leq 0$

= 1 (normal-weight concrete)

$f_c' = 25.00$, but $f_c'^{0.5} \leq 8.3$ MPa (22.5.3.1, ACI 318-14)

$h = 250.00$

$d = 2400.00$

$l_w = 3000.00$

$M_u = 1.1486927\text{E}+009$

$V_u = 1.0097420\text{E}+028$

$N_u = 27588.841$

From (11.5.4.8), ACI 318-14: $V_s = V_{s1} + V_{s2} + V_{s3} = 1.0681\text{E}+006$

$V_{s1} = 251327.412$ is calculated for pseudo-Column 1, with:

$d = 480.00$

$A_v = 157079.633$

$s = 150.00$

$f_y = 500.00$

V_{s1} has been multiplied by 1 ($s < d/2$, according to ASCE 41-17, 10.3.4)

$V_{s2} = 251327.412$ is calculated for pseudo-Column 2, with:

$d = 480.00$

$A_v = 157079.633$

$s = 150.00$

$f_y = 500.00$

V_{s2} has been multiplied by 1 ($s < d/2$, according to ASCE 41-17, 10.3.4)

$V_{s3} = 565486.678$ is calculated for web, with:

$d = 1440.00$

$A_v = 157079.633$

$s = 200.00$

$f_y = 500.00$

V_{s3} has been multiplied by 1 ($s < d/2$, according to ASCE 41-17, 10.3.4)

V_f ((11-3)-(11.4), ACI 440) = $1.5581\text{E}+006$

$f = 0.95$, for fully-wrapped sections

$w_f/s_f = 1$ (FRP strips adjacent to one another).

In (11.3) $\sin + \cos$ is replaced with $(\cot + \cot a) \sin a$ which is more a generalised expression,

where a is the angle of the crack direction (see KANEPE).

This later relation, considered as a function $V_f(\theta)$, is implemented for every different fiber orientation θ_i , as well as for 2 crack directions, $\theta = 45^\circ$ and $\theta = -45^\circ$ to take into consideration the cyclic seismic loading.

orientation 1: $\theta_1 = \theta_1 + 90^\circ = 90.00$

$V_f = \text{Min}(|V_f(45, \theta_1)|, |V_f(-45, \theta_1)|)$, with:

total thickness per orientation, $t_{f1} = N_L \cdot t / N_{\text{Dir}} = 1.016$

$d_{fv} = d$ (figure 11.2, ACI 440) = 2957.00

f_{fe} ((11-5), ACI 440) = 259.312

$E_f = 64828.00$

$f_e = 0.004$, from (11.6a), ACI 440

with $f_u = 0.01$

From (11-11), ACI 440: $V_s + V_f \leq 1.9929\text{E}+006$

$b_w = 250.00$

Calculation of Shear Strength at edge 2, $V_{r2} = 2.4900\text{E}+006$

From (22.5.1.1) and 11.5.4.3, ACI 318-14: $V_{r2} = V_n < 0.83 \cdot f_c'^{0.5} \cdot h \cdot d$

NOTE: In expression (22.5.1.1) 'Vw' is replaced by 'Vw+ f*Vf' where Vf is the contribution of FRPs (11.3), ACI 440).

From Table (11.5.4.6(d-e)), ACI 318-14: $V_c = 815517.768$

$M_u/V_u - l_w/2 = 0.00 \leq 0$

= 1 (normal-weight concrete)

$f_c' = 25.00$, but $f_c'^{0.5} \leq 8.3$ MPa (22.5.3.1, ACI 318-14)

$h = 250.00$

$d = 2400.00$

$l_w = 3000.00$

$M_u = 1.1486927E+009$

$V_u = 1.0097420E+028$

$N_u = 27588.841$

From (11.5.4.8), ACI 318-14: $V_s = V_{s1} + V_{s2} + V_{s3} = 1.0681E+006$

$V_{s1} = 251327.412$ is calculated for pseudo-Column 1, with:

$d = 480.00$

$A_v = 157079.633$

$s = 150.00$

$f_y = 500.00$

V_{s1} has been multiplied by 1 ($s < d/2$, according to ASCE 41-17,10.3.4)

$V_{s2} = 251327.412$ is calculated for pseudo-Column 2, with:

$d = 480.00$

$A_v = 157079.633$

$s = 150.00$

$f_y = 500.00$

V_{s2} has been multiplied by 1 ($s < d/2$, according to ASCE 41-17,10.3.4)

$V_{s3} = 565486.678$ is calculated for web, with:

$d = 1440.00$

$A_v = 157079.633$

$s = 200.00$

$f_y = 500.00$

V_{s3} has been multiplied by 1 ($s < d/2$, according to ASCE 41-17,10.3.4)

V_f ((11-3)-(11.4), ACI 440) = $1.5581E+006$

$f = 0.95$, for fully-wrapped sections

$w_f/s_f = 1$ (FRP strips adjacent to one another).

In (11.3) $\sin + \cos$ is replaced with $(\cot + \cot a)\sin a$ which is more a generalised expression, where a is the angle of the crack direction (see KANEPE).

This later relation, considered as a function $V_f(\theta, a)$, is implemented for every different fiber orientation a_i , as well as for 2 crack directions, $\theta = 45^\circ$ and $\theta = -45^\circ$ to take into consideration the cyclic seismic loading.

orientation 1: $\theta = b1 + 90^\circ = 90.00$

$V_f = \text{Min}(|V_f(45, \theta)|, |V_f(-45, a1)|)$, with:

total thickness per orientation, $t_{f1} = N_L * t / \text{NoDir} = 1.016$

$d_{fv} = d$ (figure 11.2, ACI 440) = 2957.00

f_{fe} ((11-5), ACI 440) = 259.312

$E_f = 64828.00$

$f_e = 0.004$, from (11.6a), ACI 440

with $f_u = 0.01$

From (11-11), ACI 440: $V_s + V_f \leq 1.9929E+006$

$b_w = 250.00$

End Of Calculation of Shear Capacity ratio for element: wall W1 of floor 1

At local axis: 3

Start Of Calculation of Shear Capacity ratio for element: wall W1 of floor 1

At Shear local axis: 2

(Bending local axis: 3)

Section Type: rcrcws

Constant Properties

Knowledge Factor, $K = 1.00$

Mean strength values are used for both shear and moment calculations.

Consequently:

New material of Secondary Member: Concrete Strength, $f_c = f_{cm} = 25.00$

New material of Secondary Member: Steel Strength, $f_s = f_{sm} = 500.00$
Concrete Elasticity, $E_c = 26999.444$
Steel Elasticity, $E_s = 200000.00$

Note: Especially for the calculation of moment strengths,
the above steel re-bar strengths are multiplied by 1.25 according to R18.6.5, ACI 318-14
New material: Steel Strength, $f_s = 1.25 \cdot f_{sm} = 625.00$

Total Height, $H_{tot} = 3000.00$
Edges Width, $W_{edg} = 250.00$
Edges Height, $H_{edg} = 600.00$
Web Width, $W_{web} = 250.00$
Cover Thickness, $c = 25.00$
Mean Confinement Factor overall section = 1.00246
Element Length, $L = 3000.00$
Secondary Member
Smooth Bars
Ductile Steel
Without Detailing for Earthquake Resistance (including stirrups not closed at 135°)
Longitudinal Bars With Ends Lapped Starting at the End Sections
Inadequate Lap Length with $l_o/l_{ou,min} = 0.30$
FRP Wrapping Data
Type: Carbon
Cured laminate properties (design values)
Thickness, $t = 1.016$
Tensile Strength, $f_{fu} = 1055.00$
Tensile Modulus, $E_f = 64828.00$
Elongation, $\epsilon_{fu} = 0.01$
Number of directions, $N_{oDir} = 1$
Fiber orientations, $b_i: 0.00^\circ$
Number of layers, $N_L = 1$
Radius of rounding corners, $R = 40.00$

Stepwise Properties

At local axis: 2
EDGE -A-
Shear Force, $V_a = 1.7354940E-029$
EDGE -B-
Shear Force, $V_b = -1.7354940E-029$
BOTH EDGES
Axial Force, $F = -27588.841$
Longitudinal Reinforcement Area Distribution (in 2 divisions)
-Tension: $A_{sl,t} = 0.00$
-Compression: $A_{sl,c} = 7269.645$
Longitudinal Reinforcement Area Distribution (in 3 divisions)
-Tension: $A_{sl,ten} = 2830.575$
-Compression: $A_{sl,com} = 2830.575$
-Middle: $A_{sl,mid} = 0.00$
(According to 10.7.2.3 $A_{sl,mid}$ is setted equal to zero)

Calculation of Shear Capacity ratio, $V_e/V_r = 0.15621236$
Member Controlled by Flexure ($V_e/V_r < 1$)
Calculation of Shear Demand from fig. R18.6.5, ACI 318-14 $V_e = (M_{pr1} + M_{pr2})/l_n = 160017.271$
with
 $M_{pr1} = \max(\mu_{u1+}, \mu_{u1-}) = 2.4003E+008$
 $\mu_{u1+} = 2.0658E+008$, is the ultimate moment strength at the edge 1 of the member in the actual moment direction
which is defined for the static loading combination
 $\mu_{u1-} = 2.4003E+008$, is the ultimate moment strength at the edge 1 of the member in the opposite moment
direction which is defined for the static loading combination
 $M_{pr2} = \max(\mu_{u2+}, \mu_{u2-}) = 2.4003E+008$
 $\mu_{u2+} = 2.0658E+008$, is the ultimate moment strength at the edge 2 of the member in the actual moment direction
which is defined for the the static loading combination

Mu2- = 2.4003E+008, is the ultimate moment strength at the edge 2 of the member in the opposite moment direction which is defined for the the static loading combination

Calculation of Mu1+

Calculation of ultimate curvature ϕ_u according to 4.1, Biskinis/Fardis 2013:

$$\phi_u = 3.0306889E-005$$

$$M_u = 2.0658E+008$$

with full section properties:

$$b = 3000.00$$

$$d = 208.00$$

$$d' = 42.00$$

$$v = 0.00176852$$

$$N = 27588.841$$

$$f_c = 25.00$$

$$\phi_{co} \text{ (5A.5, TBDY)} = 0.002$$

$$\text{Final value of } \phi_{cu}: \phi_{cu} = \text{shear_factor} * \text{Max}(\phi_{cu}, \phi_{co}) = 0.0035$$

The Shear_factor is considered equal to 1 (pure moment strength)

$$\text{From (5.4b), TBDY: } \phi_{cu} = 0.0035$$

$$\phi_{we} \text{ ((5.4c), TBDY)} = \phi_{se} * \phi_{sh,min} * f_{ywe} / f_{ce} + \text{Min}(\phi_{fx}, \phi_{fy}) = 0.00$$

where $\phi_{se} = \phi_{af} * \phi_{pf} * f_{fe} / f_{ce}$ is accounting for FRP contribution like EC8-part3 A.4.4.3(6)

$$\phi_{fx} = 0.00$$

$$\phi_{af} = 0.00$$

$$b = 250.00$$

$$h = 3000.00$$

$$\text{From EC8 A4.4.3(6), } \phi_{pf} = 2t_f/bw = 0.008128$$

$$bw = 250.00$$

$$\text{effective stress from (A.35), } f_{fe} = 757.2164$$

$$\phi_{fy} = 0.00$$

$$\phi_{af} = 0.00$$

$$b = 3000.00$$

$$h = 250.00$$

$$\text{From EC8 A4.4.3(6), } \phi_{pf} = 2t_f/bw = 0.00067733$$

$$bw = 3000.00$$

$$\text{effective stress from (A.35), } f_{fe} = 954.4864$$

$$R = 40.00$$

$$\text{Effective FRP thickness, } t_f = NL * t * \cos(b_1) = 1.016$$

$$f_{u,f} = 1055.00$$

$$E_f = 64828.00$$

$$u_{f,f} = 0.015$$

$$\phi_{ase} \text{ ((5.4d), TBDY)} = (\phi_{ase1} * A_{col1} + \phi_{ase2} * A_{col2} + \phi_{ase3} * A_{web}) / A_{sec} = 0.00$$

$$\phi_{ase1} = 0.00$$

$$sh_1 = 150.00$$

$$bo_1 = 190.00$$

$$ho_1 = 540.00$$

$$bi2_1 = 655400.00$$

$$\phi_{ase2} = 0.00$$

$$sh_2 = 150.00$$

$$bo_2 = 190.00$$

$$ho_2 = 540.00$$

$$bi2_2 = 655400.00$$

$$\phi_{ase3} = 0 \text{ (grid does not provide confinement)}$$

$$\phi_{psh,min} = \text{Min}(\phi_{psh,x}, \phi_{psh,y}) = 0.00069813$$

Expression ((5.4d), TBDY) for $\phi_{psh,min}$ has been multiplied by 0.3 according to 15.7.1.3 for members without earthquake detailing (90° closed stirrups)

$$\phi_{psh,x} = \phi_{ps1,x} + \phi_{ps2,x} + \phi_{ps3,x} = 0.00356047$$

$$\phi_{ps1,x} \text{ (column 1)} = (A_{s1} * h_1 / s_1) / A_c = 0.00083776$$

$$h_1 = 600.00$$

$$A_{s1} = A_{stir1} * n_{s1} = 157.0796$$

No stirups, ns1 = 2.00
 $ps2,x$ (column 2) = $(As2 \cdot h2 / s_2) / Ac = 0.00083776$
 $h2 = 600.00$
 $As2 = Astir2 \cdot ns2 = 157.0796$
 No stirups, ns2 = 2.00
 $ps3,x$ (web) = $(As3 \cdot h3 / s_3) / Ac = 0.00188496$
 $h3 = 1800.00$
 $As3 = Astir3 \cdot ns3 = 0.00$
 No stirups, ns3 = 2.00

$psh,y = ps1,y + ps2,y + ps3,y = 0.00069813$
 $ps1,y$ (column 1) = $(As1 \cdot h1 / s_1) / Ac = 0.00034907$
 $h1 = 250.00$
 $As1 = Astir1 \cdot ns1 = 157.0796$
 No stirups, ns1 = 2.00
 $ps2,y$ (column 2) = $(As2 \cdot h2 / s_2) / Ac = 0.00034907$
 $h2 = 250.00$
 $As2 = Astir2 \cdot ns2 = 157.0796$
 No stirups, ns2 = 2.00
 $ps3,y$ (web) = $(As3 \cdot h3 / s_3) / Ac = 0.00$
 $h3 = 250.00$
 $As3 = Astir3 \cdot ns3 = 157.0796$
 No stirups, ns3 = 0.00

$Asec = 750000.00$
 $s_1 = 150.00$
 $s_2 = 150.00$
 $s_3 = 200.00$

$fywe = 625.00$
 $fce = 25.00$

From ((5.A5), TBDY), TBDY: $cc = 0.00202463$
 $c =$ confinement factor = 1.00246

$y1 = 0.00140044$
 $sh1 = 0.0044814$
 $ft1 = 420.1317$
 $fy1 = 350.1097$
 $su1 = 0.00512$

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
 and also multiplied by the shear_factor according to 15.7.1.4, with
 Shear_factor = 1.00
 $lo/lou,min = lb/ld = 0.30$

$su1 = 0.4 \cdot esu1_nominal$ ((5.5), TBDY) = 0.032

From table 5A.1, TBDY: $esu1_nominal = 0.08$,

For calculation of $esu1_nominal$ and $y1, sh1, ft1, fy1$, it is considered
 characteristic value $fsy1 = fs1 / 1.2$, from table 5.1, TBDY.

$y1, sh1, ft1, fy1$, are also multiplied by $\text{Min}(1, 1.25 \cdot (lb/ld)^{2/3})$, from 10.3.5, ASCE 41-17.

with $fs1 = fs = 350.1097$

with $Es1 = Es = 200000.00$

$y2 = 0.00140044$
 $sh2 = 0.0044814$
 $ft2 = 420.1317$
 $fy2 = 350.1097$
 $su2 = 0.00512$

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
 and also multiplied by the shear_factor according to 15.7.1.4, with
 Shear_factor = 1.00

$lo/lou,min = lb/lb,min = 0.30$

$su2 = 0.4 \cdot esu2_nominal$ ((5.5), TBDY) = 0.032

From table 5A.1, TBDY: $esu2_nominal = 0.08$,

For calculation of $esu2_nominal$ and $y2, sh2, ft2, fy2$, it is considered
 characteristic value $fsy2 = fs2 / 1.2$, from table 5.1, TBDY.

$y1, sh1, ft1, fy1$, are also multiplied by $\text{Min}(1, 1.25 \cdot (lb/ld)^{2/3})$, from 10.3.5, ASCE 41-17.

with $fs2 = fs = 350.1097$

with $Es2 = Es = 200000.00$

$yv = 0.00140044$
 $shv = 0.0044814$
 $ftv = 420.1317$

```

fyv = 350.1097
suv = 0.00512
using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00
lo/lo,min = lb/ld = 0.30
suv = 0.4*esuv_nominal ((5.5), TBDY) = 0.032
From table 5A.1, TBDY: esuv_nominal = 0.08,
considering characteristic value fsyv = fsv/1.2, from table 5.1, TBDY
For calculation of esuv_nominal and yv, shv,ftv,fyv, it is considered
characteristic value fsyv = fsv/1.2, from table 5.1, TBDY.
y1, sh1,ft1,fy1, are also multiplied by Min(1,1.25*(lb/ld)^ 2/3), from 10.3.5, ASCE 41-17.
with fsv = fs = 350.1097
with Esv = Es = 200000.00
1 = Asl,ten/(b*d)*(fs1/fc) = 0.0635264
2 = Asl,com/(b*d)*(fs2/fc) = 0.0635264
v = Asl,mid/(b*d)*(fsv/fc) = 0.00
and confined core properties:
b = 2940.00
d = 178.00
d' = 12.00
fcc (5A.2, TBDY) = 25.06158
cc (5A.5, TBDY) = 0.00202463
c = confinement factor = 1.00246
1 = Asl,ten/(b*d)*(fs1/fc) = 0.07574806
2 = Asl,com/(b*d)*(fs2/fc) = 0.07574806
v = Asl,mid/(b*d)*(fsv/fc) = 0.00
Case/Assumption: Unconfined full section - Steel rupture
' satisfies Eq. (4.3)
--->
v < vs,y2 - LHS eq.(4.5) is satisfied
--->
su (4.9) = 0.18779572
Mu = MRc (4.14) = 2.0658E+008
u = su (4.1) = 3.0306889E-005

```

Calculation of ratio lb/ld

Inadequate Lap Length with lb/ld = 0.30

Calculation of Mu1-

Calculation of ultimate curvature u according to 4.1, Biskinis/Fardis 2013:

```

u = 3.0889637E-005
Mu = 2.4003E+008

```

with full section properties:

```

b = 3000.00
d = 208.00
d' = 42.00
v = 0.00176852
N = 27588.841
fc = 25.00
co (5A.5, TBDY) = 0.002
Final value of cu: cu* = shear_factor * Max( cu, cc) = 0.0035
The Shear_factor is considered equal to 1 (pure moment strength)
From (5.4b), TBDY: cu = 0.0035
we ((5.4c), TBDY) = ase* sh,min*fywe/fce+Min( fx, fy) = 0.00
where f = af*pf*ffe/fce is accounting for FRP contribution like EC8-part3 A.4.4.3(6)
fx = 0.00
af = 0.00

```

b = 250.00
h = 3000.00
From EC8 A4.4.3(6), $pf = 2tf/bw = 0.008128$
bw = 250.00
effective stress from (A.35), $ff,e = 757.2164$

$f_y = 0.00$
 $a_f = 0.00$
b = 3000.00
h = 250.00
From EC8 A4.4.3(6), $pf = 2tf/bw = 0.00067733$
bw = 3000.00
effective stress from (A.35), $ff,e = 954.4864$

R = 40.00
Effective FRP thickness, $tf = NL*t*Cos(b1) = 1.016$
 $f_{u,f} = 1055.00$
 $E_f = 64828.00$
 $u_f = 0.015$
 $ase((5.4d), TBDY) = (ase1*A_{col1} + ase2*A_{col2} + ase3*A_{web})/A_{sec} = 0.00$

ase1 = 0.00
sh_1 = 150.00
bo_1 = 190.00
ho_1 = 540.00
bi2_1 = 655400.00

ase2 = 0.00
sh_2 = 150.00
bo_2 = 190.00
ho_2 = 540.00
bi2_2 = 655400.00

ase3 = 0 (grid does not provide confinement)
 $p_{sh,min} = \min(p_{sh,x}, p_{sh,y}) = 0.00069813$

Expression ((5.4d), TBDY) for $p_{sh,min}$ has been multiplied by 0.3 according to 15.7.1.3 for members without earthquake detailing (90° closed stirrups)

$p_{sh,x} = p_{s1,x} + p_{s2,x} + p_{s3,x} = 0.00356047$
 $p_{s1,x} \text{ (column 1)} = (As1*h1/s_1)/Ac = 0.00083776$
h1 = 600.00
 $As1 = Astir1*ns1 = 157.0796$
No stirrups, ns1 = 2.00
 $p_{s2,x} \text{ (column 2)} = (As2*h2/s_2)/Ac = 0.00083776$
h2 = 600.00
 $As2 = Astir2*ns2 = 157.0796$
No stirrups, ns2 = 2.00
 $p_{s3,x} \text{ (web)} = (As3*h3/s_3)/Ac = 0.00188496$
h3 = 1800.00
 $As3 = Astir3*ns3 = 0.00$
No stirrups, ns3 = 2.00

$p_{sh,y} = p_{s1,y} + p_{s2,y} + p_{s3,y} = 0.00069813$
 $p_{s1,y} \text{ (column 1)} = (As1*h1/s_1)/Ac = 0.00034907$
h1 = 250.00
 $As1 = Astir1*ns1 = 157.0796$
No stirrups, ns1 = 2.00
 $p_{s2,y} \text{ (column 2)} = (As2*h2/s_2)/Ac = 0.00034907$
h2 = 250.00
 $As2 = Astir2*ns2 = 157.0796$
No stirrups, ns2 = 2.00
 $p_{s3,y} \text{ (web)} = (As3*h3/s_3)/Ac = 0.00$
h3 = 250.00
 $As3 = Astir3*ns3 = 157.0796$
No stirrups, ns3 = 0.00

$A_{sec} = 750000.00$
s_1 = 150.00
s_2 = 150.00
s_3 = 200.00

```

fywe = 625.00
fce = 25.00
From ((5A.5), TBDY), TBDY: cc = 0.00202463
c = confinement factor = 1.00246
y1 = 0.00140044
sh1 = 0.0044814
ft1 = 420.1317
fy1 = 350.1097
su1 = 0.00512
using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00
lo/lou,min = lb/d = 0.30
su1 = 0.4*esu1_nominal ((5.5), TBDY) = 0.032
From table 5A.1, TBDY: esu1_nominal = 0.08,
For calculation of esu1_nominal and y1, sh1,ft1,fy1, it is considered
characteristic value fsy1 = fs1/1.2, from table 5.1, TBDY.
y1, sh1,ft1,fy1, are also multiplied by Min(1,1.25*(lb/d)^ 2/3), from 10.3.5, ASCE 41-17.
with fs1 = fs = 350.1097
with Es1 = Es = 200000.00
y2 = 0.00140044
sh2 = 0.0044814
ft2 = 420.1317
fy2 = 350.1097
su2 = 0.00512
using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00
lo/lou,min = lb/lb,min = 0.30
su2 = 0.4*esu2_nominal ((5.5), TBDY) = 0.032
From table 5A.1, TBDY: esu2_nominal = 0.08,
For calculation of esu2_nominal and y2, sh2,ft2,fy2, it is considered
characteristic value fsy2 = fs2/1.2, from table 5.1, TBDY.
y1, sh1,ft1,fy1, are also multiplied by Min(1,1.25*(lb/d)^ 2/3), from 10.3.5, ASCE 41-17.
with fs2 = fs = 350.1097
with Es2 = Es = 200000.00
yv = 0.00140044
shv = 0.0044814
ftv = 420.1317
fyv = 350.1097
suv = 0.00512
using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00
lo/lou,min = lb/d = 0.30
suv = 0.4*esuv_nominal ((5.5), TBDY) = 0.032
From table 5A.1, TBDY: esuv_nominal = 0.08,
considering characteristic value fsyv = fsv/1.2, from table 5.1, TBDY
For calculation of esuv_nominal and yv, shv,ftv,fyv, it is considered
characteristic value fsyv = fsv/1.2, from table 5.1, TBDY.
y1, sh1,ft1,fy1, are also multiplied by Min(1,1.25*(lb/d)^ 2/3), from 10.3.5, ASCE 41-17.
with fsv = fs = 350.1097
with Esv = Es = 200000.00
1 = Asl,ten/(b*d)*(fs1/fc) = 0.0635264
2 = Asl,com/(b*d)*(fs2/fc) = 0.0635264
v = Asl,mid/(b*d)*(fsv/fc) = 0.03609935
and confined core properties:
b = 2940.00
d = 178.00
d' = 12.00
fcc (5A.2, TBDY) = 25.06158
cc (5A.5, TBDY) = 0.00202463
c = confinement factor = 1.00246
1 = Asl,ten/(b*d)*(fs1/fc) = 0.07574806
2 = Asl,com/(b*d)*(fs2/fc) = 0.07574806
v = Asl,mid/(b*d)*(fsv/fc) = 0.0430444
Case/Assumption: Unconfinedsd full section - Steel rupture

```

satisfies Eq. (4.3)

--->

$v < v_{s,y2}$ - LHS eq.(4.5) is satisfied

--->

$s_u(4.9) = 0.20311835$

$M_u = M_{Rc}(4.14) = 2.4003E+008$

$u = s_u(4.1) = 3.0889637E-005$

Calculation of ratio I_b/I_d

Inadequate Lap Length with $I_b/I_d = 0.30$

Calculation of M_{u2+}

Calculation of ultimate curvature u according to 4.1, Biskinis/Fardis 2013:

$u = 3.0306889E-005$

$M_u = 2.0658E+008$

with full section properties:

$b = 3000.00$

$d = 208.00$

$d' = 42.00$

$v = 0.00176852$

$N = 27588.841$

$f_c = 25.00$

$\alpha(5A.5, TBDY) = 0.002$

Final value of α : $\alpha^* = \text{shear_factor} * \text{Max}(\alpha, \alpha_c) = 0.0035$

The Shear_factor is considered equal to 1 (pure moment strength)

From (5.4b), TBDY: $\alpha = 0.0035$

$\alpha_e((5.4c), TBDY) = \alpha * \text{sh_min} * f_{ywe}/f_{ce} + \text{Min}(\alpha_x, \alpha_y) = 0.00$

where $f = \alpha * p_f * f_{fe}/f_{ce}$ is accounting for FRP contribution like EC8-part3 A.4.4.3(6)

$\alpha_x = 0.00$

$\alpha_f = 0.00$

$b = 250.00$

$h = 3000.00$

From EC8 A4.4.3(6), $p_f = 2t_f/bw = 0.008128$

$bw = 250.00$

effective stress from (A.35), $f_{fe} = 757.2164$

$\alpha_y = 0.00$

$\alpha_f = 0.00$

$b = 3000.00$

$h = 250.00$

From EC8 A4.4.3(6), $p_f = 2t_f/bw = 0.00067733$

$bw = 3000.00$

effective stress from (A.35), $f_{fe} = 954.4864$

$R = 40.00$

Effective FRP thickness, $t_f = NL * t * \cos(b_1) = 1.016$

$f_{u,f} = 1055.00$

$E_f = 64828.00$

$u_{f,f} = 0.015$

$\alpha_{se}((5.4d), TBDY) = (\alpha_{se1} * A_{col1} + \alpha_{se2} * A_{col2} + \alpha_{se3} * A_{web}) / A_{sec} = 0.00$

$\alpha_{se1} = 0.00$

$sh_1 = 150.00$

$bo_1 = 190.00$

$ho_1 = 540.00$

$bi_{2,1} = 655400.00$

$\alpha_{se2} = 0.00$

$sh_2 = 150.00$

$bo_2 = 190.00$

$ho_2 = 540.00$
 $bi2_2 = 655400.00$
 $ase3 = 0$ (grid does not provide confinement)
 $psh,min = \text{Min}(psh,x, psh,y) = 0.00069813$
 Expression ((5.4d), TBDY) for psh,min has been multiplied by 0.3 according to 15.7.1.3 for members without earthquake detailing (90° closed stirrups)

$psh,x = ps1,x + ps2,x + ps3,x = 0.00356047$
 $ps1,x$ (column 1) = $(As1 \cdot h1 / s_1) / Ac = 0.00083776$
 $h1 = 600.00$
 $As1 = Astir1 \cdot ns1 = 157.0796$
 No stirrups, $ns1 = 2.00$
 $ps2,x$ (column 2) = $(As2 \cdot h2 / s_2) / Ac = 0.00083776$
 $h2 = 600.00$
 $As2 = Astir2 \cdot ns2 = 157.0796$
 No stirrups, $ns2 = 2.00$
 $ps3,x$ (web) = $(As3 \cdot h3 / s_3) / Ac = 0.00188496$
 $h3 = 1800.00$
 $As3 = Astir3 \cdot ns3 = 0.00$
 No stirrups, $ns3 = 2.00$

$psh,y = ps1,y + ps2,y + ps3,y = 0.00069813$
 $ps1,y$ (column 1) = $(As1 \cdot h1 / s_1) / Ac = 0.00034907$
 $h1 = 250.00$
 $As1 = Astir1 \cdot ns1 = 157.0796$
 No stirrups, $ns1 = 2.00$
 $ps2,y$ (column 2) = $(As2 \cdot h2 / s_2) / Ac = 0.00034907$
 $h2 = 250.00$
 $As2 = Astir2 \cdot ns2 = 157.0796$
 No stirrups, $ns2 = 2.00$
 $ps3,y$ (web) = $(As3 \cdot h3 / s_3) / Ac = 0.00$
 $h3 = 250.00$
 $As3 = Astir3 \cdot ns3 = 157.0796$
 No stirrups, $ns3 = 0.00$

$Asec = 750000.00$
 $s_1 = 150.00$
 $s_2 = 150.00$
 $s_3 = 200.00$
 $fywe = 625.00$
 $fce = 25.00$
 From ((5.A5), TBDY), TBDY: $cc = 0.00202463$
 $c = \text{confinement factor} = 1.00246$
 $y1 = 0.00140044$
 $sh1 = 0.0044814$
 $ft1 = 420.1317$
 $fy1 = 350.1097$
 $su1 = 0.00512$
 using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
 and also multiplied by the shear_factor according to 15.7.1.4, with
 $\text{Shear_factor} = 1.00$
 $lo/lou,min = lb/ld = 0.30$
 $su1 = 0.4 \cdot esu1_nominal$ ((5.5), TBDY) = 0.032
 From table 5A.1, TBDY: $esu1_nominal = 0.08$,
 For calculation of $esu1_nominal$ and $y1, sh1, ft1, fy1$, it is considered
 characteristic value $fsy1 = fs1 / 1.2$, from table 5.1, TBDY.
 $y1, sh1, ft1, fy1$, are also multiplied by $\text{Min}(1, 1.25 \cdot (lb/ld)^{2/3})$, from 10.3.5, ASCE 41-17.
 with $fs1 = fs = 350.1097$
 with $Es1 = Es = 200000.00$
 $y2 = 0.00140044$
 $sh2 = 0.0044814$
 $ft2 = 420.1317$
 $fy2 = 350.1097$
 $su2 = 0.00512$
 using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
 and also multiplied by the shear_factor according to 15.7.1.4, with
 $\text{Shear_factor} = 1.00$

```

lo/lou,min = lb/lbmin = 0.30
su2 = 0.4*esu2,nominal ((5.5), TBDY) = 0.032
From table 5A.1, TBDY: esu2,nominal = 0.08,
For calculation of esu2,nominal and y2, sh2,ft2,fy2, it is considered
characteristic value fsy2 = fs2/1.2, from table 5.1, TBDY.
y1, sh1,ft1,fy1, are also multiplied by Min(1,1.25*(lb/ld)2/3), from 10.3.5, ASCE 41-17.
with fs2 = fs = 350.1097
with Es2 = Es = 200000.00
yv = 0.00140044
shv = 0.0044814
ftv = 420.1317
fyv = 350.1097
suv = 0.00512
using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00
lo/lou,min = lb/ld = 0.30
suv = 0.4*esuvnominal ((5.5), TBDY) = 0.032
From table 5A.1, TBDY: esuvnominal = 0.08,
considering characteristic value fsyv = fsv/1.2, from table 5.1, TBDY
For calculation of esuvnominal and yv, shv,ftv,fyv, it is considered
characteristic value fsyv = fsv/1.2, from table 5.1, TBDY.
y1, sh1,ft1,fy1, are also multiplied by Min(1,1.25*(lb/ld)2/3), from 10.3.5, ASCE 41-17.
with fsv = fs = 350.1097
with Esv = Es = 200000.00
1 = Aslten/(b*d)*(fs1/fc) = 0.0635264
2 = Aslcom/(b*d)*(fs2/fc) = 0.0635264
v = Aslmid/(b*d)*(fsv/fc) = 0.00
and confined core properties:
b = 2940.00
d = 178.00
d' = 12.00
fcc (5A.2, TBDY) = 25.06158
cc (5A.5, TBDY) = 0.00202463
c = confinement factor = 1.00246
1 = Aslten/(b*d)*(fs1/fc) = 0.07574806
2 = Aslcom/(b*d)*(fs2/fc) = 0.07574806
v = Aslmid/(b*d)*(fsv/fc) = 0.00
Case/Assumption: Unconfined full section - Steel rupture
'satisfies Eq. (4.3)
--->
v < vsy2 - LHS eq.(4.5) is satisfied
--->
su (4.9) = 0.18779572
Mu = MRc (4.14) = 2.0658E+008
u = su (4.1) = 3.0306889E-005

```

Calculation of ratio lb/l_d

Inadequate Lap Length with lb/l_d = 0.30

Calculation of Mu₂-

Calculation of ultimate curvature u according to 4.1, Biskinis/Fardis 2013:

u = 3.0889637E-005
Mu = 2.4003E+008

with full section properties:

b = 3000.00
d = 208.00
d' = 42.00
v = 0.00176852

$N = 27588.841$
 $f_c = 25.00$
 $\alpha (5A.5, TBDY) = 0.002$
 Final value of α : $\alpha^* = \text{shear_factor} * \text{Max}(\alpha, \alpha_c) = 0.0035$
 The Shear_factor is considered equal to 1 (pure moment strength)
 From (5.4b), TBDY: $\alpha = 0.0035$
 $\alpha_{we} ((5.4c), TBDY) = \alpha_{se} * \text{sh}_{\min} * f_{ywe} / f_{ce} + \text{Min}(\alpha_x, \alpha_y) = 0.00$
 where $\alpha = \alpha_f * \rho_f * f_{fe} / f_{ce}$ is accounting for FRP contribution like EC8-part3 A.4.4.3(6)

$\alpha_x = 0.00$
 $\alpha_f = 0.00$
 $b = 250.00$
 $h = 3000.00$
 From EC8 A.4.4.3(6), $\rho_f = 2t_f/bw = 0.008128$
 $bw = 250.00$
 effective stress from (A.35), $f_{fe} = 757.2164$

$\alpha_y = 0.00$
 $\alpha_f = 0.00$
 $b = 3000.00$
 $h = 250.00$
 From EC8 A.4.4.3(6), $\rho_f = 2t_f/bw = 0.00067733$
 $bw = 3000.00$
 effective stress from (A.35), $f_{fe} = 954.4864$

$R = 40.00$
 Effective FRP thickness, $t_f = NL * t * \cos(b_1) = 1.016$
 $f_{u,f} = 1055.00$
 $E_f = 64828.00$
 $u_{f} = 0.015$
 $\alpha_{se} ((5.4d), TBDY) = (\alpha_{se1} * A_{col1} + \alpha_{se2} * A_{col2} + \alpha_{se3} * A_{web}) / A_{sec} = 0.00$
 $\alpha_{se1} = 0.00$
 $sh_1 = 150.00$
 $bo_1 = 190.00$
 $ho_1 = 540.00$
 $bi2_1 = 655400.00$
 $\alpha_{se2} = 0.00$
 $sh_2 = 150.00$
 $bo_2 = 190.00$
 $ho_2 = 540.00$
 $bi2_2 = 655400.00$
 $\alpha_{se3} = 0$ (grid does not provide confinement)
 $\rho_{sh,\min} = \text{Min}(\rho_{sh,x}, \rho_{sh,y}) = 0.00069813$
 Expression ((5.4d), TBDY) for $\rho_{sh,\min}$ has been multiplied by 0.3 according to 15.7.1.3 for members without earthquake detailing (90° closed stirrups)

$\rho_{sh,x} = \rho_{s1,x} + \rho_{s2,x} + \rho_{s3,x} = 0.00356047$
 $\rho_{s1,x}$ (column 1) = $(A_{s1} * h_1 / s_1) / A_c = 0.00083776$
 $h_1 = 600.00$
 $A_{s1} = A_{stir1} * n_{s1} = 157.0796$
 No stirrups, $n_{s1} = 2.00$
 $\rho_{s2,x}$ (column 2) = $(A_{s2} * h_2 / s_2) / A_c = 0.00083776$
 $h_2 = 600.00$
 $A_{s2} = A_{stir2} * n_{s2} = 157.0796$
 No stirrups, $n_{s2} = 2.00$
 $\rho_{s3,x}$ (web) = $(A_{s3} * h_3 / s_3) / A_c = 0.00188496$
 $h_3 = 1800.00$
 $A_{s3} = A_{stir3} * n_{s3} = 0.00$
 No stirrups, $n_{s3} = 2.00$

$\rho_{sh,y} = \rho_{s1,y} + \rho_{s2,y} + \rho_{s3,y} = 0.00069813$
 $\rho_{s1,y}$ (column 1) = $(A_{s1} * h_1 / s_1) / A_c = 0.00034907$
 $h_1 = 250.00$
 $A_{s1} = A_{stir1} * n_{s1} = 157.0796$
 No stirrups, $n_{s1} = 2.00$
 $\rho_{s2,y}$ (column 2) = $(A_{s2} * h_2 / s_2) / A_c = 0.00034907$
 $h_2 = 250.00$

$As_2 = Astir_2 * ns_2 = 157.0796$
 No stirups, $ns_2 = 2.00$
 $ps_{3,y} (web) = (As_3 * h_3 / s_3) / A_c = 0.00$
 $h_3 = 250.00$
 $As_3 = Astir_3 * ns_3 = 157.0796$
 No stirups, $ns_3 = 0.00$

$A_{sec} = 750000.00$
 $s_1 = 150.00$
 $s_2 = 150.00$
 $s_3 = 200.00$

$fy_{we} = 625.00$
 $f_{ce} = 25.00$

From ((5.A5), TBDY), TBDY: $cc = 0.00202463$
 $c = \text{confinement factor} = 1.00246$

$y_1 = 0.00140044$
 $sh_1 = 0.0044814$

$ft_1 = 420.1317$
 $fy_1 = 350.1097$

$su_1 = 0.00512$

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
 and also multiplied by the shear_factor according to 15.7.1.4, with
 Shear_factor = 1.00

$lo/lo_{u,min} = lb/ld = 0.30$

$su_1 = 0.4 * esu_{1,nominal} ((5.5), TBDY) = 0.032$

From table 5A.1, TBDY: $esu_{1,nominal} = 0.08$,

For calculation of $esu_{1,nominal}$ and y_1 , sh_1 , ft_1 , fy_1 , it is considered
 characteristic value $fsy_1 = fs_1 / 1.2$, from table 5.1, TBDY.

y_1 , sh_1 , ft_1 , fy_1 , are also multiplied by $\text{Min}(1, 1.25 * (lb/ld)^{2/3})$, from 10.3.5, ASCE 41-17.

with $fs_1 = fs = 350.1097$

with $Es_1 = Es = 200000.00$

$y_2 = 0.00140044$
 $sh_2 = 0.0044814$

$ft_2 = 420.1317$
 $fy_2 = 350.1097$

$su_2 = 0.00512$

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
 and also multiplied by the shear_factor according to 15.7.1.4, with
 Shear_factor = 1.00

$lo/lo_{u,min} = lb/lb_{min} = 0.30$

$su_2 = 0.4 * esu_{2,nominal} ((5.5), TBDY) = 0.032$

From table 5A.1, TBDY: $esu_{2,nominal} = 0.08$,

For calculation of $esu_{2,nominal}$ and y_2 , sh_2 , ft_2 , fy_2 , it is considered
 characteristic value $fsy_2 = fs_2 / 1.2$, from table 5.1, TBDY.

y_2 , sh_2 , ft_2 , fy_2 , are also multiplied by $\text{Min}(1, 1.25 * (lb/ld)^{2/3})$, from 10.3.5, ASCE 41-17.

with $fs_2 = fs = 350.1097$

with $Es_2 = Es = 200000.00$

$y_v = 0.00140044$
 $sh_v = 0.0044814$

$ft_v = 420.1317$
 $fy_v = 350.1097$

$suv = 0.00512$

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
 and also multiplied by the shear_factor according to 15.7.1.4, with
 Shear_factor = 1.00

$lo/lo_{u,min} = lb/ld = 0.30$

$suv = 0.4 * esuv_{nominal} ((5.5), TBDY) = 0.032$

From table 5A.1, TBDY: $esuv_{nominal} = 0.08$,

considering characteristic value $fsyv = fsv / 1.2$, from table 5.1, TBDY

For calculation of $esuv_{nominal}$ and y_v , sh_v , ft_v , fy_v , it is considered
 characteristic value $fsyv = fsv / 1.2$, from table 5.1, TBDY.

y_1 , sh_1 , ft_1 , fy_1 , are also multiplied by $\text{Min}(1, 1.25 * (lb/ld)^{2/3})$, from 10.3.5, ASCE 41-17.

with $fsv = fs = 350.1097$

with $Esv = Es = 200000.00$

$1 = Asl_{ten} / (b * d) * (fs_1 / fc) = 0.0635264$

$2 = Asl_{com} / (b * d) * (fs_2 / fc) = 0.0635264$

$v = Asl_{mid} / (b * d) * (fsv / fc) = 0.03609935$

and confined core properties:

$$b = 2940.00$$

$$d = 178.00$$

$$d' = 12.00$$

$$fcc (5A.2, TBDY) = 25.06158$$

$$cc (5A.5, TBDY) = 0.00202463$$

$$c = \text{confinement factor} = 1.00246$$

$$1 = A_{sl,ten}/(b*d)*(f_{s1}/f_c) = 0.07574806$$

$$2 = A_{sl,com}/(b*d)*(f_{s2}/f_c) = 0.07574806$$

$$v = A_{sl,mid}/(b*d)*(f_{sv}/f_c) = 0.0430444$$

Case/Assumption: Unconfined full section - Steel rupture

' satisfies Eq. (4.3)

--->

$v < v_{s,y2}$ - LHS eq.(4.5) is satisfied

--->

$$s_u (4.9) = 0.20311835$$

$$M_u = M_{Rc} (4.14) = 2.4003E+008$$

$$u = s_u (4.1) = 3.0889637E-005$$

Calculation of ratio l_b/l_d

Inadequate Lap Length with $l_b/l_d = 0.30$

Calculation of Shear Strength $V_r = \min(V_{r1}, V_{r2}) = 1.0244E+006$

Calculation of Shear Strength at edge 1, $V_{r1} = 1.0244E+006$

From (22.5.1.1) and 11.5.4.3, ACI 318-14: $V_{r1} = V_n < 0.83*f'_c*0.5*h*d$

NOTE: In expression (22.5.1.1) ' V_w ' is replaced by ' $V_w + f*V_f$ ' where V_f is the contribution of FRPs (11.3), ACI 440).

From Table (11.5.4.6(d-e)), ACI 318-14: $V_c = 815517.768$

$$M_u/V_u - l_w/2 = 0.00 \leq 0$$

= 1 (normal-weight concrete)

$$f'_c = 25.00, \text{ but } f_c^{0.5} \leq 8.3 \text{ MPa (22.5.3.1, ACI 318-14)}$$

$$h = 3000.00$$

$$d = 200.00$$

$$l_w = 250.00$$

$$M_u = 3.7289358E-011$$

$$V_u = 1.7354940E-029$$

$$N_u = 27588.841$$

From (11.5.4.8), ACI 318-14: $V_s = V_{s1} + V_{s2} + V_{s3} = 104719.755$

$V_{s1} = 52359.878$ is calculated for pseudo-Column 1, with:

$$d = 200.00$$

$$A_v = 157079.633$$

$$s = 150.00$$

$$f_y = 500.00$$

V_{s1} has been multiplied by $2(1-s/d)$ ($s > d/2$, according to ASCE 41-17,10.3.4)

$$2(1-s/d) = 0.50$$

$V_{s2} = 52359.878$ is calculated for pseudo-Column 2, with:

$$d = 200.00$$

$$A_v = 157079.633$$

$$s = 150.00$$

$$f_y = 500.00$$

V_{s2} has been multiplied by $2(1-s/d)$ ($s > d/2$, according to ASCE 41-17,10.3.4)

$$2(1-s/d) = 0.50$$

$V_{s3} = 0.00$ is calculated for web, with:

$$d = 200.00$$

$$A_v = 0.00$$

$$s = 200.00$$

$$f_y = 500.00$$

V_{s3} has been multiplied by $2(1-s/d)$ ($s > d/2$, according to ASCE 41-17,10.3.4)

$$2(1-s/d) = 0.00$$

$$V_f((11-3)-(11.4), \text{ACI 440}) = 109599.773$$

$f = 0.95$, for fully-wrapped sections

$w_f/s_f = 1$ (FRP strips adjacent to one another).

In (11.3) $\sin + \cos$ is replaced with $(\cot + \cot\alpha)\sin\alpha$ which is more a generalised expression, where α is the angle of the crack direction (see KANEPE).

This later relation, considered as a function $V_f(\alpha)$, is implemented for every different fiber orientation α_i , as well as for 2 crack directions, $\alpha = 45^\circ$ and $\alpha = -45^\circ$ to take into consideration the cyclic seismic loading.

orientation 1: $\alpha = b1 + 90^\circ = 90.00$

$V_f = \text{Min}(|V_f(45, 1)|, |V_f(-45, a1)|)$, with:

total thickness per orientation, $t_{f1} = N_L \cdot t / N_{oDir} = 1.016$

$d_{fv} = d$ (figure 11.2, ACI 440) = 208.00

$f_{fe}((11-5), \text{ACI 440}) = 259.312$

$E_f = 64828.00$

$f_e = 0.004$, from (11.6a), ACI 440

with $f_u = 0.01$

From (11-11), ACI 440: $V_s + V_f \leq 1.9929E+006$

$b_w = 3000.00$

Calculation of Shear Strength at edge 2, $V_{r2} = 1.0244E+006$

From (22.5.1.1) and 11.5.4.3, ACI 318-14: $V_{r2} = V_n < 0.83 \cdot f_c' \cdot \alpha^{0.5} \cdot h \cdot d$

NOTE: In expression (22.5.1.1) ' V_w ' is replaced by ' $V_w + f \cdot V_f$ ' where V_f is the contribution of FRPs (11.3), ACI 440).

From Table (11.5.4.6(d-e)), ACI 318-14: $V_c = 815517.768$

$\mu_u / \nu_u - l_w / 2 = 0.00 \leq 0$

$= 1$ (normal-weight concrete)

$f_c' = 25.00$, but $f_c'^{0.5} \leq 8.3$ MPa (22.5.3.1, ACI 318-14)

$h = 3000.00$

$d = 200.00$

$l_w = 250.00$

$\mu_u = 3.7289358E-011$

$\nu_u = 1.7354940E-029$

$N_u = 27588.841$

From (11.5.4.8), ACI 318-14: $V_s = V_{s1} + V_{s2} + V_{s3} = 104719.755$

$V_{s1} = 52359.878$ is calculated for pseudo-Column 1, with:

$d = 200.00$

$A_v = 157079.633$

$s = 150.00$

$f_y = 500.00$

V_{s1} has been multiplied by $2(1-s/d)$ ($s > d/2$, according to ASCE 41-17,10.3.4)

$2(1-s/d) = 0.50$

$V_{s2} = 52359.878$ is calculated for pseudo-Column 2, with:

$d = 200.00$

$A_v = 157079.633$

$s = 150.00$

$f_y = 500.00$

V_{s2} has been multiplied by $2(1-s/d)$ ($s > d/2$, according to ASCE 41-17,10.3.4)

$2(1-s/d) = 0.50$

$V_{s3} = 0.00$ is calculated for web, with:

$d = 200.00$

$A_v = 0.00$

$s = 200.00$

$f_y = 500.00$

V_{s3} has been multiplied by $2(1-s/d)$ ($s > d/2$, according to ASCE 41-17,10.3.4)

$2(1-s/d) = 0.00$

$V_f((11-3)-(11.4), \text{ACI 440}) = 109599.773$

$f = 0.95$, for fully-wrapped sections

$w_f/s_f = 1$ (FRP strips adjacent to one another).

In (11.3) $\sin + \cos$ is replaced with $(\cot + \cot\alpha)\sin\alpha$ which is more a generalised expression, where α is the angle of the crack direction (see KANEPE).

This later relation, considered as a function $V_f(\alpha)$, is implemented for every different fiber orientation α_i , as well as for 2 crack directions, $\alpha = 45^\circ$ and $\alpha = -45^\circ$ to take into consideration the cyclic seismic loading.

orientation 1: $\alpha = b1 + 90^\circ = 90.00$

$V_f = \text{Min}(|V_f(45, 1)|, |V_f(-45, a1)|)$, with:

total thickness per orientation, $t_{f1} = N_L \cdot t / N_{oDir} = 1.016$

$d_{fv} = d$ (figure 11.2, ACI 440) = 208.00

$f_{fe} ((11-5), ACI 440) = 259.312$
 $E_f = 64828.00$
 $f_e = 0.004$, from (11.6a), ACI 440
with $f_u = 0.01$
From (11-11), ACI 440: $V_s + V_f \leq 1.9929E+006$
 $b_w = 3000.00$

End Of Calculation of Shear Capacity ratio for element: wall W1 of floor 1
At local axis: 2

Start Of Calculation of Chord Rotation Capacity for element: wall W1 of floor 1
At local axis: 3
Integration Section: (d)
Section Type: rcrcws

Constant Properties

Knowledge Factor, $\gamma = 1.00$
According to 10.7.2.3, ASCE 41-17, shear walls with
transverse reinforcement percentage, $\gamma < 0.0015$
are considered Force-Controlled and lower-bound strengths are used according to 7.5.1.3, ASCE 41-17
 $\gamma = 0.00069813$

with $\gamma = \gamma_1 + \gamma_2 + \gamma_3$, being the shear reinf. ratio in a plane perpendicular to the shear axis 2
(pseudo-col.1 $\gamma_1 = A_{s1} \cdot b_1 / s_1 = (A_{s1} \cdot h_1 / s_1) / A_c = 0.00034907$
 $h_1 = 250.00$
 $s_1 = 150.00$
total area of hoops perpendicular to shear axis, $A_{s1} = 157.0796$
(pseudo-col.2 $\gamma_2 = A_{s2} \cdot b_2 / s_2 = (A_{s2} \cdot h_2 / s_2) / A_c = 0.00034907$
 $h_2 = 250.00$
 $s_2 = 150.00$
total area of hoops perpendicular to shear axis, $A_{s2} = 157.0796$
(grid $\gamma_3 = A_{s3} \cdot b_3 / s_3 = (A_{s3} \cdot h_3 / s_3) / A_c = 0.00$
 $h_3 = 250.00$
 $s_3 = 200.00$
total area of hoops perpendicular to shear axis, $A_{s3} = 0.00$
total section area, $A_c = 750000.00$

Consequently:
New material of Secondary Member: Concrete Strength, $f_c = f_{c_lower_bound} = 25.00$
New material of Secondary Member: Steel Strength, $f_s = f_{s_lower_bound} = 500.00$
Concrete Elasticity, $E_c = 26999.444$
Steel Elasticity, $E_s = 200000.00$
Total Height, $H_{tot} = 3000.00$
Edges Width, $W_{edg} = 250.00$
Edges Height, $H_{edg} = 600.00$
Web Width, $W_{web} = 250.00$
Cover Thickness, $c = 25.00$
Element Length, $L = 3000.00$
Secondary Member
Smooth Bars
Ductile Steel
Without Detailing for Earthquake Resistance (including stirrups not closed at 135°)
Longitudinal Bars With Ends Lapped Starting at the End Sections
Inadequate Lap Length with $l_b / l_d = 0.30$
FRP Wrapping Data
Type: Carbon
Cured laminate properties (design values)
Thickness, $t = 1.016$
Tensile Strength, $f_{fu} = 1055.00$
Tensile Modulus, $E_f = 64828.00$
Elongation, $e_{fu} = 0.01$
Number of directions, $N_{oDir} = 1$
Fiber orientations, $\theta_i: 0.00^\circ$

Number of layers, NL = 1
Radius of rounding corners, R = 40.00

Stepwise Properties

Bending Moment, M = -6.0084169E-011
Shear Force, V2 = 2.0402016E-014
Shear Force, V3 = 32914.791
Axial Force, F = -33005.924
Longitudinal Reinforcement Area Distribution (in 2 divisions)
-Tension: Aslt = 0.00
-Compression: Aslc = 7269.645
Longitudinal Reinforcement Area Distribution (in 3 divisions)
-Tension: Asl,ten = 2830.575
-Compression: Asl,com = 2830.575
-Middle: Asl,mid = 1608.495
Mean Diameter of Tension Reinforcement, DbL = 16.46154

New component: From table 7-7, ASCE 41_17: Final chord rotation Capacity $\phi_R = 1.0$ $\phi = 0.00318826$
 $\phi = \phi_y + \phi_p = 0.00318826$

- Calculation of ϕ_y -

$\phi_y = (M_y \cdot I_p) / (E I)_{\text{Eff}} = 0.00118826$ ((10-5), ASCE 41-17))
 $M_y = 1.8276E+008$
 $(E I)_{\text{Eff}} = 0.35 \cdot E_c \cdot I$ (table 10-5)
 $E_c \cdot I = 1.0547E+014$
 $I_p = 0.5 \cdot d = 0.5 \cdot (0.8 \cdot h) = 240.00$

Calculation of Yielding Moment M_y

Calculation of ϕ_y and M_y according to Annex 7 -

$\phi_y = \text{Min}(\phi_{y_{\text{ten}}}, \phi_{y_{\text{com}}})$
 $\phi_{y_{\text{ten}}} = 8.9802449E-006$
with ((10.1), ASCE 41-17) $f_y = \text{Min}(f_y, 1.25 \cdot f_y \cdot (I_b / I_d)^{2/3}) = 280.0878$
 $d = 208.00$
 $\phi_y = 0.25025656$
 $A = 0.01183892$
 $B = 0.00719009$
with $p_t = 0.00453618$
 $p_c = 0.00453618$
 $p_v = 0.00257772$
 $N = 33005.924$
 $b = 3000.00$
 $\phi = 0.20192308$
 $\phi_{y_{\text{comp}}} = 3.2313175E-005$
with f_c^* (12.3, (ACI 440)) = 25.002
 $f_c = 25.00$
 $f_l = 0.17503396$
 $b = 3000.00$
 $h = 250.00$
 $A_g = 750000.00$
From (12.9), ACI 440: $k_a = 0.0036426$
 $g = p_t + p_c + p_v = 0.01165007$
 $r_c = 40.00$
 $A_e / A_c = 0.52453487$
Effective FRP thickness, $t_f = NL \cdot t \cdot \cos(b_1) = 1.016$
effective strain from (12.5) and (12.12), $\epsilon_{fe} = 0.004$
 $f_u = 0.01$

Ef = 64828.00
Ec = 26999.444
y = 0.24799872
A = 0.01149141
B = 0.00700125
with Es = 200000.00

Calculation of ratio lb/ld

Inadequate Lap Length with lb/ld = 0.30

- Calculation of ρ -

Considering wall controlled by flexure (shear control ratio ≤ 1),
from table 10-19: $\rho = 0.002$
with:

- Condition i (shear wall and wall segments)

- $(A_s - A_s') \cdot f_y + P / (t_w \cdot l_w \cdot f_c') = -0.19209689$

$A_s = 0.00$

$A_s' = 7269.645$

$f_y = 500.00$

$P = 33005.924$

$t_w = 3000.00$

$l_w = 250.00$

$f_c = 25.00$

- $V / (t_w \cdot l_w \cdot f_c^{0.5}) = 6.5518667E-020$, NOTE: units in lb & in

- Confined Boundary: No

Boundary hoops spacing exceed 8db ($s_1 > 8 \cdot db$ or $s_2 > 8 \cdot db$)

Boundary Trans. Reinf. does not exceed 50% of ACI 318 provision ($V_{w1} + V_{w2} > 0.50 \cdot (V - V_c - V_{w3})$)

With

Boundary Element 1:

$V_{w1} = 104719.755$

$s_1 = 150.00$

Boundary Element 2:

$V_{w2} = 104719.755$

$s_2 = 150.00$

Grid Shear Force, $V_{w3} = 0.00$

Concrete Shear Force, $V_c = 177063.805$

(The variables above have already been given in Shear control ratio calculation)

Mean diameter of all bars, $db = 17.33333$

Design Shear Force, $V = 2.0402016E-014$

End Of Calculation of Chord Rotation Capacity for element: wall W1 of floor 1

At local axis: 3

Integration Section: (d)

Calculation No. 9

wall W1, Floor 1


Limit State: Life Safety (data interpolation between analysis steps 1 and 2)

Analysis: Uniform +X

Check: Shear capacity VR_d

Edge: Start

Local Axis: (2)



Start Of Calculation of Shear Capacity for element: wall W1 of floor 1

At local axis: 2

Integration Section: (a)

Section Type: rcrws

Constant Properties

Knowledge Factor, $\gamma = 1.00$

Member Shear Force is generally considered as Force-Controlled Action according to Table C7-1, ASCE 41-17.

Lower-bound strengths are used for Force-Controlled Actions according to 7.5.1.3, ASCE 41-17

Consequently:

New material of Secondary Member: Concrete Strength, $f_c = f_{c_lower_bound} = 25.00$

New material of Secondary Member: Steel Strength, $f_s = f_{s_lower_bound} = 500.00$

Concrete Elasticity, $E_c = 26999.444$

Steel Elasticity, $E_s = 200000.00$

Total Height, $H_{tot} = 3000.00$

Edges Width, $W_{edg} = 250.00$

Edges Height, $H_{edg} = 600.00$

Web Width, $W_{web} = 250.00$

Cover Thickness, $c = 25.00$

Element Length, $L = 3000.00$

Secondary Member

Smooth Bars

Ductile Steel

Without Detailing for Earthquake Resistance (including stirrups not closed at 135°)

Longitudinal Bars With Ends Lapped Starting at the End Sections

Inadequate Lap Length with $l_o/l_{ou,min} = l_b/l_d = 0.30$

FRP Wrapping Data

Type: Carbon

Cured laminate properties (design values)

Thickness, $t = 1.016$

Tensile Strength, $f_{fu} = 1055.00$

Tensile Modulus, $E_f = 64828.00$

Elongation, $\epsilon_{fu} = 0.01$

Number of directions, $NoDir = 1$

Fiber orientations, $b_i: 0.00^\circ$

Number of layers, $NL = 1$

Radius of rounding corners, $R = 40.00$

Stepwise Properties

EDGE -A-

Bending Moment, $M_a = -1.6039204E-011$

Shear Force, $V_a = -1.2948432E-014$

EDGE -B-

Bending Moment, $M_b = -2.4510145E-011$

Shear Force, $V_b = 1.2948432E-014$

BOTH EDGES

Axial Force, $F = -31026.87$

Longitudinal Reinforcement Area Distribution (in 2 divisions)

-Tension: $As_t = 0.00$

-Compression: $As_c = 7269.645$

Longitudinal Reinforcement Area Distribution (in 3 divisions)

-Tension: $As_{t,ten} = 2830.575$

-Compression: $As_{c,com} = 2830.575$

-Middle: $As_{mid} = 1608.495$

Mean Diameter of Tension Reinforcement, $Db_{L,ten} = 16.46154$

New component: From table 7-7, ASCE 41_17: Final Shear Capacity $V_R = 1.0 \cdot V_n = 427297.088$

From (22.5.1.1) and 11.5.4.3, ACI 318-14: $V_n < 0.83 \cdot f_c' \cdot 0.5 \cdot h \cdot d = 427297.088$

NOTE: In expression (22.5.1.1) ' V_w ' is replaced by ' $V_w + f \cdot V_f$ ' where V_f is the contribution of FRPs (11.3), ACI 440).

From Table (11.5.4.6(d-e)), ACI 318-14: $V_c = 218457.549$

$\mu_u / \mu - l_w / 2 = 1113.699 > 0$

= 1 (normal-weight concrete)

$f_c' = 25.00$, but $f_c'^{0.5} \leq 8.3$ MPa (22.5.3.1, ACI 318-14)

$h = 3000.00$

$d = 200.00$

$l_w = 250.00$

$\mu_u = 1.6039204E-011$

$V_u = 1.2948432E-014$

$N_u = 31026.87$

From (11.5.4.8), ACI 318-14: $V_s = V_{s1} + V_{s2} + V_{s3} = 104719.755$

$V_{s1} = 52359.878$ is calculated for pseudo-Column 1, with:

$d = 200.00$

$A_v = 157079.633$

$s = 150.00$

$f_y = 500.00$

V_{s1} has been multiplied by $2(1-s/d)$ ($s > d/2$, according to ASCE 41-17,10.3.4)

$2(1-s/d) = 0.50$

$V_{s2} = 52359.878$ is calculated for pseudo-Column 2, with:

$d = 200.00$

$A_v = 157079.633$

$s = 150.00$

$f_y = 500.00$

V_{s2} has been multiplied by $2(1-s/d)$ ($s > d/2$, according to ASCE 41-17,10.3.4)

$2(1-s/d) = 0.50$

$V_{s3} = 0.00$ is calculated for web, with:

$d = 200.00$

$A_v = 0.00$

$s = 200.00$

$f_y = 500.00$

V_{s3} has been multiplied by $2(1-s/d)$ ($s > d/2$, according to ASCE 41-17,10.3.4)

$2(1-s/d) = 0.00$

V_f ((11-3)-(11.4), ACI 440) = 109599.773

$f = 0.95$, for fully-wrapped sections

$w_f / s_f = 1$ (FRP strips adjacent to one another).

In (11.3) $\sin + \cos$ is replaced with $(\cot + \cot a) \sin a$ which is more a generalised expression,

where a is the angle of the crack direction (see KANEPE).

This later relation, considered as a function $V_f(\alpha_i)$, is implemented for every different fiber orientation α_i ,

as well as for 2 crack directions, $\theta = 45^\circ$ and $\theta = -45^\circ$ to take into consideration the cyclic seismic loading.

orientation 1: $\theta_1 = \theta_1 + 90^\circ = 90.00$

$V_f = \text{Min}(|V_f(45, \theta_1)|, |V_f(-45, \theta_1)|)$, with:

total thickness per orientation, $t_{f1} = N_L * t / N_{\text{Dir}} = 1.016$

$d_{fv} = d$ (figure 11.2, ACI 440) = 208.00

$f_{fe}((11-5), \text{ACI 440}) = 259.312$

$E_f = 64828.00$

$f_e = 0.004$, from (11.6a), ACI 440

with $f_u = 0.01$

From (11-11), ACI 440: $V_s + V_f \leq 1.9929E+006$

$b_w = 3000.00$

End Of Calculation of Shear Capacity for element: wall W1 of floor 1

At local axis: 2

Integration Section: (a)

Calculation No. 10

wall W1, Floor 1

Limit State: Life Safety (data interpolation between analysis steps 1 and 2)

Analysis: Uniform +X

Check: Chord rotation capacity (θ_u)

Edge: Start

Local Axis: (2)



Start Of Calculation of Shear Capacity ratio for element: wall W1 of floor 1

At Shear local axis: 3

(Bending local axis: 2)

Section Type: rcrrws

Constant Properties

Knowledge Factor, $K = 1.00$

Mean strength values are used for both shear and moment calculations.

Consequently:

New material of Secondary Member: Concrete Strength, $f_c = f_{cm} = 25.00$

New material of Secondary Member: Steel Strength, $f_s = f_{sm} = 500.00$

Concrete Elasticity, $E_c = 26999.444$

```

Steel Elasticity, Es = 200000.00
#####
Note: Especially for the calculation of moment strengths,
the above steel re-bar strengths are multiplied by 1.25 according to R18.6.5, ACI 318-14
New material: Steel Strength, fs = 1.25*fsm = 625.00
#####
Total Height, Htot = 3000.00
Edges Width, Wedg = 250.00
Edges Height, Hedg = 600.00
Web Width, Wweb = 250.00
Cover Thickness, c = 25.00
Mean Confinement Factor overall section = 1.00246
Element Length, L = 3000.00
Secondary Member
Smooth Bars
Ductile Steel
Without Detailing for Earthquake Resistance (including stirrups not closed at 135°)
Longitudinal Bars With Ends Lapped Starting at the End Sections
Inadequate Lap Length with lo/lo,min = 0.30
FRP Wrapping Data
Type: Carbon
Cured laminate properties (design values)
Thickness, t = 1.016
Tensile Strength, ffu = 1055.00
Tensile Modulus, Ef = 64828.00
Elongation, efu = 0.01
Number of directions, NoDir = 1
Fiber orientations, bi: 0.00°
Number of layers, NL = 1
Radius of rounding corners, R = 40.00
-----

Stepwise Properties
-----
At local axis: 3
EDGE -A-
Shear Force, Va = 1.0097420E-028
EDGE -B-
Shear Force, Vb = -1.0097420E-028
BOTH EDGES
Axial Force, F = -27588.841
Longitudinal Reinforcement Area Distribution (in 2 divisions)
-Tension: Aslt = 0.00
-Compression: Aslc = 7269.645
Longitudinal Reinforcement Area Distribution (in 3 divisions)
-Tension: Asl,ten = 2865.133
-Compression: Asl,com = 2865.133
-Middle: Asl,mid = 0.00
(According to 10.7.2.3 Asl,mid is setted equal to zero)
-----
-----

Calculation of Shear Capacity ratio , Ve/Vr = 1.02813
Member Controlled by Shear (Ve/Vr > 1)
Calculation of Shear Demand from fig. R18.6.5, ACI 318-14 Ve = (Mpr1 + Mpr2)/ln = 2.5600E+006
with
Mpr1 = Max(Mu1+ , Mu1-) = 3.8401E+009
Mu1+ = 3.3585E+009, is the ultimate moment strength at the edge 1 of the member in the actual moment direction
which is defined for the static loading combination
Mu1- = 3.8401E+009, is the ultimate moment strength at the edge 1 of the member in the opposite moment
direction which is defined for the static loading combination
Mpr2 = Max(Mu2+ , Mu2-) = 3.8401E+009
Mu2+ = 3.3585E+009, is the ultimate moment strength at the edge 2 of the member in the actual moment direction
which is defined for the static loading combination
Mu2- = 3.8401E+009, is the ultimate moment strength at the edge 2 of the member in the opposite moment
direction which is defined for the static loading combination

```

Calculation of Mu1+

Calculation of ultimate curvature ϕ_u according to 4.1, Biskinis/Fardis 2013:

$$u = 2.0296703E-006$$

$$Mu = 3.3585E+009$$

with full section properties:

$$b = 250.00$$

$$d = 2957.00$$

$$d' = 43.00$$

$$v = 0.0014928$$

$$N = 27588.841$$

$$f_c = 25.00$$

$$\phi_c \text{ (5A.5, TBDY)} = 0.002$$

$$\text{Final value of } \phi_u: \phi_u^* = \text{shear_factor} * \text{Max}(\phi_u, \phi_c) = 0.0035$$

The Shear_factor is considered equal to 1 (pure moment strength)

$$\text{From (5.4b), TBDY: } \phi_u = 0.0035$$

$$\phi_{we} \text{ ((5.4c), TBDY)} = a_{se} * \phi_{sh,min} * f_{ywe}/f_{ce} + \text{Min}(\phi_{fx}, \phi_{fy}) = 0.00$$

where $\phi_f = a_f * \phi_f * f_{fe}/f_{ce}$ is accounting for FRP contribution like EC8-part3 A.4.4.3(6)

$$\phi_{fx} = 0.00$$

$$a_f = 0.00$$

$$b = 250.00$$

$$h = 3000.00$$

$$\text{From EC8 A.4.4.3(6), } \phi_f = 2t_f/b_w = 0.008128$$

$$b_w = 250.00$$

$$\text{effective stress from (A.35), } f_{fe} = 757.2164$$

$$\phi_{fy} = 0.00$$

$$a_f = 0.00$$

$$b = 3000.00$$

$$h = 250.00$$

$$\text{From EC8 A.4.4.3(6), } \phi_f = 2t_f/b_w = 0.00067733$$

$$b_w = 3000.00$$

$$\text{effective stress from (A.35), } f_{fe} = 954.4864$$

$$R = 40.00$$

$$\text{Effective FRP thickness, } t_f = NL * t * \cos(b_1) = 1.016$$

$$f_{u,f} = 1055.00$$

$$E_f = 64828.00$$

$$u_{f,f} = 0.015$$

$$a_{se} \text{ ((5.4d), TBDY)} = (a_{se1} * A_{col1} + a_{se2} * A_{col2} + a_{se3} * A_{web}) / A_{sec} = 0.00$$

$$a_{se1} = 0.00$$

$$sh_1 = 150.00$$

$$bo_1 = 190.00$$

$$ho_1 = 540.00$$

$$bi2_1 = 655400.00$$

$$a_{se2} = 0.00$$

$$sh_2 = 150.00$$

$$bo_2 = 190.00$$

$$ho_2 = 540.00$$

$$bi2_2 = 655400.00$$

$$a_{se3} = 0 \text{ (grid does not provide confinement)}$$

$$\phi_{sh,min} = \text{Min}(\phi_{sh,x}, \phi_{sh,y}) = 0.00069813$$

Expression ((5.4d), TBDY) for $\phi_{sh,min}$ has been multiplied by 0.3 according to 15.7.1.3 for members without earthquake detailing (90° closed stirrups)

$$\phi_{sh,x} = \phi_{s1,x} + \phi_{s2,x} + \phi_{s3,x} = 0.00356047$$

$$\phi_{s1,x} \text{ (column 1)} = (A_{s1} * h_1 / s_1) / A_c = 0.00083776$$

$$h_1 = 600.00$$

$$A_{s1} = A_{stir1} * n_{s1} = 157.0796$$

$$\text{No stirrups, } n_{s1} = 2.00$$

$$\phi_{s2,x} \text{ (column 2)} = (A_{s2} * h_2 / s_2) / A_c = 0.00083776$$

$h_2 = 600.00$
 $As_2 = Astir_2 * ns_2 = 157.0796$
 No stirups, $ns_2 = 2.00$
 $ps_{3,x} (web) = (As_3 * h_3 / s_3) / Ac = 0.00188496$
 $h_3 = 1800.00$
 $As_3 = Astir_3 * ns_3 = 0.00$
 No stirups, $ns_3 = 2.00$

$ps_{sh,y} = ps_1,y + ps_2,y + ps_3,y = 0.00069813$
 $ps_1,y (column\ 1) = (As_1 * h_1 / s_1) / Ac = 0.00034907$
 $h_1 = 250.00$
 $As_1 = Astir_1 * ns_1 = 157.0796$
 No stirups, $ns_1 = 2.00$
 $ps_2,y (column\ 2) = (As_2 * h_2 / s_2) / Ac = 0.00034907$
 $h_2 = 250.00$
 $As_2 = Astir_2 * ns_2 = 157.0796$
 No stirups, $ns_2 = 2.00$
 $ps_3,y (web) = (As_3 * h_3 / s_3) / Ac = 0.00$
 $h_3 = 250.00$
 $As_3 = Astir_3 * ns_3 = 157.0796$
 No stirups, $ns_3 = 0.00$

$A_{sec} = 750000.00$
 $s_1 = 150.00$
 $s_2 = 150.00$
 $s_3 = 200.00$
 $fy_{we} = 625.00$
 $f_{ce} = 25.00$
 From ((5.A.5), TBDY), TBDY: $cc = 0.00202463$
 $c = \text{confinement factor} = 1.00246$
 $y_1 = 0.00140044$
 $sh_1 = 0.0044814$
 $ft_1 = 420.1317$
 $fy_1 = 350.1097$
 $su_1 = 0.00512$
 using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
 and also multiplied by the shear_factor according to 15.7.1.4, with
 $Shear_factor = 1.00$
 $lo/lou, min = lb/l_d = 0.30$
 $su_1 = 0.4 * esu_{1_nominal} ((5.5), TBDY) = 0.032$
 From table 5A.1, TBDY: $esu_{1_nominal} = 0.08$,
 For calculation of $esu_{1_nominal}$ and y_1, sh_1, ft_1, fy_1 , it is considered
 characteristic value $fsy_1 = fs_1 / 1.2$, from table 5.1, TBDY.
 y_1, sh_1, ft_1, fy_1 , are also multiplied by $\text{Min}(1, 1.25 * (lb/l_d)^{2/3})$, from 10.3.5, ASCE 41-17.
 with $fs_1 = fs = 350.1097$
 with $Es_1 = Es = 200000.00$
 $y_2 = 0.00140044$
 $sh_2 = 0.0044814$
 $ft_2 = 420.1317$
 $fy_2 = 350.1097$
 $su_2 = 0.00512$
 using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
 and also multiplied by the shear_factor according to 15.7.1.4, with
 $Shear_factor = 1.00$
 $lo/lou, min = lb/l_b, min = 0.30$
 $su_2 = 0.4 * esu_{2_nominal} ((5.5), TBDY) = 0.032$
 From table 5A.1, TBDY: $esu_{2_nominal} = 0.08$,
 For calculation of $esu_{2_nominal}$ and y_2, sh_2, ft_2, fy_2 , it is considered
 characteristic value $fsy_2 = fs_2 / 1.2$, from table 5.1, TBDY.
 y_1, sh_1, ft_1, fy_1 , are also multiplied by $\text{Min}(1, 1.25 * (lb/l_d)^{2/3})$, from 10.3.5, ASCE 41-17.
 with $fs_2 = fs = 350.1097$
 with $Es_2 = Es = 200000.00$
 $y_v = 0.00140044$
 $sh_v = 0.0044814$
 $ft_v = 420.1317$
 $fy_v = 350.1097$
 $suv = 0.00512$

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
 and also multiplied by the shear_factor according to 15.7.1.4, with
 Shear_factor = 1.00
 $l_o/l_{ou,min} = l_b/l_d = 0.30$
 $suv = 0.4 * esuv_{nominal} ((5.5), TBDY) = 0.032$
 From table 5A.1, TBDY: $esuv_{nominal} = 0.08$,
 considering characteristic value $fsyv = fsv/1.2$, from table 5.1, TBDY
 For calculation of $esuv_{nominal}$ and yv , shv , ftv , fyv , it is considered
 characteristic value $fsyv = fsv/1.2$, from table 5.1, TBDY.
 $y1$, $sh1$, $ft1$, $fy1$, are also multiplied by $Min(1, 1.25 * (l_b/l_d)^{2/3})$, from 10.3.5, ASCE 41-17.
 with $fsv = fs = 350.1097$
 with $Esv = Es = 200000.00$
 $1 = Asl_{ten}/(b*d) * (fs1/fc) = 0.05427722$
 $2 = Asl_{com}/(b*d) * (fs2/fc) = 0.05427722$
 $v = Asl_{mid}/(b*d) * (fsv/fc) = 0.00$

and confined core properties:

$b = 190.00$
 $d = 2927.00$
 $d' = 13.00$
 $fcc (5A.2, TBDY) = 25.06158$
 $cc (5A.5, TBDY) = 0.00202463$
 $c = \text{confinement factor} = 1.00246$
 $1 = Asl_{ten}/(b*d) * (fs1/fc) = 0.07214938$
 $2 = Asl_{com}/(b*d) * (fs2/fc) = 0.07214938$
 $v = Asl_{mid}/(b*d) * (fsv/fc) = 0.00$

Case/Assumption: Unconfined full section - Steel rupture
 ' satisfies Eq. (4.3)

--->
 $v < v_{s,y2}$ - LHS eq.(4.5) is satisfied
 --->
 $su (4.9) = 0.14691336$
 $Mu = MRc (4.14) = 3.3585E+009$
 $u = su (4.1) = 2.0296703E-006$

Calculation of ratio l_b/l_d

Inadequate Lap Length with $l_b/l_d = 0.30$

Calculation of $Mu1$ -

Calculation of ultimate curvature u according to 4.1, Biskinis/Fardis 2013:
 $u = 2.0532423E-006$
 $Mu = 3.8401E+009$

with full section properties:

$b = 250.00$
 $d = 2957.00$
 $d' = 43.00$
 $v = 0.0014928$
 $N = 27588.841$
 $fc = 25.00$
 $co (5A.5, TBDY) = 0.002$
 Final value of cu : $cu * = \text{shear_factor} * \text{Max}(cu, cc) = 0.0035$
 The Shear_factor is considered equal to 1 (pure moment strength)
 From (5.4b), TBDY: $cu = 0.0035$
 $we ((5.4c), TBDY) = ase * sh_{min} * fy_{we}/f_{ce} + \text{Min}(fx, fy) = 0.00$
 where $f = af * pf * f_{fe}/f_{ce}$ is accounting for FRP contribution like EC8-part3 A.4.4.3(6)

 $fx = 0.00$
 $af = 0.00$
 $b = 250.00$
 $h = 3000.00$

From EC8 A4.4.3(6), $pf = 2tf/bw = 0.008128$
 $bw = 250.00$
effective stress from (A.35), $ff,e = 757.2164$

$f_y = 0.00$
 $a_f = 0.00$
 $b = 3000.00$
 $h = 250.00$
From EC8 A4.4.3(6), $pf = 2tf/bw = 0.00067733$
 $bw = 3000.00$
effective stress from (A.35), $ff,e = 954.4864$

$R = 40.00$
Effective FRP thickness, $tf = NL*t*Cos(b1) = 1.016$
 $f_{u,f} = 1055.00$
 $E_f = 64828.00$
 $u_f = 0.015$
 $ase((5.4d), TBDY) = (ase1*A_{col1} + ase2*A_{col2} + ase3*A_{web})/A_{sec} = 0.00$
 $ase1 = 0.00$
 $sh_1 = 150.00$
 $bo_1 = 190.00$
 $ho_1 = 540.00$
 $bi2_1 = 655400.00$
 $ase2 = 0.00$
 $sh_2 = 150.00$
 $bo_2 = 190.00$
 $ho_2 = 540.00$
 $bi2_2 = 655400.00$

$ase3 = 0$ (grid does not provide confinement)
 $psh,min = Min(psh,x, psh,y) = 0.00069813$

Expression ((5.4d), TBDY) for psh,min has been multiplied by 0.3 according to 15.7.1.3 for members without earthquake detailing (90° closed stirrups)

$psh,x = ps1,x + ps2,x + ps3,x = 0.00356047$
 $ps1,x$ (column 1) = $(As1*h1/s_1)/Ac = 0.00083776$
 $h1 = 600.00$
 $As1 = Astir1*ns1 = 157.0796$
No stirrups, $ns1 = 2.00$
 $ps2,x$ (column 2) = $(As2*h2/s_2)/Ac = 0.00083776$
 $h2 = 600.00$
 $As2 = Astir2*ns2 = 157.0796$
No stirrups, $ns2 = 2.00$
 $ps3,x$ (web) = $(As3*h3/s_3)/Ac = 0.00188496$
 $h3 = 1800.00$
 $As3 = Astir3*ns3 = 0.00$
No stirrups, $ns3 = 2.00$

$psh,y = ps1,y + ps2,y + ps3,y = 0.00069813$
 $ps1,y$ (column 1) = $(As1*h1/s_1)/Ac = 0.00034907$
 $h1 = 250.00$
 $As1 = Astir1*ns1 = 157.0796$
No stirrups, $ns1 = 2.00$
 $ps2,y$ (column 2) = $(As2*h2/s_2)/Ac = 0.00034907$
 $h2 = 250.00$
 $As2 = Astir2*ns2 = 157.0796$
No stirrups, $ns2 = 2.00$
 $ps3,y$ (web) = $(As3*h3/s_3)/Ac = 0.00$
 $h3 = 250.00$
 $As3 = Astir3*ns3 = 157.0796$
No stirrups, $ns3 = 0.00$

$A_{sec} = 750000.00$
 $s_1 = 150.00$
 $s_2 = 150.00$
 $s_3 = 200.00$
 $f_{ywe} = 625.00$
 $f_{ce} = 25.00$

From (5A.5), TBDY, TBDY: $cc = 0.00202463$
 $c = \text{confinement factor} = 1.00246$
 $y1 = 0.00140044$
 $sh1 = 0.0044814$
 $ft1 = 420.1317$
 $fy1 = 350.1097$
 $su1 = 0.00512$
 using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
 and also multiplied by the shear_factor according to 15.7.1.4, with
 Shear_factor = 1.00
 $lo/lou, \min = lb/ld = 0.30$
 $su1 = 0.4 * esu1_{nominal} ((5.5), TBDY) = 0.032$
 From table 5A.1, TBDY: $esu1_{nominal} = 0.08$,
 For calculation of $esu1_{nominal}$ and $y1, sh1, ft1, fy1$, it is considered
 characteristic value $fsy1 = fs1/1.2$, from table 5.1, TBDY.
 $y1, sh1, ft1, fy1$, are also multiplied by $\text{Min}(1, 1.25 * (lb/ld)^{2/3})$, from 10.3.5, ASCE 41-17.
 with $fs1 = fs = 350.1097$
 with $Es1 = Es = 200000.00$
 $y2 = 0.00140044$
 $sh2 = 0.0044814$
 $ft2 = 420.1317$
 $fy2 = 350.1097$
 $su2 = 0.00512$
 using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
 and also multiplied by the shear_factor according to 15.7.1.4, with
 Shear_factor = 1.00
 $lo/lou, \min = lb/lb, \min = 0.30$
 $su2 = 0.4 * esu2_{nominal} ((5.5), TBDY) = 0.032$
 From table 5A.1, TBDY: $esu2_{nominal} = 0.08$,
 For calculation of $esu2_{nominal}$ and $y2, sh2, ft2, fy2$, it is considered
 characteristic value $fsy2 = fs2/1.2$, from table 5.1, TBDY.
 $y1, sh1, ft1, fy1$, are also multiplied by $\text{Min}(1, 1.25 * (lb/ld)^{2/3})$, from 10.3.5, ASCE 41-17.
 with $fs2 = fs = 350.1097$
 with $Es2 = Es = 200000.00$
 $yv = 0.00140044$
 $shv = 0.0044814$
 $ftv = 420.1317$
 $fyv = 350.1097$
 $suv = 0.00512$
 using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
 and also multiplied by the shear_factor according to 15.7.1.4, with
 Shear_factor = 1.00
 $lo/lou, \min = lb/ld = 0.30$
 $suv = 0.4 * esuv_{nominal} ((5.5), TBDY) = 0.032$
 From table 5A.1, TBDY: $esuv_{nominal} = 0.08$,
 considering characteristic value $fsyv = fsv/1.2$, from table 5.1, TBDY
 For calculation of $esuv_{nominal}$ and yv, shv, ftv, fyv , it is considered
 characteristic value $fsyv = fsv/1.2$, from table 5.1, TBDY.
 $y1, sh1, ft1, fy1$, are also multiplied by $\text{Min}(1, 1.25 * (lb/ld)^{2/3})$, from 10.3.5, ASCE 41-17.
 with $fsv = fs = 350.1097$
 with $Esv = Es = 200000.00$
 $1 = Asl, \text{ten} / (b * d) * (fs1 / fc) = 0.05427722$
 $2 = Asl, \text{com} / (b * d) * (fs2 / fc) = 0.05427722$
 $v = Asl, \text{mid} / (b * d) * (fsv / fc) = 0.0291621$
 and confined core properties:
 $b = 190.00$
 $d = 2927.00$
 $d' = 13.00$
 $fcc (5A.2, TBDY) = 25.06158$
 $cc (5A.5, TBDY) = 0.00202463$
 $c = \text{confinement factor} = 1.00246$
 $1 = Asl, \text{ten} / (b * d) * (fs1 / fc) = 0.07214938$
 $2 = Asl, \text{com} / (b * d) * (fs2 / fc) = 0.07214938$
 $v = Asl, \text{mid} / (b * d) * (fsv / fc) = 0.03876447$
 Case/Assumption: Unconfined full section - Steel rupture
 ' satisfies Eq. (4.3)

--->

$v < v_{s,y2}$ - LHS eq.(4.5) is satisfied

---->

$$s_u(4.9) = 0.15670711$$

$$M_u = M_{Rc}(4.14) = 3.8401E+009$$

$$u = s_u(4.1) = 2.0532423E-006$$

Calculation of ratio I_b/I_d

Inadequate Lap Length with $I_b/I_d = 0.30$

Calculation of M_{u2+}

Calculation of ultimate curvature u according to 4.1, Biskinis/Fardis 2013:

$$u = 2.0296703E-006$$

$$M_u = 3.3585E+009$$

with full section properties:

$$b = 250.00$$

$$d = 2957.00$$

$$d' = 43.00$$

$$v = 0.0014928$$

$$N = 27588.841$$

$$f_c = 25.00$$

$$\alpha(5A.5, TBDY) = 0.002$$

$$\text{Final value of } \alpha: \alpha^* = \text{shear_factor} * \text{Max}(\alpha, \alpha_c) = 0.0035$$

The Shear_factor is considered equal to 1 (pure moment strength)

$$\text{From (5.4b), TBDY: } \alpha = 0.0035$$

$$\alpha_e((5.4c), TBDY) = \alpha_{se} * \text{sh}_{\min} * f_{ywe}/f_{ce} + \text{Min}(\alpha_x, \alpha_y) = 0.00$$

where $\alpha = \alpha_f * p_f * f_{fe}/f_{ce}$ is accounting for FRP contribution like EC8-part3 A.4.4.3(6)

$$\alpha_x = 0.00$$

$$\alpha_f = 0.00$$

$$b = 250.00$$

$$h = 3000.00$$

$$\text{From EC8 A4.4.3(6), } p_f = 2t_f/bw = 0.008128$$

$$bw = 250.00$$

$$\text{effective stress from (A.35), } f_{fe} = 757.2164$$

$$\alpha_y = 0.00$$

$$\alpha_f = 0.00$$

$$b = 3000.00$$

$$h = 250.00$$

$$\text{From EC8 A4.4.3(6), } p_f = 2t_f/bw = 0.00067733$$

$$bw = 3000.00$$

$$\text{effective stress from (A.35), } f_{fe} = 954.4864$$

$$R = 40.00$$

$$\text{Effective FRP thickness, } t_f = NL * t * \cos(\beta_1) = 1.016$$

$$f_{u,f} = 1055.00$$

$$E_f = 64828.00$$

$$u_{,f} = 0.015$$

$$\alpha_{se}((5.4d), TBDY) = (\alpha_{se1} * A_{col1} + \alpha_{se2} * A_{col2} + \alpha_{se3} * A_{web}) / A_{sec} = 0.00$$

$$\alpha_{se1} = 0.00$$

$$sh_1 = 150.00$$

$$bo_1 = 190.00$$

$$ho_1 = 540.00$$

$$bi2_1 = 655400.00$$

$$\alpha_{se2} = 0.00$$

$$sh_2 = 150.00$$

$$bo_2 = 190.00$$

$$ho_2 = 540.00$$

$$bi2_2 = 655400.00$$

ase3 = 0 (grid does not provide confinement)
 psh,min = Min(psh,x , psh,y) = 0.00069813
 Expression ((5.4d), TBDY) for psh,min has been multiplied by 0.3 according to 15.7.1.3 for members without earthquake detailing (90° closed stirrups)

 psh,x = ps1,x+ps2,x+ps3,x = 0.00356047
 ps1,x (column 1) = (As1*h1/s_1)/Ac = 0.00083776
 h1 = 600.00
 As1 = Astir1*ns1 = 157.0796
 No stirrups, ns1 = 2.00
 ps2,x (column 2) = (As2*h2/s_2)/Ac = 0.00083776
 h2 = 600.00
 As2 = Astir2*ns2 = 157.0796
 No stirrups, ns2 = 2.00
 ps3,x (web) = (As3*h3/s_3)/Ac = 0.00188496
 h3 = 1800.00
 As3 = Astir3*ns3 = 0.00
 No stirrups, ns3 = 2.00

 psh,y = ps1,y+ps2,y+ps3,y = 0.00069813
 ps1,y (column 1) = (As1*h1/s_1)/Ac = 0.00034907
 h1 = 250.00
 As1 = Astir1*ns1 = 157.0796
 No stirrups, ns1 = 2.00
 ps2,y (column 2) = (As2*h2/s_2)/Ac = 0.00034907
 h2 = 250.00
 As2 = Astir2*ns2 = 157.0796
 No stirrups, ns2 = 2.00
 ps3,y (web) = (As3*h3/s_3)/Ac = 0.00
 h3 = 250.00
 As3 = Astir3*ns3 = 157.0796
 No stirrups, ns3 = 0.00

 Asec = 750000.00
 s_1 = 150.00
 s_2 = 150.00
 s_3 = 200.00
 fywe = 625.00
 fce = 25.00
 From ((5.A5), TBDY), TBDY: cc = 0.00202463
 c = confinement factor = 1.00246
 y1 = 0.00140044
 sh1 = 0.0044814
 ft1 = 420.1317
 fy1 = 350.1097
 su1 = 0.00512
 using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
 and also multiplied by the shear_factor according to 15.7.1.4, with
 Shear_factor = 1.00
 lo/lou,min = lb/lb = 0.30
 su1 = 0.4*esu1_nominal ((5.5), TBDY) = 0.032
 From table 5A.1, TBDY: esu1_nominal = 0.08,
 For calculation of esu1_nominal and y1, sh1,ft1,fy1, it is considered
 characteristic value fsy1 = fs1/1.2, from table 5.1, TBDY.
 y1, sh1,ft1,fy1, are also multiplied by Min(1,1.25*(lb/lb)^ 2/3), from 10.3.5, ASCE 41-17.
 with fs1 = fs = 350.1097
 with Es1 = Es = 200000.00
 y2 = 0.00140044
 sh2 = 0.0044814
 ft2 = 420.1317
 fy2 = 350.1097
 su2 = 0.00512
 using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
 and also multiplied by the shear_factor according to 15.7.1.4, with
 Shear_factor = 1.00
 lo/lou,min = lb/lb,min = 0.30
 su2 = 0.4*esu2_nominal ((5.5), TBDY) = 0.032

From table 5A.1, TBDY: $esu2_nominal = 0.08$,
For calculation of $esu2_nominal$ and $y2$, $sh2, ft2, fy2$, it is considered
characteristic value $fsy2 = fs2/1.2$, from table 5.1, TBDY.
 $y1$, $sh1, ft1, fy1$, are also multiplied by $Min(1, 1.25 \cdot (lb/ld)^{2/3})$, from 10.3.5, ASCE 41-17.
with $fs2 = fs = 350.1097$
with $Es2 = Es = 200000.00$
 $yv = 0.00140044$
 $shv = 0.0044814$
 $ftv = 420.1317$
 $fyv = 350.1097$
 $suv = 0.00512$
using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00
 $lo/lou, min = lb/ld = 0.30$
 $suv = 0.4 \cdot esuv_nominal \text{ ((5.5), TBDY)} = 0.032$
From table 5A.1, TBDY: $esuv_nominal = 0.08$,
considering characteristic value $fsyv = fsv/1.2$, from table 5.1, TBDY
For calculation of $esuv_nominal$ and yv , shv, ftv, fyv , it is considered
characteristic value $fsyv = fsv/1.2$, from table 5.1, TBDY.
 $y1$, $sh1, ft1, fy1$, are also multiplied by $Min(1, 1.25 \cdot (lb/ld)^{2/3})$, from 10.3.5, ASCE 41-17.
with $fsv = fs = 350.1097$
with $Es = Es = 200000.00$
 $1 = Asl, ten / (b \cdot d) \cdot (fs1 / fc) = 0.05427722$
 $2 = Asl, com / (b \cdot d) \cdot (fs2 / fc) = 0.05427722$
 $v = Asl, mid / (b \cdot d) \cdot (fsv / fc) = 0.00$
and confined core properties:
 $b = 190.00$
 $d = 2927.00$
 $d' = 13.00$
 $fcc \text{ (5A.2, TBDY)} = 25.06158$
 $cc \text{ (5A.5, TBDY)} = 0.00202463$
 $c = \text{confinement factor} = 1.00246$
 $1 = Asl, ten / (b \cdot d) \cdot (fs1 / fc) = 0.07214938$
 $2 = Asl, com / (b \cdot d) \cdot (fs2 / fc) = 0.07214938$
 $v = Asl, mid / (b \cdot d) \cdot (fsv / fc) = 0.00$
Case/Assumption: Unconfined full section - Steel rupture
'satisfies Eq. (4.3)
--->
 $v < vs, y2$ - LHS eq.(4.5) is satisfied
--->
 $su \text{ (4.9)} = 0.14691336$
 $Mu = MRc \text{ (4.14)} = 3.3585E+009$
 $u = su \text{ (4.1)} = 2.0296703E-006$

Calculation of ratio lb/ld

Inadequate Lap Length with $lb/ld = 0.30$

Calculation of $Mu2$ -

Calculation of ultimate curvature u according to 4.1, Biskinis/Fardis 2013:

$u = 2.0532423E-006$
 $Mu = 3.8401E+009$

with full section properties:

$b = 250.00$
 $d = 2957.00$
 $d' = 43.00$
 $v = 0.0014928$
 $N = 27588.841$
 $fc = 25.00$

co (5A.5, TBDY) = 0.002

Final value of α : $\alpha = \text{shear_factor} * \text{Max}(\alpha_c, \alpha_s) = 0.0035$

The Shear_factor is considered equal to 1 (pure moment strength)

From (5.4b), TBDY: $\alpha = 0.0035$

we ((5.4c), TBDY) = $\alpha * \text{sh}_{\min} * f_{ywe} / f_{ce} + \text{Min}(\alpha_x, \alpha_y) = 0.00$

where $\alpha = \alpha_f * \rho_f * f_{fe} / f_{ce}$ is accounting for FRP contribution like EC8-part3 A.4.4.3(6)

 $\alpha_x = 0.00$

$\alpha_f = 0.00$

$b = 250.00$

$h = 3000.00$

From EC8 A4.4.3(6), $\rho_f = 2t_f/bw = 0.008128$

$bw = 250.00$

effective stress from (A.35), $f_{fe} = 757.2164$

 $\alpha_y = 0.00$

$\alpha_f = 0.00$

$b = 3000.00$

$h = 250.00$

From EC8 A4.4.3(6), $\rho_f = 2t_f/bw = 0.00067733$

$bw = 3000.00$

effective stress from (A.35), $f_{fe} = 954.4864$

 $R = 40.00$

Effective FRP thickness, $t_f = NL * t * \cos(\theta_1) = 1.016$

$f_u, f = 1055.00$

$E_f = 64828.00$

$u, f = 0.015$

α_{se} ((5.4d), TBDY) = $(\alpha_{se1} * A_{col1} + \alpha_{se2} * A_{col2} + \alpha_{se3} * A_{web}) / A_{sec} = 0.00$

$\alpha_{se1} = 0.00$

$sh_1 = 150.00$

$bo_1 = 190.00$

$ho_1 = 540.00$

$bi2_1 = 655400.00$

$\alpha_{se2} = 0.00$

$sh_2 = 150.00$

$bo_2 = 190.00$

$ho_2 = 540.00$

$bi2_2 = 655400.00$

$\alpha_{se3} = 0$ (grid does not provide confinement)

$\rho_{sh, \min} = \text{Min}(\rho_{sh, x}, \rho_{sh, y}) = 0.00069813$

Expression ((5.4d), TBDY) for $\rho_{sh, \min}$ has been multiplied by 0.3 according to 15.7.1.3 for members without earthquake detailing (90° closed stirrups)

 $\rho_{sh, x} = \rho_{s1, x} + \rho_{s2, x} + \rho_{s3, x} = 0.00356047$

$\rho_{s1, x}$ (column 1) = $(A_{s1} * h_1 / s_1) / A_c = 0.00083776$

$h_1 = 600.00$

$A_{s1} = A_{stir1} * n_{s1} = 157.0796$

No stirrups, $n_{s1} = 2.00$

$\rho_{s2, x}$ (column 2) = $(A_{s2} * h_2 / s_2) / A_c = 0.00083776$

$h_2 = 600.00$

$A_{s2} = A_{stir2} * n_{s2} = 157.0796$

No stirrups, $n_{s2} = 2.00$

$\rho_{s3, x}$ (web) = $(A_{s3} * h_3 / s_3) / A_c = 0.00188496$

$h_3 = 1800.00$

$A_{s3} = A_{stir3} * n_{s3} = 0.00$

No stirrups, $n_{s3} = 2.00$

 $\rho_{sh, y} = \rho_{s1, y} + \rho_{s2, y} + \rho_{s3, y} = 0.00069813$

$\rho_{s1, y}$ (column 1) = $(A_{s1} * h_1 / s_1) / A_c = 0.00034907$

$h_1 = 250.00$

$A_{s1} = A_{stir1} * n_{s1} = 157.0796$

No stirrups, $n_{s1} = 2.00$

$\rho_{s2, y}$ (column 2) = $(A_{s2} * h_2 / s_2) / A_c = 0.00034907$

$h_2 = 250.00$

$A_{s2} = A_{stir2} * n_{s2} = 157.0796$

No stirrups, $n_{s2} = 2.00$

$$ps3,y \text{ (web)} = (As3 \cdot h3/s_3)/Ac = 0.00$$

$$h3 = 250.00$$

$$As3 = Astir3 \cdot ns3 = 157.0796$$

$$\text{No stirups, } ns3 = 0.00$$

$$Asec = 750000.00$$

$$s_1 = 150.00$$

$$s_2 = 150.00$$

$$s_3 = 200.00$$

$$fywe = 625.00$$

$$fce = 25.00$$

$$\text{From } ((5.A5), \text{ TBDY}), \text{ TBDY: } cc = 0.00202463$$

$$c = \text{confinement factor} = 1.00246$$

$$y1 = 0.00140044$$

$$sh1 = 0.0044814$$

$$ft1 = 420.1317$$

$$fy1 = 350.1097$$

$$su1 = 0.00512$$

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00

$$lo/lou,min = lb/ld = 0.30$$

$$su1 = 0.4 \cdot esu1_nominal \text{ ((5.5), TBDY)} = 0.032$$

$$\text{From table 5A.1, TBDY: } esu1_nominal = 0.08,$$

For calculation of esu1_nominal and y1, sh1,ft1,fy1, it is considered
characteristic value fsy1 = fs1/1.2, from table 5.1, TBDY.

y1, sh1,ft1,fy1, are also multiplied by $\text{Min}(1, 1.25 \cdot (lb/ld)^{2/3})$, from 10.3.5, ASCE 41-17.

$$\text{with } fs1 = fs = 350.1097$$

$$\text{with } Es1 = Es = 200000.00$$

$$y2 = 0.00140044$$

$$sh2 = 0.0044814$$

$$ft2 = 420.1317$$

$$fy2 = 350.1097$$

$$su2 = 0.00512$$

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00

$$lo/lou,min = lb/lb,min = 0.30$$

$$su2 = 0.4 \cdot esu2_nominal \text{ ((5.5), TBDY)} = 0.032$$

$$\text{From table 5A.1, TBDY: } esu2_nominal = 0.08,$$

For calculation of esu2_nominal and y2, sh2,ft2,fy2, it is considered
characteristic value fsy2 = fs2/1.2, from table 5.1, TBDY.

y1, sh1,ft1,fy1, are also multiplied by $\text{Min}(1, 1.25 \cdot (lb/ld)^{2/3})$, from 10.3.5, ASCE 41-17.

$$\text{with } fs2 = fs = 350.1097$$

$$\text{with } Es2 = Es = 200000.00$$

$$yv = 0.00140044$$

$$shv = 0.0044814$$

$$ftv = 420.1317$$

$$fyv = 350.1097$$

$$suv = 0.00512$$

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00

$$lo/lou,min = lb/ld = 0.30$$

$$suv = 0.4 \cdot esuv_nominal \text{ ((5.5), TBDY)} = 0.032$$

$$\text{From table 5A.1, TBDY: } esuv_nominal = 0.08,$$

considering characteristic value fsyv = fsv/1.2, from table 5.1, TBDY

For calculation of esuv_nominal and yv, shv,ftv,fyv, it is considered
characteristic value fsyv = fsv/1.2, from table 5.1, TBDY.

y1, sh1,ft1,fy1, are also multiplied by $\text{Min}(1, 1.25 \cdot (lb/ld)^{2/3})$, from 10.3.5, ASCE 41-17.

$$\text{with } fsv = fs = 350.1097$$

$$\text{with } Esv = Es = 200000.00$$

$$1 = Asl,ten/(b \cdot d) \cdot (fs1/fc) = 0.05427722$$

$$2 = Asl,com/(b \cdot d) \cdot (fs2/fc) = 0.05427722$$

$$v = Asl,mid/(b \cdot d) \cdot (fsv/fc) = 0.0291621$$

and confined core properties:

$$b = 190.00$$

$d = 2927.00$
 $d' = 13.00$
 $f_{cc} (5A.2, TBDY) = 25.06158$
 $cc (5A.5, TBDY) = 0.00202463$
 $c = \text{confinement factor} = 1.00246$
 $1 = A_{sl,ten}/(b*d)*(f_{s1}/f_c) = 0.07214938$
 $2 = A_{sl,com}/(b*d)*(f_{s2}/f_c) = 0.07214938$
 $v = A_{sl,mid}/(b*d)*(f_{sv}/f_c) = 0.03876447$
 Case/Assumption: Unconfined full section - Steel rupture
 ' satisfies Eq. (4.3)

--->
 $v < v_{s,y2}$ - LHS eq.(4.5) is satisfied
 --->
 $s_u (4.9) = 0.15670711$
 $M_u = MR_c (4.14) = 3.8401E+009$
 $u = s_u (4.1) = 2.0532423E-006$

Calculation of ratio l_b/l_d

Inadequate Lap Length with $l_b/l_d = 0.30$

Calculation of Shear Strength $V_r = \text{Min}(V_{r1}, V_{r2}) = 2.4900E+006$

Calculation of Shear Strength at edge 1, $V_{r1} = 2.4900E+006$
 From (22.5.1.1) and 11.5.4.3, ACI 318-14: $V_{r1} = V_n < 0.83*f_c'^{0.5}*h*d$

NOTE: In expression (22.5.1.1) ' V_w ' is replaced by ' $V_w + f*V_f$ '
 where V_f is the contribution of FRPs (11.3), ACI 440).

From Table (11.5.4.6(d-e)), ACI 318-14: $V_c = 815517.768$
 $M_u/V_u - l_w/2 = 0.00 \leq 0$
 $= 1$ (normal-weight concrete)
 $f_c' = 25.00$, but $f_c'^{0.5} \leq 8.3$ MPa (22.5.3.1, ACI 318-14)
 $h = 250.00$
 $d = 2400.00$
 $l_w = 3000.00$
 $M_u = 1.1486927E+009$
 $V_u = 1.0097420E+028$
 $N_u = 27588.841$

From (11.5.4.8), ACI 318-14: $V_s = V_{s1} + V_{s2} + V_{s3} = 1.0681E+006$
 $V_{s1} = 251327.412$ is calculated for pseudo-Column 1, with:
 $d = 480.00$
 $A_v = 157079.633$
 $s = 150.00$
 $f_y = 500.00$

V_{s1} has been multiplied by 1 ($s < d/2$, according to ASCE 41-17,10.3.4)
 $V_{s2} = 251327.412$ is calculated for pseudo-Column 2, with:
 $d = 480.00$
 $A_v = 157079.633$
 $s = 150.00$
 $f_y = 500.00$

V_{s2} has been multiplied by 1 ($s < d/2$, according to ASCE 41-17,10.3.4)
 $V_{s3} = 565486.678$ is calculated for web, with:
 $d = 1440.00$
 $A_v = 157079.633$
 $s = 200.00$
 $f_y = 500.00$

V_{s3} has been multiplied by 1 ($s < d/2$, according to ASCE 41-17,10.3.4)
 $V_f ((11-3)-(11.4), ACI 440) = 1.5581E+006$
 $f = 0.95$, for fully-wrapped sections
 $w_f/s_f = 1$ (FRP strips adjacent to one another).

In (11.3) $\sin + \cos$ is replaced with $(\cot + \cot a)\sin a$ which is more a generalised expression,
 where a is the angle of the crack direction (see KANEPE).

This later relation, considered as a function $V_f(\theta)$, is implemented for every different fiber orientation θ_i , as well as for 2 crack directions, $\theta = 45^\circ$ and $\theta = -45^\circ$ to take into consideration the cyclic seismic loading.

orientation 1: $\theta_1 = \theta_1 + 90^\circ = 90.00$

$V_f = \text{Min}(|V_f(45, \theta_1)|, |V_f(-45, \theta_1)|)$, with:

total thickness per orientation, $t_{f1} = N_L \cdot t / N_{\text{Dir}} = 1.016$

$d_{fv} = d$ (figure 11.2, ACI 440) = 2957.00

f_{fe} ((11-5), ACI 440) = 259.312

$E_f = 64828.00$

$f_e = 0.004$, from (11.6a), ACI 440

with $f_u = 0.01$

From (11-11), ACI 440: $V_s + V_f \leq 1.9929E+006$

$b_w = 250.00$

Calculation of Shear Strength at edge 2, $V_{r2} = 2.4900E+006$

From (22.5.1.1) and 11.5.4.3, ACI 318-14: $V_{r2} = V_n < 0.83 \cdot f_c' \cdot h \cdot d$

NOTE: In expression (22.5.1.1) ' V_w ' is replaced by ' $V_w + f \cdot V_f$ ' where V_f is the contribution of FRPs (11.3), ACI 440).

From Table (11.5.4.6(d-e)), ACI 318-14: $V_c = 815517.768$

$\mu_u / \mu_u - l_w / 2 = 0.00 \leq 0$

= 1 (normal-weight concrete)

$f_c' = 25.00$, but $f_c' \cdot 0.5 \leq 8.3$ MPa (22.5.3.1, ACI 318-14)

$h = 250.00$

$d = 2400.00$

$l_w = 3000.00$

$\mu_u = 1.1486927E-009$

$V_u = 1.0097420E-028$

$N_u = 27588.841$

From (11.5.4.8), ACI 318-14: $V_s = V_{s1} + V_{s2} + V_{s3} = 1.0681E+006$

$V_{s1} = 251327.412$ is calculated for pseudo-Column 1, with:

$d = 480.00$

$A_v = 157079.633$

$s = 150.00$

$f_y = 500.00$

V_{s1} has been multiplied by 1 ($s < d/2$, according to ASCE 41-17,10.3.4)

$V_{s2} = 251327.412$ is calculated for pseudo-Column 2, with:

$d = 480.00$

$A_v = 157079.633$

$s = 150.00$

$f_y = 500.00$

V_{s2} has been multiplied by 1 ($s < d/2$, according to ASCE 41-17,10.3.4)

$V_{s3} = 565486.678$ is calculated for web, with:

$d = 1440.00$

$A_v = 157079.633$

$s = 200.00$

$f_y = 500.00$

V_{s3} has been multiplied by 1 ($s < d/2$, according to ASCE 41-17,10.3.4)

V_f ((11-3)-(11.4), ACI 440) = 1.5581E+006

$f = 0.95$, for fully-wrapped sections

$w_f / s_f = 1$ (FRP strips adjacent to one another).

In (11.3) $\sin \theta + \cos \theta$ is replaced with $(\cot \theta + \cot \alpha) \sin \alpha$ which is more a generalised expression, where α is the angle of the crack direction (see KANEPE).

This later relation, considered as a function $V_f(\theta)$, is implemented for every different fiber orientation θ_i , as well as for 2 crack directions, $\theta = 45^\circ$ and $\theta = -45^\circ$ to take into consideration the cyclic seismic loading.

orientation 1: $\theta_1 = \theta_1 + 90^\circ = 90.00$

$V_f = \text{Min}(|V_f(45, \theta_1)|, |V_f(-45, \theta_1)|)$, with:

total thickness per orientation, $t_{f1} = N_L \cdot t / N_{\text{Dir}} = 1.016$

$d_{fv} = d$ (figure 11.2, ACI 440) = 2957.00

f_{fe} ((11-5), ACI 440) = 259.312

$E_f = 64828.00$

$f_e = 0.004$, from (11.6a), ACI 440

with $f_u = 0.01$

From (11-11), ACI 440: $V_s + V_f \leq 1.9929E+006$

$b_w = 250.00$

End Of Calculation of Shear Capacity ratio for element: wall W1 of floor 1

At local axis: 3

Start Of Calculation of Shear Capacity ratio for element: wall W1 of floor 1

At Shear local axis: 2

(Bending local axis: 3)

Section Type: rcwrs

Constant Properties

Knowledge Factor, $\gamma = 1.00$

Mean strength values are used for both shear and moment calculations.

Consequently:

New material of Secondary Member: Concrete Strength, $f_c = f_{cm} = 25.00$

New material of Secondary Member: Steel Strength, $f_s = f_{sm} = 500.00$

Concrete Elasticity, $E_c = 26999.444$

Steel Elasticity, $E_s = 200000.00$

#####

Note: Especially for the calculation of moment strengths,

the above steel re-bar strengths are multiplied by 1.25 according to R18.6.5, ACI 318-14

New material: Steel Strength, $f_s = 1.25 \cdot f_{sm} = 625.00$

#####

Total Height, $H_{tot} = 3000.00$

Edges Width, $W_{edg} = 250.00$

Edges Height, $H_{edg} = 600.00$

Web Width, $W_{web} = 250.00$

Cover Thickness, $c = 25.00$

Mean Confinement Factor overall section = 1.00246

Element Length, $L = 3000.00$

Secondary Member

Smooth Bars

Ductile Steel

Without Detailing for Earthquake Resistance (including stirrups not closed at 135°)

Longitudinal Bars With Ends Lapped Starting at the End Sections

Inadequate Lap Length with $l_o/l_{ou,min} = 0.30$

FRP Wrapping Data

Type: Carbon

Cured laminate properties (design values)

Thickness, $t = 1.016$

Tensile Strength, $f_{fu} = 1055.00$

Tensile Modulus, $E_f = 64828.00$

Elongation, $\epsilon_{fu} = 0.01$

Number of directions, $N_{oDir} = 1$

Fiber orientations, $b_i = 0.00^\circ$

Number of layers, $N_L = 1$

Radius of rounding corners, $R = 40.00$

Stepwise Properties

At local axis: 2

EDGE -A-

Shear Force, $V_a = 1.7354940E-029$

EDGE -B-

Shear Force, $V_b = -1.7354940E-029$

BOTH EDGES

Axial Force, $F = -27588.841$

Longitudinal Reinforcement Area Distribution (in 2 divisions)

-Tension: $As_t = 0.00$

-Compression: $As_c = 7269.645$

Longitudinal Reinforcement Area Distribution (in 3 divisions)

-Tension: $As_{t,ten} = 2830.575$

-Compression: $As_{l,com} = 2830.575$

-Middle: $As_{l,mid} = 0.00$

(According to 10.7.2.3 $As_{l,mid}$ is setted equal to zero)

Calculation of Shear Capacity ratio , $V_e/V_r = 0.15621236$

Member Controlled by Flexure ($V_e/V_r < 1$)

Calculation of Shear Demand from fig. R18.6.5, ACI 318-14 $V_e = (M_{pr1} + M_{pr2})/l_n = 160017.271$
with

$M_{pr1} = \text{Max}(M_{u1+}, M_{u1-}) = 2.4003E+008$

$M_{u1+} = 2.0658E+008$, is the ultimate moment strength at the edge 1 of the member in the actual moment direction which is defined for the static loading combination

$M_{u1-} = 2.4003E+008$, is the ultimate moment strength at the edge 1 of the member in the opposite moment direction which is defined for the static loading combination

$M_{pr2} = \text{Max}(M_{u2+}, M_{u2-}) = 2.4003E+008$

$M_{u2+} = 2.0658E+008$, is the ultimate moment strength at the edge 2 of the member in the actual moment direction which is defined for the static loading combination

$M_{u2-} = 2.4003E+008$, is the ultimate moment strength at the edge 2 of the member in the opposite moment direction which is defined for the static loading combination

Calculation of M_{u1+}

Calculation of ultimate curvature ϕ_u according to 4.1, Biskinis/Fardis 2013:

$\phi_u = 3.0306889E-005$

$M_u = 2.0658E+008$

with full section properties:

$b = 3000.00$

$d = 208.00$

$d' = 42.00$

$\nu = 0.00176852$

$N = 27588.841$

$f_c = 25.00$

$\phi_{co} (5A.5, \text{TBDY}) = 0.002$

Final value of ϕ_u : $\phi_u^* = \text{shear_factor} * \text{Max}(\phi_u, \phi_{co}) = 0.0035$

The Shear_factor is considered equal to 1 (pure moment strength)

From (5.4b), TBDY: $\phi_u = 0.0035$

$\phi_{we} ((5.4c), \text{TBDY}) = a_{se} * \phi_u, \min(f_y w_e / f_{ce} + \min(\phi_{fx}, \phi_{fy})) = 0.00$

where $\phi_{fx} = a_f * \phi_u * f_{fe} / f_{ce}$ is accounting for FRP contribution like EC8-part3 A.4.4.3(6)

$\phi_{fx} = 0.00$

$a_f = 0.00$

$b = 250.00$

$h = 3000.00$

From EC8 A.4.4.3(6), $\phi_{fx} = 2t_f/bw = 0.008128$

$bw = 250.00$

effective stress from (A.35), $f_{fe} = 757.2164$

$\phi_{fy} = 0.00$

$a_f = 0.00$

$b = 3000.00$

$h = 250.00$

From EC8 A.4.4.3(6), $\phi_{fy} = 2t_f/bw = 0.00067733$

$bw = 3000.00$

effective stress from (A.35), $f_{fe} = 954.4864$

$R = 40.00$

Effective FRP thickness, $t_f = N L * t * \cos(b_1) = 1.016$

$f_{u,f} = 1055.00$

$E_f = 64828.00$

$u_{f,f} = 0.015$

$a_{se} ((5.4d), \text{TBDY}) = (a_{se1} * A_{col1} + a_{se2} * A_{col2} + a_{se3} * A_{web}) / A_{sec} = 0.00$

$a_{se1} = 0.00$

$sh_1 = 150.00$

$bo_1 = 190.00$

$ho_1 = 540.00$
 $bi2_1 = 655400.00$
 $ase2 = 0.00$
 $sh_2 = 150.00$
 $bo_2 = 190.00$
 $ho_2 = 540.00$
 $bi2_2 = 655400.00$
 $ase3 = 0$ (grid does not provide confinement)
 $psh,min = \text{Min}(psh,x, psh,y) = 0.00069813$
 Expression ((5.4d), TBDY) for psh,min has been multiplied by 0.3 according to 15.7.1.3 for members without earthquake detailing (90° closed stirrups)

$psh,x = ps1,x + ps2,x + ps3,x = 0.00356047$
 $ps1,x$ (column 1) = $(As1 \cdot h1 / s_1) / Ac = 0.00083776$
 $h1 = 600.00$
 $As1 = Astir1 \cdot ns1 = 157.0796$
 No stirrups, $ns1 = 2.00$
 $ps2,x$ (column 2) = $(As2 \cdot h2 / s_2) / Ac = 0.00083776$
 $h2 = 600.00$
 $As2 = Astir2 \cdot ns2 = 157.0796$
 No stirrups, $ns2 = 2.00$
 $ps3,x$ (web) = $(As3 \cdot h3 / s_3) / Ac = 0.00188496$
 $h3 = 1800.00$
 $As3 = Astir3 \cdot ns3 = 0.00$
 No stirrups, $ns3 = 2.00$

$psh,y = ps1,y + ps2,y + ps3,y = 0.00069813$
 $ps1,y$ (column 1) = $(As1 \cdot h1 / s_1) / Ac = 0.00034907$
 $h1 = 250.00$
 $As1 = Astir1 \cdot ns1 = 157.0796$
 No stirrups, $ns1 = 2.00$
 $ps2,y$ (column 2) = $(As2 \cdot h2 / s_2) / Ac = 0.00034907$
 $h2 = 250.00$
 $As2 = Astir2 \cdot ns2 = 157.0796$
 No stirrups, $ns2 = 2.00$
 $ps3,y$ (web) = $(As3 \cdot h3 / s_3) / Ac = 0.00$
 $h3 = 250.00$
 $As3 = Astir3 \cdot ns3 = 157.0796$
 No stirrups, $ns3 = 0.00$

$Asec = 750000.00$
 $s_1 = 150.00$
 $s_2 = 150.00$
 $s_3 = 200.00$
 $fywe = 625.00$
 $fce = 25.00$

From ((5.A5), TBDY), TBDY: $cc = 0.00202463$
 $c = \text{confinement factor} = 1.00246$

$y1 = 0.00140044$
 $sh1 = 0.0044814$
 $ft1 = 420.1317$
 $fy1 = 350.1097$
 $su1 = 0.00512$

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
 and also multiplied by the shear_factor according to 15.7.1.4, with
 $\text{Shear_factor} = 1.00$

$lo/lo_{u,min} = lb/ld = 0.30$

$su1 = 0.4 \cdot esu1_nominal$ ((5.5), TBDY) = 0.032

From table 5A.1, TBDY: $esu1_nominal = 0.08$,

For calculation of $esu1_nominal$ and $y1, sh1, ft1, fy1$, it is considered
 characteristic value $fsy1 = fs1 / 1.2$, from table 5.1, TBDY.

$y1, sh1, ft1, fy1$, are also multiplied by $\text{Min}(1, 1.25 \cdot (lb/ld)^{2/3})$, from 10.3.5, ASCE 41-17.

with $fs1 = fs = 350.1097$

with $Es1 = Es = 200000.00$

$y2 = 0.00140044$
 $sh2 = 0.0044814$
 $ft2 = 420.1317$

```

fy2 = 350.1097
su2 = 0.00512
    using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
    and also multiplied by the shear_factor according to 15.7.1.4, with
    Shear_factor = 1.00
    lo/lo,min = lb/lb,min = 0.30
    su2 = 0.4*esu2_nominal ((5.5), TBDY) = 0.032
    From table 5A.1, TBDY: esu2_nominal = 0.08,
    For calculation of esu2_nominal and y2, sh2,ft2,fy2, it is considered
    characteristic value fsy2 = fs2/1.2, from table 5.1, TBDY.
    y1, sh1,ft1,fy1, are also multiplied by Min(1,1.25*(lb/ld)^ 2/3), from 10.3.5, ASCE 41-17.
    with fs2 = fs = 350.1097
    with Es2 = Es = 200000.00
    yv = 0.00140044
    shv = 0.0044814
    ftv = 420.1317
    fyv = 350.1097
    suv = 0.00512
    using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
    and also multiplied by the shear_factor according to 15.7.1.4, with
    Shear_factor = 1.00
    lo/lo,min = lb/ld = 0.30
    suv = 0.4*esuv_nominal ((5.5), TBDY) = 0.032
    From table 5A.1, TBDY: esuv_nominal = 0.08,
    considering characteristic value fsyv = fsv/1.2, from table 5.1, TBDY
    For calculation of esuv_nominal and yv, shv,ftv,fyv, it is considered
    characteristic value fsyv = fsv/1.2, from table 5.1, TBDY.
    y1, sh1,ft1,fy1, are also multiplied by Min(1,1.25*(lb/ld)^ 2/3), from 10.3.5, ASCE 41-17.
    with fsv = fs = 350.1097
    with Esv = Es = 200000.00
    1 = Asl,ten/(b*d)*(fs1/fc) = 0.0635264
    2 = Asl,com/(b*d)*(fs2/fc) = 0.0635264
    v = Asl,mid/(b*d)*(fsv/fc) = 0.00
and confined core properties:
b = 2940.00
d = 178.00
d' = 12.00
fcc (5A.2, TBDY) = 25.06158
cc (5A.5, TBDY) = 0.00202463
    c = confinement factor = 1.00246
    1 = Asl,ten/(b*d)*(fs1/fc) = 0.07574806
    2 = Asl,com/(b*d)*(fs2/fc) = 0.07574806
    v = Asl,mid/(b*d)*(fsv/fc) = 0.00
Case/Assumption: Unconfined full section - Steel rupture
' satisfies Eq. (4.3)
--->
v < vs,y2 - LHS eq.(4.5) is satisfied
--->
su (4.9) = 0.18779572
Mu = MRc (4.14) = 2.0658E+008
u = su (4.1) = 3.0306889E-005

```

Calculation of ratio lb/ld

Inadequate Lap Length with lb/ld = 0.30

Calculation of Mu1-

Calculation of ultimate curvature u according to 4.1, Biskinis/Fardis 2013:

u = 3.0889637E-005

Mu = 2.4003E+008

with full section properties:

$$b = 3000.00$$

$$d = 208.00$$

$$d' = 42.00$$

$$v = 0.00176852$$

$$N = 27588.841$$

$$f_c = 25.00$$

$$\alpha (5A.5, \text{TB DY}) = 0.002$$

$$\text{Final value of } \alpha: \alpha = \text{shear_factor} * \text{Max}(\alpha_c, \alpha_c) = 0.0035$$

The Shear_factor is considered equal to 1 (pure moment strength)

$$\text{From (5.4b), TB DY: } \alpha_c = 0.0035$$

$$\alpha_e ((5.4c), \text{TB DY}) = \alpha_e * \text{sh}_{\min} * f_{ywe} / f_{ce} + \text{Min}(\alpha_{fx}, \alpha_{fy}) = 0.00$$

where $\alpha = \alpha_f * p_f * f_{fe} / f_{ce}$ is accounting for FRP contribution like EC8-part3 A.4.4.3(6)

$$\alpha_{fx} = 0.00$$

$$\alpha_f = 0.00$$

$$b = 250.00$$

$$h = 3000.00$$

$$\text{From EC8 A4.4.3(6), } p_f = 2t_f / b_w = 0.008128$$

$$b_w = 250.00$$

$$\text{effective stress from (A.35), } f_{fe} = 757.2164$$

$$\alpha_{fy} = 0.00$$

$$\alpha_f = 0.00$$

$$b = 3000.00$$

$$h = 250.00$$

$$\text{From EC8 A4.4.3(6), } p_f = 2t_f / b_w = 0.00067733$$

$$b_w = 3000.00$$

$$\text{effective stress from (A.35), } f_{fe} = 954.4864$$

$$R = 40.00$$

$$\text{Effective FRP thickness, } t_f = N L * t * \cos(\beta_1) = 1.016$$

$$f_{u,f} = 1055.00$$

$$E_f = 64828.00$$

$$\alpha_{u,f} = 0.015$$

$$\alpha_e ((5.4d), \text{TB DY}) = (\alpha_{e1} * A_{col1} + \alpha_{e2} * A_{col2} + \alpha_{e3} * A_{web}) / A_{sec} = 0.00$$

$$\alpha_{e1} = 0.00$$

$$sh_1 = 150.00$$

$$bo_1 = 190.00$$

$$ho_1 = 540.00$$

$$bi2_1 = 655400.00$$

$$\alpha_{e2} = 0.00$$

$$sh_2 = 150.00$$

$$bo_2 = 190.00$$

$$ho_2 = 540.00$$

$$bi2_2 = 655400.00$$

$$\alpha_{e3} = 0 \text{ (grid does not provide confinement)}$$

$$p_{sh,\min} = \text{Min}(p_{sh,x}, p_{sh,y}) = 0.00069813$$

Expression ((5.4d), TB DY) for $p_{sh,\min}$ has been multiplied by 0.3 according to 15.7.1.3 for members without earthquake detailing (90° closed stirrups)

$$p_{sh,x} = p_{s1,x} + p_{s2,x} + p_{s3,x} = 0.00356047$$

$$p_{s1,x} \text{ (column 1)} = (A_{s1} * h_1 / s_1) / A_c = 0.00083776$$

$$h_1 = 600.00$$

$$A_{s1} = A_{stir1} * n_{s1} = 157.0796$$

$$\text{No stirrups, } n_{s1} = 2.00$$

$$p_{s2,x} \text{ (column 2)} = (A_{s2} * h_2 / s_2) / A_c = 0.00083776$$

$$h_2 = 600.00$$

$$A_{s2} = A_{stir2} * n_{s2} = 157.0796$$

$$\text{No stirrups, } n_{s2} = 2.00$$

$$p_{s3,x} \text{ (web)} = (A_{s3} * h_3 / s_3) / A_c = 0.00188496$$

$$h_3 = 1800.00$$

$$A_{s3} = A_{stir3} * n_{s3} = 0.00$$

$$\text{No stirrups, } n_{s3} = 2.00$$

$$p_{sh,y} = p_{s1,y} + p_{s2,y} + p_{s3,y} = 0.00069813$$

$$p_{s1,y} \text{ (column 1)} = (A_{s1} * h_1 / s_1) / A_c = 0.00034907$$

$h1 = 250.00$
 $As1 = Astir1 * ns1 = 157.0796$
 No stirups, $ns1 = 2.00$
 $ps2,y \text{ (column 2)} = (As2 * h2 / s_2) / Ac = 0.00034907$
 $h2 = 250.00$
 $As2 = Astir2 * ns2 = 157.0796$
 No stirups, $ns2 = 2.00$
 $ps3,y \text{ (web)} = (As3 * h3 / s_3) / Ac = 0.00$
 $h3 = 250.00$
 $As3 = Astir3 * ns3 = 157.0796$
 No stirups, $ns3 = 0.00$

 $Asec = 750000.00$

$s_1 = 150.00$

$s_2 = 150.00$

$s_3 = 200.00$

$fywe = 625.00$

$fce = 25.00$

From ((5.A5), TBDY), TBDY: $cc = 0.00202463$

$c = \text{confinement factor} = 1.00246$

$y1 = 0.00140044$

$sh1 = 0.0044814$

$ft1 = 420.1317$

$fy1 = 350.1097$

$su1 = 0.00512$

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
 and also multiplied by the shear_factor according to 15.7.1.4, with
 $\text{Shear_factor} = 1.00$

$lo/lou,min = lb/ld = 0.30$

$su1 = 0.4 * esu1_nominal \text{ ((5.5), TBDY)} = 0.032$

From table 5A.1, TBDY: $esu1_nominal = 0.08$,

For calculation of $esu1_nominal$ and $y1$, $sh1$, $ft1$, $fy1$, it is considered
 characteristic value $fsy1 = fs1/1.2$, from table 5.1, TBDY.

$y1$, $sh1$, $ft1$, $fy1$, are also multiplied by $\text{Min}(1, 1.25 * (lb/ld)^{2/3})$, from 10.3.5, ASCE 41-17.

with $fs1 = fs = 350.1097$

with $Es1 = Es = 200000.00$

$y2 = 0.00140044$

$sh2 = 0.0044814$

$ft2 = 420.1317$

$fy2 = 350.1097$

$su2 = 0.00512$

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
 and also multiplied by the shear_factor according to 15.7.1.4, with
 $\text{Shear_factor} = 1.00$

$lo/lou,min = lb/lb,min = 0.30$

$su2 = 0.4 * esu2_nominal \text{ ((5.5), TBDY)} = 0.032$

From table 5A.1, TBDY: $esu2_nominal = 0.08$,

For calculation of $esu2_nominal$ and $y2$, $sh2$, $ft2$, $fy2$, it is considered
 characteristic value $fsy2 = fs2/1.2$, from table 5.1, TBDY.

$y1$, $sh1$, $ft1$, $fy1$, are also multiplied by $\text{Min}(1, 1.25 * (lb/ld)^{2/3})$, from 10.3.5, ASCE 41-17.

with $fs2 = fs = 350.1097$

with $Es2 = Es = 200000.00$

$yv = 0.00140044$

$shv = 0.0044814$

$ftv = 420.1317$

$fyv = 350.1097$

$suv = 0.00512$

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
 and also multiplied by the shear_factor according to 15.7.1.4, with
 $\text{Shear_factor} = 1.00$

$lo/lou,min = lb/ld = 0.30$

$suv = 0.4 * esuv_nominal \text{ ((5.5), TBDY)} = 0.032$

From table 5A.1, TBDY: $esuv_nominal = 0.08$,

considering characteristic value $fsyv = fsv/1.2$, from table 5.1, TBDY
 For calculation of $esuv_nominal$ and yv , shv , ftv , fyv , it is considered

characteristic value $fsyv = fsv/1.2$, from table 5.1, TBDY.

$y1$, $sh1$, $ft1$, $fy1$, are also multiplied by $\text{Min}(1, 1.25 * (lb/ld)^{2/3})$, from 10.3.5, ASCE 41-17.

with $f_{sv} = f_s = 350.1097$
 with $E_{sv} = E_s = 200000.00$
 $1 = A_{sl,ten}/(b*d)*(f_{s1}/f_c) = 0.0635264$
 $2 = A_{sl,com}/(b*d)*(f_{s2}/f_c) = 0.0635264$
 $v = A_{sl,mid}/(b*d)*(f_{sv}/f_c) = 0.03609935$
 and confined core properties:
 $b = 2940.00$
 $d = 178.00$
 $d' = 12.00$
 $f_{cc} (5A.2, TBDY) = 25.06158$
 $cc (5A.5, TBDY) = 0.00202463$
 $c = \text{confinement factor} = 1.00246$
 $1 = A_{sl,ten}/(b*d)*(f_{s1}/f_c) = 0.07574806$
 $2 = A_{sl,com}/(b*d)*(f_{s2}/f_c) = 0.07574806$
 $v = A_{sl,mid}/(b*d)*(f_{sv}/f_c) = 0.0430444$
 Case/Assumption: Unconfined full section - Steel rupture
 ' satisfies Eq. (4.3)

--->
 $v < v_{s,y2}$ - LHS eq.(4.5) is satisfied
 --->
 $su (4.9) = 0.20311835$
 $Mu = MR_c (4.14) = 2.4003E+008$
 $u = su (4.1) = 3.0889637E-005$

Calculation of ratio l_b/d

Inadequate Lap Length with $l_b/d = 0.30$

Calculation of Mu_{2+}

Calculation of ultimate curvature u according to 4.1, Biskinis/Fardis 2013:
 $u = 3.0306889E-005$
 $Mu = 2.0658E+008$

with full section properties:

$b = 3000.00$
 $d = 208.00$
 $d' = 42.00$
 $v = 0.00176852$
 $N = 27588.841$
 $f_c = 25.00$
 $co (5A.5, TBDY) = 0.002$
 Final value of cu : $cu^* = \text{shear_factor} * \text{Max}(cu, cc) = 0.0035$
 The Shear_factor is considered equal to 1 (pure moment strength)
 From (5.4b), TBDY: $cu = 0.0035$
 $w_e ((5.4c), TBDY) = a_{se} * sh_{min} * f_{ywe}/f_{ce} + \text{Min}(f_x, f_y) = 0.00$
 where $f = a_f * p_f * f_{fe}/f_{ce}$ is accounting for FRP contribution like EC8-part3 A.4.4.3(6)

$f_x = 0.00$
 $a_f = 0.00$
 $b = 250.00$
 $h = 3000.00$
 From EC8 A.4.4.3(6), $p_f = 2t_f/bw = 0.008128$
 $bw = 250.00$
 effective stress from (A.35), $f_{fe} = 757.2164$

$f_y = 0.00$
 $a_f = 0.00$
 $b = 3000.00$
 $h = 250.00$
 From EC8 A.4.4.3(6), $p_f = 2t_f/bw = 0.00067733$
 $bw = 3000.00$

effective stress from (A.35), $f_{f,e} = 954.4864$

$R = 40.00$

Effective FRP thickness, $t_f = NL \cdot t \cdot \cos(b_1) = 1.016$

$f_{u,f} = 1055.00$

$E_f = 64828.00$

$u_{f,e} = 0.015$

$a_{se}((5.4d), TBDY) = (a_{se1} \cdot A_{col1} + a_{se2} \cdot A_{col2} + a_{se3} \cdot A_{web}) / A_{sec} = 0.00$

$a_{se1} = 0.00$

$sh_1 = 150.00$

$bo_1 = 190.00$

$ho_1 = 540.00$

$bi2_1 = 655400.00$

$a_{se2} = 0.00$

$sh_2 = 150.00$

$bo_2 = 190.00$

$ho_2 = 540.00$

$bi2_2 = 655400.00$

$a_{se3} = 0$ (grid does not provide confinement)

$p_{sh,min} = \min(p_{sh,x}, p_{sh,y}) = 0.00069813$

Expression ((5.4d), TBDY) for $p_{sh,min}$ has been multiplied by 0.3 according to 15.7.1.3 for members without earthquake detailing (90° closed stirrups)

$p_{sh,x} = p_{s1,x} + p_{s2,x} + p_{s3,x} = 0.00356047$

$p_{s1,x}$ (column 1) = $(A_{s1} \cdot h_1 / s_1) / A_c = 0.00083776$

$h_1 = 600.00$

$A_{s1} = A_{stir1} \cdot n_{s1} = 157.0796$

No stirrups, $n_{s1} = 2.00$

$p_{s2,x}$ (column 2) = $(A_{s2} \cdot h_2 / s_2) / A_c = 0.00083776$

$h_2 = 600.00$

$A_{s2} = A_{stir2} \cdot n_{s2} = 157.0796$

No stirrups, $n_{s2} = 2.00$

$p_{s3,x}$ (web) = $(A_{s3} \cdot h_3 / s_3) / A_c = 0.00188496$

$h_3 = 1800.00$

$A_{s3} = A_{stir3} \cdot n_{s3} = 0.00$

No stirrups, $n_{s3} = 2.00$

$p_{sh,y} = p_{s1,y} + p_{s2,y} + p_{s3,y} = 0.00069813$

$p_{s1,y}$ (column 1) = $(A_{s1} \cdot h_1 / s_1) / A_c = 0.00034907$

$h_1 = 250.00$

$A_{s1} = A_{stir1} \cdot n_{s1} = 157.0796$

No stirrups, $n_{s1} = 2.00$

$p_{s2,y}$ (column 2) = $(A_{s2} \cdot h_2 / s_2) / A_c = 0.00034907$

$h_2 = 250.00$

$A_{s2} = A_{stir2} \cdot n_{s2} = 157.0796$

No stirrups, $n_{s2} = 2.00$

$p_{s3,y}$ (web) = $(A_{s3} \cdot h_3 / s_3) / A_c = 0.00$

$h_3 = 250.00$

$A_{s3} = A_{stir3} \cdot n_{s3} = 157.0796$

No stirrups, $n_{s3} = 0.00$

$A_{sec} = 750000.00$

$s_1 = 150.00$

$s_2 = 150.00$

$s_3 = 200.00$

$f_{ywe} = 625.00$

$f_{ce} = 25.00$

From ((5.A5), TBDY), TBDY: $cc = 0.00202463$

c = confinement factor = 1.00246

$y_1 = 0.00140044$

$sh_1 = 0.0044814$

$ft_1 = 420.1317$

$fy_1 = 350.1097$

$su_1 = 0.00512$

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor

and also multiplied by the shear_factor according to 15.7.1.4, with

Shear_factor = 1.00

$l_o/l_{ou,min} = l_b/l_d = 0.30$
 $su_1 = 0.4 * esu_{1,nominal} ((5.5), TBDY) = 0.032$
 From table 5A.1, TBDY: $esu_{1,nominal} = 0.08$,
 For calculation of $esu_{1,nominal}$ and y_1, sh_1, ft_1, fy_1 , it is considered
 characteristic value $fsy_1 = fs_1/1.2$, from table 5.1, TBDY.
 y_1, sh_1, ft_1, fy_1 , are also multiplied by $Min(1, 1.25 * (l_b/l_d)^{2/3})$, from 10.3.5, ASCE 41-17.
 with $fs_1 = fs = 350.1097$
 with $Es_1 = Es = 200000.00$
 $y_2 = 0.00140044$
 $sh_2 = 0.0044814$
 $ft_2 = 420.1317$
 $fy_2 = 350.1097$
 $su_2 = 0.00512$
 using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
 and also multiplied by the shear_factor according to 15.7.1.4, with
 Shear_factor = 1.00
 $l_o/l_{ou,min} = l_b/l_{b,min} = 0.30$
 $su_2 = 0.4 * esu_{2,nominal} ((5.5), TBDY) = 0.032$
 From table 5A.1, TBDY: $esu_{2,nominal} = 0.08$,
 For calculation of $esu_{2,nominal}$ and y_2, sh_2, ft_2, fy_2 , it is considered
 characteristic value $fsy_2 = fs_2/1.2$, from table 5.1, TBDY.
 y_1, sh_1, ft_1, fy_1 , are also multiplied by $Min(1, 1.25 * (l_b/l_d)^{2/3})$, from 10.3.5, ASCE 41-17.
 with $fs_2 = fs = 350.1097$
 with $Es_2 = Es = 200000.00$
 $y_v = 0.00140044$
 $sh_v = 0.0044814$
 $ft_v = 420.1317$
 $fy_v = 350.1097$
 $suv = 0.00512$
 using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
 and also multiplied by the shear_factor according to 15.7.1.4, with
 Shear_factor = 1.00
 $l_o/l_{ou,min} = l_b/l_d = 0.30$
 $suv = 0.4 * esuv_{nominal} ((5.5), TBDY) = 0.032$
 From table 5A.1, TBDY: $esuv_{nominal} = 0.08$,
 considering characteristic value $fsyv = fsv/1.2$, from table 5.1, TBDY
 For calculation of $esuv_{nominal}$ and y_v, sh_v, ft_v, fy_v , it is considered
 characteristic value $fsyv = fsv/1.2$, from table 5.1, TBDY.
 y_1, sh_1, ft_1, fy_1 , are also multiplied by $Min(1, 1.25 * (l_b/l_d)^{2/3})$, from 10.3.5, ASCE 41-17.
 with $fsv = fs = 350.1097$
 with $Esv = Es = 200000.00$
 $1 = Asl_{ten}/(b * d) * (fs_1/fc) = 0.0635264$
 $2 = Asl_{com}/(b * d) * (fs_2/fc) = 0.0635264$
 $v = Asl_{mid}/(b * d) * (fsv/fc) = 0.00$

and confined core properties:

$b = 2940.00$
 $d = 178.00$
 $d' = 12.00$
 $f_{cc} (5A.2, TBDY) = 25.06158$
 $cc (5A.5, TBDY) = 0.00202463$
 $c = \text{confinement factor} = 1.00246$
 $1 = Asl_{ten}/(b * d) * (fs_1/fc) = 0.07574806$
 $2 = Asl_{com}/(b * d) * (fs_2/fc) = 0.07574806$
 $v = Asl_{mid}/(b * d) * (fsv/fc) = 0.00$

Case/Assumption: Unconfined full section - Steel rupture

' satisfies Eq. (4.3)

--->

$v < v_{s,y2}$ - LHS eq.(4.5) is satisfied

--->

$su (4.9) = 0.18779572$
 $Mu = MRc (4.14) = 2.0658E+008$
 $u = su (4.1) = 3.0306889E-005$

Calculation of ratio l_b/l_d

Inadequate Lap Length with $l_b/l_d = 0.30$

Calculation of Mu2-

Calculation of ultimate curvature ϕ_u according to 4.1, Biskinis/Fardis 2013:

$$\phi_u = 3.0889637E-005$$

$$M_u = 2.4003E+008$$

with full section properties:

$$b = 3000.00$$

$$d = 208.00$$

$$d' = 42.00$$

$$v = 0.00176852$$

$$N = 27588.841$$

$$f_c = 25.00$$

$$\phi_c \text{ (5A.5, TBDY)} = 0.002$$

$$\text{Final value of } \phi_u: \phi_u^* = \text{shear_factor} * \text{Max}(\phi_u, \phi_c) = 0.0035$$

The Shear_factor is considered equal to 1 (pure moment strength)

$$\text{From (5.4b), TBDY: } \phi_u = 0.0035$$

$$\phi_{we} \text{ ((5.4c), TBDY)} = a_{se} * \phi_{sh,min} * f_{ywe} / f_{ce} + \text{Min}(\phi_{fx}, \phi_{fy}) = 0.00$$

where $\phi_f = a_f * \phi_f * f_{fe} / f_{ce}$ is accounting for FRP contribution like EC8-part3 A.4.4.3(6)

$$\phi_{fx} = 0.00$$

$$a_f = 0.00$$

$$b = 250.00$$

$$h = 3000.00$$

$$\text{From EC8 A.4.4.3(6), } \phi_f = 2t_f/bw = 0.008128$$

$$bw = 250.00$$

$$\text{effective stress from (A.35), } f_{fe} = 757.2164$$

$$\phi_{fy} = 0.00$$

$$a_f = 0.00$$

$$b = 3000.00$$

$$h = 250.00$$

$$\text{From EC8 A.4.4.3(6), } \phi_f = 2t_f/bw = 0.00067733$$

$$bw = 3000.00$$

$$\text{effective stress from (A.35), } f_{fe} = 954.4864$$

$$R = 40.00$$

$$\text{Effective FRP thickness, } t_f = NL * t * \cos(b_1) = 1.016$$

$$f_{u,f} = 1055.00$$

$$E_f = 64828.00$$

$$u_{f,f} = 0.015$$

$$a_{se} \text{ ((5.4d), TBDY)} = (a_{se1} * A_{col1} + a_{se2} * A_{col2} + a_{se3} * A_{web}) / A_{sec} = 0.00$$

$$a_{se1} = 0.00$$

$$sh_1 = 150.00$$

$$bo_1 = 190.00$$

$$ho_1 = 540.00$$

$$bi2_1 = 655400.00$$

$$a_{se2} = 0.00$$

$$sh_2 = 150.00$$

$$bo_2 = 190.00$$

$$ho_2 = 540.00$$

$$bi2_2 = 655400.00$$

$$a_{se3} = 0 \text{ (grid does not provide confinement)}$$

$$\phi_{sh,min} = \text{Min}(\phi_{sh,x}, \phi_{sh,y}) = 0.00069813$$

Expression ((5.4d), TBDY) for $\phi_{sh,min}$ has been multiplied by 0.3 according to 15.7.1.3 for members without earthquake detailing (90° closed stirrups)

$$\phi_{sh,x} = \phi_{s1,x} + \phi_{s2,x} + \phi_{s3,x} = 0.00356047$$

$$\phi_{s1,x} \text{ (column 1)} = (A_{s1} * h_1 / s_1) / A_c = 0.00083776$$

$$h_1 = 600.00$$

$$A_{s1} = A_{stir1} * n_{s1} = 157.0796$$

$$\text{No stirrups, } n_{s1} = 2.00$$

$$ps2,x \text{ (column 2)} = (As2 \cdot h2 / s_2) / Ac = 0.00083776$$

$$h2 = 600.00$$

$$As2 = Astir2 \cdot ns2 = 157.0796$$

$$\text{No stirups, } ns2 = 2.00$$

$$ps3,x \text{ (web)} = (As3 \cdot h3 / s_3) / Ac = 0.00188496$$

$$h3 = 1800.00$$

$$As3 = Astir3 \cdot ns3 = 0.00$$

$$\text{No stirups, } ns3 = 2.00$$

$$psh,y = ps1,y + ps2,y + ps3,y = 0.00069813$$

$$ps1,y \text{ (column 1)} = (As1 \cdot h1 / s_1) / Ac = 0.00034907$$

$$h1 = 250.00$$

$$As1 = Astir1 \cdot ns1 = 157.0796$$

$$\text{No stirups, } ns1 = 2.00$$

$$ps2,y \text{ (column 2)} = (As2 \cdot h2 / s_2) / Ac = 0.00034907$$

$$h2 = 250.00$$

$$As2 = Astir2 \cdot ns2 = 157.0796$$

$$\text{No stirups, } ns2 = 2.00$$

$$ps3,y \text{ (web)} = (As3 \cdot h3 / s_3) / Ac = 0.00$$

$$h3 = 250.00$$

$$As3 = Astir3 \cdot ns3 = 157.0796$$

$$\text{No stirups, } ns3 = 0.00$$

$$Asec = 750000.00$$

$$s_1 = 150.00$$

$$s_2 = 150.00$$

$$s_3 = 200.00$$

$$fywe = 625.00$$

$$fce = 25.00$$

$$\text{From ((5.A5), TBDY), TBDY: } cc = 0.00202463$$

$$c = \text{confinement factor} = 1.00246$$

$$y1 = 0.00140044$$

$$sh1 = 0.0044814$$

$$ft1 = 420.1317$$

$$fy1 = 350.1097$$

$$su1 = 0.00512$$

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00

$$lo/lo_{u,min} = lb/l_d = 0.30$$

$$su1 = 0.4 \cdot esu1_{nominal} ((5.5), TBDY) = 0.032$$

From table 5A.1, TBDY: $esu1_{nominal} = 0.08$,

For calculation of $esu1_{nominal}$ and $y1$, $sh1$, $ft1$, $fy1$, it is considered
characteristic value $fsy1 = fs1/1.2$, from table 5.1, TBDY.

$y1$, $sh1$, $ft1$, $fy1$, are also multiplied by $\text{Min}(1, 1.25 \cdot (lb/l_d)^{2/3})$, from 10.3.5, ASCE 41-17.

$$\text{with } fs1 = fs = 350.1097$$

$$\text{with } Es1 = Es = 200000.00$$

$$y2 = 0.00140044$$

$$sh2 = 0.0044814$$

$$ft2 = 420.1317$$

$$fy2 = 350.1097$$

$$su2 = 0.00512$$

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00

$$lo/lo_{u,min} = lb/l_{b,min} = 0.30$$

$$su2 = 0.4 \cdot esu2_{nominal} ((5.5), TBDY) = 0.032$$

From table 5A.1, TBDY: $esu2_{nominal} = 0.08$,

For calculation of $esu2_{nominal}$ and $y2$, $sh2$, $ft2$, $fy2$, it is considered
characteristic value $fsy2 = fs2/1.2$, from table 5.1, TBDY.

$y1$, $sh1$, $ft1$, $fy1$, are also multiplied by $\text{Min}(1, 1.25 \cdot (lb/l_d)^{2/3})$, from 10.3.5, ASCE 41-17.

$$\text{with } fs2 = fs = 350.1097$$

$$\text{with } Es2 = Es = 200000.00$$

$$yv = 0.00140044$$

$$shv = 0.0044814$$

$$ftv = 420.1317$$

$$fyv = 350.1097$$

$suv = 0.00512$
 using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
 and also multiplied by the shear_factor according to 15.7.1.4, with
 $Shear_factor = 1.00$
 $lo/lo_{u,min} = lb/ld = 0.30$
 $suv = 0.4 * esuv_nominal ((5.5), TBDY) = 0.032$
 From table 5A.1, TBDY: $esuv_nominal = 0.08$,
 considering characteristic value $fsyv = fsv/1.2$, from table 5.1, TBDY
 For calculation of $esuv_nominal$ and yv, shv,ftv,fyv , it is considered
 characteristic value $fsyv = fsv/1.2$, from table 5.1, TBDY.
 $y1, sh1,ft1,fy1$, are also multiplied by $Min(1,1.25*(lb/ld)^{2/3})$, from 10.3.5, ASCE 41-17.
 with $fsv = fs = 350.1097$
 with $Esv = Es = 200000.00$
 $1 = Asl,ten/(b*d)*(fs1/fc) = 0.0635264$
 $2 = Asl,com/(b*d)*(fs2/fc) = 0.0635264$
 $v = Asl,mid/(b*d)*(fsv/fc) = 0.03609935$
 and confined core properties:
 $b = 2940.00$
 $d = 178.00$
 $d' = 12.00$
 $fcc (5A.2, TBDY) = 25.06158$
 $cc (5A.5, TBDY) = 0.00202463$
 $c = \text{confinement factor} = 1.00246$
 $1 = Asl,ten/(b*d)*(fs1/fc) = 0.07574806$
 $2 = Asl,com/(b*d)*(fs2/fc) = 0.07574806$
 $v = Asl,mid/(b*d)*(fsv/fc) = 0.0430444$
 Case/Assumption: Unconfined full section - Steel rupture
 ' satisfies Eq. (4.3)
 --->
 $v < vs,y2$ - LHS eq.(4.5) is satisfied
 --->
 $su (4.9) = 0.20311835$
 $Mu = MRc (4.14) = 2.4003E+008$
 $u = su (4.1) = 3.0889637E-005$

Calculation of ratio lb/ld

Inadequate Lap Length with $lb/ld = 0.30$

Calculation of Shear Strength $Vr = Min(Vr1,Vr2) = 1.0244E+006$

Calculation of Shear Strength at edge 1, $Vr1 = 1.0244E+006$
 From (22.5.1.1) and 11.5.4.3, ACI 318-14: $Vr1 = Vn < 0.83*fc^{0.5}*h*d$

NOTE: In expression (22.5.1.1) 'Vw' is replaced by 'Vw+ f*Vf'
 where Vf is the contribution of FRPs (11.3), ACI 440).

From Table (11.5.4.6(d-e)), ACI 318-14: $Vc = 815517.768$
 $Mu/Vu-lw/2 = 0.00 <= 0$
 $= 1$ (normal-weight concrete)
 $fc' = 25.00$, but $fc^{0.5} <= 8.3$ MPa (22.5.3.1, ACI 318-14)
 $h = 3000.00$
 $d = 200.00$
 $lw = 250.00$
 $Mu = 3.7289358E-011$
 $Vu = 1.7354940E-029$
 $Nu = 27588.841$
 From (11.5.4.8), ACI 318-14: $Vs = Vs1 + Vs2 + Vs3 = 104719.755$
 $Vs1 = 52359.878$ is calculated for pseudo-Column 1, with:
 $d = 200.00$
 $Av = 157079.633$
 $s = 150.00$
 $fy = 500.00$

Vs1 has been multiplied by $2(1-s/d)$ ($s > d/2$, according to ASCE 41-17,10.3.4)

$$2(1-s/d) = 0.50$$

Vs2 = 52359.878 is calculated for pseudo-Column 2, with:

$$d = 200.00$$

$$A_v = 157079.633$$

$$s = 150.00$$

$$f_y = 500.00$$

Vs2 has been multiplied by $2(1-s/d)$ ($s > d/2$, according to ASCE 41-17,10.3.4)

$$2(1-s/d) = 0.50$$

Vs3 = 0.00 is calculated for web, with:

$$d = 200.00$$

$$A_v = 0.00$$

$$s = 200.00$$

$$f_y = 500.00$$

Vs3 has been multiplied by $2(1-s/d)$ ($s > d/2$, according to ASCE 41-17,10.3.4)

$$2(1-s/d) = 0.00$$

$$V_f ((11-3)-(11.4), \text{ACI 440}) = 109599.773$$

$$f = 0.95, \text{ for fully-wrapped sections}$$

$$w_f/s_f = 1 \text{ (FRP strips adjacent to one another).}$$

In (11.3) $\sin + \cos$ is replaced with $(\cot + \cot a) \sin a$ which is more a generalised expression,

where a is the angle of the crack direction (see KANEPE).

This later relation, considered as a function $V_f(\alpha)$, is implemented for every different fiber orientation α_i , as well as for 2 crack directions, $\alpha = 45^\circ$ and $\alpha = -45^\circ$ to take into consideration the cyclic seismic loading.

orientation 1: $\alpha = b_1 + 90^\circ = 90.00$

$$V_f = \text{Min}(|V_f(45, \alpha)|, |V_f(-45, \alpha)|), \text{ with:}$$

$$\text{total thickness per orientation, } t_{f1} = N_L * t / N_{\text{Dir}} = 1.016$$

$$d_{fv} = d \text{ (figure 11.2, ACI 440)} = 208.00$$

$$f_{fe} ((11-5), \text{ACI 440}) = 259.312$$

$$E_f = 64828.00$$

$$f_e = 0.004, \text{ from (11.6a), ACI 440}$$

$$\text{with } f_u = 0.01$$

$$\text{From (11-11), ACI 440: } V_s + V_f \leq 1.9929E+006$$

$$b_w = 3000.00$$

Calculation of Shear Strength at edge 2, $V_{r2} = 1.0244E+006$

$$\text{From (22.5.1.1) and 11.5.4.3, ACI 318-14: } V_{r2} = V_n < 0.83 * f_c'^{0.5} * h * d$$

NOTE: In expression (22.5.1.1) ' V_w ' is replaced by ' $V_w + f * V_f$ '

where V_f is the contribution of FRPs (11.3), ACI 440).

$$\text{From Table (11.5.4.6(d-e)), ACI 318-14: } V_c = 815517.768$$

$$\mu_u / \mu_u - l_w / 2 = 0.00 \leq 0$$

$$= 1 \text{ (normal-weight concrete)}$$

$$f_c' = 25.00, \text{ but } f_c'^{0.5} \leq 8.3 \text{ MPa (22.5.3.1, ACI 318-14)}$$

$$h = 3000.00$$

$$d = 200.00$$

$$l_w = 250.00$$

$$\mu_u = 3.7289358E-011$$

$$V_u = 1.7354940E-029$$

$$N_u = 27588.841$$

$$\text{From (11.5.4.8), ACI 318-14: } V_s = V_{s1} + V_{s2} + V_{s3} = 104719.755$$

Vs1 = 52359.878 is calculated for pseudo-Column 1, with:

$$d = 200.00$$

$$A_v = 157079.633$$

$$s = 150.00$$

$$f_y = 500.00$$

Vs1 has been multiplied by $2(1-s/d)$ ($s > d/2$, according to ASCE 41-17,10.3.4)

$$2(1-s/d) = 0.50$$

Vs2 = 52359.878 is calculated for pseudo-Column 2, with:

$$d = 200.00$$

$$A_v = 157079.633$$

$$s = 150.00$$

$$f_y = 500.00$$

Vs2 has been multiplied by $2(1-s/d)$ ($s > d/2$, according to ASCE 41-17,10.3.4)

$$2(1-s/d) = 0.50$$

Vs3 = 0.00 is calculated for web, with:

$$d = 200.00$$

$$A_v = 0.00$$

$$s = 200.00$$

$$f_y = 500.00$$

Vs3 has been multiplied by $2(1-s/d)$ ($s > d/2$, according to ASCE 41-17, 10.3.4)

$$2(1-s/d) = 0.00$$

$$V_f((11-3)-(11.4), \text{ACI 440}) = 109599.773$$

$$f = 0.95, \text{ for fully-wrapped sections}$$

$$w_f/s_f = 1 \text{ (FRP strips adjacent to one another).}$$

In (11.3) $\sin + \cos$ is replaced with $(\cot + \cot a) \sin a$ which is more a generalised expression,

where a is the angle of the crack direction (see KANEPE).

This later relation, considered as a function $V_f(\theta)$, is implemented for every different fiber orientation a_i , as well as for 2 crack directions, $\theta = 45^\circ$ and $\theta = -45^\circ$ to take into consideration the cyclic seismic loading.

orientation 1: $\theta = b_1 + 90^\circ = 90.00$

$$V_f = \text{Min}(|V_f(45, 1)|, |V_f(-45, a_1)|), \text{ with:}$$

$$\text{total thickness per orientation, } t_{f1} = N_L * t / N_{\text{Dir}} = 1.016$$

$$d_{fv} = d \text{ (figure 11.2, ACI 440)} = 208.00$$

$$f_{fe}((11-5), \text{ACI 440}) = 259.312$$

$$E_f = 64828.00$$

$$f_e = 0.004, \text{ from (11.6a), ACI 440}$$

$$\text{with } f_u = 0.01$$

$$\text{From (11-11), ACI 440: } V_s + V_f \leq 1.9929E+006$$

$$b_w = 3000.00$$

End Of Calculation of Shear Capacity ratio for element: wall W1 of floor 1

At local axis: 2

Start Of Calculation of Chord Rotation Capacity for element: wall W1 of floor 1

At local axis: 2

Integration Section: (a)

Section Type: rcrws

Constant Properties

$$\text{Knowledge Factor, } \phi = 1.00$$

According to 10.7.2.3, ASCE 41-17, shear walls with

transverse reinforcement percentage, $\rho_n < 0.0015$

are considered Force-Controlled and lower-bound strengths are used according to 7.5.1.3, ASCE 41-17

$$\rho_n = 0.00069813$$

with $\rho_n = \rho_{s1} + \rho_{s2} + \rho_{s3}$, being the shear reinf. ratio in a plane perpendicular to the shear axis 3

$$(\text{pseudo-col.1 } \rho_{s1} = A_{s1} * b_1 / s_1 = (A_{s1} * h_1 / s_1) / A_c = 0.00034907$$

$$h_1 = 250.00$$

$$s_1 = 150.00$$

$$\text{total area of hoops perpendicular to shear axis, } A_{s1} = 157.0796$$

$$(\text{pseudo-col.2 } \rho_{s2} = A_{s2} * b_2 / s_2 = (A_{s2} * h_2 / s_2) / A_c = 0.00034907$$

$$h_2 = 250.00$$

$$s_2 = 150.00$$

$$\text{total area of hoops perpendicular to shear axis, } A_{s2} = 157.0796$$

$$(\text{grid } \rho_{s3} = A_{s3} * b_3 / s_3 = (A_{s3} * h_3 / s_3) / A_c = 0.00$$

$$h_3 = 250.00$$

$$s_3 = 200.00$$

$$\text{total area of hoops perpendicular to shear axis, } A_{s3} = 0.00$$

$$\text{total section area, } A_c = 750000.00$$

Consequently:

New material of Secondary Member: Concrete Strength, $f_c = f_{c_lower_bound} = 25.00$

New material of Secondary Member: Steel Strength, $f_s = f_{s_lower_bound} = 500.00$

Concrete Elasticity, $E_c = 26999.444$

Steel Elasticity, $E_s = 200000.00$

Total Height, $H_{tot} = 3000.00$

Edges Width, $W_{edg} = 250.00$

Edges Height, $H_{edg} = 600.00$

Web Width, $W_{web} = 250.00$

Cover Thickness, $c = 25.00$

Element Length, L = 3000.00
Secondary Member
Smooth Bars
Ductile Steel
Without Detailing for Earthquake Resistance (including stirrups not closed at 135°)
Longitudinal Bars With Ends Lapped Starting at the End Sections
Inadequate Lap Length with $l_b/l_d = 0.30$
FRP Wrapping Data
Type: Carbon
Cured laminate properties (design values)
Thickness, t = 1.016
Tensile Strength, $f_{fu} = 1055.00$
Tensile Modulus, $E_f = 64828.00$
Elongation, $e_{fu} = 0.01$
Number of directions, NoDir = 1
Fiber orientations, bi: 0.00°
Number of layers, NL = 1
Radius of rounding corners, R = 40.00

Stepwise Properties

Axial Force, F = -31026.87
Longitudinal Reinforcement Area Distribution (in 2 divisions)
-Tension: $A_{st} = 0.00$
-Compression: $A_{sc} = 7269.645$
Longitudinal Reinforcement Area Distribution (in 3 divisions)
-Tension: $A_{st,ten} = 2865.133$
-Compression: $A_{sc,com} = 2865.133$
-Middle: $A_{st,mid} = 1539.38$
Mean Diameter of Tension Reinforcement, $D_bL = 17.33333$

Considering wall controlled by Shear (shear control ratio > 1),
interstorey drift provided values are calculated
New component: From table 7-7, ASCE 41_17: Final chord rotation Capacity $u_R = 1.0^*$ $u = 0.015$
from table 10-20: $u = 0.015$

with:

- Condition i (shear wall and wall segments)
- $(A_s - A_s') * f_y + P) / (t_w * l_w * f_c') = -0.19220244$
 $A_s = 0.00$
 $A_s' = 7269.645$
 $f_y = 500.00$
 $P = 31026.87$
 $t_w = 250.00$
 $l_w = 3000.00$
 $f_c = 25.00$

End Of Calculation of Chord Rotation Capacity for element: wall W1 of floor 1
At local axis: 2
Integration Section: (a)

Calculation No. 11

wall W1, Floor 1

Limit State: Life Safety (data interpolation between analysis steps 1 and 2)

Analysis: Uniform +X

Check: Shear capacity VR_d

Edge: Start

Local Axis: (3)



Start Of Calculation of Shear Capacity for element: wall W1 of floor 1

At local axis: 3

Integration Section: (a)

Section Type: rcwrs

Constant Properties

Knowledge Factor, $\gamma = 1.00$

Member Shear Force is generally considered as Force-Controlled Action according to Table C7-1, ASCE 41-17.

Lower-bound strengths are used for Force-Controlled Actions according to 7.5.1.3, ASCE 41-17

Consequently:

New material of Secondary Member: Concrete Strength, $f_c = f_{c_lower_bound} = 25.00$

New material of Secondary Member: Steel Strength, $f_s = f_{s_lower_bound} = 500.00$

Concrete Elasticity, $E_c = 26999.444$

Steel Elasticity, $E_s = 200000.00$

Total Height, $H_{tot} = 3000.00$

Edges Width, $W_{edg} = 250.00$

Edges Height, $H_{edg} = 600.00$

Web Width, $W_{web} = 250.00$

Cover Thickness, $c = 25.00$

Element Length, $L = 3000.00$

Secondary Member

Smooth Bars

Ductile Steel

Without Detailing for Earthquake Resistance (including stirrups not closed at 135°)

Longitudinal Bars With Ends Lapped Starting at the End Sections

Inadequate Lap Length with $l_o/l_{ou,min} = l_b/l_d = 0.30$

FRP Wrapping Data

Type: Carbon

Cured laminate properties (design values)

Thickness, $t = 1.016$

Tensile Strength, $f_{fu} = 1055.00$

Tensile Modulus, $E_f = 64828.00$
Elongation, $\epsilon_{fu} = 0.01$
Number of directions, $N_{oDir} = 1$
Fiber orientations, $b_i = 0.00^\circ$
Number of layers, $N_L = 1$
Radius of rounding corners, $R = 40.00$

Stepwise Properties

EDGE -A-
Bending Moment, $M_a = 6.1793E+007$
Shear Force, $V_a = -20889.844$
EDGE -B-
Bending Moment, $M_b = 889554.947$
Shear Force, $V_b = 20889.844$
BOTH EDGES
Axial Force, $F = -31026.87$
Longitudinal Reinforcement Area Distribution (in 2 divisions)
-Tension: $A_{sl,t} = 0.00$
-Compression: $A_{sl,c} = 7269.645$
Longitudinal Reinforcement Area Distribution (in 3 divisions)
-Tension: $A_{sl,ten} = 2865.133$
-Compression: $A_{sl,com} = 2865.133$
-Middle: $A_{sl,mid} = 1539.38$
Mean Diameter of Tension Reinforcement, $D_{bL,ten} = 17.33333$

New component: From table 7-7, ASCE 41_17: Final Shear Capacity $V_R = 1.0 \cdot V_n = 2.4900E+006$
From (22.5.1.1) and 11.5.4.3, ACI 318-14: $V_n < 0.83 \cdot f_c' \cdot 0.5 \cdot h \cdot d = 2.4900E+006$

NOTE: In expression (22.5.1.1) ' V_w ' is replaced by ' $V_w + f \cdot V_f$ '
where V_f is the contribution of FRPs (11.3), ACI 440).

From Table (11.5.4.6(d-e)), ACI 318-14: $V_c = 777478.649$
 $\mu_u / V_u - l_w / 2 = 1458.046 > 0$
= 1 (normal-weight concrete)
 $f_c' = 25.00$, but $f_c' \cdot 0.5 \leq 8.3$ MPa (22.5.3.1, ACI 318-14)
 $h = 250.00$
 $d = 2400.00$
 $l_w = 3000.00$
 $\mu_u = 6.1793E+007$
 $V_u = 20889.844$
 $N_u = 31026.87$

From (11.5.4.8), ACI 318-14: $V_s = V_{s1} + V_{s2} + V_{s3} = 1.0681E+006$

$V_{s1} = 251327.412$ is calculated for pseudo-Column 1, with:

$d = 480.00$
 $A_v = 157079.633$
 $s = 150.00$
 $f_y = 500.00$

V_{s1} has been multiplied by 1 ($s < d/2$, according to ASCE 41-17,10.3.4)

$V_{s2} = 251327.412$ is calculated for pseudo-Column 2, with:

$d = 480.00$
 $A_v = 157079.633$
 $s = 150.00$
 $f_y = 500.00$

V_{s2} has been multiplied by 1 ($s < d/2$, according to ASCE 41-17,10.3.4)

$V_{s3} = 565486.678$ is calculated for web, with:

$d = 1440.00$
 $A_v = 157079.633$
 $s = 200.00$
 $f_y = 500.00$

V_{s3} has been multiplied by 1 ($s < d/2$, according to ASCE 41-17,10.3.4)

V_f ((11-3)-(11.4), ACI 440) = $1.5581E+006$

$f = 0.95$, for fully-wrapped sections

$wf/sf = 1$ (FRP strips adjacent to one another).

In (11.3) $\sin + \cos$ is replaced with $(\cot + \cot a) \sin a$ which is more a generalised expression, where a is the angle of the crack direction (see KANEPE).

This later relation, considered as a function $V_f(\alpha)$, is implemented for every different fiber orientation α_i , as well as for 2 crack directions, $\alpha = 45^\circ$ and $\alpha = -45^\circ$ to take into consideration the cyclic seismic loading.

orientation 1: $\alpha_1 = \alpha_1 + 90^\circ = 90.00$

$V_f = \text{Min}(|V_f(45, \alpha_1)|, |V_f(-45, \alpha_1)|)$, with:

total thickness per orientation, $tf_1 = NL \cdot t / NoDir = 1.016$

$df_v = d$ (figure 11.2, ACI 440) = 2957.00

f_{fe} ((11-5), ACI 440) = 259.312

$E_f = 64828.00$

$f_e = 0.004$, from (11.6a), ACI 440

with $f_u = 0.01$

From (11-11), ACI 440: $V_s + V_f \leq 1.9929E+006$

$bw = 250.00$

End Of Calculation of Shear Capacity for element: wall W1 of floor 1

At local axis: 3

Integration Section: (a)

Calculation No. 12

wall W1, Floor 1

Limit State: Life Safety (data interpolation between analysis steps 1 and 2)

Analysis: Uniform +X

Check: Chord rotation capacity (θ_u)

Edge: Start

Local Axis: (3)



Start Of Calculation of Shear Capacity ratio for element: wall W1 of floor 1

At Shear local axis: 3

(Bending local axis: 2)

Section Type: rcrws

Constant Properties

Knowledge Factor, $\gamma = 1.00$

Mean strength values are used for both shear and moment calculations.

Consequently:

New material of Secondary Member: Concrete Strength, $f_c = f_{cm} = 25.00$

New material of Secondary Member: Steel Strength, $f_s = f_{sm} = 500.00$

Concrete Elasticity, $E_c = 26999.444$

Steel Elasticity, $E_s = 200000.00$

#####

Note: Especially for the calculation of moment strengths,

the above steel re-bar strengths are multiplied by 1.25 according to R18.6.5, ACI 318-14

New material: Steel Strength, $f_s = 1.25 \cdot f_{sm} = 625.00$

#####

Total Height, $H_{tot} = 3000.00$

Edges Width, $W_{edg} = 250.00$

Edges Height, $H_{edg} = 600.00$

Web Width, $W_{web} = 250.00$

Cover Thickness, $c = 25.00$

Mean Confinement Factor overall section = 1.00246

Element Length, $L = 3000.00$

Secondary Member

Smooth Bars

Ductile Steel

Without Detailing for Earthquake Resistance (including stirrups not closed at 135°)

Longitudinal Bars With Ends Lapped Starting at the End Sections

Inadequate Lap Length with $l_o/l_{ou,min} = 0.30$

FRP Wrapping Data

Type: Carbon

Cured laminate properties (design values)

Thickness, $t = 1.016$

Tensile Strength, $f_{fu} = 1055.00$

Tensile Modulus, $E_f = 64828.00$

Elongation, $\epsilon_{fu} = 0.01$

Number of directions, $N_{oDir} = 1$

Fiber orientations, $b_i: 0.00^\circ$

Number of layers, $N_L = 1$

Radius of rounding corners, $R = 40.00$

Stepwise Properties

At local axis: 3

EDGE -A-

Shear Force, $V_a = 1.0097420E-028$

EDGE -B-

Shear Force, $V_b = -1.0097420E-028$

BOTH EDGES

Axial Force, $F = -27588.841$

Longitudinal Reinforcement Area Distribution (in 2 divisions)

-Tension: $As_t = 0.00$

-Compression: $As_c = 7269.645$

Longitudinal Reinforcement Area Distribution (in 3 divisions)

-Tension: $As_{t,ten} = 2865.133$

-Compression: $As_{c,com} = 2865.133$

-Middle: $As_{mid} = 0.00$

(According to 10.7.2.3 As_{mid} is setted equal to zero)

Calculation of Shear Capacity ratio, $V_e/V_r = 1.02813$

Member Controlled by Shear ($V_e/V_r > 1$)

Calculation of Shear Demand from fig. R18.6.5, ACI 318-14 $V_e = (M_{pr1} + M_{pr2})/l_n = 2.5600E+006$ with

$M_{pr1} = \text{Max}(Mu_{1+}, Mu_{1-}) = 3.8401E+009$

$Mu_{1+} = 3.3585E+009$, is the ultimate moment strength at the edge 1 of the member in the actual moment direction which is defined for the static loading combination

$Mu_{1-} = 3.8401E+009$, is the ultimate moment strength at the edge 1 of the member in the opposite moment direction which is defined for the static loading combination

$M_{pr2} = \text{Max}(Mu_{2+}, Mu_{2-}) = 3.8401E+009$

Mu2+ = 3.3585E+009, is the ultimate moment strength at the edge 2 of the member in the actual moment direction which is defined for the static loading combination

Mu2- = 3.8401E+009, is the ultimate moment strength at the edge 2 of the member in the opposite moment direction which is defined for the static loading combination

Calculation of Mu1+

Calculation of ultimate curvature ϕ_u according to 4.1, Biskinis/Fardis 2013:

$$\phi_u = 2.0296703E-006$$

$$M_u = 3.3585E+009$$

with full section properties:

$$b = 250.00$$

$$d = 2957.00$$

$$d' = 43.00$$

$$v = 0.0014928$$

$$N = 27588.841$$

$$f_c = 25.00$$

$$\phi_{co} \text{ (5A.5, TBDY)} = 0.002$$

$$\text{Final value of } \phi_{cu}: \phi_{cu}^* = \text{shear_factor} * \text{Max}(\phi_{cu}, \phi_{co}) = 0.0035$$

The Shear_factor is considered equal to 1 (pure moment strength)

$$\text{From (5.4b), TBDY: } \phi_{cu} = 0.0035$$

$$\phi_{we} \text{ ((5.4c), TBDY)} = a_{se} * \phi_{sh, \min} * f_{ywe} / f_{ce} + \text{Min}(\phi_{fx}, \phi_{fy}) = 0.00$$

where $\phi_f = a_f * \phi_{pf} * f_{fe} / f_{ce}$ is accounting for FRP contribution like EC8-part3 A.4.4.3(6)

$$\phi_{fx} = 0.00$$

$$a_f = 0.00$$

$$b = 250.00$$

$$h = 3000.00$$

$$\text{From EC8 A.4.4.3(6), } \phi_{pf} = 2t_f/b_w = 0.008128$$

$$b_w = 250.00$$

$$\text{effective stress from (A.35), } f_{fe} = 757.2164$$

$$\phi_{fy} = 0.00$$

$$a_f = 0.00$$

$$b = 3000.00$$

$$h = 250.00$$

$$\text{From EC8 A.4.4.3(6), } \phi_{pf} = 2t_f/b_w = 0.00067733$$

$$b_w = 3000.00$$

$$\text{effective stress from (A.35), } f_{fe} = 954.4864$$

$$R = 40.00$$

$$\text{Effective FRP thickness, } t_f = N L * t * \cos(\theta_1) = 1.016$$

$$f_{u,f} = 1055.00$$

$$E_f = 64828.00$$

$$u_{f,f} = 0.015$$

$$a_{se} \text{ ((5.4d), TBDY)} = (a_{se1} * A_{col1} + a_{se2} * A_{col2} + a_{se3} * A_{web}) / A_{sec} = 0.00$$

$$a_{se1} = 0.00$$

$$sh_1 = 150.00$$

$$bo_1 = 190.00$$

$$ho_1 = 540.00$$

$$bi2_1 = 655400.00$$

$$a_{se2} = 0.00$$

$$sh_2 = 150.00$$

$$bo_2 = 190.00$$

$$ho_2 = 540.00$$

$$bi2_2 = 655400.00$$

$$a_{se3} = 0 \text{ (grid does not provide confinement)}$$

$$\phi_{sh, \min} = \text{Min}(\phi_{sh,x}, \phi_{sh,y}) = 0.00069813$$

Expression ((5.4d), TBDY) for $\phi_{sh, \min}$ has been multiplied by 0.3 according to 15.7.1.3 for members without earthquake detailing (90° closed stirrups)

$$\phi_{sh,x} = \phi_{s1,x} + \phi_{s2,x} + \phi_{s3,x} = 0.00356047$$

$$\phi_{s1,x} \text{ (column 1)} = (A_{s1} * h_1 / s_{s1}) / A_c = 0.00083776$$

$h1 = 600.00$
 $As1 = Astir1 * ns1 = 157.0796$
 No stirups, $ns1 = 2.00$
 $ps2,x \text{ (column 2)} = (As2 * h2 / s_2) / Ac = 0.00083776$
 $h2 = 600.00$
 $As2 = Astir2 * ns2 = 157.0796$
 No stirups, $ns2 = 2.00$
 $ps3,x \text{ (web)} = (As3 * h3 / s_3) / Ac = 0.00188496$
 $h3 = 1800.00$
 $As3 = Astir3 * ns3 = 0.00$
 No stirups, $ns3 = 2.00$

$psh,y = ps1,y + ps2,y + ps3,y = 0.00069813$
 $ps1,y \text{ (column 1)} = (As1 * h1 / s_1) / Ac = 0.00034907$
 $h1 = 250.00$
 $As1 = Astir1 * ns1 = 157.0796$
 No stirups, $ns1 = 2.00$
 $ps2,y \text{ (column 2)} = (As2 * h2 / s_2) / Ac = 0.00034907$
 $h2 = 250.00$
 $As2 = Astir2 * ns2 = 157.0796$
 No stirups, $ns2 = 2.00$
 $ps3,y \text{ (web)} = (As3 * h3 / s_3) / Ac = 0.00$
 $h3 = 250.00$
 $As3 = Astir3 * ns3 = 157.0796$
 No stirups, $ns3 = 0.00$

$Asec = 750000.00$
 $s_1 = 150.00$
 $s_2 = 150.00$
 $s_3 = 200.00$

$fywe = 625.00$
 $fce = 25.00$

From ((5.A5), TBDY), TBDY: $cc = 0.00202463$
 $c = \text{confinement factor} = 1.00246$

$y1 = 0.00140044$
 $sh1 = 0.0044814$
 $ft1 = 420.1317$
 $fy1 = 350.1097$
 $su1 = 0.00512$

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
 and also multiplied by the shear_factor according to 15.7.1.4, with
 $\text{Shear_factor} = 1.00$

$lo/lou,min = lb/ld = 0.30$

$su1 = 0.4 * esu1_nominal \text{ ((5.5), TBDY)} = 0.032$

From table 5A.1, TBDY: $esu1_nominal = 0.08$,

For calculation of $esu1_nominal$ and $y1, sh1, ft1, fy1$, it is considered
 characteristic value $fsy1 = fs1 / 1.2$, from table 5.1, TBDY.

$y1, sh1, ft1, fy1$, are also multiplied by $\text{Min}(1, 1.25 * (lb/ld)^{2/3})$, from 10.3.5, ASCE 41-17.

with $fs1 = fs = 350.1097$

with $Es1 = Es = 200000.00$

$y2 = 0.00140044$
 $sh2 = 0.0044814$
 $ft2 = 420.1317$
 $fy2 = 350.1097$
 $su2 = 0.00512$

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
 and also multiplied by the shear_factor according to 15.7.1.4, with
 $\text{Shear_factor} = 1.00$

$lo/lou,min = lb/lb,min = 0.30$

$su2 = 0.4 * esu2_nominal \text{ ((5.5), TBDY)} = 0.032$

From table 5A.1, TBDY: $esu2_nominal = 0.08$,

For calculation of $esu2_nominal$ and $y2, sh2, ft2, fy2$, it is considered
 characteristic value $fsy2 = fs2 / 1.2$, from table 5.1, TBDY.

$y2, sh2, ft2, fy2$, are also multiplied by $\text{Min}(1, 1.25 * (lb/ld)^{2/3})$, from 10.3.5, ASCE 41-17.

with $fs2 = fs = 350.1097$

with $Es2 = Es = 200000.00$

$yv = 0.00140044$

```

shv = 0.0044814
ftv = 420.1317
fyv = 350.1097
suv = 0.00512
    using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
    and also multiplied by the shear_factor according to 15.7.1.4, with
    Shear_factor = 1.00
    lo/lo,min = lb/ld = 0.30
    suv = 0.4*esuv_nominal ((5.5), TBDY) = 0.032
    From table 5A.1, TBDY: esuv_nominal = 0.08,
    considering characteristic value fsyv = fsv/1.2, from table 5.1, TBDY
    For calculation of esuv_nominal and yv, shv,ftv,fyv, it is considered
    characteristic value fsyv = fsv/1.2, from table 5.1, TBDY.
    y1, sh1,ft1,fy1, are also multiplied by Min(1,1.25*(lb/ld)^ 2/3), from 10.3.5, ASCE 41-17.
    with fsv = fs = 350.1097
    with Esv = Es = 200000.00
    1 = Asl,ten/(b*d)*(fs1/fc) = 0.05427722
    2 = Asl,com/(b*d)*(fs2/fc) = 0.05427722
    v = Asl,mid/(b*d)*(fsv/fc) = 0.00
and confined core properties:
b = 190.00
d = 2927.00
d' = 13.00
fcc (5A.2, TBDY) = 25.06158
cc (5A.5, TBDY) = 0.00202463
    c = confinement factor = 1.00246
    1 = Asl,ten/(b*d)*(fs1/fc) = 0.07214938
    2 = Asl,com/(b*d)*(fs2/fc) = 0.07214938
    v = Asl,mid/(b*d)*(fsv/fc) = 0.00
Case/Assumption: Unconfined full section - Steel rupture
' satisfies Eq. (4.3)
--->
v < vs,y2 - LHS eq.(4.5) is satisfied
--->
su (4.9) = 0.14691336
Mu = MRc (4.14) = 3.3585E+009
u = su (4.1) = 2.0296703E-006

```

Calculation of ratio lb/ld

Inadequate Lap Length with lb/ld = 0.30

Calculation of Mu1-

Calculation of ultimate curvature u according to 4.1, Biskinis/Fardis 2013:

```

u = 2.0532423E-006
Mu = 3.8401E+009

```

with full section properties:

```

b = 250.00
d = 2957.00
d' = 43.00
v = 0.0014928
N = 27588.841
fc = 25.00
co (5A.5, TBDY) = 0.002
Final value of cu: cu* = shear_factor * Max( cu, cc) = 0.0035
The Shear_factor is considered equal to 1 (pure moment strength)
From (5.4b), TBDY: cu = 0.0035
    we ((5.4c), TBDY) = ase* sh,min*fywe/fce+Min( fx, fy) = 0.00
where f = af*pf*ffe/fce is accounting for FRP contribution like EC8-part3 A.4.4.3(6)

```

fx = 0.00
af = 0.00
b = 250.00
h = 3000.00
From EC8 A4.4.3(6), pf = 2tf/bw = 0.008128
bw = 250.00
effective stress from (A.35), ff,e = 757.2164

fy = 0.00
af = 0.00
b = 3000.00
h = 250.00
From EC8 A4.4.3(6), pf = 2tf/bw = 0.00067733
bw = 3000.00
effective stress from (A.35), ff,e = 954.4864

R = 40.00
Effective FRP thickness, tf = NL*t*cos(b1) = 1.016
fu,f = 1055.00
Ef = 64828.00
u,f = 0.015
ase ((5.4d), TBDY) = (ase1*Acol1+ase2*Acol2+ase3*Aweb)/Asec = 0.00
ase1 = 0.00
sh_1 = 150.00
bo_1 = 190.00
ho_1 = 540.00
bi2_1 = 655400.00
ase2 = 0.00
sh_2 = 150.00
bo_2 = 190.00
ho_2 = 540.00
bi2_2 = 655400.00

ase3 = 0 (grid does not provide confinement)
psh,min = Min(psh,x , psh,y) = 0.00069813

Expression ((5.4d), TBDY) for psh,min has been multiplied by 0.3 according to 15.7.1.3 for members without earthquake detailing (90° closed stirrups)

psh,x = ps1,x+ps2,x+ps3,x = 0.00356047
ps1,x (column 1) = (As1*h1/s_1)/Ac = 0.00083776
h1 = 600.00
As1 = Astir1*ns1 = 157.0796
No stirups, ns1 = 2.00
ps2,x (column 2) = (As2*h2/s_2)/Ac = 0.00083776
h2 = 600.00
As2 = Astir2*ns2 = 157.0796
No stirups, ns2 = 2.00
ps3,x (web) = (As3*h3/s_3)/Ac = 0.00188496
h3 = 1800.00
As3 = Astir3*ns3 = 0.00
No stirups, ns3 = 2.00

psh,y = ps1,y+ps2,y+ps3,y = 0.00069813
ps1,y (column 1) = (As1*h1/s_1)/Ac = 0.00034907
h1 = 250.00
As1 = Astir1*ns1 = 157.0796
No stirups, ns1 = 2.00
ps2,y (column 2) = (As2*h2/s_2)/Ac = 0.00034907
h2 = 250.00
As2 = Astir2*ns2 = 157.0796
No stirups, ns2 = 2.00
ps3,y (web) = (As3*h3/s_3)/Ac = 0.00
h3 = 250.00
As3 = Astir3*ns3 = 157.0796
No stirups, ns3 = 0.00

Asec = 750000.00
s_1 = 150.00

```

s_2 = 150.00
s_3 = 200.00
fywe = 625.00
fce = 25.00
From ((5A.5), TBDY), TBDY: cc = 0.00202463
c = confinement factor = 1.00246
y1 = 0.00140044
sh1 = 0.0044814
ft1 = 420.1317
fy1 = 350.1097
su1 = 0.00512
using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00
lo/lou,min = lb/d = 0.30
su1 = 0.4*esu1_nominal ((5.5), TBDY) = 0.032
From table 5A.1, TBDY: esu1_nominal = 0.08,
For calculation of esu1_nominal and y1, sh1,ft1,fy1, it is considered
characteristic value fsy1 = fs1/1.2, from table 5.1, TBDY.
y1, sh1,ft1,fy1, are also multiplied by Min(1,1.25*(lb/d)^ 2/3), from 10.3.5, ASCE 41-17.
with fs1 = fs = 350.1097
with Es1 = Es = 200000.00
y2 = 0.00140044
sh2 = 0.0044814
ft2 = 420.1317
fy2 = 350.1097
su2 = 0.00512
using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00
lo/lou,min = lb/lb,min = 0.30
su2 = 0.4*esu2_nominal ((5.5), TBDY) = 0.032
From table 5A.1, TBDY: esu2_nominal = 0.08,
For calculation of esu2_nominal and y2, sh2,ft2,fy2, it is considered
characteristic value fsy2 = fs2/1.2, from table 5.1, TBDY.
y1, sh1,ft1,fy1, are also multiplied by Min(1,1.25*(lb/d)^ 2/3), from 10.3.5, ASCE 41-17.
with fs2 = fs = 350.1097
with Es2 = Es = 200000.00
yv = 0.00140044
shv = 0.0044814
ftv = 420.1317
fyv = 350.1097
suv = 0.00512
using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00
lo/lou,min = lb/d = 0.30
suv = 0.4*esuv_nominal ((5.5), TBDY) = 0.032
From table 5A.1, TBDY: esuv_nominal = 0.08,
considering characteristic value fsyv = fsv/1.2, from table 5.1, TBDY
For calculation of esuv_nominal and yv, shv,ftv,fyv, it is considered
characteristic value fsyv = fsv/1.2, from table 5.1, TBDY.
y1, sh1,ft1,fy1, are also multiplied by Min(1,1.25*(lb/d)^ 2/3), from 10.3.5, ASCE 41-17.
with fsv = fs = 350.1097
with Esv = Es = 200000.00
1 = Asl,ten/(b*d)*(fs1/fc) = 0.05427722
2 = Asl,com/(b*d)*(fs2/fc) = 0.05427722
v = Asl,mid/(b*d)*(fsv/fc) = 0.0291621
and confined core properties:
b = 190.00
d = 2927.00
d' = 13.00
fcc (5A.2, TBDY) = 25.06158
cc (5A.5, TBDY) = 0.00202463
c = confinement factor = 1.00246
1 = Asl,ten/(b*d)*(fs1/fc) = 0.07214938
2 = Asl,com/(b*d)*(fs2/fc) = 0.07214938

```

$$v = A_{sl, mid} / (b \cdot d) \cdot (f_{sv} / f_c) = 0.03876447$$

Case/Assumption: Unconfined full section - Steel rupture
' satisfies Eq. (4.3)

--->

$v < v_{s,y2}$ - LHS eq.(4.5) is satisfied

--->

$$s_u(4.9) = 0.15670711$$

$$M_u = M_{Rc}(4.14) = 3.8401E+009$$

$$u = s_u(4.1) = 2.0532423E-006$$

Calculation of ratio I_b/I_d

Inadequate Lap Length with $I_b/I_d = 0.30$

Calculation of M_{u2+}

Calculation of ultimate curvature κ_u according to 4.1, Biskinis/Fardis 2013:

$$u = 2.0296703E-006$$

$$M_u = 3.3585E+009$$

with full section properties:

$$b = 250.00$$

$$d = 2957.00$$

$$d' = 43.00$$

$$v = 0.0014928$$

$$N = 27588.841$$

$$f_c = 25.00$$

$$\omega(5A.5, TBDY) = 0.002$$

$$\text{Final value of } \kappa_u: \kappa_u^* = \text{shear_factor} \cdot \text{Max}(\kappa_u, \kappa_c) = 0.0035$$

The Shear_factor is considered equal to 1 (pure moment strength)

$$\text{From (5.4b), TBDY: } \kappa_u = 0.0035$$

$$\omega_e((5.4c), TBDY) = a_{se} \cdot \text{sh}_{\min} \cdot f_{ywe} / f_{ce} + \text{Min}(f_x, f_y) = 0.00$$

where $f = a_f \cdot p_f \cdot f_{fe} / f_{ce}$ is accounting for FRP contribution like EC8-part3 A.4.4.3(6)

$$f_x = 0.00$$

$$a_f = 0.00$$

$$b = 250.00$$

$$h = 3000.00$$

$$\text{From EC8 A.4.4.3(6), } p_f = 2t_f/bw = 0.008128$$

$$bw = 250.00$$

$$\text{effective stress from (A.35), } f_{fe} = 757.2164$$

$$f_y = 0.00$$

$$a_f = 0.00$$

$$b = 3000.00$$

$$h = 250.00$$

$$\text{From EC8 A.4.4.3(6), } p_f = 2t_f/bw = 0.00067733$$

$$bw = 3000.00$$

$$\text{effective stress from (A.35), } f_{fe} = 954.4864$$

$$R = 40.00$$

$$\text{Effective FRP thickness, } t_f = NL \cdot t \cdot \cos(b_1) = 1.016$$

$$f_{u,f} = 1055.00$$

$$E_f = 64828.00$$

$$u_{f,f} = 0.015$$

$$a_{se}((5.4d), TBDY) = (a_{se1} \cdot A_{col1} + a_{se2} \cdot A_{col2} + a_{se3} \cdot A_{web}) / A_{sec} = 0.00$$

$$a_{se1} = 0.00$$

$$sh_1 = 150.00$$

$$bo_1 = 190.00$$

$$ho_1 = 540.00$$

$$bi_{2,1} = 655400.00$$

$$a_{se2} = 0.00$$

$sh_2 = 150.00$
 $bo_2 = 190.00$
 $ho_2 = 540.00$
 $bi2_2 = 655400.00$
 $ase3 = 0$ (grid does not provide confinement)
 $psh,min = \text{Min}(psh,x, psh,y) = 0.00069813$
 Expression ((5.4d), TBDY) for psh,min has been multiplied by 0.3 according to 15.7.1.3 for members without earthquake detailing (90° closed stirrups)

$psh,x = ps1,x + ps2,x + ps3,x = 0.00356047$
 $ps1,x$ (column 1) = $(As1 \cdot h1 / s_1) / Ac = 0.00083776$
 $h1 = 600.00$
 $As1 = Astir1 \cdot ns1 = 157.0796$
 No stirrups, $ns1 = 2.00$
 $ps2,x$ (column 2) = $(As2 \cdot h2 / s_2) / Ac = 0.00083776$
 $h2 = 600.00$
 $As2 = Astir2 \cdot ns2 = 157.0796$
 No stirrups, $ns2 = 2.00$
 $ps3,x$ (web) = $(As3 \cdot h3 / s_3) / Ac = 0.00188496$
 $h3 = 1800.00$
 $As3 = Astir3 \cdot ns3 = 0.00$
 No stirrups, $ns3 = 2.00$

$psh,y = ps1,y + ps2,y + ps3,y = 0.00069813$
 $ps1,y$ (column 1) = $(As1 \cdot h1 / s_1) / Ac = 0.00034907$
 $h1 = 250.00$
 $As1 = Astir1 \cdot ns1 = 157.0796$
 No stirrups, $ns1 = 2.00$
 $ps2,y$ (column 2) = $(As2 \cdot h2 / s_2) / Ac = 0.00034907$
 $h2 = 250.00$
 $As2 = Astir2 \cdot ns2 = 157.0796$
 No stirrups, $ns2 = 2.00$
 $ps3,y$ (web) = $(As3 \cdot h3 / s_3) / Ac = 0.00$
 $h3 = 250.00$
 $As3 = Astir3 \cdot ns3 = 157.0796$
 No stirrups, $ns3 = 0.00$

$Asec = 750000.00$
 $s_1 = 150.00$
 $s_2 = 150.00$
 $s_3 = 200.00$
 $fywe = 625.00$
 $fce = 25.00$
 From ((5.A5), TBDY), TBDY: $cc = 0.00202463$
 $c = \text{confinement factor} = 1.00246$
 $y1 = 0.00140044$
 $sh1 = 0.0044814$
 $ft1 = 420.1317$
 $fy1 = 350.1097$
 $su1 = 0.00512$
 using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
 and also multiplied by the shear_factor according to 15.7.1.4, with
 $\text{Shear_factor} = 1.00$
 $lo/lou,min = lb/ld = 0.30$
 $su1 = 0.4 \cdot esu1_nominal$ ((5.5), TBDY) = 0.032
 From table 5A.1, TBDY: $esu1_nominal = 0.08$,
 For calculation of $esu1_nominal$ and $y1, sh1, ft1, fy1$, it is considered
 characteristic value $fsy1 = fs1 / 1.2$, from table 5.1, TBDY.
 $y1, sh1, ft1, fy1$, are also multiplied by $\text{Min}(1, 1.25 \cdot (lb/ld)^{2/3})$, from 10.3.5, ASCE 41-17.
 with $fs1 = fs = 350.1097$
 with $Es1 = Es = 200000.00$
 $y2 = 0.00140044$
 $sh2 = 0.0044814$
 $ft2 = 420.1317$
 $fy2 = 350.1097$
 $su2 = 0.00512$
 using (30) in Biskinis/Fardis (2013) multiplied with shear_factor

and also multiplied by the shear_factor according to 15.7.1.4, with
 Shear_factor = 1.00
 $l_o/l_{ou,min} = l_b/l_{b,min} = 0.30$
 $su_2 = 0.4 * esu_{2,nominal} ((5.5), TBDY) = 0.032$
 From table 5A.1, TBDY: $esu_{2,nominal} = 0.08$,
 For calculation of $esu_{2,nominal}$ and y_2, sh_2, ft_2, fy_2 , it is considered
 characteristic value $fsy_2 = fs_2/1.2$, from table 5.1, TBDY.
 y_1, sh_1, ft_1, fy_1 , are also multiplied by $Min(1, 1.25 * (l_b/l_d)^{2/3})$, from 10.3.5, ASCE 41-17.
 with $fs_2 = fs = 350.1097$
 with $Es_2 = Es = 200000.00$
 $y_v = 0.00140044$
 $sh_v = 0.0044814$
 $ft_v = 420.1317$
 $fy_v = 350.1097$
 $suv = 0.00512$
 using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
 and also multiplied by the shear_factor according to 15.7.1.4, with
 Shear_factor = 1.00
 $l_o/l_{ou,min} = l_b/l_d = 0.30$
 $suv = 0.4 * esuv_{nominal} ((5.5), TBDY) = 0.032$
 From table 5A.1, TBDY: $esuv_{nominal} = 0.08$,
 considering characteristic value $fsy_v = fs_v/1.2$, from table 5.1, TBDY
 For calculation of $esuv_{nominal}$ and y_v, sh_v, ft_v, fy_v , it is considered
 characteristic value $fsy_v = fs_v/1.2$, from table 5.1, TBDY.
 y_1, sh_1, ft_1, fy_1 , are also multiplied by $Min(1, 1.25 * (l_b/l_d)^{2/3})$, from 10.3.5, ASCE 41-17.
 with $fs_v = fs = 350.1097$
 with $Es_v = Es = 200000.00$
 $1 = Asl_{ten}/(b * d) * (fs_1/f_c) = 0.05427722$
 $2 = Asl_{com}/(b * d) * (fs_2/f_c) = 0.05427722$
 $v = Asl_{mid}/(b * d) * (fs_v/f_c) = 0.00$
 and confined core properties:
 $b = 190.00$
 $d = 2927.00$
 $d' = 13.00$
 $f_{cc} (5A.2, TBDY) = 25.06158$
 $cc (5A.5, TBDY) = 0.00202463$
 $c = \text{confinement factor} = 1.00246$
 $1 = Asl_{ten}/(b * d) * (fs_1/f_c) = 0.07214938$
 $2 = Asl_{com}/(b * d) * (fs_2/f_c) = 0.07214938$
 $v = Asl_{mid}/(b * d) * (fs_v/f_c) = 0.00$
 Case/Assumption: Unconfined full section - Steel rupture
 ' satisfies Eq. (4.3)
 --->
 $v < v_{s,y_2}$ - LHS eq.(4.5) is satisfied
 --->
 $su (4.9) = 0.14691336$
 $Mu = MRc (4.14) = 3.3585E+009$
 $u = su (4.1) = 2.0296703E-006$

 Calculation of ratio l_b/l_d

 Inadequate Lap Length with $l_b/l_d = 0.30$

 Calculation of Mu_2 -

 Calculation of ultimate curvature u according to 4.1, Biskinis/Fardis 2013:

$$u = 2.0532423E-006$$

$$Mu = 3.8401E+009$$

 with full section properties:

$$b = 250.00$$

$$d = 2957.00$$

$d' = 43.00$
 $v = 0.0014928$
 $N = 27588.841$
 $f_c = 25.00$
 $\alpha (5A.5, TBDY) = 0.002$
 Final value of α : $\alpha^* = \text{shear_factor} * \text{Max}(\alpha, \alpha_c) = 0.0035$
 The Shear_factor is considered equal to 1 (pure moment strength)
 From (5.4b), TBDY: $\alpha = 0.0035$
 $\alpha_{we} ((5.4c), TBDY) = \alpha_{se} * \text{sh}_{min} * f_{ywe} / f_{ce} + \text{Min}(\alpha_x, \alpha_y) = 0.00$
 where $\alpha = \alpha_f * p_f * f_{fe} / f_{ce}$ is accounting for FRP contribution like EC8-part3 A.4.4.3(6)

$\alpha_x = 0.00$
 $\alpha_f = 0.00$
 $b = 250.00$
 $h = 3000.00$
 From EC8 A.4.4.3(6), $p_f = 2t_f / b_w = 0.008128$
 $b_w = 250.00$
 effective stress from (A.35), $f_{fe} = 757.2164$

$\alpha_y = 0.00$
 $\alpha_f = 0.00$
 $b = 3000.00$
 $h = 250.00$
 From EC8 A.4.4.3(6), $p_f = 2t_f / b_w = 0.00067733$
 $b_w = 3000.00$
 effective stress from (A.35), $f_{fe} = 954.4864$

$R = 40.00$
 Effective FRP thickness, $t_f = N L * t * \text{Cos}(b_1) = 1.016$
 $f_{u,f} = 1055.00$
 $E_f = 64828.00$
 $u_{f,f} = 0.015$
 $\alpha_{se} ((5.4d), TBDY) = (\alpha_{se1} * A_{col1} + \alpha_{se2} * A_{col2} + \alpha_{se3} * A_{web}) / A_{sec} = 0.00$
 $\alpha_{se1} = 0.00$
 $sh_1 = 150.00$
 $bo_1 = 190.00$
 $ho_1 = 540.00$
 $bi2_1 = 655400.00$
 $\alpha_{se2} = 0.00$
 $sh_2 = 150.00$
 $bo_2 = 190.00$
 $ho_2 = 540.00$
 $bi2_2 = 655400.00$
 $\alpha_{se3} = 0$ (grid does not provide confinement)
 $p_{sh,min} = \text{Min}(p_{sh,x}, p_{sh,y}) = 0.00069813$
 Expression ((5.4d), TBDY) for $p_{sh,min}$ has been multiplied by 0.3 according to 15.7.1.3 for members without earthquake detailing (90° closed stirrups)

$p_{sh,x} = p_{s1,x} + p_{s2,x} + p_{s3,x} = 0.00356047$
 $p_{s1,x}$ (column 1) = $(A_{s1} * h_1 / s_1) / A_c = 0.00083776$
 $h_1 = 600.00$
 $A_{s1} = A_{stir1} * n_{s1} = 157.0796$
 No stirrups, $n_{s1} = 2.00$
 $p_{s2,x}$ (column 2) = $(A_{s2} * h_2 / s_2) / A_c = 0.00083776$
 $h_2 = 600.00$
 $A_{s2} = A_{stir2} * n_{s2} = 157.0796$
 No stirrups, $n_{s2} = 2.00$
 $p_{s3,x}$ (web) = $(A_{s3} * h_3 / s_3) / A_c = 0.00188496$
 $h_3 = 1800.00$
 $A_{s3} = A_{stir3} * n_{s3} = 0.00$
 No stirrups, $n_{s3} = 2.00$

$p_{sh,y} = p_{s1,y} + p_{s2,y} + p_{s3,y} = 0.00069813$
 $p_{s1,y}$ (column 1) = $(A_{s1} * h_1 / s_1) / A_c = 0.00034907$
 $h_1 = 250.00$
 $A_{s1} = A_{stir1} * n_{s1} = 157.0796$
 No stirrups, $n_{s1} = 2.00$

$$ps2,y \text{ (column 2)} = (As2 \cdot h2 / s_2) / Ac = 0.00034907$$

$$h2 = 250.00$$

$$As2 = Astir2 \cdot ns2 = 157.0796$$

$$\text{No stirups, } ns2 = 2.00$$

$$ps3,y \text{ (web)} = (As3 \cdot h3 / s_3) / Ac = 0.00$$

$$h3 = 250.00$$

$$As3 = Astir3 \cdot ns3 = 157.0796$$

$$\text{No stirups, } ns3 = 0.00$$

$$Asec = 750000.00$$

$$s_1 = 150.00$$

$$s_2 = 150.00$$

$$s_3 = 200.00$$

$$fywe = 625.00$$

$$fce = 25.00$$

$$\text{From } ((5.A5), \text{ TBDY}), \text{ TBDY: } cc = 0.00202463$$

$$c = \text{confinement factor} = 1.00246$$

$$y1 = 0.00140044$$

$$sh1 = 0.0044814$$

$$ft1 = 420.1317$$

$$fy1 = 350.1097$$

$$su1 = 0.00512$$

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00

$$lo/lou,min = lb/d = 0.30$$

$$su1 = 0.4 \cdot esu1_nominal \text{ ((5.5), TBDY)} = 0.032$$

From table 5A.1, TBDY: esu1_nominal = 0.08,

For calculation of esu1_nominal and y1, sh1,ft1,fy1, it is considered
characteristic value fsy1 = fs1/1.2, from table 5.1, TBDY.

y1, sh1,ft1,fy1, are also multiplied by $\text{Min}(1, 1.25 \cdot (lb/d)^{2/3})$, from 10.3.5, ASCE 41-17.

$$\text{with } fs1 = fs = 350.1097$$

$$\text{with } Es1 = Es = 200000.00$$

$$y2 = 0.00140044$$

$$sh2 = 0.0044814$$

$$ft2 = 420.1317$$

$$fy2 = 350.1097$$

$$su2 = 0.00512$$

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00

$$lo/lou,min = lb/lb,min = 0.30$$

$$su2 = 0.4 \cdot esu2_nominal \text{ ((5.5), TBDY)} = 0.032$$

From table 5A.1, TBDY: esu2_nominal = 0.08,

For calculation of esu2_nominal and y2, sh2,ft2,fy2, it is considered
characteristic value fsy2 = fs2/1.2, from table 5.1, TBDY.

y1, sh1,ft1,fy1, are also multiplied by $\text{Min}(1, 1.25 \cdot (lb/d)^{2/3})$, from 10.3.5, ASCE 41-17.

$$\text{with } fs2 = fs = 350.1097$$

$$\text{with } Es2 = Es = 200000.00$$

$$yv = 0.00140044$$

$$shv = 0.0044814$$

$$ftv = 420.1317$$

$$fyv = 350.1097$$

$$suv = 0.00512$$

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00

$$lo/lou,min = lb/d = 0.30$$

$$suv = 0.4 \cdot esuv_nominal \text{ ((5.5), TBDY)} = 0.032$$

From table 5A.1, TBDY: esuv_nominal = 0.08,

considering characteristic value fsyv = fsv/1.2, from table 5.1, TBDY

For calculation of esuv_nominal and yv, shv,ftv,fyv, it is considered
characteristic value fsyv = fsv/1.2, from table 5.1, TBDY.

y1, sh1,ft1,fy1, are also multiplied by $\text{Min}(1, 1.25 \cdot (lb/d)^{2/3})$, from 10.3.5, ASCE 41-17.

$$\text{with } fsv = fs = 350.1097$$

$$\text{with } Esv = Es = 200000.00$$

$$1 = Asl,ten/(b \cdot d) \cdot (fs1/fc) = 0.05427722$$

$$2 = A_{sl,com}/(b*d)*(f_s2/f_c) = 0.05427722$$

$$v = A_{sl,mid}/(b*d)*(f_{sv}/f_c) = 0.0291621$$

and confined core properties:

$$b = 190.00$$

$$d = 2927.00$$

$$d' = 13.00$$

$$f_{cc} (5A.2, TBDY) = 25.06158$$

$$c_c (5A.5, TBDY) = 0.00202463$$

$$c = \text{confinement factor} = 1.00246$$

$$1 = A_{sl,ten}/(b*d)*(f_{s1}/f_c) = 0.07214938$$

$$2 = A_{sl,com}/(b*d)*(f_s2/f_c) = 0.07214938$$

$$v = A_{sl,mid}/(b*d)*(f_{sv}/f_c) = 0.03876447$$

Case/Assumption: Unconfined full section - Steel rupture

' satisfies Eq. (4.3)

--->

$v < v_{s,y2}$ - LHS eq.(4.5) is satisfied

--->

$$s_u (4.9) = 0.15670711$$

$$M_u = M_{Rc} (4.14) = 3.8401E+009$$

$$u = s_u (4.1) = 2.0532423E-006$$

Calculation of ratio l_b/l_d

Inadequate Lap Length with $l_b/l_d = 0.30$

Calculation of Shear Strength $V_r = \text{Min}(V_{r1}, V_{r2}) = 2.4900E+006$

Calculation of Shear Strength at edge 1, $V_{r1} = 2.4900E+006$

From (22.5.1.1) and 11.5.4.3, ACI 318-14: $V_{r1} = V_n < 0.83*f_c'^{0.5}*h*d$

NOTE: In expression (22.5.1.1) ' V_w ' is replaced by ' $V_w + f*V_f$ ' where V_f is the contribution of FRPs (11.3), ACI 440).

From Table (11.5.4.6(d-e)), ACI 318-14: $V_c = 815517.768$

$$M_u/V_u - l_w/2 = 0.00 \leq 0$$

= 1 (normal-weight concrete)

$$f_c' = 25.00, \text{ but } f_c'^{0.5} \leq 8.3 \text{ MPa (22.5.3.1, ACI 318-14)}$$

$$h = 250.00$$

$$d = 2400.00$$

$$l_w = 3000.00$$

$$M_u = 1.1486927E-009$$

$$V_u = 1.0097420E-028$$

$$N_u = 27588.841$$

From (11.5.4.8), ACI 318-14: $V_s = V_{s1} + V_{s2} + V_{s3} = 1.0681E+006$

$V_{s1} = 251327.412$ is calculated for pseudo-Column 1, with:

$$d = 480.00$$

$$A_v = 157079.633$$

$$s = 150.00$$

$$f_y = 500.00$$

V_{s1} has been multiplied by 1 ($s < d/2$, according to ASCE 41-17,10.3.4)

$V_{s2} = 251327.412$ is calculated for pseudo-Column 2, with:

$$d = 480.00$$

$$A_v = 157079.633$$

$$s = 150.00$$

$$f_y = 500.00$$

V_{s2} has been multiplied by 1 ($s < d/2$, according to ASCE 41-17,10.3.4)

$V_{s3} = 565486.678$ is calculated for web, with:

$$d = 1440.00$$

$$A_v = 157079.633$$

$$s = 200.00$$

$$f_y = 500.00$$

V_{s3} has been multiplied by 1 ($s < d/2$, according to ASCE 41-17,10.3.4)

$$V_f ((11-3)-(11.4), \text{ ACI 440}) = 1.5581E+006$$

$f = 0.95$, for fully-wrapped sections
 $wf/sf = 1$ (FRP strips adjacent to one another).
 In (11.3) $\sin + \cos$ is replaced with $(\cot + \cot a)\sin a$ which is more a generalised expression,
 where a is the angle of the crack direction (see KANEPE).
 This later relation, considered as a function $V_f(\theta)$, is implemented for every different fiber orientation a_i ,
 as well as for 2 crack directions, $\theta = 45^\circ$ and $\theta = -45^\circ$ to take into consideration the cyclic seismic loading.
 orientation 1: $\theta = b1 + 90^\circ = 90.00$
 $V_f = \text{Min}(|V_f(45, 1)|, |V_f(-45, a1)|)$, with:
 total thickness per orientation, $tf1 = NL * t / NoDir = 1.016$
 $dfv = d$ (figure 11.2, ACI 440) = 2957.00
 $ffe ((11-5), ACI 440) = 259.312$
 $Ef = 64828.00$
 $fe = 0.004$, from (11.6a), ACI 440
 with $fu = 0.01$
 From (11-11), ACI 440: $V_s + V_f \leq 1.9929E+006$
 $bw = 250.00$

Calculation of Shear Strength at edge 2, $V_{r2} = 2.4900E+006$
 From (22.5.1.1) and 11.5.4.3, ACI 318-14: $V_{r2} = V_n < 0.83 * f_c' ^{0.5} * h * d$

NOTE: In expression (22.5.1.1) ' V_w ' is replaced by ' $V_w + f * V_f$ '
 where V_f is the contribution of FRPs (11.3), ACI 440).

From Table (11.5.4.6(d-e)), ACI 318-14: $V_c = 815517.768$
 $Mu / Vu - lw / 2 = 0.00 \leq 0$
 $= 1$ (normal-weight concrete)
 $f_c' = 25.00$, but $f_c' ^{0.5} \leq 8.3$ MPa (22.5.3.1, ACI 318-14)
 $h = 250.00$
 $d = 2400.00$
 $lw = 3000.00$
 $Mu = 1.1486927E-009$
 $Vu = 1.0097420E-028$
 $Nu = 27588.841$
 From (11.5.4.8), ACI 318-14: $V_s = V_{s1} + V_{s2} + V_{s3} = 1.0681E+006$
 $V_{s1} = 251327.412$ is calculated for pseudo-Column 1, with:
 $d = 480.00$
 $Av = 157079.633$
 $s = 150.00$
 $fy = 500.00$
 V_{s1} has been multiplied by 1 ($s < d/2$, according to ASCE 41-17, 10.3.4)
 $V_{s2} = 251327.412$ is calculated for pseudo-Column 2, with:
 $d = 480.00$
 $Av = 157079.633$
 $s = 150.00$
 $fy = 500.00$
 V_{s2} has been multiplied by 1 ($s < d/2$, according to ASCE 41-17, 10.3.4)
 $V_{s3} = 565486.678$ is calculated for web, with:
 $d = 1440.00$
 $Av = 157079.633$
 $s = 200.00$
 $fy = 500.00$
 V_{s3} has been multiplied by 1 ($s < d/2$, according to ASCE 41-17, 10.3.4)
 $V_f ((11-3)-(11.4), ACI 440) = 1.5581E+006$
 $f = 0.95$, for fully-wrapped sections
 $wf/sf = 1$ (FRP strips adjacent to one another).
 In (11.3) $\sin + \cos$ is replaced with $(\cot + \cot a)\sin a$ which is more a generalised expression,
 where a is the angle of the crack direction (see KANEPE).
 This later relation, considered as a function $V_f(\theta)$, is implemented for every different fiber orientation a_i ,
 as well as for 2 crack directions, $\theta = 45^\circ$ and $\theta = -45^\circ$ to take into consideration the cyclic seismic loading.
 orientation 1: $\theta = b1 + 90^\circ = 90.00$
 $V_f = \text{Min}(|V_f(45, 1)|, |V_f(-45, a1)|)$, with:
 total thickness per orientation, $tf1 = NL * t / NoDir = 1.016$
 $dfv = d$ (figure 11.2, ACI 440) = 2957.00
 $ffe ((11-5), ACI 440) = 259.312$
 $Ef = 64828.00$
 $fe = 0.004$, from (11.6a), ACI 440
 with $fu = 0.01$

From (11-11), ACI 440: $V_s + V_f \leq 1.9929E+006$
bw = 250.00

End Of Calculation of Shear Capacity ratio for element: wall W1 of floor 1
At local axis: 3

Start Of Calculation of Shear Capacity ratio for element: wall W1 of floor 1
At Shear local axis: 2
(Bending local axis: 3)
Section Type: rcrrws

Constant Properties

Knowledge Factor, $\phi = 1.00$
Mean strength values are used for both shear and moment calculations.
Consequently:
New material of Secondary Member: Concrete Strength, $f_c = f_{cm} = 25.00$
New material of Secondary Member: Steel Strength, $f_s = f_{sm} = 500.00$
Concrete Elasticity, $E_c = 26999.444$
Steel Elasticity, $E_s = 200000.00$

Note: Especially for the calculation of moment strengths,
the above steel re-bar strengths are multiplied by 1.25 according to R18.6.5, ACI 318-14
New material: Steel Strength, $f_s = 1.25 \cdot f_{sm} = 625.00$

Total Height, $H_{tot} = 3000.00$
Edges Width, $W_{edg} = 250.00$
Edges Height, $H_{edg} = 600.00$
Web Width, $W_{web} = 250.00$
Cover Thickness, $c = 25.00$
Mean Confinement Factor overall section = 1.00246
Element Length, $L = 3000.00$
Secondary Member
Smooth Bars
Ductile Steel
Without Detailing for Earthquake Resistance (including stirrups not closed at 135°)
Longitudinal Bars With Ends Lapped Starting at the End Sections
Inadequate Lap Length with $l_o/l_{ou,min} = 0.30$
FRP Wrapping Data
Type: Carbon
Cured laminate properties (design values)
Thickness, $t = 1.016$
Tensile Strength, $f_{fu} = 1055.00$
Tensile Modulus, $E_f = 64828.00$
Elongation, $\epsilon_{fu} = 0.01$
Number of directions, $N_{oDir} = 1$
Fiber orientations, $b_i: 0.00^\circ$
Number of layers, $N_L = 1$
Radius of rounding corners, $R = 40.00$

Stepwise Properties

At local axis: 2
EDGE -A-
Shear Force, $V_a = 1.7354940E-029$
EDGE -B-
Shear Force, $V_b = -1.7354940E-029$
BOTH EDGES
Axial Force, $F = -27588.841$
Longitudinal Reinforcement Area Distribution (in 2 divisions)
-Tension: $A_{st} = 0.00$
-Compression: $A_{sc} = 7269.645$
Longitudinal Reinforcement Area Distribution (in 3 divisions)

-Tension: $Asl_{ten} = 2830.575$
 -Compression: $Asl_{com} = 2830.575$
 -Middle: $Asl_{mid} = 0.00$
 (According to 10.7.2.3 Asl_{mid} is setted equal to zero)

Calculation of Shear Capacity ratio , $Ve/Vr = 0.15621236$

Member Controlled by Flexure ($Ve/Vr < 1$)

Calculation of Shear Demand from fig. R18.6.5, ACI 318-14 $Ve = (Mpr1 + Mpr2)/ln = 160017.271$

with
 $Mpr1 = \text{Max}(Mu1+, Mu1-) = 2.4003E+008$
 $Mu1+ = 2.0658E+008$, is the ultimate moment strength at the edge 1 of the member in the actual moment direction which is defined for the static loading combination
 $Mu1- = 2.4003E+008$, is the ultimate moment strength at the edge 1 of the member in the opposite moment direction which is defined for the static loading combination
 $Mpr2 = \text{Max}(Mu2+, Mu2-) = 2.4003E+008$
 $Mu2+ = 2.0658E+008$, is the ultimate moment strength at the edge 2 of the member in the actual moment direction which is defined for the static loading combination
 $Mu2- = 2.4003E+008$, is the ultimate moment strength at the edge 2 of the member in the opposite moment direction which is defined for the static loading combination

Calculation of $Mu1+$

Calculation of ultimate curvature u according to 4.1, Biskinis/Fardis 2013:

$u = 3.0306889E-005$

$Mu = 2.0658E+008$

with full section properties:

$b = 3000.00$

$d = 208.00$

$d' = 42.00$

$v = 0.00176852$

$N = 27588.841$

$fc = 25.00$

co (5A.5, TBDY) = 0.002

Final value of cu : $cu^* = \text{shear_factor} * \text{Max}(cu, cc) = 0.0035$

The Shear_factor is considered equal to 1 (pure moment strength)

From (5.4b), TBDY: $cu = 0.0035$

we ((5.4c), TBDY) = $ase * sh_{min} * fy_{we} / f_{ce} + \text{Min}(fx, fy) = 0.00$

where $f = af * pf * f_{fe} / f_{ce}$ is accounting for FRP contribution like EC8-part3 A.4.4.3(6)

$fx = 0.00$

$af = 0.00$

$b = 250.00$

$h = 3000.00$

From EC8 A4.4.3(6), $pf = 2tf/bw = 0.008128$

$bw = 250.00$

effective stress from (A.35), $ff_{e} = 757.2164$

$fy = 0.00$

$af = 0.00$

$b = 3000.00$

$h = 250.00$

From EC8 A4.4.3(6), $pf = 2tf/bw = 0.00067733$

$bw = 3000.00$

effective stress from (A.35), $ff_{e} = 954.4864$

$R = 40.00$

Effective FRP thickness, $tf = NL * t * \text{Cos}(b1) = 1.016$

$fu_{f} = 1055.00$

$Ef = 64828.00$

$u_{f} = 0.015$


```

ase ((5.4d), TBDY) = (ase1*Acol1+ase2*Acol2+ase3*Aweb)/Asec = 0.00
ase1 = 0.00
sh_1 = 150.00
bo_1 = 190.00
ho_1 = 540.00
bi2_1 = 655400.00
ase2 = 0.00
sh_2 = 150.00
bo_2 = 190.00
ho_2 = 540.00
bi2_2 = 655400.00
ase3 = 0 (grid does not provide confinement)
psh,min = Min(psh,x , psh,y) = 0.00069813
Expression ((5.4d), TBDY) for psh,min has been multiplied by 0.3 according to 15.7.1.3 for members without
earthquake detailing (90° closed stirrups)

```

```

psh,x = ps1,x+ps2,x+ps3,x = 0.00356047
ps1,x (column 1) = (As1*h1/s_1)/Ac = 0.00083776
h1 = 600.00
As1 = Astir1*ns1 = 157.0796
No stirups, ns1 = 2.00
ps2,x (column 2) = (As2*h2/s_2)/Ac = 0.00083776
h2 = 600.00
As2 = Astir2*ns2 = 157.0796
No stirups, ns2 = 2.00
ps3,x (web) = (As3*h3/s_3)/Ac = 0.00188496
h3 = 1800.00
As3 = Astir3*ns3 = 0.00
No stirups, ns3 = 2.00

```

```

psh,y = ps1,y+ps2,y+ps3,y = 0.00069813
ps1,y (column 1) = (As1*h1/s_1)/Ac = 0.00034907
h1 = 250.00
As1 = Astir1*ns1 = 157.0796
No stirups, ns1 = 2.00
ps2,y (column 2) = (As2*h2/s_2)/Ac = 0.00034907
h2 = 250.00
As2 = Astir2*ns2 = 157.0796
No stirups, ns2 = 2.00
ps3,y (web) = (As3*h3/s_3)/Ac = 0.00
h3 = 250.00
As3 = Astir3*ns3 = 157.0796
No stirups, ns3 = 0.00

```

```

Asec = 750000.00
s_1 = 150.00
s_2 = 150.00
s_3 = 200.00
fywe = 625.00
fce = 25.00
From ((5.A5), TBDY), TBDY: cc = 0.00202463
c = confinement factor = 1.00246
y1 = 0.00140044
sh1 = 0.0044814
ft1 = 420.1317
fy1 = 350.1097
su1 = 0.00512
using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00
lo/lou,min = lb/l_d = 0.30
su1 = 0.4*esu1_nominal ((5.5), TBDY) = 0.032
From table 5A.1, TBDY: esu1_nominal = 0.08,
For calculation of esu1_nominal and y1, sh1,ft1,fy1, it is considered
characteristic value fsy1 = fs1/1.2, from table 5.1, TBDY.
y1, sh1,ft1,fy1, are also multiplied by Min(1,1.25*(lb/l_d)^ 2/3), from 10.3.5, ASCE 41-17.
with fs1 = fs = 350.1097

```

```

    with Es1 = Es = 200000.00
    y2 = 0.00140044
    sh2 = 0.0044814
    ft2 = 420.1317
    fy2 = 350.1097
    su2 = 0.00512
    using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
    and also multiplied by the shear_factor according to 15.7.1.4, with
    Shear_factor = 1.00
    lo/lo,min = lb/lb,min = 0.30
    su2 = 0.4*esu2_nominal ((5.5), TBDY) = 0.032
    From table 5A.1, TBDY: esu2_nominal = 0.08,
    For calculation of esu2_nominal and y2, sh2,ft2,fy2, it is considered
    characteristic value fsy2 = fs2/1.2, from table 5.1, TBDY.
    y1, sh1,ft1,fy1, are also multiplied by Min(1,1.25*(lb/lb)^ 2/3), from 10.3.5, ASCE 41-17.
    with fs2 = fs = 350.1097
    with Es2 = Es = 200000.00
    yv = 0.00140044
    shv = 0.0044814
    ftv = 420.1317
    fyv = 350.1097
    suv = 0.00512
    using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
    and also multiplied by the shear_factor according to 15.7.1.4, with
    Shear_factor = 1.00
    lo/lo,min = lb/lb = 0.30
    suv = 0.4*esuv_nominal ((5.5), TBDY) = 0.032
    From table 5A.1, TBDY: esuv_nominal = 0.08,
    considering characteristic value fsyv = fsv/1.2, from table 5.1, TBDY
    For calculation of esuv_nominal and yv, shv,ftv,fyv, it is considered
    characteristic value fsyv = fsv/1.2, from table 5.1, TBDY.
    y1, sh1,ft1,fy1, are also multiplied by Min(1,1.25*(lb/lb)^ 2/3), from 10.3.5, ASCE 41-17.
    with fsv = fs = 350.1097
    with Esv = Es = 200000.00
    1 = Asl,ten/(b*d)*(fs1/fc) = 0.0635264
    2 = Asl,com/(b*d)*(fs2/fc) = 0.0635264
    v = Asl,mid/(b*d)*(fsv/fc) = 0.00
    and confined core properties:
    b = 2940.00
    d = 178.00
    d' = 12.00
    fcc (5A.2, TBDY) = 25.06158
    cc (5A.5, TBDY) = 0.00202463
    c = confinement factor = 1.00246
    1 = Asl,ten/(b*d)*(fs1/fc) = 0.07574806
    2 = Asl,com/(b*d)*(fs2/fc) = 0.07574806
    v = Asl,mid/(b*d)*(fsv/fc) = 0.00
    Case/Assumption: Unconfined full section - Steel rupture
    ' satisfies Eq. (4.3)
    --->
    v < vs,y2 - LHS eq.(4.5) is satisfied
    --->
    su (4.9) = 0.18779572
    Mu = MRc (4.14) = 2.0658E+008
    u = su (4.1) = 3.0306889E-005

```

Calculation of ratio lb/lb

Inadequate Lap Length with lb/lb = 0.30

Calculation of Mu1-

Calculation of ultimate curvature ϕ_u according to 4.1, Biskinis/Fardis 2013:

$$\phi_u = 3.0889637E-005$$

$$\mu_u = 2.4003E+008$$

with full section properties:

$$b = 3000.00$$

$$d = 208.00$$

$$d' = 42.00$$

$$v = 0.00176852$$

$$N = 27588.841$$

$$f_c = 25.00$$

$$\omega (5A.5, \text{TBDY}) = 0.002$$

$$\text{Final value of } \phi_u: \phi_u^* = \text{shear_factor} * \text{Max}(\phi_u, \phi_c) = 0.0035$$

The Shear_factor is considered equal to 1 (pure moment strength)

$$\text{From (5.4b), TBDY: } \phi_u = 0.0035$$

$$\omega_e ((5.4c), \text{TBDY}) = a_{se} * \frac{\text{sh}_{\min} * f_{ywe}}{f_{ce}} + \text{Min}(\phi_x, \phi_y) = 0.00$$

where $\phi = a_f * \phi_f * f_{fe} / f_{ce}$ is accounting for FRP contribution like EC8-part3 A.4.4.3(6)

$$\phi_x = 0.00$$

$$a_f = 0.00$$

$$b = 250.00$$

$$h = 3000.00$$

$$\text{From EC8 A.4.4.3(6), } \phi_f = 2t_f/bw = 0.008128$$

$$bw = 250.00$$

$$\text{effective stress from (A.35), } f_{fe} = 757.2164$$

$$f_y = 0.00$$

$$a_f = 0.00$$

$$b = 3000.00$$

$$h = 250.00$$

$$\text{From EC8 A.4.4.3(6), } \phi_f = 2t_f/bw = 0.00067733$$

$$bw = 3000.00$$

$$\text{effective stress from (A.35), } f_{fe} = 954.4864$$

$$R = 40.00$$

$$\text{Effective FRP thickness, } t_f = NL * t * \cos(\beta_1) = 1.016$$

$$f_{u,f} = 1055.00$$

$$E_f = 64828.00$$

$$u_{f,f} = 0.015$$

$$a_{se} ((5.4d), \text{TBDY}) = (a_{se1} * A_{col1} + a_{se2} * A_{col2} + a_{se3} * A_{web}) / A_{sec} = 0.00$$

$$a_{se1} = 0.00$$

$$\text{sh}_1 = 150.00$$

$$\text{bo}_1 = 190.00$$

$$\text{ho}_1 = 540.00$$

$$\text{bi2}_1 = 655400.00$$

$$a_{se2} = 0.00$$

$$\text{sh}_2 = 150.00$$

$$\text{bo}_2 = 190.00$$

$$\text{ho}_2 = 540.00$$

$$\text{bi2}_2 = 655400.00$$

$$a_{se3} = 0 \text{ (grid does not provide confinement)}$$

$$\text{psh}_{\min} = \text{Min}(\text{psh}_x, \text{psh}_y) = 0.00069813$$

Expression ((5.4d), TBDY) for psh_{\min} has been multiplied by 0.3 according to 15.7.1.3 for members without earthquake detailing (90° closed stirrups)

$$\text{psh}_x = \text{ps1}_x + \text{ps2}_x + \text{ps3}_x = 0.00356047$$

$$\text{ps1}_x \text{ (column 1)} = (A_{s1} * h_1 / s_1) / A_c = 0.00083776$$

$$h_1 = 600.00$$

$$A_{s1} = A_{stir1} * n_{s1} = 157.0796$$

$$\text{No stirrups, } n_{s1} = 2.00$$

$$\text{ps2}_x \text{ (column 2)} = (A_{s2} * h_2 / s_2) / A_c = 0.00083776$$

$$h_2 = 600.00$$

$$A_{s2} = A_{stir2} * n_{s2} = 157.0796$$

$$\text{No stirrups, } n_{s2} = 2.00$$

$$\text{ps3}_x \text{ (web)} = (A_{s3} * h_3 / s_3) / A_c = 0.00188496$$

$$h_3 = 1800.00$$

$$A_{s3} = A_{stir3} * n_{s3} = 0.00$$

No stirups, ns3 = 2.00

psh,y = ps1,y+ps2,y+ps3,y = 0.00069813

ps1,y (column 1) = (As1*h1/s_1)/Ac = 0.00034907

h1 = 250.00

As1 = Astir1*ns1 = 157.0796

No stirups, ns1 = 2.00

ps2,y (column 2) = (As2*h2/s_2)/Ac = 0.00034907

h2 = 250.00

As2 = Astir2*ns2 = 157.0796

No stirups, ns2 = 2.00

ps3,y (web) = (As3*h3/s_3)/Ac = 0.00

h3 = 250.00

As3 = Astir3*ns3 = 157.0796

No stirups, ns3 = 0.00

Asec = 750000.00

s_1 = 150.00

s_2 = 150.00

s_3 = 200.00

fywe = 625.00

fce = 25.00

From ((5.A5), TBDY), TBDY: cc = 0.00202463

c = confinement factor = 1.00246

y1 = 0.00140044

sh1 = 0.0044814

ft1 = 420.1317

fy1 = 350.1097

su1 = 0.00512

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00

lo/lou,min = lb/ld = 0.30

su1 = 0.4*esu1_nominal ((5.5), TBDY) = 0.032

From table 5A.1, TBDY: esu1_nominal = 0.08,

For calculation of esu1_nominal and y1, sh1,ft1,fy1, it is considered
characteristic value fsy1 = fs1/1.2, from table 5.1, TBDY.

y1, sh1,ft1,fy1, are also multiplied by $\text{Min}(1, 1.25 \cdot (lb/ld)^{2/3})$, from 10.3.5, ASCE 41-17.

with fs1 = fs = 350.1097

with Es1 = Es = 200000.00

y2 = 0.00140044

sh2 = 0.0044814

ft2 = 420.1317

fy2 = 350.1097

su2 = 0.00512

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00

lo/lou,min = lb/lb,min = 0.30

su2 = 0.4*esu2_nominal ((5.5), TBDY) = 0.032

From table 5A.1, TBDY: esu2_nominal = 0.08,

For calculation of esu2_nominal and y2, sh2,ft2,fy2, it is considered
characteristic value fsy2 = fs2/1.2, from table 5.1, TBDY.

y1, sh1,ft1,fy1, are also multiplied by $\text{Min}(1, 1.25 \cdot (lb/ld)^{2/3})$, from 10.3.5, ASCE 41-17.

with fs2 = fs = 350.1097

with Es2 = Es = 200000.00

yv = 0.00140044

shv = 0.0044814

ftv = 420.1317

fyv = 350.1097

suv = 0.00512

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00

lo/lou,min = lb/ld = 0.30

suv = 0.4*esuv_nominal ((5.5), TBDY) = 0.032

From table 5A.1, TBDY: esuv_nominal = 0.08,

considering characteristic value $f_{sv} = f_{sv}/1.2$, from table 5.1, TBDY
For calculation of $e_{suv_nominal}$ and y_v , sh_v , ft_v , fy_v , it is considered
characteristic value $f_{sv} = f_{sv}/1.2$, from table 5.1, TBDY.

y_1 , sh_1 , ft_1 , fy_1 , are also multiplied by $\text{Min}(1, 1.25 \cdot (l_b/l_d)^{2/3})$, from 10.3.5, ASCE 41-17.

with $f_{sv} = f_s = 350.1097$

with $E_{sv} = E_s = 200000.00$

1 = $A_{sl,ten}/(b \cdot d) \cdot (f_{s1}/f_c) = 0.0635264$

2 = $A_{sl,com}/(b \cdot d) \cdot (f_{s2}/f_c) = 0.0635264$

$v = A_{sl,mid}/(b \cdot d) \cdot (f_{sv}/f_c) = 0.03609935$

and confined core properties:

$b = 2940.00$

$d = 178.00$

$d' = 12.00$

f_{cc} (5A.2, TBDY) = 25.06158

cc (5A.5, TBDY) = 0.00202463

c = confinement factor = 1.00246

1 = $A_{sl,ten}/(b \cdot d) \cdot (f_{s1}/f_c) = 0.07574806$

2 = $A_{sl,com}/(b \cdot d) \cdot (f_{s2}/f_c) = 0.07574806$

$v = A_{sl,mid}/(b \cdot d) \cdot (f_{sv}/f_c) = 0.0430444$

Case/Assumption: Unconfined full section - Steel rupture

' satisfies Eq. (4.3)

--->

$v < v_{s,y2}$ - LHS eq.(4.5) is satisfied

--->

su (4.9) = 0.20311835

$Mu = MR_c$ (4.14) = 2.4003E+008

$u = su$ (4.1) = 3.0889637E-005

Calculation of ratio l_b/l_d

Inadequate Lap Length with $l_b/l_d = 0.30$

Calculation of Mu_{2+}

Calculation of ultimate curvature u according to 4.1, Biskinis/Fardis 2013:

$u = 3.0306889E-005$

$Mu = 2.0658E+008$

with full section properties:

$b = 3000.00$

$d = 208.00$

$d' = 42.00$

$v = 0.00176852$

$N = 27588.841$

$f_c = 25.00$

co (5A.5, TBDY) = 0.002

Final value of cu : $cu^* = \text{shear_factor} \cdot \text{Max}(cu, cc) = 0.0035$

The Shear_factor is considered equal to 1 (pure moment strength)

From (5.4b), TBDY: $cu = 0.0035$

w_e ((5.4c), TBDY) = $ase \cdot sh_{min} \cdot fy_{we}/f_{ce} + \text{Min}(fx, fy) = 0.00$

where $f = af \cdot pf \cdot f_{fe}/f_{ce}$ is accounting for FRP contribution like EC8-part3 A.4.4.3(6)

$fx = 0.00$

$af = 0.00$

$b = 250.00$

$h = 3000.00$

From EC8 A4.4.3(6), $pf = 2tf/bw = 0.008128$

$bw = 250.00$

effective stress from (A.35), $f_{fe} = 757.2164$

$fy = 0.00$

$af = 0.00$

b = 3000.00
h = 250.00
From EC8 A4.4.3(6), $pf = 2tf/bw = 0.00067733$
bw = 3000.00
effective stress from (A.35), $ff,e = 954.4864$

R = 40.00
Effective FRP thickness, $tf = NL*t*Cos(b1) = 1.016$
 $f_{u,f} = 1055.00$
 $E_f = 64828.00$
 $u,f = 0.015$
 $ase((5.4d), TBDY) = (ase1*Acol1 + ase2*Acol2 + ase3*Aweb)/Asec = 0.00$

ase1 = 0.00
sh_1 = 150.00
bo_1 = 190.00
ho_1 = 540.00
bi2_1 = 655400.00

ase2 = 0.00
sh_2 = 150.00
bo_2 = 190.00
ho_2 = 540.00
bi2_2 = 655400.00

ase3 = 0 (grid does not provide confinement)
 $psh,min = Min(psh,x, psh,y) = 0.00069813$

Expression ((5.4d), TBDY) for psh,min has been multiplied by 0.3 according to 15.7.1.3 for members without earthquake detailing (90° closed stirrups)

$psh,x = ps1,x + ps2,x + ps3,x = 0.00356047$
 $ps1,x$ (column 1) = $(As1*h1/s_1)/Ac = 0.00083776$
h1 = 600.00
 $As1 = Astir1*ns1 = 157.0796$
No stirrups, ns1 = 2.00
 $ps2,x$ (column 2) = $(As2*h2/s_2)/Ac = 0.00083776$
h2 = 600.00
 $As2 = Astir2*ns2 = 157.0796$
No stirrups, ns2 = 2.00
 $ps3,x$ (web) = $(As3*h3/s_3)/Ac = 0.00188496$
h3 = 1800.00
 $As3 = Astir3*ns3 = 0.00$
No stirrups, ns3 = 2.00

$psh,y = ps1,y + ps2,y + ps3,y = 0.00069813$
 $ps1,y$ (column 1) = $(As1*h1/s_1)/Ac = 0.00034907$
h1 = 250.00
 $As1 = Astir1*ns1 = 157.0796$
No stirrups, ns1 = 2.00
 $ps2,y$ (column 2) = $(As2*h2/s_2)/Ac = 0.00034907$
h2 = 250.00
 $As2 = Astir2*ns2 = 157.0796$
No stirrups, ns2 = 2.00
 $ps3,y$ (web) = $(As3*h3/s_3)/Ac = 0.00$
h3 = 250.00
 $As3 = Astir3*ns3 = 157.0796$
No stirrups, ns3 = 0.00

Asec = 750000.00
s_1 = 150.00
s_2 = 150.00
s_3 = 200.00

$f_{ywe} = 625.00$
 $f_{ce} = 25.00$

From ((5.A5), TBDY), TBDY: $cc = 0.00202463$
c = confinement factor = 1.00246

y1 = 0.00140044
sh1 = 0.0044814
ft1 = 420.1317
fy1 = 350.1097

```

su1 = 0.00512
using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00
lo/lou,min = lb/lb,min = 0.30
su1 = 0.4*esu1_nominal ((5.5), TBDY) = 0.032
From table 5A.1, TBDY: esu1_nominal = 0.08,
For calculation of esu1_nominal and y1, sh1,ft1,fy1, it is considered
characteristic value fsy1 = fs1/1.2, from table 5.1, TBDY.
y1, sh1,ft1,fy1, are also multiplied by Min(1,1.25*(lb/lb,min)^ 2/3), from 10.3.5, ASCE 41-17.
with fs1 = fs = 350.1097
with Es1 = Es = 200000.00
y2 = 0.00140044
sh2 = 0.0044814
ft2 = 420.1317
fy2 = 350.1097
su2 = 0.00512
using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00
lo/lou,min = lb/lb,min = 0.30
su2 = 0.4*esu2_nominal ((5.5), TBDY) = 0.032
From table 5A.1, TBDY: esu2_nominal = 0.08,
For calculation of esu2_nominal and y2, sh2,ft2,fy2, it is considered
characteristic value fsy2 = fs2/1.2, from table 5.1, TBDY.
y1, sh1,ft1,fy1, are also multiplied by Min(1,1.25*(lb/lb,min)^ 2/3), from 10.3.5, ASCE 41-17.
with fs2 = fs = 350.1097
with Es2 = Es = 200000.00
yv = 0.00140044
shv = 0.0044814
ftv = 420.1317
fyv = 350.1097
suv = 0.00512
using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00
lo/lou,min = lb/lb,min = 0.30
suv = 0.4*esuv_nominal ((5.5), TBDY) = 0.032
From table 5A.1, TBDY: esuv_nominal = 0.08,
considering characteristic value fsyv = fsv/1.2, from table 5.1, TBDY
For calculation of esuv_nominal and yv, shv,ftv,fyv, it is considered
characteristic value fsyv = fsv/1.2, from table 5.1, TBDY.
y1, sh1,ft1,fy1, are also multiplied by Min(1,1.25*(lb/lb,min)^ 2/3), from 10.3.5, ASCE 41-17.
with fsv = fs = 350.1097
with Esv = Es = 200000.00
1 = Asl,ten/(b*d)*(fs1/fc) = 0.0635264
2 = Asl,com/(b*d)*(fs2/fc) = 0.0635264
v = Asl,mid/(b*d)*(fsv/fc) = 0.00
and confined core properties:
b = 2940.00
d = 178.00
d' = 12.00
fcc (5A.2, TBDY) = 25.06158
cc (5A.5, TBDY) = 0.00202463
c = confinement factor = 1.00246
1 = Asl,ten/(b*d)*(fs1/fc) = 0.07574806
2 = Asl,com/(b*d)*(fs2/fc) = 0.07574806
v = Asl,mid/(b*d)*(fsv/fc) = 0.00
Case/Assumption: Unconfined full section - Steel rupture
' satisfies Eq. (4.3)
--->
v < vs,y2 - LHS eq.(4.5) is satisfied
--->
su (4.9) = 0.18779572
Mu = MRc (4.14) = 2.0658E+008
u = su (4.1) = 3.0306889E-005

```

Calculation of ratio l_b/l_d

Inadequate Lap Length with $l_b/l_d = 0.30$

Calculation of μ_2 -

Calculation of ultimate curvature μ according to 4.1, Biskinis/Fardis 2013:

$\mu = 3.0889637E-005$

$\mu_2 = 2.4003E+008$

with full section properties:

$b = 3000.00$

$d = 208.00$

$d' = 42.00$

$v = 0.00176852$

$N = 27588.841$

$f_c = 25.00$

α (5A.5, TBDY) = 0.002

Final value of μ : $\mu^* = \text{shear_factor} * \text{Max}(\mu, \alpha) = 0.0035$

The Shear_factor is considered equal to 1 (pure moment strength)

From (5.4b), TBDY: $\mu = 0.0035$

μ_e ((5.4c), TBDY) = $\alpha * \text{sh}_{\min} * f_{ywe}/f_{ce} + \text{Min}(f_x, f_y) = 0.00$

where $f = \alpha * \rho_f * f_{fe}/f_{ce}$ is accounting for FRP contribution like EC8-part3 A.4.4.3(6)

$f_x = 0.00$

$\alpha_f = 0.00$

$b = 250.00$

$h = 3000.00$

From EC8 A.4.4.3(6), $\rho_f = 2t_f/bw = 0.008128$

$bw = 250.00$

effective stress from (A.35), $f_{fe} = 757.2164$

$f_y = 0.00$

$\alpha_f = 0.00$

$b = 3000.00$

$h = 250.00$

From EC8 A.4.4.3(6), $\rho_f = 2t_f/bw = 0.00067733$

$bw = 3000.00$

effective stress from (A.35), $f_{fe} = 954.4864$

$R = 40.00$

Effective FRP thickness, $t_f = NL * t * \cos(\theta_1) = 1.016$

$f_{u,f} = 1055.00$

$E_f = 64828.00$

$\mu_{f,f} = 0.015$

α_{se} ((5.4d), TBDY) = $(\alpha_{se1} * A_{col1} + \alpha_{se2} * A_{col2} + \alpha_{se3} * A_{web}) / A_{sec} = 0.00$

$\alpha_{se1} = 0.00$

$sh_1 = 150.00$

$bo_1 = 190.00$

$ho_1 = 540.00$

$bi2_1 = 655400.00$

$\alpha_{se2} = 0.00$

$sh_2 = 150.00$

$bo_2 = 190.00$

$ho_2 = 540.00$

$bi2_2 = 655400.00$

$\alpha_{se3} = 0$ (grid does not provide confinement)

$\rho_{sh,\min} = \text{Min}(\rho_{sh,x}, \rho_{sh,y}) = 0.00069813$

Expression ((5.4d), TBDY) for $\rho_{sh,\min}$ has been multiplied by 0.3 according to 15.7.1.3 for members without earthquake detailing (90° closed stirrups)

$\rho_{sh,x} = \rho_{s1,x} + \rho_{s2,x} + \rho_{s3,x} = 0.00356047$

$$ps1,x \text{ (column 1)} = (As1 \cdot h1 / s_1) / Ac = 0.00083776$$

$$h1 = 600.00$$

$$As1 = Astir1 \cdot ns1 = 157.0796$$

$$\text{No stirups, } ns1 = 2.00$$

$$ps2,x \text{ (column 2)} = (As2 \cdot h2 / s_2) / Ac = 0.00083776$$

$$h2 = 600.00$$

$$As2 = Astir2 \cdot ns2 = 157.0796$$

$$\text{No stirups, } ns2 = 2.00$$

$$ps3,x \text{ (web)} = (As3 \cdot h3 / s_3) / Ac = 0.00188496$$

$$h3 = 1800.00$$

$$As3 = Astir3 \cdot ns3 = 0.00$$

$$\text{No stirups, } ns3 = 2.00$$

$$psh,y = ps1,y + ps2,y + ps3,y = 0.00069813$$

$$ps1,y \text{ (column 1)} = (As1 \cdot h1 / s_1) / Ac = 0.00034907$$

$$h1 = 250.00$$

$$As1 = Astir1 \cdot ns1 = 157.0796$$

$$\text{No stirups, } ns1 = 2.00$$

$$ps2,y \text{ (column 2)} = (As2 \cdot h2 / s_2) / Ac = 0.00034907$$

$$h2 = 250.00$$

$$As2 = Astir2 \cdot ns2 = 157.0796$$

$$\text{No stirups, } ns2 = 2.00$$

$$ps3,y \text{ (web)} = (As3 \cdot h3 / s_3) / Ac = 0.00$$

$$h3 = 250.00$$

$$As3 = Astir3 \cdot ns3 = 157.0796$$

$$\text{No stirups, } ns3 = 0.00$$

$$Asec = 750000.00$$

$$s_1 = 150.00$$

$$s_2 = 150.00$$

$$s_3 = 200.00$$

$$fywe = 625.00$$

$$fce = 25.00$$

$$\text{From } ((5.A5), \text{ TBDY}), \text{ TBDY: } cc = 0.00202463$$

$$c = \text{confinement factor} = 1.00246$$

$$y1 = 0.00140044$$

$$sh1 = 0.0044814$$

$$ft1 = 420.1317$$

$$fy1 = 350.1097$$

$$su1 = 0.00512$$

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00

$$lo/lo,min = lb/ld = 0.30$$

$$su1 = 0.4 \cdot esu1_nominal ((5.5), \text{ TBDY}) = 0.032$$

$$\text{From table 5A.1, TBDY: } esu1_nominal = 0.08,$$

For calculation of esu1_nominal and y1, sh1, ft1, fy1, it is considered
characteristic value fsy1 = fs1/1.2, from table 5.1, TBDY.

$$y1, sh1, ft1, fy1, \text{ are also multiplied by } \text{Min}(1, 1.25 \cdot (lb/ld)^{2/3}), \text{ from 10.3.5, ASCE 41-17.}$$

$$\text{with } fs1 = fs = 350.1097$$

$$\text{with } Es1 = Es = 200000.00$$

$$y2 = 0.00140044$$

$$sh2 = 0.0044814$$

$$ft2 = 420.1317$$

$$fy2 = 350.1097$$

$$su2 = 0.00512$$

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00

$$lo/lo,min = lb/lb,min = 0.30$$

$$su2 = 0.4 \cdot esu2_nominal ((5.5), \text{ TBDY}) = 0.032$$

$$\text{From table 5A.1, TBDY: } esu2_nominal = 0.08,$$

For calculation of esu2_nominal and y2, sh2, ft2, fy2, it is considered
characteristic value fsy2 = fs2/1.2, from table 5.1, TBDY.

$$y1, sh1, ft1, fy1, \text{ are also multiplied by } \text{Min}(1, 1.25 \cdot (lb/ld)^{2/3}), \text{ from 10.3.5, ASCE 41-17.}$$

$$\text{with } fs2 = fs = 350.1097$$

$$\text{with } Es2 = Es = 200000.00$$

```

yv = 0.00140044
shv = 0.0044814
ftv = 420.1317
fyv = 350.1097
suv = 0.00512
using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00
lo/lou,min = lb/ld = 0.30
suv = 0.4*esuv_nominal ((5.5), TBDY) = 0.032
From table 5A.1, TBDY: esuv_nominal = 0.08,
considering characteristic value fsyv = fsv/1.2, from table 5.1, TBDY
For calculation of esuv_nominal and yv, shv,ftv,fyv, it is considered
characteristic value fsyv = fsv/1.2, from table 5.1, TBDY.
y1, sh1,ft1,fy1, are also multiplied by Min(1,1.25*(lb/ld)^ 2/3), from 10.3.5, ASCE 41-17.
with fsv = fs = 350.1097
with Esv = Es = 200000.00
1 = Asl,ten/(b*d)*(fs1/fc) = 0.0635264
2 = Asl,com/(b*d)*(fs2/fc) = 0.0635264
v = Asl,mid/(b*d)*(fsv/fc) = 0.03609935
and confined core properties:
b = 2940.00
d = 178.00
d' = 12.00
fcc (5A.2, TBDY) = 25.06158
cc (5A.5, TBDY) = 0.00202463
c = confinement factor = 1.00246
1 = Asl,ten/(b*d)*(fs1/fc) = 0.07574806
2 = Asl,com/(b*d)*(fs2/fc) = 0.07574806
v = Asl,mid/(b*d)*(fsv/fc) = 0.0430444
Case/Assumption: Unconfined full section - Steel rupture
' satisfies Eq. (4.3)
--->
v < vs,y2 - LHS eq.(4.5) is satisfied
--->
su (4.9) = 0.20311835
Mu = MRc (4.14) = 2.4003E+008
u = su (4.1) = 3.0889637E-005

```

Calculation of ratio lb/ld

Inadequate Lap Length with lb/ld = 0.30

Calculation of Shear Strength $V_r = \text{Min}(V_{r1}, V_{r2}) = 1.0244\text{E}+006$

Calculation of Shear Strength at edge 1, $V_{r1} = 1.0244\text{E}+006$
From (22.5.1.1) and 11.5.4.3, ACI 318-14: $V_{r1} = V_n < 0.83*fc'^{0.5}*h*d$

NOTE: In expression (22.5.1.1) 'Vw' is replaced by 'Vw+ f*Vf'
where Vf is the contribution of FRPs (11.3), ACI 440).

From Table (11.5.4.6(d-e)), ACI 318-14: $V_c = 815517.768$
 $Mu/V_u - l_w/2 = 0.00 \leq 0$
= 1 (normal-weight concrete)
 $fc' = 25.00$, but $fc'^{0.5} \leq 8.3 \text{ MPa}$ (22.5.3.1, ACI 318-14)
 $h = 3000.00$
 $d = 200.00$
 $l_w = 250.00$
 $Mu = 3.7289358\text{E}+011$
 $V_u = 1.7354940\text{E}+029$
 $Nu = 27588.841$
From (11.5.4.8), ACI 318-14: $V_s = V_{s1} + V_{s2} + V_{s3} = 104719.755$
 $V_{s1} = 52359.878$ is calculated for pseudo-Column 1, with:

$d = 200.00$
 $A_v = 157079.633$
 $s = 150.00$
 $f_y = 500.00$
 V_{s1} has been multiplied by $2(1-s/d)$ ($s > d/2$, according to ASCE 41-17,10.3.4)
 $2(1-s/d) = 0.50$
 $V_{s2} = 52359.878$ is calculated for pseudo-Column 2, with:
 $d = 200.00$
 $A_v = 157079.633$
 $s = 150.00$
 $f_y = 500.00$
 V_{s2} has been multiplied by $2(1-s/d)$ ($s > d/2$, according to ASCE 41-17,10.3.4)
 $2(1-s/d) = 0.50$
 $V_{s3} = 0.00$ is calculated for web, with:
 $d = 200.00$
 $A_v = 0.00$
 $s = 200.00$
 $f_y = 500.00$
 V_{s3} has been multiplied by $2(1-s/d)$ ($s > d/2$, according to ASCE 41-17,10.3.4)
 $2(1-s/d) = 0.00$
 $V_f ((11-3)-(11.4), \text{ACI 440}) = 109599.773$
 $f = 0.95$, for fully-wrapped sections
 $w_f/s_f = 1$ (FRP strips adjacent to one another).
In (11.3) $\sin + \cos$ is replaced with $(\cot + \cot a) \sin a$ which is more a generalised expression,
where a is the angle of the crack direction (see KANEPE).
This later relation, considered as a function $V_f(,)$, is implemented for every different fiber orientation a_i ,
as well as for 2 crack directions, $a_i = 45^\circ$ and $a_i = -45^\circ$ to take into consideration the cyclic seismic loading.
orientation 1: $a_i = b1 + 90^\circ = 90.00$
 $V_f = \text{Min}(|V_f(45, 1)|, |V_f(-45, a1)|)$, with:
total thickness per orientation, $t_{f1} = N_L * t / N_{oDir} = 1.016$
 $d_{fv} = d$ (figure 11.2, ACI 440) = 208.00
 $f_{fe} ((11-5), \text{ACI 440}) = 259.312$
 $E_f = 64828.00$
 $f_e = 0.004$, from (11.6a), ACI 440
with $f_u = 0.01$
From (11-11), ACI 440: $V_s + V_f \leq 1.9929E+006$
 $b_w = 3000.00$

Calculation of Shear Strength at edge 2, $V_{r2} = 1.0244E+006$
From (22.5.1.1) and 11.5.4.3, ACI 318-14: $V_{r2} = V_n < 0.83 * f_c' ^{0.5} * h * d$

NOTE: In expression (22.5.1.1) ' V_w ' is replaced by ' $V_w + f * V_f$ '
where V_f is the contribution of FRPs (11.3), ACI 440).

From Table (11.5.4.6(d-e)), ACI 318-14: $V_c = 815517.768$
 $\mu_u / \mu_u - l_w / 2 = 0.00 \leq 0$
 $= 1$ (normal-weight concrete)
 $f_c' = 25.00$, but $f_c' ^{0.5} \leq 8.3$ MPa (22.5.3.1, ACI 318-14)
 $h = 3000.00$
 $d = 200.00$
 $l_w = 250.00$
 $\mu_u = 3.7289358E-011$
 $V_u = 1.7354940E-029$
 $N_u = 27588.841$
From (11.5.4.8), ACI 318-14: $V_s = V_{s1} + V_{s2} + V_{s3} = 104719.755$
 $V_{s1} = 52359.878$ is calculated for pseudo-Column 1, with:
 $d = 200.00$
 $A_v = 157079.633$
 $s = 150.00$
 $f_y = 500.00$
 V_{s1} has been multiplied by $2(1-s/d)$ ($s > d/2$, according to ASCE 41-17,10.3.4)
 $2(1-s/d) = 0.50$
 $V_{s2} = 52359.878$ is calculated for pseudo-Column 2, with:
 $d = 200.00$
 $A_v = 157079.633$
 $s = 150.00$
 $f_y = 500.00$

Vs2 has been multiplied by $2(1-s/d)$ ($s > d/2$, according to ASCE 41-17,10.3.4)

$$2(1-s/d) = 0.50$$

Vs3 = 0.00 is calculated for web, with:

$$d = 200.00$$

$$A_v = 0.00$$

$$s = 200.00$$

$$f_y = 500.00$$

Vs3 has been multiplied by $2(1-s/d)$ ($s > d/2$, according to ASCE 41-17,10.3.4)

$$2(1-s/d) = 0.00$$

$$V_f((11-3)-(11.4), \text{ACI 440}) = 109599.773$$

$$f = 0.95, \text{ for fully-wrapped sections}$$

$$w_f/s_f = 1 \text{ (FRP strips adjacent to one another).}$$

In (11.3) $\sin + \cos$ is replaced with $(\cot + \cot a)\sin a$ which is more a generalised expression,

where a is the angle of the crack direction (see KANEPE).

This later relation, considered as a function $V_f(\theta)$, is implemented for every different fiber orientation a_i , as well as for 2 crack directions, $\theta = 45^\circ$ and $\theta = -45^\circ$ to take into consideration the cyclic seismic loading.

$$\text{orientation 1: } \theta_1 = b_1 + 90^\circ = 90.00$$

$$V_f = \text{Min}(|V_f(45, \theta_1)|, |V_f(-45, a_1)|), \text{ with:}$$

$$\text{total thickness per orientation, } t_{f1} = N_L * t / N_{\text{Dir}} = 1.016$$

$$d_{fv} = d \text{ (figure 11.2, ACI 440)} = 208.00$$

$$f_{fe}((11-5), \text{ACI 440}) = 259.312$$

$$E_f = 64828.00$$

$$f_e = 0.004, \text{ from (11.6a), ACI 440}$$

$$\text{with } f_u = 0.01$$

$$\text{From (11-11), ACI 440: } V_s + V_f \leq 1.9929E+006$$

$$b_w = 3000.00$$

End Of Calculation of Shear Capacity ratio for element: wall W1 of floor 1

At local axis: 2

Start Of Calculation of Chord Rotation Capacity for element: wall W1 of floor 1

At local axis: 3

Integration Section: (a)

Section Type: rcrws

Constant Properties

Knowledge Factor, $\gamma = 1.00$

According to 10.7.2.3, ASCE 41-17, shear walls with

transverse reinforcement percentage, $\rho_n < 0.0015$

are considered Force-Controlled and lower-bound strengths are used according to 7.5.1.3, ASCE 41-17

$$\rho_n = 0.00069813$$

with $\rho_n = \rho_{s1} + \rho_{s2} + \rho_{s3}$, being the shear reinf. ratio in a plane perpendicular to the shear axis 2

$$\text{(pseudo-col.1 } \rho_{s1} = A_{s1} * b_1 / s_1 = (A_{s1} * h_1 / s_1) / A_c = 0.00034907$$

$$h_1 = 250.00$$

$$s_1 = 150.00$$

$$\text{total area of hoops perpendicular to shear axis, } A_{s1} = 157.0796$$

$$\text{(pseudo-col.2 } \rho_{s2} = A_{s2} * b_2 / s_2 = (A_{s2} * h_2 / s_2) / A_c = 0.00034907$$

$$h_2 = 250.00$$

$$s_2 = 150.00$$

$$\text{total area of hoops perpendicular to shear axis, } A_{s2} = 157.0796$$

$$\text{(grid } \rho_{s3} = A_{s3} * b_3 / s_3 = (A_{s3} * h_3 / s_3) / A_c = 0.00$$

$$h_3 = 250.00$$

$$s_3 = 200.00$$

$$\text{total area of hoops perpendicular to shear axis, } A_{s3} = 0.00$$

$$\text{total section area, } A_c = 750000.00$$

Consequently:

New material of Secondary Member: Concrete Strength, $f_c = f_{c_lower_bound} = 25.00$

New material of Secondary Member: Steel Strength, $f_s = f_{s_lower_bound} = 500.00$

Concrete Elasticity, $E_c = 26999.444$

Steel Elasticity, $E_s = 200000.00$

Total Height, $H_{tot} = 3000.00$

Edges Width, Wedg = 250.00
Edges Height, Hedg = 600.00
Web Width, Wweb = 250.00
Cover Thickness, c = 25.00
Element Length, L = 3000.00
Secondary Member
Smooth Bars
Ductile Steel
Without Detailing for Earthquake Resistance (including stirrups not closed at 135°)
Longitudinal Bars With Ends Lapped Starting at the End Sections
Inadequate Lap Length with $l_b/l_d = 0.30$
FRP Wrapping Data
Type: Carbon
Cured laminate properties (design values)
Thickness, t = 1.016
Tensile Strength, $f_{fu} = 1055.00$
Tensile Modulus, $E_f = 64828.00$
Elongation, $\epsilon_{fu} = 0.01$
Number of directions, NoDir = 1
Fiber orientations, $b_i: 0.00^\circ$
Number of layers, NL = 1
Radius of rounding corners, R = 40.00

Stepwise Properties

Bending Moment, M = -1.6039204E-011
Shear Force, V2 = -1.2948432E-014
Shear Force, V3 = -20889.844
Axial Force, F = -31026.87
Longitudinal Reinforcement Area Distribution (in 2 divisions)
-Tension: $A_{slt} = 0.00$
-Compression: $A_{slc} = 7269.645$
Longitudinal Reinforcement Area Distribution (in 3 divisions)
-Tension: $A_{sl,ten} = 2830.575$
-Compression: $A_{sl,com} = 2830.575$
-Middle: $A_{sl,mid} = 1608.495$
Mean Diameter of Tension Reinforcement, DbL = 16.46154

New component: From table 7-7, ASCE 41_17: Final chord rotation Capacity $u_R = 1.0^* u = 0.00918702$
 $u = y + p = 0.00918702$

- Calculation of y -

$y = (M_y * I_p) / (E I)_{Eff} = 0.00118702 ((10^{-5}), \text{ASCE 41-17})$
 $M_y = 1.8257E+008$
 $(E I)_{Eff} = 0.35 * E_c * I$ (table 10-5)
 $E_c * I = 1.0547E+014$
 $I_p = 0.5 * d = 0.5 * (0.8 * h) = 240.00$

Calculation of Yielding Moment M_y

Calculation of y and M_y according to Annex 7 -

$y = \text{Min}(y_{ten}, y_{com})$
 $y_{ten} = 8.9780154E-006$
with $((10^{-1}), \text{ASCE 41-17}) f_y = \text{Min}(f_y, 1.25 * f_y * (l_b/l_d)^{2/3}) = 280.0878$
d = 208.00
 $y = 0.25007038$
A = 0.0118276
B = 0.00717877

with $p_t = 0.00453618$
 $p_c = 0.00453618$
 $p_v = 0.00257772$
 $N = 31026.87$
 $b = 3000.00$
 $" = 0.20192308$
 $y_{comp} = 3.2320012E-005$
 with $f_c^* (12.3, (ACI 440)) = 25.002$
 $f_c = 25.00$
 $f_l = 0.17503396$
 $b = 3000.00$
 $h = 250.00$
 $A_g = 750000.00$
 From (12.9), ACI 440: $k_a = 0.0036426$
 $g = p_t + p_c + p_v = 0.01165007$
 $r_c = 40.00$
 $A_e/A_c = 0.52453487$
 Effective FRP thickness, $t_f = NL * t * \cos(b_1) = 1.016$
 effective strain from (12.5) and (12.12), $\epsilon_{fe} = 0.004$
 $f_u = 0.01$
 $E_f = 64828.00$
 $E_c = 26999.444$
 $y = 0.24794626$
 $A = 0.01150092$
 $B = 0.00700125$
 with $E_s = 200000.00$

Calculation of ratio I_b/I_d

Inadequate Lap Length with $I_b/I_d = 0.30$

- Calculation of p -

Considering wall controlled by flexure (shear control ratio ≤ 1),
 from table 10-19: $p = 0.008$

with:

- Condition i (shear wall and wall segments)

- $(A_s - A_s') * f_y + P / (t_w * I_w * f_c') = -0.19220244$

$A_s = 0.00$

$A_s' = 7269.645$

$f_y = 500.00$

$P = 31026.87$

$t_w = 3000.00$

$I_w = 250.00$

$f_c = 25.00$

- $V / (t_w * I_w * f_c^{0.5}) = 4.1582360E-020$, NOTE: units in lb & in

- Confined Boundary: No

Boundary hoops spacing exceed $8d_b$ ($s_1 > 8 * d_b$ or $s_2 > 8 * d_b$)

Boundary Trans. Reinf. does not exceed 50% of ACI 318 provision ($V_{w1} + V_{w2} > 0.50 * (V - V_c - V_{w3})$)

With

Boundary Element 1:

$V_{w1} = 104719.755$

$s_1 = 150.00$

Boundary Element 2:

$V_{w2} = 104719.755$

$s_2 = 150.00$

Grid Shear Force, $V_{w3} = 0.00$

Concrete Shear Force, $V_c = 218457.549$

(The variables above have already been given in Shear control ratio calculation)

Mean diameter of all bars, $d_b = 17.33333$

Design Shear Force, $V = 1.2948432E-014$

End Of Calculation of Chord Rotation Capacity for element: wall W1 of floor 1

At local axis: 3
Integration Section: (a)

Calculation No. 13

wall W1, Floor 1
Limit State: Life Safety (data interpolation between analysis steps 1 and 2)
Analysis: Uniform +X
Check: Shear capacity V_{Rd}
Edge: End
Local Axis: (2)



Start Of Calculation of Shear Capacity for element: wall W1 of floor 1

At local axis: 2
Integration Section: (d)
Section Type: rcwvs

Constant Properties

Knowledge Factor, $\gamma = 1.00$
Member Shear Force is generally considered as Force-Controlled Action according to Table C7-1, ASCE 41-17.
Lower-bound strengths are used for Force-Controlled Actions according to 7.5.1.3, ASCE 41-17
Consequently:
New material of Secondary Member: Concrete Strength, $f_c = f_{c_lower_bound} = 25.00$
New material of Secondary Member: Steel Strength, $f_s = f_{s_lower_bound} = 500.00$
Concrete Elasticity, $E_c = 26999.444$
Steel Elasticity, $E_s = 200000.00$
Total Height, $H_{tot} = 3000.00$
Edges Width, $W_{edg} = 250.00$
Edges Height, $H_{edg} = 600.00$
Web Width, $W_{web} = 250.00$
Cover Thickness, $c = 25.00$
Element Length, $L = 3000.00$
Secondary Member

Smooth Bars
 Ductile Steel
 Without Detailing for Earthquake Resistance (including stirrups not closed at 135°)
 Longitudinal Bars With Ends Lapped Starting at the End Sections
 Inadequate Lap Length with $l_o/l_{ou,min} = l_b/l_d = 0.30$
 FRP Wrapping Data
 Type: Carbon
 Cured laminate properties (design values)
 Thickness, $t = 1.016$
 Tensile Strength, $f_{fu} = 1055.00$
 Tensile Modulus, $E_f = 64828.00$
 Elongation, $\epsilon_{fu} = 0.01$
 Number of directions, $N_{oDir} = 1$
 Fiber orientations, $b_i: 0.00^\circ$
 Number of layers, $N_L = 1$
 Radius of rounding corners, $R = 40.00$

Stepwise Properties

EDGE -A-
 Bending Moment, $M_a = -1.6039204E-011$
 Shear Force, $V_a = -1.2948432E-014$
 EDGE -B-
 Bending Moment, $M_b = -2.4510145E-011$
 Shear Force, $V_b = 1.2948432E-014$
 BOTH EDGES
 Axial Force, $F = -31026.87$
 Longitudinal Reinforcement Area Distribution (in 2 divisions)
 -Tension: $A_{sl,t} = 0.00$
 -Compression: $A_{sl,c} = 7269.645$
 Longitudinal Reinforcement Area Distribution (in 3 divisions)
 -Tension: $A_{sl,ten} = 2830.575$
 -Compression: $A_{sl,com} = 2830.575$
 -Middle: $A_{sl,mid} = 1608.495$
 Mean Diameter of Tension Reinforcement, $Db_{L,ten} = 16.46154$

New component: From table 7-7, ASCE 41_17: Final Shear Capacity $V_R = 1.0 \cdot V_n = 401964.647$
 From (22.5.1.1) and 11.5.4.3, ACI 318-14: $V_n < 0.83 \cdot f_c'^{0.5} \cdot h \cdot d = 401964.647$

NOTE: In expression (22.5.1.1) ' V_w ' is replaced by ' $V_{w+} + f \cdot V_f$ '
 where V_f is the contribution of FRPs (11.3), ACI 440).

From Table (11.5.4.6(d-e)), ACI 318-14: $V_c = 193125.108$
 $\mu_u/V_u - l_w/2 = 1767.905 > 0$
 = 1 (normal-weight concrete)
 $f_c' = 25.00$, but $f_c'^{0.5} \leq 8.3$ MPa (22.5.3.1, ACI 318-14)
 $h = 3000.00$
 $d = 200.00$
 $l_w = 250.00$
 $\mu_u = 2.4510145E-011$
 $V_u = 1.2948432E-014$
 $N_u = 31026.87$
 From (11.5.4.8), ACI 318-14: $V_s = V_{s1} + V_{s2} + V_{s3} = 104719.755$
 $V_{s1} = 52359.878$ is calculated for pseudo-Column 1, with:
 $d = 200.00$
 $A_v = 157079.633$
 $s = 150.00$
 $f_y = 500.00$
 V_{s1} has been multiplied by $2(1-s/d)$ ($s > d/2$, according to ASCE 41-17,10.3.4)
 $2(1-s/d) = 0.50$
 $V_{s2} = 52359.878$ is calculated for pseudo-Column 2, with:
 $d = 200.00$
 $A_v = 157079.633$

$s = 150.00$
 $f_y = 500.00$
 V_{s2} has been multiplied by $2(1-s/d)$ ($s > d/2$, according to ASCE 41-17,10.3.4)
 $2(1-s/d) = 0.50$
 $V_{s3} = 0.00$ is calculated for web, with:
 $d = 200.00$
 $A_v = 0.00$
 $s = 200.00$
 $f_y = 500.00$
 V_{s3} has been multiplied by $2(1-s/d)$ ($s > d/2$, according to ASCE 41-17,10.3.4)
 $2(1-s/d) = 0.00$
 $V_f ((11-3)-(11.4), \text{ACI 440}) = 109599.773$
 $f = 0.95$, for fully-wrapped sections
 $w_f/s_f = 1$ (FRP strips adjacent to one another).
 $\ln (11.3) \sin + \cos$ is replaced with $(\cot + \cot a) \sin a$ which is more a generalised expression,
 where a is the angle of the crack direction (see KANEPE).
 This later relation, considered as a function $V_f(\theta, a)$, is implemented for every different fiber orientation a_i ,
 as well as for 2 crack directions, $\theta = 45^\circ$ and $\theta = -45^\circ$ to take into consideration the cyclic seismic loading.
 orientation 1: $\theta = b1 + 90^\circ = 90.00$
 $V_f = \text{Min}(|V_f(45, \theta)|, |V_f(-45, a1)|)$, with:
 total thickness per orientation, $t_{f1} = NL \cdot t / \text{NoDir} = 1.016$
 $d_{fv} = d$ (figure 11.2, ACI 440) = 208.00
 $f_{fe} ((11-5), \text{ACI 440}) = 259.312$
 $E_f = 64828.00$
 $f_e = 0.004$, from (11.6a), ACI 440
 with $f_u = 0.01$
 From (11-11), ACI 440: $V_s + V_f \leq 1.9929E+006$
 $b_w = 3000.00$

 End Of Calculation of Shear Capacity for element: wall W1 of floor 1
 At local axis: 2
 Integration Section: (d)

Calculation No. 14

wall W1, Floor 1
 Limit State: Life Safety (data interpolation between analysis steps 1 and 2)
 Analysis: Uniform +X
 Check: Chord rotation capacity (θ_u)
 Edge: End
 Local Axis: (2)



Start Of Calculation of Shear Capacity ratio for element: wall W1 of floor 1

At Shear local axis: 3

(Bending local axis: 2)

Section Type: rcwrs

Constant Properties

Knowledge Factor, $\gamma = 1.00$

Mean strength values are used for both shear and moment calculations.

Consequently:

New material of Secondary Member: Concrete Strength, $f_c = f_{cm} = 25.00$

New material of Secondary Member: Steel Strength, $f_s = f_{sm} = 500.00$

Concrete Elasticity, $E_c = 26999.444$

Steel Elasticity, $E_s = 200000.00$

#####

Note: Especially for the calculation of moment strengths,

the above steel re-bar strengths are multiplied by 1.25 according to R18.6.5, ACI 318-14

New material: Steel Strength, $f_s = 1.25 \cdot f_{sm} = 625.00$

#####

Total Height, $H_{tot} = 3000.00$

Edges Width, $W_{edg} = 250.00$

Edges Height, $H_{edg} = 600.00$

Web Width, $W_{web} = 250.00$

Cover Thickness, $c = 25.00$

Mean Confinement Factor overall section = 1.00246

Element Length, $L = 3000.00$

Secondary Member

Smooth Bars

Ductile Steel

Without Detailing for Earthquake Resistance (including stirrups not closed at 135°)

Longitudinal Bars With Ends Lapped Starting at the End Sections

Inadequate Lap Length with $l_o/l_{o,min} = 0.30$

FRP Wrapping Data

Type: Carbon

Cured laminate properties (design values)

Thickness, $t = 1.016$

Tensile Strength, $f_{fu} = 1055.00$

Tensile Modulus, $E_f = 64828.00$

Elongation, $\epsilon_{fu} = 0.01$

Number of directions, $NoDir = 1$

Fiber orientations, $b_i: 0.00^\circ$

Number of layers, $NL = 1$

Radius of rounding corners, $R = 40.00$

Stepwise Properties

At local axis: 3

EDGE -A-

Shear Force, $V_a = 1.0097420E-028$

EDGE -B-

Shear Force, $V_b = -1.0097420E-028$

BOTH EDGES

Axial Force, $F = -27588.841$

Longitudinal Reinforcement Area Distribution (in 2 divisions)

-Tension: $As_t = 0.00$

-Compression: $As_c = 7269.645$

Longitudinal Reinforcement Area Distribution (in 3 divisions)

-Tension: $As_{t,ten} = 2865.133$

-Compression: $As_{c,com} = 2865.133$

-Middle: $As_{mid} = 0.00$

(According to 10.7.2.3 As_{mid} is setted equal to zero)

Calculation of Shear Capacity ratio, $V_e/V_r = 1.02813$

Member Controlled by Shear ($V_e/V_r > 1$)

Calculation of Shear Demand from fig. R18.6.5, ACI 318-14 $V_e = (M_{pr1} + M_{pr2})/l_n = 2.5600E+006$ with

$M_{pr1} = \text{Max}(Mu_{1+}, Mu_{1-}) = 3.8401E+009$

$Mu_{1+} = 3.3585E+009$, is the ultimate moment strength at the edge 1 of the member in the actual moment direction which is defined for the static loading combination

$Mu_{1-} = 3.8401E+009$, is the ultimate moment strength at the edge 1 of the member in the opposite moment direction which is defined for the static loading combination

$M_{pr2} = \text{Max}(Mu_{2+}, Mu_{2-}) = 3.8401E+009$

$Mu_{2+} = 3.3585E+009$, is the ultimate moment strength at the edge 2 of the member in the actual moment direction which is defined for the static loading combination

$Mu_{2-} = 3.8401E+009$, is the ultimate moment strength at the edge 2 of the member in the opposite moment direction which is defined for the static loading combination

Calculation of Mu_{1+}

Calculation of ultimate curvature ϕ_u according to 4.1, Biskinis/Fardis 2013:

$\phi_u = 2.0296703E-006$

$M_u = 3.3585E+009$

with full section properties:

$b = 250.00$

$d = 2957.00$

$d' = 43.00$

$v = 0.0014928$

$N = 27588.841$

$f_c = 25.00$

ϕ_c (5A.5, TBDY) = 0.002

Final value of ϕ_u : $\phi_u^* = \text{shear_factor} * \text{Max}(\phi_u, \phi_c) = 0.0035$

The Shear_factor is considered equal to 1 (pure moment strength)

From (5.4b), TBDY: $\phi_u = 0.0035$

ϕ_{we} ((5.4c), TBDY) = $a s_e * \phi_{sh,min} * f_{ywe} / f_{ce} + \text{Min}(\phi_x, \phi_y) = 0.00$

where $\phi_f = a f * \phi_f * f_{fe} / f_{ce}$ is accounting for FRP contribution like EC8-part3 A.4.4.3(6)

$\phi_x = 0.00$

$a f = 0.00$

$b = 250.00$

$h = 3000.00$

From EC8 A.4.4.3(6), $\phi_f = 2 t_f / b_w = 0.008128$

$b_w = 250.00$

effective stress from (A.35), $f_{fe} = 757.2164$

$\phi_y = 0.00$

$a f = 0.00$

$b = 3000.00$

$h = 250.00$

From EC8 A.4.4.3(6), $\phi_f = 2 t_f / b_w = 0.00067733$

$b_w = 3000.00$

effective stress from (A.35), $f_{fe} = 954.4864$

$R = 40.00$
 Effective FRP thickness, $t_f = NL \cdot t \cdot \cos(b_1) = 1.016$
 $f_{u,f} = 1055.00$
 $E_f = 64828.00$
 $u_f = 0.015$
 $ase((5.4d), TBDY) = (ase_1 \cdot A_{col1} + ase_2 \cdot A_{col2} + ase_3 \cdot A_{web}) / A_{sec} = 0.00$
 $ase_1 = 0.00$
 $sh_1 = 150.00$
 $bo_1 = 190.00$
 $ho_1 = 540.00$
 $bi2_1 = 655400.00$
 $ase_2 = 0.00$
 $sh_2 = 150.00$
 $bo_2 = 190.00$
 $ho_2 = 540.00$
 $bi2_2 = 655400.00$
 $ase_3 = 0$ (grid does not provide confinement)
 $psh,min = \min(psh,x, psh,y) = 0.00069813$

Expression ((5.4d), TBDY) for psh,min has been multiplied by 0.3 according to 15.7.1.3 for members without earthquake detailing (90° closed stirrups)

$psh,x = ps1,x + ps2,x + ps3,x = 0.00356047$
 $ps1,x$ (column 1) = $(As1 \cdot h1 / s_1) / A_c = 0.00083776$
 $h1 = 600.00$
 $As1 = Astir1 \cdot ns1 = 157.0796$
 No stirrups, $ns1 = 2.00$
 $ps2,x$ (column 2) = $(As2 \cdot h2 / s_2) / A_c = 0.00083776$
 $h2 = 600.00$
 $As2 = Astir2 \cdot ns2 = 157.0796$
 No stirrups, $ns2 = 2.00$
 $ps3,x$ (web) = $(As3 \cdot h3 / s_3) / A_c = 0.00188496$
 $h3 = 1800.00$
 $As3 = Astir3 \cdot ns3 = 0.00$
 No stirrups, $ns3 = 2.00$

$psh,y = ps1,y + ps2,y + ps3,y = 0.00069813$
 $ps1,y$ (column 1) = $(As1 \cdot h1 / s_1) / A_c = 0.00034907$
 $h1 = 250.00$
 $As1 = Astir1 \cdot ns1 = 157.0796$
 No stirrups, $ns1 = 2.00$
 $ps2,y$ (column 2) = $(As2 \cdot h2 / s_2) / A_c = 0.00034907$
 $h2 = 250.00$
 $As2 = Astir2 \cdot ns2 = 157.0796$
 No stirrups, $ns2 = 2.00$
 $ps3,y$ (web) = $(As3 \cdot h3 / s_3) / A_c = 0.00$
 $h3 = 250.00$
 $As3 = Astir3 \cdot ns3 = 157.0796$
 No stirrups, $ns3 = 0.00$

$A_{sec} = 750000.00$
 $s_1 = 150.00$
 $s_2 = 150.00$
 $s_3 = 200.00$
 $f_{ywe} = 625.00$
 $f_{ce} = 25.00$

From ((5.A5), TBDY), TBDY: $cc = 0.00202463$
 c = confinement factor = 1.00246

$y1 = 0.00140044$
 $sh1 = 0.0044814$
 $ft1 = 420.1317$
 $fy1 = 350.1097$
 $su1 = 0.00512$

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
 and also multiplied by the shear_factor according to 15.7.1.4, with
 $Shear_factor = 1.00$
 $lo/lo,min = lb/ld = 0.30$

```

su1 = 0.4*esu1_nominal ((5.5), TBDY) = 0.032
From table 5A.1, TBDY: esu1_nominal = 0.08,
For calculation of esu1_nominal and y1, sh1,ft1,fy1, it is considered
characteristic value fsy1 = fs1/1.2, from table 5.1, TBDY.
y1, sh1,ft1,fy1, are also multiplied by Min(1,1.25*(lb/ld)^ 2/3), from 10.3.5, ASCE 41-17.
with fs1 = fs = 350.1097
with Es1 = Es = 200000.00
y2 = 0.00140044
sh2 = 0.0044814
ft2 = 420.1317
fy2 = 350.1097
su2 = 0.00512
using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00
lo/lou,min = lb/lb,min = 0.30
su2 = 0.4*esu2_nominal ((5.5), TBDY) = 0.032
From table 5A.1, TBDY: esu2_nominal = 0.08,
For calculation of esu2_nominal and y2, sh2,ft2,fy2, it is considered
characteristic value fsy2 = fs2/1.2, from table 5.1, TBDY.
y1, sh1,ft1,fy1, are also multiplied by Min(1,1.25*(lb/ld)^ 2/3), from 10.3.5, ASCE 41-17.
with fs2 = fs = 350.1097
with Es2 = Es = 200000.00
yv = 0.00140044
shv = 0.0044814
ftv = 420.1317
fyv = 350.1097
suv = 0.00512
using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00
lo/lou,min = lb/ld = 0.30
suv = 0.4*esuv_nominal ((5.5), TBDY) = 0.032
From table 5A.1, TBDY: esuv_nominal = 0.08,
considering characteristic value fsyv = fsv/1.2, from table 5.1, TBDY
For calculation of esuv_nominal and yv, shv,ftv,fyv, it is considered
characteristic value fsyv = fsv/1.2, from table 5.1, TBDY.
y1, sh1,ft1,fy1, are also multiplied by Min(1,1.25*(lb/ld)^ 2/3), from 10.3.5, ASCE 41-17.
with fsv = fs = 350.1097
with Esv = Es = 200000.00
1 = Asl,ten/(b*d)*(fs1/fc) = 0.05427722
2 = Asl,com/(b*d)*(fs2/fc) = 0.05427722
v = Asl,mid/(b*d)*(fsv/fc) = 0.00

```

and confined core properties:

```

b = 190.00
d = 2927.00
d' = 13.00
fcc (5A.2, TBDY) = 25.06158
cc (5A.5, TBDY) = 0.00202463
c = confinement factor = 1.00246
1 = Asl,ten/(b*d)*(fs1/fc) = 0.07214938
2 = Asl,com/(b*d)*(fs2/fc) = 0.07214938
v = Asl,mid/(b*d)*(fsv/fc) = 0.00

```

Case/Assumption: Unconfined full section - Steel rupture
 ' satisfies Eq. (4.3)

```

--->
v < vs,y2 - LHS eq.(4.5) is satisfied
--->
su (4.9) = 0.14691336
Mu = MRc (4.14) = 3.3585E+009
u = su (4.1) = 2.0296703E-006

```

Calculation of ratio lb/ld

Inadequate Lap Length with lb/ld = 0.30

Calculation of Mu1-

Calculation of ultimate curvature ϕ_u according to 4.1, Biskinis/Fardis 2013:

$$u = 2.0532423E-006$$

$$Mu = 3.8401E+009$$

with full section properties:

$$b = 250.00$$

$$d = 2957.00$$

$$d' = 43.00$$

$$v = 0.0014928$$

$$N = 27588.841$$

$$f_c = 25.00$$

$$c_o \text{ (5A.5, TBDY)} = 0.002$$

$$\text{Final value of } c_u: c_u^* = \text{shear_factor} * \text{Max}(c_u, c_o) = 0.0035$$

The Shear_factor is considered equal to 1 (pure moment strength)

$$\text{From (5.4b), TBDY: } c_u = 0.0035$$

$$w_e \text{ ((5.4c), TBDY)} = a_{se} * \text{sh}_{\min} * f_{ywe} / f_{ce} + \text{Min}(f_x, f_y) = 0.00$$

where $f = a_f * p_f * f_{fe} / f_{ce}$ is accounting for FRP contribution like EC8-part3 A.4.4.3(6)

$$f_x = 0.00$$

$$a_f = 0.00$$

$$b = 250.00$$

$$h = 3000.00$$

$$\text{From EC8 A.4.4.3(6), } p_f = 2t_f / b_w = 0.008128$$

$$b_w = 250.00$$

$$\text{effective stress from (A.35), } f_{fe} = 757.2164$$

$$f_y = 0.00$$

$$a_f = 0.00$$

$$b = 3000.00$$

$$h = 250.00$$

$$\text{From EC8 A.4.4.3(6), } p_f = 2t_f / b_w = 0.00067733$$

$$b_w = 3000.00$$

$$\text{effective stress from (A.35), } f_{fe} = 954.4864$$

$$R = 40.00$$

$$\text{Effective FRP thickness, } t_f = N L * t * \cos(b_1) = 1.016$$

$$f_{u,f} = 1055.00$$

$$E_f = 64828.00$$

$$u_{,f} = 0.015$$

$$a_{se} \text{ ((5.4d), TBDY)} = (a_{se1} * A_{col1} + a_{se2} * A_{col2} + a_{se3} * A_{web}) / A_{sec} = 0.00$$

$$a_{se1} = 0.00$$

$$sh_1 = 150.00$$

$$bo_1 = 190.00$$

$$ho_1 = 540.00$$

$$bi2_1 = 655400.00$$

$$a_{se2} = 0.00$$

$$sh_2 = 150.00$$

$$bo_2 = 190.00$$

$$ho_2 = 540.00$$

$$bi2_2 = 655400.00$$

$$a_{se3} = 0 \text{ (grid does not provide confinement)}$$

$$p_{sh,\min} = \text{Min}(p_{sh,x}, p_{sh,y}) = 0.00069813$$

Expression ((5.4d), TBDY) for $p_{sh,\min}$ has been multiplied by 0.3 according to 15.7.1.3 for members without earthquake detailing (90° closed stirrups)

$$p_{sh,x} = p_{s1,x} + p_{s2,x} + p_{s3,x} = 0.00356047$$

$$p_{s1,x} \text{ (column 1)} = (A_{s1} * h_1 / s_1) / A_c = 0.00083776$$

$$h_1 = 600.00$$

$$A_{s1} = A_{stir1} * n_{s1} = 157.0796$$

$$\text{No stirrups, } n_{s1} = 2.00$$

$$p_{s2,x} \text{ (column 2)} = (A_{s2} * h_2 / s_2) / A_c = 0.00083776$$

$h_2 = 600.00$
 $As_2 = Astir_2 * ns_2 = 157.0796$
 No stirups, $ns_2 = 2.00$
 $ps_{3,x} (web) = (As_3 * h_3 / s_3) / A_c = 0.00188496$
 $h_3 = 1800.00$
 $As_3 = Astir_3 * ns_3 = 0.00$
 No stirups, $ns_3 = 2.00$

$psh,y = ps_1,y + ps_2,y + ps_3,y = 0.00069813$
 $ps_1,y (column\ 1) = (As_1 * h_1 / s_1) / A_c = 0.00034907$
 $h_1 = 250.00$
 $As_1 = Astir_1 * ns_1 = 157.0796$
 No stirups, $ns_1 = 2.00$
 $ps_2,y (column\ 2) = (As_2 * h_2 / s_2) / A_c = 0.00034907$
 $h_2 = 250.00$
 $As_2 = Astir_2 * ns_2 = 157.0796$
 No stirups, $ns_2 = 2.00$
 $ps_3,y (web) = (As_3 * h_3 / s_3) / A_c = 0.00$
 $h_3 = 250.00$
 $As_3 = Astir_3 * ns_3 = 157.0796$
 No stirups, $ns_3 = 0.00$

$A_{sec} = 750000.00$
 $s_1 = 150.00$
 $s_2 = 150.00$
 $s_3 = 200.00$
 $fy_{we} = 625.00$
 $f_{ce} = 25.00$
 From ((5.A.5), TBDY), TBDY: $cc = 0.00202463$
 $c = \text{confinement factor} = 1.00246$
 $y_1 = 0.00140044$
 $sh_1 = 0.0044814$
 $ft_1 = 420.1317$
 $fy_1 = 350.1097$
 $su_1 = 0.00512$
 using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
 and also multiplied by the shear_factor according to 15.7.1.4, with
 $Shear_factor = 1.00$
 $lo/lou,min = lb/l_d = 0.30$
 $su_1 = 0.4 * esu_{1_nominal} ((5.5), TBDY) = 0.032$
 From table 5A.1, TBDY: $esu_{1_nominal} = 0.08$,
 For calculation of $esu_{1_nominal}$ and y_1, sh_1, ft_1, fy_1 , it is considered
 characteristic value $fsy_1 = fs_1 / 1.2$, from table 5.1, TBDY.
 y_1, sh_1, ft_1, fy_1 , are also multiplied by $\text{Min}(1, 1.25 * (lb/l_d)^{2/3})$, from 10.3.5, ASCE 41-17.
 with $fs_1 = fs = 350.1097$
 with $Es_1 = Es = 200000.00$
 $y_2 = 0.00140044$
 $sh_2 = 0.0044814$
 $ft_2 = 420.1317$
 $fy_2 = 350.1097$
 $su_2 = 0.00512$
 using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
 and also multiplied by the shear_factor according to 15.7.1.4, with
 $Shear_factor = 1.00$
 $lo/lou,min = lb/l_b,min = 0.30$
 $su_2 = 0.4 * esu_{2_nominal} ((5.5), TBDY) = 0.032$
 From table 5A.1, TBDY: $esu_{2_nominal} = 0.08$,
 For calculation of $esu_{2_nominal}$ and y_2, sh_2, ft_2, fy_2 , it is considered
 characteristic value $fsy_2 = fs_2 / 1.2$, from table 5.1, TBDY.
 y_1, sh_1, ft_1, fy_1 , are also multiplied by $\text{Min}(1, 1.25 * (lb/l_d)^{2/3})$, from 10.3.5, ASCE 41-17.
 with $fs_2 = fs = 350.1097$
 with $Es_2 = Es = 200000.00$
 $y_v = 0.00140044$
 $sh_v = 0.0044814$
 $ft_v = 420.1317$
 $fy_v = 350.1097$
 $suv = 0.00512$

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
 and also multiplied by the shear_factor according to 15.7.1.4, with
 Shear_factor = 1.00
 $l_o/l_{ou,min} = l_b/l_d = 0.30$
 $suv = 0.4 * esuv_{nominal} ((5.5), TBDY) = 0.032$
 From table 5A.1, TBDY: $esuv_{nominal} = 0.08$,
 considering characteristic value $fsyv = fsv/1.2$, from table 5.1, TBDY
 For calculation of $esuv_{nominal}$ and y_v , sh_v, ft_v, fy_v , it is considered
 characteristic value $fsyv = fsv/1.2$, from table 5.1, TBDY.
 y_1 , sh_1, ft_1, fy_1 , are also multiplied by $Min(1, 1.25 * (l_b/l_d)^{2/3})$, from 10.3.5, ASCE 41-17.
 with $fsv = fs = 350.1097$
 with $Esv = Es = 200000.00$
 $1 = Asl_{ten}/(b*d) * (fs_1/fc) = 0.05427722$
 $2 = Asl_{com}/(b*d) * (fs_2/fc) = 0.05427722$
 $v = Asl_{mid}/(b*d) * (fsv/fc) = 0.0291621$

and confined core properties:

$b = 190.00$
 $d = 2927.00$
 $d' = 13.00$
 $fcc (5A.2, TBDY) = 25.06158$
 $cc (5A.5, TBDY) = 0.00202463$
 $c = \text{confinement factor} = 1.00246$
 $1 = Asl_{ten}/(b*d) * (fs_1/fc) = 0.07214938$
 $2 = Asl_{com}/(b*d) * (fs_2/fc) = 0.07214938$
 $v = Asl_{mid}/(b*d) * (fsv/fc) = 0.03876447$

Case/Assumption: Unconfined full section - Steel rupture
 ' satisfies Eq. (4.3)

--->
 $v < v_{s,y2}$ - LHS eq.(4.5) is satisfied
 --->
 $su (4.9) = 0.15670711$
 $Mu = MRc (4.14) = 3.8401E+009$
 $u = su (4.1) = 2.0532423E-006$

Calculation of ratio l_b/l_d

Inadequate Lap Length with $l_b/l_d = 0.30$

Calculation of Mu_{2+}

Calculation of ultimate curvature u according to 4.1, Biskinis/Fardis 2013:

$u = 2.0296703E-006$
 $Mu = 3.3585E+009$

with full section properties:

$b = 250.00$
 $d = 2957.00$
 $d' = 43.00$
 $v = 0.0014928$
 $N = 27588.841$
 $fc = 25.00$
 $co (5A.5, TBDY) = 0.002$
 Final value of cu : $cu^* = \text{shear_factor} * \text{Max}(cu, cc) = 0.0035$
 The Shear_factor is considered equal to 1 (pure moment strength)
 From (5.4b), TBDY: $cu = 0.0035$
 $we ((5.4c), TBDY) = ase * sh_{min} * fy_{we}/f_{ce} + \text{Min}(fx, fy) = 0.00$
 where $f = af * pf * f_{fe}/f_{ce}$ is accounting for FRP contribution like EC8-part3 A.4.4.3(6)

 $fx = 0.00$
 $af = 0.00$
 $b = 250.00$
 $h = 3000.00$

From EC8 A4.4.3(6), $pf = 2tf/bw = 0.008128$
 $bw = 250.00$
effective stress from (A.35), $ff,e = 757.2164$

$f_y = 0.00$
 $a_f = 0.00$
 $b = 3000.00$
 $h = 250.00$
From EC8 A4.4.3(6), $pf = 2tf/bw = 0.00067733$
 $bw = 3000.00$
effective stress from (A.35), $ff,e = 954.4864$

$R = 40.00$
Effective FRP thickness, $tf = NL*t*Cos(b1) = 1.016$
 $f_{u,f} = 1055.00$
 $E_f = 64828.00$
 $u_f = 0.015$
 $ase((5.4d), TBDY) = (ase1*Acol1 + ase2*Acol2 + ase3*Aweb)/Asec = 0.00$
 $ase1 = 0.00$
 $sh_1 = 150.00$
 $bo_1 = 190.00$
 $ho_1 = 540.00$
 $bi2_1 = 655400.00$
 $ase2 = 0.00$
 $sh_2 = 150.00$
 $bo_2 = 190.00$
 $ho_2 = 540.00$
 $bi2_2 = 655400.00$

$ase3 = 0$ (grid does not provide confinement)
 $psh,min = Min(psh,x, psh,y) = 0.00069813$

Expression ((5.4d), TBDY) for psh,min has been multiplied by 0.3 according to 15.7.1.3 for members without earthquake detailing (90° closed stirrups)

$psh,x = ps1,x + ps2,x + ps3,x = 0.00356047$
 $ps1,x$ (column 1) = $(As1*h1/s_1)/Ac = 0.00083776$
 $h1 = 600.00$
 $As1 = Astir1*ns1 = 157.0796$
No stirrups, $ns1 = 2.00$
 $ps2,x$ (column 2) = $(As2*h2/s_2)/Ac = 0.00083776$
 $h2 = 600.00$
 $As2 = Astir2*ns2 = 157.0796$
No stirrups, $ns2 = 2.00$
 $ps3,x$ (web) = $(As3*h3/s_3)/Ac = 0.00188496$
 $h3 = 1800.00$
 $As3 = Astir3*ns3 = 0.00$
No stirrups, $ns3 = 2.00$

$psh,y = ps1,y + ps2,y + ps3,y = 0.00069813$
 $ps1,y$ (column 1) = $(As1*h1/s_1)/Ac = 0.00034907$
 $h1 = 250.00$
 $As1 = Astir1*ns1 = 157.0796$
No stirrups, $ns1 = 2.00$
 $ps2,y$ (column 2) = $(As2*h2/s_2)/Ac = 0.00034907$
 $h2 = 250.00$
 $As2 = Astir2*ns2 = 157.0796$
No stirrups, $ns2 = 2.00$
 $ps3,y$ (web) = $(As3*h3/s_3)/Ac = 0.00$
 $h3 = 250.00$
 $As3 = Astir3*ns3 = 157.0796$
No stirrups, $ns3 = 0.00$

$Asec = 750000.00$
 $s_1 = 150.00$
 $s_2 = 150.00$
 $s_3 = 200.00$
 $f_{ywe} = 625.00$
 $f_{ce} = 25.00$

From ((5.A.5), TBDY), TBDY: $cc = 0.00202463$
 $c = \text{confinement factor} = 1.00246$
 $y1 = 0.00140044$
 $sh1 = 0.0044814$
 $ft1 = 420.1317$
 $fy1 = 350.1097$
 $su1 = 0.00512$
 using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
 and also multiplied by the shear_factor according to 15.7.1.4, with
 Shear_factor = 1.00
 $lo/lou, \min = lb/ld = 0.30$
 $su1 = 0.4 * esu1_nominal ((5.5), TBDY) = 0.032$
 From table 5A.1, TBDY: $esu1_nominal = 0.08$,
 For calculation of $esu1_nominal$ and $y1, sh1, ft1, fy1$, it is considered
 characteristic value $fsy1 = fs1/1.2$, from table 5.1, TBDY.
 $y1, sh1, ft1, fy1$, are also multiplied by $\text{Min}(1, 1.25 * (lb/ld)^{2/3})$, from 10.3.5, ASCE 41-17.
 with $fs1 = fs = 350.1097$
 with $Es1 = Es = 200000.00$
 $y2 = 0.00140044$
 $sh2 = 0.0044814$
 $ft2 = 420.1317$
 $fy2 = 350.1097$
 $su2 = 0.00512$
 using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
 and also multiplied by the shear_factor according to 15.7.1.4, with
 Shear_factor = 1.00
 $lo/lou, \min = lb/lb, \min = 0.30$
 $su2 = 0.4 * esu2_nominal ((5.5), TBDY) = 0.032$
 From table 5A.1, TBDY: $esu2_nominal = 0.08$,
 For calculation of $esu2_nominal$ and $y2, sh2, ft2, fy2$, it is considered
 characteristic value $fsy2 = fs2/1.2$, from table 5.1, TBDY.
 $y1, sh1, ft1, fy1$, are also multiplied by $\text{Min}(1, 1.25 * (lb/ld)^{2/3})$, from 10.3.5, ASCE 41-17.
 with $fs2 = fs = 350.1097$
 with $Es2 = Es = 200000.00$
 $yv = 0.00140044$
 $shv = 0.0044814$
 $ftv = 420.1317$
 $fyv = 350.1097$
 $suv = 0.00512$
 using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
 and also multiplied by the shear_factor according to 15.7.1.4, with
 Shear_factor = 1.00
 $lo/lou, \min = lb/ld = 0.30$
 $suv = 0.4 * esuv_nominal ((5.5), TBDY) = 0.032$
 From table 5A.1, TBDY: $esuv_nominal = 0.08$,
 considering characteristic value $fsyv = fsv/1.2$, from table 5.1, TBDY
 For calculation of $esuv_nominal$ and yv, shv, ftv, fyv , it is considered
 characteristic value $fsyv = fsv/1.2$, from table 5.1, TBDY.
 $y1, sh1, ft1, fy1$, are also multiplied by $\text{Min}(1, 1.25 * (lb/ld)^{2/3})$, from 10.3.5, ASCE 41-17.
 with $fsv = fs = 350.1097$
 with $Esv = Es = 200000.00$
 $1 = Asl, \text{ten} / (b * d) * (fs1 / fc) = 0.05427722$
 $2 = Asl, \text{com} / (b * d) * (fs2 / fc) = 0.05427722$
 $v = Asl, \text{mid} / (b * d) * (fsv / fc) = 0.00$
 and confined core properties:
 $b = 190.00$
 $d = 2927.00$
 $d' = 13.00$
 $fcc (5A.2, TBDY) = 25.06158$
 $cc (5A.5, TBDY) = 0.00202463$
 $c = \text{confinement factor} = 1.00246$
 $1 = Asl, \text{ten} / (b * d) * (fs1 / fc) = 0.07214938$
 $2 = Asl, \text{com} / (b * d) * (fs2 / fc) = 0.07214938$
 $v = Asl, \text{mid} / (b * d) * (fsv / fc) = 0.00$
 Case/Assumption: Unconfined full section - Steel rupture
 ' satisfies Eq. (4.3)

--->

$v < v_{s,y2}$ - LHS eq.(4.5) is satisfied

---->

$$s_u(4.9) = 0.14691336$$

$$\mu_u = M_{Rc}(4.14) = 3.3585E+009$$

$$u = s_u(4.1) = 2.0296703E-006$$

Calculation of ratio I_b/I_d

Inadequate Lap Length with $I_b/I_d = 0.30$

Calculation of μ_{u2} -

Calculation of ultimate curvature μ_u according to 4.1, Biskinis/Fardis 2013:

$$u = 2.0532423E-006$$

$$\mu_u = 3.8401E+009$$

with full section properties:

$$b = 250.00$$

$$d = 2957.00$$

$$d' = 43.00$$

$$v = 0.0014928$$

$$N = 27588.841$$

$$f_c = 25.00$$

$$\alpha_{co}(5A.5, TBDY) = 0.002$$

$$\text{Final value of } \mu_u: \mu_u^* = \text{shear_factor} * \text{Max}(\mu_u, \alpha_{co}) = 0.0035$$

The Shear_factor is considered equal to 1 (pure moment strength)

$$\text{From (5.4b), TBDY: } \mu_u = 0.0035$$

$$\mu_{ue}((5.4c), TBDY) = \alpha_{se} * \text{sh}_{\min} * f_{ywe}/f_{ce} + \text{Min}(f_x, f_y) = 0.00$$

where $f = \alpha_f * p_f * f_{fe}/f_{ce}$ is accounting for FRP contribution like EC8-part3 A.4.4.3(6)

$$f_x = 0.00$$

$$\alpha_f = 0.00$$

$$b = 250.00$$

$$h = 3000.00$$

$$\text{From EC8 A4.4.3(6), } p_f = 2t_f/bw = 0.008128$$

$$bw = 250.00$$

$$\text{effective stress from (A.35), } f_{fe} = 757.2164$$

$$f_y = 0.00$$

$$\alpha_f = 0.00$$

$$b = 3000.00$$

$$h = 250.00$$

$$\text{From EC8 A4.4.3(6), } p_f = 2t_f/bw = 0.00067733$$

$$bw = 3000.00$$

$$\text{effective stress from (A.35), } f_{fe} = 954.4864$$

$$R = 40.00$$

$$\text{Effective FRP thickness, } t_f = NL * t * \cos(b_1) = 1.016$$

$$f_{u,f} = 1055.00$$

$$E_f = 64828.00$$

$$u_{,f} = 0.015$$

$$\alpha_{se}((5.4d), TBDY) = (\alpha_{se1} * A_{col1} + \alpha_{se2} * A_{col2} + \alpha_{se3} * A_{web}) / A_{sec} = 0.00$$

$$\alpha_{se1} = 0.00$$

$$sh_1 = 150.00$$

$$bo_1 = 190.00$$

$$ho_1 = 540.00$$

$$bi2_1 = 655400.00$$

$$\alpha_{se2} = 0.00$$

$$sh_2 = 150.00$$

$$bo_2 = 190.00$$

$$ho_2 = 540.00$$

$$bi2_2 = 655400.00$$

ase3 = 0 (grid does not provide confinement)
 psh,min = Min(psh,x , psh,y) = 0.00069813
 Expression ((5.4d), TBDY) for psh,min has been multiplied by 0.3 according to 15.7.1.3 for members without earthquake detailing (90° closed stirrups)

psh,x = ps1,x+ps2,x+ps3,x = 0.00356047
 ps1,x (column 1) = (As1*h1/s_1)/Ac = 0.00083776
 h1 = 600.00
 As1 = Astir1*ns1 = 157.0796
 No stirrups, ns1 = 2.00
 ps2,x (column 2) = (As2*h2/s_2)/Ac = 0.00083776
 h2 = 600.00
 As2 = Astir2*ns2 = 157.0796
 No stirrups, ns2 = 2.00
 ps3,x (web) = (As3*h3/s_3)/Ac = 0.00188496
 h3 = 1800.00
 As3 = Astir3*ns3 = 0.00
 No stirrups, ns3 = 2.00

psh,y = ps1,y+ps2,y+ps3,y = 0.00069813
 ps1,y (column 1) = (As1*h1/s_1)/Ac = 0.00034907
 h1 = 250.00
 As1 = Astir1*ns1 = 157.0796
 No stirrups, ns1 = 2.00
 ps2,y (column 2) = (As2*h2/s_2)/Ac = 0.00034907
 h2 = 250.00
 As2 = Astir2*ns2 = 157.0796
 No stirrups, ns2 = 2.00
 ps3,y (web) = (As3*h3/s_3)/Ac = 0.00
 h3 = 250.00
 As3 = Astir3*ns3 = 157.0796
 No stirrups, ns3 = 0.00

Asec = 750000.00

s_1 = 150.00

s_2 = 150.00

s_3 = 200.00

fywe = 625.00

fce = 25.00

From ((5.A5), TBDY), TBDY: cc = 0.00202463

c = confinement factor = 1.00246

y1 = 0.00140044

sh1 = 0.0044814

ft1 = 420.1317

fy1 = 350.1097

su1 = 0.00512

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
 and also multiplied by the shear_factor according to 15.7.1.4, with

Shear_factor = 1.00

lo/lou,min = lb/lb = 0.30

su1 = 0.4*esu1_nominal ((5.5), TBDY) = 0.032

From table 5A.1, TBDY: esu1_nominal = 0.08,

For calculation of esu1_nominal and y1, sh1,ft1,fy1, it is considered
 characteristic value fsy1 = fs1/1.2, from table 5.1, TBDY.

y1, sh1,ft1,fy1, are also multiplied by Min(1,1.25*(lb/lb)^ 2/3), from 10.3.5, ASCE 41-17.

with fs1 = fs = 350.1097

with Es1 = Es = 200000.00

y2 = 0.00140044

sh2 = 0.0044814

ft2 = 420.1317

fy2 = 350.1097

su2 = 0.00512

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
 and also multiplied by the shear_factor according to 15.7.1.4, with

Shear_factor = 1.00

lo/lou,min = lb/lb,min = 0.30

su2 = 0.4*esu2_nominal ((5.5), TBDY) = 0.032

From table 5A.1, TBDY: $es_{u2_nominal} = 0.08$,
For calculation of $es_{u2_nominal}$ and y_2 , sh_2 , ft_2 , fy_2 , it is considered
characteristic value $fs_{y2} = fs_2/1.2$, from table 5.1, TBDY.
 y_1 , sh_1 , ft_1 , fy_1 , are also multiplied by $\text{Min}(1, 1.25 \cdot (lb/d)^{2/3})$, from 10.3.5, ASCE 41-17.
with $fs_2 = fs = 350.1097$
with $Es_2 = Es = 200000.00$
 $y_v = 0.00140044$
 $sh_v = 0.0044814$
 $ft_v = 420.1317$
 $fy_v = 350.1097$
 $s_{uv} = 0.00512$
using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00
 $lo/lou, \min = lb/d = 0.30$
 $s_{uv} = 0.4 \cdot es_{uv_nominal} ((5.5), TBDY) = 0.032$
From table 5A.1, TBDY: $es_{uv_nominal} = 0.08$,
considering characteristic value $fs_{yv} = fs_v/1.2$, from table 5.1, TBDY
For calculation of $es_{uv_nominal}$ and y_v , sh_v , ft_v , fy_v , it is considered
characteristic value $fs_{yv} = fs_v/1.2$, from table 5.1, TBDY.
 y_1 , sh_1 , ft_1 , fy_1 , are also multiplied by $\text{Min}(1, 1.25 \cdot (lb/d)^{2/3})$, from 10.3.5, ASCE 41-17.
with $fs_v = fs = 350.1097$
with $Es_v = Es = 200000.00$
 $1 = As_{l,ten}/(b \cdot d) \cdot (fs_1/f_c) = 0.05427722$
 $2 = As_{l,com}/(b \cdot d) \cdot (fs_2/f_c) = 0.05427722$
 $v = As_{l,mid}/(b \cdot d) \cdot (fs_v/f_c) = 0.0291621$
and confined core properties:
 $b = 190.00$
 $d = 2927.00$
 $d' = 13.00$
 $f_{cc} (5A.2, TBDY) = 25.06158$
 $cc (5A.5, TBDY) = 0.00202463$
 $c = \text{confinement factor} = 1.00246$
 $1 = As_{l,ten}/(b \cdot d) \cdot (fs_1/f_c) = 0.07214938$
 $2 = As_{l,com}/(b \cdot d) \cdot (fs_2/f_c) = 0.07214938$
 $v = As_{l,mid}/(b \cdot d) \cdot (fs_v/f_c) = 0.03876447$
Case/Assumption: Unconfined full section - Steel rupture
'satisfies Eq. (4.3)
--->
 $v < v_{s,y2}$ - LHS eq.(4.5) is satisfied
--->
 $su (4.9) = 0.15670711$
 $Mu = MR_c (4.14) = 3.8401E+009$
 $u = su (4.1) = 2.0532423E-006$

Calculation of ratio lb/d

Inadequate Lap Length with $lb/d = 0.30$

Calculation of Shear Strength $V_r = \text{Min}(V_{r1}, V_{r2}) = 2.4900E+006$

Calculation of Shear Strength at edge 1, $V_{r1} = 2.4900E+006$
From (22.5.1.1) and 11.5.4.3, ACI 318-14: $V_{r1} = V_n < 0.83 \cdot f_c'^{0.5} \cdot h \cdot d$

NOTE: In expression (22.5.1.1) ' V_w ' is replaced by ' $V_w + f \cdot V_f$ '
where V_f is the contribution of FRPs (11.3), ACI 440).

From Table (11.5.4.6(d-e)), ACI 318-14: $V_c = 815517.768$
 $Mu/V_u - lw/2 = 0.00 \leq 0$
= 1 (normal-weight concrete)
 $f_c' = 25.00$, but $f_c'^{0.5} \leq 8.3 \text{ MPa}$ (22.5.3.1, ACI 318-14)
 $h = 250.00$
 $d = 2400.00$

$l_w = 3000.00$
 $\mu_u = 1.1486927E-009$
 $\mu_u = 1.0097420E-028$
 $\mu_u = 27588.841$
 From (11.5.4.8), ACI 318-14: $V_s = V_{s1} + V_{s2} + V_{s3} = 1.0681E+006$
 $V_{s1} = 251327.412$ is calculated for pseudo-Column 1, with:
 $d = 480.00$
 $A_v = 157079.633$
 $s = 150.00$
 $f_y = 500.00$
 V_{s1} has been multiplied by 1 ($s < d/2$, according to ASCE 41-17,10.3.4)
 $V_{s2} = 251327.412$ is calculated for pseudo-Column 2, with:
 $d = 480.00$
 $A_v = 157079.633$
 $s = 150.00$
 $f_y = 500.00$
 V_{s2} has been multiplied by 1 ($s < d/2$, according to ASCE 41-17,10.3.4)
 $V_{s3} = 565486.678$ is calculated for web, with:
 $d = 1440.00$
 $A_v = 157079.633$
 $s = 200.00$
 $f_y = 500.00$
 V_{s3} has been multiplied by 1 ($s < d/2$, according to ASCE 41-17,10.3.4)
 V_f ((11-3)-(11.4), ACI 440) = $1.5581E+006$
 $f = 0.95$, for fully-wrapped sections
 $w_f/s_f = 1$ (FRP strips adjacent to one another).
 In (11.3) $\sin + \cos$ is replaced with $(\cot + \cot a)\sin a$ which is more a generalised expression,
 where a is the angle of the crack direction (see KANEPE).
 This later relation, considered as a function $V_f(,)$, is implemented for every different fiber orientation a_i ,
 as well as for 2 crack directions, $a = 45^\circ$ and $a = -45^\circ$ to take into consideration the cyclic seismic loading.
 orientation 1: $a_1 = b_1 + 90^\circ = 90.00$
 $V_f = \text{Min}(|V_f(45, 1)|, |V_f(-45, a_1)|)$, with:
 total thickness per orientation, $t_{f1} = N_L \cdot t / N_{oDir} = 1.016$
 $d_{fv} = d$ (figure 11.2, ACI 440) = 2957.00
 f_{fe} ((11-5), ACI 440) = 259.312
 $E_f = 64828.00$
 $f_e = 0.004$, from (11.6a), ACI 440
 with $f_u = 0.01$
 From (11-11), ACI 440: $V_s + V_f \leq 1.9929E+006$
 $b_w = 250.00$

Calculation of Shear Strength at edge 2, $V_{r2} = 2.4900E+006$
 From (22.5.1.1) and 11.5.4.3, ACI 318-14: $V_{r2} = V_n < 0.83 \cdot f_c'^{0.5} \cdot h \cdot d$

NOTE: In expression (22.5.1.1) ' V_w ' is replaced by ' $V_w + f \cdot V_f$ '
 where V_f is the contribution of FRPs (11.3), ACI 440).

From Table (11.5.4.6(d-e)), ACI 318-14: $V_c = 815517.768$
 $\mu_u / \mu_u - l_w / 2 = 0.00 \leq 0$
 $= 1$ (normal-weight concrete)
 $f_c' = 25.00$, but $f_c'^{0.5} \leq 8.3$ MPa (22.5.3.1, ACI 318-14)
 $h = 250.00$
 $d = 2400.00$
 $l_w = 3000.00$
 $\mu_u = 1.1486927E-009$
 $\mu_u = 1.0097420E-028$
 $\mu_u = 27588.841$
 From (11.5.4.8), ACI 318-14: $V_s = V_{s1} + V_{s2} + V_{s3} = 1.0681E+006$
 $V_{s1} = 251327.412$ is calculated for pseudo-Column 1, with:
 $d = 480.00$
 $A_v = 157079.633$
 $s = 150.00$
 $f_y = 500.00$
 V_{s1} has been multiplied by 1 ($s < d/2$, according to ASCE 41-17,10.3.4)
 $V_{s2} = 251327.412$ is calculated for pseudo-Column 2, with:
 $d = 480.00$
 $A_v = 157079.633$

$s = 150.00$
 $f_y = 500.00$
 V_{s2} has been multiplied by 1 ($s < d/2$, according to ASCE 41-17,10.3.4)
 $V_{s3} = 565486.678$ is calculated for web, with:
 $d = 1440.00$
 $A_v = 157079.633$
 $s = 200.00$
 $f_y = 500.00$
 V_{s3} has been multiplied by 1 ($s < d/2$, according to ASCE 41-17,10.3.4)
 $V_f ((11-3)-(11.4), \text{ACI 440}) = 1.5581\text{E}+006$
 $f = 0.95$, for fully-wrapped sections
 $w_f/s_f = 1$ (FRP strips adjacent to one another).
 In (11.3) $\sin + \cos$ is replaced with $(\cot + \cot a)\sin a$ which is more a generalised expression,
 where a is the angle of the crack direction (see KANEPE).
 This later relation, considered as a function $V_f(\theta)$, is implemented for every different fiber orientation a_i ,
 as well as for 2 crack directions, $\theta = 45^\circ$ and $\theta = -45^\circ$ to take into consideration the cyclic seismic loading.
 orientation 1: $\theta_1 = b_1 + 90^\circ = 90.00$
 $V_f = \text{Min}(|V_f(45, \theta_1)|, |V_f(-45, a_1)|)$, with:
 total thickness per orientation, $t_{f1} = N_L * t / \text{NoDir} = 1.016$
 $d_{fv} = d$ (figure 11.2, ACI 440) = 2957.00
 $f_{fe} ((11-5), \text{ACI 440}) = 259.312$
 $E_f = 64828.00$
 $f_e = 0.004$, from (11.6a), ACI 440
 with $f_u = 0.01$
 From (11-11), ACI 440: $V_s + V_f \leq 1.9929\text{E}+006$
 $b_w = 250.00$

 End Of Calculation of Shear Capacity ratio for element: wall W1 of floor 1
 At local axis: 3

 Start Of Calculation of Shear Capacity ratio for element: wall W1 of floor 1
 At Shear local axis: 2
 (Bending local axis: 3)
 Section Type: rcrcws

Constant Properties

 Knowledge Factor, $K = 1.00$
 Mean strength values are used for both shear and moment calculations.
 Consequently:
 New material of Secondary Member: Concrete Strength, $f_c = f_{cm} = 25.00$
 New material of Secondary Member: Steel Strength, $f_s = f_{sm} = 500.00$
 Concrete Elasticity, $E_c = 26999.444$
 Steel Elasticity, $E_s = 200000.00$
 #####
 Note: Especially for the calculation of moment strengths,
 the above steel re-bar strengths are multiplied by 1.25 according to R18.6.5, ACI 318-14
 New material: Steel Strength, $f_s = 1.25 * f_{sm} = 625.00$
 #####
 Total Height, $H_{tot} = 3000.00$
 Edges Width, $W_{edg} = 250.00$
 Edges Height, $H_{edg} = 600.00$
 Web Width, $W_{web} = 250.00$
 Cover Thickness, $c = 25.00$
 Mean Confinement Factor overall section = 1.00246
 Element Length, $L = 3000.00$
 Secondary Member
 Smooth Bars
 Ductile Steel
 Without Detailing for Earthquake Resistance (including stirrups not closed at 135°)
 Longitudinal Bars With Ends Lapped Starting at the End Sections
 Inadequate Lap Length with $l_o/l_{ou,min} = 0.30$
 FRP Wrapping Data
 Type: Carbon

Cured laminate properties (design values)

Thickness, $t = 1.016$

Tensile Strength, $f_{fu} = 1055.00$

Tensile Modulus, $E_f = 64828.00$

Elongation, $\epsilon_{fu} = 0.01$

Number of directions, $NoDir = 1$

Fiber orientations, $b_i = 0.00^\circ$

Number of layers, $NL = 1$

Radius of rounding corners, $R = 40.00$

Stepwise Properties

At local axis: 2

EDGE -A-

Shear Force, $V_a = 1.7354940E-029$

EDGE -B-

Shear Force, $V_b = -1.7354940E-029$

BOTH EDGES

Axial Force, $F = -27588.841$

Longitudinal Reinforcement Area Distribution (in 2 divisions)

-Tension: $As_t = 0.00$

-Compression: $As_c = 7269.645$

Longitudinal Reinforcement Area Distribution (in 3 divisions)

-Tension: $As_{t,ten} = 2830.575$

-Compression: $As_{c,com} = 2830.575$

-Middle: $As_{mid} = 0.00$

(According to 10.7.2.3 As_{mid} is setted equal to zero)

Calculation of Shear Capacity ratio, $V_e/V_r = 0.15621236$

Member Controlled by Flexure ($V_e/V_r < 1$)

Calculation of Shear Demand from fig. R18.6.5, ACI 318-14 $V_e = (M_{pr1} + M_{pr2})/l_n = 160017.271$

with

$M_{pr1} = \text{Max}(\mu_{u1+}, \mu_{u1-}) = 2.4003E+008$

$\mu_{u1+} = 2.0658E+008$, is the ultimate moment strength at the edge 1 of the member in the actual moment direction which is defined for the static loading combination

$\mu_{u1-} = 2.4003E+008$, is the ultimate moment strength at the edge 1 of the member in the opposite moment direction which is defined for the static loading combination

$M_{pr2} = \text{Max}(\mu_{u2+}, \mu_{u2-}) = 2.4003E+008$

$\mu_{u2+} = 2.0658E+008$, is the ultimate moment strength at the edge 2 of the member in the actual moment direction which is defined for the static loading combination

$\mu_{u2-} = 2.4003E+008$, is the ultimate moment strength at the edge 2 of the member in the opposite moment direction which is defined for the static loading combination

Calculation of μ_{u1+}

Calculation of ultimate curvature ϕ_u according to 4.1, Biskinis/Fardis 2013:

$\phi_u = 3.0306889E-005$

$\mu_u = 2.0658E+008$

with full section properties:

$b = 3000.00$

$d = 208.00$

$d' = 42.00$

$v = 0.00176852$

$N = 27588.841$

$f_c = 25.00$

ϕ_o (5A.5, TBDY) = 0.002

Final value of ϕ_u : $\phi_u^* = \text{shear_factor} * \text{Max}(\phi_u, \phi_o) = 0.0035$

The Shear_factor is considered equal to 1 (pure moment strength)

From (5.4b), TBDY: $\phi_u = 0.0035$

$w_e ((5.4c), TBDY) = a_{se} \cdot \min(f_{ywe}/f_{ce} + \min(f_x, f_y)) = 0.00$
where $f = a_f \cdot p_f \cdot f_{fe}/f_{ce}$ is accounting for FRP contribution like EC8-part3 A.4.4.3(6)

$f_x = 0.00$
 $a_f = 0.00$
 $b = 250.00$
 $h = 3000.00$
From EC8 A.4.4.3(6), $p_f = 2t_f/bw = 0.008128$
 $bw = 250.00$
effective stress from (A.35), $f_{fe} = 757.2164$

$f_y = 0.00$
 $a_f = 0.00$
 $b = 3000.00$
 $h = 250.00$
From EC8 A.4.4.3(6), $p_f = 2t_f/bw = 0.00067733$
 $bw = 3000.00$
effective stress from (A.35), $f_{fe} = 954.4864$

$R = 40.00$
Effective FRP thickness, $t_f = NL \cdot t \cdot \cos(b_1) = 1.016$
 $f_{u,f} = 1055.00$
 $E_f = 64828.00$
 $u_f = 0.015$
 $a_{se} ((5.4d), TBDY) = (a_{se1} \cdot A_{col1} + a_{se2} \cdot A_{col2} + a_{se3} \cdot A_{web})/A_{sec} = 0.00$
 $a_{se1} = 0.00$
 $sh_1 = 150.00$
 $bo_1 = 190.00$
 $ho_1 = 540.00$
 $bi2_1 = 655400.00$
 $a_{se2} = 0.00$
 $sh_2 = 150.00$
 $bo_2 = 190.00$
 $ho_2 = 540.00$
 $bi2_2 = 655400.00$

$a_{se3} = 0$ (grid does not provide confinement)
 $p_{sh,min} = \min(p_{sh,x}, p_{sh,y}) = 0.00069813$

Expression ((5.4d), TBDY) for $p_{sh,min}$ has been multiplied by 0.3 according to 15.7.1.3 for members without earthquake detailing (90° closed stirrups)

$p_{sh,x} = p_{s1,x} + p_{s2,x} + p_{s3,x} = 0.00356047$
 $p_{s1,x} \text{ (column 1)} = (A_{s1} \cdot h_1/s_1)/A_c = 0.00083776$
 $h_1 = 600.00$
 $A_{s1} = A_{stir1} \cdot n_{s1} = 157.0796$
No stirrups, $n_{s1} = 2.00$
 $p_{s2,x} \text{ (column 2)} = (A_{s2} \cdot h_2/s_2)/A_c = 0.00083776$
 $h_2 = 600.00$
 $A_{s2} = A_{stir2} \cdot n_{s2} = 157.0796$
No stirrups, $n_{s2} = 2.00$
 $p_{s3,x} \text{ (web)} = (A_{s3} \cdot h_3/s_3)/A_c = 0.00188496$
 $h_3 = 1800.00$
 $A_{s3} = A_{stir3} \cdot n_{s3} = 0.00$
No stirrups, $n_{s3} = 2.00$

$p_{sh,y} = p_{s1,y} + p_{s2,y} + p_{s3,y} = 0.00069813$
 $p_{s1,y} \text{ (column 1)} = (A_{s1} \cdot h_1/s_1)/A_c = 0.00034907$
 $h_1 = 250.00$
 $A_{s1} = A_{stir1} \cdot n_{s1} = 157.0796$
No stirrups, $n_{s1} = 2.00$
 $p_{s2,y} \text{ (column 2)} = (A_{s2} \cdot h_2/s_2)/A_c = 0.00034907$
 $h_2 = 250.00$
 $A_{s2} = A_{stir2} \cdot n_{s2} = 157.0796$
No stirrups, $n_{s2} = 2.00$
 $p_{s3,y} \text{ (web)} = (A_{s3} \cdot h_3/s_3)/A_c = 0.00$
 $h_3 = 250.00$
 $A_{s3} = A_{stir3} \cdot n_{s3} = 157.0796$
No stirrups, $n_{s3} = 0.00$

```

Asec = 750000.00
s_1 = 150.00
s_2 = 150.00
s_3 = 200.00
fywe = 625.00
fce = 25.00
From ((5.A.5), TBDY), TBDY: cc = 0.00202463
c = confinement factor = 1.00246
y1 = 0.00140044
sh1 = 0.0044814
ft1 = 420.1317
fy1 = 350.1097
su1 = 0.00512
using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00
lo/lou,min = lb/lb,min = 0.30
su1 = 0.4*esu1_nominal ((5.5), TBDY) = 0.032
From table 5A.1, TBDY: esu1_nominal = 0.08,
For calculation of esu1_nominal and y1, sh1,ft1,fy1, it is considered
characteristic value fsy1 = fs1/1.2, from table 5.1, TBDY.
y1, sh1,ft1,fy1, are also multiplied by Min(1,1.25*(lb/lb,min)^ 2/3), from 10.3.5, ASCE 41-17.
with fs1 = fs = 350.1097
with Es1 = Es = 200000.00
y2 = 0.00140044
sh2 = 0.0044814
ft2 = 420.1317
fy2 = 350.1097
su2 = 0.00512
using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00
lo/lou,min = lb/lb,min = 0.30
su2 = 0.4*esu2_nominal ((5.5), TBDY) = 0.032
From table 5A.1, TBDY: esu2_nominal = 0.08,
For calculation of esu2_nominal and y2, sh2,ft2,fy2, it is considered
characteristic value fsy2 = fs2/1.2, from table 5.1, TBDY.
y1, sh1,ft1,fy1, are also multiplied by Min(1,1.25*(lb/lb,min)^ 2/3), from 10.3.5, ASCE 41-17.
with fs2 = fs = 350.1097
with Es2 = Es = 200000.00
yv = 0.00140044
shv = 0.0044814
ftv = 420.1317
fyv = 350.1097
suv = 0.00512
using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00
lo/lou,min = lb/lb,min = 0.30
suv = 0.4*esuv_nominal ((5.5), TBDY) = 0.032
From table 5A.1, TBDY: esuv_nominal = 0.08,
considering characteristic value fsyv = fsv/1.2, from table 5.1, TBDY
For calculation of esuv_nominal and yv, shv,ftv,fyv, it is considered
characteristic value fsyv = fsv/1.2, from table 5.1, TBDY.
y1, sh1,ft1,fy1, are also multiplied by Min(1,1.25*(lb/lb,min)^ 2/3), from 10.3.5, ASCE 41-17.
with fsv = fs = 350.1097
with Esv = Es = 200000.00
1 = Asl,ten/(b*d)*(fs1/fc) = 0.0635264
2 = Asl,com/(b*d)*(fs2/fc) = 0.0635264
v = Asl,mid/(b*d)*(fsv/fc) = 0.00
and confined core properties:
b = 2940.00
d = 178.00
d' = 12.00
fcc (5A.2, TBDY) = 25.06158
cc (5A.5, TBDY) = 0.00202463

```

$c = \text{confinement factor} = 1.00246$
 $1 = A_{sl,ten}/(b*d)*(f_{s1}/f_c) = 0.07574806$
 $2 = A_{sl,com}/(b*d)*(f_{s2}/f_c) = 0.07574806$
 $v = A_{sl,mid}/(b*d)*(f_{sv}/f_c) = 0.00$

Case/Assumption: Unconfined full section - Steel rupture
 ' satisfies Eq. (4.3)

--->

$v < v_{s,y2}$ - LHS eq.(4.5) is satisfied

--->

$\mu_u(4.9) = 0.18779572$
 $\mu_u = M_{Rc}(4.14) = 2.0658E+008$
 $u = \mu_u(4.1) = 3.0306889E-005$

Calculation of ratio l_b/l_d

Inadequate Lap Length with $l_b/l_d = 0.30$

Calculation of μ_{u1} -

Calculation of ultimate curvature μ_u according to 4.1, Biskinis/Fardis 2013:

$u = 3.0889637E-005$
 $\mu_u = 2.4003E+008$

with full section properties:

$b = 3000.00$
 $d = 208.00$
 $d' = 42.00$
 $v = 0.00176852$
 $N = 27588.841$
 $f_c = 25.00$
 $\alpha(5A.5, TBDY) = 0.002$

Final value of μ_u : $\mu_u^* = \text{shear_factor} * \text{Max}(\mu_u, \mu_c) = 0.0035$

The Shear_factor is considered equal to 1 (pure moment strength)

From (5.4b), TBDY: $\mu_u = 0.0035$

$\mu_{we}((5.4c), TBDY) = \alpha_{se} * \text{sh}_{,min} * f_{ywe}/f_{ce} + \text{Min}(f_x, f_y) = 0.00$

where $f = \alpha_f * p_f * f_{fe}/f_{ce}$ is accounting for FRP contribution like EC8-part3 A.4.4.3(6)

$f_x = 0.00$

$\alpha_f = 0.00$

$b = 250.00$

$h = 3000.00$

From EC8 A.4.4.3(6), $p_f = 2t_f/bw = 0.008128$

$bw = 250.00$

effective stress from (A.35), $f_{fe} = 757.2164$

$f_y = 0.00$

$\alpha_f = 0.00$

$b = 3000.00$

$h = 250.00$

From EC8 A.4.4.3(6), $p_f = 2t_f/bw = 0.00067733$

$bw = 3000.00$

effective stress from (A.35), $f_{fe} = 954.4864$

$R = 40.00$

Effective FRP thickness, $t_f = N L * t * \cos(b_1) = 1.016$

$f_{u,f} = 1055.00$

$E_f = 64828.00$

$u_{,f} = 0.015$

$\alpha_{se}((5.4d), TBDY) = (\alpha_{se1} * A_{col1} + \alpha_{se2} * A_{col2} + \alpha_{se3} * A_{web})/A_{sec} = 0.00$

$\alpha_{se1} = 0.00$

$sh_{_1} = 150.00$

$bo_{_1} = 190.00$

$ho_1 = 540.00$
 $bi2_1 = 655400.00$
 $ase2 = 0.00$
 $sh_2 = 150.00$
 $bo_2 = 190.00$
 $ho_2 = 540.00$
 $bi2_2 = 655400.00$
 $ase3 = 0$ (grid does not provide confinement)
 $psh,min = \text{Min}(psh,x, psh,y) = 0.00069813$
 Expression ((5.4d), TBDY) for psh,min has been multiplied by 0.3 according to 15.7.1.3 for members without earthquake detailing (90° closed stirrups)

$psh,x = ps1,x + ps2,x + ps3,x = 0.00356047$
 $ps1,x$ (column 1) = $(As1 \cdot h1 / s_1) / Ac = 0.00083776$
 $h1 = 600.00$
 $As1 = Astir1 \cdot ns1 = 157.0796$
 No stirrups, $ns1 = 2.00$
 $ps2,x$ (column 2) = $(As2 \cdot h2 / s_2) / Ac = 0.00083776$
 $h2 = 600.00$
 $As2 = Astir2 \cdot ns2 = 157.0796$
 No stirrups, $ns2 = 2.00$
 $ps3,x$ (web) = $(As3 \cdot h3 / s_3) / Ac = 0.00188496$
 $h3 = 1800.00$
 $As3 = Astir3 \cdot ns3 = 0.00$
 No stirrups, $ns3 = 2.00$

$psh,y = ps1,y + ps2,y + ps3,y = 0.00069813$
 $ps1,y$ (column 1) = $(As1 \cdot h1 / s_1) / Ac = 0.00034907$
 $h1 = 250.00$
 $As1 = Astir1 \cdot ns1 = 157.0796$
 No stirrups, $ns1 = 2.00$
 $ps2,y$ (column 2) = $(As2 \cdot h2 / s_2) / Ac = 0.00034907$
 $h2 = 250.00$
 $As2 = Astir2 \cdot ns2 = 157.0796$
 No stirrups, $ns2 = 2.00$
 $ps3,y$ (web) = $(As3 \cdot h3 / s_3) / Ac = 0.00$
 $h3 = 250.00$
 $As3 = Astir3 \cdot ns3 = 157.0796$
 No stirrups, $ns3 = 0.00$

$Asec = 750000.00$
 $s_1 = 150.00$
 $s_2 = 150.00$
 $s_3 = 200.00$
 $fywe = 625.00$
 $fce = 25.00$

From ((5.A5), TBDY), TBDY: $cc = 0.00202463$
 $c = \text{confinement factor} = 1.00246$

$y1 = 0.00140044$
 $sh1 = 0.0044814$
 $ft1 = 420.1317$
 $fy1 = 350.1097$
 $su1 = 0.00512$

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
 and also multiplied by the shear_factor according to 15.7.1.4, with
 $\text{Shear_factor} = 1.00$

$lo/lo_{u,min} = lb/ld = 0.30$

$su1 = 0.4 \cdot esu1_nominal$ ((5.5), TBDY) = 0.032

From table 5A.1, TBDY: $esu1_nominal = 0.08$,

For calculation of $esu1_nominal$ and $y1, sh1, ft1, fy1$, it is considered
 characteristic value $fsy1 = fs1 / 1.2$, from table 5.1, TBDY.

$y1, sh1, ft1, fy1$, are also multiplied by $\text{Min}(1, 1.25 \cdot (lb/ld)^{2/3})$, from 10.3.5, ASCE 41-17.

with $fs1 = fs = 350.1097$

with $Es1 = Es = 200000.00$

$y2 = 0.00140044$
 $sh2 = 0.0044814$
 $ft2 = 420.1317$

```

fy2 = 350.1097
su2 = 0.00512
    using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
    and also multiplied by the shear_factor according to 15.7.1.4, with
    Shear_factor = 1.00
    lo/lo,min = lb/lb,min = 0.30
    su2 = 0.4*esu2_nominal ((5.5), TBDY) = 0.032
    From table 5A.1, TBDY: esu2_nominal = 0.08,
    For calculation of esu2_nominal and y2, sh2,ft2,fy2, it is considered
    characteristic value fsy2 = fs2/1.2, from table 5.1, TBDY.
    y1, sh1,ft1,fy1, are also multiplied by Min(1,1.25*(lb/ld)^ 2/3), from 10.3.5, ASCE 41-17.
    with fs2 = fs = 350.1097
    with Es2 = Es = 200000.00
    yv = 0.00140044
    shv = 0.0044814
    ftv = 420.1317
    fyv = 350.1097
    suv = 0.00512
    using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
    and also multiplied by the shear_factor according to 15.7.1.4, with
    Shear_factor = 1.00
    lo/lo,min = lb/ld = 0.30
    suv = 0.4*esuv_nominal ((5.5), TBDY) = 0.032
    From table 5A.1, TBDY: esuv_nominal = 0.08,
    considering characteristic value fsyv = fsv/1.2, from table 5.1, TBDY
    For calculation of esuv_nominal and yv, shv,ftv,fyv, it is considered
    characteristic value fsyv = fsv/1.2, from table 5.1, TBDY.
    y1, sh1,ft1,fy1, are also multiplied by Min(1,1.25*(lb/ld)^ 2/3), from 10.3.5, ASCE 41-17.
    with fsv = fs = 350.1097
    with Esv = Es = 200000.00
    1 = Asl,ten/(b*d)*(fs1/fc) = 0.0635264
    2 = Asl,com/(b*d)*(fs2/fc) = 0.0635264
    v = Asl,mid/(b*d)*(fsv/fc) = 0.03609935
and confined core properties:
b = 2940.00
d = 178.00
d' = 12.00
fcc (5A.2, TBDY) = 25.06158
cc (5A.5, TBDY) = 0.00202463
    c = confinement factor = 1.00246
    1 = Asl,ten/(b*d)*(fs1/fc) = 0.07574806
    2 = Asl,com/(b*d)*(fs2/fc) = 0.07574806
    v = Asl,mid/(b*d)*(fsv/fc) = 0.0430444
Case/Assumption: Unconfined full section - Steel rupture
' satisfies Eq. (4.3)
--->
v < vs,y2 - LHS eq.(4.5) is satisfied
--->
su (4.9) = 0.20311835
Mu = MRc (4.14) = 2.4003E+008
u = su (4.1) = 3.0889637E-005

```

Calculation of ratio lb/ld

Inadequate Lap Length with lb/ld = 0.30

Calculation of Mu2+

Calculation of ultimate curvature u according to 4.1, Biskinis/Fardis 2013:

u = 3.0306889E-005

Mu = 2.0658E+008

with full section properties:

$$b = 3000.00$$

$$d = 208.00$$

$$d' = 42.00$$

$$v = 0.00176852$$

$$N = 27588.841$$

$$f_c = 25.00$$

$$\alpha (5A.5, \text{TB DY}) = 0.002$$

$$\text{Final value of } \alpha: \alpha = \text{shear_factor} * \text{Max}(\alpha_c, \alpha_c) = 0.0035$$

The Shear_factor is considered equal to 1 (pure moment strength)

$$\text{From (5.4b), TB DY: } \alpha_c = 0.0035$$

$$\alpha_e ((5.4c), \text{TB DY}) = \alpha_e * \text{sh}_{\min} * f_{ywe} / f_{ce} + \text{Min}(\alpha_{fx}, \alpha_{fy}) = 0.00$$

where $\alpha = \alpha_e * \rho_f * f_{fe} / f_{ce}$ is accounting for FRP contribution like EC8-part3 A.4.4.3(6)

$$\alpha_{fx} = 0.00$$

$$\alpha_e = 0.00$$

$$b = 250.00$$

$$h = 3000.00$$

$$\text{From EC8 A4.4.3(6), } \rho_f = 2t_f/bw = 0.008128$$

$$bw = 250.00$$

$$\text{effective stress from (A.35), } f_{fe} = 757.2164$$

$$\alpha_{fy} = 0.00$$

$$\alpha_e = 0.00$$

$$b = 3000.00$$

$$h = 250.00$$

$$\text{From EC8 A4.4.3(6), } \rho_f = 2t_f/bw = 0.00067733$$

$$bw = 3000.00$$

$$\text{effective stress from (A.35), } f_{fe} = 954.4864$$

$$R = 40.00$$

$$\text{Effective FRP thickness, } t_f = NL * t * \cos(\beta_1) = 1.016$$

$$f_{u,f} = 1055.00$$

$$E_f = 64828.00$$

$$\alpha_{u,f} = 0.015$$

$$\alpha_e ((5.4d), \text{TB DY}) = (\alpha_e1 * A_{col1} + \alpha_e2 * A_{col2} + \alpha_e3 * A_{web}) / A_{sec} = 0.00$$

$$\alpha_e1 = 0.00$$

$$sh_1 = 150.00$$

$$bo_1 = 190.00$$

$$ho_1 = 540.00$$

$$bi2_1 = 655400.00$$

$$\alpha_e2 = 0.00$$

$$sh_2 = 150.00$$

$$bo_2 = 190.00$$

$$ho_2 = 540.00$$

$$bi2_2 = 655400.00$$

$$\alpha_e3 = 0 \text{ (grid does not provide confinement)}$$

$$\rho_{sh,\min} = \text{Min}(\rho_{sh,x}, \rho_{sh,y}) = 0.00069813$$

Expression ((5.4d), TB DY) for $\rho_{sh,\min}$ has been multiplied by 0.3 according to 15.7.1.3 for members without earthquake detailing (90° closed stirrups)

$$\rho_{sh,x} = \rho_{s1,x} + \rho_{s2,x} + \rho_{s3,x} = 0.00356047$$

$$\rho_{s1,x} \text{ (column 1)} = (A_{s1} * h_1 / s_1) / A_c = 0.00083776$$

$$h_1 = 600.00$$

$$A_{s1} = A_{stir1} * n_{s1} = 157.0796$$

$$\text{No stirrups, } n_{s1} = 2.00$$

$$\rho_{s2,x} \text{ (column 2)} = (A_{s2} * h_2 / s_2) / A_c = 0.00083776$$

$$h_2 = 600.00$$

$$A_{s2} = A_{stir2} * n_{s2} = 157.0796$$

$$\text{No stirrups, } n_{s2} = 2.00$$

$$\rho_{s3,x} \text{ (web)} = (A_{s3} * h_3 / s_3) / A_c = 0.00188496$$

$$h_3 = 1800.00$$

$$A_{s3} = A_{stir3} * n_{s3} = 0.00$$

$$\text{No stirrups, } n_{s3} = 2.00$$

$$\rho_{sh,y} = \rho_{s1,y} + \rho_{s2,y} + \rho_{s3,y} = 0.00069813$$

$$\rho_{s1,y} \text{ (column 1)} = (A_{s1} * h_1 / s_1) / A_c = 0.00034907$$

$h1 = 250.00$
 $As1 = Astir1 * ns1 = 157.0796$
 No stirups, $ns1 = 2.00$
 $ps2,y \text{ (column 2)} = (As2 * h2 / s_2) / Ac = 0.00034907$
 $h2 = 250.00$
 $As2 = Astir2 * ns2 = 157.0796$
 No stirups, $ns2 = 2.00$
 $ps3,y \text{ (web)} = (As3 * h3 / s_3) / Ac = 0.00$
 $h3 = 250.00$
 $As3 = Astir3 * ns3 = 157.0796$
 No stirups, $ns3 = 0.00$

 $Asec = 750000.00$

$s_1 = 150.00$

$s_2 = 150.00$

$s_3 = 200.00$

$fywe = 625.00$

$fce = 25.00$

From ((5.A5), TBDY), TBDY: $cc = 0.00202463$

$c = \text{confinement factor} = 1.00246$

$y1 = 0.00140044$

$sh1 = 0.0044814$

$ft1 = 420.1317$

$fy1 = 350.1097$

$su1 = 0.00512$

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
 and also multiplied by the shear_factor according to 15.7.1.4, with
 $\text{Shear_factor} = 1.00$

$lo/lou,min = lb/ld = 0.30$

$su1 = 0.4 * esu1_nominal \text{ ((5.5), TBDY)} = 0.032$

From table 5A.1, TBDY: $esu1_nominal = 0.08$,

For calculation of $esu1_nominal$ and $y1$, $sh1$, $ft1$, $fy1$, it is considered
 characteristic value $fsy1 = fs1/1.2$, from table 5.1, TBDY.

$y1$, $sh1$, $ft1$, $fy1$, are also multiplied by $\text{Min}(1, 1.25 * (lb/ld)^{2/3})$, from 10.3.5, ASCE 41-17.

with $fs1 = fs = 350.1097$

with $Es1 = Es = 200000.00$

$y2 = 0.00140044$

$sh2 = 0.0044814$

$ft2 = 420.1317$

$fy2 = 350.1097$

$su2 = 0.00512$

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
 and also multiplied by the shear_factor according to 15.7.1.4, with
 $\text{Shear_factor} = 1.00$

$lo/lou,min = lb/lb,min = 0.30$

$su2 = 0.4 * esu2_nominal \text{ ((5.5), TBDY)} = 0.032$

From table 5A.1, TBDY: $esu2_nominal = 0.08$,

For calculation of $esu2_nominal$ and $y2$, $sh2$, $ft2$, $fy2$, it is considered
 characteristic value $fsy2 = fs2/1.2$, from table 5.1, TBDY.

$y1$, $sh1$, $ft1$, $fy1$, are also multiplied by $\text{Min}(1, 1.25 * (lb/ld)^{2/3})$, from 10.3.5, ASCE 41-17.

with $fs2 = fs = 350.1097$

with $Es2 = Es = 200000.00$

$yv = 0.00140044$

$shv = 0.0044814$

$ftv = 420.1317$

$fyv = 350.1097$

$suv = 0.00512$

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
 and also multiplied by the shear_factor according to 15.7.1.4, with
 $\text{Shear_factor} = 1.00$

$lo/lou,min = lb/ld = 0.30$

$suv = 0.4 * esuv_nominal \text{ ((5.5), TBDY)} = 0.032$

From table 5A.1, TBDY: $esuv_nominal = 0.08$,

considering characteristic value $fsyv = fsv/1.2$, from table 5.1, TBDY
 For calculation of $esuv_nominal$ and yv , shv , ftv , fyv , it is considered

characteristic value $fsyv = fsv/1.2$, from table 5.1, TBDY.

$y1$, $sh1$, $ft1$, $fy1$, are also multiplied by $\text{Min}(1, 1.25 * (lb/ld)^{2/3})$, from 10.3.5, ASCE 41-17.

```

with fsv = fs = 350.1097
with Esv = Es = 200000.00
1 = Asl,ten/(b*d)*(fs1/fc) = 0.0635264
2 = Asl,com/(b*d)*(fs2/fc) = 0.0635264
v = Asl,mid/(b*d)*(fsv/fc) = 0.00
and confined core properties:
b = 2940.00
d = 178.00
d' = 12.00
fcc (5A.2, TBDY) = 25.06158
cc (5A.5, TBDY) = 0.00202463
c = confinement factor = 1.00246
1 = Asl,ten/(b*d)*(fs1/fc) = 0.07574806
2 = Asl,com/(b*d)*(fs2/fc) = 0.07574806
v = Asl,mid/(b*d)*(fsv/fc) = 0.00
Case/Assumption: Unconfined full section - Steel rupture
'satisfies Eq. (4.3)

```

```

--->
v < vs,y2 - LHS eq.(4.5) is satisfied
--->
su (4.9) = 0.18779572
Mu = MRc (4.14) = 2.0658E+008
u = su (4.1) = 3.0306889E-005

```

Calculation of ratio lb/d

Inadequate Lap Length with lb/d = 0.30

Calculation of Mu2-

Calculation of ultimate curvature ϕ_u according to 4.1, Biskinis/Fardis 2013:
 $\phi_u = 3.0889637E-005$
 $M_u = 2.4003E+008$

with full section properties:

```

b = 3000.00
d = 208.00
d' = 42.00
v = 0.00176852
N = 27588.841
fc = 25.00
co (5A.5, TBDY) = 0.002
Final value of  $\phi_u$ :  $\phi_u^* = \text{shear\_factor} * \text{Max}(\phi_u, \phi_c) = 0.0035$ 
The Shear_factor is considered equal to 1 (pure moment strength)
From (5.4b), TBDY:  $\phi_u = 0.0035$ 
 $\phi_{we} ((5.4c), TBDY) = a_{se} * \phi_{sh,min} * f_{ywe}/f_{ce} + \text{Min}(\phi_{fx}, \phi_{fy}) = 0.00$ 
where  $\phi_f = a_f * \phi_f * f_{fe}/f_{ce}$  is accounting for FRP contribution like EC8-part3 A.4.4.3(6)

```

```

fx = 0.00
af = 0.00
b = 250.00
h = 3000.00
From EC8 A.4.4.3(6),  $\phi_f = 2t_f/bw = 0.008128$ 
bw = 250.00
effective stress from (A.35),  $f_{fe} = 757.2164$ 

```

```

fy = 0.00
af = 0.00
b = 3000.00
h = 250.00
From EC8 A.4.4.3(6),  $\phi_f = 2t_f/bw = 0.00067733$ 
bw = 3000.00

```


effective stress from (A.35), $f_{f,e} = 954.4864$

$R = 40.00$

Effective FRP thickness, $t_f = NL \cdot t \cdot \cos(b_1) = 1.016$

$f_{u,f} = 1055.00$

$E_f = 64828.00$

$u_{,f} = 0.015$

$a_{se}((5.4d), TBDY) = (a_{se1} \cdot A_{col1} + a_{se2} \cdot A_{col2} + a_{se3} \cdot A_{web}) / A_{sec} = 0.00$

$a_{se1} = 0.00$

$sh_{,1} = 150.00$

$bo_{,1} = 190.00$

$ho_{,1} = 540.00$

$bi2_{,1} = 655400.00$

$a_{se2} = 0.00$

$sh_{,2} = 150.00$

$bo_{,2} = 190.00$

$ho_{,2} = 540.00$

$bi2_{,2} = 655400.00$

$a_{se3} = 0$ (grid does not provide confinement)

$p_{sh,min} = \min(p_{sh,x}, p_{sh,y}) = 0.00069813$

Expression ((5.4d), TBDY) for $p_{sh,min}$ has been multiplied by 0.3 according to 15.7.1.3 for members without earthquake detailing (90° closed stirrups)

$p_{sh,x} = p_{s1,x} + p_{s2,x} + p_{s3,x} = 0.00356047$

$p_{s1,x}$ (column 1) = $(A_{s1} \cdot h_1 / s_{,1}) / A_c = 0.00083776$

$h_1 = 600.00$

$A_{s1} = A_{stir1} \cdot n_{s1} = 157.0796$

No stirrups, $n_{s1} = 2.00$

$p_{s2,x}$ (column 2) = $(A_{s2} \cdot h_2 / s_{,2}) / A_c = 0.00083776$

$h_2 = 600.00$

$A_{s2} = A_{stir2} \cdot n_{s2} = 157.0796$

No stirrups, $n_{s2} = 2.00$

$p_{s3,x}$ (web) = $(A_{s3} \cdot h_3 / s_{,3}) / A_c = 0.00188496$

$h_3 = 1800.00$

$A_{s3} = A_{stir3} \cdot n_{s3} = 0.00$

No stirrups, $n_{s3} = 2.00$

$p_{sh,y} = p_{s1,y} + p_{s2,y} + p_{s3,y} = 0.00069813$

$p_{s1,y}$ (column 1) = $(A_{s1} \cdot h_1 / s_{,1}) / A_c = 0.00034907$

$h_1 = 250.00$

$A_{s1} = A_{stir1} \cdot n_{s1} = 157.0796$

No stirrups, $n_{s1} = 2.00$

$p_{s2,y}$ (column 2) = $(A_{s2} \cdot h_2 / s_{,2}) / A_c = 0.00034907$

$h_2 = 250.00$

$A_{s2} = A_{stir2} \cdot n_{s2} = 157.0796$

No stirrups, $n_{s2} = 2.00$

$p_{s3,y}$ (web) = $(A_{s3} \cdot h_3 / s_{,3}) / A_c = 0.00$

$h_3 = 250.00$

$A_{s3} = A_{stir3} \cdot n_{s3} = 157.0796$

No stirrups, $n_{s3} = 0.00$

$A_{sec} = 750000.00$

$s_{,1} = 150.00$

$s_{,2} = 150.00$

$s_{,3} = 200.00$

$f_{ywe} = 625.00$

$f_{ce} = 25.00$

From ((5.A5), TBDY), TBDY: $cc = 0.00202463$

c = confinement factor = 1.00246

$y_1 = 0.00140044$

$sh_1 = 0.0044814$

$ft_1 = 420.1317$

$fy_1 = 350.1097$

$su_1 = 0.00512$

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00

$l_o/l_{ou,min} = l_b/l_d = 0.30$
 $su_1 = 0.4 \cdot esu_{1,nominal} ((5.5), TBDY) = 0.032$
 From table 5A.1, TBDY: $esu_{1,nominal} = 0.08$,
 For calculation of $esu_{1,nominal}$ and y_1, sh_1, ft_1, fy_1 , it is considered
 characteristic value $fsy_1 = fs_1/1.2$, from table 5.1, TBDY.
 y_1, sh_1, ft_1, fy_1 , are also multiplied by $\text{Min}(1, 1.25 \cdot (l_b/l_d)^{2/3})$, from 10.3.5, ASCE 41-17.
 with $fs_1 = fs = 350.1097$
 with $Es_1 = Es = 200000.00$
 $y_2 = 0.00140044$
 $sh_2 = 0.0044814$
 $ft_2 = 420.1317$
 $fy_2 = 350.1097$
 $su_2 = 0.00512$
 using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
 and also multiplied by the shear_factor according to 15.7.1.4, with
 Shear_factor = 1.00
 $l_o/l_{ou,min} = l_b/l_{b,min} = 0.30$
 $su_2 = 0.4 \cdot esu_{2,nominal} ((5.5), TBDY) = 0.032$
 From table 5A.1, TBDY: $esu_{2,nominal} = 0.08$,
 For calculation of $esu_{2,nominal}$ and y_2, sh_2, ft_2, fy_2 , it is considered
 characteristic value $fsy_2 = fs_2/1.2$, from table 5.1, TBDY.
 y_1, sh_1, ft_1, fy_1 , are also multiplied by $\text{Min}(1, 1.25 \cdot (l_b/l_d)^{2/3})$, from 10.3.5, ASCE 41-17.
 with $fs_2 = fs = 350.1097$
 with $Es_2 = Es = 200000.00$
 $y_v = 0.00140044$
 $sh_v = 0.0044814$
 $ft_v = 420.1317$
 $fy_v = 350.1097$
 $suv = 0.00512$
 using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
 and also multiplied by the shear_factor according to 15.7.1.4, with
 Shear_factor = 1.00
 $l_o/l_{ou,min} = l_b/l_d = 0.30$
 $suv = 0.4 \cdot esuv_{nominal} ((5.5), TBDY) = 0.032$
 From table 5A.1, TBDY: $esuv_{nominal} = 0.08$,
 considering characteristic value $fsyv = fsv/1.2$, from table 5.1, TBDY
 For calculation of $esuv_{nominal}$ and y_v, sh_v, ft_v, fy_v , it is considered
 characteristic value $fsyv = fsv/1.2$, from table 5.1, TBDY.
 y_1, sh_1, ft_1, fy_1 , are also multiplied by $\text{Min}(1, 1.25 \cdot (l_b/l_d)^{2/3})$, from 10.3.5, ASCE 41-17.
 with $fsv = fs = 350.1097$
 with $Esv = Es = 200000.00$
 $1 = Asl_{ten}/(b \cdot d) \cdot (fs_1/f_c) = 0.0635264$
 $2 = Asl_{com}/(b \cdot d) \cdot (fs_2/f_c) = 0.0635264$
 $v = Asl_{mid}/(b \cdot d) \cdot (fsv/f_c) = 0.03609935$

and confined core properties:

$b = 2940.00$
 $d = 178.00$
 $d' = 12.00$
 $f_{cc} (5A.2, TBDY) = 25.06158$
 $cc (5A.5, TBDY) = 0.00202463$
 $c = \text{confinement factor} = 1.00246$
 $1 = Asl_{ten}/(b \cdot d) \cdot (fs_1/f_c) = 0.07574806$
 $2 = Asl_{com}/(b \cdot d) \cdot (fs_2/f_c) = 0.07574806$
 $v = Asl_{mid}/(b \cdot d) \cdot (fsv/f_c) = 0.0430444$

Case/Assumption: Unconfined full section - Steel rupture

' satisfies Eq. (4.3)

--->

$v < v_{s,y2}$ - LHS eq.(4.5) is satisfied

--->

$su (4.9) = 0.20311835$
 $Mu = MRc (4.14) = 2.4003E+008$
 $u = su (4.1) = 3.0889637E-005$

Calculation of ratio l_b/l_d

Inadequate Lap Length with $l_b/l_d = 0.30$

Calculation of Shear Strength $V_r = \text{Min}(V_{r1}, V_{r2}) = 1.0244\text{E}+006$

Calculation of Shear Strength at edge 1, $V_{r1} = 1.0244\text{E}+006$

From (22.5.1.1) and 11.5.4.3, ACI 318-14: $V_{r1} = V_n < 0.83 \cdot f_c' \cdot 0.5 \cdot h \cdot d$

NOTE: In expression (22.5.1.1) 'Vw' is replaced by 'Vw + f * Vf' where Vf is the contribution of FRPs (11.3), ACI 440).

From Table (11.5.4.6(d-e)), ACI 318-14: $V_c = 815517.768$

$\mu_u / \mu_u - l_w / 2 = 0.00 \leq 0$

= 1 (normal-weight concrete)

$f_c' = 25.00$, but $f_c'^{0.5} \leq 8.3$ MPa (22.5.3.1, ACI 318-14)

$h = 3000.00$

$d = 200.00$

$l_w = 250.00$

$\mu_u = 3.7289358\text{E}-011$

$\mu_u = 1.7354940\text{E}-029$

$\mu_u = 27588.841$

From (11.5.4.8), ACI 318-14: $V_s = V_{s1} + V_{s2} + V_{s3} = 104719.755$

$V_{s1} = 52359.878$ is calculated for pseudo-Column 1, with:

$d = 200.00$

$A_v = 157079.633$

$s = 150.00$

$f_y = 500.00$

V_{s1} has been multiplied by $2(1-s/d)$ ($s > d/2$, according to ASCE 41-17,10.3.4)

$2(1-s/d) = 0.50$

$V_{s2} = 52359.878$ is calculated for pseudo-Column 2, with:

$d = 200.00$

$A_v = 157079.633$

$s = 150.00$

$f_y = 500.00$

V_{s2} has been multiplied by $2(1-s/d)$ ($s > d/2$, according to ASCE 41-17,10.3.4)

$2(1-s/d) = 0.50$

$V_{s3} = 0.00$ is calculated for web, with:

$d = 200.00$

$A_v = 0.00$

$s = 200.00$

$f_y = 500.00$

V_{s3} has been multiplied by $2(1-s/d)$ ($s > d/2$, according to ASCE 41-17,10.3.4)

$2(1-s/d) = 0.00$

V_f ((11-3)-(11.4), ACI 440) = 109599.773

$f = 0.95$, for fully-wrapped sections

$w_f / s_f = 1$ (FRP strips adjacent to one another).

In (11.3) $\sin + \cos$ is replaced with $(\cot + \cot a) \sin a$ which is more a generalised expression,

where a is the angle of the crack direction (see KANEPE).

This later relation, considered as a function $V_f(,)$, is implemented for every different fiber orientation a_i , as well as for 2 crack directions, $a = 45^\circ$ and $a = -45^\circ$ to take into consideration the cyclic seismic loading.

orientation 1: $a_1 = b_1 + 90^\circ = 90.00$

$V_f = \text{Min}(|V_f(45, a_1)|, |V_f(-45, a_1)|)$, with:

total thickness per orientation, $t_{f1} = N_L \cdot t / N_{oDir} = 1.016$

$d_{fv} = d$ (figure 11.2, ACI 440) = 208.00

f_{fe} ((11-5), ACI 440) = 259.312

$E_f = 64828.00$

$f_e = 0.004$, from (11.6a), ACI 440

with $f_u = 0.01$

From (11-11), ACI 440: $V_s + V_f \leq 1.9929\text{E}+006$

$b_w = 3000.00$

Calculation of Shear Strength at edge 2, $V_{r2} = 1.0244\text{E}+006$

From (22.5.1.1) and 11.5.4.3, ACI 318-14: $V_{r2} = V_n < 0.83 \cdot f_c' \cdot 0.5 \cdot h \cdot d$

NOTE: In expression (22.5.1.1) 'Vw' is replaced by 'Vw + f * Vf' where Vf is the contribution of FRPs (11.3), ACI 440).

From Table (11.5.4.6(d-e)), ACI 318-14: $V_c = 815517.768$

$M_u/V_u - l_w/2 = 0.00 \leq 0$

$= 1$ (normal-weight concrete)

$f_c' = 25.00$, but $f_c'^{0.5} \leq 8.3$ MPa (22.5.3.1, ACI 318-14)

$h = 3000.00$

$d = 200.00$

$l_w = 250.00$

$M_u = 3.7289358E-011$

$V_u = 1.7354940E-029$

$N_u = 27588.841$

From (11.5.4.8), ACI 318-14: $V_s = V_{s1} + V_{s2} + V_{s3} = 104719.755$

$V_{s1} = 52359.878$ is calculated for pseudo-Column 1, with:

$d = 200.00$

$A_v = 157079.633$

$s = 150.00$

$f_y = 500.00$

V_{s1} has been multiplied by $2(1-s/d)$ ($s > d/2$, according to ASCE 41-17,10.3.4)

$2(1-s/d) = 0.50$

$V_{s2} = 52359.878$ is calculated for pseudo-Column 2, with:

$d = 200.00$

$A_v = 157079.633$

$s = 150.00$

$f_y = 500.00$

V_{s2} has been multiplied by $2(1-s/d)$ ($s > d/2$, according to ASCE 41-17,10.3.4)

$2(1-s/d) = 0.50$

$V_{s3} = 0.00$ is calculated for web, with:

$d = 200.00$

$A_v = 0.00$

$s = 200.00$

$f_y = 500.00$

V_{s3} has been multiplied by $2(1-s/d)$ ($s > d/2$, according to ASCE 41-17,10.3.4)

$2(1-s/d) = 0.00$

V_f ((11-3)-(11.4), ACI 440) = 109599.773

$f = 0.95$, for fully-wrapped sections

$w_f/s_f = 1$ (FRP strips adjacent to one another).

In (11.3) $\sin + \cos$ is replaced with $(\cot + \cot a)\sin a$ which is more a generalised expression,

where a is the angle of the crack direction (see KANEPE).

This later relation, considered as a function $V_f(\theta, a)$, is implemented for every different fiber orientation a_i , as well as for 2 crack directions, $\theta = 45^\circ$ and $\theta = -45^\circ$ to take into consideration the cyclic seismic loading.

orientation 1: $\theta = \theta_1 + 90^\circ = 90.00$

$V_f = \text{Min}(|V_f(45, \theta_1)|, |V_f(-45, a_1)|)$, with:

total thickness per orientation, $t_{f1} = N_L \cdot t / N_{\text{Dir}} = 1.016$

$d_{fv} = d$ (figure 11.2, ACI 440) = 208.00

f_{fe} ((11-5), ACI 440) = 259.312

$E_f = 64828.00$

$f_e = 0.004$, from (11.6a), ACI 440

with $f_u = 0.01$

From (11-11), ACI 440: $V_s + V_f \leq 1.9929E+006$

$b_w = 3000.00$

End Of Calculation of Shear Capacity ratio for element: wall W1 of floor 1

At local axis: 2

Start Of Calculation of Chord Rotation Capacity for element: wall W1 of floor 1

At local axis: 2

Integration Section: (a)

Section Type: rcrcws

Constant Properties

Knowledge Factor, $\gamma = 1.00$

According to 10.7.2.3, ASCE 41-17, shear walls with
transverse reinforcement percentage, $\rho_n < 0.0015$

are considered Force-Controlled and lower-bound strengths are used according to 7.5.1.3, ASCE 41-17
 $n = 0.00069813$

with $n = ps1 + ps2 + ps3$, being the shear reinf. ratio in a plane perpendicular to the shear axis 3
(pseudo-col.1 $ps1 = As1*b1/s1 = (As1*h1/s1) / Ac = 0.00034907$
 $h1 = 250.00$
 $s1 = 150.00$
total area of hoops perpendicular to shear axis, $As1 = 157.0796$
(pseudo-col.2 $ps2 = As2*b2/s2 = (As2*h2/s2) / Ac = 0.00034907$
 $h2 = 250.00$
 $s2 = 150.00$
total area of hoops perpendicular to shear axis, $As2 = 157.0796$
(grid $ps3 = As3*b3/s3 = (As3*h3/s3) / Ac = 0.00$
 $h3 = 250.00$
 $s3 = 200.00$
total area of hoops perpendicular to shear axis, $As3 = 0.00$
total section area, $Ac = 750000.00$

Consequently:

New material of Secondary Member: Concrete Strength, $fc = fc_lower_bound = 25.00$
New material of Secondary Member: Steel Strength, $fs = fs_lower_bound = 500.00$
Concrete Elasticity, $Ec = 26999.444$
Steel Elasticity, $Es = 200000.00$
Total Height, $H_{tot} = 3000.00$
Edges Width, $W_{edg} = 250.00$
Edges Height, $H_{edg} = 600.00$
Web Width, $W_{web} = 250.00$
Cover Thickness, $c = 25.00$
Element Length, $L = 3000.00$
Secondary Member
Smooth Bars
Ductile Steel
Without Detailing for Earthquake Resistance (including stirrups not closed at 135°)
Longitudinal Bars With Ends Lapped Starting at the End Sections
Inadequate Lap Length with $lb/ld = 0.30$
FRP Wrapping Data
Type: Carbon
Cured laminate properties (design values)
Thickness, $t = 1.016$
Tensile Strength, $ffu = 1055.00$
Tensile Modulus, $E_f = 64828.00$
Elongation, $efu = 0.01$
Number of directions, $NoDir = 1$
Fiber orientations, $bi: 0.00^\circ$
Number of layers, $NL = 1$
Radius of rounding corners, $R = 40.00$

Stepwise Properties

Axial Force, $F = -31026.87$
Longitudinal Reinforcement Area Distribution (in 2 divisions)
-Tension: $As_{lt} = 0.00$
-Compression: $As_{lc} = 7269.645$
Longitudinal Reinforcement Area Distribution (in 3 divisions)
-Tension: $As_{l,ten} = 2865.133$
-Compression: $As_{l,com} = 2865.133$
-Middle: $As_{l,mid} = 1539.38$
Mean Diameter of Tension Reinforcement, $DbL = 17.33333$

Considering wall controlled by Shear (shear control ratio > 1),
interstorey drift provided values are calculated
New component: From table 7-7, ASCE 41_17: Final chord rotation Capacity $u_R = 1.0^*$ $u = 0.015$
from table 10-20: $u = 0.015$

with:

- Condition i (shear wall and wall segments)
- $(A_s - A_s') \cdot f_y + P) / (t_w \cdot l_w \cdot f_c') = -0.19220244$
 - $A_s = 0.00$
 - $A_s' = 7269.645$
 - $f_y = 500.00$
 - $P = 31026.87$
 - $t_w = 250.00$
 - $l_w = 3000.00$
 - $f_c = 25.00$

End Of Calculation of Chord Rotation Capacity for element: wall W1 of floor 1

At local axis: 2

Integration Section: (a)

Calculation No. 15

wall W1, Floor 1

Limit State: Life Safety (data interpolation between analysis steps 1 and 2)

Analysis: Uniform +X

Check: Shear capacity VR_d

Edge: End

Local Axis: (3)



Start Of Calculation of Shear Capacity for element: wall W1 of floor 1

At local axis: 3

Integration Section: (d)

Section Type: rcrws

Constant Properties

Knowledge Factor, = 1.00

Member Shear Force is generally considered as Force-Controlled Action according to Table C7-1, ASCE 41-17.

Lower-bound strengths are used for Force-Controlled Actions according to 7.5.1.3, ASCE 41-17

Consequently:

New material of Secondary Member: Concrete Strength, $f_c = f_{c_lower_bound} = 25.00$

New material of Secondary Member: Steel Strength, $f_s = f_{s_lower_bound} = 500.00$

Concrete Elasticity, $E_c = 26999.444$

Steel Elasticity, $E_s = 200000.00$

Total Height, $H_{tot} = 3000.00$

Edges Width, $W_{edg} = 250.00$

Edges Height, $H_{edg} = 600.00$

Web Width, $W_{web} = 250.00$

Cover Thickness, $c = 25.00$

Element Length, $L = 3000.00$

Secondary Member

Smooth Bars

Ductile Steel

Without Detailing for Earthquake Resistance (including stirrups not closed at 135°)

Longitudinal Bars With Ends Lapped Starting at the End Sections

Inadequate Lap Length with $l_o/l_{ou,min} = l_b/l_d = 0.30$

FRP Wrapping Data

Type: Carbon

Cured laminate properties (design values)

Thickness, $t = 1.016$

Tensile Strength, $f_{fu} = 1055.00$

Tensile Modulus, $E_f = 64828.00$

Elongation, $\epsilon_{fu} = 0.01$

Number of directions, $N_{oDir} = 1$

Fiber orientations, $b_i: 0.00^\circ$

Number of layers, $N_L = 1$

Radius of rounding corners, $R = 40.00$

Stepwise Properties

EDGE -A-

Bending Moment, $M_a = 6.1793E+007$

Shear Force, $V_a = -20889.844$

EDGE -B-

Bending Moment, $M_b = 889554.947$

Shear Force, $V_b = 20889.844$

BOTH EDGES

Axial Force, $F = -31026.87$

Longitudinal Reinforcement Area Distribution (in 2 divisions)

-Tension: $A_{sl,t} = 0.00$

-Compression: $A_{sl,c} = 7269.645$

Longitudinal Reinforcement Area Distribution (in 3 divisions)

-Tension: $A_{sl,ten} = 2865.133$

-Compression: $A_{sl,com} = 2865.133$

-Middle: $A_{sl,mid} = 1539.38$

Mean Diameter of Tension Reinforcement, $D_{bL,ten} = 17.33333$

New component: From table 7-7, ASCE 41_17: Final Shear Capacity $V_R = 1.0 \cdot V_n = 2.4900E+006$

From (22.5.1.1) and 11.5.4.3, ACI 318-14: $V_n < 0.83 \cdot f_c' \cdot 0.5 \cdot h \cdot d = 2.4900E+006$

NOTE: In expression (22.5.1.1) ' V_w ' is replaced by ' $V_w + f \cdot V_f$ '
where V_f is the contribution of FRPs (11.3), ACI 440).

From Table (11.5.4.6(d-e)), ACI 318-14: $V_c = 816205.374$

$\mu_u / \mu_u - l_w / 2 = -1457.417 \leq 0$

= 1 (normal-weight concrete)

$f_c' = 25.00$, but $f_c' \cdot 0.5 \leq 8.3 \text{ MPa}$ (22.5.3.1, ACI 318-14)

$h = 250.00$

$d = 2400.00$

$l_w = 3000.00$

$\mu_u = 889554.947$

$V_u = 20889.844$
 $N_u = 31026.87$
 From (11.5.4.8), ACI 318-14: $V_s = V_{s1} + V_{s2} + V_{s3} = 1.0681E+006$
 $V_{s1} = 251327.412$ is calculated for pseudo-Column 1, with:
 $d = 480.00$
 $A_v = 157079.633$
 $s = 150.00$
 $f_y = 500.00$
 V_{s1} has been multiplied by 1 ($s < d/2$, according to ASCE 41-17,10.3.4)
 $V_{s2} = 251327.412$ is calculated for pseudo-Column 2, with:
 $d = 480.00$
 $A_v = 157079.633$
 $s = 150.00$
 $f_y = 500.00$
 V_{s2} has been multiplied by 1 ($s < d/2$, according to ASCE 41-17,10.3.4)
 $V_{s3} = 565486.678$ is calculated for web, with:
 $d = 1440.00$
 $A_v = 157079.633$
 $s = 200.00$
 $f_y = 500.00$
 V_{s3} has been multiplied by 1 ($s < d/2$, according to ASCE 41-17,10.3.4)
 $V_f ((11-3)-(11.4), ACI 440) = 1.5581E+006$
 $f = 0.95$, for fully-wrapped sections
 $w_f/s_f = 1$ (FRP strips adjacent to one another).
 In (11.3) $\sin + \cos$ is replaced with $(\cot + \cot a)\sin a$ which is more a generalised expression,
 where a is the angle of the crack direction (see KANEPE).
 This later relation, considered as a function $V_f(,)$, is implemented for every different fiber orientation a_i ,
 as well as for 2 crack directions, $a = 45^\circ$ and $a = -45^\circ$ to take into consideration the cyclic seismic loading.
 orientation 1: $a_1 = b_1 + 90^\circ = 90.00$
 $V_f = \text{Min}(|V_f(45, a_1)|, |V_f(-45, a_1)|)$, with:
 total thickness per orientation, $t_{f1} = NL \cdot t / \text{NoDir} = 1.016$
 $d_{fv} = d$ (figure 11.2, ACI 440) = 2957.00
 $f_{fe} ((11-5), ACI 440) = 259.312$
 $E_f = 64828.00$
 $f_e = 0.004$, from (11.6a), ACI 440
 with $f_u = 0.01$
 From (11-11), ACI 440: $V_s + V_f \leq 1.9929E+006$
 $b_w = 250.00$

 End Of Calculation of Shear Capacity for element: wall W1 of floor 1
 At local axis: 3
 Integration Section: (d)

Calculation No. 16

wall W1, Floor 1
 Limit State: Life Safety (data interpolation between analysis steps 1 and 2)
 Analysis: Uniform +X
 Check: Chord rotation capacity (ϕ_r)
 Edge: End
 Local Axis: (3)



Start Of Calculation of Shear Capacity ratio for element: wall W1 of floor 1

At Shear local axis: 3

(Bending local axis: 2)

Section Type: rcwrs

Constant Properties

Knowledge Factor, $\gamma = 1.00$

Mean strength values are used for both shear and moment calculations.

Consequently:

New material of Secondary Member: Concrete Strength, $f_c = f_{cm} = 25.00$

New material of Secondary Member: Steel Strength, $f_s = f_{sm} = 500.00$

Concrete Elasticity, $E_c = 26999.444$

Steel Elasticity, $E_s = 200000.00$

#####

Note: Especially for the calculation of moment strengths,

the above steel re-bar strengths are multiplied by 1.25 according to R18.6.5, ACI 318-14

New material: Steel Strength, $f_s = 1.25 \cdot f_{sm} = 625.00$

#####

Total Height, $H_{tot} = 3000.00$

Edges Width, $W_{edg} = 250.00$

Edges Height, $H_{edg} = 600.00$

Web Width, $W_{web} = 250.00$

Cover Thickness, $c = 25.00$

Mean Confinement Factor overall section = 1.00246

Element Length, $L = 3000.00$

Secondary Member

Smooth Bars

Ductile Steel

Without Detailing for Earthquake Resistance (including stirrups not closed at 135°)

Longitudinal Bars With Ends Lapped Starting at the End Sections

Inadequate Lap Length with $l_o/l_{ou,min} = 0.30$

FRP Wrapping Data

Type: Carbon

Cured laminate properties (design values)

Thickness, $t = 1.016$

Tensile Strength, $f_{fu} = 1055.00$

Tensile Modulus, $E_f = 64828.00$

Elongation, $\epsilon_{fu} = 0.01$

Number of directions, $NoDir = 1$

Fiber orientations, $b_i: 0.00^\circ$

Number of layers, $NL = 1$

Radius of rounding corners, $R = 40.00$

Stepwise Properties

At local axis: 3

EDGE -A-

Shear Force, $V_a = 1.0097420E-028$

EDGE -B-

Shear Force, $V_b = -1.0097420E-028$

BOTH EDGES

Axial Force, $F = -27588.841$

Longitudinal Reinforcement Area Distribution (in 2 divisions)

-Tension: $As_t = 0.00$

-Compression: $As_c = 7269.645$

Longitudinal Reinforcement Area Distribution (in 3 divisions)

-Tension: $As_{t,ten} = 2865.133$

-Compression: $As_{c,com} = 2865.133$

-Middle: $As_{mid} = 0.00$

(According to 10.7.2.3 As_{mid} is setted equal to zero)

Calculation of Shear Capacity ratio, $V_e/V_r = 1.02813$

Member Controlled by Shear ($V_e/V_r > 1$)

Calculation of Shear Demand from fig. R18.6.5, ACI 318-14 $V_e = (M_{pr1} + M_{pr2})/l_n = 2.5600E+006$ with

$M_{pr1} = \text{Max}(Mu_{1+}, Mu_{1-}) = 3.8401E+009$

$Mu_{1+} = 3.3585E+009$, is the ultimate moment strength at the edge 1 of the member in the actual moment direction which is defined for the static loading combination

$Mu_{1-} = 3.8401E+009$, is the ultimate moment strength at the edge 1 of the member in the opposite moment direction which is defined for the static loading combination

$M_{pr2} = \text{Max}(Mu_{2+}, Mu_{2-}) = 3.8401E+009$

$Mu_{2+} = 3.3585E+009$, is the ultimate moment strength at the edge 2 of the member in the actual moment direction which is defined for the static loading combination

$Mu_{2-} = 3.8401E+009$, is the ultimate moment strength at the edge 2 of the member in the opposite moment direction which is defined for the static loading combination

Calculation of Mu_{1+}

Calculation of ultimate curvature ϕ_u according to 4.1, Biskinis/Fardis 2013:

$\phi_u = 2.0296703E-006$

$M_u = 3.3585E+009$

with full section properties:

$b = 250.00$

$d = 2957.00$

$d' = 43.00$

$v = 0.0014928$

$N = 27588.841$

$f_c = 25.00$

ϕ_c (5A.5, TBDY) = 0.002

Final value of ϕ_u : $\phi_u^* = \text{shear_factor} * \text{Max}(\phi_u, \phi_c) = 0.0035$

The Shear_factor is considered equal to 1 (pure moment strength)

From (5.4b), TBDY: $\phi_u = 0.0035$

ϕ_{we} ((5.4c), TBDY) = $a s_e * \phi_{sh,min} * f_{ywe} / f_{ce} + \text{Min}(\phi_x, \phi_y) = 0.00$

where $\phi_f = a f * \phi_f * f_{fe} / f_{ce}$ is accounting for FRP contribution like EC8-part3 A.4.4.3(6)

$\phi_x = 0.00$

$a f = 0.00$

$b = 250.00$

$h = 3000.00$

From EC8 A.4.4.3(6), $\phi_f = 2 t_f / b_w = 0.008128$

$b_w = 250.00$

effective stress from (A.35), $f_{fe} = 757.2164$

$\phi_y = 0.00$

$a f = 0.00$

$b = 3000.00$

$h = 250.00$

From EC8 A.4.4.3(6), $\phi_f = 2 t_f / b_w = 0.00067733$

$b_w = 3000.00$

effective stress from (A.35), $f_{fe} = 954.4864$

$R = 40.00$
 Effective FRP thickness, $t_f = NL \cdot t \cdot \cos(b_1) = 1.016$
 $f_{u,f} = 1055.00$
 $E_f = 64828.00$
 $u_f = 0.015$
 $ase((5.4d), TBDY) = (ase_1 \cdot A_{col1} + ase_2 \cdot A_{col2} + ase_3 \cdot A_{web}) / A_{sec} = 0.00$
 $ase_1 = 0.00$
 $sh_1 = 150.00$
 $bo_1 = 190.00$
 $ho_1 = 540.00$
 $bi2_1 = 655400.00$
 $ase_2 = 0.00$
 $sh_2 = 150.00$
 $bo_2 = 190.00$
 $ho_2 = 540.00$
 $bi2_2 = 655400.00$
 $ase_3 = 0$ (grid does not provide confinement)
 $psh,min = \min(psh,x, psh,y) = 0.00069813$

Expression ((5.4d), TBDY) for psh,min has been multiplied by 0.3 according to 15.7.1.3 for members without earthquake detailing (90° closed stirrups)

$psh,x = ps1,x + ps2,x + ps3,x = 0.00356047$
 $ps1,x$ (column 1) = $(As1 \cdot h1 / s_1) / A_c = 0.00083776$
 $h1 = 600.00$
 $As1 = Astir1 \cdot ns1 = 157.0796$
 No stirrups, $ns1 = 2.00$
 $ps2,x$ (column 2) = $(As2 \cdot h2 / s_2) / A_c = 0.00083776$
 $h2 = 600.00$
 $As2 = Astir2 \cdot ns2 = 157.0796$
 No stirrups, $ns2 = 2.00$
 $ps3,x$ (web) = $(As3 \cdot h3 / s_3) / A_c = 0.00188496$
 $h3 = 1800.00$
 $As3 = Astir3 \cdot ns3 = 0.00$
 No stirrups, $ns3 = 2.00$

$psh,y = ps1,y + ps2,y + ps3,y = 0.00069813$
 $ps1,y$ (column 1) = $(As1 \cdot h1 / s_1) / A_c = 0.00034907$
 $h1 = 250.00$
 $As1 = Astir1 \cdot ns1 = 157.0796$
 No stirrups, $ns1 = 2.00$
 $ps2,y$ (column 2) = $(As2 \cdot h2 / s_2) / A_c = 0.00034907$
 $h2 = 250.00$
 $As2 = Astir2 \cdot ns2 = 157.0796$
 No stirrups, $ns2 = 2.00$
 $ps3,y$ (web) = $(As3 \cdot h3 / s_3) / A_c = 0.00$
 $h3 = 250.00$
 $As3 = Astir3 \cdot ns3 = 157.0796$
 No stirrups, $ns3 = 0.00$

$A_{sec} = 750000.00$
 $s_1 = 150.00$
 $s_2 = 150.00$
 $s_3 = 200.00$

$f_{ywe} = 625.00$
 $f_{ce} = 25.00$

From ((5.A5), TBDY), TBDY: $cc = 0.00202463$
 c = confinement factor = 1.00246

$y1 = 0.00140044$
 $sh1 = 0.0044814$

$ft1 = 420.1317$
 $fy1 = 350.1097$

$su1 = 0.00512$

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
 and also multiplied by the shear_factor according to 15.7.1.4, with
 $Shear_factor = 1.00$
 $lo/lo,min = lb/ld = 0.30$

```

su1 = 0.4*esu1_nominal ((5.5), TBDY) = 0.032
From table 5A.1, TBDY: esu1_nominal = 0.08,
For calculation of esu1_nominal and y1, sh1,ft1,fy1, it is considered
characteristic value fsy1 = fs1/1.2, from table 5.1, TBDY.
y1, sh1,ft1,fy1, are also multiplied by Min(1,1.25*(lb/ld)^ 2/3), from 10.3.5, ASCE 41-17.
with fs1 = fs = 350.1097
with Es1 = Es = 200000.00
y2 = 0.00140044
sh2 = 0.0044814
ft2 = 420.1317
fy2 = 350.1097
su2 = 0.00512
using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00
lo/lou,min = lb/lb,min = 0.30
su2 = 0.4*esu2_nominal ((5.5), TBDY) = 0.032
From table 5A.1, TBDY: esu2_nominal = 0.08,
For calculation of esu2_nominal and y2, sh2,ft2,fy2, it is considered
characteristic value fsy2 = fs2/1.2, from table 5.1, TBDY.
y1, sh1,ft1,fy1, are also multiplied by Min(1,1.25*(lb/ld)^ 2/3), from 10.3.5, ASCE 41-17.
with fs2 = fs = 350.1097
with Es2 = Es = 200000.00
yv = 0.00140044
shv = 0.0044814
ftv = 420.1317
fyv = 350.1097
suv = 0.00512
using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00
lo/lou,min = lb/ld = 0.30
suv = 0.4*esuv_nominal ((5.5), TBDY) = 0.032
From table 5A.1, TBDY: esuv_nominal = 0.08,
considering characteristic value fsyv = fsv/1.2, from table 5.1, TBDY
For calculation of esuv_nominal and yv, shv,ftv,fyv, it is considered
characteristic value fsyv = fsv/1.2, from table 5.1, TBDY.
y1, sh1,ft1,fy1, are also multiplied by Min(1,1.25*(lb/ld)^ 2/3), from 10.3.5, ASCE 41-17.
with fsv = fs = 350.1097
with Esv = Es = 200000.00
1 = Asl,ten/(b*d)*(fs1/fc) = 0.05427722
2 = Asl,com/(b*d)*(fs2/fc) = 0.05427722
v = Asl,mid/(b*d)*(fsv/fc) = 0.00

```

and confined core properties:

```

b = 190.00
d = 2927.00
d' = 13.00
fcc (5A.2, TBDY) = 25.06158
cc (5A.5, TBDY) = 0.00202463
c = confinement factor = 1.00246
1 = Asl,ten/(b*d)*(fs1/fc) = 0.07214938
2 = Asl,com/(b*d)*(fs2/fc) = 0.07214938
v = Asl,mid/(b*d)*(fsv/fc) = 0.00

```

Case/Assumption: Unconfined full section - Steel rupture
 ' satisfies Eq. (4.3)

```

--->
v < vs,y2 - LHS eq.(4.5) is satisfied
--->
su (4.9) = 0.14691336
Mu = MRc (4.14) = 3.3585E+009
u = su (4.1) = 2.0296703E-006

```

Calculation of ratio lb/ld

Inadequate Lap Length with lb/ld = 0.30

Calculation of Mu1-

Calculation of ultimate curvature ϕ_u according to 4.1, Biskinis/Fardis 2013:

$$u = 2.0532423E-006$$

$$Mu = 3.8401E+009$$

with full section properties:

$$b = 250.00$$

$$d = 2957.00$$

$$d' = 43.00$$

$$v = 0.0014928$$

$$N = 27588.841$$

$$f_c = 25.00$$

$$c_o \text{ (5A.5, TBDY)} = 0.002$$

$$\text{Final value of } c_u: c_u^* = \text{shear_factor} * \text{Max}(c_u, c_o) = 0.0035$$

The Shear_factor is considered equal to 1 (pure moment strength)

$$\text{From (5.4b), TBDY: } c_u = 0.0035$$

$$w_e \text{ ((5.4c), TBDY)} = a_{se} * s_{h,min} * f_{ywe} / f_{ce} + \text{Min}(f_x, f_y) = 0.00$$

where $f = a_f * p_f * f_{fe} / f_{ce}$ is accounting for FRP contribution like EC8-part3 A.4.4.3(6)

$$f_x = 0.00$$

$$a_f = 0.00$$

$$b = 250.00$$

$$h = 3000.00$$

$$\text{From EC8 A.4.4.3(6), } p_f = 2t_f / b_w = 0.008128$$

$$b_w = 250.00$$

$$\text{effective stress from (A.35), } f_{fe} = 757.2164$$

$$f_y = 0.00$$

$$a_f = 0.00$$

$$b = 3000.00$$

$$h = 250.00$$

$$\text{From EC8 A.4.4.3(6), } p_f = 2t_f / b_w = 0.00067733$$

$$b_w = 3000.00$$

$$\text{effective stress from (A.35), } f_{fe} = 954.4864$$

$$R = 40.00$$

$$\text{Effective FRP thickness, } t_f = N L * t * \cos(b_1) = 1.016$$

$$f_{u,f} = 1055.00$$

$$E_f = 64828.00$$

$$u_{,f} = 0.015$$

$$a_{se} \text{ ((5.4d), TBDY)} = (a_{se1} * A_{col1} + a_{se2} * A_{col2} + a_{se3} * A_{web}) / A_{sec} = 0.00$$

$$a_{se1} = 0.00$$

$$s_{h,1} = 150.00$$

$$b_{o,1} = 190.00$$

$$h_{o,1} = 540.00$$

$$b_{i2,1} = 655400.00$$

$$a_{se2} = 0.00$$

$$s_{h,2} = 150.00$$

$$b_{o,2} = 190.00$$

$$h_{o,2} = 540.00$$

$$b_{i2,2} = 655400.00$$

$$a_{se3} = 0 \text{ (grid does not provide confinement)}$$

$$p_{sh,min} = \text{Min}(p_{sh,x}, p_{sh,y}) = 0.00069813$$

Expression ((5.4d), TBDY) for $p_{sh,min}$ has been multiplied by 0.3 according to 15.7.1.3 for members without earthquake detailing (90° closed stirrups)

$$p_{sh,x} = p_{s1,x} + p_{s2,x} + p_{s3,x} = 0.00356047$$

$$p_{s1,x} \text{ (column 1)} = (A_{s1} * h_1 / s_{,1}) / A_c = 0.00083776$$

$$h_1 = 600.00$$

$$A_{s1} = A_{stir1} * n_{s1} = 157.0796$$

$$\text{No stirrups, } n_{s1} = 2.00$$

$$p_{s2,x} \text{ (column 2)} = (A_{s2} * h_2 / s_{,2}) / A_c = 0.00083776$$

$h_2 = 600.00$
 $As_2 = Astir_2 * ns_2 = 157.0796$
 No stirups, $ns_2 = 2.00$
 $ps_{3,x} (web) = (As_3 * h_3 / s_3) / Ac = 0.00188496$
 $h_3 = 1800.00$
 $As_3 = Astir_3 * ns_3 = 0.00$
 No stirups, $ns_3 = 2.00$

$psh,y = ps_1,y + ps_2,y + ps_3,y = 0.00069813$
 $ps_{1,y} (column\ 1) = (As_1 * h_1 / s_1) / Ac = 0.00034907$
 $h_1 = 250.00$
 $As_1 = Astir_1 * ns_1 = 157.0796$
 No stirups, $ns_1 = 2.00$
 $ps_{2,y} (column\ 2) = (As_2 * h_2 / s_2) / Ac = 0.00034907$
 $h_2 = 250.00$
 $As_2 = Astir_2 * ns_2 = 157.0796$
 No stirups, $ns_2 = 2.00$
 $ps_{3,y} (web) = (As_3 * h_3 / s_3) / Ac = 0.00$
 $h_3 = 250.00$
 $As_3 = Astir_3 * ns_3 = 157.0796$
 No stirups, $ns_3 = 0.00$

$A_{sec} = 750000.00$
 $s_1 = 150.00$
 $s_2 = 150.00$
 $s_3 = 200.00$
 $fy_{we} = 625.00$
 $f_{ce} = 25.00$
 From ((5.A.5), TBDY), TBDY: $cc = 0.00202463$
 $c = \text{confinement factor} = 1.00246$
 $y_1 = 0.00140044$
 $sh_1 = 0.0044814$
 $ft_1 = 420.1317$
 $fy_1 = 350.1097$
 $su_1 = 0.00512$
 using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
 and also multiplied by the shear_factor according to 15.7.1.4, with
 $Shear_factor = 1.00$
 $lo/lou,min = lb/l_d = 0.30$
 $su_1 = 0.4 * esu_{1_nominal} ((5.5), TBDY) = 0.032$
 From table 5A.1, TBDY: $esu_{1_nominal} = 0.08$,
 For calculation of $esu_{1_nominal}$ and y_1, sh_1, ft_1, fy_1 , it is considered
 characteristic value $fsy_1 = fs_1 / 1.2$, from table 5.1, TBDY.
 y_1, sh_1, ft_1, fy_1 , are also multiplied by $\text{Min}(1, 1.25 * (lb/l_d)^{2/3})$, from 10.3.5, ASCE 41-17.
 with $fs_1 = fs = 350.1097$
 with $Es_1 = Es = 200000.00$
 $y_2 = 0.00140044$
 $sh_2 = 0.0044814$
 $ft_2 = 420.1317$
 $fy_2 = 350.1097$
 $su_2 = 0.00512$
 using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
 and also multiplied by the shear_factor according to 15.7.1.4, with
 $Shear_factor = 1.00$
 $lo/lou,min = lb/l_b,min = 0.30$
 $su_2 = 0.4 * esu_{2_nominal} ((5.5), TBDY) = 0.032$
 From table 5A.1, TBDY: $esu_{2_nominal} = 0.08$,
 For calculation of $esu_{2_nominal}$ and y_2, sh_2, ft_2, fy_2 , it is considered
 characteristic value $fsy_2 = fs_2 / 1.2$, from table 5.1, TBDY.
 y_1, sh_1, ft_1, fy_1 , are also multiplied by $\text{Min}(1, 1.25 * (lb/l_d)^{2/3})$, from 10.3.5, ASCE 41-17.
 with $fs_2 = fs = 350.1097$
 with $Es_2 = Es = 200000.00$
 $y_v = 0.00140044$
 $sh_v = 0.0044814$
 $ft_v = 420.1317$
 $fy_v = 350.1097$
 $su_v = 0.00512$

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
 and also multiplied by the shear_factor according to 15.7.1.4, with
 Shear_factor = 1.00
 $l_o/l_{ou,min} = l_b/l_d = 0.30$
 $suv = 0.4 * esuv_{nominal} ((5.5), TBDY) = 0.032$
 From table 5A.1, TBDY: $esuv_{nominal} = 0.08$,
 considering characteristic value $fsyv = fsv/1.2$, from table 5.1, TBDY
 For calculation of $esuv_{nominal}$ and yv, shv,ftv,fyv , it is considered
 characteristic value $fsyv = fsv/1.2$, from table 5.1, TBDY.
 $y1, sh1,ft1,fy1$, are also multiplied by $Min(1,1.25*(l_b/l_d)^{2/3})$, from 10.3.5, ASCE 41-17.
 with $fsv = fs = 350.1097$
 with $Esv = Es = 200000.00$
 $1 = Asl_{ten}/(b*d)*(fs1/fc) = 0.05427722$
 $2 = Asl_{com}/(b*d)*(fs2/fc) = 0.05427722$
 $v = Asl_{mid}/(b*d)*(fsv/fc) = 0.0291621$

and confined core properties:

$b = 190.00$
 $d = 2927.00$
 $d' = 13.00$
 $fcc (5A.2, TBDY) = 25.06158$
 $cc (5A.5, TBDY) = 0.00202463$
 $c = \text{confinement factor} = 1.00246$
 $1 = Asl_{ten}/(b*d)*(fs1/fc) = 0.07214938$
 $2 = Asl_{com}/(b*d)*(fs2/fc) = 0.07214938$
 $v = Asl_{mid}/(b*d)*(fsv/fc) = 0.03876447$

Case/Assumption: Unconfined full section - Steel rupture
 ' satisfies Eq. (4.3)

--->
 $v < v_{s,y2}$ - LHS eq.(4.5) is satisfied
 --->
 $su (4.9) = 0.15670711$
 $Mu = MRc (4.14) = 3.8401E+009$
 $u = su (4.1) = 2.0532423E-006$

Calculation of ratio l_b/l_d

Inadequate Lap Length with $l_b/l_d = 0.30$

Calculation of $Mu2+$

Calculation of ultimate curvature u according to 4.1, Biskinis/Fardis 2013:

$u = 2.0296703E-006$
 $Mu = 3.3585E+009$

with full section properties:

$b = 250.00$
 $d = 2957.00$
 $d' = 43.00$
 $v = 0.0014928$
 $N = 27588.841$
 $fc = 25.00$
 $co (5A.5, TBDY) = 0.002$
 Final value of cu : $cu^* = \text{shear_factor} * \text{Max}(cu, cc) = 0.0035$
 The Shear_factor is considered equal to 1 (pure moment strength)
 From (5.4b), TBDY: $cu = 0.0035$
 $we ((5.4c), TBDY) = ase * sh_{min} * fy_{we}/f_{ce} + \text{Min}(fx, fy) = 0.00$
 where $f = af * pf * f_{fe}/f_{ce}$ is accounting for FRP contribution like EC8-part3 A.4.4.3(6)

 $fx = 0.00$
 $af = 0.00$
 $b = 250.00$
 $h = 3000.00$

From EC8 A4.4.3(6), $pf = 2tf/bw = 0.008128$
 $bw = 250.00$
effective stress from (A.35), $ff,e = 757.2164$

$f_y = 0.00$
 $a_f = 0.00$
 $b = 3000.00$
 $h = 250.00$
From EC8 A4.4.3(6), $pf = 2tf/bw = 0.00067733$
 $bw = 3000.00$
effective stress from (A.35), $ff,e = 954.4864$

$R = 40.00$
Effective FRP thickness, $tf = NL*t*Cos(b1) = 1.016$
 $f_{u,f} = 1055.00$
 $E_f = 64828.00$
 $u_f = 0.015$
 $ase((5.4d), TBDY) = (ase1*A_{col1} + ase2*A_{col2} + ase3*A_{web})/A_{sec} = 0.00$
 $ase1 = 0.00$
 $sh_1 = 150.00$
 $bo_1 = 190.00$
 $ho_1 = 540.00$
 $bi2_1 = 655400.00$
 $ase2 = 0.00$
 $sh_2 = 150.00$
 $bo_2 = 190.00$
 $ho_2 = 540.00$
 $bi2_2 = 655400.00$

$ase3 = 0$ (grid does not provide confinement)
 $psh,min = Min(psh,x, psh,y) = 0.00069813$

Expression ((5.4d), TBDY) for psh,min has been multiplied by 0.3 according to 15.7.1.3 for members without earthquake detailing (90° closed stirrups)

$psh,x = ps1,x + ps2,x + ps3,x = 0.00356047$
 $ps1,x$ (column 1) = $(As1*h1/s_1)/Ac = 0.00083776$
 $h1 = 600.00$
 $As1 = Astir1*ns1 = 157.0796$
No stirrups, $ns1 = 2.00$
 $ps2,x$ (column 2) = $(As2*h2/s_2)/Ac = 0.00083776$
 $h2 = 600.00$
 $As2 = Astir2*ns2 = 157.0796$
No stirrups, $ns2 = 2.00$
 $ps3,x$ (web) = $(As3*h3/s_3)/Ac = 0.00188496$
 $h3 = 1800.00$
 $As3 = Astir3*ns3 = 0.00$
No stirrups, $ns3 = 2.00$

$psh,y = ps1,y + ps2,y + ps3,y = 0.00069813$
 $ps1,y$ (column 1) = $(As1*h1/s_1)/Ac = 0.00034907$
 $h1 = 250.00$
 $As1 = Astir1*ns1 = 157.0796$
No stirrups, $ns1 = 2.00$
 $ps2,y$ (column 2) = $(As2*h2/s_2)/Ac = 0.00034907$
 $h2 = 250.00$
 $As2 = Astir2*ns2 = 157.0796$
No stirrups, $ns2 = 2.00$
 $ps3,y$ (web) = $(As3*h3/s_3)/Ac = 0.00$
 $h3 = 250.00$
 $As3 = Astir3*ns3 = 157.0796$
No stirrups, $ns3 = 0.00$

$A_{sec} = 750000.00$
 $s_1 = 150.00$
 $s_2 = 150.00$
 $s_3 = 200.00$
 $f_{ywe} = 625.00$
 $f_{ce} = 25.00$

From ((5.A.5), TBDY), TBDY: $cc = 0.00202463$
 $c = \text{confinement factor} = 1.00246$
 $y1 = 0.00140044$
 $sh1 = 0.0044814$
 $ft1 = 420.1317$
 $fy1 = 350.1097$
 $su1 = 0.00512$
 using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
 and also multiplied by the shear_factor according to 15.7.1.4, with
 Shear_factor = 1.00
 $lo/lou,min = lb/ld = 0.30$
 $su1 = 0.4 * esu1_nominal ((5.5), TBDY) = 0.032$
 From table 5A.1, TBDY: $esu1_nominal = 0.08$,
 For calculation of $esu1_nominal$ and $y1, sh1, ft1, fy1$, it is considered
 characteristic value $fsy1 = fs1/1.2$, from table 5.1, TBDY.
 $y1, sh1, ft1, fy1$, are also multiplied by $\text{Min}(1, 1.25 * (lb/ld)^{2/3})$, from 10.3.5, ASCE 41-17.
 with $fs1 = fs = 350.1097$
 with $Es1 = Es = 200000.00$
 $y2 = 0.00140044$
 $sh2 = 0.0044814$
 $ft2 = 420.1317$
 $fy2 = 350.1097$
 $su2 = 0.00512$
 using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
 and also multiplied by the shear_factor according to 15.7.1.4, with
 Shear_factor = 1.00
 $lo/lou,min = lb/lb,min = 0.30$
 $su2 = 0.4 * esu2_nominal ((5.5), TBDY) = 0.032$
 From table 5A.1, TBDY: $esu2_nominal = 0.08$,
 For calculation of $esu2_nominal$ and $y2, sh2, ft2, fy2$, it is considered
 characteristic value $fsy2 = fs2/1.2$, from table 5.1, TBDY.
 $y1, sh1, ft1, fy1$, are also multiplied by $\text{Min}(1, 1.25 * (lb/ld)^{2/3})$, from 10.3.5, ASCE 41-17.
 with $fs2 = fs = 350.1097$
 with $Es2 = Es = 200000.00$
 $yv = 0.00140044$
 $shv = 0.0044814$
 $ftv = 420.1317$
 $fyv = 350.1097$
 $suv = 0.00512$
 using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
 and also multiplied by the shear_factor according to 15.7.1.4, with
 Shear_factor = 1.00
 $lo/lou,min = lb/ld = 0.30$
 $suv = 0.4 * esuv_nominal ((5.5), TBDY) = 0.032$
 From table 5A.1, TBDY: $esuv_nominal = 0.08$,
 considering characteristic value $fsyv = fsv/1.2$, from table 5.1, TBDY
 For calculation of $esuv_nominal$ and yv, shv, ftv, fyv , it is considered
 characteristic value $fsyv = fsv/1.2$, from table 5.1, TBDY.
 $y1, sh1, ft1, fy1$, are also multiplied by $\text{Min}(1, 1.25 * (lb/ld)^{2/3})$, from 10.3.5, ASCE 41-17.
 with $fsv = fs = 350.1097$
 with $Esv = Es = 200000.00$
 $1 = Asl,ten/(b*d)*(fs1/fc) = 0.05427722$
 $2 = Asl,com/(b*d)*(fs2/fc) = 0.05427722$
 $v = Asl,mid/(b*d)*(fsv/fc) = 0.00$
 and confined core properties:
 $b = 190.00$
 $d = 2927.00$
 $d' = 13.00$
 $fcc (5A.2, TBDY) = 25.06158$
 $cc (5A.5, TBDY) = 0.00202463$
 $c = \text{confinement factor} = 1.00246$
 $1 = Asl,ten/(b*d)*(fs1/fc) = 0.07214938$
 $2 = Asl,com/(b*d)*(fs2/fc) = 0.07214938$
 $v = Asl,mid/(b*d)*(fsv/fc) = 0.00$
 Case/Assumption: Unconfined full section - Steel rupture
 ' satisfies Eq. (4.3)

--->

$v < v_{s,y2}$ - LHS eq.(4.5) is satisfied

---->

$$s_u(4.9) = 0.14691336$$

$$\mu_u = M_{Rc}(4.14) = 3.3585E+009$$

$$u = s_u(4.1) = 2.0296703E-006$$

Calculation of ratio I_b/I_d

Inadequate Lap Length with $I_b/I_d = 0.30$

Calculation of μ_{u2} -

Calculation of ultimate curvature κ_u according to 4.1, Biskinis/Fardis 2013:

$$\kappa_u = 2.0532423E-006$$

$$\mu_u = 3.8401E+009$$

with full section properties:

$$b = 250.00$$

$$d = 2957.00$$

$$d' = 43.00$$

$$v = 0.0014928$$

$$N = 27588.841$$

$$f_c = 25.00$$

$$\alpha_{co}(5A.5, TBDY) = 0.002$$

$$\text{Final value of } \kappa_u: \kappa_u^* = \text{shear_factor} * \text{Max}(\kappa_u, \alpha_{co}) = 0.0035$$

The Shear_factor is considered equal to 1 (pure moment strength)

$$\text{From (5.4b), TBDY: } \kappa_u = 0.0035$$

$$\omega_{se}((5.4c), TBDY) = \alpha_{se} * \text{sh}_{min} * f_{ywe}/f_{ce} + \text{Min}(f_x, f_y) = 0.00$$

where $f = \alpha_f * p_f * f_{fe}/f_{ce}$ is accounting for FRP contribution like EC8-part3 A.4.4.3(6)

$$f_x = 0.00$$

$$\alpha_f = 0.00$$

$$b = 250.00$$

$$h = 3000.00$$

$$\text{From EC8 A4.4.3(6), } p_f = 2t_f/bw = 0.008128$$

$$bw = 250.00$$

$$\text{effective stress from (A.35), } f_{fe} = 757.2164$$

$$f_y = 0.00$$

$$\alpha_f = 0.00$$

$$b = 3000.00$$

$$h = 250.00$$

$$\text{From EC8 A4.4.3(6), } p_f = 2t_f/bw = 0.00067733$$

$$bw = 3000.00$$

$$\text{effective stress from (A.35), } f_{fe} = 954.4864$$

$$R = 40.00$$

$$\text{Effective FRP thickness, } t_f = NL * t * \cos(\beta_1) = 1.016$$

$$f_{u,f} = 1055.00$$

$$E_f = 64828.00$$

$$u_{,f} = 0.015$$

$$\alpha_{se}((5.4d), TBDY) = (\alpha_{se1} * A_{col1} + \alpha_{se2} * A_{col2} + \alpha_{se3} * A_{web}) / A_{sec} = 0.00$$

$$\alpha_{se1} = 0.00$$

$$sh_1 = 150.00$$

$$bo_1 = 190.00$$

$$ho_1 = 540.00$$

$$bi2_1 = 655400.00$$

$$\alpha_{se2} = 0.00$$

$$sh_2 = 150.00$$

$$bo_2 = 190.00$$

$$ho_2 = 540.00$$

$$bi2_2 = 655400.00$$

ase3 = 0 (grid does not provide confinement)
 psh,min = Min(psh,x , psh,y) = 0.00069813
 Expression ((5.4d), TBDY) for psh,min has been multiplied by 0.3 according to 15.7.1.3 for members without earthquake detailing (90° closed stirrups)

psh,x = ps1,x+ps2,x+ps3,x = 0.00356047
 ps1,x (column 1) = (As1*h1/s_1)/Ac = 0.00083776
 h1 = 600.00
 As1 = Astir1*ns1 = 157.0796
 No stirrups, ns1 = 2.00
 ps2,x (column 2) = (As2*h2/s_2)/Ac = 0.00083776
 h2 = 600.00
 As2 = Astir2*ns2 = 157.0796
 No stirrups, ns2 = 2.00
 ps3,x (web) = (As3*h3/s_3)/Ac = 0.00188496
 h3 = 1800.00
 As3 = Astir3*ns3 = 0.00
 No stirrups, ns3 = 2.00

psh,y = ps1,y+ps2,y+ps3,y = 0.00069813
 ps1,y (column 1) = (As1*h1/s_1)/Ac = 0.00034907
 h1 = 250.00
 As1 = Astir1*ns1 = 157.0796
 No stirrups, ns1 = 2.00
 ps2,y (column 2) = (As2*h2/s_2)/Ac = 0.00034907
 h2 = 250.00
 As2 = Astir2*ns2 = 157.0796
 No stirrups, ns2 = 2.00
 ps3,y (web) = (As3*h3/s_3)/Ac = 0.00
 h3 = 250.00
 As3 = Astir3*ns3 = 157.0796
 No stirrups, ns3 = 0.00

Asec = 750000.00
 s_1 = 150.00
 s_2 = 150.00
 s_3 = 200.00
 fywe = 625.00
 fce = 25.00
 From ((5.A5), TBDY), TBDY: cc = 0.00202463
 c = confinement factor = 1.00246
 y1 = 0.00140044
 sh1 = 0.0044814
 ft1 = 420.1317
 fy1 = 350.1097
 su1 = 0.00512
 using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
 and also multiplied by the shear_factor according to 15.7.1.4, with
 Shear_factor = 1.00
 lo/lou,min = lb/lb = 0.30
 su1 = 0.4*esu1_nominal ((5.5), TBDY) = 0.032
 From table 5A.1, TBDY: esu1_nominal = 0.08,
 For calculation of esu1_nominal and y1, sh1,ft1,fy1, it is considered
 characteristic value fsy1 = fs1/1.2, from table 5.1, TBDY.
 y1, sh1,ft1,fy1, are also multiplied by Min(1,1.25*(lb/lb)^ 2/3), from 10.3.5, ASCE 41-17.
 with fs1 = fs = 350.1097
 with Es1 = Es = 200000.00
 y2 = 0.00140044
 sh2 = 0.0044814
 ft2 = 420.1317
 fy2 = 350.1097
 su2 = 0.00512
 using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
 and also multiplied by the shear_factor according to 15.7.1.4, with
 Shear_factor = 1.00
 lo/lou,min = lb/lb,min = 0.30
 su2 = 0.4*esu2_nominal ((5.5), TBDY) = 0.032

From table 5A.1, TBDY: $es_{u2_nominal} = 0.08$,
For calculation of $es_{u2_nominal}$ and y_2 , sh_2, ft_2, fy_2 , it is considered
characteristic value $fs_{y2} = fs_2/1.2$, from table 5.1, TBDY.
 y_1 , sh_1, ft_1, fy_1 , are also multiplied by $\text{Min}(1, 1.25 \cdot (lb/d)^{2/3})$, from 10.3.5, ASCE 41-17.
with $fs_2 = fs = 350.1097$
with $Es_2 = Es = 200000.00$
 $y_v = 0.00140044$
 $sh_v = 0.0044814$
 $ft_v = 420.1317$
 $fy_v = 350.1097$
 $s_{uv} = 0.00512$
using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00
 $lo/lou, min = lb/d = 0.30$
 $s_{uv} = 0.4 \cdot es_{uv_nominal} ((5.5), TBDY) = 0.032$
From table 5A.1, TBDY: $es_{uv_nominal} = 0.08$,
considering characteristic value $fs_{yv} = fs_v/1.2$, from table 5.1, TBDY
For calculation of $es_{uv_nominal}$ and y_v , sh_v, ft_v, fy_v , it is considered
characteristic value $fs_{yv} = fs_v/1.2$, from table 5.1, TBDY.
 y_1 , sh_1, ft_1, fy_1 , are also multiplied by $\text{Min}(1, 1.25 \cdot (lb/d)^{2/3})$, from 10.3.5, ASCE 41-17.
with $fs_v = fs = 350.1097$
with $Es_v = Es = 200000.00$
 $1 = Asl, ten / (b \cdot d) \cdot (fs_1 / fc) = 0.05427722$
 $2 = Asl, com / (b \cdot d) \cdot (fs_2 / fc) = 0.05427722$
 $v = Asl, mid / (b \cdot d) \cdot (fs_v / fc) = 0.0291621$
and confined core properties:
 $b = 190.00$
 $d = 2927.00$
 $d' = 13.00$
 $f_{cc} (5A.2, TBDY) = 25.06158$
 $cc (5A.5, TBDY) = 0.00202463$
 $c = \text{confinement factor} = 1.00246$
 $1 = Asl, ten / (b \cdot d) \cdot (fs_1 / fc) = 0.07214938$
 $2 = Asl, com / (b \cdot d) \cdot (fs_2 / fc) = 0.07214938$
 $v = Asl, mid / (b \cdot d) \cdot (fs_v / fc) = 0.03876447$
Case/Assumption: Unconfined full section - Steel rupture
'satisfies Eq. (4.3)
--->
 $v < v_{s,y2}$ - LHS eq.(4.5) is satisfied
--->
 $su (4.9) = 0.15670711$
 $Mu = MRc (4.14) = 3.8401E+009$
 $u = su (4.1) = 2.0532423E-006$

Calculation of ratio lb/d

Inadequate Lap Length with $lb/d = 0.30$

Calculation of Shear Strength $V_r = \text{Min}(V_{r1}, V_{r2}) = 2.4900E+006$

Calculation of Shear Strength at edge 1, $V_{r1} = 2.4900E+006$
From (22.5.1.1) and 11.5.4.3, ACI 318-14: $V_{r1} = V_n < 0.83 \cdot fc' \cdot 0.5 \cdot h \cdot d$

NOTE: In expression (22.5.1.1) ' V_w ' is replaced by ' $V_w + f \cdot V_f$ '
where V_f is the contribution of FRPs (11.3), ACI 440).

From Table (11.5.4.6(d-e)), ACI 318-14: $V_c = 815517.768$
 $Mu / Vu - lw / 2 = 0.00 \leq 0$
= 1 (normal-weight concrete)
 $fc' = 25.00$, but $fc' \cdot 0.5 \leq 8.3 \text{ MPa}$ (22.5.3.1, ACI 318-14)
 $h = 250.00$
 $d = 2400.00$

$l_w = 3000.00$
 $\mu_u = 1.1486927E-009$
 $\mu_u = 1.0097420E-028$
 $\mu_u = 27588.841$
 From (11.5.4.8), ACI 318-14: $V_s = V_{s1} + V_{s2} + V_{s3} = 1.0681E+006$
 $V_{s1} = 251327.412$ is calculated for pseudo-Column 1, with:
 $d = 480.00$
 $A_v = 157079.633$
 $s = 150.00$
 $f_y = 500.00$
 V_{s1} has been multiplied by 1 ($s < d/2$, according to ASCE 41-17,10.3.4)
 $V_{s2} = 251327.412$ is calculated for pseudo-Column 2, with:
 $d = 480.00$
 $A_v = 157079.633$
 $s = 150.00$
 $f_y = 500.00$
 V_{s2} has been multiplied by 1 ($s < d/2$, according to ASCE 41-17,10.3.4)
 $V_{s3} = 565486.678$ is calculated for web, with:
 $d = 1440.00$
 $A_v = 157079.633$
 $s = 200.00$
 $f_y = 500.00$
 V_{s3} has been multiplied by 1 ($s < d/2$, according to ASCE 41-17,10.3.4)
 V_f ((11-3)-(11.4), ACI 440) = $1.5581E+006$
 $f = 0.95$, for fully-wrapped sections
 $w_f/s_f = 1$ (FRP strips adjacent to one another).
 In (11.3) $\sin + \cos$ is replaced with $(\cot + \cot a)\sin a$ which is more a generalised expression,
 where a is the angle of the crack direction (see KANEPE).
 This later relation, considered as a function $V_f(,)$, is implemented for every different fiber orientation a_i ,
 as well as for 2 crack directions, $a = 45^\circ$ and $a = -45^\circ$ to take into consideration the cyclic seismic loading.
 orientation 1: $a_1 = b_1 + 90^\circ = 90.00$
 $V_f = \text{Min}(|V_f(45, 1)|, |V_f(-45, a_1)|)$, with:
 total thickness per orientation, $t_{f1} = N_L \cdot t / N_oDir = 1.016$
 $d_{fv} = d$ (figure 11.2, ACI 440) = 2957.00
 f_{fe} ((11-5), ACI 440) = 259.312
 $E_f = 64828.00$
 $f_e = 0.004$, from (11.6a), ACI 440
 with $f_u = 0.01$
 From (11-11), ACI 440: $V_s + V_f \leq 1.9929E+006$
 $b_w = 250.00$

Calculation of Shear Strength at edge 2, $V_{r2} = 2.4900E+006$
 From (22.5.1.1) and 11.5.4.3, ACI 318-14: $V_{r2} = V_n < 0.83 \cdot f_c'^{0.5} \cdot h \cdot d$

NOTE: In expression (22.5.1.1) ' V_w ' is replaced by ' $V_w + f \cdot V_f$ '
 where V_f is the contribution of FRPs (11.3), ACI 440).

From Table (11.5.4.6(d-e)), ACI 318-14: $V_c = 815517.768$
 $\mu_u / \mu_u - l_w / 2 = 0.00 \leq 0$
 $= 1$ (normal-weight concrete)
 $f_c' = 25.00$, but $f_c'^{0.5} \leq 8.3$ MPa (22.5.3.1, ACI 318-14)
 $h = 250.00$
 $d = 2400.00$
 $l_w = 3000.00$
 $\mu_u = 1.1486927E-009$
 $\mu_u = 1.0097420E-028$
 $\mu_u = 27588.841$
 From (11.5.4.8), ACI 318-14: $V_s = V_{s1} + V_{s2} + V_{s3} = 1.0681E+006$
 $V_{s1} = 251327.412$ is calculated for pseudo-Column 1, with:
 $d = 480.00$
 $A_v = 157079.633$
 $s = 150.00$
 $f_y = 500.00$
 V_{s1} has been multiplied by 1 ($s < d/2$, according to ASCE 41-17,10.3.4)
 $V_{s2} = 251327.412$ is calculated for pseudo-Column 2, with:
 $d = 480.00$
 $A_v = 157079.633$

$s = 150.00$
 $f_y = 500.00$
 V_{s2} has been multiplied by 1 ($s < d/2$, according to ASCE 41-17,10.3.4)
 $V_{s3} = 565486.678$ is calculated for web, with:
 $d = 1440.00$
 $A_v = 157079.633$
 $s = 200.00$
 $f_y = 500.00$
 V_{s3} has been multiplied by 1 ($s < d/2$, according to ASCE 41-17,10.3.4)
 $V_f ((11-3)-(11.4), \text{ACI 440}) = 1.5581\text{E}+006$
 $f = 0.95$, for fully-wrapped sections
 $w_f/s_f = 1$ (FRP strips adjacent to one another).
 In (11.3) $\sin + \cos$ is replaced with $(\cot + \cot a)\sin a$ which is more a generalised expression,
 where a is the angle of the crack direction (see KANEPE).
 This later relation, considered as a function $V_f(\theta)$, is implemented for every different fiber orientation a_i ,
 as well as for 2 crack directions, $\theta = 45^\circ$ and $\theta = -45^\circ$ to take into consideration the cyclic seismic loading.
 orientation 1: $\theta_1 = b_1 + 90^\circ = 90.00$
 $V_f = \text{Min}(|V_f(45, \theta_1)|, |V_f(-45, a_1)|)$, with:
 total thickness per orientation, $t_{f1} = N_L * t / \text{NoDir} = 1.016$
 $d_{fv} = d$ (figure 11.2, ACI 440) = 2957.00
 $f_{fe} ((11-5), \text{ACI 440}) = 259.312$
 $E_f = 64828.00$
 $f_e = 0.004$, from (11.6a), ACI 440
 with $f_u = 0.01$
 From (11-11), ACI 440: $V_s + V_f \leq 1.9929\text{E}+006$
 $b_w = 250.00$

 End Of Calculation of Shear Capacity ratio for element: wall W1 of floor 1
 At local axis: 3

 Start Of Calculation of Shear Capacity ratio for element: wall W1 of floor 1
 At Shear local axis: 2
 (Bending local axis: 3)
 Section Type: rcrcws

Constant Properties

 Knowledge Factor, $K = 1.00$
 Mean strength values are used for both shear and moment calculations.
 Consequently:
 New material of Secondary Member: Concrete Strength, $f_c = f_{cm} = 25.00$
 New material of Secondary Member: Steel Strength, $f_s = f_{sm} = 500.00$
 Concrete Elasticity, $E_c = 26999.444$
 Steel Elasticity, $E_s = 200000.00$
 #####
 Note: Especially for the calculation of moment strengths,
 the above steel re-bar strengths are multiplied by 1.25 according to R18.6.5, ACI 318-14
 New material: Steel Strength, $f_s = 1.25 * f_{sm} = 625.00$
 #####
 Total Height, $H_{tot} = 3000.00$
 Edges Width, $W_{edg} = 250.00$
 Edges Height, $H_{edg} = 600.00$
 Web Width, $W_{web} = 250.00$
 Cover Thickness, $c = 25.00$
 Mean Confinement Factor overall section = 1.00246
 Element Length, $L = 3000.00$
 Secondary Member
 Smooth Bars
 Ductile Steel
 Without Detailing for Earthquake Resistance (including stirrups not closed at 135°)
 Longitudinal Bars With Ends Lapped Starting at the End Sections
 Inadequate Lap Length with $l_o/l_{ou,min} = 0.30$
 FRP Wrapping Data
 Type: Carbon

Cured laminate properties (design values)

Thickness, $t = 1.016$

Tensile Strength, $f_{fu} = 1055.00$

Tensile Modulus, $E_f = 64828.00$

Elongation, $\epsilon_{fu} = 0.01$

Number of directions, $NoDir = 1$

Fiber orientations, $b_i = 0.00^\circ$

Number of layers, $NL = 1$

Radius of rounding corners, $R = 40.00$

Stepwise Properties

At local axis: 2

EDGE -A-

Shear Force, $V_a = 1.7354940E-029$

EDGE -B-

Shear Force, $V_b = -1.7354940E-029$

BOTH EDGES

Axial Force, $F = -27588.841$

Longitudinal Reinforcement Area Distribution (in 2 divisions)

-Tension: $As_t = 0.00$

-Compression: $As_c = 7269.645$

Longitudinal Reinforcement Area Distribution (in 3 divisions)

-Tension: $As_{t,ten} = 2830.575$

-Compression: $As_{l,com} = 2830.575$

-Middle: $As_{l,mid} = 0.00$

(According to 10.7.2.3 $As_{l,mid}$ is setted equal to zero)

Calculation of Shear Capacity ratio, $V_e/V_r = 0.15621236$

Member Controlled by Flexure ($V_e/V_r < 1$)

Calculation of Shear Demand from fig. R18.6.5, ACI 318-14 $V_e = (M_{pr1} + M_{pr2})/l_n = 160017.271$

with

$M_{pr1} = \text{Max}(\mu_{u1+}, \mu_{u1-}) = 2.4003E+008$

$\mu_{u1+} = 2.0658E+008$, is the ultimate moment strength at the edge 1 of the member in the actual moment direction which is defined for the static loading combination

$\mu_{u1-} = 2.4003E+008$, is the ultimate moment strength at the edge 1 of the member in the opposite moment direction which is defined for the static loading combination

$M_{pr2} = \text{Max}(\mu_{u2+}, \mu_{u2-}) = 2.4003E+008$

$\mu_{u2+} = 2.0658E+008$, is the ultimate moment strength at the edge 2 of the member in the actual moment direction which is defined for the static loading combination

$\mu_{u2-} = 2.4003E+008$, is the ultimate moment strength at the edge 2 of the member in the opposite moment direction which is defined for the static loading combination

Calculation of μ_{u1+}

Calculation of ultimate curvature ϕ_u according to 4.1, Biskinis/Fardis 2013:

$\phi_u = 3.0306889E-005$

$\mu_u = 2.0658E+008$

with full section properties:

$b = 3000.00$

$d = 208.00$

$d' = 42.00$

$v = 0.00176852$

$N = 27588.841$

$f_c = 25.00$

ϕ_o (5A.5, TBDY) = 0.002

Final value of ϕ_u : $\phi_u^* = \text{shear_factor} * \text{Max}(\phi_u, \phi_o) = 0.0035$

The Shear_factor is considered equal to 1 (pure moment strength)

From (5.4b), TBDY: $\phi_u = 0.0035$

we ((5.4c), TBDY) = $a_{se} \cdot \frac{sh_{min} \cdot f_{ywe}}{f_{ce}} + \min(f_x, f_y) = 0.00$
where $f = a_f \cdot p_f \cdot f_{fe} / f_{ce}$ is accounting for FRP contribution like EC8-part3 A.4.4.3(6)

$f_x = 0.00$
 $a_f = 0.00$
 $b = 250.00$
 $h = 3000.00$
From EC8 A.4.4.3(6), $p_f = 2t_f/bw = 0.008128$
 $bw = 250.00$
effective stress from (A.35), $f_{fe} = 757.2164$

$f_y = 0.00$
 $a_f = 0.00$
 $b = 3000.00$
 $h = 250.00$
From EC8 A.4.4.3(6), $p_f = 2t_f/bw = 0.00067733$
 $bw = 3000.00$
effective stress from (A.35), $f_{fe} = 954.4864$

$R = 40.00$
Effective FRP thickness, $t_f = NL \cdot t \cdot \cos(b_1) = 1.016$
 $f_{u,f} = 1055.00$
 $E_f = 64828.00$
 $u_{,f} = 0.015$
 $a_{se} ((5.4d), TBDY) = (a_{se1} \cdot A_{col1} + a_{se2} \cdot A_{col2} + a_{se3} \cdot A_{web}) / A_{sec} = 0.00$
 $a_{se1} = 0.00$
 $sh_1 = 150.00$
 $bo_1 = 190.00$
 $ho_1 = 540.00$
 $bi2_1 = 655400.00$
 $a_{se2} = 0.00$
 $sh_2 = 150.00$
 $bo_2 = 190.00$
 $ho_2 = 540.00$
 $bi2_2 = 655400.00$

$a_{se3} = 0$ (grid does not provide confinement)
 $p_{sh,min} = \min(p_{sh,x}, p_{sh,y}) = 0.00069813$

Expression ((5.4d), TBDY) for $p_{sh,min}$ has been multiplied by 0.3 according to 15.7.1.3 for members without earthquake detailing (90° closed stirrups)

$p_{sh,x} = p_{s1,x} + p_{s2,x} + p_{s3,x} = 0.00356047$
 $p_{s1,x} \text{ (column 1)} = (A_{s1} \cdot h_1 / s_1) / A_c = 0.00083776$
 $h_1 = 600.00$
 $A_{s1} = A_{stir1} \cdot n_{s1} = 157.0796$
No stirrups, $n_{s1} = 2.00$
 $p_{s2,x} \text{ (column 2)} = (A_{s2} \cdot h_2 / s_2) / A_c = 0.00083776$
 $h_2 = 600.00$
 $A_{s2} = A_{stir2} \cdot n_{s2} = 157.0796$
No stirrups, $n_{s2} = 2.00$
 $p_{s3,x} \text{ (web)} = (A_{s3} \cdot h_3 / s_3) / A_c = 0.00188496$
 $h_3 = 1800.00$
 $A_{s3} = A_{stir3} \cdot n_{s3} = 0.00$
No stirrups, $n_{s3} = 2.00$

$p_{sh,y} = p_{s1,y} + p_{s2,y} + p_{s3,y} = 0.00069813$
 $p_{s1,y} \text{ (column 1)} = (A_{s1} \cdot h_1 / s_1) / A_c = 0.00034907$
 $h_1 = 250.00$
 $A_{s1} = A_{stir1} \cdot n_{s1} = 157.0796$
No stirrups, $n_{s1} = 2.00$
 $p_{s2,y} \text{ (column 2)} = (A_{s2} \cdot h_2 / s_2) / A_c = 0.00034907$
 $h_2 = 250.00$
 $A_{s2} = A_{stir2} \cdot n_{s2} = 157.0796$
No stirrups, $n_{s2} = 2.00$
 $p_{s3,y} \text{ (web)} = (A_{s3} \cdot h_3 / s_3) / A_c = 0.00$
 $h_3 = 250.00$
 $A_{s3} = A_{stir3} \cdot n_{s3} = 157.0796$
No stirrups, $n_{s3} = 0.00$


```

Asec = 750000.00
s_1 = 150.00
s_2 = 150.00
s_3 = 200.00
fywe = 625.00
fce = 25.00
From ((5.A.5), TBDY), TBDY: cc = 0.00202463
c = confinement factor = 1.00246
y1 = 0.00140044
sh1 = 0.0044814
ft1 = 420.1317
fy1 = 350.1097
su1 = 0.00512
using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00
lo/lou,min = lb/lb,min = 0.30
su1 = 0.4*esu1_nominal ((5.5), TBDY) = 0.032
From table 5A.1, TBDY: esu1_nominal = 0.08,
For calculation of esu1_nominal and y1, sh1,ft1,fy1, it is considered
characteristic value fsy1 = fs1/1.2, from table 5.1, TBDY.
y1, sh1,ft1,fy1, are also multiplied by Min(1,1.25*(lb/lb,min)^ 2/3), from 10.3.5, ASCE 41-17.
with fs1 = fs = 350.1097
with Es1 = Es = 200000.00
y2 = 0.00140044
sh2 = 0.0044814
ft2 = 420.1317
fy2 = 350.1097
su2 = 0.00512
using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00
lo/lou,min = lb/lb,min = 0.30
su2 = 0.4*esu2_nominal ((5.5), TBDY) = 0.032
From table 5A.1, TBDY: esu2_nominal = 0.08,
For calculation of esu2_nominal and y2, sh2,ft2,fy2, it is considered
characteristic value fsy2 = fs2/1.2, from table 5.1, TBDY.
y1, sh1,ft1,fy1, are also multiplied by Min(1,1.25*(lb/lb,min)^ 2/3), from 10.3.5, ASCE 41-17.
with fs2 = fs = 350.1097
with Es2 = Es = 200000.00
yv = 0.00140044
shv = 0.0044814
ftv = 420.1317
fyv = 350.1097
suv = 0.00512
using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00
lo/lou,min = lb/lb,min = 0.30
suv = 0.4*esuv_nominal ((5.5), TBDY) = 0.032
From table 5A.1, TBDY: esuv_nominal = 0.08,
considering characteristic value fsyv = fsv/1.2, from table 5.1, TBDY
For calculation of esuv_nominal and yv, shv,ftv,fyv, it is considered
characteristic value fsyv = fsv/1.2, from table 5.1, TBDY.
y1, sh1,ft1,fy1, are also multiplied by Min(1,1.25*(lb/lb,min)^ 2/3), from 10.3.5, ASCE 41-17.
with fsv = fs = 350.1097
with Esv = Es = 200000.00
1 = Asl,ten/(b*d)*(fs1/fc) = 0.0635264
2 = Asl,com/(b*d)*(fs2/fc) = 0.0635264
v = Asl,mid/(b*d)*(fsv/fc) = 0.00
and confined core properties:
b = 2940.00
d = 178.00
d' = 12.00
fcc (5A.2, TBDY) = 25.06158
cc (5A.5, TBDY) = 0.00202463

```

$c = \text{confinement factor} = 1.00246$
 $1 = A_{sl,ten}/(b*d)*(f_{s1}/f_c) = 0.07574806$
 $2 = A_{sl,com}/(b*d)*(f_{s2}/f_c) = 0.07574806$
 $v = A_{sl,mid}/(b*d)*(f_{sv}/f_c) = 0.00$

Case/Assumption: Unconfined full section - Steel rupture
 ' satisfies Eq. (4.3)

--->

$v < v_{s,y2}$ - LHS eq.(4.5) is satisfied

--->

$\mu_u(4.9) = 0.18779572$
 $\mu_u = M_{Rc}(4.14) = 2.0658E+008$
 $u = \mu_u(4.1) = 3.0306889E-005$

Calculation of ratio l_b/l_d

Inadequate Lap Length with $l_b/l_d = 0.30$

Calculation of μ_{u1} -

Calculation of ultimate curvature μ_u according to 4.1, Biskinis/Fardis 2013:

$u = 3.0889637E-005$
 $\mu_u = 2.4003E+008$

with full section properties:

$b = 3000.00$
 $d = 208.00$
 $d' = 42.00$
 $v = 0.00176852$
 $N = 27588.841$
 $f_c = 25.00$
 $\alpha_{co}(5A.5, TBDY) = 0.002$

Final value of μ_{cu} : $\mu_{cu}^* = \text{shear_factor} * \text{Max}(\mu_{cu}, \mu_{cc}) = 0.0035$

The Shear_factor is considered equal to 1 (pure moment strength)

From (5.4b), TBDY: $\mu_{cu} = 0.0035$

$\mu_{we}((5.4c), TBDY) = \alpha_{se} * \text{sh}_{,min} * f_{ywe}/f_{ce} + \text{Min}(f_x, f_y) = 0.00$

where $f = \alpha_f * p_f * f_{fe}/f_{ce}$ is accounting for FRP contribution like EC8-part3 A.4.4.3(6)

$f_x = 0.00$

$\alpha_f = 0.00$

$b = 250.00$

$h = 3000.00$

From EC8 A.4.4.3(6), $p_f = 2t_f/bw = 0.008128$

$bw = 250.00$

effective stress from (A.35), $f_{fe} = 757.2164$

$f_y = 0.00$

$\alpha_f = 0.00$

$b = 3000.00$

$h = 250.00$

From EC8 A.4.4.3(6), $p_f = 2t_f/bw = 0.00067733$

$bw = 3000.00$

effective stress from (A.35), $f_{fe} = 954.4864$

$R = 40.00$

Effective FRP thickness, $t_f = N L * t * \text{Cos}(b_1) = 1.016$

$f_{u,f} = 1055.00$

$E_f = 64828.00$

$u_{,f} = 0.015$

$\alpha_{se}((5.4d), TBDY) = (\alpha_{se1} * A_{col1} + \alpha_{se2} * A_{col2} + \alpha_{se3} * A_{web})/A_{sec} = 0.00$

$\alpha_{se1} = 0.00$

$sh_{,1} = 150.00$

$bo_{,1} = 190.00$

$ho_1 = 540.00$
 $bi2_1 = 655400.00$
 $ase2 = 0.00$
 $sh_2 = 150.00$
 $bo_2 = 190.00$
 $ho_2 = 540.00$
 $bi2_2 = 655400.00$
 $ase3 = 0$ (grid does not provide confinement)
 $psh,min = \text{Min}(psh,x, psh,y) = 0.00069813$
 Expression ((5.4d), TBDY) for psh,min has been multiplied by 0.3 according to 15.7.1.3 for members without earthquake detailing (90° closed stirrups)

$psh,x = ps1,x + ps2,x + ps3,x = 0.00356047$
 $ps1,x$ (column 1) = $(As1 \cdot h1 / s_1) / Ac = 0.00083776$
 $h1 = 600.00$
 $As1 = Astir1 \cdot ns1 = 157.0796$
 No stirrups, $ns1 = 2.00$
 $ps2,x$ (column 2) = $(As2 \cdot h2 / s_2) / Ac = 0.00083776$
 $h2 = 600.00$
 $As2 = Astir2 \cdot ns2 = 157.0796$
 No stirrups, $ns2 = 2.00$
 $ps3,x$ (web) = $(As3 \cdot h3 / s_3) / Ac = 0.00188496$
 $h3 = 1800.00$
 $As3 = Astir3 \cdot ns3 = 0.00$
 No stirrups, $ns3 = 2.00$

$psh,y = ps1,y + ps2,y + ps3,y = 0.00069813$
 $ps1,y$ (column 1) = $(As1 \cdot h1 / s_1) / Ac = 0.00034907$
 $h1 = 250.00$
 $As1 = Astir1 \cdot ns1 = 157.0796$
 No stirrups, $ns1 = 2.00$
 $ps2,y$ (column 2) = $(As2 \cdot h2 / s_2) / Ac = 0.00034907$
 $h2 = 250.00$
 $As2 = Astir2 \cdot ns2 = 157.0796$
 No stirrups, $ns2 = 2.00$
 $ps3,y$ (web) = $(As3 \cdot h3 / s_3) / Ac = 0.00$
 $h3 = 250.00$
 $As3 = Astir3 \cdot ns3 = 157.0796$
 No stirrups, $ns3 = 0.00$

$Asec = 750000.00$
 $s_1 = 150.00$
 $s_2 = 150.00$
 $s_3 = 200.00$
 $fywe = 625.00$
 $fce = 25.00$

From ((5.A5), TBDY), TBDY: $cc = 0.00202463$
 $c = \text{confinement factor} = 1.00246$

$y1 = 0.00140044$
 $sh1 = 0.0044814$
 $ft1 = 420.1317$
 $fy1 = 350.1097$
 $su1 = 0.00512$

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
 and also multiplied by the shear_factor according to 15.7.1.4, with
 $\text{Shear_factor} = 1.00$

$lo/lo_{u,min} = lb/ld = 0.30$

$su1 = 0.4 \cdot esu1_nominal$ ((5.5), TBDY) = 0.032

From table 5A.1, TBDY: $esu1_nominal = 0.08$,

For calculation of $esu1_nominal$ and $y1, sh1, ft1, fy1$, it is considered
 characteristic value $fsy1 = fs1 / 1.2$, from table 5.1, TBDY.

$y1, sh1, ft1, fy1$, are also multiplied by $\text{Min}(1, 1.25 \cdot (lb/ld)^{2/3})$, from 10.3.5, ASCE 41-17.

with $fs1 = fs = 350.1097$

with $Es1 = Es = 200000.00$

$y2 = 0.00140044$
 $sh2 = 0.0044814$
 $ft2 = 420.1317$

```

fy2 = 350.1097
su2 = 0.00512
    using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
    and also multiplied by the shear_factor according to 15.7.1.4, with
    Shear_factor = 1.00
    lo/lo,min = lb/lb,min = 0.30
    su2 = 0.4*esu2_nominal ((5.5), TBDY) = 0.032
    From table 5A.1, TBDY: esu2_nominal = 0.08,
    For calculation of esu2_nominal and y2, sh2,ft2,fy2, it is considered
    characteristic value fsy2 = fs2/1.2, from table 5.1, TBDY.
    y1, sh1,ft1,fy1, are also multiplied by Min(1,1.25*(lb/ld)^ 2/3), from 10.3.5, ASCE 41-17.
    with fs2 = fs = 350.1097
    with Es2 = Es = 200000.00
    yv = 0.00140044
    shv = 0.0044814
    ftv = 420.1317
    fyv = 350.1097
    suv = 0.00512
    using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
    and also multiplied by the shear_factor according to 15.7.1.4, with
    Shear_factor = 1.00
    lo/lo,min = lb/ld = 0.30
    suv = 0.4*esuv_nominal ((5.5), TBDY) = 0.032
    From table 5A.1, TBDY: esuv_nominal = 0.08,
    considering characteristic value fsyv = fsv/1.2, from table 5.1, TBDY
    For calculation of esuv_nominal and yv, shv,ftv,fyv, it is considered
    characteristic value fsyv = fsv/1.2, from table 5.1, TBDY.
    y1, sh1,ft1,fy1, are also multiplied by Min(1,1.25*(lb/ld)^ 2/3), from 10.3.5, ASCE 41-17.
    with fsv = fs = 350.1097
    with Esv = Es = 200000.00
    1 = Asl,ten/(b*d)*(fs1/fc) = 0.0635264
    2 = Asl,com/(b*d)*(fs2/fc) = 0.0635264
    v = Asl,mid/(b*d)*(fsv/fc) = 0.03609935
and confined core properties:
b = 2940.00
d = 178.00
d' = 12.00
fcc (5A.2, TBDY) = 25.06158
cc (5A.5, TBDY) = 0.00202463
    c = confinement factor = 1.00246
    1 = Asl,ten/(b*d)*(fs1/fc) = 0.07574806
    2 = Asl,com/(b*d)*(fs2/fc) = 0.07574806
    v = Asl,mid/(b*d)*(fsv/fc) = 0.0430444
Case/Assumption: Unconfined full section - Steel rupture
' satisfies Eq. (4.3)
--->
v < vs,y2 - LHS eq.(4.5) is satisfied
--->
su (4.9) = 0.20311835
Mu = MRc (4.14) = 2.4003E+008
u = su (4.1) = 3.0889637E-005

```

Calculation of ratio lb/ld

Inadequate Lap Length with lb/ld = 0.30

Calculation of Mu2+

Calculation of ultimate curvature u according to 4.1, Biskinis/Fardis 2013:

u = 3.0306889E-005

Mu = 2.0658E+008

with full section properties:

$$b = 3000.00$$

$$d = 208.00$$

$$d' = 42.00$$

$$v = 0.00176852$$

$$N = 27588.841$$

$$f_c = 25.00$$

$$\alpha (5A.5, \text{TB DY}) = 0.002$$

$$\text{Final value of } \alpha: \alpha = \text{shear_factor} * \text{Max}(\alpha_c, \alpha_c) = 0.0035$$

The Shear_factor is considered equal to 1 (pure moment strength)

$$\text{From (5.4b), TB DY: } \alpha_c = 0.0035$$

$$\alpha_{ve} ((5.4c), \text{TB DY}) = \alpha_{se} * \text{sh}_{\min} * f_{yve} / f_{ce} + \text{Min}(\alpha_{fx}, \alpha_{fy}) = 0.00$$

where $\alpha_{fx} = \alpha_{se} * \alpha_{pf} * f_{fe} / f_{ce}$ is accounting for FRP contribution like EC8-part3 A.4.4.3(6)

$$\alpha_{fx} = 0.00$$

$$\alpha_{fe} = 0.00$$

$$b = 250.00$$

$$h = 3000.00$$

$$\text{From EC8 A4.4.3(6), } \alpha_{pf} = 2t_f / b_w = 0.008128$$

$$b_w = 250.00$$

$$\text{effective stress from (A.35), } f_{fe} = 757.2164$$

$$\alpha_{fy} = 0.00$$

$$\alpha_{fe} = 0.00$$

$$b = 3000.00$$

$$h = 250.00$$

$$\text{From EC8 A4.4.3(6), } \alpha_{pf} = 2t_f / b_w = 0.00067733$$

$$b_w = 3000.00$$

$$\text{effective stress from (A.35), } f_{fe} = 954.4864$$

$$R = 40.00$$

$$\text{Effective FRP thickness, } t_f = N L * t * \cos(\beta_1) = 1.016$$

$$f_{u,f} = 1055.00$$

$$E_f = 64828.00$$

$$\alpha_{u,f} = 0.015$$

$$\alpha_{se} ((5.4d), \text{TB DY}) = (\alpha_{se1} * A_{col1} + \alpha_{se2} * A_{col2} + \alpha_{se3} * A_{web}) / A_{sec} = 0.00$$

$$\alpha_{se1} = 0.00$$

$$\text{sh}_1 = 150.00$$

$$\text{bo}_1 = 190.00$$

$$\text{ho}_1 = 540.00$$

$$\text{bi2}_1 = 655400.00$$

$$\alpha_{se2} = 0.00$$

$$\text{sh}_2 = 150.00$$

$$\text{bo}_2 = 190.00$$

$$\text{ho}_2 = 540.00$$

$$\text{bi2}_2 = 655400.00$$

$$\alpha_{se3} = 0 \text{ (grid does not provide confinement)}$$

$$\text{psh}_{\min} = \text{Min}(\text{psh}_x, \text{psh}_y) = 0.00069813$$

Expression ((5.4d), TB DY) for psh_{\min} has been multiplied by 0.3 according to 15.7.1.3 for members without earthquake detailing (90° closed stirrups)

$$\text{psh}_x = \text{ps1}_x + \text{ps2}_x + \text{ps3}_x = 0.00356047$$

$$\text{ps1}_x \text{ (column 1)} = (A_{s1} * h_1 / s_1) / A_c = 0.00083776$$

$$h_1 = 600.00$$

$$A_{s1} = A_{stir1} * n_{s1} = 157.0796$$

$$\text{No stirrups, } n_{s1} = 2.00$$

$$\text{ps2}_x \text{ (column 2)} = (A_{s2} * h_2 / s_2) / A_c = 0.00083776$$

$$h_2 = 600.00$$

$$A_{s2} = A_{stir2} * n_{s2} = 157.0796$$

$$\text{No stirrups, } n_{s2} = 2.00$$

$$\text{ps3}_x \text{ (web)} = (A_{s3} * h_3 / s_3) / A_c = 0.00188496$$

$$h_3 = 1800.00$$

$$A_{s3} = A_{stir3} * n_{s3} = 0.00$$

$$\text{No stirrups, } n_{s3} = 2.00$$

$$\text{psh}_y = \text{ps1}_y + \text{ps2}_y + \text{ps3}_y = 0.00069813$$

$$\text{ps1}_y \text{ (column 1)} = (A_{s1} * h_1 / s_1) / A_c = 0.00034907$$

$h1 = 250.00$
 $As1 = Astir1 * ns1 = 157.0796$
 No stirups, $ns1 = 2.00$
 $ps2,y \text{ (column 2)} = (As2 * h2 / s_2) / Ac = 0.00034907$
 $h2 = 250.00$
 $As2 = Astir2 * ns2 = 157.0796$
 No stirups, $ns2 = 2.00$
 $ps3,y \text{ (web)} = (As3 * h3 / s_3) / Ac = 0.00$
 $h3 = 250.00$
 $As3 = Astir3 * ns3 = 157.0796$
 No stirups, $ns3 = 0.00$

 $Asec = 750000.00$

$s_1 = 150.00$

$s_2 = 150.00$

$s_3 = 200.00$

$fywe = 625.00$

$fce = 25.00$

From ((5.A5), TBDY), TBDY: $cc = 0.00202463$

$c = \text{confinement factor} = 1.00246$

$y1 = 0.00140044$

$sh1 = 0.0044814$

$ft1 = 420.1317$

$fy1 = 350.1097$

$su1 = 0.00512$

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
 and also multiplied by the shear_factor according to 15.7.1.4, with
 $\text{Shear_factor} = 1.00$

$lo/lou,min = lb/ld = 0.30$

$su1 = 0.4 * esu1_nominal \text{ ((5.5), TBDY)} = 0.032$

From table 5A.1, TBDY: $esu1_nominal = 0.08$,

For calculation of $esu1_nominal$ and $y1, sh1, ft1, fy1$, it is considered
 characteristic value $fsy1 = fs1/1.2$, from table 5.1, TBDY.

$y1, sh1, ft1, fy1$, are also multiplied by $\text{Min}(1, 1.25 * (lb/ld)^{2/3})$, from 10.3.5, ASCE 41-17.

with $fs1 = fs = 350.1097$

with $Es1 = Es = 200000.00$

$y2 = 0.00140044$

$sh2 = 0.0044814$

$ft2 = 420.1317$

$fy2 = 350.1097$

$su2 = 0.00512$

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
 and also multiplied by the shear_factor according to 15.7.1.4, with
 $\text{Shear_factor} = 1.00$

$lo/lou,min = lb/lb,min = 0.30$

$su2 = 0.4 * esu2_nominal \text{ ((5.5), TBDY)} = 0.032$

From table 5A.1, TBDY: $esu2_nominal = 0.08$,

For calculation of $esu2_nominal$ and $y2, sh2, ft2, fy2$, it is considered
 characteristic value $fsy2 = fs2/1.2$, from table 5.1, TBDY.

$y2, sh2, ft2, fy2$, are also multiplied by $\text{Min}(1, 1.25 * (lb/ld)^{2/3})$, from 10.3.5, ASCE 41-17.

with $fs2 = fs = 350.1097$

with $Es2 = Es = 200000.00$

$yv = 0.00140044$

$shv = 0.0044814$

$ftv = 420.1317$

$fyv = 350.1097$

$suv = 0.00512$

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
 and also multiplied by the shear_factor according to 15.7.1.4, with
 $\text{Shear_factor} = 1.00$

$lo/lou,min = lb/ld = 0.30$

$suv = 0.4 * esuv_nominal \text{ ((5.5), TBDY)} = 0.032$

From table 5A.1, TBDY: $esuv_nominal = 0.08$,

considering characteristic value $fsyv = fsv/1.2$, from table 5.1, TBDY
 For calculation of $esuv_nominal$ and yv, shv, ftv, fyv , it is considered

characteristic value $fsyv = fsv/1.2$, from table 5.1, TBDY.

$y1, sh1, ft1, fy1$, are also multiplied by $\text{Min}(1, 1.25 * (lb/ld)^{2/3})$, from 10.3.5, ASCE 41-17.

with $f_{sv} = f_s = 350.1097$
 with $E_{sv} = E_s = 200000.00$
 $1 = A_{sl,ten}/(b*d)*(f_{s1}/f_c) = 0.0635264$
 $2 = A_{sl,com}/(b*d)*(f_{s2}/f_c) = 0.0635264$
 $v = A_{sl,mid}/(b*d)*(f_{sv}/f_c) = 0.00$
 and confined core properties:
 $b = 2940.00$
 $d = 178.00$
 $d' = 12.00$
 $f_{cc} (5A.2, TBDY) = 25.06158$
 $cc (5A.5, TBDY) = 0.00202463$
 $c = \text{confinement factor} = 1.00246$
 $1 = A_{sl,ten}/(b*d)*(f_{s1}/f_c) = 0.07574806$
 $2 = A_{sl,com}/(b*d)*(f_{s2}/f_c) = 0.07574806$
 $v = A_{sl,mid}/(b*d)*(f_{sv}/f_c) = 0.00$
 Case/Assumption: Unconfined full section - Steel rupture
 ' satisfies Eq. (4.3)

--->
 $v < v_{s,y2}$ - LHS eq.(4.5) is satisfied
 --->
 $su (4.9) = 0.18779572$
 $Mu = MRc (4.14) = 2.0658E+008$
 $u = su (4.1) = 3.0306889E-005$

Calculation of ratio l_b/l_d

Inadequate Lap Length with $l_b/l_d = 0.30$

Calculation of Mu_2 -

Calculation of ultimate curvature u according to 4.1, Biskinis/Fardis 2013:
 $u = 3.0889637E-005$
 $Mu = 2.4003E+008$

with full section properties:

$b = 3000.00$
 $d = 208.00$
 $d' = 42.00$
 $v = 0.00176852$
 $N = 27588.841$
 $f_c = 25.00$
 $co (5A.5, TBDY) = 0.002$
 Final value of cu : $cu^* = \text{shear_factor} * \text{Max}(cu, cc) = 0.0035$
 The Shear_factor is considered equal to 1 (pure moment strength)
 From (5.4b), TBDY: $cu = 0.0035$
 $w_e ((5.4c), TBDY) = a_{se} * sh_{,min} * f_{ywe}/f_{ce} + \text{Min}(f_x, f_y) = 0.00$
 where $f = a_f * p_f * f_{fe}/f_{ce}$ is accounting for FRP contribution like EC8-part3 A.4.4.3(6)

$f_x = 0.00$
 $a_f = 0.00$
 $b = 250.00$
 $h = 3000.00$
 From EC8 A.4.4.3(6), $p_f = 2t_f/bw = 0.008128$
 $bw = 250.00$
 effective stress from (A.35), $f_{fe} = 757.2164$

$f_y = 0.00$
 $a_f = 0.00$
 $b = 3000.00$
 $h = 250.00$
 From EC8 A.4.4.3(6), $p_f = 2t_f/bw = 0.00067733$
 $bw = 3000.00$

effective stress from (A.35), $f_{f,e} = 954.4864$

$R = 40.00$

Effective FRP thickness, $t_f = NL \cdot t \cdot \cos(b_1) = 1.016$

$f_{u,f} = 1055.00$

$E_f = 64828.00$

$u_f = 0.015$

$a_{se}((5.4d), TBDY) = (a_{se1} \cdot A_{col1} + a_{se2} \cdot A_{col2} + a_{se3} \cdot A_{web}) / A_{sec} = 0.00$

$a_{se1} = 0.00$

$sh_1 = 150.00$

$bo_1 = 190.00$

$ho_1 = 540.00$

$bi2_1 = 655400.00$

$a_{se2} = 0.00$

$sh_2 = 150.00$

$bo_2 = 190.00$

$ho_2 = 540.00$

$bi2_2 = 655400.00$

$a_{se3} = 0$ (grid does not provide confinement)

$p_{sh,min} = \min(p_{sh,x}, p_{sh,y}) = 0.00069813$

Expression ((5.4d), TBDY) for $p_{sh,min}$ has been multiplied by 0.3 according to 15.7.1.3 for members without earthquake detailing (90° closed stirrups)

$p_{sh,x} = p_{s1,x} + p_{s2,x} + p_{s3,x} = 0.00356047$

$p_{s1,x}$ (column 1) = $(A_{s1} \cdot h_1 / s_1) / A_c = 0.00083776$

$h_1 = 600.00$

$A_{s1} = A_{stir1} \cdot n_{s1} = 157.0796$

No stirrups, $n_{s1} = 2.00$

$p_{s2,x}$ (column 2) = $(A_{s2} \cdot h_2 / s_2) / A_c = 0.00083776$

$h_2 = 600.00$

$A_{s2} = A_{stir2} \cdot n_{s2} = 157.0796$

No stirrups, $n_{s2} = 2.00$

$p_{s3,x}$ (web) = $(A_{s3} \cdot h_3 / s_3) / A_c = 0.00188496$

$h_3 = 1800.00$

$A_{s3} = A_{stir3} \cdot n_{s3} = 0.00$

No stirrups, $n_{s3} = 2.00$

$p_{sh,y} = p_{s1,y} + p_{s2,y} + p_{s3,y} = 0.00069813$

$p_{s1,y}$ (column 1) = $(A_{s1} \cdot h_1 / s_1) / A_c = 0.00034907$

$h_1 = 250.00$

$A_{s1} = A_{stir1} \cdot n_{s1} = 157.0796$

No stirrups, $n_{s1} = 2.00$

$p_{s2,y}$ (column 2) = $(A_{s2} \cdot h_2 / s_2) / A_c = 0.00034907$

$h_2 = 250.00$

$A_{s2} = A_{stir2} \cdot n_{s2} = 157.0796$

No stirrups, $n_{s2} = 2.00$

$p_{s3,y}$ (web) = $(A_{s3} \cdot h_3 / s_3) / A_c = 0.00$

$h_3 = 250.00$

$A_{s3} = A_{stir3} \cdot n_{s3} = 157.0796$

No stirrups, $n_{s3} = 0.00$

$A_{sec} = 750000.00$

$s_1 = 150.00$

$s_2 = 150.00$

$s_3 = 200.00$

$f_{ywe} = 625.00$

$f_{ce} = 25.00$

From ((5.A5), TBDY), TBDY: $cc = 0.00202463$

c = confinement factor = 1.00246

$y_1 = 0.00140044$

$sh_1 = 0.0044814$

$ft_1 = 420.1317$

$fy_1 = 350.1097$

$su_1 = 0.00512$

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00

$l_o/l_{ou,min} = l_b/l_d = 0.30$
 $su_1 = 0.4 \cdot esu_{1,nominal} ((5.5), TBDY) = 0.032$
 From table 5A.1, TBDY: $esu_{1,nominal} = 0.08$,
 For calculation of $esu_{1,nominal}$ and y_1, sh_1, ft_1, fy_1 , it is considered
 characteristic value $fsy_1 = fs_1/1.2$, from table 5.1, TBDY.
 y_1, sh_1, ft_1, fy_1 , are also multiplied by $\text{Min}(1, 1.25 \cdot (l_b/l_d)^{2/3})$, from 10.3.5, ASCE 41-17.
 with $fs_1 = fs = 350.1097$
 with $Es_1 = Es = 200000.00$
 $y_2 = 0.00140044$
 $sh_2 = 0.0044814$
 $ft_2 = 420.1317$
 $fy_2 = 350.1097$
 $su_2 = 0.00512$
 using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
 and also multiplied by the shear_factor according to 15.7.1.4, with
 Shear_factor = 1.00
 $l_o/l_{ou,min} = l_b/l_{b,min} = 0.30$
 $su_2 = 0.4 \cdot esu_{2,nominal} ((5.5), TBDY) = 0.032$
 From table 5A.1, TBDY: $esu_{2,nominal} = 0.08$,
 For calculation of $esu_{2,nominal}$ and y_2, sh_2, ft_2, fy_2 , it is considered
 characteristic value $fsy_2 = fs_2/1.2$, from table 5.1, TBDY.
 y_1, sh_1, ft_1, fy_1 , are also multiplied by $\text{Min}(1, 1.25 \cdot (l_b/l_d)^{2/3})$, from 10.3.5, ASCE 41-17.
 with $fs_2 = fs = 350.1097$
 with $Es_2 = Es = 200000.00$
 $y_v = 0.00140044$
 $sh_v = 0.0044814$
 $ft_v = 420.1317$
 $fy_v = 350.1097$
 $suv = 0.00512$
 using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
 and also multiplied by the shear_factor according to 15.7.1.4, with
 Shear_factor = 1.00
 $l_o/l_{ou,min} = l_b/l_d = 0.30$
 $suv = 0.4 \cdot esuv_{nominal} ((5.5), TBDY) = 0.032$
 From table 5A.1, TBDY: $esuv_{nominal} = 0.08$,
 considering characteristic value $fsyv = fsv/1.2$, from table 5.1, TBDY
 For calculation of $esuv_{nominal}$ and y_v, sh_v, ft_v, fy_v , it is considered
 characteristic value $fsyv = fsv/1.2$, from table 5.1, TBDY.
 y_1, sh_1, ft_1, fy_1 , are also multiplied by $\text{Min}(1, 1.25 \cdot (l_b/l_d)^{2/3})$, from 10.3.5, ASCE 41-17.
 with $fsv = fs = 350.1097$
 with $Es_v = Es = 200000.00$
 $1 = A_{sl,ten}/(b \cdot d) \cdot (fs_1/f_c) = 0.0635264$
 $2 = A_{sl,com}/(b \cdot d) \cdot (fs_2/f_c) = 0.0635264$
 $v = A_{sl,mid}/(b \cdot d) \cdot (fsv/f_c) = 0.03609935$

and confined core properties:

$b = 2940.00$
 $d = 178.00$
 $d' = 12.00$
 $f_{cc} (5A.2, TBDY) = 25.06158$
 $cc (5A.5, TBDY) = 0.00202463$
 $c = \text{confinement factor} = 1.00246$
 $1 = A_{sl,ten}/(b \cdot d) \cdot (fs_1/f_c) = 0.07574806$
 $2 = A_{sl,com}/(b \cdot d) \cdot (fs_2/f_c) = 0.07574806$
 $v = A_{sl,mid}/(b \cdot d) \cdot (fsv/f_c) = 0.0430444$

Case/Assumption: Unconfined full section - Steel rupture

' satisfies Eq. (4.3)

--->

$v < v_{s,y2}$ - LHS eq.(4.5) is satisfied

--->

$su (4.9) = 0.20311835$
 $Mu = MRc (4.14) = 2.4003E+008$
 $u = su (4.1) = 3.0889637E-005$

Calculation of ratio l_b/l_d

Inadequate Lap Length with $l_b/l_d = 0.30$

Calculation of Shear Strength $V_r = \text{Min}(V_{r1}, V_{r2}) = 1.0244\text{E}+006$

Calculation of Shear Strength at edge 1, $V_{r1} = 1.0244\text{E}+006$

From (22.5.1.1) and 11.5.4.3, ACI 318-14: $V_{r1} = V_n < 0.83 \cdot f_c' \cdot h \cdot d$

NOTE: In expression (22.5.1.1) 'Vw' is replaced by 'Vw + f * Vf' where Vf is the contribution of FRPs (11.3), ACI 440).

From Table (11.5.4.6(d-e)), ACI 318-14: $V_c = 815517.768$

$\mu_u / \mu_n - l_w / 2 = 0.00 \leq 0$

= 1 (normal-weight concrete)

$f_c' = 25.00$, but $f_c'^{0.5} \leq 8.3$ MPa (22.5.3.1, ACI 318-14)

$h = 3000.00$

$d = 200.00$

$l_w = 250.00$

$\mu_u = 3.7289358\text{E}-011$

$\mu_n = 1.7354940\text{E}-029$

$\mu_n = 27588.841$

From (11.5.4.8), ACI 318-14: $V_s = V_{s1} + V_{s2} + V_{s3} = 104719.755$

$V_{s1} = 52359.878$ is calculated for pseudo-Column 1, with:

$d = 200.00$

$A_v = 157079.633$

$s = 150.00$

$f_y = 500.00$

V_{s1} has been multiplied by $2(1-s/d)$ ($s > d/2$, according to ASCE 41-17, 10.3.4)

$2(1-s/d) = 0.50$

$V_{s2} = 52359.878$ is calculated for pseudo-Column 2, with:

$d = 200.00$

$A_v = 157079.633$

$s = 150.00$

$f_y = 500.00$

V_{s2} has been multiplied by $2(1-s/d)$ ($s > d/2$, according to ASCE 41-17, 10.3.4)

$2(1-s/d) = 0.50$

$V_{s3} = 0.00$ is calculated for web, with:

$d = 200.00$

$A_v = 0.00$

$s = 200.00$

$f_y = 500.00$

V_{s3} has been multiplied by $2(1-s/d)$ ($s > d/2$, according to ASCE 41-17, 10.3.4)

$2(1-s/d) = 0.00$

V_f ((11-3)-(11.4), ACI 440) = 109599.773

$f = 0.95$, for fully-wrapped sections

$w_f / s_f = 1$ (FRP strips adjacent to one another).

In (11.3) $\sin + \cos$ is replaced with $(\cot + \cot a) \sin a$ which is more a generalised expression,

where a is the angle of the crack direction (see KANEPE).

This later relation, considered as a function $V_f(\theta)$, is implemented for every different fiber orientation θ_i , as well as for 2 crack directions, $\theta = 45^\circ$ and $\theta = -45^\circ$ to take into consideration the cyclic seismic loading.

orientation 1: $\theta_1 = \theta_1 + 90^\circ = 90.00$

$V_f = \text{Min}(|V_f(45, \theta_1)|, |V_f(-45, \theta_1)|)$, with:

total thickness per orientation, $t_{f1} = N_L \cdot t / N_{oDir} = 1.016$

$d_{fv} = d$ (figure 11.2, ACI 440) = 208.00

f_{fe} ((11-5), ACI 440) = 259.312

$E_f = 64828.00$

$f_e = 0.004$, from (11.6a), ACI 440

with $f_u = 0.01$

From (11-11), ACI 440: $V_s + V_f \leq 1.9929\text{E}+006$

$b_w = 3000.00$

Calculation of Shear Strength at edge 2, $V_{r2} = 1.0244\text{E}+006$

From (22.5.1.1) and 11.5.4.3, ACI 318-14: $V_{r2} = V_n < 0.83 \cdot f_c' \cdot h \cdot d$

NOTE: In expression (22.5.1.1) 'Vw' is replaced by 'Vw + f * Vf' where Vf is the contribution of FRPs (11.3), ACI 440).

From Table (11.5.4.6(d-e)), ACI 318-14: $V_c = 815517.768$
 $M_u/V_u - l_w/2 = 0.00 \leq 0$
 $= 1$ (normal-weight concrete)
 $f_c' = 25.00$, but $f_c'^{0.5} \leq 8.3$ MPa (22.5.3.1, ACI 318-14)
 $h = 3000.00$
 $d = 200.00$
 $l_w = 250.00$
 $M_u = 3.7289358E-011$
 $V_u = 1.7354940E-029$
 $N_u = 27588.841$
 From (11.5.4.8), ACI 318-14: $V_s = V_{s1} + V_{s2} + V_{s3} = 104719.755$
 $V_{s1} = 52359.878$ is calculated for pseudo-Column 1, with:
 $d = 200.00$
 $A_v = 157079.633$
 $s = 150.00$
 $f_y = 500.00$
 V_{s1} has been multiplied by $2(1-s/d)$ ($s > d/2$, according to ASCE 41-17,10.3.4)
 $2(1-s/d) = 0.50$
 $V_{s2} = 52359.878$ is calculated for pseudo-Column 2, with:
 $d = 200.00$
 $A_v = 157079.633$
 $s = 150.00$
 $f_y = 500.00$
 V_{s2} has been multiplied by $2(1-s/d)$ ($s > d/2$, according to ASCE 41-17,10.3.4)
 $2(1-s/d) = 0.50$
 $V_{s3} = 0.00$ is calculated for web, with:
 $d = 200.00$
 $A_v = 0.00$
 $s = 200.00$
 $f_y = 500.00$
 V_{s3} has been multiplied by $2(1-s/d)$ ($s > d/2$, according to ASCE 41-17,10.3.4)
 $2(1-s/d) = 0.00$
 V_f ((11-3)-(11.4), ACI 440) = 109599.773
 $f = 0.95$, for fully-wrapped sections
 $w_f/s_f = 1$ (FRP strips adjacent to one another).
 In (11.3) $\sin + \cos$ is replaced with $(\cot + \cot a)\sin a$ which is more a generalised expression,
 where a is the angle of the crack direction (see KANEPE).
 This later relation, considered as a function $V_f(\theta, a)$, is implemented for every different fiber orientation a_i ,
 as well as for 2 crack directions, $\theta = 45^\circ$ and $\theta = -45^\circ$ to take into consideration the cyclic seismic loading.
 orientation 1: $\theta = \theta_1 + 90^\circ = 90.00$
 $V_f = \text{Min}(|V_f(45, \theta_1)|, |V_f(-45, a_1)|)$, with:
 total thickness per orientation, $t_{f1} = N_L \cdot t / N_{oDir} = 1.016$
 $d_{fv} = d$ (figure 11.2, ACI 440) = 208.00
 f_{fe} ((11-5), ACI 440) = 259.312
 $E_f = 64828.00$
 $f_e = 0.004$, from (11.6a), ACI 440
 with $f_u = 0.01$
 From (11-11), ACI 440: $V_s + V_f \leq 1.9929E+006$
 $b_w = 3000.00$

End Of Calculation of Shear Capacity ratio for element: wall W1 of floor 1
 At local axis: 2

Start Of Calculation of Chord Rotation Capacity for element: wall W1 of floor 1
 At local axis: 3
 Integration Section: (d)
 Section Type: rcrcws

Constant Properties

Knowledge Factor, $\gamma = 1.00$
 According to 10.7.2.3, ASCE 41-17, shear walls with
 transverse reinforcement percentage, $\rho_n < 0.0015$

are considered Force-Controlled and lower-bound strengths are used according to 7.5.1.3, ASCE 41-17
 $n = 0.00069813$

with $n = ps1 + ps2 + ps3$, being the shear reinf. ratio in a plane perpendicular to the shear axis 2
(pseudo-col.1 $ps1 = As1*b1/s1 = (As1*h1/s1) / Ac = 0.00034907$
 $h1 = 250.00$
 $s1 = 150.00$
total area of hoops perpendicular to shear axis, $As1 = 157.0796$
(pseudo-col.2 $ps2 = As2*b2/s2 = (As2*h2/s2) / Ac = 0.00034907$
 $h2 = 250.00$
 $s2 = 150.00$
total area of hoops perpendicular to shear axis, $As2 = 157.0796$
(grid $ps3 = As3*b3/s3 = (As3*h3/s3) / Ac = 0.00$
 $h3 = 250.00$
 $s3 = 200.00$
total area of hoops perpendicular to shear axis, $As3 = 0.00$
total section area, $Ac = 750000.00$

Consequently:

New material of Secondary Member: Concrete Strength, $fc = fc_lower_bound = 25.00$
New material of Secondary Member: Steel Strength, $fs = fs_lower_bound = 500.00$
Concrete Elasticity, $Ec = 26999.444$
Steel Elasticity, $Es = 200000.00$
Total Height, $H_{tot} = 3000.00$
Edges Width, $W_{edg} = 250.00$
Edges Height, $H_{edg} = 600.00$
Web Width, $W_{web} = 250.00$
Cover Thickness, $c = 25.00$
Element Length, $L = 3000.00$
Secondary Member
Smooth Bars
Ductile Steel
Without Detailing for Earthquake Resistance (including stirrups not closed at 135°)
Longitudinal Bars With Ends Lapped Starting at the End Sections
Inadequate Lap Length with $lb/ld = 0.30$
FRP Wrapping Data
Type: Carbon
Cured laminate properties (design values)
Thickness, $t = 1.016$
Tensile Strength, $ffu = 1055.00$
Tensile Modulus, $E_f = 64828.00$
Elongation, $efu = 0.01$
Number of directions, $NoDir = 1$
Fiber orientations, $bi: 0.00^\circ$
Number of layers, $NL = 1$
Radius of rounding corners, $R = 40.00$

Stepwise Properties

Bending Moment, $M = -2.4510145E-011$
Shear Force, $V2 = 1.2948432E-014$
Shear Force, $V3 = 20889.844$
Axial Force, $F = -31026.87$
Longitudinal Reinforcement Area Distribution (in 2 divisions)
-Tension: $As_t = 0.00$
-Compression: $As_c = 7269.645$
Longitudinal Reinforcement Area Distribution (in 3 divisions)
-Tension: $As_{t,ten} = 2830.575$
-Compression: $As_{c,com} = 2830.575$
-Middle: $As_{l,mid} = 1608.495$
Mean Diameter of Tension Reinforcement, $DbL = 16.46154$

New component: From table 7-7, ASCE 41_17: Final chord rotation Capacity $u_R = 1.0^*$ $u = 0.00918702$

$$u = y + p = 0.00918702$$

- Calculation of y -

$$y = (M_y \cdot I_p) / (EI)_{\text{Eff}} = 0.00118702 \text{ ((10-5), ASCE 41-17)}$$

$$M_y = 1.8257\text{E}+008$$

$$(EI)_{\text{Eff}} = 0.35 \cdot E_c \cdot I \text{ (table 10-5)}$$

$$E_c \cdot I = 1.0547\text{E}+014$$

$$I_p = 0.5 \cdot d = 0.5 \cdot (0.8 \cdot h) = 240.00$$

Calculation of Yielding Moment M_y

Calculation of y and M_y according to Annex 7 -

$$y = \text{Min}(y_{\text{ten}}, y_{\text{com}})$$

$$y_{\text{ten}} = 8.9780154\text{E}-006$$

$$\text{with } ((10.1), \text{ASCE 41-17}) \quad f_y = \text{Min}(f_y, 1.25 \cdot f_y \cdot (I_b/I_d)^{2/3}) = 280.0878$$

$$d = 208.00$$

$$y = 0.25007038$$

$$A = 0.0118276$$

$$B = 0.00717877$$

$$\text{with } p_t = 0.00453618$$

$$p_c = 0.00453618$$

$$p_v = 0.00257772$$

$$N = 31026.87$$

$$b = 3000.00$$

$$" = 0.20192308$$

$$y_{\text{comp}} = 3.2320012\text{E}-005$$

$$\text{with } f_c' (12.3, \text{ACI 440}) = 25.002$$

$$f_c = 25.00$$

$$f_l = 0.17503396$$

$$b = 3000.00$$

$$h = 250.00$$

$$A_g = 750000.00$$

$$\text{From } (12.9), \text{ACI 440: } k_a = 0.0036426$$

$$g = p_t + p_c + p_v = 0.01165007$$

$$r_c = 40.00$$

$$A_e/A_c = 0.52453487$$

$$\text{Effective FRP thickness, } t_f = N L^* t \cdot \cos(b_1) = 1.016$$

$$\text{effective strain from (12.5) and (12.12), } e_{fe} = 0.004$$

$$f_u = 0.01$$

$$E_f = 64828.00$$

$$E_c = 26999.444$$

$$y = 0.24794626$$

$$A = 0.01150092$$

$$B = 0.00700125$$

$$\text{with } E_s = 200000.00$$

Calculation of ratio I_b/I_d

Inadequate Lap Length with $I_b/I_d = 0.30$

- Calculation of p -

Considering wall controlled by flexure (shear control ratio ≤ 1),

from table 10-19: $p = 0.008$

with:

- Condition i (shear wall and wall segments)

$$-(A_s - A_s') \cdot f_y + P / (t_w \cdot I_w \cdot f_c') = -0.19220244$$

$$A_s = 0.00$$

$$A_s' = 7269.645$$

$f_y = 500.00$
 $P = 31026.87$
 $t_w = 3000.00$
 $l_w = 250.00$
 $f_c = 25.00$

- $V/(t_w \cdot l_w \cdot f_c^{0.5}) = 4.1582360E-020$, NOTE: units in lb & in

- Confined Boundary: No

Boundary hoops spacing exceed $8d_b$ ($s_1 > 8 \cdot d_b$ or $s_2 > 8 \cdot d_b$)

Boundary Trans. Reinf. does not exceed 50% of ACI 318 provision ($V_{w1} + V_{w2} > 0.50 \cdot (V - V_c - V_{w3})$)

With

Boundary Element 1:

$V_{w1} = 104719.755$

$s_1 = 150.00$

Boundary Element 2:

$V_{w2} = 104719.755$

$s_2 = 150.00$

Grid Shear Force, $V_{w3} = 0.00$

Concrete Shear Force, $V_c = 193125.108$

(The variables above have already been given in Shear control ratio calculation)

Mean diameter of all bars, $d_b = 17.33333$

Design Shear Force, $V = 1.2948432E-014$

End Of Calculation of Chord Rotation Capacity for element: wall W1 of floor 1

At local axis: 3

Integration Section: (d)