

Detailed Member Calculations

Units: N&mm

Regulation: ASCE 41-17

Calculation No. 1

beam B1, Floor 1



Limit State: Operational Level (data interpolation between analysis steps 1 and 2)

Analysis: Uniform +X

Check: Shear capacity V_{Rd}

Edge: Start

Local Axis: (2)



Start Of Calculation of Shear Capacity for element: beam B1 of floor 1

At local axis: 2

Integration Section: (a)

Section Type: rcars

Constant Properties

Knowledge Factor, $\gamma = 1.00$

Member Shear Force is generally considered as Force-Controlled Action according to Table C7-1, ASCE 41-17.

Lower-bound strengths are used for Force-Controlled Actions according to 7.5.1.3, ASCE 41-17

Consequently:

New material of Secondary Member: Concrete Strength, $f_c = f_{c_lower_bound} = 25.00$

New material of Secondary Member: Steel Strength, $f_s = f_{s_lower_bound} = 500.00$

Concrete Elasticity, $E_c = 26999.444$

Steel Elasticity, $E_s = 200000.00$
Section Height, $H = 400.00$
Section Width, $W = 300.00$
Cover Thickness, $c = 25.00$
Element Length, $L = 1850.00$
Secondary Member
Smooth Bars
Ductile Steel
Without Detailing for Earthquake Resistance (including stirrups not closed at 135°)
Longitudinal Bars With Ends Lapped Starting at the End Sections
Inadequate Lap Length with $l_o/l_{o,min} = l_b/l_d = 0.30$
No FRP Wrapping

Stepwise Properties

EDGE -A-
Bending Moment, $M_a = 3.0614186E-011$
Shear Force, $V_a = 5.3543557E-014$
EDGE -B-
Bending Moment, $M_b = 6.8346901E-011$
Shear Force, $V_b = -5.3543557E-014$
BOTH EDGES
Axial Force, $F = -613.7698$
Longitudinal Reinforcement Area Distribution (in 2 divisions)
-Tension: $A_{s,t} = 911.0619$
-Compression: $A_{s,c} = 1231.504$
Longitudinal Reinforcement Area Distribution (in 3 divisions)
-Tension: $A_{s,ten} = 816.8141$
-Compression: $A_{s,com} = 816.8141$
-Middle: $A_{s,mid} = 508.938$
Mean Diameter of Tension Reinforcement, $Db_{L,ten} = 14.40$

New component: From table 7-7, ASCE 41_17: Final Shear Capacity $VR = 1.0 \cdot V_n = 171047.78$
 V_n ((22.5.1.1), ACI 318-14) = 171047.78

NOTE: In expression (22.5.1.1) 'V_w' is replaced by 'V_w + f_vV_f'
where V_f is the contribution of FRPs (11.3), ACI 440).

From Table (22.5.5.1), ACI 318-14: $V_c = 76800.00$
= 1 (normal-weight concrete)
 $f'_c = 25.00$, but $f'_c^{0.5} \leq 8.3$ MPa (22.5.3.1, ACI 318-14)
 $\rho_w = A_s/(b_w \cdot d) = 0.00949023$
 A_s (tension reinf.) = 911.0619
 $b_w = 400.00$
 $d = 240.00$
 $V_u \cdot d / M_u < 1 = 0.00$
 $M_u = 3.0614186E-011$
 $V_u = 5.3543557E-014$
From (11.5.4.8), ACI 318-14: $V_s = 94247.78$
 $A_v = 157079.633$
 $f_y = 500.00$
 $s = 150.00$
 V_s has been multiplied by $2(1-s/d)$ ($s > d/2$, according to ASCE 41-17, 10.3.4)
 $2(1-s/d) = 0.75$
 V_f ((11-3)-(11.4), ACI 440) = 0.00
From (11-11), ACI 440: $V_s + V_f \leq 318865.838$

End Of Calculation of Shear Capacity for element: beam B1 of floor 1
At local axis: 2
Integration Section: (a)

Calculation No. 2

beam B1, Floor 1



Limit State: Operational Level (data interpolation between analysis steps 1 and 2)

Analysis: Uniform +X

Check: Chord rotation capacity (μ)

Edge: Start

Local Axis: (2)



Start Of Calculation of Shear Capacity ratio for element: beam B1 of floor 1

At Shear local axis: 3

(Bending local axis: 2)

Section Type: rcars

Constant Properties

Knowledge Factor, $\gamma = 1.00$

Mean strength values are used for both shear and moment calculations.

Consequently:

New material of Secondary Member: Concrete Strength, $f_c = f_{cm} = 33.00$

New material of Secondary Member: Steel Strength, $f_s = f_{sm} = 555.56$

Concrete Elasticity, $E_c = 26999.444$

Steel Elasticity, $E_s = 200000.00$

#####

Note: Especially for the calculation of moment strengths,

the above steel re-bar strengths are multiplied by 1.25 according to R18.6.5, ACI 318-14

New material: Steel Strength, $f_s = 1.25 \cdot f_{sm} = 694.45$

#####

Section Height, $H = 400.00$

Section Width, $W = 300.00$

Cover Thickness, $c = 25.00$

Mean Confinement Factor overall section = 1.00

Element Length, $L = 1850.00$

Secondary Member

Smooth Bars

Ductile Steel

Without Detailing for Earthquake Resistance (including stirrups not closed at 135°)

Longitudinal Bars With Ends Lapped Starting at the End Sections

Inadequate Lap Length with $l_o/l_{ou,min} = 0.30$

No FRP Wrapping

Stepwise Properties

At local axis: 3

EDGE -A-

Shear Force, $V_a = 2771.021$

EDGE -B-

Shear Force, $V_b = 2771.021$

BOTH EDGES

Axial Force, $F = -190.8684$

Longitudinal Reinforcement Area Distribution (in 2 divisions)

-Tension: $As_t = 911.0619$

-Compression: $As_c = 1231.504$

Longitudinal Reinforcement Area Distribution (in 3 divisions)

-Tension: $As_{t,ten} = 603.1858$

-Compression: $As_{c,com} = 923.6282$

-Middle: $As_{mid} = 615.7522$

Calculation of Shear Capacity ratio, $V_e/V_r = 0.59550037$

Member Controlled by Flexure ($V_e/V_r < 1$)

Calculation of Shear Demand from fig. R18.6.5, ACI 318-14 $V_e = (M_{pr1} + M_{pr2})/l_n \pm w_u \cdot l_n / 2 = 172632.267$
with

$M_{pr1} = \text{Max}(Mu_{1+}, Mu_{1-}) = 1.5721E+008$

$Mu_{1+} = 1.1233E+008$, is the ultimate moment strength at the edge 1 of the member in the actual moment direction which is defined for the static loading combination

$Mu_{1-} = 1.5721E+008$, is the ultimate moment strength at the edge 1 of the member in the opposite moment direction which is defined for the static loading combination

$M_{pr2} = \text{Max}(Mu_{2+}, Mu_{2-}) = 1.5703E+008$

$Mu_{2+} = 1.1247E+008$, is the ultimate moment strength at the edge 2 of the member in the actual moment direction which is defined for the the static loading combination

$Mu_{2-} = 1.5703E+008$, is the ultimate moment strength at the edge 2 of the member in the opposite moment direction which is defined for the the static loading combination

and

$\pm w_u \cdot l_n = (|V_1| + |V_2|)/2$

with

$V_1 = 2771.021$, is the shear force acting at edge 1 for the the static loading combination

$V_2 = 2771.021$, is the shear force acting at edge 2 for the the static loading combination

Calculation of Mu_{1+}

Calculation of ultimate curvature u according to 4.1, Biskinis/Fardis 2013:

$u = 1.7687265E-005$

$Mu = 1.1233E+008$

with full section properties:

$b = 300.00$

$d = 357.00$

$d' = 42.00$

$v = 5.4004576E-005$

$N = 190.8684$

$f_c = 33.00$

$co (5A.5, TBDY) = 0.002$

Final value of cu : $cu^* = \text{shear_factor} * \text{Max}(cu, cc) = 0.00553582$

The Shear_factor is considered equal to 1 (pure moment strength)

From (5.4b), TBDY: $cu = 0.00553582$

$w_e (5.4c) = 0.00259035$

$ase ((5.4d), TBDY) = 0.15672608$

$bo = 240.00$

$ho = 340.00$

$bi2 = 346400.00$

$$psh,min = \text{Min}(psh,x, psh,y) = 0.00261799$$

Expression ((5.4d), TBDY) for psh,min has been multiplied by 0.3 according to 15.7.1.3 for members without earthquake detailing (90° closed stirrups)

$$psh,x (5.4d) = 0.00349066$$

$$Ash = Astir*ns = 78.53982$$

$$\text{No stirups, } ns = 2.00$$

$$bk = 300.00$$

$$psh,y (5.4d) = 0.00261799$$

$$Ash = Astir*ns = 78.53982$$

$$\text{No stirups, } ns = 2.00$$

$$bk = 400.00$$

$$s = 150.00$$

$$fywe = 694.45$$

$$fce = 33.00$$

From ((5.A5), TBDY), TBDY: $cc = 0.002$

$$c = \text{confinement factor} = 1.00$$

$$y1 = 0.00140044$$

$$sh1 = 0.0044814$$

$$ft1 = 466.8167$$

$$fy1 = 389.0139$$

$$su1 = 0.00512$$

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor and also multiplied by the shear_factor according to 15.7.1.4, with Shear_factor = 1.00

$$lo/lou,min = lb/d = 0.30$$

$$su1 = 0.4*esu1_nominal ((5.5), TBDY) = 0.032$$

From table 5A.1, TBDY: $esu1_nominal = 0.08$,

For calculation of $esu1_nominal$ and $y1, sh1, ft1, fy1$, it is considered characteristic value $fsy1 = fs/1.2$, from table 5.1, TBDY.

$y1, sh1, ft1, fy1$, are also multiplied by $\text{Min}(1, 1.25*(lb/d)^{2/3})$, from 10.3.5, ASCE 41-17.

$$\text{with } fs1 = fs = 389.0139$$

$$\text{with } Es1 = Es = 200000.00$$

$$y2 = 0.00140044$$

$$sh2 = 0.0044814$$

$$ft2 = 466.8167$$

$$fy2 = 389.0139$$

$$su2 = 0.00512$$

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor and also multiplied by the shear_factor according to 15.7.1.4, with Shear_factor = 1.00

$$lo/lou,min = lb/lb,min = 0.30$$

$$su2 = 0.4*esu2_nominal ((5.5), TBDY) = 0.032$$

From table 5A.1, TBDY: $esu2_nominal = 0.08$,

For calculation of $esu2_nominal$ and $y2, sh2, ft2, fy2$, it is considered characteristic value $fsy2 = fs/1.2$, from table 5.1, TBDY.

$y2, sh2, ft2, fy2$, are also multiplied by $\text{Min}(1, 1.25*(lb/d)^{2/3})$, from 10.3.5, ASCE 41-17.

$$\text{with } fs2 = fs = 389.0139$$

$$\text{with } Es2 = Es = 200000.00$$

$$yv = 0.00140044$$

$$shv = 0.0044814$$

$$ftv = 466.8167$$

$$fyv = 389.0139$$

$$suv = 0.00512$$

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor and also multiplied by the shear_factor according to 15.7.1.4, with Shear_factor = 1.00

$$lo/lou,min = lb/d = 0.30$$

$$suv = 0.4*esuv_nominal ((5.5), TBDY) = 0.032$$

From table 5A.1, TBDY: $esuv_nominal = 0.08$,

considering characteristic value $fsyv = fsv/1.2$, from table 5.1, TBDY
For calculation of $esuv_nominal$ and yv, shv, ftv, fyv , it is considered

characteristic value $fsyv = fsv/1.2$, from table 5.1, TBDY.

$y1, sh1, ft1, fy1$, are also multiplied by $\text{Min}(1, 1.25*(lb/d)^{2/3})$, from 10.3.5, ASCE 41-17.

$$\text{with } fsv = fs = 389.0139$$

with $E_{sv} = E_s = 200000.00$

$$1 = A_{sl,ten}/(b*d)*(f_{s1}/f_c) = 0.06639156$$

$$2 = A_{sl,com}/(b*d)*(f_{s2}/f_c) = 0.10166207$$

$$v = A_{sl,mid}/(b*d)*(f_{sv}/f_c) = 0.06777471$$

and confined core properties:

$$b = 240.00$$

$$d = 327.00$$

$$d' = 12.00$$

$$f_{cc} (5A.2, TBDY) = 33.00$$

$$c_c (5A.5, TBDY) = 0.002$$

c = confinement factor = 1.00

$$1 = A_{sl,ten}/(b*d)*(f_{s1}/f_c) = 0.09060316$$

$$2 = A_{sl,com}/(b*d)*(f_{s2}/f_c) = 0.13873608$$

$$v = A_{sl,mid}/(b*d)*(f_{sv}/f_c) = 0.09249072$$

Case/Assumption: Unconfined full section - Steel rupture

' satisfies Eq. (4.3)

--->

$v < v_{s,y2}$ - LHS eq.(4.5) is satisfied

--->

$$s_u (4.9) = 0.189149$$

$$M_u = M_{Rc} (4.14) = 1.1233E+008$$

$$u = s_u (4.1) = 1.7687265E-005$$

Calculation of ratio l_b/d

Inadequate Lap Length with $l_b/d = 0.30$

Calculation of M_{u1} -

Calculation of ultimate curvature u according to 4.1, Biskinis/Fardis 2013:

$$u = 1.8434312E-005$$

$$M_u = 1.5721E+008$$

with full section properties:

$$b = 300.00$$

$$d = 358.00$$

$$d' = 43.00$$

$$v = 5.3853726E-005$$

$$N = 190.8684$$

$$f_c = 33.00$$

$$c_c (5A.5, TBDY) = 0.002$$

$$\text{Final value of } c_u: c_u^* = \text{shear_factor} * \text{Max}(c_u, c_c) = 0.00553582$$

The Shear_factor is considered equal to 1 (pure moment strength)

$$\text{From (5.4b), TBDY: } c_u = 0.00553582$$

$$w_e (5.4c) = 0.00259035$$

$$a_{se} ((5.4d), TBDY) = 0.15672608$$

$$b_o = 240.00$$

$$h_o = 340.00$$

$$b_{i2} = 346400.00$$

$$p_{sh,min} = \text{Min}(p_{sh,x}, p_{sh,y}) = 0.00261799$$

Expression ((5.4d), TBDY) for $p_{sh,min}$ has been multiplied by 0.3 according to 15.7.1.3 for members without earthquake detailing (90° closed stirrups)

$$p_{sh,x} (5.4d) = 0.00349066$$

$$A_{sh} = A_{stir} * n_s = 78.53982$$

$$\text{No stirrups, } n_s = 2.00$$

$$b_k = 300.00$$

$$p_{sh,y} (5.4d) = 0.00261799$$

$$A_{sh} = A_{stir} * n_s = 78.53982$$

$$\text{No stirrups, } n_s = 2.00$$

$$b_k = 400.00$$

$s = 150.00$
 $fy_{we} = 694.45$
 $f_{ce} = 33.00$
 From ((5.A.5), TBDY), TBDY: $cc = 0.002$
 $c = \text{confinement factor} = 1.00$
 $y_1 = 0.00140044$
 $sh_1 = 0.0044814$
 $ft_1 = 466.8167$
 $fy_1 = 389.0139$
 $su_1 = 0.00512$
 using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
 and also multiplied by the shear_factor according to 15.7.1.4, with
 $\text{Shear_factor} = 1.00$
 $lo/lou, \text{min} = lb/d = 0.30$
 $su_1 = 0.4 * esu_1 \text{ nominal} ((5.5), \text{TBDY}) = 0.032$
 From table 5A.1, TBDY: $esu_1 \text{ nominal} = 0.08$,
 For calculation of $esu_1 \text{ nominal}$ and y_1, sh_1, ft_1, fy_1 , it is considered
 characteristic value $fsy_1 = fs_1/1.2$, from table 5.1, TBDY.
 y_1, sh_1, ft_1, fy_1 , are also multiplied by $\text{Min}(1, 1.25 * (lb/d)^{2/3})$, from 10.3.5, ASCE 41-17.
 with $fs_1 = fs = 389.0139$
 with $Es_1 = Es = 200000.00$
 $y_2 = 0.00140044$
 $sh_2 = 0.0044814$
 $ft_2 = 466.8167$
 $fy_2 = 389.0139$
 $su_2 = 0.00512$
 using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
 and also multiplied by the shear_factor according to 15.7.1.4, with
 $\text{Shear_factor} = 1.00$
 $lo/lou, \text{min} = lb/lb, \text{min} = 0.30$
 $su_2 = 0.4 * esu_2 \text{ nominal} ((5.5), \text{TBDY}) = 0.032$
 From table 5A.1, TBDY: $esu_2 \text{ nominal} = 0.08$,
 For calculation of $esu_2 \text{ nominal}$ and y_2, sh_2, ft_2, fy_2 , it is considered
 characteristic value $fsy_2 = fs_2/1.2$, from table 5.1, TBDY.
 y_1, sh_1, ft_1, fy_1 , are also multiplied by $\text{Min}(1, 1.25 * (lb/d)^{2/3})$, from 10.3.5, ASCE 41-17.
 with $fs_2 = fs = 389.0139$
 with $Es_2 = Es = 200000.00$
 $y_v = 0.00140044$
 $sh_v = 0.0044814$
 $ft_v = 466.8167$
 $fy_v = 389.0139$
 $suv = 0.00512$
 using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
 and also multiplied by the shear_factor according to 15.7.1.4, with
 $\text{Shear_factor} = 1.00$
 $lo/lou, \text{min} = lb/d = 0.30$
 $suv = 0.4 * esuv \text{ nominal} ((5.5), \text{TBDY}) = 0.032$
 From table 5A.1, TBDY: $esuv \text{ nominal} = 0.08$,
 considering characteristic value $fsyv = fsv/1.2$, from table 5.1, TBDY
 For calculation of $esuv \text{ nominal}$ and y_v, sh_v, ft_v, fy_v , it is considered
 characteristic value $fsyv = fsv/1.2$, from table 5.1, TBDY.
 y_1, sh_1, ft_1, fy_1 , are also multiplied by $\text{Min}(1, 1.25 * (lb/d)^{2/3})$, from 10.3.5, ASCE 41-17.
 with $fsv = fs = 389.0139$
 with $Es_v = Es = 200000.00$
 $1 = Asl, \text{ten} / (b * d) * (fs_1 / fc) = 0.1013781$
 $2 = Asl, \text{com} / (b * d) * (fs_2 / fc) = 0.06620611$
 $v = Asl, \text{mid} / (b * d) * (fsv / fc) = 0.0675854$
 and confined core properties:
 $b = 240.00$
 $d = 328.00$
 $d' = 13.00$
 $f_{cc} (5A.2, \text{TBDY}) = 33.00$
 $cc (5A.5, \text{TBDY}) = 0.002$
 $c = \text{confinement factor} = 1.00$
 $1 = Asl, \text{ten} / (b * d) * (fs_1 / fc) = 0.13831311$
 $2 = Asl, \text{com} / (b * d) * (fs_2 / fc) = 0.09032693$

$$v = A_{sl, mid} / (b \cdot d) \cdot (f_{sv} / f_c) = 0.09220874$$

Case/Assumption: Unconfined full section - Steel rupture
' satisfies Eq. (4.3)

--->

$v < v_{s,y2}$ - LHS eq.(4.5) is satisfied

--->

$$s_u(4.9) = 0.22418173$$

$$\mu = M_{Rc}(4.14) = 1.5721E+008$$

$$u = s_u(4.1) = 1.8434312E-005$$

Calculation of ratio l_b/l_d

Inadequate Lap Length with $l_b/l_d = 0.30$

Calculation of μ_{2+}

Calculation of ultimate curvature u according to 4.1, Biskinis/Fardis 2013:

$$u = 1.7651391E-005$$

$$\mu = 1.1247E+008$$

with full section properties:

$$b = 300.00$$

$$d = 358.00$$

$$d' = 43.00$$

$$v = 5.3853726E-005$$

$$N = 190.8684$$

$$f_c = 33.00$$

$$c_o(5A.5, TBDY) = 0.002$$

$$\text{Final value of } c_u: c_u^* = \text{shear_factor} \cdot \text{Max}(c_u, c_c) = 0.00553582$$

The Shear_factor is considered equal to 1 (pure moment strength)

$$\text{From (5.4b), TBDY: } c_u = 0.00553582$$

$$w_e(5.4c) = 0.00259035$$

$$a_{se}((5.4d), TBDY) = 0.15672608$$

$$b_o = 240.00$$

$$h_o = 340.00$$

$$b_{i2} = 346400.00$$

$$p_{sh, min} = \text{Min}(p_{sh, x}, p_{sh, y}) = 0.00261799$$

Expression ((5.4d), TBDY) for $p_{sh, min}$ has been multiplied by 0.3 according to 15.7.1.3 for members without earthquake detailing (90° closed stirrups)

$$p_{sh, x}(5.4d) = 0.00349066$$

$$A_{sh} = A_{stir} \cdot n_s = 78.53982$$

$$\text{No stirrups, } n_s = 2.00$$

$$b_k = 300.00$$

$$p_{sh, y}(5.4d) = 0.00261799$$

$$A_{sh} = A_{stir} \cdot n_s = 78.53982$$

$$\text{No stirrups, } n_s = 2.00$$

$$b_k = 400.00$$

$$s = 150.00$$

$$f_{ywe} = 694.45$$

$$f_{ce} = 33.00$$

$$\text{From ((5.A5), TBDY), TBDY: } c_c = 0.002$$

$$c = \text{confinement factor} = 1.00$$

$$y_1 = 0.00140044$$

$$sh_1 = 0.0044814$$

$$ft_1 = 466.8167$$

$$fy_1 = 389.0139$$

$$su_1 = 0.00512$$

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with

Shear_factor = 1.00

lo/lou,min = lb/d = 0.30

su1 = 0.4*esu1_nominal ((5.5), TBDY) = 0.032

From table 5A.1, TBDY: esu1_nominal = 0.08,

For calculation of esu1_nominal and y1, sh1,ft1,fy1, it is considered characteristic value fsy1 = fs1/1.2, from table 5.1, TBDY.

y1, sh1,ft1,fy1, are also multiplied by $\text{Min}(1, 1.25 \cdot (lb/d)^{2/3})$, from 10.3.5, ASCE 41-17.

with fs1 = fs = 389.0139

with Es1 = Es = 200000.00

y2 = 0.00140044

sh2 = 0.0044814

ft2 = 466.8167

fy2 = 389.0139

su2 = 0.00512

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor and also multiplied by the shear_factor according to 15.7.1.4, with Shear_factor = 1.00

lo/lou,min = lb/lb,min = 0.30

su2 = 0.4*esu2_nominal ((5.5), TBDY) = 0.032

From table 5A.1, TBDY: esu2_nominal = 0.08,

For calculation of esu2_nominal and y2, sh2,ft2,fy2, it is considered characteristic value fsy2 = fs2/1.2, from table 5.1, TBDY.

y1, sh1,ft1,fy1, are also multiplied by $\text{Min}(1, 1.25 \cdot (lb/d)^{2/3})$, from 10.3.5, ASCE 41-17.

with fs2 = fs = 389.0139

with Es2 = Es = 200000.00

yv = 0.00140044

shv = 0.0044814

ftv = 466.8167

fyv = 389.0139

suv = 0.00512

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor and also multiplied by the shear_factor according to 15.7.1.4, with Shear_factor = 1.00

lo/lou,min = lb/d = 0.30

suv = 0.4*esuv_nominal ((5.5), TBDY) = 0.032

From table 5A.1, TBDY: esuv_nominal = 0.08,

considering characteristic value fsyv = fsv/1.2, from table 5.1, TBDY For calculation of esuv_nominal and yv, shv,ftv,fyv, it is considered characteristic value fsyv = fsv/1.2, from table 5.1, TBDY.

y1, sh1,ft1,fy1, are also multiplied by $\text{Min}(1, 1.25 \cdot (lb/d)^{2/3})$, from 10.3.5, ASCE 41-17.

with fsv = fs = 389.0139

with Esv = Es = 200000.00

1 = Asl,ten/(b*d)*(fs1/fc) = 0.06620611

2 = Asl,com/(b*d)*(fs2/fc) = 0.1013781

v = Asl,mid/(b*d)*(fsv/fc) = 0.0675854

and confined core properties:

b = 240.00

d = 328.00

d' = 13.00

fcc (5A.2, TBDY) = 33.00

cc (5A.5, TBDY) = 0.002

c = confinement factor = 1.00

1 = Asl,ten/(b*d)*(fs1/fc) = 0.09032693

2 = Asl,com/(b*d)*(fs2/fc) = 0.13831311

v = Asl,mid/(b*d)*(fsv/fc) = 0.09220874

Case/Assumption: Unconfined full section - Steel rupture

' satisfies Eq. (4.3)

--->

v < vsy2 - LHS eq.(4.5) is satisfied

--->

su (4.9) = 0.18977061

Mu = MRc (4.14) = 1.1247E+008

u = su (4.1) = 1.7651391E-005

Calculation of ratio lb/d

Inadequate Lap Length with $l_b/l_d = 0.30$

Calculation of μ_2 -

Calculation of ultimate curvature μ according to 4.1, Biskinis/Fardis 2013:

$$\mu = 1.8476637E-005$$

$$\mu = 1.5703E+008$$

with full section properties:

$$b = 300.00$$

$$d = 357.00$$

$$d' = 42.00$$

$$v = 5.4004576E-005$$

$$N = 190.8684$$

$$f_c = 33.00$$

$$c_o \text{ (5A.5, TBDY)} = 0.002$$

$$\text{Final value of } c_u: c_u^* = \text{shear_factor} * \text{Max}(c_u, c_c) = 0.00553582$$

The Shear_factor is considered equal to 1 (pure moment strength)

$$\text{From (5.4b), TBDY: } c_u = 0.00553582$$

$$w_e \text{ (5.4c)} = 0.00259035$$

$$a_{se} \text{ ((5.4d), TBDY)} = 0.15672608$$

$$b_o = 240.00$$

$$h_o = 340.00$$

$$b_{i2} = 346400.00$$

$$p_{sh,min} = \text{Min}(p_{sh,x}, p_{sh,y}) = 0.00261799$$

Expression ((5.4d), TBDY) for $p_{sh,min}$ has been multiplied by 0.3 according to 15.7.1.3 for members without earthquake detailing (90° closed stirrups)

$$p_{sh,x} \text{ (5.4d)} = 0.00349066$$

$$A_{sh} = A_{stir} * n_s = 78.53982$$

$$\text{No stirrups, } n_s = 2.00$$

$$b_k = 300.00$$

$$p_{sh,y} \text{ (5.4d)} = 0.00261799$$

$$A_{sh} = A_{stir} * n_s = 78.53982$$

$$\text{No stirrups, } n_s = 2.00$$

$$b_k = 400.00$$

$$s = 150.00$$

$$f_{ywe} = 694.45$$

$$f_{ce} = 33.00$$

$$\text{From ((5.A5), TBDY), TBDY: } c_c = 0.002$$

$$c = \text{confinement factor} = 1.00$$

$$y_1 = 0.00140044$$

$$sh_1 = 0.0044814$$

$$ft_1 = 466.8167$$

$$fy_1 = 389.0139$$

$$su_1 = 0.00512$$

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor and also multiplied by the shear_factor according to 15.7.1.4, with Shear_factor = 1.00

$$l_o/l_{o,min} = l_b/l_d = 0.30$$

$$su_1 = 0.4 * esu_{1,nominal} \text{ ((5.5), TBDY)} = 0.032$$

$$\text{From table 5A.1, TBDY: } esu_{1,nominal} = 0.08,$$

For calculation of $esu_{1,nominal}$ and y_1, sh_1, ft_1, fy_1 , it is considered characteristic value $fsy_1 = fs_1/1.2$, from table 5.1, TBDY.

y_1, sh_1, ft_1, fy_1 , are also multiplied by $\text{Min}(1, 1.25 * (l_b/l_d)^{2/3})$, from 10.3.5, ASCE 41-17.

$$\text{with } fs_1 = fs = 389.0139$$

$$\text{with } Es_1 = Es = 200000.00$$

$$y_2 = 0.00140044$$

$$sh_2 = 0.0044814$$

$$ft_2 = 466.8167$$

$$fy_2 = 389.0139$$

$$su_2 = 0.00512$$

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00

$$lo/lo_{u,min} = lb/lb_{u,min} = 0.30$$

$$su_2 = 0.4 * esu_{2,nominal} ((5.5), TBDY) = 0.032$$

From table 5A.1, TBDY: $esu_{2,nominal} = 0.08$,

For calculation of $esu_{2,nominal}$ and y_2, sh_2, ft_2, fy_2 , it is considered
characteristic value $fsy_2 = fs_2/1.2$, from table 5.1, TBDY.

y_1, sh_1, ft_1, fy_1 , are also multiplied by $\text{Min}(1, 1.25 * (lb/ld)^{2/3})$, from 10.3.5, ASCE 41-17.

$$\text{with } fs_2 = fs = 389.0139$$

$$\text{with } Es_2 = Es = 200000.00$$

$$yv = 0.00140044$$

$$shv = 0.0044814$$

$$ftv = 466.8167$$

$$fyv = 389.0139$$

$$suv = 0.00512$$

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00

$$lo/lo_{u,min} = lb/ld = 0.30$$

$$suv = 0.4 * esuv_{nominal} ((5.5), TBDY) = 0.032$$

From table 5A.1, TBDY: $esuv_{nominal} = 0.08$,

considering characteristic value $fsyv = fsv/1.2$, from table 5.1, TBDY

For calculation of $esuv_{nominal}$ and yv, shv, ftv, fyv , it is considered
characteristic value $fsyv = fsv/1.2$, from table 5.1, TBDY.

y_1, sh_1, ft_1, fy_1 , are also multiplied by $\text{Min}(1, 1.25 * (lb/ld)^{2/3})$, from 10.3.5, ASCE 41-17.

$$\text{with } fsv = fs = 389.0139$$

$$\text{with } Esv = Es = 200000.00$$

$$1 = Asl_{ten}/(b*d) * (fs_1/fc) = 0.10166207$$

$$2 = Asl_{com}/(b*d) * (fs_2/fc) = 0.06639156$$

$$v = Asl_{mid}/(b*d) * (fsv/fc) = 0.06777471$$

and confined core properties:

$$b = 240.00$$

$$d = 327.00$$

$$d' = 12.00$$

$$fcc (5A.2, TBDY) = 33.00$$

$$cc (5A.5, TBDY) = 0.002$$

$$c = \text{confinement factor} = 1.00$$

$$1 = Asl_{ten}/(b*d) * (fs_1/fc) = 0.13873608$$

$$2 = Asl_{com}/(b*d) * (fs_2/fc) = 0.09060316$$

$$v = Asl_{mid}/(b*d) * (fsv/fc) = 0.09249072$$

Case/Assumption: Unconfined full section - Steel rupture

' satisfies Eq. (4.3)

--->

$v < vs_{y2}$ - LHS eq.(4.5) is satisfied

--->

$$su (4.9) = 0.22379076$$

$$\mu = MRc (4.14) = 1.5703E+008$$

$$u = su (4.1) = 1.8476637E-005$$

Calculation of ratio lb/ld

Inadequate Lap Length with $lb/ld = 0.30$

Calculation of Shear Strength $V_r = \text{Min}(V_{r1}, V_{r2}) = 289894.477$

Calculation of Shear Strength at edge 1, $V_{r1} = 289894.477$

$$V_{r1} = V_n ((22.5.1.1), ACI 318-14)$$

NOTE: In expression (22.5.1.1) ' V_w ' is replaced by ' $V_w + f * V_f$ '
where V_f is the contribution of FRPs (11.3), ACI 440).

From Table (22.5.5.1), ACI 318-14: $V_c = 103724.534$
 $= 1$ (normal-weight concrete)
 $f'_c = 33.00$, but $f'_c^{0.5} \leq 8.3$ MPa (22.5.3.1, ACI 318-14)
 $\rho_w = A_s/(b_w*d) = 0.00949023$
 A_s (tension reinf.) = 911.0619
 $b_w = 300.00$
 $d = 320.00$
 $V_u*d/M_u < 1 = 1.00$
 $M_u = 71267.116$
 $V_u = 2771.021$
From (11.5.4.8), ACI 318-14: $V_s = 186169.943$
 $A_v = 157079.633$
 $f_y = 555.56$
 $s = 150.00$
 V_s has been multiplied by 1 ($s < d/2$, according to ASCE 41-17,10.3.4)
 V_f ((11-3)-(11.4), ACI 440) = 0.00
From (11-11), ACI 440: $V_s + V_f \leq 366348.956$

Calculation of Shear Strength at edge 2, $V_{r2} = 289894.477$
 $V_{r2} = V_n$ ((22.5.1.1), ACI 318-14)

NOTE: In expression (22.5.1.1) ' V_w ' is replaced by ' $V_w + \phi V_f$ '
where V_f is the contribution of FRPs (11.3), ACI 440).

From Table (22.5.5.1), ACI 318-14: $V_c = 103724.534$
 $= 1$ (normal-weight concrete)
 $f'_c = 33.00$, but $f'_c^{0.5} \leq 8.3$ MPa (22.5.3.1, ACI 318-14)
 $\rho_w = A_s/(b_w*d) = 0.00949023$
 A_s (tension reinf.) = 911.0619
 $b_w = 300.00$
 $d = 320.00$
 $V_u*d/M_u < 1 = 1.00$
 $M_u = 71267.116$
 $V_u = 2771.021$
From (11.5.4.8), ACI 318-14: $V_s = 186169.943$
 $A_v = 157079.633$
 $f_y = 555.56$
 $s = 150.00$
 V_s has been multiplied by 1 ($s < d/2$, according to ASCE 41-17,10.3.4)
 V_f ((11-3)-(11.4), ACI 440) = 0.00
From (11-11), ACI 440: $V_s + V_f \leq 366348.956$

End Of Calculation of Shear Capacity ratio for element: beam B1 of floor 1
At local axis: 3

Start Of Calculation of Shear Capacity ratio for element: beam B1 of floor 1
At Shear local axis: 2
(Bending local axis: 3)
Section Type: rcars

Constant Properties

Knowledge Factor, $\phi = 1.00$
Mean strength values are used for both shear and moment calculations.
Consequently:
New material of Secondary Member: Concrete Strength, $f_c = f_{cm} = 33.00$
New material of Secondary Member: Steel Strength, $f_s = f_{sm} = 555.56$
Concrete Elasticity, $E_c = 26999.444$
Steel Elasticity, $E_s = 200000.00$

Note: Especially for the calculation of moment strengths,
the above steel re-bar strengths are multiplied by 1.25 according to R18.6.5, ACI 318-14
New material: Steel Strength, $f_s = 1.25*f_{sm} = 694.45$
#####

Section Height, H = 400.00
Section Width, W = 300.00
Cover Thickness, c = 25.00
Mean Confinement Factor overall section = 1.00
Element Length, L = 1850.00
Secondary Member
Smooth Bars
Ductile Steel
Without Detailing for Earthquake Resistance (including stirrups not closed at 135°)
Longitudinal Bars With Ends Lapped Starting at the End Sections
Inadequate Lap Length with $l_o/l_{o,min} = 0.30$
No FRP Wrapping

Stepwise Properties

At local axis: 2
EDGE -A-
Shear Force, $V_a = 4.9160836E-020$
EDGE -B-
Shear Force, $V_b = -4.9160836E-020$
BOTH EDGES
Axial Force, $F = -190.8684$
Longitudinal Reinforcement Area Distribution (in 2 divisions)
-Tension: $A_{st} = 911.0619$
-Compression: $A_{sc} = 1231.504$
Longitudinal Reinforcement Area Distribution (in 3 divisions)
-Tension: $A_{st,ten} = 816.8141$
-Compression: $A_{sc,com} = 816.8141$
-Middle: $A_{st,mid} = 508.938$

Calculation of Shear Capacity ratio, $V_e/V_r = 0.54312483$
Member Controlled by Flexure ($V_e/V_r < 1$)
Calculation of Shear Demand from fig. R18.6.5, ACI 318-14 $V_e = (M_{pr1} + M_{pr2})/l_n \pm w_u \cdot l_n/2 = 104799.778$
with
 $M_{pr1} = \text{Max}(Mu_{1+}, Mu_{1-}) = 9.6940E+007$
 $Mu_{1+} = 9.6940E+007$, is the ultimate moment strength at the edge 1 of the member in the actual moment direction which is defined for the static loading combination
 $Mu_{1-} = 9.6940E+007$, is the ultimate moment strength at the edge 1 of the member in the opposite moment direction which is defined for the static loading combination
 $M_{pr2} = \text{Max}(Mu_{2+}, Mu_{2-}) = 9.6940E+007$
 $Mu_{2+} = 9.6940E+007$, is the ultimate moment strength at the edge 2 of the member in the actual moment direction which is defined for the the static loading combination
 $Mu_{2-} = 9.6940E+007$, is the ultimate moment strength at the edge 2 of the member in the opposite moment direction which is defined for the the static loading combination
and
 $\pm w_u \cdot l_n = (|V_1| + |V_2|)/2$
with
 $V_1 = 4.9160836E-020$, is the shear force acting at edge 1 for the the static loading combination
 $V_2 = -4.9160836E-020$, is the shear force acting at edge 2 for the the static loading combination

Calculation of Mu_{1+}

Calculation of ultimate curvature ϕ_u according to 4.1, Biskinis/Fardis 2013:
 $\phi_u = 2.5454950E-005$
 $Mu = 9.6940E+007$

with full section properties:
 $b = 400.00$
 $d = 258.00$
 $d' = 42.00$

v = 5.6045447E-005

N = 190.8684

fc = 33.00

co (5A.5, TBDY) = 0.002

Final value of cu: $cu^* = \text{shear_factor} * \text{Max}(cu, cc) = 0.00553582$

The Shear_factor is considered equal to 1 (pure moment strength)

From (5.4b), TBDY: $cu = 0.00553582$

we (5.4c) = 0.00259035

ase ((5.4d), TBDY) = 0.15672608

bo = 240.00

ho = 340.00

bi2 = 346400.00

psh,min = Min(psh,x, psh,y) = 0.00261799

Expression ((5.4d), TBDY) for psh,min has been multiplied by 0.3 according to 15.7.1.3 for members without earthquake detailing (90° closed stirrups)

psh,x (5.4d) = 0.00349066

Ash = Astir*ns = 78.53982

No stirrups, ns = 2.00

bk = 300.00

psh,y (5.4d) = 0.00261799

Ash = Astir*ns = 78.53982

No stirrups, ns = 2.00

bk = 400.00

s = 150.00

fywe = 694.45

fce = 33.00

From ((5.A5), TBDY), TBDY: $cc = 0.002$

c = confinement factor = 1.00

y1 = 0.00140044

sh1 = 0.0044814

ft1 = 466.8167

fy1 = 389.0139

su1 = 0.00512

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor and also multiplied by the shear_factor according to 15.7.1.4, with Shear_factor = 1.00

lo/lou,min = lb/lb,min = 0.30

su1 = $0.4 * \text{esu1_nominal} ((5.5), \text{TBDY}) = 0.032$

From table 5A.1, TBDY: $\text{esu1_nominal} = 0.08$,

For calculation of esu1_nominal and y1, sh1,ft1,fy1, it is considered characteristic value $\text{fsy1} = \text{fs1}/1.2$, from table 5.1, TBDY.

y1, sh1,ft1,fy1, are also multiplied by $\text{Min}(1, 1.25 * (\text{lb}/\text{ld})^{2/3})$, from 10.3.5, ASCE 41-17.

with $\text{fs1} = \text{fs} = 389.0139$

with $\text{Es1} = \text{Es} = 200000.00$

y2 = 0.00140044

sh2 = 0.0044814

ft2 = 466.8167

fy2 = 389.0139

su2 = 0.00512

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor and also multiplied by the shear_factor according to 15.7.1.4, with Shear_factor = 1.00

lo/lou,min = lb/lb,min = 0.30

su2 = $0.4 * \text{esu2_nominal} ((5.5), \text{TBDY}) = 0.032$

From table 5A.1, TBDY: $\text{esu2_nominal} = 0.08$,

For calculation of esu2_nominal and y2, sh2,ft2,fy2, it is considered characteristic value $\text{fsy2} = \text{fs2}/1.2$, from table 5.1, TBDY.

y1, sh1,ft1,fy1, are also multiplied by $\text{Min}(1, 1.25 * (\text{lb}/\text{ld})^{2/3})$, from 10.3.5, ASCE 41-17.

with $\text{fs2} = \text{fs} = 389.0139$

with $\text{Es2} = \text{Es} = 200000.00$

yv = 0.00140044

shv = 0.0044814

ftv = 466.8167

fyv = 389.0139

suv = 0.00512

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00

lo/lou,min = lb/d = 0.30

suv = 0.4*esuv_nominal ((5.5), TBDY) = 0.032

From table 5A.1, TBDY: esuv_nominal = 0.08,

considering characteristic value fsyv = fsv/1.2, from table 5.1, TBDY

For calculation of esuv_nominal and yv, shv,ftv,fyv, it is considered
characteristic value fsyv = fsv/1.2, from table 5.1, TBDY.

y1, sh1,ft1,fy1, are also multiplied by $\text{Min}(1, 1.25 \cdot (lb/d)^{2/3})$, from 10.3.5, ASCE 41-17.

with fsv = fs = 389.0139

with Esv = Es = 200000.00

1 = Asl,ten/(b*d)*(fs1/fc) = 0.09330282

2 = Asl,com/(b*d)*(fs2/fc) = 0.09330282

v = Asl,mid/(b*d)*(fsv/fc) = 0.05813483

and confined core properties:

b = 340.00

d = 228.00

d' = 12.00

fcc (5A.2, TBDY) = 33.00

cc (5A.5, TBDY) = 0.002

c = confinement factor = 1.00

1 = Asl,ten/(b*d)*(fs1/fc) = 0.12421118

2 = Asl,com/(b*d)*(fs2/fc) = 0.12421118

v = Asl,mid/(b*d)*(fsv/fc) = 0.07739312

Case/Assumption: Unconfined full section - Steel rupture

' satisfies Eq. (4.3)

--->

v < vs,y2 - LHS eq.(4.5) is satisfied

--->

su (4.9) = 0.22038892

Mu = MRc (4.14) = 9.6940E+007

u = su (4.1) = 2.5454950E-005

Calculation of ratio lb/d

Inadequate Lap Length with lb/d = 0.30

Calculation of Mu1-

Calculation of ultimate curvature u according to 4.1, Biskinis/Fardis 2013:

u = 2.5454950E-005

Mu = 9.6940E+007

with full section properties:

b = 400.00

d = 258.00

d' = 42.00

v = 5.6045447E-005

N = 190.8684

fc = 33.00

co (5A.5, TBDY) = 0.002

Final value of cu: $cu^* = \text{shear_factor} \cdot \text{Max}(cu, cc) = 0.00553582$

The Shear_factor is considered equal to 1 (pure moment strength)

From (5.4b), TBDY: cu = 0.00553582

we (5.4c) = 0.00259035

ase ((5.4d), TBDY) = 0.15672608

bo = 240.00

ho = 340.00

bi2 = 346400.00

psh,min = $\text{Min}(psh,x, psh,y) = 0.00261799$

Expression ((5.4d), TBDY) for psh,min has been multiplied by 0.3 according to 15.7.1.3 for members without earthquake detailing (90° closed stirrups)

psh,x (5.4d) = 0.00349066
Ash = Astir*ns = 78.53982
No stirups, ns = 2.00
bk = 300.00

psh,y (5.4d) = 0.00261799
Ash = Astir*ns = 78.53982
No stirups, ns = 2.00
bk = 400.00

s = 150.00
fywe = 694.45
fce = 33.00

From ((5.A5), TBDY), TBDY: cc = 0.002
c = confinement factor = 1.00

y1 = 0.00140044
sh1 = 0.0044814
ft1 = 466.8167
fy1 = 389.0139
su1 = 0.00512

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00

lo/lou,min = lb/d = 0.30

su1 = 0.4*esu1_nominal ((5.5), TBDY) = 0.032

From table 5A.1, TBDY: esu1_nominal = 0.08,

For calculation of esu1_nominal and y1, sh1,ft1,fy1, it is considered
characteristic value fsy1 = fs1/1.2, from table 5.1, TBDY.

y1, sh1,ft1,fy1, are also multiplied by $\text{Min}(1, 1.25 \cdot (lb/d)^{2/3})$, from 10.3.5, ASCE 41-17.

with fs1 = fs = 389.0139

with Es1 = Es = 200000.00

y2 = 0.00140044
sh2 = 0.0044814
ft2 = 466.8167
fy2 = 389.0139
su2 = 0.00512

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00

lo/lou,min = lb/lb,min = 0.30

su2 = 0.4*esu2_nominal ((5.5), TBDY) = 0.032

From table 5A.1, TBDY: esu2_nominal = 0.08,

For calculation of esu2_nominal and y2, sh2,ft2,fy2, it is considered
characteristic value fsy2 = fs2/1.2, from table 5.1, TBDY.

y1, sh1,ft1,fy1, are also multiplied by $\text{Min}(1, 1.25 \cdot (lb/d)^{2/3})$, from 10.3.5, ASCE 41-17.

with fs2 = fs = 389.0139

with Es2 = Es = 200000.00

yv = 0.00140044
shv = 0.0044814
ftv = 466.8167
fyv = 389.0139
suv = 0.00512

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00

lo/lou,min = lb/d = 0.30

suv = 0.4*esuv_nominal ((5.5), TBDY) = 0.032

From table 5A.1, TBDY: esuv_nominal = 0.08,

considering characteristic value fsyv = fsv/1.2, from table 5.1, TBDY

For calculation of esuv_nominal and yv, shv,ftv,fyv, it is considered
characteristic value fsyv = fsv/1.2, from table 5.1, TBDY.

y1, sh1,ft1,fy1, are also multiplied by $\text{Min}(1, 1.25 \cdot (lb/d)^{2/3})$, from 10.3.5, ASCE 41-17.

with fsv = fs = 389.0139

with Esv = Es = 200000.00

$$1 = A_{sl,ten}/(b*d)*(f_{s1}/f_c) = 0.09330282$$

$$2 = A_{sl,com}/(b*d)*(f_{s2}/f_c) = 0.09330282$$

$$v = A_{sl,mid}/(b*d)*(f_{sv}/f_c) = 0.05813483$$

and confined core properties:

$$b = 340.00$$

$$d = 228.00$$

$$d' = 12.00$$

$$f_{cc} (5A.2, TBDY) = 33.00$$

$$c_c (5A.5, TBDY) = 0.002$$

$$c = \text{confinement factor} = 1.00$$

$$1 = A_{sl,ten}/(b*d)*(f_{s1}/f_c) = 0.12421118$$

$$2 = A_{sl,com}/(b*d)*(f_{s2}/f_c) = 0.12421118$$

$$v = A_{sl,mid}/(b*d)*(f_{sv}/f_c) = 0.07739312$$

Case/Assumption: Unconfined full section - Steel rupture

' satisfies Eq. (4.3)

--->

$v < v_{s,y2}$ - LHS eq.(4.5) is satisfied

--->

$$s_u (4.9) = 0.22038892$$

$$M_u = M_{Rc} (4.14) = 9.6940E+007$$

$$u = s_u (4.1) = 2.5454950E-005$$

Calculation of ratio l_b/l_d

Inadequate Lap Length with $l_b/l_d = 0.30$

Calculation of M_{u2+}

Calculation of ultimate curvature ϕ_u according to 4.1, Biskinis/Fardis 2013:

$$u = 2.5454950E-005$$

$$M_u = 9.6940E+007$$

with full section properties:

$$b = 400.00$$

$$d = 258.00$$

$$d' = 42.00$$

$$v = 5.6045447E-005$$

$$N = 190.8684$$

$$f_c = 33.00$$

$$c_c (5A.5, TBDY) = 0.002$$

$$\text{Final value of } \phi_u: \phi_u^* = \text{shear_factor} * \text{Max}(\phi_{cu}, \phi_{cc}) = 0.00553582$$

The Shear_factor is considered equal to 1 (pure moment strength)

$$\text{From (5.4b), TBDY: } \phi_{cu} = 0.00553582$$

$$\phi_{we} (5.4c) = 0.00259035$$

$$\phi_{ase} ((5.4d), TBDY) = 0.15672608$$

$$b_o = 240.00$$

$$h_o = 340.00$$

$$b_{i2} = 346400.00$$

$$\phi_{psh,min} = \text{Min}(\phi_{psh,x}, \phi_{psh,y}) = 0.00261799$$

Expression ((5.4d), TBDY) for $\phi_{psh,min}$ has been multiplied by 0.3 according to 15.7.1.3 for members without earthquake detailing (90° closed stirrups)

$$\phi_{psh,x} (5.4d) = 0.00349066$$

$$A_{sh} = A_{stir} * n_s = 78.53982$$

$$\text{No stirrups, } n_s = 2.00$$

$$b_k = 300.00$$

$$\phi_{psh,y} (5.4d) = 0.00261799$$

$$A_{sh} = A_{stir} * n_s = 78.53982$$

$$\text{No stirrups, } n_s = 2.00$$

$$b_k = 400.00$$

$$s = 150.00$$

$$f_{ywe} = 694.45$$

$$f_{ce} = 33.00$$

From ((5.A.5), TBDY), TBDY: $cc = 0.002$

$$c = \text{confinement factor} = 1.00$$

$$y_1 = 0.00140044$$

$$sh_1 = 0.0044814$$

$$ft_1 = 466.8167$$

$$fy_1 = 389.0139$$

$$su_1 = 0.00512$$

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00

$$l_0/l_{ou,min} = l_b/l_d = 0.30$$

$$su_1 = 0.4 * esu_{1,nominal} ((5.5), TBDY) = 0.032$$

From table 5A.1, TBDY: $esu_{1,nominal} = 0.08$,

For calculation of $esu_{1,nominal}$ and y_1, sh_1, ft_1, fy_1 , it is considered
characteristic value $fsy_1 = fs_1/1.2$, from table 5.1, TBDY.

y_1, sh_1, ft_1, fy_1 , are also multiplied by $\text{Min}(1, 1.25 * (l_b/l_d)^{2/3})$, from 10.3.5, ASCE 41-17.

$$\text{with } fs_1 = fs = 389.0139$$

$$\text{with } Es_1 = Es = 200000.00$$

$$y_2 = 0.00140044$$

$$sh_2 = 0.0044814$$

$$ft_2 = 466.8167$$

$$fy_2 = 389.0139$$

$$su_2 = 0.00512$$

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00

$$l_0/l_{ou,min} = l_b/l_{b,min} = 0.30$$

$$su_2 = 0.4 * esu_{2,nominal} ((5.5), TBDY) = 0.032$$

From table 5A.1, TBDY: $esu_{2,nominal} = 0.08$,

For calculation of $esu_{2,nominal}$ and y_2, sh_2, ft_2, fy_2 , it is considered
characteristic value $fsy_2 = fs_2/1.2$, from table 5.1, TBDY.

y_1, sh_1, ft_1, fy_1 , are also multiplied by $\text{Min}(1, 1.25 * (l_b/l_d)^{2/3})$, from 10.3.5, ASCE 41-17.

$$\text{with } fs_2 = fs = 389.0139$$

$$\text{with } Es_2 = Es = 200000.00$$

$$y_v = 0.00140044$$

$$sh_v = 0.0044814$$

$$ft_v = 466.8167$$

$$fy_v = 389.0139$$

$$su_v = 0.00512$$

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00

$$l_0/l_{ou,min} = l_b/l_d = 0.30$$

$$su_v = 0.4 * esu_{v,nominal} ((5.5), TBDY) = 0.032$$

From table 5A.1, TBDY: $esu_{v,nominal} = 0.08$,

considering characteristic value $fsy_v = fs_v/1.2$, from table 5.1, TBDY
For calculation of $esu_{v,nominal}$ and y_v, sh_v, ft_v, fy_v , it is considered
characteristic value $fsy_v = fs_v/1.2$, from table 5.1, TBDY.

y_1, sh_1, ft_1, fy_1 , are also multiplied by $\text{Min}(1, 1.25 * (l_b/l_d)^{2/3})$, from 10.3.5, ASCE 41-17.

$$\text{with } fs_v = fs = 389.0139$$

$$\text{with } Es_v = Es = 200000.00$$

$$1 = Asl_{ten}/(b*d) * (fs_1/f_c) = 0.09330282$$

$$2 = Asl_{com}/(b*d) * (fs_2/f_c) = 0.09330282$$

$$v = Asl_{mid}/(b*d) * (fs_v/f_c) = 0.05813483$$

and confined core properties:

$$b = 340.00$$

$$d = 228.00$$

$$d' = 12.00$$

$$f_{cc} (5A.2, TBDY) = 33.00$$

$$cc (5A.5, TBDY) = 0.002$$

$$c = \text{confinement factor} = 1.00$$

$$1 = Asl_{ten}/(b*d) * (fs_1/f_c) = 0.12421118$$

$$2 = Asl_{com}/(b*d) * (fs_2/f_c) = 0.12421118$$

$$v = Asl_{mid}/(b*d) * (fs_v/f_c) = 0.07739312$$

Case/Assumption: Unconfined full section - Steel rupture
' satisfies Eq. (4.3)

--->
v < vs,y2 - LHS eq.(4.5) is satisfied

--->
su (4.9) = 0.22038892
Mu = MRc (4.14) = 9.6940E+007
u = su (4.1) = 2.5454950E-005

Calculation of ratio lb/ld

Inadequate Lap Length with lb/ld = 0.30

Calculation of Mu2-

Calculation of ultimate curvature u according to 4.1, Biskinis/Fardis 2013:

u = 2.5454950E-005
Mu = 9.6940E+007

with full section properties:

b = 400.00
d = 258.00
d' = 42.00
v = 5.6045447E-005
N = 190.8684
fc = 33.00
co (5A.5, TBDY) = 0.002
Final value of cu: cu* = shear_factor * Max(cu, cc) = 0.00553582
The Shear_factor is considered equal to 1 (pure moment strength)
From (5.4b), TBDY: cu = 0.00553582
we (5.4c) = 0.00259035
ase ((5.4d), TBDY) = 0.15672608
bo = 240.00
ho = 340.00
bi2 = 346400.00
psh,min = Min(psh,x , psh,y) = 0.00261799

Expression ((5.4d), TBDY) for psh,min has been multiplied by 0.3 according to 15.7.1.3 for members without earthquake detailing (90° closed stirrups)

psh,x (5.4d) = 0.00349066
Ash = Astir*ns = 78.53982
No stirups, ns = 2.00
bk = 300.00

psh,y (5.4d) = 0.00261799
Ash = Astir*ns = 78.53982
No stirups, ns = 2.00
bk = 400.00

s = 150.00
fywe = 694.45
fce = 33.00

From ((5A5), TBDY), TBDY: cc = 0.002
c = confinement factor = 1.00

y1 = 0.00140044
sh1 = 0.0044814
ft1 = 466.8167
fy1 = 389.0139
su1 = 0.00512

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00

$$l_o/l_{o,min} = l_b/l_d = 0.30$$

$$s_u1 = 0.4 * e_{s1_nominal} ((5.5), TBDY) = 0.032$$

$$\text{From table 5A.1, TBDY: } e_{s1_nominal} = 0.08,$$

For calculation of $e_{s1_nominal}$ and y_1, sh_1, ft_1, fy_1 , it is considered characteristic value $f_{sy1} = f_{s1}/1.2$, from table 5.1, TBDY.

y_1, sh_1, ft_1, fy_1 , are also multiplied by $\text{Min}(1, 1.25 * (l_b/l_d)^{2/3})$, from 10.3.5, ASCE 41-17.

$$\text{with } f_{s1} = f_s = 389.0139$$

$$\text{with } E_{s1} = E_s = 200000.00$$

$$y_2 = 0.00140044$$

$$sh_2 = 0.0044814$$

$$ft_2 = 466.8167$$

$$fy_2 = 389.0139$$

$$s_u2 = 0.00512$$

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor and also multiplied by the shear_factor according to 15.7.1.4, with Shear_factor = 1.00

$$l_o/l_{o,min} = l_b/l_{b,min} = 0.30$$

$$s_u2 = 0.4 * e_{s2_nominal} ((5.5), TBDY) = 0.032$$

$$\text{From table 5A.1, TBDY: } e_{s2_nominal} = 0.08,$$

For calculation of $e_{s2_nominal}$ and y_2, sh_2, ft_2, fy_2 , it is considered characteristic value $f_{sy2} = f_{s2}/1.2$, from table 5.1, TBDY.

y_2, sh_2, ft_2, fy_2 , are also multiplied by $\text{Min}(1, 1.25 * (l_b/l_d)^{2/3})$, from 10.3.5, ASCE 41-17.

$$\text{with } f_{s2} = f_s = 389.0139$$

$$\text{with } E_{s2} = E_s = 200000.00$$

$$y_v = 0.00140044$$

$$sh_v = 0.0044814$$

$$ft_v = 466.8167$$

$$fy_v = 389.0139$$

$$s_uv = 0.00512$$

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor and also multiplied by the shear_factor according to 15.7.1.4, with Shear_factor = 1.00

$$l_o/l_{o,min} = l_b/l_d = 0.30$$

$$s_uv = 0.4 * e_{suv_nominal} ((5.5), TBDY) = 0.032$$

$$\text{From table 5A.1, TBDY: } e_{suv_nominal} = 0.08,$$

considering characteristic value $f_{syv} = f_{sv}/1.2$, from table 5.1, TBDY
For calculation of $e_{suv_nominal}$ and y_v, sh_v, ft_v, fy_v , it is considered characteristic value $f_{syv} = f_{sv}/1.2$, from table 5.1, TBDY.

y_1, sh_1, ft_1, fy_1 , are also multiplied by $\text{Min}(1, 1.25 * (l_b/l_d)^{2/3})$, from 10.3.5, ASCE 41-17.

$$\text{with } f_{sv} = f_s = 389.0139$$

$$\text{with } E_{sv} = E_s = 200000.00$$

$$1 = A_{sl,ten}/(b*d) * (f_{s1}/f_c) = 0.09330282$$

$$2 = A_{sl,com}/(b*d) * (f_{s2}/f_c) = 0.09330282$$

$$v = A_{sl,mid}/(b*d) * (f_{sv}/f_c) = 0.05813483$$

and confined core properties:

$$b = 340.00$$

$$d = 228.00$$

$$d' = 12.00$$

$$f_{cc} (5A.2, TBDY) = 33.00$$

$$c_c (5A.5, TBDY) = 0.002$$

$$c = \text{confinement factor} = 1.00$$

$$1 = A_{sl,ten}/(b*d) * (f_{s1}/f_c) = 0.12421118$$

$$2 = A_{sl,com}/(b*d) * (f_{s2}/f_c) = 0.12421118$$

$$v = A_{sl,mid}/(b*d) * (f_{sv}/f_c) = 0.07739312$$

Case/Assumption: Unconfined full section - Steel rupture

' satisfies Eq. (4.3)

$v < v_{s,y2}$ - LHS eq.(4.5) is satisfied

$$s_u (4.9) = 0.22038892$$

$$\mu = M_{Rc} (4.14) = 9.6940E+007$$

$$u = s_u (4.1) = 2.5454950E-005$$

Calculation of ratio l_b/l_d

Inadequate Lap Length with $l_b/l_d = 0.30$

Calculation of Shear Strength $V_r = \text{Min}(V_{r1}, V_{r2}) = 192957.075$

Calculation of Shear Strength at edge 1, $V_{r1} = 192957.075$
 $V_{r1} = V_n$ ((22.5.1.1), ACI 318-14)

NOTE: In expression (22.5.1.1) 'Vw' is replaced by 'Vw+ f*Vf'
where Vf is the contribution of FRPs (11.3), ACI 440).

From Table (22.5.5.1), ACI 318-14: $V_c = 88236.482$
= 1 (normal-weight concrete)
 $f_c' = 33.00$, but $f_c'^{0.5} \leq 8.3$ MPa (22.5.3.1, ACI 318-14)
 $p_w = A_s/(b_w*d) = 0.00949023$
 A_s (tension reinf.) = 911.0619
 $b_w = 400.00$
 $d = 240.00$
 $V_u*d/M_u < 1 = 0.00$
 $M_u = 3.3205266E-012$
 $V_u = 4.9160836E-020$

From (11.5.4.8), ACI 318-14: $V_s = 104720.593$
 $A_v = 157079.633$
 $f_y = 555.56$
 $s = 150.00$

V_s has been multiplied by $2(1-s/d)$ ($s > d/2$, according to ASCE 41-17,10.3.4)
 $2(1-s/d) = 0.75$
 V_f ((11-3)-(11.4), ACI 440) = 0.00
From (11-11), ACI 440: $V_s + V_f \leq 366348.956$

Calculation of Shear Strength at edge 2, $V_{r2} = 192957.075$
 $V_{r2} = V_n$ ((22.5.1.1), ACI 318-14)

NOTE: In expression (22.5.1.1) 'Vw' is replaced by 'Vw+ f*Vf'
where Vf is the contribution of FRPs (11.3), ACI 440).

From Table (22.5.5.1), ACI 318-14: $V_c = 88236.482$
= 1 (normal-weight concrete)
 $f_c' = 33.00$, but $f_c'^{0.5} \leq 8.3$ MPa (22.5.3.1, ACI 318-14)
 $p_w = A_s/(b_w*d) = 0.00949023$
 A_s (tension reinf.) = 911.0619
 $b_w = 400.00$
 $d = 240.00$
 $V_u*d/M_u < 1 = 0.00$
 $M_u = 3.3203395E-012$
 $V_u = 4.9160836E-020$

From (11.5.4.8), ACI 318-14: $V_s = 104720.593$
 $A_v = 157079.633$
 $f_y = 555.56$
 $s = 150.00$

V_s has been multiplied by $2(1-s/d)$ ($s > d/2$, according to ASCE 41-17,10.3.4)
 $2(1-s/d) = 0.75$
 V_f ((11-3)-(11.4), ACI 440) = 0.00
From (11-11), ACI 440: $V_s + V_f \leq 366348.956$

End Of Calculation of Shear Capacity ratio for element: beam B1 of floor 1
At local axis: 2

Start Of Calculation of Chord Rotation Capacity for element: beam B1 of floor 1
At local axis: 2
Integration Section: (a)
Section Type: rcars

Constant Properties

Knowledge Factor, $\phi = 1.00$

Chord Rotation is generally considered as Deformation-Controlled Action according to Table C7-1, ASCE 41-17.

Mean strengths are used for Deformation-Controlled Actions according to 7.5.1.3, ASCE 41-17

Consequently:

New material of Secondary Member: Concrete Strength, $f_c = f_{cm} = 33.00$

New material of Secondary Member: Steel Strength, $f_s = f_{sm} = 555.56$

Concrete Elasticity, $E_c = 26999.444$

Steel Elasticity, $E_s = 200000.00$

Section Height, $H = 400.00$

Section Width, $W = 300.00$

Cover Thickness, $c = 25.00$

Element Length, $L = 1850.00$

Secondary Member

Smooth Bars

Ductile Steel

Without Detailing for Earthquake Resistance (including stirrups not closed at 135°)

Longitudinal Bars With Ends Lapped Starting at the End Sections

Inadequate Lap Length with $l_b/l_d = 0.30$

No FRP Wrapping

Stepwise Properties

Bending Moment, $M = 6.8399E+006$

Shear Force, $V_2 = 5.3543557E-014$

Shear Force, $V_3 = -4685.405$

Axial Force, $F = -613.7698$

Longitudinal Reinforcement Area Distribution (in 2 divisions)

-Tension: $A_{st} = 911.0619$

-Compression: $A_{sc} = 1231.504$

Longitudinal Reinforcement Area Distribution (in 3 divisions)

-Tension: $A_{st,ten} = 603.1858$

-Compression: $A_{st,com} = 923.6282$

-Middle: $A_{st,mid} = 615.7522$

Mean Diameter of Tension Reinforcement, $D_bL = 16.00$

New component: From table 7-7, ASCE 41_17: Final chord rotation Capacity $u_{,R} = 1.0^*$ $u = 0.00799054$

$u = y + p = 0.00799054$

- Calculation of y -

$y = (M_y * L_s / 3) / E_{eff} = 0.00299054$ ((4.29), Biskinis Phd))

$M_y = 7.9646E+007$

$L_s = M/V$ (with $L_s > 0.1 * L$ and $L_s < 2 * L$) = 1459.828

From table 10.5, ASCE 41_17: $E_{eff} = 0.3 * E_c * I_g = 1.2960E+013$

Calculation of Yielding Moment M_y

Calculation of y and M_y according to Annex 7 -

$y = \text{Min}(y_{ten}, y_{com})$

$y_{ten} = 5.9058454E-006$

with ((10.1), ASCE 41-17) $f_y = \text{Min}(f_y, 1.25 * f_y * (l_b/l_d)^{2/3}) = 311.2112$

$d = 357.00$

$y = 0.26196855$

$A = 0.0200237$

$B = 0.00987784$

with $p_t = 0.00563199$

$p_c = 0.00862398$

pv = 0.00574932
N = 613.7698
b = 300.00
" = 0.11764706
y_comp = 2.3540693E-005
with fc = 33.00
Ec = 26999.444
y = 0.26178464
A = 0.01999226
B = 0.00985943
with Es = 200000.00

Calculation of ratio lb/d

Inadequate Lap Length with lb/d = 0.30

- Calculation of p -

From table 10-7: p = 0.005

with:

- Condition iv occurred

Beam controlled by inadequate embedment into beam-column joint:
(lb/d < 1 and With Lapping in the Vicinity of the End Regions

- Condition i occurred

Beam controlled by flexure: $V_p/V_o \leq 1$
shear control ratio $V_p/V_o = 0.59550037$

- Transverse Reinforcement: NC

- Stirrup Spacing > d/3

- Low ductility demand, $\lambda / y < 2$ (table 10-6, ASCE 41-17)
= 6.0619939E-005

- Stirrup Spacing $\leq d/2$

d = 357.00

s = 150.00

- Strength provided by hoops $V_s < 3/4$ *design Shear

$V_s = 186169.943$, already given in calculation of shear control ratio
design Shear = 4685.405

- (-)/ bal = -0.17558466

= $A_{st}/(b_w*d) = 0.00850665$

Tension Reinf Area: $A_{st} = 911.0619$

' = $A_{sc}/(b_w*d) = 0.01149864$

Compression Reinf Area: $A_{sc} = 1231.504$

From (B-1), ACI 318-11: bal = 0.01704017

fc = 33.00

fy = 555.56

From 10.2.7.3, ACI 318-11: $\lambda = 0.65$

From fig R10.3.3, ACI 318-11 (Ence 454, too): $87000/(87000+fy) = cb/dt = 0.003/(0.003+ y) = 0.51922877$
y = 0.0027778

- $V/(b_w*d*fc^{0.5}) = 0.09171153$, NOTE: units in lb & in

b_w = 300.00

End Of Calculation of Chord Rotation Capacity for element: beam B1 of floor 1

At local axis: 2

Integration Section: (a)

Calculation No. 3

beam B1, Floor 1



Limit State: Operational Level (data interpolation between analysis steps 1 and 2)

Analysis: Uniform +X

Check: Shear capacity VRd

Edge: Start

Local Axis: (3)



Start Of Calculation of Shear Capacity for element: beam B1 of floor 1

At local axis: 3

Integration Section: (a)

Section Type: rcars

Constant Properties

Knowledge Factor, $\gamma = 1.00$

Member Shear Force is generally considered as Force-Controlled Action according to Table C7-1, ASCE 41-17.

Lower-bound strengths are used for Force-Controlled Actions according to 7.5.1.3, ASCE 41-17

Consequently:

New material of Secondary Member: Concrete Strength, $f_c = f_{c_lower_bound} = 25.00$

New material of Secondary Member: Steel Strength, $f_s = f_{s_lower_bound} = 500.00$

Concrete Elasticity, $E_c = 26999.444$

Steel Elasticity, $E_s = 200000.00$

Section Height, $H = 400.00$

Section Width, $W = 300.00$

Cover Thickness, $c = 25.00$

Element Length, $L = 1850.00$

Secondary Member

Smooth Bars

Ductile Steel

Without Detailing for Earthquake Resistance (including stirrups not closed at 135°)

Longitudinal Bars With Ends Lapped Starting at the End Sections

Inadequate Lap Length with $l_o/l_{o,min} = l_b/l_d = 0.30$

No FRP Wrapping

Stepwise Properties

EDGE -A-

Bending Moment, $M_a = 6.8399E+006$

Shear Force, $V_a = -4685.405$
EDGE -B-
Bending Moment, $M_b = 6.9545E+006$
Shear Force, $V_b = 10227.447$
BOTH EDGES
Axial Force, $F = -613.7698$
Longitudinal Reinforcement Area Distribution (in 2 divisions)
-Tension: $A_{st} = 911.0619$
-Compression: $A_{sc} = 1231.504$
Longitudinal Reinforcement Area Distribution (in 3 divisions)
-Tension: $A_{st,ten} = 603.1858$
-Compression: $A_{sc,com} = 923.6282$
-Middle: $A_{st,mid} = 615.7522$
Mean Diameter of Tension Reinforcement, $Db_{L,ten} = 16.00$

New component: From table 7-7, ASCE 41_17: Final Shear Capacity $V_R = 1.0 \cdot V_n = 247746.65$
 V_n ((22.5.1.1), ACI 318-14) = 247746.65

NOTE: In expression (22.5.1.1) ' V_w ' is replaced by ' $V_w + f \cdot V_f$ '
where V_f is the contribution of FRPs (11.3), ACI 440).

From Table (22.5.5.1), ACI 318-14: $V_c = 80195.042$
= 1 (normal-weight concrete)
 $f_c' = 25.00$, but $f_c'^{0.5} \leq 8.3$ MPa (22.5.3.1, ACI 318-14)
 $\rho_w = A_s / (b_w \cdot d) = 0.00949023$
 A_s (tension reinf.) = 911.0619
 $b_w = 300.00$
 $d = 320.00$
 $V_u \cdot d / M_u < 1 = 0.21920395$
 $M_u = 6.8399E+006$
 $V_u = 4685.405$
From (11.5.4.8), ACI 318-14: $V_s = 167551.608$
 $A_v = 157079.633$
 $f_y = 500.00$
 $s = 150.00$
 V_s has been multiplied by 1 ($s < d/2$, according to ASCE 41-17,10.3.4)
 V_f ((11-3)-(11.4), ACI 440) = 0.00
From (11-11), ACI 440: $V_s + V_f \leq 318865.838$

End Of Calculation of Shear Capacity for element: beam B1 of floor 1
At local axis: 3
Integration Section: (a)

Calculation No. 4

beam B1, Floor 1



Limit State: Operational Level (data interpolation between analysis steps 1 and 2)

Analysis: Uniform +X

Check: Chord rotation capacity (ϕ)

Edge: Start

Local Axis: (3)



Start Of Calculation of Shear Capacity ratio for element: beam B1 of floor 1

At Shear local axis: 3

(Bending local axis: 2)

Section Type: rcars

Constant Properties

Knowledge Factor, $\gamma = 1.00$

Mean strength values are used for both shear and moment calculations.

Consequently:

New material of Secondary Member: Concrete Strength, $f_c = f_{cm} = 33.00$

New material of Secondary Member: Steel Strength, $f_s = f_{sm} = 555.56$

Concrete Elasticity, $E_c = 26999.444$

Steel Elasticity, $E_s = 200000.00$

#####

Note: Especially for the calculation of moment strengths,

the above steel re-bar strengths are multiplied by 1.25 according to R18.6.5, ACI 318-14

New material: Steel Strength, $f_s = 1.25 \cdot f_{sm} = 694.45$

#####

Section Height, $H = 400.00$

Section Width, $W = 300.00$

Cover Thickness, $c = 25.00$

Mean Confinement Factor overall section = 1.00

Element Length, $L = 1850.00$

Secondary Member

Smooth Bars

Ductile Steel

Without Detailing for Earthquake Resistance (including stirrups not closed at 135°)

Longitudinal Bars With Ends Lapped Starting at the End Sections

Inadequate Lap Length with $l_o/l_{ou,min} = 0.30$

No FRP Wrapping

Stepwise Properties

At local axis: 3

EDGE -A-

Shear Force, $V_a = 2771.021$

EDGE -B-

Shear Force, $V_b = 2771.021$
BOTH EDGES
Axial Force, $F = -190.8684$
Longitudinal Reinforcement Area Distribution (in 2 divisions)
-Tension: $As_t = 911.0619$
-Compression: $As_c = 1231.504$
Longitudinal Reinforcement Area Distribution (in 3 divisions)
-Tension: $As_{t,ten} = 603.1858$
-Compression: $As_{c,com} = 923.6282$
-Middle: $As_{c,mid} = 615.7522$

Calculation of Shear Capacity ratio, $V_e/V_r = 0.59550037$
Member Controlled by Flexure ($V_e/V_r < 1$)
Calculation of Shear Demand from fig. R18.6.5, ACI 318-14 $V_e = (M_{pr1} + M_{pr2})/l_n \pm w_u \cdot l_n/2 = 172632.267$
with
 $M_{pr1} = \text{Max}(Mu_{1+}, Mu_{1-}) = 1.5721E+008$
 $Mu_{1+} = 1.1233E+008$, is the ultimate moment strength at the edge 1 of the member in the actual moment direction
which is defined for the static loading combination
 $Mu_{1-} = 1.5721E+008$, is the ultimate moment strength at the edge 1 of the member in the opposite moment
direction which is defined for the static loading combination
 $M_{pr2} = \text{Max}(Mu_{2+}, Mu_{2-}) = 1.5703E+008$
 $Mu_{2+} = 1.1247E+008$, is the ultimate moment strength at the edge 2 of the member in the actual moment direction
which is defined for the the static loading combination
 $Mu_{2-} = 1.5703E+008$, is the ultimate moment strength at the edge 2 of the member in the opposite moment
direction which is defined for the the static loading combination
and
 $\pm w_u \cdot l_n = (|V_1| + |V_2|)/2$
with
 $V_1 = 2771.021$, is the shear force acting at edge 1 for the the static loading combination
 $V_2 = 2771.021$, is the shear force acting at edge 2 for the the static loading combination

Calculation of Mu_{1+}

Calculation of ultimate curvature ϕ_u according to 4.1, Biskinis/Fardis 2013:
 $\phi_u = 1.7687265E-005$
 $Mu = 1.1233E+008$

with full section properties:

$b = 300.00$
 $d = 357.00$
 $d' = 42.00$
 $v = 5.4004576E-005$
 $N = 190.8684$
 $f_c = 33.00$
 ϕ_c (5A.5, TBDY) = 0.002
Final value of ϕ_c : $\phi_c^* = \text{shear_factor} \cdot \text{Max}(\phi_c, \phi_{cc}) = 0.00553582$
The Shear_factor is considered equal to 1 (pure moment strength)
From (5.4b), TBDY: $\phi_c = 0.00553582$
 w_e (5.4c) = 0.00259035
 a_{se} ((5.4d), TBDY) = 0.15672608
 $b_o = 240.00$
 $h_o = 340.00$
 $bi_2 = 346400.00$
 $p_{sh,min} = \text{Min}(p_{sh,x}, p_{sh,y}) = 0.00261799$
Expression ((5.4d), TBDY) for $p_{sh,min}$ has been multiplied by 0.3 according to 15.7.1.3 for members without
earthquake detailing (90° closed stirrups)

 $p_{sh,x}$ (5.4d) = 0.00349066
 $A_{sh} = A_{stir} \cdot n_s = 78.53982$
No stirrups, $n_s = 2.00$
 $b_k = 300.00$

psh,y (5.4d) = 0.00261799
Ash = Astir*ns = 78.53982
No stirups, ns = 2.00
bk = 400.00

s = 150.00
fywe = 694.45
fce = 33.00

From ((5.A5), TBDY), TBDY: cc = 0.002
c = confinement factor = 1.00

y1 = 0.00140044
sh1 = 0.0044814
ft1 = 466.8167
fy1 = 389.0139
su1 = 0.00512

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00

lo/lou,min = lb/d = 0.30

su1 = 0.4*esu1_nominal ((5.5), TBDY) = 0.032

From table 5A.1, TBDY: esu1_nominal = 0.08,

For calculation of esu1_nominal and y1, sh1,ft1,fy1, it is considered
characteristic value fsy1 = fs1/1.2, from table 5.1, TBDY.

y1, sh1,ft1,fy1, are also multiplied by $\text{Min}(1, 1.25 \cdot (lb/d)^{2/3})$, from 10.3.5, ASCE 41-17.

with fs1 = fs = 389.0139

with Es1 = Es = 200000.00

y2 = 0.00140044
sh2 = 0.0044814
ft2 = 466.8167
fy2 = 389.0139
su2 = 0.00512

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00

lo/lou,min = lb/lb,min = 0.30

su2 = 0.4*esu2_nominal ((5.5), TBDY) = 0.032

From table 5A.1, TBDY: esu2_nominal = 0.08,

For calculation of esu2_nominal and y2, sh2,ft2,fy2, it is considered
characteristic value fsy2 = fs2/1.2, from table 5.1, TBDY.

y1, sh1,ft1,fy1, are also multiplied by $\text{Min}(1, 1.25 \cdot (lb/d)^{2/3})$, from 10.3.5, ASCE 41-17.

with fs2 = fs = 389.0139

with Es2 = Es = 200000.00

yv = 0.00140044
shv = 0.0044814
ftv = 466.8167
fyv = 389.0139
suv = 0.00512

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00

lo/lou,min = lb/d = 0.30

suv = 0.4*esuv_nominal ((5.5), TBDY) = 0.032

From table 5A.1, TBDY: esuv_nominal = 0.08,

considering characteristic value fsyv = fsv/1.2, from table 5.1, TBDY

For calculation of esuv_nominal and yv, shv,ftv,fyv, it is considered
characteristic value fsyv = fsv/1.2, from table 5.1, TBDY.

y1, sh1,ft1,fy1, are also multiplied by $\text{Min}(1, 1.25 \cdot (lb/d)^{2/3})$, from 10.3.5, ASCE 41-17.

with fsv = fs = 389.0139

with Esv = Es = 200000.00

1 = Asl,ten/(b*d)*(fs1/fc) = 0.06639156

2 = Asl,com/(b*d)*(fs2/fc) = 0.10166207

v = Asl,mid/(b*d)*(fsv/fc) = 0.06777471

and confined core properties:

b = 240.00
d = 327.00
d' = 12.00

$$fcc(5A.2, TBDY) = 33.00$$

$$cc(5A.5, TBDY) = 0.002$$

$$c = \text{confinement factor} = 1.00$$

$$1 = Asl,ten/(b*d)*(fs1/fc) = 0.09060316$$

$$2 = Asl,com/(b*d)*(fs2/fc) = 0.13873608$$

$$v = Asl,mid/(b*d)*(fsv/fc) = 0.09249072$$

Case/Assumption: Unconfined full section - Steel rupture

' satisfies Eq. (4.3)

--->

$v < v_{s,y2}$ - LHS eq.(4.5) is satisfied

--->

$$su(4.9) = 0.189149$$

$$Mu = MRc(4.14) = 1.1233E+008$$

$$u = su(4.1) = 1.7687265E-005$$

Calculation of ratio l_b/l_d

Inadequate Lap Length with $l_b/l_d = 0.30$

Calculation of Mu_1 -

Calculation of ultimate curvature u according to 4.1, Biskinis/Fardis 2013:

$$u = 1.8434312E-005$$

$$Mu = 1.5721E+008$$

with full section properties:

$$b = 300.00$$

$$d = 358.00$$

$$d' = 43.00$$

$$v = 5.3853726E-005$$

$$N = 190.8684$$

$$fc = 33.00$$

$$co(5A.5, TBDY) = 0.002$$

$$\text{Final value of } cu: cu^* = \text{shear_factor} * \text{Max}(cu, cc) = 0.00553582$$

The Shear_factor is considered equal to 1 (pure moment strength)

$$\text{From (5.4b), TBDY: } cu = 0.00553582$$

$$we(5.4c) = 0.00259035$$

$$ase((5.4d), TBDY) = 0.15672608$$

$$bo = 240.00$$

$$ho = 340.00$$

$$bi2 = 346400.00$$

$$psh,min = \text{Min}(psh,x, psh,y) = 0.00261799$$

Expression ((5.4d), TBDY) for psh,min has been multiplied by 0.3 according to 15.7.1.3 for members without earthquake detailing (90° closed stirrups)

 $psh,x(5.4d) = 0.00349066$

$$Ash = Astir*ns = 78.53982$$

$$\text{No stirrups, } ns = 2.00$$

$$bk = 300.00$$

 $psh,y(5.4d) = 0.00261799$

$$Ash = Astir*ns = 78.53982$$

$$\text{No stirrups, } ns = 2.00$$

$$bk = 400.00$$

 $s = 150.00$

$$fywe = 694.45$$

$$fce = 33.00$$

$$\text{From ((5.A5), TBDY), TBDY: } cc = 0.002$$

$$c = \text{confinement factor} = 1.00$$

$$y1 = 0.00140044$$

$$sh1 = 0.0044814$$

$$ft1 = 466.8167$$

$$fy1 = 389.0139$$

$$su1 = 0.00512$$

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00

$$lo/lou,min = lb/d = 0.30$$

$$su1 = 0.4*esu1_nominal ((5.5), TBDY) = 0.032$$

From table 5A.1, TBDY: esu1_nominal = 0.08,

For calculation of esu1_nominal and y1, sh1,ft1,fy1, it is considered
characteristic value fsy1 = fs1/1.2, from table 5.1, TBDY.

y1, sh1,ft1,fy1, are also multiplied by $\text{Min}(1, 1.25*(lb/d)^{2/3})$, from 10.3.5, ASCE 41-17.

$$\text{with } fs1 = fs = 389.0139$$

$$\text{with } Es1 = Es = 200000.00$$

$$y2 = 0.00140044$$

$$sh2 = 0.0044814$$

$$ft2 = 466.8167$$

$$fy2 = 389.0139$$

$$su2 = 0.00512$$

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00

$$lo/lou,min = lb/lb,min = 0.30$$

$$su2 = 0.4*esu2_nominal ((5.5), TBDY) = 0.032$$

From table 5A.1, TBDY: esu2_nominal = 0.08,

For calculation of esu2_nominal and y2, sh2,ft2,fy2, it is considered
characteristic value fsy2 = fs2/1.2, from table 5.1, TBDY.

y1, sh1,ft1,fy1, are also multiplied by $\text{Min}(1, 1.25*(lb/d)^{2/3})$, from 10.3.5, ASCE 41-17.

$$\text{with } fs2 = fs = 389.0139$$

$$\text{with } Es2 = Es = 200000.00$$

$$yv = 0.00140044$$

$$shv = 0.0044814$$

$$ftv = 466.8167$$

$$fyv = 389.0139$$

$$suv = 0.00512$$

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00

$$lo/lou,min = lb/d = 0.30$$

$$suv = 0.4*esuv_nominal ((5.5), TBDY) = 0.032$$

From table 5A.1, TBDY: esuv_nominal = 0.08,

considering characteristic value fsyv = fsv/1.2, from table 5.1, TBDY

For calculation of esuv_nominal and yv, shv,ftv,fyv, it is considered
characteristic value fsyv = fsv/1.2, from table 5.1, TBDY.

y1, sh1,ft1,fy1, are also multiplied by $\text{Min}(1, 1.25*(lb/d)^{2/3})$, from 10.3.5, ASCE 41-17.

$$\text{with } fsv = fs = 389.0139$$

$$\text{with } Esv = Es = 200000.00$$

$$1 = Asl,ten/(b*d)*(fs1/fc) = 0.1013781$$

$$2 = Asl,com/(b*d)*(fs2/fc) = 0.06620611$$

$$v = Asl,mid/(b*d)*(fsv/fc) = 0.0675854$$

and confined core properties:

$$b = 240.00$$

$$d = 328.00$$

$$d' = 13.00$$

$$fcc (5A.2, TBDY) = 33.00$$

$$cc (5A.5, TBDY) = 0.002$$

$$c = \text{confinement factor} = 1.00$$

$$1 = Asl,ten/(b*d)*(fs1/fc) = 0.13831311$$

$$2 = Asl,com/(b*d)*(fs2/fc) = 0.09032693$$

$$v = Asl,mid/(b*d)*(fsv/fc) = 0.09220874$$

Case/Assumption: Unconfined full section - Steel rupture

' satisfies Eq. (4.3)

--->

v < vs,y2 - LHS eq.(4.5) is satisfied

--->

$$su (4.9) = 0.22418173$$

$$Mu = MRc (4.14) = 1.5721E+008$$

$$u = su(4.1) = 1.8434312E-005$$

Calculation of ratio l_b/d

Inadequate Lap Length with $l_b/d = 0.30$

Calculation of μ_{2+}

Calculation of ultimate curvature μ according to 4.1, Biskinis/Fardis 2013:

$$u = 1.7651391E-005$$

$$\mu = 1.1247E+008$$

with full section properties:

$$b = 300.00$$

$$d = 358.00$$

$$d' = 43.00$$

$$v = 5.3853726E-005$$

$$N = 190.8684$$

$$f_c = 33.00$$

$$c_o(5A.5, \text{TB DY}) = 0.002$$

$$\text{Final value of } \mu: \mu^* = \text{shear_factor} * \text{Max}(\mu, c_c) = 0.00553582$$

The Shear_factor is considered equal to 1 (pure moment strength)

$$\text{From (5.4b), TB DY: } \mu = 0.00553582$$

$$w_e(5.4c) = 0.00259035$$

$$a_{se}((5.4d), \text{TB DY}) = 0.15672608$$

$$b_o = 240.00$$

$$h_o = 340.00$$

$$b_{i2} = 346400.00$$

$$p_{sh,min} = \text{Min}(p_{sh,x}, p_{sh,y}) = 0.00261799$$

Expression ((5.4d), TB DY) for $p_{sh,min}$ has been multiplied by 0.3 according to 15.7.1.3 for members without earthquake detailing (90° closed stirrups)

$$p_{sh,x}(5.4d) = 0.00349066$$

$$A_{sh} = A_{stir} * n_s = 78.53982$$

$$\text{No stirrups, } n_s = 2.00$$

$$b_k = 300.00$$

$$p_{sh,y}(5.4d) = 0.00261799$$

$$A_{sh} = A_{stir} * n_s = 78.53982$$

$$\text{No stirrups, } n_s = 2.00$$

$$b_k = 400.00$$

$$s = 150.00$$

$$f_{ywe} = 694.45$$

$$f_{ce} = 33.00$$

$$\text{From ((5.A5), TB DY), TB DY: } c_c = 0.002$$

$$c = \text{confinement factor} = 1.00$$

$$y_1 = 0.00140044$$

$$sh_1 = 0.0044814$$

$$ft_1 = 466.8167$$

$$fy_1 = 389.0139$$

$$su_1 = 0.00512$$

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor and also multiplied by the shear_factor according to 15.7.1.4, with Shear_factor = 1.00

$$l_o/l_{o,min} = l_b/d = 0.30$$

$$su_1 = 0.4 * esu_1_{nominal}((5.5), \text{TB DY}) = 0.032$$

$$\text{From table 5A.1, TB DY: } esu_1_{nominal} = 0.08,$$

For calculation of $esu_1_{nominal}$ and y_1, sh_1, ft_1, fy_1 , it is considered characteristic value $fsy_1 = fs_1/1.2$, from table 5.1, TB DY.

y_1, sh_1, ft_1, fy_1 , are also multiplied by $\text{Min}(1, 1.25 * (l_b/d)^{2/3})$, from 10.3.5, ASCE 41-17.

$$\text{with } fs_1 = fs = 389.0139$$

with $E_{s1} = E_s = 200000.00$
 $y_2 = 0.00140044$
 $sh_2 = 0.0044814$
 $ft_2 = 466.8167$
 $fy_2 = 389.0139$
 $su_2 = 0.00512$
 using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
 and also multiplied by the shear_factor according to 15.7.1.4, with
 Shear_factor = 1.00
 $l_o/l_{o,min} = l_b/l_{b,min} = 0.30$
 $su_2 = 0.4 * esu_{2,nominal} ((5.5), TBDY) = 0.032$
 From table 5A.1, TBDY: $esu_{2,nominal} = 0.08$,
 For calculation of $esu_{2,nominal}$ and y_2, sh_2, ft_2, fy_2 , it is considered
 characteristic value $fsy_2 = fs_2/1.2$, from table 5.1, TBDY.
 y_1, sh_1, ft_1, fy_1 , are also multiplied by $Min(1, 1.25 * (l_b/l_d)^{2/3})$, from 10.3.5, ASCE 41-17.
 with $fs_2 = fs = 389.0139$
 with $E_{s2} = E_s = 200000.00$
 $y_v = 0.00140044$
 $sh_v = 0.0044814$
 $ft_v = 466.8167$
 $fy_v = 389.0139$
 $suv = 0.00512$
 using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
 and also multiplied by the shear_factor according to 15.7.1.4, with
 Shear_factor = 1.00
 $l_o/l_{o,min} = l_b/l_d = 0.30$
 $suv = 0.4 * esuv_{nominal} ((5.5), TBDY) = 0.032$
 From table 5A.1, TBDY: $esuv_{nominal} = 0.08$,
 considering characteristic value $fsyv = fsv/1.2$, from table 5.1, TBDY
 For calculation of $esuv_{nominal}$ and y_v, sh_v, ft_v, fy_v , it is considered
 characteristic value $fsyv = fsv/1.2$, from table 5.1, TBDY.
 y_1, sh_1, ft_1, fy_1 , are also multiplied by $Min(1, 1.25 * (l_b/l_d)^{2/3})$, from 10.3.5, ASCE 41-17.
 with $fsv = fs = 389.0139$
 with $E_{sv} = E_s = 200000.00$
 $1 = A_{sl,ten}/(b*d) * (fs_1/f_c) = 0.06620611$
 $2 = A_{sl,com}/(b*d) * (fs_2/f_c) = 0.1013781$
 $v = A_{sl,mid}/(b*d) * (fsv/f_c) = 0.0675854$
 and confined core properties:
 $b = 240.00$
 $d = 328.00$
 $d' = 13.00$
 $f_{cc} (5A.2, TBDY) = 33.00$
 $cc (5A.5, TBDY) = 0.002$
 $c = \text{confinement factor} = 1.00$
 $1 = A_{sl,ten}/(b*d) * (fs_1/f_c) = 0.09032693$
 $2 = A_{sl,com}/(b*d) * (fs_2/f_c) = 0.13831311$
 $v = A_{sl,mid}/(b*d) * (fsv/f_c) = 0.09220874$
 Case/Assumption: Unconfined full section - Steel rupture
 ' satisfies Eq. (4.3)
 --->
 $v < v_s, y_2$ - LHS eq.(4.5) is satisfied
 --->
 $su (4.9) = 0.18977061$
 $Mu = MRc (4.14) = 1.1247E+008$
 $u = su (4.1) = 1.7651391E-005$

 Calculation of ratio l_b/l_d

Inadequate Lap Length with $l_b/l_d = 0.30$

Calculation of Mu_2 -

Calculation of ultimate curvature ϕ_u according to 4.1, Biskinis/Fardis 2013:

$$u = 1.8476637E-005$$

$$Mu = 1.5703E+008$$

with full section properties:

$$b = 300.00$$

$$d = 357.00$$

$$d' = 42.00$$

$$v = 5.4004576E-005$$

$$N = 190.8684$$

$$f_c = 33.00$$

$$c_o(5A.5, TBDY) = 0.002$$

$$\text{Final value of } \phi_u: \phi_u^* = \text{shear_factor} * \text{Max}(\phi_u, \phi_c) = 0.00553582$$

The Shear_factor is considered equal to 1 (pure moment strength)

$$\text{From (5.4b), TBDY: } \phi_u = 0.00553582$$

$$w_e(5.4c) = 0.00259035$$

$$a_{se}((5.4d), TBDY) = 0.15672608$$

$$b_o = 240.00$$

$$h_o = 340.00$$

$$b_{i2} = 346400.00$$

$$p_{sh,min} = \text{Min}(p_{sh,x}, p_{sh,y}) = 0.00261799$$

Expression ((5.4d), TBDY) for $p_{sh,min}$ has been multiplied by 0.3 according to 15.7.1.3 for members without earthquake detailing (90° closed stirrups)

$$p_{sh,x}(5.4d) = 0.00349066$$

$$A_{sh} = A_{stir} * n_s = 78.53982$$

$$\text{No stirrups, } n_s = 2.00$$

$$b_k = 300.00$$

$$p_{sh,y}(5.4d) = 0.00261799$$

$$A_{sh} = A_{stir} * n_s = 78.53982$$

$$\text{No stirrups, } n_s = 2.00$$

$$b_k = 400.00$$

$$s = 150.00$$

$$f_{ywe} = 694.45$$

$$f_{ce} = 33.00$$

$$\text{From ((5.A5), TBDY), TBDY: } \phi_c = 0.002$$

$$c = \text{confinement factor} = 1.00$$

$$y_1 = 0.00140044$$

$$sh_1 = 0.0044814$$

$$f_{t1} = 466.8167$$

$$f_{y1} = 389.0139$$

$$su_1 = 0.00512$$

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor and also multiplied by the shear_factor according to 15.7.1.4, with Shear_factor = 1.00

$$l_o/l_{o,min} = l_b/l_d = 0.30$$

$$su_1 = 0.4 * esu_{1,nominal}((5.5), TBDY) = 0.032$$

$$\text{From table 5A.1, TBDY: } esu_{1,nominal} = 0.08,$$

For calculation of $esu_{1,nominal}$ and $y_1, sh_1, f_{t1}, f_{y1}$, it is considered characteristic value $f_{s1} = f_s/1.2$, from table 5.1, TBDY.

$y_1, sh_1, f_{t1}, f_{y1}$, are also multiplied by $\text{Min}(1, 1.25 * (l_b/l_d)^{2/3})$, from 10.3.5, ASCE 41-17.

$$\text{with } f_{s1} = f_s = 389.0139$$

$$\text{with } E_{s1} = E_s = 200000.00$$

$$y_2 = 0.00140044$$

$$sh_2 = 0.0044814$$

$$f_{t2} = 466.8167$$

$$f_{y2} = 389.0139$$

$$su_2 = 0.00512$$

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor and also multiplied by the shear_factor according to 15.7.1.4, with Shear_factor = 1.00

$$l_o/l_{o,min} = l_b/l_{b,min} = 0.30$$

$$su_2 = 0.4 * esu_{2,nominal}((5.5), TBDY) = 0.032$$

$$\text{From table 5A.1, TBDY: } esu_{2,nominal} = 0.08,$$

For calculation of $esu_{2,nominal}$ and $y_2, sh_2, f_{t2}, f_{y2}$, it is considered

characteristic value $f_{sy2} = f_{s2}/1.2$, from table 5.1, TBDY.

y_1, sh_1, ft_1, f_{y1} , are also multiplied by $\text{Min}(1, 1.25 \cdot (l_b/l_d)^{2/3})$, from 10.3.5, ASCE 41-17.

with $f_{s2} = f_s = 389.0139$

with $E_{s2} = E_s = 200000.00$

$y_v = 0.00140044$

$sh_v = 0.0044814$

$ft_v = 466.8167$

$f_{yv} = 389.0139$

$s_{uv} = 0.00512$

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor

and also multiplied by the shear_factor according to 15.7.1.4, with

Shear_factor = 1.00

$l_o/l_{ou,min} = l_b/l_d = 0.30$

$s_{uv} = 0.4 \cdot e_{suv,nominal} ((5.5), TBDY) = 0.032$

From table 5A.1, TBDY: $e_{suv,nominal} = 0.08$,

considering characteristic value $f_{syv} = f_{sv}/1.2$, from table 5.1, TBDY

For calculation of $e_{suv,nominal}$ and y_v, sh_v, ft_v, f_{yv} , it is considered

characteristic value $f_{syv} = f_{sv}/1.2$, from table 5.1, TBDY.

y_1, sh_1, ft_1, f_{y1} , are also multiplied by $\text{Min}(1, 1.25 \cdot (l_b/l_d)^{2/3})$, from 10.3.5, ASCE 41-17.

with $f_{sv} = f_s = 389.0139$

with $E_{sv} = E_s = 200000.00$

1 = $As_{l,ten}/(b \cdot d) \cdot (f_{s1}/f_c) = 0.10166207$

2 = $As_{l,com}/(b \cdot d) \cdot (f_{s2}/f_c) = 0.06639156$

v = $As_{l,mid}/(b \cdot d) \cdot (f_{sv}/f_c) = 0.06777471$

and confined core properties:

b = 240.00

d = 327.00

d' = 12.00

f_{cc} (5A.2, TBDY) = 33.00

cc (5A.5, TBDY) = 0.002

c = confinement factor = 1.00

1 = $As_{l,ten}/(b \cdot d) \cdot (f_{s1}/f_c) = 0.13873608$

2 = $As_{l,com}/(b \cdot d) \cdot (f_{s2}/f_c) = 0.09060316$

v = $As_{l,mid}/(b \cdot d) \cdot (f_{sv}/f_c) = 0.09249072$

Case/Assumption: Unconfined full section - Steel rupture

' satisfies Eq. (4.3)

--->

v < v_{s,y2} - LHS eq.(4.5) is satisfied

--->

su (4.9) = 0.22379076

Mu = MRc (4.14) = 1.5703E+008

u = su (4.1) = 1.8476637E-005

Calculation of ratio l_b/l_d

Inadequate Lap Length with $l_b/l_d = 0.30$

Calculation of Shear Strength $V_r = \text{Min}(V_{r1}, V_{r2}) = 289894.477$

Calculation of Shear Strength at edge 1, $V_{r1} = 289894.477$

$V_{r1} = V_n ((22.5.1.1), ACI 318-14)$

NOTE: In expression (22.5.1.1) 'V_w' is replaced by 'V_w+ f*V_f'
where V_f is the contribution of FRPs (11.3), ACI 440).

From Table (22.5.5.1), ACI 318-14: $V_c = 103724.534$

= 1 (normal-weight concrete)

$f'_c = 33.00$, but $f_c^{0.5} \leq 8.3$ MPa (22.5.3.1, ACI 318-14)

$p_w = A_s/(b_w \cdot d) = 0.00949023$

A_s (tension reinf.) = 911.0619

$b_w = 300.00$

d = 320.00

$V_u \cdot d / \mu < 1 = 1.00$

Mu = 71267.116

Vu = 2771.021

From (11.5.4.8), ACI 318-14: Vs = 186169.943

Av = 157079.633

fy = 555.56

s = 150.00

Vs has been multiplied by 1 ($s < d/2$, according to ASCE 41-17,10.3.4)

Vf ((11-3)-(11.4), ACI 440) = 0.00

From (11-11), ACI 440: Vs + Vf <= 366348.956

Calculation of Shear Strength at edge 2, Vr2 = 289894.477

Vr2 = Vn ((22.5.1.1), ACI 318-14)

NOTE: In expression (22.5.1.1) 'Vw' is replaced by 'Vw+ f*Vf'

where Vf is the contribution of FRPs (11.3), ACI 440).

From Table (22.5.5.1), ACI 318-14: Vc = 103724.534

= 1 (normal-weight concrete)

fc' = 33.00, but $fc'^{0.5} <= 8.3$ MPa (22.5.3.1, ACI 318-14)

pw = As/(bw*d) = 0.00949023

As (tension reinf.) = 911.0619

bw = 300.00

d = 320.00

Vu*d/Mu < 1 = 1.00

Mu = 71267.116

Vu = 2771.021

From (11.5.4.8), ACI 318-14: Vs = 186169.943

Av = 157079.633

fy = 555.56

s = 150.00

Vs has been multiplied by 1 ($s < d/2$, according to ASCE 41-17,10.3.4)

Vf ((11-3)-(11.4), ACI 440) = 0.00

From (11-11), ACI 440: Vs + Vf <= 366348.956

End Of Calculation of Shear Capacity ratio for element: beam B1 of floor 1

At local axis: 3

Start Of Calculation of Shear Capacity ratio for element: beam B1 of floor 1

At Shear local axis: 2

(Bending local axis: 3)

Section Type: rcars

Constant Properties

Knowledge Factor, = 1.00

Mean strength values are used for both shear and moment calculations.

Consequently:

New material of Secondary Member: Concrete Strength, fc = fcm = 33.00

New material of Secondary Member: Steel Strength, fs = fsm = 555.56

Concrete Elasticity, Ec = 26999.444

Steel Elasticity, Es = 200000.00

#####

Note: Especially for the calculation of moment strengths,

the above steel re-bar strengths are multiplied by 1.25 according to R18.6.5, ACI 318-14

New material: Steel Strength, fs = 1.25*fsm = 694.45

#####

Section Height, H = 400.00

Section Width, W = 300.00

Cover Thickness, c = 25.00

Mean Confinement Factor overall section = 1.00

Element Length, L = 1850.00

Secondary Member

Smooth Bars

Ductile Steel

Without Detailing for Earthquake Resistance (including stirrups not closed at 135°)
Longitudinal Bars With Ends Lapped Starting at the End Sections
Inadequate Lap Length with $l_o/l_{ou,min} = 0.30$
No FRP Wrapping

Stepwise Properties

At local axis: 2
EDGE -A-
Shear Force, $V_a = 4.9160836E-020$
EDGE -B-
Shear Force, $V_b = -4.9160836E-020$
BOTH EDGES
Axial Force, $F = -190.8684$
Longitudinal Reinforcement Area Distribution (in 2 divisions)
-Tension: $A_{st} = 911.0619$
-Compression: $A_{sc} = 1231.504$
Longitudinal Reinforcement Area Distribution (in 3 divisions)
-Tension: $A_{st,ten} = 816.8141$
-Compression: $A_{sc,com} = 816.8141$
-Middle: $A_{sc,mid} = 508.938$

Calculation of Shear Capacity ratio , $V_e/V_r = 0.54312483$
Member Controlled by Flexure ($V_e/V_r < 1$)
Calculation of Shear Demand from fig. R18.6.5, ACI 318-14 $V_e = (M_{pr1} + M_{pr2})/l_n \pm w_u \cdot l_n/2 = 104799.778$
with
 $M_{pr1} = \text{Max}(M_{u1+} , M_{u1-}) = 9.6940E+007$
 $M_{u1+} = 9.6940E+007$, is the ultimate moment strength at the edge 1 of the member in the actual moment direction
which is defined for the static loading combination
 $M_{u1-} = 9.6940E+007$, is the ultimate moment strength at the edge 1 of the member in the opposite moment
direction which is defined for the static loading combination
 $M_{pr2} = \text{Max}(M_{u2+} , M_{u2-}) = 9.6940E+007$
 $M_{u2+} = 9.6940E+007$, is the ultimate moment strength at the edge 2 of the member in the actual moment direction
which is defined for the the static loading combination
 $M_{u2-} = 9.6940E+007$, is the ultimate moment strength at the edge 2 of the member in the opposite moment
direction which is defined for the the static loading combination
and
 $\pm w_u \cdot l_n = (|V_1| + |V_2|)/2$
with
 $V_1 = 4.9160836E-020$, is the shear force acting at edge 1 for the the static loading combination
 $V_2 = -4.9160836E-020$, is the shear force acting at edge 2 for the the static loading combination

Calculation of M_{u1+}

Calculation of ultimate curvature ϕ_u according to 4.1, Biskinis/Fardis 2013:
 $\phi_u = 2.5454950E-005$
 $M_u = 9.6940E+007$

with full section properties:

$b = 400.00$
 $d = 258.00$
 $d' = 42.00$
 $v = 5.6045447E-005$
 $N = 190.8684$
 $f_c = 33.00$
 ϕ_o (5A.5, TBDY) = 0.002
Final value of ϕ_u : $\phi_u^* = \text{shear_factor} * \text{Max}(\phi_u, \phi_o) = 0.00553582$
The Shear_factor is considered equal to 1 (pure moment strength)
From (5.4b), TBDY: $\phi_u = 0.00553582$
 ϕ_{we} (5.4c) = 0.00259035

ase ((5.4d), TBDY) = 0.15672608

bo = 240.00

ho = 340.00

bi2 = 346400.00

psh,min = Min(psh,x , psh,y) = 0.00261799

Expression ((5.4d), TBDY) for psh,min has been multiplied by 0.3 according to 15.7.1.3 for members without earthquake detailing (90° closed stirrups)

psh,x (5.4d) = 0.00349066

Ash = Astir*ns = 78.53982

No stirrups, ns = 2.00

bk = 300.00

psh,y (5.4d) = 0.00261799

Ash = Astir*ns = 78.53982

No stirrups, ns = 2.00

bk = 400.00

s = 150.00

fywe = 694.45

fce = 33.00

From ((5.A5), TBDY), TBDY: cc = 0.002

c = confinement factor = 1.00

y1 = 0.00140044

sh1 = 0.0044814

ft1 = 466.8167

fy1 = 389.0139

su1 = 0.00512

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor and also multiplied by the shear_factor according to 15.7.1.4, with Shear_factor = 1.00

lo/lou,min = lb/d = 0.30

su1 = 0.4*esu1_nominal ((5.5), TBDY) = 0.032

From table 5A.1, TBDY: esu1_nominal = 0.08,

For calculation of esu1_nominal and y1, sh1,ft1,fy1, it is considered characteristic value fsy1 = fs1/1.2, from table 5.1, TBDY.

y1, sh1,ft1,fy1, are also multiplied by Min(1,1.25*(lb/d)^2/3), from 10.3.5, ASCE 41-17.

with fs1 = fs = 389.0139

with Es1 = Es = 200000.00

y2 = 0.00140044

sh2 = 0.0044814

ft2 = 466.8167

fy2 = 389.0139

su2 = 0.00512

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor and also multiplied by the shear_factor according to 15.7.1.4, with Shear_factor = 1.00

lo/lou,min = lb/lb,min = 0.30

su2 = 0.4*esu2_nominal ((5.5), TBDY) = 0.032

From table 5A.1, TBDY: esu2_nominal = 0.08,

For calculation of esu2_nominal and y2, sh2,ft2,fy2, it is considered characteristic value fsy2 = fs2/1.2, from table 5.1, TBDY.

y1, sh1,ft1,fy1, are also multiplied by Min(1,1.25*(lb/d)^2/3), from 10.3.5, ASCE 41-17.

with fs2 = fs = 389.0139

with Es2 = Es = 200000.00

yv = 0.00140044

shv = 0.0044814

ftv = 466.8167

fyv = 389.0139

suv = 0.00512

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor and also multiplied by the shear_factor according to 15.7.1.4, with Shear_factor = 1.00

lo/lou,min = lb/d = 0.30

suv = 0.4*esuv_nominal ((5.5), TBDY) = 0.032

From table 5A.1, TBDY: esuv_nominal = 0.08,

considering characteristic value fsyv = fsv/1.2, from table 5.1, TBDY

For calculation of $e_{sv_nominal}$ and γ_v , sh_v , ft_v , fy_v , it is considered characteristic value $f_{sv} = f_{sv}/1.2$, from table 5.1, TBDY.

γ_1 , sh_1 , ft_1 , fy_1 , are also multiplied by $\text{Min}(1, 1.25 \cdot (l_b/l_d)^{2/3})$, from 10.3.5, ASCE 41-17.

with $f_{sv} = f_s = 389.0139$

with $E_{sv} = E_s = 200000.00$

1 = $Asl_{ten}/(b \cdot d) \cdot (f_{s1}/f_c) = 0.09330282$

2 = $Asl_{com}/(b \cdot d) \cdot (f_{s2}/f_c) = 0.09330282$

$v = Asl_{mid}/(b \cdot d) \cdot (f_{sv}/f_c) = 0.05813483$

and confined core properties:

$b = 340.00$

$d = 228.00$

$d' = 12.00$

f_{cc} (5A.2, TBDY) = 33.00

cc (5A.5, TBDY) = 0.002

c = confinement factor = 1.00

1 = $Asl_{ten}/(b \cdot d) \cdot (f_{s1}/f_c) = 0.12421118$

2 = $Asl_{com}/(b \cdot d) \cdot (f_{s2}/f_c) = 0.12421118$

$v = Asl_{mid}/(b \cdot d) \cdot (f_{sv}/f_c) = 0.07739312$

Case/Assumption: Unconfined full section - Steel rupture

' satisfies Eq. (4.3)

--->

$v < v_{s,y2}$ - LHS eq.(4.5) is satisfied

--->

su (4.9) = 0.22038892

$Mu = MRc$ (4.14) = 9.6940E+007

$u = su$ (4.1) = 2.5454950E-005

Calculation of ratio l_b/l_d

Inadequate Lap Length with $l_b/l_d = 0.30$

Calculation of Mu_1 -

Calculation of ultimate curvature u according to 4.1, Biskinis/Fardis 2013:

$u = 2.5454950E-005$

$Mu = 9.6940E+007$

with full section properties:

$b = 400.00$

$d = 258.00$

$d' = 42.00$

$v = 5.6045447E-005$

$N = 190.8684$

$f_c = 33.00$

co (5A.5, TBDY) = 0.002

Final value of cu : $cu^* = \text{shear_factor} \cdot \text{Max}(cu, cc) = 0.00553582$

The Shear_factor is considered equal to 1 (pure moment strength)

From (5.4b), TBDY: $cu = 0.00553582$

w_e (5.4c) = 0.00259035

ase ((5.4d), TBDY) = 0.15672608

$bo = 240.00$

$ho = 340.00$

$bi_2 = 346400.00$

$psh_{min} = \text{Min}(psh_x, psh_y) = 0.00261799$

Expression ((5.4d), TBDY) for psh_{min} has been multiplied by 0.3 according to 15.7.1.3 for members without earthquake detailing (90° closed stirrups)

 psh_x (5.4d) = 0.00349066

$A_{stir} = A_{stir} \cdot n_s = 78.53982$

No stirrups, $n_s = 2.00$

$bk = 300.00$

psh,y (5.4d) = 0.00261799
Ash = Astir*ns = 78.53982
No stirups, ns = 2.00
bk = 400.00

s = 150.00
fywe = 694.45
fce = 33.00
From ((5.A.5), TBDY), TBDY: cc = 0.002
c = confinement factor = 1.00

y1 = 0.00140044
sh1 = 0.0044814
ft1 = 466.8167
fy1 = 389.0139
su1 = 0.00512

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00

lo/lou,min = lb/d = 0.30

su1 = 0.4*esu1_nominal ((5.5), TBDY) = 0.032

From table 5A.1, TBDY: esu1_nominal = 0.08,

For calculation of esu1_nominal and y1, sh1,ft1,fy1, it is considered
characteristic value fsy1 = fs1/1.2, from table 5.1, TBDY.

y1, sh1,ft1,fy1, are also multiplied by $\text{Min}(1, 1.25 \cdot (lb/d)^{2/3})$, from 10.3.5, ASCE 41-17.

with fs1 = fs = 389.0139

with Es1 = Es = 200000.00

y2 = 0.00140044
sh2 = 0.0044814
ft2 = 466.8167
fy2 = 389.0139
su2 = 0.00512

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00

lo/lou,min = lb/lb,min = 0.30

su2 = 0.4*esu2_nominal ((5.5), TBDY) = 0.032

From table 5A.1, TBDY: esu2_nominal = 0.08,

For calculation of esu2_nominal and y2, sh2,ft2,fy2, it is considered
characteristic value fsy2 = fs2/1.2, from table 5.1, TBDY.

y1, sh1,ft1,fy1, are also multiplied by $\text{Min}(1, 1.25 \cdot (lb/d)^{2/3})$, from 10.3.5, ASCE 41-17.

with fs2 = fs = 389.0139

with Es2 = Es = 200000.00

yv = 0.00140044
shv = 0.0044814
ftv = 466.8167
fyv = 389.0139
suv = 0.00512

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00

lo/lou,min = lb/d = 0.30

suv = 0.4*esuv_nominal ((5.5), TBDY) = 0.032

From table 5A.1, TBDY: esuv_nominal = 0.08,

considering characteristic value fsyv = fsv/1.2, from table 5.1, TBDY
For calculation of esuv_nominal and yv, shv,ftv,fyv, it is considered
characteristic value fsyv = fsv/1.2, from table 5.1, TBDY.

y1, sh1,ft1,fy1, are also multiplied by $\text{Min}(1, 1.25 \cdot (lb/d)^{2/3})$, from 10.3.5, ASCE 41-17.

with fsv = fs = 389.0139

with Esv = Es = 200000.00

1 = Asl,ten/(b*d)*(fs1/fc) = 0.09330282

2 = Asl,com/(b*d)*(fs2/fc) = 0.09330282

v = Asl,mid/(b*d)*(fsv/fc) = 0.05813483

and confined core properties:

b = 340.00
d = 228.00
d' = 12.00
fcc (5A.2, TBDY) = 33.00

$$cc \text{ (5A.5, TBDY)} = 0.002$$

$$c = \text{confinement factor} = 1.00$$

$$1 = Asl,ten/(b*d)*(fs1/fc) = 0.12421118$$

$$2 = Asl,com/(b*d)*(fs2/fc) = 0.12421118$$

$$v = Asl,mid/(b*d)*(fsv/fc) = 0.07739312$$

Case/Assumption: Unconfined full section - Steel rupture
' satisfies Eq. (4.3)

---->

$v < v_{s,y2}$ - LHS eq.(4.5) is satisfied

---->

$$su \text{ (4.9)} = 0.22038892$$

$$Mu = MRc \text{ (4.14)} = 9.6940E+007$$

$$u = su \text{ (4.1)} = 2.5454950E-005$$

Calculation of ratio l_b/l_d

Inadequate Lap Length with $l_b/l_d = 0.30$

Calculation of Mu_{2+}

Calculation of ultimate curvature u according to 4.1, Biskinis/Fardis 2013:

$$u = 2.5454950E-005$$

$$Mu = 9.6940E+007$$

with full section properties:

$$b = 400.00$$

$$d = 258.00$$

$$d' = 42.00$$

$$v = 5.6045447E-005$$

$$N = 190.8684$$

$$fc = 33.00$$

$$co \text{ (5A.5, TBDY)} = 0.002$$

$$\text{Final value of } cu: cu^* = \text{shear_factor} * \text{Max}(cu, cc) = 0.00553582$$

The Shear_factor is considered equal to 1 (pure moment strength)

$$\text{From (5.4b), TBDY: } cu = 0.00553582$$

$$w_e \text{ (5.4c)} = 0.00259035$$

$$ase \text{ ((5.4d), TBDY)} = 0.15672608$$

$$bo = 240.00$$

$$ho = 340.00$$

$$bi2 = 346400.00$$

$$psh,min = \text{Min}(psh,x, psh,y) = 0.00261799$$

Expression ((5.4d), TBDY) for psh,min has been multiplied by 0.3 according to 15.7.1.3 for members without earthquake detailing (90° closed stirrups)

$$psh,x \text{ (5.4d)} = 0.00349066$$

$$Ash = Astir*ns = 78.53982$$

$$\text{No stirrups, } ns = 2.00$$

$$bk = 300.00$$

$$psh,y \text{ (5.4d)} = 0.00261799$$

$$Ash = Astir*ns = 78.53982$$

$$\text{No stirrups, } ns = 2.00$$

$$bk = 400.00$$

$$s = 150.00$$

$$fywe = 694.45$$

$$fce = 33.00$$

$$\text{From ((5.A5), TBDY), TBDY: } cc = 0.002$$

$$c = \text{confinement factor} = 1.00$$

$$y1 = 0.00140044$$

$$sh1 = 0.0044814$$

$$ft1 = 466.8167$$

$f_{y1} = 389.0139$
 $s_{u1} = 0.00512$
 using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
 and also multiplied by the shear_factor according to 15.7.1.4, with
 Shear_factor = 1.00
 $l_o/l_{ou,min} = l_b/l_d = 0.30$
 $s_{u1} = 0.4 * e_{su1,nominal} ((5.5), TBDY) = 0.032$
 From table 5A.1, TBDY: $e_{su1,nominal} = 0.08$,
 For calculation of $e_{su1,nominal}$ and y_1, sh_1, ft_1, f_{y1} , it is considered
 characteristic value $f_{sy1} = f_{s1}/1.2$, from table 5.1, TBDY.
 y_1, sh_1, ft_1, f_{y1} , are also multiplied by $\text{Min}(1, 1.25 * (l_b/l_d)^{2/3})$, from 10.3.5, ASCE 41-17.
 with $f_{s1} = f_s = 389.0139$
 with $E_{s1} = E_s = 200000.00$
 $y_2 = 0.00140044$
 $sh_2 = 0.0044814$
 $ft_2 = 466.8167$
 $f_{y2} = 389.0139$
 $s_{u2} = 0.00512$
 using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
 and also multiplied by the shear_factor according to 15.7.1.4, with
 Shear_factor = 1.00
 $l_o/l_{ou,min} = l_b/l_{b,min} = 0.30$
 $s_{u2} = 0.4 * e_{su2,nominal} ((5.5), TBDY) = 0.032$
 From table 5A.1, TBDY: $e_{su2,nominal} = 0.08$,
 For calculation of $e_{su2,nominal}$ and y_2, sh_2, ft_2, f_{y2} , it is considered
 characteristic value $f_{sy2} = f_{s2}/1.2$, from table 5.1, TBDY.
 y_2, sh_2, ft_2, f_{y2} , are also multiplied by $\text{Min}(1, 1.25 * (l_b/l_d)^{2/3})$, from 10.3.5, ASCE 41-17.
 with $f_{s2} = f_s = 389.0139$
 with $E_{s2} = E_s = 200000.00$
 $y_v = 0.00140044$
 $sh_v = 0.0044814$
 $ft_v = 466.8167$
 $f_{yv} = 389.0139$
 $s_{uv} = 0.00512$
 using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
 and also multiplied by the shear_factor according to 15.7.1.4, with
 Shear_factor = 1.00
 $l_o/l_{ou,min} = l_b/l_d = 0.30$
 $s_{uv} = 0.4 * e_{suv,nominal} ((5.5), TBDY) = 0.032$
 From table 5A.1, TBDY: $e_{suv,nominal} = 0.08$,
 considering characteristic value $f_{sv} = f_{sv}/1.2$, from table 5.1, TBDY
 For calculation of $e_{suv,nominal}$ and y_v, sh_v, ft_v, f_{yv} , it is considered
 characteristic value $f_{sv} = f_{sv}/1.2$, from table 5.1, TBDY.
 y_1, sh_1, ft_1, f_{y1} , are also multiplied by $\text{Min}(1, 1.25 * (l_b/l_d)^{2/3})$, from 10.3.5, ASCE 41-17.
 with $f_{sv} = f_s = 389.0139$
 with $E_{sv} = E_s = 200000.00$
 $1 = A_{sl,ten}/(b*d)*(f_{s1}/f_c) = 0.09330282$
 $2 = A_{sl,com}/(b*d)*(f_{s2}/f_c) = 0.09330282$
 $v = A_{sl,mid}/(b*d)*(f_{sv}/f_c) = 0.05813483$
 and confined core properties:
 $b = 340.00$
 $d = 228.00$
 $d' = 12.00$
 $f_{cc} (5A.2, TBDY) = 33.00$
 $cc (5A.5, TBDY) = 0.002$
 $c = \text{confinement factor} = 1.00$
 $1 = A_{sl,ten}/(b*d)*(f_{s1}/f_c) = 0.12421118$
 $2 = A_{sl,com}/(b*d)*(f_{s2}/f_c) = 0.12421118$
 $v = A_{sl,mid}/(b*d)*(f_{sv}/f_c) = 0.07739312$
 Case/Assumption: Unconfined full section - Steel rupture
 ' satisfies Eq. (4.3)
 --->
 $v < v_{s,y2}$ - LHS eq.(4.5) is satisfied
 --->
 $s_u (4.9) = 0.22038892$
 $M_u = M_{Rc} (4.14) = 9.6940E+007$
 $u = s_u (4.1) = 2.5454950E-005$

Calculation of ratio l_b/d

Inadequate Lap Length with $l_b/d = 0.30$

Calculation of μ_2

Calculation of ultimate curvature μ according to 4.1, Biskinis/Fardis 2013:

$$\mu = 2.5454950E-005$$

$$\mu_2 = 9.6940E+007$$

with full section properties:

$$b = 400.00$$

$$d = 258.00$$

$$d' = 42.00$$

$$v = 5.6045447E-005$$

$$N = 190.8684$$

$$f_c = 33.00$$

$$c_o \text{ (5A.5, TBDY)} = 0.002$$

$$\text{Final value of } \mu: \mu^* = \text{shear_factor} * \text{Max}(\mu, c_o) = 0.00553582$$

The Shear_factor is considered equal to 1 (pure moment strength)

$$\text{From (5.4b), TBDY: } \mu = 0.00553582$$

$$w_e \text{ (5.4c)} = 0.00259035$$

$$a_{se} \text{ ((5.4d), TBDY)} = 0.15672608$$

$$b_o = 240.00$$

$$h_o = 340.00$$

$$b_{i2} = 346400.00$$

$$p_{sh,min} = \text{Min}(p_{sh,x}, p_{sh,y}) = 0.00261799$$

Expression ((5.4d), TBDY) for $p_{sh,min}$ has been multiplied by 0.3 according to 15.7.1.3 for members without earthquake detailing (90° closed stirrups)

$$p_{sh,x} \text{ (5.4d)} = 0.00349066$$

$$A_{sh} = A_{stir} * n_s = 78.53982$$

$$\text{No stirrups, } n_s = 2.00$$

$$b_k = 300.00$$

$$p_{sh,y} \text{ (5.4d)} = 0.00261799$$

$$A_{sh} = A_{stir} * n_s = 78.53982$$

$$\text{No stirrups, } n_s = 2.00$$

$$b_k = 400.00$$

$$s = 150.00$$

$$f_{ywe} = 694.45$$

$$f_{ce} = 33.00$$

$$\text{From ((5.A.5), TBDY), TBDY: } c_c = 0.002$$

$$c = \text{confinement factor} = 1.00$$

$$y_1 = 0.00140044$$

$$sh_1 = 0.0044814$$

$$ft_1 = 466.8167$$

$$fy_1 = 389.0139$$

$$su_1 = 0.00512$$

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor and also multiplied by the shear_factor according to 15.7.1.4, with Shear_factor = 1.00

$$l_o/l_{o,min} = l_b/d = 0.30$$

$$su_1 = 0.4 * esu_1_{nominal} \text{ ((5.5), TBDY)} = 0.032$$

$$\text{From table 5A.1, TBDY: } esu_1_{nominal} = 0.08,$$

For calculation of $esu_1_{nominal}$ and y_1, sh_1, ft_1, fy_1 , it is considered characteristic value $fs_1 = fs_1/1.2$, from table 5.1, TBDY.

y_1, sh_1, ft_1, fy_1 , are also multiplied by $\text{Min}(1, 1.25 * (l_b/d)^{2/3})$, from 10.3.5, ASCE 41-17.

$$\text{with } fs_1 = fs = 389.0139$$

$$\text{with } E_s = E_s = 200000.00$$

y2 = 0.00140044
sh2 = 0.0044814
ft2 = 466.8167
fy2 = 389.0139
su2 = 0.00512

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00

lo/lou,min = lb/lb,min = 0.30

su2 = 0.4*esu2_nominal ((5.5), TBDY) = 0.032

From table 5A.1, TBDY: esu2_nominal = 0.08,

For calculation of esu2_nominal and y2, sh2,ft2,fy2, it is considered
characteristic value fsy2 = fs2/1.2, from table 5.1, TBDY.

y1, sh1,ft1,fy1, are also multiplied by $\text{Min}(1, 1.25 \cdot (lb/ld)^{2/3})$, from 10.3.5, ASCE 41-17.

with fs2 = fs = 389.0139

with Es2 = Es = 200000.00

yv = 0.00140044
shv = 0.0044814

ftv = 466.8167

fyv = 389.0139

suv = 0.00512

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00

lo/lou,min = lb/ld = 0.30

suv = 0.4*esuv_nominal ((5.5), TBDY) = 0.032

From table 5A.1, TBDY: esuv_nominal = 0.08,

considering characteristic value fsyv = fsv/1.2, from table 5.1, TBDY

For calculation of esuv_nominal and yv, shv,ftv,fyv, it is considered
characteristic value fsyv = fsv/1.2, from table 5.1, TBDY.

y1, sh1,ft1,fy1, are also multiplied by $\text{Min}(1, 1.25 \cdot (lb/ld)^{2/3})$, from 10.3.5, ASCE 41-17.

with fsv = fs = 389.0139

with Esv = Es = 200000.00

1 = Asl,ten/(b*d)*(fs1/fc) = 0.09330282

2 = Asl,com/(b*d)*(fs2/fc) = 0.09330282

v = Asl,mid/(b*d)*(fsv/fc) = 0.05813483

and confined core properties:

b = 340.00

d = 228.00

d' = 12.00

fcc (5A.2, TBDY) = 33.00

cc (5A.5, TBDY) = 0.002

c = confinement factor = 1.00

1 = Asl,ten/(b*d)*(fs1/fc) = 0.12421118

2 = Asl,com/(b*d)*(fs2/fc) = 0.12421118

v = Asl,mid/(b*d)*(fsv/fc) = 0.07739312

Case/Assumption: Unconfined full section - Steel rupture

' satisfies Eq. (4.3)

v < vs,y2 - LHS eq.(4.5) is satisfied

su (4.9) = 0.22038892

Mu = MRc (4.14) = 9.6940E+007

u = su (4.1) = 2.5454950E-005

Calculation of ratio lb/ld

Inadequate Lap Length with lb/ld = 0.30

Calculation of Shear Strength Vr = Min(Vr1,Vr2) = 192957.075

Calculation of Shear Strength at edge 1, Vr1 = 192957.075

Vr1 = Vn ((22.5.1.1), ACI 318-14)

NOTE: In expression (22.5.1.1) 'Vw' is replaced by 'Vw+ f*Vf'
where Vf is the contribution of FRPs (11.3), ACI 440).

From Table (22.5.5.1), ACI 318-14: $V_c = 88236.482$
= 1 (normal-weight concrete)
 $f_c' = 33.00$, but $f_c'^{0.5} \leq 8.3$ MPa (22.5.3.1, ACI 318-14)
 $\rho_w = A_s/(b_w*d) = 0.00949023$
 A_s (tension reinf.) = 911.0619
 $b_w = 400.00$
 $d = 240.00$
 $V_u*d/M_u < 1 = 0.00$
 $M_u = 3.3205266E-012$
 $V_u = 4.9160836E-020$

From (11.5.4.8), ACI 318-14: $V_s = 104720.593$
 $A_v = 157079.633$
 $f_y = 555.56$
 $s = 150.00$
 V_s has been multiplied by $2(1-s/d)$ ($s > d/2$, according to ASCE 41-17,10.3.4)
 $2(1-s/d) = 0.75$
 V_f ((11-3)-(11.4), ACI 440) = 0.00
From (11-11), ACI 440: $V_s + V_f \leq 366348.956$

Calculation of Shear Strength at edge 2, $V_{r2} = 192957.075$
 $V_{r2} = V_n$ ((22.5.1.1), ACI 318-14)

NOTE: In expression (22.5.1.1) 'Vw' is replaced by 'Vw+ f*Vf'
where Vf is the contribution of FRPs (11.3), ACI 440).

From Table (22.5.5.1), ACI 318-14: $V_c = 88236.482$
= 1 (normal-weight concrete)
 $f_c' = 33.00$, but $f_c'^{0.5} \leq 8.3$ MPa (22.5.3.1, ACI 318-14)
 $\rho_w = A_s/(b_w*d) = 0.00949023$
 A_s (tension reinf.) = 911.0619
 $b_w = 400.00$
 $d = 240.00$
 $V_u*d/M_u < 1 = 0.00$
 $M_u = 3.3203395E-012$
 $V_u = 4.9160836E-020$

From (11.5.4.8), ACI 318-14: $V_s = 104720.593$
 $A_v = 157079.633$
 $f_y = 555.56$
 $s = 150.00$
 V_s has been multiplied by $2(1-s/d)$ ($s > d/2$, according to ASCE 41-17,10.3.4)
 $2(1-s/d) = 0.75$
 V_f ((11-3)-(11.4), ACI 440) = 0.00
From (11-11), ACI 440: $V_s + V_f \leq 366348.956$

End Of Calculation of Shear Capacity ratio for element: beam B1 of floor 1
At local axis: 2

Start Of Calculation of Chord Rotation Capacity for element: beam B1 of floor 1
At local axis: 3

Integration Section: (a)
Section Type: rcars

Constant Properties

Knowledge Factor, = 1.00
Chord Rotation is generally considered as Deformation-Controlled Action according to Table C7-1, ASCE 41-17.
Mean strengths are used for Deformation-Controlled Actions according to 7.5.1.3, ASCE 41-17
Consequently:
New material of Secondary Member: Concrete Strength, $f_c = f_{cm} = 33.00$
New material of Secondary Member: Steel Strength, $f_s = f_{sm} = 555.56$

Concrete Elasticity, $E_c = 26999.444$
Steel Elasticity, $E_s = 200000.00$
Section Height, $H = 400.00$
Section Width, $W = 300.00$
Cover Thickness, $c = 25.00$
Element Length, $L = 1850.00$
Secondary Member
Smooth Bars
Ductile Steel
Without Detailing for Earthquake Resistance (including stirrups not closed at 135°)
Longitudinal Bars With Ends Lapped Starting at the End Sections
Inadequate Lap Length with $l_b/l_d = 0.30$
No FRP Wrapping

Stepwise Properties

Bending Moment, $M = 3.0614186E-011$
Shear Force, $V_2 = 5.3543557E-014$
Shear Force, $V_3 = -4685.405$
Axial Force, $F = -613.7698$
Longitudinal Reinforcement Area Distribution (in 2 divisions)
-Tension: $A_{st} = 911.0619$
-Compression: $A_{sc} = 1231.504$
Longitudinal Reinforcement Area Distribution (in 3 divisions)
-Tension: $A_{st,ten} = 816.8141$
-Compression: $A_{st,com} = 816.8141$
-Middle: $A_{st,mid} = 508.938$
Mean Diameter of Tension Reinforcement, $D_bL = 14.40$

New component: From table 7-7, ASCE 41_17: Final chord rotation Capacity $u_{,R} = 1.0^*$ $u = 0.00795075$
 $u = y + p = 0.00795075$

- Calculation of y -

$y = (M_y * L_s / 3) / E_{eff} = 0.00295075$ ((4.29), Biskinis Phd)
 $M_y = 6.9764E+007$
 $L_s = M/V$ (with $L_s > 0.1 * L$ and $L_s < 2 * L$) = 925.00
From table 10.5, ASCE 41_17: $E_{eff} = 0.3 * E_c * I_g = 7.2898E+012$

Calculation of Yielding Moment M_y

Calculation of y and M_y according to Annex 7 -

$y = \text{Min}(y_{ten}, y_{com})$
 $y_{ten} = 8.5720234E-006$
with ((10.1), ASCE 41-17) $f_y = \text{Min}(f_y, 1.25 * f_y * (l_b/l_d)^{2/3}) = 311.2112$
 $d = 258.00$
 $y = 0.29640604$
 $A = 0.02078041$
 $B = 0.01208963$
with $p_t = 0.00791487$
 $p_c = 0.00791487$
 $p_v = 0.00493157$
 $N = 613.7698$
 $b = 400.00$
 $" = 0.1627907$
 $y_{comp} = 2.8784095E-005$
with $f_c = 33.00$
 $E_c = 26999.444$
 $y = 0.29625066$

A = 0.02074778
B = 0.01207052
with Es = 200000.00

Calculation of ratio l_b/d

Inadequate Lap Length with $l_b/d = 0.30$

- Calculation of ρ -

From table 10-7: $\rho = 0.005$

with:

- Condition iv occurred

Beam controlled by inadequate embedment into beam-column joint:
($l_b/d < 1$ and With Lapping in the Vicinity of the End Regions)

- Condition i occurred

Beam controlled by flexure: $V_p/V_o \leq 1$

shear control ratio $V_p/V_o = 0.54312483$

- Transverse Reinforcement: NC

- Stirrup Spacing $> d/3$

- Low ductility demand, $\mu_y < 2$ (table 10-6, ASCE 41-17)

= -1.1509578E-022

- Stirrup Spacing $> d/2$

d = 258.00

s = 150.00

- Strength provided by hoops $V_s < 3/4$ *design Shear

$V_s = 139627.457$, already given in calculation of shear control ratio

design Shear = 5.3543557E-014

- ($\rho - \rho'$)/ bal = -0.18222013

= $A_{st}/(b_w*d) = 0.00882812$

Tension Reinf Area: $A_{st} = 911.0619$

$\rho' = A_{sc}/(b_w*d) = 0.01193318$

Compression Reinf Area: $A_{sc} = 1231.504$

From (B-1), ACI 318-11: bal = 0.01704017

$f_c = 33.00$

$f_y = 555.56$

From 10.2.7.3, ACI 318-11: $\beta_1 = 0.65$

From fig R10.3.3, ACI 318-11 (Ence 454, too): $87000/(87000+f_y) = c_b/d_t = 0.003/(0.003+ \mu_y) = 0.51922877$

$\mu_y = 0.0027778$

- $V/(b_w*d*f_c^{0.5}) = 1.0876616E-018$, NOTE: units in lb & in

$b_w = 400.00$

End Of Calculation of Chord Rotation Capacity for element: beam B1 of floor 1

At local axis: 3

Integration Section: (a)

Calculation No. 5

beam B1, Floor 1



Limit State: Operational Level (data interpolation between analysis steps 1 and 2)

Analysis: Uniform +X

Check: Shear capacity VRd

Edge: End

Local Axis: (2)



Start Of Calculation of Shear Capacity for element: beam B1 of floor 1

At local axis: 2

Integration Section: (b)

Section Type: rcars

Constant Properties

Knowledge Factor, $\gamma = 1.00$

Member Shear Force is generally considered as Force-Controlled Action according to Table C7-1, ASCE 41-17.

Lower-bound strengths are used for Force-Controlled Actions according to 7.5.1.3, ASCE 41-17

Consequently:

New material of Secondary Member: Concrete Strength, $f_c = f_{c_lower_bound} = 25.00$

New material of Secondary Member: Steel Strength, $f_s = f_{s_lower_bound} = 500.00$

Concrete Elasticity, $E_c = 26999.444$

Steel Elasticity, $E_s = 200000.00$

Section Height, $H = 400.00$

Section Width, $W = 300.00$

Cover Thickness, $c = 25.00$

Element Length, $L = 1850.00$

Secondary Member

Smooth Bars

Ductile Steel

Without Detailing for Earthquake Resistance (including stirrups not closed at 135°)

Longitudinal Bars With Ends Lapped Starting at the End Sections

Inadequate Lap Length with $l_o/l_{o,min} = l_b/l_d = 0.30$

No FRP Wrapping

Stepwise Properties

EDGE -A-

Bending Moment, $M_a = 3.0614186E-011$

Shear Force, $V_a = 5.3543557E-014$

EDGE -B-

Bending Moment, $M_b = 6.8346901E-011$

Shear Force, $V_b = -5.3543557E-014$

BOTH EDGES

Axial Force, $F = -613.7698$

Longitudinal Reinforcement Area Distribution (in 2 divisions)

-Tension: $A_{st} = 923.6282$
-Compression: $A_{sc} = 1218.938$
Longitudinal Reinforcement Area Distribution (in 3 divisions)
-Tension: $A_{st,ten} = 816.8141$
-Compression: $A_{sc,com} = 816.8141$
-Middle: $A_{s,mid} = 508.938$
Mean Diameter of Tension Reinforcement, $D_{bL,ten} = 14.40$

New component: From table 7-7, ASCE 41_17: Final Shear Capacity $V_R = 1.0 \cdot V_n = 171047.78$
 V_n ((22.5.1.1), ACI 318-14) = 171047.78

NOTE: In expression (22.5.1.1) ' V_w ' is replaced by ' $V_w + f \cdot V_f$ '
where V_f is the contribution of FRPs (11.3), ACI 440).

From Table (22.5.5.1), ACI 318-14: $V_c = 76800.00$
= 1 (normal-weight concrete)
 $f_c' = 25.00$, but $f_c'^{0.5} \leq 8.3$ MPa (22.5.3.1, ACI 318-14)
 $\rho_w = A_s / (b_w \cdot d) = 0.00962113$
 A_s (tension reinf.) = 923.6282
 $b_w = 400.00$
 $d = 240.00$
 $V_u \cdot d / M_u < 1 = 0.00$
 $M_u = 6.8346901E-011$
 $V_u = 5.3543557E-014$

From (11.5.4.8), ACI 318-14: $V_s = 94247.78$
 $A_v = 157079.633$
 $f_y = 500.00$
 $s = 150.00$

V_s has been multiplied by $2(1-s/d)$ ($s > d/2$, according to ASCE 41-17,10.3.4)

$2(1-s/d) = 0.75$

V_f ((11-3)-(11.4), ACI 440) = 0.00

From (11-11), ACI 440: $V_s + V_f \leq 318865.838$

End Of Calculation of Shear Capacity for element: beam B1 of floor 1
At local axis: 2
Integration Section: (b)

Calculation No. 6

beam B1, Floor 1



Limit State: Operational Level (data interpolation between analysis steps 1 and 2)

Analysis: Uniform +X

Check: Chord rotation capacity (θ)

Edge: End

Local Axis: (2)



Start Of Calculation of Shear Capacity ratio for element: beam B1 of floor 1

At Shear local axis: 3
 (Bending local axis: 2)
 Section Type: rcars

Constant Properties

 Knowledge Factor, $\gamma = 1.00$
 Mean strength values are used for both shear and moment calculations.
 Consequently:
 New material of Secondary Member: Concrete Strength, $f_c = f_{cm} = 33.00$
 New material of Secondary Member: Steel Strength, $f_s = f_{sm} = 555.56$
 Concrete Elasticity, $E_c = 26999.444$
 Steel Elasticity, $E_s = 200000.00$

 Note: Especially for the calculation of moment strengths,
 the above steel re-bar strengths are multiplied by 1.25 according to R18.6.5, ACI 318-14
 New material: Steel Strength, $f_s = 1.25 \cdot f_{sm} = 694.45$

 Section Height, $H = 400.00$
 Section Width, $W = 300.00$
 Cover Thickness, $c = 25.00$
 Mean Confinement Factor overall section = 1.00
 Element Length, $L = 1850.00$
 Secondary Member
 Smooth Bars
 Ductile Steel
 Without Detailing for Earthquake Resistance (including stirrups not closed at 135°)
 Longitudinal Bars With Ends Lapped Starting at the End Sections
 Inadequate Lap Length with $l_o/l_{ou,min} = 0.30$
 No FRP Wrapping

 Stepwise Properties

 At local axis: 3
 EDGE -A-
 Shear Force, $V_a = 2771.021$
 EDGE -B-
 Shear Force, $V_b = 2771.021$
 BOTH EDGES
 Axial Force, $F = -190.8684$
 Longitudinal Reinforcement Area Distribution (in 2 divisions)
 -Tension: $A_{sl,t} = 911.0619$
 -Compression: $A_{sl,c} = 1231.504$
 Longitudinal Reinforcement Area Distribution (in 3 divisions)
 -Tension: $A_{sl,ten} = 603.1858$
 -Compression: $A_{sl,com} = 923.6282$
 -Middle: $A_{sl,mid} = 615.7522$

Calculation of Shear Capacity ratio , $V_e/V_r = 0.59550037$

Member Controlled by Flexure ($V_e/V_r < 1$)

Calculation of Shear Demand from fig. R18.6.5, ACI 318-14 $V_e = (M_{pr1} + M_{pr2})/l_n \pm w_u \cdot l_n/2 = 172632.267$
with

$M_{pr1} = \text{Max}(M_{u1+} , M_{u1-}) = 1.5721E+008$

$M_{u1+} = 1.1233E+008$, is the ultimate moment strength at the edge 1 of the member in the actual moment direction which is defined for the static loading combination

$M_{u1-} = 1.5721E+008$, is the ultimate moment strength at the edge 1 of the member in the opposite moment direction which is defined for the static loading combination

$M_{pr2} = \text{Max}(M_{u2+} , M_{u2-}) = 1.5703E+008$

$M_{u2+} = 1.1247E+008$, is the ultimate moment strength at the edge 2 of the member in the actual moment direction which is defined for the the static loading combination

$M_{u2-} = 1.5703E+008$, is the ultimate moment strength at the edge 2 of the member in the opposite moment direction which is defined for the the static loading combination

and

$\pm w_u \cdot l_n = (|V_1| + |V_2|)/2$

with

$V_1 = 2771.021$, is the shear force acting at edge 1 for the the static loading combination

$V_2 = 2771.021$, is the shear force acting at edge 2 for the the static loading combination

Calculation of M_{u1+}

Calculation of ultimate curvature ϕ_u according to 4.1, Biskinis/Fardis 2013:

$\phi_u = 1.7687265E-005$

$M_u = 1.1233E+008$

with full section properties:

$b = 300.00$

$d = 357.00$

$d' = 42.00$

$v = 5.4004576E-005$

$N = 190.8684$

$f_c = 33.00$

ϕ_c (5A.5, TBDY) = 0.002

Final value of ϕ_u : $\phi_u^* = \text{shear_factor} * \text{Max}(\phi_u, \phi_c) = 0.00553582$

The Shear_factor is considered equal to 1 (pure moment strength)

From (5.4b), TBDY: $\phi_u = 0.00553582$

w_e (5.4c) = 0.00259035

a_{se} ((5.4d), TBDY) = 0.15672608

$b_o = 240.00$

$h_o = 340.00$

$b_{i2} = 346400.00$

$\phi_{sh,min} = \text{Min}(\phi_{sh,x} , \phi_{sh,y}) = 0.00261799$

Expression ((5.4d), TBDY) for $\phi_{sh,min}$ has been multiplied by 0.3 according to 15.7.1.3 for members without earthquake detailing (90° closed stirrups)

 $\phi_{sh,x}$ (5.4d) = 0.00349066

$A_{sh} = A_{stir} \cdot n_s = 78.53982$

No stirrups, $n_s = 2.00$

$b_k = 300.00$

$\phi_{sh,y}$ (5.4d) = 0.00261799

$A_{sh} = A_{stir} \cdot n_s = 78.53982$

No stirrups, $n_s = 2.00$

$b_k = 400.00$

$s = 150.00$

$f_{ywe} = 694.45$

$f_{ce} = 33.00$

From ((5.A5), TBDY), TBDY: $\phi_c = 0.002$

c = confinement factor = 1.00

$y_1 = 0.00140044$

$sh_1 = 0.0044814$

$$ft1 = 466.8167$$

$$fy1 = 389.0139$$

$$su1 = 0.00512$$

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00

$$lo/lou,min = lb/lb = 0.30$$

$$su1 = 0.4 * esu1_nominal ((5.5), TBDY) = 0.032$$

From table 5A.1, TBDY: esu1_nominal = 0.08,

For calculation of esu1_nominal and y1, sh1,ft1,fy1, it is considered
characteristic value fsy1 = fs1/1.2, from table 5.1, TBDY.

y1, sh1,ft1,fy1, are also multiplied by $\text{Min}(1, 1.25 * (lb/lb)^{2/3})$, from 10.3.5, ASCE 41-17.

$$\text{with } fs1 = fs = 389.0139$$

$$\text{with } Es1 = Es = 200000.00$$

$$y2 = 0.00140044$$

$$sh2 = 0.0044814$$

$$ft2 = 466.8167$$

$$fy2 = 389.0139$$

$$su2 = 0.00512$$

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00

$$lo/lou,min = lb/lb,min = 0.30$$

$$su2 = 0.4 * esu2_nominal ((5.5), TBDY) = 0.032$$

From table 5A.1, TBDY: esu2_nominal = 0.08,

For calculation of esu2_nominal and y2, sh2,ft2,fy2, it is considered
characteristic value fsy2 = fs2/1.2, from table 5.1, TBDY.

y1, sh1,ft1,fy1, are also multiplied by $\text{Min}(1, 1.25 * (lb/lb)^{2/3})$, from 10.3.5, ASCE 41-17.

$$\text{with } fs2 = fs = 389.0139$$

$$\text{with } Es2 = Es = 200000.00$$

$$yv = 0.00140044$$

$$shv = 0.0044814$$

$$ftv = 466.8167$$

$$fyv = 389.0139$$

$$suv = 0.00512$$

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00

$$lo/lou,min = lb/lb = 0.30$$

$$suv = 0.4 * esuv_nominal ((5.5), TBDY) = 0.032$$

From table 5A.1, TBDY: esuv_nominal = 0.08,

considering characteristic value fsyv = fsv/1.2, from table 5.1, TBDY
For calculation of esuv_nominal and yv, shv,ftv,fyv, it is considered
characteristic value fsyv = fsv/1.2, from table 5.1, TBDY.

y1, sh1,ft1,fy1, are also multiplied by $\text{Min}(1, 1.25 * (lb/lb)^{2/3})$, from 10.3.5, ASCE 41-17.

$$\text{with } fsv = fs = 389.0139$$

$$\text{with } Esv = Es = 200000.00$$

$$1 = Asl,ten / (b * d) * (fs1 / fc) = 0.06639156$$

$$2 = Asl,com / (b * d) * (fs2 / fc) = 0.10166207$$

$$v = Asl,mid / (b * d) * (fsv / fc) = 0.06777471$$

and confined core properties:

$$b = 240.00$$

$$d = 327.00$$

$$d' = 12.00$$

$$fcc (5A.2, TBDY) = 33.00$$

$$cc (5A.5, TBDY) = 0.002$$

$$c = \text{confinement factor} = 1.00$$

$$1 = Asl,ten / (b * d) * (fs1 / fc) = 0.09060316$$

$$2 = Asl,com / (b * d) * (fs2 / fc) = 0.13873608$$

$$v = Asl,mid / (b * d) * (fsv / fc) = 0.09249072$$

Case/Assumption: Unconfined full section - Steel rupture

' satisfies Eq. (4.3)

--->

v < vs,y2 - LHS eq.(4.5) is satisfied

--->

$$su (4.9) = 0.189149$$

$$Mu = MRc (4.14) = 1.1233E+008$$

$$u = s_u(4.1) = 1.7687265E-005$$

Calculation of ratio l_b/d

Inadequate Lap Length with $l_b/d = 0.30$

Calculation of μ_1 -

Calculation of ultimate curvature μ according to 4.1, Biskinis/Fardis 2013:

$$u = 1.8434312E-005$$

$$\mu = 1.5721E+008$$

with full section properties:

$$b = 300.00$$

$$d = 358.00$$

$$d' = 43.00$$

$$v = 5.3853726E-005$$

$$N = 190.8684$$

$$f_c = 33.00$$

$$c_o(5A.5, \text{TB DY}) = 0.002$$

$$\text{Final value of } c_u: c_u^* = \text{shear_factor} * \text{Max}(c_u, c_c) = 0.00553582$$

The Shear_factor is considered equal to 1 (pure moment strength)

$$\text{From (5.4b), TB DY: } c_u = 0.00553582$$

$$w_e(5.4c) = 0.00259035$$

$$a_{se}((5.4d), \text{TB DY}) = 0.15672608$$

$$b_o = 240.00$$

$$h_o = 340.00$$

$$b_{i2} = 346400.00$$

$$p_{sh,min} = \text{Min}(p_{sh,x}, p_{sh,y}) = 0.00261799$$

Expression ((5.4d), TB DY) for $p_{sh,min}$ has been multiplied by 0.3 according to 15.7.1.3 for members without earthquake detailing (90° closed stirrups)

$$p_{sh,x}(5.4d) = 0.00349066$$

$$A_{sh} = A_{stir} * n_s = 78.53982$$

$$\text{No stirrups, } n_s = 2.00$$

$$b_k = 300.00$$

$$p_{sh,y}(5.4d) = 0.00261799$$

$$A_{sh} = A_{stir} * n_s = 78.53982$$

$$\text{No stirrups, } n_s = 2.00$$

$$b_k = 400.00$$

$$s = 150.00$$

$$f_{ywe} = 694.45$$

$$f_{ce} = 33.00$$

$$\text{From ((5.A5), TB DY), TB DY: } c_c = 0.002$$

$$c = \text{confinement factor} = 1.00$$

$$y_1 = 0.00140044$$

$$sh_1 = 0.0044814$$

$$ft_1 = 466.8167$$

$$fy_1 = 389.0139$$

$$su_1 = 0.00512$$

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor and also multiplied by the shear_factor according to 15.7.1.4, with Shear_factor = 1.00

$$l_o/l_{o,min} = l_b/d = 0.30$$

$$su_1 = 0.4 * esu_1_{nominal}((5.5), \text{TB DY}) = 0.032$$

From table 5A.1, TB DY: $esu_1_{nominal} = 0.08$,

For calculation of $esu_1_{nominal}$ and y_1, sh_1, ft_1, fy_1 , it is considered characteristic value $fsy_1 = fs_1/1.2$, from table 5.1, TB DY.

y_1, sh_1, ft_1, fy_1 , are also multiplied by $\text{Min}(1, 1.25 * (l_b/d)^{2/3})$, from 10.3.5, ASCE 41-17.

$$\text{with } fs_1 = fs = 389.0139$$

with $E_{s1} = E_s = 200000.00$
 $y_2 = 0.00140044$
 $sh_2 = 0.0044814$
 $ft_2 = 466.8167$
 $fy_2 = 389.0139$
 $su_2 = 0.00512$
 using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
 and also multiplied by the shear_factor according to 15.7.1.4, with
 Shear_factor = 1.00
 $l_o/l_{o,min} = l_b/l_{b,min} = 0.30$
 $su_2 = 0.4 * esu_{2,nominal} ((5.5), TBDY) = 0.032$
 From table 5A.1, TBDY: $esu_{2,nominal} = 0.08$,
 For calculation of $esu_{2,nominal}$ and y_2, sh_2, ft_2, fy_2 , it is considered
 characteristic value $fs_2 = fs_2/1.2$, from table 5.1, TBDY.
 y_1, sh_1, ft_1, fy_1 , are also multiplied by $Min(1, 1.25 * (l_b/l_d)^{2/3})$, from 10.3.5, ASCE 41-17.
 with $fs_2 = fs = 389.0139$
 with $E_{s2} = E_s = 200000.00$
 $y_v = 0.00140044$
 $sh_v = 0.0044814$
 $ft_v = 466.8167$
 $fy_v = 389.0139$
 $suv = 0.00512$
 using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
 and also multiplied by the shear_factor according to 15.7.1.4, with
 Shear_factor = 1.00
 $l_o/l_{o,min} = l_b/l_d = 0.30$
 $suv = 0.4 * esuv_{nominal} ((5.5), TBDY) = 0.032$
 From table 5A.1, TBDY: $esuv_{nominal} = 0.08$,
 considering characteristic value $fs_{yv} = fs_v/1.2$, from table 5.1, TBDY
 For calculation of $esuv_{nominal}$ and y_v, sh_v, ft_v, fy_v , it is considered
 characteristic value $fs_{yv} = fs_v/1.2$, from table 5.1, TBDY.
 y_1, sh_1, ft_1, fy_1 , are also multiplied by $Min(1, 1.25 * (l_b/l_d)^{2/3})$, from 10.3.5, ASCE 41-17.
 with $fs_v = fs = 389.0139$
 with $E_{sv} = E_s = 200000.00$
 $1 = A_{sl,ten}/(b*d) * (fs_1/f_c) = 0.1013781$
 $2 = A_{sl,com}/(b*d) * (fs_2/f_c) = 0.06620611$
 $v = A_{sl,mid}/(b*d) * (fs_v/f_c) = 0.0675854$
 and confined core properties:
 $b = 240.00$
 $d = 328.00$
 $d' = 13.00$
 $f_{cc} (5A.2, TBDY) = 33.00$
 $cc (5A.5, TBDY) = 0.002$
 $c = \text{confinement factor} = 1.00$
 $1 = A_{sl,ten}/(b*d) * (fs_1/f_c) = 0.13831311$
 $2 = A_{sl,com}/(b*d) * (fs_2/f_c) = 0.09032693$
 $v = A_{sl,mid}/(b*d) * (fs_v/f_c) = 0.09220874$
 Case/Assumption: Unconfined full section - Steel rupture
 ' satisfies Eq. (4.3)
 --->
 $v < v_s, y_2$ - LHS eq.(4.5) is satisfied
 --->
 $su (4.9) = 0.22418173$
 $Mu = MRc (4.14) = 1.5721E+008$
 $u = su (4.1) = 1.8434312E-005$

 Calculation of ratio l_b/l_d

Inadequate Lap Length with $l_b/l_d = 0.30$

 Calculation of Mu_{2+}

Calculation of ultimate curvature ϕ_u according to 4.1, Biskinis/Fardis 2013:

$$u = 1.7651391E-005$$

$$Mu = 1.1247E+008$$

with full section properties:

$$b = 300.00$$

$$d = 358.00$$

$$d' = 43.00$$

$$v = 5.3853726E-005$$

$$N = 190.8684$$

$$f_c = 33.00$$

$$c_o \text{ (5A.5, TBDY)} = 0.002$$

$$\text{Final value of } \phi_u: \phi_u^* = \text{shear_factor} * \text{Max}(\phi_u, \phi_c) = 0.00553582$$

The Shear_factor is considered equal to 1 (pure moment strength)

$$\text{From (5.4b), TBDY: } \phi_u = 0.00553582$$

$$w_e \text{ (5.4c)} = 0.00259035$$

$$a_{se} \text{ ((5.4d), TBDY)} = 0.15672608$$

$$b_o = 240.00$$

$$h_o = 340.00$$

$$b_{i2} = 346400.00$$

$$\phi_{sh,min} = \text{Min}(\phi_{sh,x}, \phi_{sh,y}) = 0.00261799$$

Expression ((5.4d), TBDY) for $\phi_{sh,min}$ has been multiplied by 0.3 according to 15.7.1.3 for members without earthquake detailing (90° closed stirrups)

$$\phi_{sh,x} \text{ (5.4d)} = 0.00349066$$

$$A_{sh} = A_{stir} * n_s = 78.53982$$

$$\text{No stirrups, } n_s = 2.00$$

$$b_k = 300.00$$

$$\phi_{sh,y} \text{ (5.4d)} = 0.00261799$$

$$A_{sh} = A_{stir} * n_s = 78.53982$$

$$\text{No stirrups, } n_s = 2.00$$

$$b_k = 400.00$$

$$s = 150.00$$

$$f_{ywe} = 694.45$$

$$f_{ce} = 33.00$$

$$\text{From ((5.A5), TBDY), TBDY: } \phi_c = 0.002$$

$$c = \text{confinement factor} = 1.00$$

$$y_1 = 0.00140044$$

$$sh_1 = 0.0044814$$

$$f_{t1} = 466.8167$$

$$f_{y1} = 389.0139$$

$$su_1 = 0.00512$$

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00

$$l_o/l_{o,min} = l_b/l_d = 0.30$$

$$su_1 = 0.4 * esu1_{nominal} \text{ ((5.5), TBDY)} = 0.032$$

$$\text{From table 5A.1, TBDY: } esu1_{nominal} = 0.08,$$

For calculation of $esu1_{nominal}$ and $y_1, sh_1, f_{t1}, f_{y1}$, it is considered
characteristic value $f_{s1} = f_s/1.2$, from table 5.1, TBDY.

$y_1, sh_1, f_{t1}, f_{y1}$, are also multiplied by $\text{Min}(1, 1.25 * (l_b/l_d)^{2/3})$, from 10.3.5, ASCE 41-17.

$$\text{with } f_{s1} = f_s = 389.0139$$

$$\text{with } E_{s1} = E_s = 200000.00$$

$$y_2 = 0.00140044$$

$$sh_2 = 0.0044814$$

$$f_{t2} = 466.8167$$

$$f_{y2} = 389.0139$$

$$su_2 = 0.00512$$

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00

$$l_o/l_{o,min} = l_b/l_{b,min} = 0.30$$

$$su_2 = 0.4 * esu2_{nominal} \text{ ((5.5), TBDY)} = 0.032$$

$$\text{From table 5A.1, TBDY: } esu2_{nominal} = 0.08,$$

For calculation of $esu2_{nominal}$ and $y_2, sh_2, f_{t2}, f_{y2}$, it is considered

characteristic value $f_{sy2} = f_{s2}/1.2$, from table 5.1, TBDY.

y_1, sh_1, ft_1, fy_1 , are also multiplied by $\text{Min}(1, 1.25 \cdot (l_b/l_d)^{2/3})$, from 10.3.5, ASCE 41-17.

with $f_{s2} = f_s = 389.0139$

with $E_{s2} = E_s = 200000.00$

$y_v = 0.00140044$

$sh_v = 0.0044814$

$ft_v = 466.8167$

$fy_v = 389.0139$

$s_{uv} = 0.00512$

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor

and also multiplied by the shear_factor according to 15.7.1.4, with

Shear_factor = 1.00

$l_o/l_{o,min} = l_b/l_d = 0.30$

$s_{uv} = 0.4 \cdot e_{suv,nominal} ((5.5), TBDY) = 0.032$

From table 5A.1, TBDY: $e_{suv,nominal} = 0.08$,

considering characteristic value $f_{syv} = f_{sv}/1.2$, from table 5.1, TBDY

For calculation of $e_{suv,nominal}$ and y_v, sh_v, ft_v, fy_v , it is considered

characteristic value $f_{syv} = f_{sv}/1.2$, from table 5.1, TBDY.

y_1, sh_1, ft_1, fy_1 , are also multiplied by $\text{Min}(1, 1.25 \cdot (l_b/l_d)^{2/3})$, from 10.3.5, ASCE 41-17.

with $f_{sv} = f_s = 389.0139$

with $E_{sv} = E_s = 200000.00$

1 = $Asl_{,ten}/(b \cdot d) \cdot (f_{s1}/f_c) = 0.06620611$

2 = $Asl_{,com}/(b \cdot d) \cdot (f_{s2}/f_c) = 0.1013781$

v = $Asl_{,mid}/(b \cdot d) \cdot (f_{sv}/f_c) = 0.0675854$

and confined core properties:

b = 240.00

d = 328.00

d' = 13.00

f_{cc} (5A.2, TBDY) = 33.00

cc (5A.5, TBDY) = 0.002

c = confinement factor = 1.00

1 = $Asl_{,ten}/(b \cdot d) \cdot (f_{s1}/f_c) = 0.09032693$

2 = $Asl_{,com}/(b \cdot d) \cdot (f_{s2}/f_c) = 0.13831311$

v = $Asl_{,mid}/(b \cdot d) \cdot (f_{sv}/f_c) = 0.09220874$

Case/Assumption: Unconfined full section - Steel rupture

' satisfies Eq. (4.3)

--->

v < v_{s,y2} - LHS eq.(4.5) is satisfied

--->

su (4.9) = 0.18977061

Mu = MRc (4.14) = 1.1247E+008

u = su (4.1) = 1.7651391E-005

Calculation of ratio l_b/l_d

Inadequate Lap Length with $l_b/l_d = 0.30$

Calculation of Mu2-

Calculation of ultimate curvature ϕ_u according to 4.1, Biskinis/Fardis 2013:

u = 1.8476637E-005

Mu = 1.5703E+008

with full section properties:

b = 300.00

d = 357.00

d' = 42.00

v = 5.4004576E-005

N = 190.8684

f_c = 33.00

co (5A.5, TBDY) = 0.002

Final value of ϕ_u : $\phi_u^* = \text{shear_factor} \cdot \text{Max}(\phi_u, \phi_c) = 0.00553582$

The Shear_factor is considered equal to 1 (pure moment strength)

From (5.4b), TBDY: $c_u = 0.00553582$

w_e (5.4c) = 0.00259035

a_{se} ((5.4d), TBDY) = 0.15672608

$b_o = 240.00$

$h_o = 340.00$

$b_{i2} = 346400.00$

$p_{sh,min} = \text{Min}(p_{sh,x}, p_{sh,y}) = 0.00261799$

Expression ((5.4d), TBDY) for $p_{sh,min}$ has been multiplied by 0.3 according to 15.7.1.3 for members without earthquake detailing (90° closed stirrups)

 $p_{sh,x}$ (5.4d) = 0.00349066

$A_{sh} = A_{stir} * n_s = 78.53982$

No stirrups, $n_s = 2.00$

$b_k = 300.00$

 $p_{sh,y}$ (5.4d) = 0.00261799

$A_{sh} = A_{stir} * n_s = 78.53982$

No stirrups, $n_s = 2.00$

$b_k = 400.00$

 $s = 150.00$

$f_{ywe} = 694.45$

$f_{ce} = 33.00$

From ((5.A5), TBDY), TBDY: $c_c = 0.002$

$c = \text{confinement factor} = 1.00$

$y_1 = 0.00140044$

$sh_1 = 0.0044814$

$ft_1 = 466.8167$

$fy_1 = 389.0139$

$su_1 = 0.00512$

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor and also multiplied by the shear_factor according to 15.7.1.4, with Shear_factor = 1.00

$l_o/l_{ou,min} = l_b/l_d = 0.30$

$su_1 = 0.4 * esu_{1,nominal}$ ((5.5), TBDY) = 0.032

From table 5A.1, TBDY: $esu_{1,nominal} = 0.08$,

For calculation of $esu_{1,nominal}$ and y_1, sh_1, ft_1, fy_1 , it is considered characteristic value $fsy_1 = fs_1/1.2$, from table 5.1, TBDY.

y_1, sh_1, ft_1, fy_1 , are also multiplied by $\text{Min}(1, 1.25 * (l_b/l_d)^{2/3})$, from 10.3.5, ASCE 41-17.

with $fs_1 = fs = 389.0139$

with $Es_1 = Es = 200000.00$

$y_2 = 0.00140044$

$sh_2 = 0.0044814$

$ft_2 = 466.8167$

$fy_2 = 389.0139$

$su_2 = 0.00512$

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor and also multiplied by the shear_factor according to 15.7.1.4, with Shear_factor = 1.00

$l_o/l_{ou,min} = l_b/l_{b,min} = 0.30$

$su_2 = 0.4 * esu_{2,nominal}$ ((5.5), TBDY) = 0.032

From table 5A.1, TBDY: $esu_{2,nominal} = 0.08$,

For calculation of $esu_{2,nominal}$ and y_2, sh_2, ft_2, fy_2 , it is considered characteristic value $fsy_2 = fs_2/1.2$, from table 5.1, TBDY.

y_2, sh_2, ft_2, fy_2 , are also multiplied by $\text{Min}(1, 1.25 * (l_b/l_d)^{2/3})$, from 10.3.5, ASCE 41-17.

with $fs_2 = fs = 389.0139$

with $Es_2 = Es = 200000.00$

$y_v = 0.00140044$

$sh_v = 0.0044814$

$ft_v = 466.8167$

$fy_v = 389.0139$

$su_v = 0.00512$

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor and also multiplied by the shear_factor according to 15.7.1.4, with Shear_factor = 1.00

$l_o/l_{ou,min} = l_b/l_d = 0.30$

$$suv = 0.4 * esuv_nominal ((5.5), TBDY) = 0.032$$

From table 5A.1, TBDY: $esuv_nominal = 0.08$,

considering characteristic value $fsyv = fsv/1.2$, from table 5.1, TBDY

For calculation of $esuv_nominal$ and yv , shv,ftv,fyv , it is considered characteristic value $fsyv = fsv/1.2$, from table 5.1, TBDY.

$y1$, $sh1,ft1,fy1$, are also multiplied by $\text{Min}(1, 1.25 * (lb/ld)^{2/3})$, from 10.3.5, ASCE 41-17.

with $fsv = fs = 389.0139$

with $Esv = Es = 200000.00$

$$1 = Asl,ten/(b*d)*(fs1/fc) = 0.10166207$$

$$2 = Asl,com/(b*d)*(fs2/fc) = 0.06639156$$

$$v = Asl,mid/(b*d)*(fsv/fc) = 0.06777471$$

and confined core properties:

$$b = 240.00$$

$$d = 327.00$$

$$d' = 12.00$$

$$fcc (5A.2, TBDY) = 33.00$$

$$cc (5A.5, TBDY) = 0.002$$

$c =$ confinement factor = 1.00

$$1 = Asl,ten/(b*d)*(fs1/fc) = 0.13873608$$

$$2 = Asl,com/(b*d)*(fs2/fc) = 0.09060316$$

$$v = Asl,mid/(b*d)*(fsv/fc) = 0.09249072$$

Case/Assumption: Unconfined full section - Steel rupture
' satisfies Eq. (4.3)

$v < vs,y2$ - LHS eq.(4.5) is satisfied

$$su (4.9) = 0.22379076$$

$$Mu = MRc (4.14) = 1.5703E+008$$

$$u = su (4.1) = 1.8476637E-005$$

Calculation of ratio lb/ld

Inadequate Lap Length with $lb/ld = 0.30$

Calculation of Shear Strength $Vr = \text{Min}(Vr1, Vr2) = 289894.477$

Calculation of Shear Strength at edge 1, $Vr1 = 289894.477$

$Vr1 = Vn$ ((22.5.1.1), ACI 318-14)

NOTE: In expression (22.5.1.1) ' Vw ' is replaced by ' $Vw + f*Vf$ '
where Vf is the contribution of FRPs (11.3), ACI 440).

From Table (22.5.5.1), ACI 318-14: $Vc = 103724.534$

= 1 (normal-weight concrete)

$fc' = 33.00$, but $fc^{0.5} <= 8.3$ MPa (22.5.3.1, ACI 318-14)

$$pw = As/(bw*d) = 0.00949023$$

As (tension reinf.) = 911.0619

$bw = 300.00$

$d = 320.00$

$$Vu*d/Mu < 1 = 1.00$$

$Mu = 71267.116$

$Vu = 2771.021$

From (11.5.4.8), ACI 318-14: $Vs = 186169.943$

$Av = 157079.633$

$fy = 555.56$

$s = 150.00$

Vs has been multiplied by 1 ($s < d/2$, according to ASCE 41-17,10.3.4)

Vf ((11-3)-(11.4), ACI 440) = 0.00

From (11-11), ACI 440: $Vs + Vf <= 366348.956$

Calculation of Shear Strength at edge 2, $Vr2 = 289894.477$

$Vr2 = Vn$ ((22.5.1.1), ACI 318-14)

NOTE: In expression (22.5.1.1) 'Vw' is replaced by 'Vw+ f*Vf'
where Vf is the contribution of FRPs (11.3), ACI 440).

From Table (22.5.5.1), ACI 318-14: $V_c = 103724.534$
= 1 (normal-weight concrete)
 $f'_c = 33.00$, but $f'_c^{0.5} \leq 8.3$ MPa (22.5.3.1, ACI 318-14)
 $\rho_w = A_s/(b_w*d) = 0.00949023$
As (tension reinf.) = 911.0619
bw = 300.00
d = 320.00
 $V_u*d/\mu_u < 1 = 1.00$
 $\mu_u = 71267.116$
 $V_u = 2771.021$
From (11.5.4.8), ACI 318-14: $V_s = 186169.943$
 $A_v = 157079.633$
 $f_y = 555.56$
s = 150.00
 V_s has been multiplied by 1 ($s < d/2$, according to ASCE 41-17,10.3.4)
 V_f ((11-3)-(11.4), ACI 440) = 0.00
From (11-11), ACI 440: $V_s + V_f \leq 366348.956$

End Of Calculation of Shear Capacity ratio for element: beam B1 of floor 1
At local axis: 3

Start Of Calculation of Shear Capacity ratio for element: beam B1 of floor 1
At Shear local axis: 2
(Bending local axis: 3)
Section Type: rcars

Constant Properties

Knowledge Factor, = 1.00
Mean strength values are used for both shear and moment calculations.
Consequently:
New material of Secondary Member: Concrete Strength, $f_c = f_{cm} = 33.00$
New material of Secondary Member: Steel Strength, $f_s = f_{sm} = 555.56$
Concrete Elasticity, $E_c = 26999.444$
Steel Elasticity, $E_s = 200000.00$

Note: Especially for the calculation of moment strengths,
the above steel re-bar strengths are multiplied by 1.25 according to R18.6.5, ACI 318-14
New material: Steel Strength, $f_s = 1.25*f_{sm} = 694.45$

Section Height, H = 400.00
Section Width, W = 300.00
Cover Thickness, c = 25.00
Mean Confinement Factor overall section = 1.00
Element Length, L = 1850.00
Secondary Member
Smooth Bars
Ductile Steel
Without Detailing for Earthquake Resistance (including stirrups not closed at 135°)
Longitudinal Bars With Ends Lapped Starting at the End Sections
Inadequate Lap Length with $l_o/l_{ou,min} = 0.30$
No FRP Wrapping

Stepwise Properties

At local axis: 2
EDGE -A-
Shear Force, $V_a = 4.9160836E-020$
EDGE -B-
Shear Force, $V_b = -4.9160836E-020$

BOTH EDGES

Axial Force, $F = -190.8684$

Longitudinal Reinforcement Area Distribution (in 2 divisions)

-Tension: $As_t = 911.0619$

-Compression: $As_c = 1231.504$

Longitudinal Reinforcement Area Distribution (in 3 divisions)

-Tension: $As_{t,ten} = 816.8141$

-Compression: $As_{c,com} = 816.8141$

-Middle: $As_{mid} = 508.938$

Calculation of Shear Capacity ratio, $V_e/V_r = 0.54312483$

Member Controlled by Flexure ($V_e/V_r < 1$)

Calculation of Shear Demand from fig. R18.6.5, ACI 318-14 $V_e = (M_{pr1} + M_{pr2})/l_n \pm w_u \cdot l_n/2 = 104799.778$
with

$M_{pr1} = \text{Max}(Mu_{1+}, Mu_{1-}) = 9.6940E+007$

$Mu_{1+} = 9.6940E+007$, is the ultimate moment strength at the edge 1 of the member in the actual moment direction which is defined for the static loading combination

$Mu_{1-} = 9.6940E+007$, is the ultimate moment strength at the edge 1 of the member in the opposite moment direction which is defined for the static loading combination

$M_{pr2} = \text{Max}(Mu_{2+}, Mu_{2-}) = 9.6940E+007$

$Mu_{2+} = 9.6940E+007$, is the ultimate moment strength at the edge 2 of the member in the actual moment direction which is defined for the the static loading combination

$Mu_{2-} = 9.6940E+007$, is the ultimate moment strength at the edge 2 of the member in the opposite moment direction which is defined for the the static loading combination

and

$\pm w_u \cdot l_n = (|V_1| + |V_2|)/2$

with

$V_1 = 4.9160836E-020$, is the shear force acting at edge 1 for the the static loading combination

$V_2 = -4.9160836E-020$, is the shear force acting at edge 2 for the the static loading combination

Calculation of Mu_{1+}

Calculation of ultimate curvature ϕ_u according to 4.1, Biskinis/Fardis 2013:

$\phi_u = 2.5454950E-005$

$M_u = 9.6940E+007$

with full section properties:

$b = 400.00$

$d = 258.00$

$d' = 42.00$

$v = 5.6045447E-005$

$N = 190.8684$

$f_c = 33.00$

ϕ_c (5A.5, TBDY) = 0.002

Final value of ϕ_u : $\phi_u^* = \text{shear_factor} \cdot \text{Max}(\phi_u, \phi_c) = 0.00553582$

The Shear_factor is considered equal to 1 (pure moment strength)

From (5.4b), TBDY: $\phi_u = 0.00553582$

w_e (5.4c) = 0.00259035

a_{se} ((5.4d), TBDY) = 0.15672608

$b_o = 240.00$

$h_o = 340.00$

$bi_2 = 346400.00$

$p_{sh,min} = \text{Min}(p_{sh,x}, p_{sh,y}) = 0.00261799$

Expression ((5.4d), TBDY) for $p_{sh,min}$ has been multiplied by 0.3 according to 15.7.1.3 for members without earthquake detailing (90° closed stirrups)

$p_{sh,x}$ (5.4d) = 0.00349066

$A_{sh} = A_{stir} \cdot n_s = 78.53982$

No stirrups, $n_s = 2.00$

$b_k = 300.00$

psh,y (5.4d) = 0.00261799
Ash = Astir*ns = 78.53982
No stirups, ns = 2.00
bk = 400.00

s = 150.00
fywe = 694.45
fce = 33.00
From ((5.A.5), TBDY), TBDY: cc = 0.002
c = confinement factor = 1.00

y1 = 0.00140044
sh1 = 0.0044814
ft1 = 466.8167
fy1 = 389.0139
su1 = 0.00512

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00

lo/lou,min = lb/d = 0.30

su1 = 0.4*esu1_nominal ((5.5), TBDY) = 0.032

From table 5A.1, TBDY: esu1_nominal = 0.08,

For calculation of esu1_nominal and y1, sh1,ft1,fy1, it is considered
characteristic value fsy1 = fs1/1.2, from table 5.1, TBDY.

y1, sh1,ft1,fy1, are also multiplied by $\text{Min}(1, 1.25 \cdot (lb/d)^{2/3})$, from 10.3.5, ASCE 41-17.

with fs1 = fs = 389.0139

with Es1 = Es = 200000.00

y2 = 0.00140044
sh2 = 0.0044814
ft2 = 466.8167
fy2 = 389.0139
su2 = 0.00512

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00

lo/lou,min = lb/lb,min = 0.30

su2 = 0.4*esu2_nominal ((5.5), TBDY) = 0.032

From table 5A.1, TBDY: esu2_nominal = 0.08,

For calculation of esu2_nominal and y2, sh2,ft2,fy2, it is considered
characteristic value fsy2 = fs2/1.2, from table 5.1, TBDY.

y1, sh1,ft1,fy1, are also multiplied by $\text{Min}(1, 1.25 \cdot (lb/d)^{2/3})$, from 10.3.5, ASCE 41-17.

with fs2 = fs = 389.0139

with Es2 = Es = 200000.00

yv = 0.00140044
shv = 0.0044814
ftv = 466.8167
fyv = 389.0139
suv = 0.00512

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00

lo/lou,min = lb/d = 0.30

suv = 0.4*esuv_nominal ((5.5), TBDY) = 0.032

From table 5A.1, TBDY: esuv_nominal = 0.08,

considering characteristic value fsyv = fsv/1.2, from table 5.1, TBDY
For calculation of esuv_nominal and yv, shv,ftv,fyv, it is considered
characteristic value fsyv = fsv/1.2, from table 5.1, TBDY.

y1, sh1,ft1,fy1, are also multiplied by $\text{Min}(1, 1.25 \cdot (lb/d)^{2/3})$, from 10.3.5, ASCE 41-17.

with fsv = fs = 389.0139

with Esv = Es = 200000.00

1 = Asl,ten/(b*d)*(fs1/fc) = 0.09330282

2 = Asl,com/(b*d)*(fs2/fc) = 0.09330282

v = Asl,mid/(b*d)*(fsv/fc) = 0.05813483

and confined core properties:

b = 340.00

d = 228.00

d' = 12.00

fcc (5A.2, TBDY) = 33.00

$$cc \text{ (5A.5, TBDY)} = 0.002$$

$$c = \text{confinement factor} = 1.00$$

$$1 = A_{sl,ten}/(b*d)*(f_{s1}/f_c) = 0.12421118$$

$$2 = A_{sl,com}/(b*d)*(f_{s2}/f_c) = 0.12421118$$

$$v = A_{sl,mid}/(b*d)*(f_{sv}/f_c) = 0.07739312$$

Case/Assumption: Unconfined full section - Steel rupture
' satisfies Eq. (4.3)

--->

$v < v_{s,y2}$ - LHS eq.(4.5) is satisfied

--->

$$s_u \text{ (4.9)} = 0.22038892$$

$$M_u = M_{Rc} \text{ (4.14)} = 9.6940E+007$$

$$u = s_u \text{ (4.1)} = 2.5454950E-005$$

Calculation of ratio l_b/l_d

Inadequate Lap Length with $l_b/l_d = 0.30$

Calculation of M_{u1} -

Calculation of ultimate curvature u according to 4.1, Biskinis/Fardis 2013:

$$u = 2.5454950E-005$$

$$M_u = 9.6940E+007$$

with full section properties:

$$b = 400.00$$

$$d = 258.00$$

$$d' = 42.00$$

$$v = 5.6045447E-005$$

$$N = 190.8684$$

$$f_c = 33.00$$

$$cc \text{ (5A.5, TBDY)} = 0.002$$

$$\text{Final value of } cu: cu^* = \text{shear_factor} * \text{Max}(cu, cc) = 0.00553582$$

The Shear_factor is considered equal to 1 (pure moment strength)

$$\text{From (5.4b), TBDY: } cu = 0.00553582$$

$$w_e \text{ (5.4c)} = 0.00259035$$

$$a_{se} \text{ ((5.4d), TBDY)} = 0.15672608$$

$$b_o = 240.00$$

$$h_o = 340.00$$

$$b_{i2} = 346400.00$$

$$p_{sh,min} = \text{Min}(p_{sh,x}, p_{sh,y}) = 0.00261799$$

Expression ((5.4d), TBDY) for $p_{sh,min}$ has been multiplied by 0.3 according to 15.7.1.3 for members without earthquake detailing (90° closed stirrups)

$$p_{sh,x} \text{ (5.4d)} = 0.00349066$$

$$A_{sh} = A_{stir} * n_s = 78.53982$$

$$\text{No stirrups, } n_s = 2.00$$

$$b_k = 300.00$$

$$p_{sh,y} \text{ (5.4d)} = 0.00261799$$

$$A_{sh} = A_{stir} * n_s = 78.53982$$

$$\text{No stirrups, } n_s = 2.00$$

$$b_k = 400.00$$

$$s = 150.00$$

$$f_{ywe} = 694.45$$

$$f_{ce} = 33.00$$

$$\text{From ((5.A5), TBDY), TBDY: } cc = 0.002$$

$$c = \text{confinement factor} = 1.00$$

$$y_1 = 0.00140044$$

$$sh_1 = 0.0044814$$

$$ft_1 = 466.8167$$

$f_{y1} = 389.0139$
 $s_{u1} = 0.00512$
 using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
 and also multiplied by the shear_factor according to 15.7.1.4, with
 Shear_factor = 1.00
 $l_o/l_{ou,min} = l_b/l_d = 0.30$
 $s_{u1} = 0.4 * e_{su1,nominal} ((5.5), TBDY) = 0.032$
 From table 5A.1, TBDY: $e_{su1,nominal} = 0.08$,
 For calculation of $e_{su1,nominal}$ and y_1, sh_1, ft_1, f_{y1} , it is considered
 characteristic value $f_{sy1} = f_{s1}/1.2$, from table 5.1, TBDY.
 y_1, sh_1, ft_1, f_{y1} , are also multiplied by $\text{Min}(1, 1.25 * (l_b/l_d)^{2/3})$, from 10.3.5, ASCE 41-17.
 with $f_{s1} = f_s = 389.0139$
 with $E_{s1} = E_s = 200000.00$
 $y_2 = 0.00140044$
 $sh_2 = 0.0044814$
 $ft_2 = 466.8167$
 $f_{y2} = 389.0139$
 $s_{u2} = 0.00512$
 using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
 and also multiplied by the shear_factor according to 15.7.1.4, with
 Shear_factor = 1.00
 $l_o/l_{ou,min} = l_b/l_{b,min} = 0.30$
 $s_{u2} = 0.4 * e_{su2,nominal} ((5.5), TBDY) = 0.032$
 From table 5A.1, TBDY: $e_{su2,nominal} = 0.08$,
 For calculation of $e_{su2,nominal}$ and y_2, sh_2, ft_2, f_{y2} , it is considered
 characteristic value $f_{sy2} = f_{s2}/1.2$, from table 5.1, TBDY.
 y_2, sh_2, ft_2, f_{y2} , are also multiplied by $\text{Min}(1, 1.25 * (l_b/l_d)^{2/3})$, from 10.3.5, ASCE 41-17.
 with $f_{s2} = f_s = 389.0139$
 with $E_{s2} = E_s = 200000.00$
 $y_v = 0.00140044$
 $sh_v = 0.0044814$
 $ft_v = 466.8167$
 $f_{yv} = 389.0139$
 $s_{uv} = 0.00512$
 using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
 and also multiplied by the shear_factor according to 15.7.1.4, with
 Shear_factor = 1.00
 $l_o/l_{ou,min} = l_b/l_d = 0.30$
 $s_{uv} = 0.4 * e_{suv,nominal} ((5.5), TBDY) = 0.032$
 From table 5A.1, TBDY: $e_{suv,nominal} = 0.08$,
 considering characteristic value $f_{sv} = f_{sv}/1.2$, from table 5.1, TBDY
 For calculation of $e_{suv,nominal}$ and y_v, sh_v, ft_v, f_{yv} , it is considered
 characteristic value $f_{sv} = f_{sv}/1.2$, from table 5.1, TBDY.
 y_1, sh_1, ft_1, f_{y1} , are also multiplied by $\text{Min}(1, 1.25 * (l_b/l_d)^{2/3})$, from 10.3.5, ASCE 41-17.
 with $f_{sv} = f_s = 389.0139$
 with $E_{sv} = E_s = 200000.00$
 $1 = A_{sl,ten}/(b*d)*(f_{s1}/f_c) = 0.09330282$
 $2 = A_{sl,com}/(b*d)*(f_{s2}/f_c) = 0.09330282$
 $v = A_{sl,mid}/(b*d)*(f_{sv}/f_c) = 0.05813483$
 and confined core properties:
 $b = 340.00$
 $d = 228.00$
 $d' = 12.00$
 $f_{cc} (5A.2, TBDY) = 33.00$
 $cc (5A.5, TBDY) = 0.002$
 $c = \text{confinement factor} = 1.00$
 $1 = A_{sl,ten}/(b*d)*(f_{s1}/f_c) = 0.12421118$
 $2 = A_{sl,com}/(b*d)*(f_{s2}/f_c) = 0.12421118$
 $v = A_{sl,mid}/(b*d)*(f_{sv}/f_c) = 0.07739312$
 Case/Assumption: Unconfined full section - Steel rupture
 ' satisfies Eq. (4.3)
 --->
 $v < v_{s,y2}$ - LHS eq.(4.5) is satisfied
 --->
 $s_u (4.9) = 0.22038892$
 $M_u = M_{Rc} (4.14) = 9.6940E+007$
 $u = s_u (4.1) = 2.5454950E-005$

Calculation of ratio l_b/d

Inadequate Lap Length with $l_b/d = 0.30$

Calculation of μ_{2+}

Calculation of ultimate curvature μ according to 4.1, Biskinis/Fardis 2013:

$$\mu = 2.5454950E-005$$

$$\mu_{2+} = 9.6940E+007$$

with full section properties:

$$b = 400.00$$

$$d = 258.00$$

$$d' = 42.00$$

$$v = 5.6045447E-005$$

$$N = 190.8684$$

$$f_c = 33.00$$

$$c_o \text{ (5A.5, TBDY)} = 0.002$$

$$\text{Final value of } \mu_{cu}: \mu_{cu}^* = \text{shear_factor} * \text{Max}(\mu_{cu}, \mu_{cc}) = 0.00553582$$

The Shear_factor is considered equal to 1 (pure moment strength)

$$\text{From (5.4b), TBDY: } \mu_{cu} = 0.00553582$$

$$\mu_{we} \text{ (5.4c)} = 0.00259035$$

$$\mu_{ase} \text{ ((5.4d), TBDY)} = 0.15672608$$

$$b_o = 240.00$$

$$h_o = 340.00$$

$$b_{i2} = 346400.00$$

$$\mu_{psh,min} = \text{Min}(\mu_{psh,x}, \mu_{psh,y}) = 0.00261799$$

Expression ((5.4d), TBDY) for $\mu_{psh,min}$ has been multiplied by 0.3 according to 15.7.1.3 for members without earthquake detailing (90° closed stirrups)

$$\mu_{psh,x} \text{ (5.4d)} = 0.00349066$$

$$A_{sh} = A_{stir} * n_s = 78.53982$$

$$\text{No stirrups, } n_s = 2.00$$

$$b_k = 300.00$$

$$\mu_{psh,y} \text{ (5.4d)} = 0.00261799$$

$$A_{sh} = A_{stir} * n_s = 78.53982$$

$$\text{No stirrups, } n_s = 2.00$$

$$b_k = 400.00$$

$$s = 150.00$$

$$f_{ywe} = 694.45$$

$$f_{ce} = 33.00$$

$$\text{From ((5.A.5), TBDY), TBDY: } \mu_{cc} = 0.002$$

$$c = \text{confinement factor} = 1.00$$

$$y_1 = 0.00140044$$

$$sh_1 = 0.0044814$$

$$ft_1 = 466.8167$$

$$fy_1 = 389.0139$$

$$su_1 = 0.00512$$

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor and also multiplied by the shear_factor according to 15.7.1.4, with Shear_factor = 1.00

$$l_o/l_{o,min} = l_b/d = 0.30$$

$$\mu_{su_1} = 0.4 * \mu_{su_1,nominal} \text{ ((5.5), TBDY)} = 0.032$$

$$\text{From table 5A.1, TBDY: } \mu_{su_1,nominal} = 0.08,$$

For calculation of $\mu_{su_1,nominal}$ and y_1, sh_1, ft_1, fy_1 , it is considered characteristic value $f_{sy1} = f_{s1}/1.2$, from table 5.1, TBDY.

y_1, sh_1, ft_1, fy_1 , are also multiplied by $\text{Min}(1, 1.25 * (l_b/d)^{2/3})$, from 10.3.5, ASCE 41-17.

$$\text{with } f_{s1} = f_s = 389.0139$$

$$\text{with } E_{s1} = E_s = 200000.00$$

y2 = 0.00140044
sh2 = 0.0044814
ft2 = 466.8167
fy2 = 389.0139
su2 = 0.00512

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00

lo/lou,min = lb/lb,min = 0.30

su2 = 0.4*esu2_nominal ((5.5), TBDY) = 0.032

From table 5A.1, TBDY: esu2_nominal = 0.08,

For calculation of esu2_nominal and y2, sh2,ft2,fy2, it is considered
characteristic value fsy2 = fs2/1.2, from table 5.1, TBDY.

y1, sh1,ft1,fy1, are also multiplied by $\text{Min}(1, 1.25 \cdot (lb/ld)^{2/3})$, from 10.3.5, ASCE 41-17.

with fs2 = fs = 389.0139

with Es2 = Es = 200000.00

yv = 0.00140044
shv = 0.0044814

ftv = 466.8167

fyv = 389.0139

suv = 0.00512

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00

lo/lou,min = lb/ld = 0.30

suv = 0.4*esuv_nominal ((5.5), TBDY) = 0.032

From table 5A.1, TBDY: esuv_nominal = 0.08,

considering characteristic value fsyv = fsv/1.2, from table 5.1, TBDY

For calculation of esuv_nominal and yv, shv,ftv,fyv, it is considered
characteristic value fsyv = fsv/1.2, from table 5.1, TBDY.

y1, sh1,ft1,fy1, are also multiplied by $\text{Min}(1, 1.25 \cdot (lb/ld)^{2/3})$, from 10.3.5, ASCE 41-17.

with fsv = fs = 389.0139

with Esv = Es = 200000.00

1 = Asl,ten/(b*d)*(fs1/fc) = 0.09330282

2 = Asl,com/(b*d)*(fs2/fc) = 0.09330282

v = Asl,mid/(b*d)*(fsv/fc) = 0.05813483

and confined core properties:

b = 340.00

d = 228.00

d' = 12.00

fcc (5A.2, TBDY) = 33.00

cc (5A.5, TBDY) = 0.002

c = confinement factor = 1.00

1 = Asl,ten/(b*d)*(fs1/fc) = 0.12421118

2 = Asl,com/(b*d)*(fs2/fc) = 0.12421118

v = Asl,mid/(b*d)*(fsv/fc) = 0.07739312

Case/Assumption: Unconfined full section - Steel rupture

' satisfies Eq. (4.3)

v < vs,y2 - LHS eq.(4.5) is satisfied

su (4.9) = 0.22038892

Mu = MRc (4.14) = 9.6940E+007

u = su (4.1) = 2.5454950E-005

Calculation of ratio lb/ld

Inadequate Lap Length with lb/ld = 0.30

Calculation of Mu2-

Calculation of ultimate curvature u according to 4.1, Biskinis/Fardis 2013:

u = 2.5454950E-005
Mu = 9.6940E+007

with full section properties:

b = 400.00
d = 258.00
d' = 42.00
v = 5.6045447E-005
N = 190.8684
fc = 33.00
co (5A.5, TBDY) = 0.002
Final value of cu: $cu^* = \text{shear_factor} * \text{Max}(cu, cc) = 0.00553582$
The Shear_factor is considered equal to 1 (pure moment strength)
From (5.4b), TBDY: $cu = 0.00553582$
we (5.4c) = 0.00259035
ase ((5.4d), TBDY) = 0.15672608
bo = 240.00
ho = 340.00
bi2 = 346400.00
psh,min = $\text{Min}(\text{psh},x, \text{psh},y) = 0.00261799$
Expression ((5.4d), TBDY) for psh,min has been multiplied by 0.3 according to 15.7.1.3 for members without earthquake detailing (90° closed stirrups)

psh,x (5.4d) = 0.00349066
Ash = $\text{Astir} * ns = 78.53982$
No stirrups, ns = 2.00
bk = 300.00

psh,y (5.4d) = 0.00261799
Ash = $\text{Astir} * ns = 78.53982$
No stirrups, ns = 2.00
bk = 400.00

s = 150.00
fywe = 694.45
fce = 33.00
From ((5.A5), TBDY), TBDY: $cc = 0.002$
c = confinement factor = 1.00
y1 = 0.00140044
sh1 = 0.0044814
ft1 = 466.8167
fy1 = 389.0139
su1 = 0.00512

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00
 $lo/lou,min = lb/d = 0.30$
 $su1 = 0.4 * esu1_nominal ((5.5), TBDY) = 0.032$
From table 5A.1, TBDY: $esu1_nominal = 0.08$,
For calculation of $esu1_nominal$ and $y1, sh1, ft1, fy1$, it is considered
characteristic value $fsy1 = fs1/1.2$, from table 5.1, TBDY.
 $y1, sh1, ft1, fy1$, are also multiplied by $\text{Min}(1, 1.25 * (lb/d)^{2/3})$, from 10.3.5, ASCE 41-17.
with $fs1 = fs = 389.0139$
with $Es1 = Es = 200000.00$

y2 = 0.00140044
sh2 = 0.0044814
ft2 = 466.8167
fy2 = 389.0139
su2 = 0.00512

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00
 $lo/lou,min = lb/lb,min = 0.30$
 $su2 = 0.4 * esu2_nominal ((5.5), TBDY) = 0.032$
From table 5A.1, TBDY: $esu2_nominal = 0.08$,
For calculation of $esu2_nominal$ and $y2, sh2, ft2, fy2$, it is considered
characteristic value $fsy2 = fs2/1.2$, from table 5.1, TBDY.

y_1, sh_1, ft_1, fy_1 , are also multiplied by $\text{Min}(1, 1.25 \cdot (l_b/l_d)^{2/3})$, from 10.3.5, ASCE 41-17.

with $fs_2 = fs = 389.0139$

with $Es_2 = Es = 200000.00$

$y_v = 0.00140044$

$sh_v = 0.0044814$

$ft_v = 466.8167$

$fy_v = 389.0139$

$suv = 0.00512$

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor

and also multiplied by the shear_factor according to 15.7.1.4, with

Shear_factor = 1.00

$l_o/l_{o,min} = l_b/l_d = 0.30$

$suv = 0.4 \cdot esuv_{nominal} ((5.5), TBDY) = 0.032$

From table 5A.1, TBDY: $esuv_{nominal} = 0.08$,

considering characteristic value $fsyv = fsv/1.2$, from table 5.1, TBDY

For calculation of $esuv_{nominal}$ and y_v, sh_v, ft_v, fy_v , it is considered

characteristic value $fsyv = fsv/1.2$, from table 5.1, TBDY.

y_1, sh_1, ft_1, fy_1 , are also multiplied by $\text{Min}(1, 1.25 \cdot (l_b/l_d)^{2/3})$, from 10.3.5, ASCE 41-17.

with $fsv = fs = 389.0139$

with $Es_v = Es = 200000.00$

1 = $Asl_{ten}/(b \cdot d) \cdot (fs_1/fc) = 0.09330282$

2 = $Asl_{com}/(b \cdot d) \cdot (fs_2/fc) = 0.09330282$

v = $Asl_{mid}/(b \cdot d) \cdot (fsv/fc) = 0.05813483$

and confined core properties:

b = 340.00

d = 228.00

d' = 12.00

fcc (5A.2, TBDY) = 33.00

cc (5A.5, TBDY) = 0.002

c = confinement factor = 1.00

1 = $Asl_{ten}/(b \cdot d) \cdot (fs_1/fc) = 0.12421118$

2 = $Asl_{com}/(b \cdot d) \cdot (fs_2/fc) = 0.12421118$

v = $Asl_{mid}/(b \cdot d) \cdot (fsv/fc) = 0.07739312$

Case/Assumption: Unconfined full section - Steel rupture

' satisfies Eq. (4.3)

--->

$v < v_{s,y2}$ - LHS eq.(4.5) is satisfied

--->

su (4.9) = 0.22038892

Mu = MRc (4.14) = 9.6940E+007

u = su (4.1) = 2.5454950E-005

Calculation of ratio l_b/l_d

Inadequate Lap Length with $l_b/l_d = 0.30$

Calculation of Shear Strength $V_r = \text{Min}(V_{r1}, V_{r2}) = 192957.075$

Calculation of Shear Strength at edge 1, $V_{r1} = 192957.075$

$V_{r1} = V_n ((22.5.1.1), ACI 318-14)$

NOTE: In expression (22.5.1.1) 'Vw' is replaced by 'Vw+ f*Vf'
where Vf is the contribution of FRPs (11.3), ACI 440).

From Table (22.5.5.1), ACI 318-14: $V_c = 88236.482$

= 1 (normal-weight concrete)

$fc' = 33.00$, but $fc'^{0.5} \leq 8.3$ MPa (22.5.3.1, ACI 318-14)

$pw = As/(bw \cdot d) = 0.00949023$

As (tension reinf.) = 911.0619

bw = 400.00

d = 240.00

$V_u \cdot d / Mu < 1 = 0.00$

Mu = 3.3205266E-012

$$V_u = 4.9160836E-020$$

From (11.5.4.8), ACI 318-14: $V_s = 104720.593$

$$A_v = 157079.633$$

$$f_y = 555.56$$

$$s = 150.00$$

V_s has been multiplied by $2(1-s/d)$ ($s > d/2$, according to ASCE 41-17,10.3.4)

$$2(1-s/d) = 0.75$$

$$V_f ((11-3)-(11.4), ACI 440) = 0.00$$

$$\text{From (11-11), ACI 440: } V_s + V_f \leq 366348.956$$

Calculation of Shear Strength at edge 2, $V_{r2} = 192957.075$

$$V_{r2} = V_n ((22.5.1.1), ACI 318-14)$$

NOTE: In expression (22.5.1.1) ' V_w ' is replaced by ' $V_w + f \cdot V_f$ ' where V_f is the contribution of FRPs (11.3), ACI 440).

From Table (22.5.5.1), ACI 318-14: $V_c = 88236.482$

= 1 (normal-weight concrete)

$$f_c' = 33.00, \text{ but } f_c'^{0.5} \leq 8.3 \text{ MPa (22.5.3.1, ACI 318-14)}$$

$$p_w = A_s / (b_w \cdot d) = 0.00949023$$

$$A_s (\text{tension reinf.}) = 911.0619$$

$$b_w = 400.00$$

$$d = 240.00$$

$$V_u \cdot d / M_u < 1 = 0.00$$

$$M_u = 3.3203395E-012$$

$$V_u = 4.9160836E-020$$

From (11.5.4.8), ACI 318-14: $V_s = 104720.593$

$$A_v = 157079.633$$

$$f_y = 555.56$$

$$s = 150.00$$

V_s has been multiplied by $2(1-s/d)$ ($s > d/2$, according to ASCE 41-17,10.3.4)

$$2(1-s/d) = 0.75$$

$$V_f ((11-3)-(11.4), ACI 440) = 0.00$$

$$\text{From (11-11), ACI 440: } V_s + V_f \leq 366348.956$$

End Of Calculation of Shear Capacity ratio for element: beam B1 of floor 1

At local axis: 2

Start Of Calculation of Chord Rotation Capacity for element: beam B1 of floor 1

At local axis: 2

Integration Section: (b)

Section Type: rcars

Constant Properties

Knowledge Factor, = 1.00

Chord Rotation is generally considered as Deformation-Controlled Action according to Table C7-1, ASCE 41-17.

Mean strengths are used for Deformation-Controlled Actions according to 7.5.1.3, ASCE 41-17

Consequently:

New material of Secondary Member: Concrete Strength, $f_c = f_{cm} = 33.00$

New material of Secondary Member: Steel Strength, $f_s = f_{sm} = 555.56$

Concrete Elasticity, $E_c = 26999.444$

Steel Elasticity, $E_s = 200000.00$

Section Height, $H = 400.00$

Section Width, $W = 300.00$

Cover Thickness, $c = 25.00$

Element Length, $L = 1850.00$

Secondary Member

Smooth Bars

Ductile Steel

Without Detailing for Earthquake Resistance (including stirrups not closed at 135°)

Longitudinal Bars With Ends Lapped Starting at the End Sections

Inadequate Lap Length with $l_b / l_d = 0.30$

No FRP Wrapping

Stepwise Properties

Bending Moment, $M = 6.9545E+006$
Shear Force, $V2 = -5.3543557E-014$
Shear Force, $V3 = 10227.447$
Axial Force, $F = -613.7698$
Longitudinal Reinforcement Area Distribution (in 2 divisions)
-Tension: $As_t = 923.6282$
-Compression: $As_c = 1218.938$
Longitudinal Reinforcement Area Distribution (in 3 divisions)
-Tension: $As_{t,ten} = 923.6282$
-Compression: $As_{c,com} = 603.1858$
-Middle: $As_{c,mid} = 615.7522$
Mean Diameter of Tension Reinforcement, $Db_L = 14.00$

New component: From table 7-7, ASCE 41_17: Final chord rotation Capacity $u_{,R} = 1.0^*$ $u = 0.00692376$
 $u = y + p = 0.00692376$

- Calculation of y -

$y = (M_y * L_s / 3) / E_{eff} = 0.00192376$ ((4.29), Biskinis Phd)
 $M_y = 1.0999E+008$
 $L_s = M/V$ (with $L_s > 0.1 * L$ and $L_s < 2 * L$) = 679.9831
From table 10.5, ASCE 41_17: $E_{eff} = 0.3 * E_c * I_g = 1.2960E+013$

Calculation of Yielding Moment M_y

Calculation of y and M_y according to Annex 7 -

$y = \text{Min}(y_{ten}, y_{com})$
 $y_{ten} = 6.2738091E-006$
with ((10.1), ASCE 41-17) $f_y = \text{Min}(f_y, 1.25 * f_y * (l_b/d)^{2/3}) = 311.2112$
 $d = 358.00$
 $y = 0.3071953$
 $A = 0.01996777$
 $B = 0.01250378$
with $p_t = 0.00859989$
 $p_c = 0.00561626$
 $p_v = 0.00573326$
 $N = 613.7698$
 $b = 300.00$
 $" = 0.12011173$
 $y_{comp} = 2.0014058E-005$
with $f_c = 33.00$
 $E_c = 26999.444$
 $y = 0.30705307$
 $A = 0.01993642$
 $B = 0.01248541$
with $E_s = 200000.00$

Calculation of ratio l_b/d

Inadequate Lap Length with $l_b/d = 0.30$

- Calculation of p -

From table 10-7: $p = 0.005$

with:

- Condition iv occurred
Beam controlled by inadequate embedment into beam-column joint:
($l_b/d < 1$ and With Lapping in the Vicinity of the End Regions)
- Condition i occurred
Beam controlled by flexure: $V_p/V_o \leq 1$
shear control ratio $V_p/V_o = 0.59550037$
- Transverse Reinforcement: NC
- Stirrup Spacing $> d/3$
- Low ductility demand, $\lambda / y < 2$ (table 10-6, ASCE 41-17)
 $= 2.7669270E-005$
- Stirrup Spacing $\leq d/2$
 $d = 358.00$
 $s = 150.00$
- Strength provided by hoops $V_s < 3/4 \cdot \text{design Shear}$
 $V_s = 186169.943$, already given in calculation of shear control ratio
design Shear = 10227.447
- ($\rho' - \rho$)/ bal = -0.16136132
 $= A_{st}/(b_w \cdot d) = 0.00859989$
Tension Reinf Area: $A_{st} = 923.6282$
 $\rho' = A_{sc}/(b_w \cdot d) = 0.01134952$
Compression Reinf Area: $A_{sc} = 1218.938$
- From (B-1), ACI 318-11: bal = 0.01704017
 $f_c = 33.00$
 $f_y = 555.56$
From 10.2.7.3, ACI 318-11: $\lambda = 1 = 0.65$
From fig R10.3.3, ACI 318-11 (Ence 454, too): $87000/(87000 + f_y) = c_b/d_t = 0.003/(0.003 + \lambda) = 0.51922877$
 $y = 0.0027778$
- $V/(b_w \cdot d \cdot f_c^{0.5}) = 0.19963157$, NOTE: units in lb & in
 $b_w = 300.00$

End Of Calculation of Chord Rotation Capacity for element: beam B1 of floor 1

At local axis: 2

Integration Section: (b)

Calculation No. 7

beam B1, Floor 1



Limit State: Operational Level (data interpolation between analysis steps 1 and 2)

Analysis: Uniform +X

Check: Shear capacity V_{Rd}

Edge: End

Local Axis: (3)



Start Of Calculation of Shear Capacity for element: beam B1 of floor 1

At local axis: 3

Integration Section: (b)

Section Type: rcars

Constant Properties

Knowledge Factor, $\gamma = 1.00$

Member Shear Force is generally considered as Force-Controlled Action according to Table C7-1, ASCE 41-17.

Lower-bound strengths are used for Force-Controlled Actions according to 7.5.1.3, ASCE 41-17

Consequently:

New material of Secondary Member: Concrete Strength, $f_c = f_{c_lower_bound} = 25.00$

New material of Secondary Member: Steel Strength, $f_s = f_{s_lower_bound} = 500.00$

Concrete Elasticity, $E_c = 26999.444$

Steel Elasticity, $E_s = 200000.00$

Section Height, $H = 400.00$

Section Width, $W = 300.00$

Cover Thickness, $c = 25.00$

Element Length, $L = 1850.00$

Secondary Member

Smooth Bars

Ductile Steel

Without Detailing for Earthquake Resistance (including stirrups not closed at 135°)

Longitudinal Bars With Ends Lapped Starting at the End Sections

Inadequate Lap Length with $l_o/l_{o,min} = l_b/l_d = 0.30$

No FRP Wrapping

Stepwise Properties

EDGE -A-

Bending Moment, $M_a = 6.8399E+006$

Shear Force, $V_a = -4685.405$

EDGE -B-

Bending Moment, $M_b = 6.9545E+006$

Shear Force, $V_b = 10227.447$

BOTH EDGES

Axial Force, $F = -613.7698$

Longitudinal Reinforcement Area Distribution (in 2 divisions)

-Tension: $A_{sl,t} = 923.6282$

-Compression: $A_{sl,c} = 1218.938$

Longitudinal Reinforcement Area Distribution (in 3 divisions)

-Tension: $A_{sl,ten} = 923.6282$

-Compression: $A_{sl,com} = 603.1858$

-Middle: $A_{sl,mid} = 615.7522$

Mean Diameter of Tension Reinforcement, $Db_{L,ten} = 14.00$

New component: From table 7-7, ASCE 41_17: Final Shear Capacity $VR = 1.0 \cdot V_n = 251740.817$

V_n ((22.5.1.1), ACI 318-14) = 251740.817

NOTE: In expression (22.5.1.1) 'Vw' is replaced by 'Vw+ f*Vf' where Vf is the contribution of FRPs (11.3), ACI 440).

From Table (22.5.5.1), ACI 318-14: $V_c = 84189.209$
= 1 (normal-weight concrete)
 $f'_c = 25.00$, but $f'_c^{0.5} \leq 8.3$ MPa (22.5.3.1, ACI 318-14)
 $\rho_w = A_s/(b_w*d) = 0.00962113$
 A_s (tension reinf.) = 923.6282
 $b_w = 300.00$
 $d = 320.00$
 $V_u*d/\mu_u < 1 = 0.4705999$
 $\mu_u = 6.9545E+006$
 $V_u = 10227.447$

From (11.5.4.8), ACI 318-14: $V_s = 167551.608$
 $A_v = 157079.633$
 $f_y = 500.00$
 $s = 150.00$

V_s has been multiplied by 1 ($s < d/2$, according to ASCE 41-17,10.3.4)

V_f ((11-3)-(11.4), ACI 440) = 0.00

From (11-11), ACI 440: $V_s + V_f \leq 318865.838$

End Of Calculation of Shear Capacity for element: beam B1 of floor 1

At local axis: 3

Integration Section: (b)

Calculation No. 8

beam B1, Floor 1



Limit State: Operational Level (data interpolation between analysis steps 1 and 2)

Analysis: Uniform +X

Check: Chord rotation capacity (μ)

Edge: End

Local Axis: (3)



Start Of Calculation of Shear Capacity ratio for element: beam B1 of floor 1

At Shear local axis: 3

(Bending local axis: 2)

Section Type: rcars

Constant Properties

Knowledge Factor, $\gamma = 1.00$

Mean strength values are used for both shear and moment calculations.

Consequently:

New material of Secondary Member: Concrete Strength, $f_c = f_{cm} = 33.00$

New material of Secondary Member: Steel Strength, $f_s = f_{sm} = 555.56$

Concrete Elasticity, $E_c = 26999.444$

Steel Elasticity, $E_s = 200000.00$

#####

Note: Especially for the calculation of moment strengths,

the above steel re-bar strengths are multiplied by 1.25 according to R18.6.5, ACI 318-14

New material: Steel Strength, $f_s = 1.25 \cdot f_{sm} = 694.45$

#####

Section Height, $H = 400.00$

Section Width, $W = 300.00$

Cover Thickness, $c = 25.00$

Mean Confinement Factor overall section = 1.00

Element Length, $L = 1850.00$

Secondary Member

Smooth Bars

Ductile Steel

Without Detailing for Earthquake Resistance (including stirrups not closed at 135°)

Longitudinal Bars With Ends Lapped Starting at the End Sections

Inadequate Lap Length with $l_o/l_{o,min} = 0.30$

No FRP Wrapping

Stepwise Properties

At local axis: 3

EDGE -A-

Shear Force, $V_a = 2771.021$

EDGE -B-

Shear Force, $V_b = 2771.021$

BOTH EDGES

Axial Force, $F = -190.8684$

Longitudinal Reinforcement Area Distribution (in 2 divisions)

-Tension: $A_{sl,t} = 911.0619$

-Compression: $A_{sl,c} = 1231.504$

Longitudinal Reinforcement Area Distribution (in 3 divisions)

-Tension: $A_{sl,ten} = 603.1858$

-Compression: $A_{sl,com} = 923.6282$

-Middle: $A_{sl,mid} = 615.7522$

Calculation of Shear Capacity ratio, $V_e/V_r = 0.59550037$

Member Controlled by Flexure ($V_e/V_r < 1$)

Calculation of Shear Demand from fig. R18.6.5, ACI 318-14 $V_e = (M_{pr1} + M_{pr2})/l_n \pm w_u \cdot l_n/2 = 172632.267$

with

$M_{pr1} = \text{Max}(M_{u1+}, M_{u1-}) = 1.5721E+008$

$M_{u1+} = 1.1233E+008$, is the ultimate moment strength at the edge 1 of the member in the actual moment direction which is defined for the static loading combination

$M_{u1-} = 1.5721E+008$, is the ultimate moment strength at the edge 1 of the member in the opposite moment direction which is defined for the static loading combination

$M_{pr2} = \text{Max}(M_{u2+}, M_{u2-}) = 1.5703E+008$

$M_{u2+} = 1.1247E+008$, is the ultimate moment strength at the edge 2 of the member in the actual moment direction which is defined for the the static loading combination

$M_{u2-} = 1.5703E+008$, is the ultimate moment strength at the edge 2 of the member in the opposite moment direction which is defined for the the static loading combination

and

$\pm w_u \cdot l_n = (|V_1| + |V_2|)/2$

with

V1 = 2771.021, is the shear force acting at edge 1 for the the static loading combination
V2 = 2771.021, is the shear force acting at edge 2 for the the static loading combination

Calculation of Mu1+

Calculation of ultimate curvature μ according to 4.1, Biskinis/Fardis 2013:

$$u = 1.7687265E-005$$

$$Mu = 1.1233E+008$$

with full section properties:

$$b = 300.00$$

$$d = 357.00$$

$$d' = 42.00$$

$$v = 5.4004576E-005$$

$$N = 190.8684$$

$$f_c = 33.00$$

$$c_o \text{ (5A.5, TBDY)} = 0.002$$

$$\text{Final value of } c_u: c_u^* = \text{shear_factor} * \text{Max}(c_u, c_c) = 0.00553582$$

The Shear_factor is considered equal to 1 (pure moment strength)

$$\text{From (5.4b), TBDY: } c_u = 0.00553582$$

$$w_e \text{ (5.4c)} = 0.00259035$$

$$a_{se} \text{ ((5.4d), TBDY)} = 0.15672608$$

$$b_o = 240.00$$

$$h_o = 340.00$$

$$b_{i2} = 346400.00$$

$$p_{sh,min} = \text{Min}(p_{sh,x}, p_{sh,y}) = 0.00261799$$

Expression ((5.4d), TBDY) for $p_{sh,min}$ has been multiplied by 0.3 according to 15.7.1.3 for members without earthquake detailing (90° closed stirrups)

$$p_{sh,x} \text{ (5.4d)} = 0.00349066$$

$$A_{sh} = A_{stir} * n_s = 78.53982$$

$$\text{No stirrups, } n_s = 2.00$$

$$b_k = 300.00$$

$$p_{sh,y} \text{ (5.4d)} = 0.00261799$$

$$A_{sh} = A_{stir} * n_s = 78.53982$$

$$\text{No stirrups, } n_s = 2.00$$

$$b_k = 400.00$$

$$s = 150.00$$

$$f_{ywe} = 694.45$$

$$f_{ce} = 33.00$$

$$\text{From ((5.A5), TBDY), TBDY: } c_c = 0.002$$

$$c = \text{confinement factor} = 1.00$$

$$y_1 = 0.00140044$$

$$sh_1 = 0.0044814$$

$$ft_1 = 466.8167$$

$$fy_1 = 389.0139$$

$$su_1 = 0.00512$$

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00

$$l_o/l_{ou,min} = l_b/l_d = 0.30$$

$$su_1 = 0.4 * esu_{1,nominal} \text{ ((5.5), TBDY)} = 0.032$$

$$\text{From table 5A.1, TBDY: } esu_{1,nominal} = 0.08,$$

For calculation of $esu_{1,nominal}$ and y_1, sh_1, ft_1, fy_1 , it is considered
characteristic value $fsy_1 = fs_1/1.2$, from table 5.1, TBDY.

$$y_1, sh_1, ft_1, fy_1, \text{ are also multiplied by } \text{Min}(1, 1.25 * (l_b/l_d)^{2/3}), \text{ from 10.3.5, ASCE 41-17.}$$

$$\text{with } fs_1 = fs = 389.0139$$

$$\text{with } Es_1 = Es = 200000.00$$

$$y_2 = 0.00140044$$

$$sh_2 = 0.0044814$$

$$ft_2 = 466.8167$$

$$fy_2 = 389.0139$$

$$su_2 = 0.00512$$

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor and also multiplied by the shear_factor according to 15.7.1.4, with Shear_factor = 1.00

$$l_o/l_{o,min} = l_b/l_{b,min} = 0.30$$

$$su_2 = 0.4 * esu_{2,nominal} ((5.5), TBDY) = 0.032$$

From table 5A.1, TBDY: $esu_{2,nominal} = 0.08$,

For calculation of $esu_{2,nominal}$ and y_2, sh_2, ft_2, fy_2 , it is considered characteristic value $fsy_2 = fs_2/1.2$, from table 5.1, TBDY.

y_1, sh_1, ft_1, fy_1 , are also multiplied by $\text{Min}(1, 1.25 * (l_b/l_d)^{2/3})$, from 10.3.5, ASCE 41-17.

$$\text{with } fs_2 = fs = 389.0139$$

$$\text{with } Es_2 = Es = 200000.00$$

$$yv = 0.00140044$$

$$shv = 0.0044814$$

$$ftv = 466.8167$$

$$fyv = 389.0139$$

$$suv = 0.00512$$

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor and also multiplied by the shear_factor according to 15.7.1.4, with Shear_factor = 1.00

$$l_o/l_{o,min} = l_b/l_d = 0.30$$

$$suv = 0.4 * esuv_{nominal} ((5.5), TBDY) = 0.032$$

From table 5A.1, TBDY: $esuv_{nominal} = 0.08$,

considering characteristic value $fsyv = fsv/1.2$, from table 5.1, TBDY

For calculation of $esuv_{nominal}$ and yv, shv, ftv, fyv , it is considered characteristic value $fsyv = fsv/1.2$, from table 5.1, TBDY.

y_1, sh_1, ft_1, fy_1 , are also multiplied by $\text{Min}(1, 1.25 * (l_b/l_d)^{2/3})$, from 10.3.5, ASCE 41-17.

$$\text{with } fsv = fs = 389.0139$$

$$\text{with } Esv = Es = 200000.00$$

$$1 = A_{sl,ten}/(b*d) * (fs_1/f_c) = 0.06639156$$

$$2 = A_{sl,com}/(b*d) * (fs_2/f_c) = 0.10166207$$

$$v = A_{sl,mid}/(b*d) * (fsv/f_c) = 0.06777471$$

and confined core properties:

$$b = 240.00$$

$$d = 327.00$$

$$d' = 12.00$$

$$fcc (5A.2, TBDY) = 33.00$$

$$cc (5A.5, TBDY) = 0.002$$

$$c = \text{confinement factor} = 1.00$$

$$1 = A_{sl,ten}/(b*d) * (fs_1/f_c) = 0.09060316$$

$$2 = A_{sl,com}/(b*d) * (fs_2/f_c) = 0.13873608$$

$$v = A_{sl,mid}/(b*d) * (fsv/f_c) = 0.09249072$$

Case/Assumption: Unconfined full section - Steel rupture
' satisfies Eq. (4.3)

--->

$v < v_{s,y2}$ - LHS eq.(4.5) is satisfied

--->

$$su (4.9) = 0.189149$$

$$Mu = MRc (4.14) = 1.1233E+008$$

$$u = su (4.1) = 1.7687265E-005$$

Calculation of ratio l_b/l_d

Inadequate Lap Length with $l_b/l_d = 0.30$

Calculation of Mu_1 -

Calculation of ultimate curvature u according to 4.1, Biskinis/Fardis 2013:

$$u = 1.8434312E-005$$

$$Mu = 1.5721E+008$$

with full section properties:

b = 300.00
d = 358.00
d' = 43.00
v = 5.3853726E-005
N = 190.8684

fc = 33.00
co (5A.5, TBDY) = 0.002

Final value of cu: $cu^* = \text{shear_factor} * \text{Max}(cu, cc) = 0.00553582$
The Shear_factor is considered equal to 1 (pure moment strength)

From (5.4b), TBDY: $cu = 0.00553582$

we (5.4c) = 0.00259035

ase ((5.4d), TBDY) = 0.15672608

bo = 240.00

ho = 340.00

bi2 = 346400.00

psh,min = Min(psh,x , psh,y) = 0.00261799

Expression ((5.4d), TBDY) for psh,min has been multiplied by 0.3 according to 15.7.1.3 for members without earthquake detailing (90° closed stirrups)

psh,x (5.4d) = 0.00349066

Ash = Astir*ns = 78.53982

No stirrups, ns = 2.00

bk = 300.00

psh,y (5.4d) = 0.00261799

Ash = Astir*ns = 78.53982

No stirrups, ns = 2.00

bk = 400.00

s = 150.00

fywe = 694.45

fce = 33.00

From ((5.A5), TBDY), TBDY: $cc = 0.002$

c = confinement factor = 1.00

y1 = 0.00140044

sh1 = 0.0044814

ft1 = 466.8167

fy1 = 389.0139

su1 = 0.00512

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00

lo/lou,min = lb/d = 0.30

su1 = $0.4 * \text{esu1_nominal} ((5.5), \text{TBDY}) = 0.032$

From table 5A.1, TBDY: $\text{esu1_nominal} = 0.08$,

For calculation of esu1_nominal and y1, sh1,ft1,fy1, it is considered
characteristic value $\text{fsy1} = \text{fs1}/1.2$, from table 5.1, TBDY.

y1, sh1,ft1,fy1, are also multiplied by $\text{Min}(1, 1.25 * (\text{lb}/\text{d})^{2/3})$, from 10.3.5, ASCE 41-17.

with $\text{fs1} = \text{fs} = 389.0139$

with $\text{Es1} = \text{Es} = 200000.00$

y2 = 0.00140044

sh2 = 0.0044814

ft2 = 466.8167

fy2 = 389.0139

su2 = 0.00512

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00

lo/lou,min = lb/lb,min = 0.30

su2 = $0.4 * \text{esu2_nominal} ((5.5), \text{TBDY}) = 0.032$

From table 5A.1, TBDY: $\text{esu2_nominal} = 0.08$,

For calculation of esu2_nominal and y2, sh2,ft2,fy2, it is considered
characteristic value $\text{fsy2} = \text{fs2}/1.2$, from table 5.1, TBDY.

y1, sh1,ft1,fy1, are also multiplied by $\text{Min}(1, 1.25 * (\text{lb}/\text{d})^{2/3})$, from 10.3.5, ASCE 41-17.

with $\text{fs2} = \text{fs} = 389.0139$

with $\text{Es2} = \text{Es} = 200000.00$

yv = 0.00140044

$$shv = 0.0044814$$

$$ftv = 466.8167$$

$$fyv = 389.0139$$

$$suv = 0.00512$$

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00

$$lo/lo_{u,min} = lb/ld = 0.30$$

$$suv = 0.4 * esuv_{nominal} ((5.5), TBDY) = 0.032$$

From table 5A.1, TBDY: $esuv_{nominal} = 0.08$,

considering characteristic value $fsyv = fsv/1.2$, from table 5.1, TBDY

For calculation of $esuv_{nominal}$ and yv , shv,ftv,fyv , it is considered
characteristic value $fsyv = fsv/1.2$, from table 5.1, TBDY.

$y1, sh1,ft1,fy1$, are also multiplied by $\text{Min}(1, 1.25 * (lb/ld)^{2/3})$, from 10.3.5, ASCE 41-17.

$$\text{with } fsv = fs = 389.0139$$

$$\text{with } Es = Es = 200000.00$$

$$1 = Asl_{ten}/(b*d)*(fs1/fc) = 0.1013781$$

$$2 = Asl_{com}/(b*d)*(fs2/fc) = 0.06620611$$

$$v = Asl_{mid}/(b*d)*(fsv/fc) = 0.0675854$$

and confined core properties:

$$b = 240.00$$

$$d = 328.00$$

$$d' = 13.00$$

$$fcc (5A.2, TBDY) = 33.00$$

$$cc (5A.5, TBDY) = 0.002$$

$$c = \text{confinement factor} = 1.00$$

$$1 = Asl_{ten}/(b*d)*(fs1/fc) = 0.13831311$$

$$2 = Asl_{com}/(b*d)*(fs2/fc) = 0.09032693$$

$$v = Asl_{mid}/(b*d)*(fsv/fc) = 0.09220874$$

Case/Assumption: Unconfined full section - Steel rupture

' satisfies Eq. (4.3)

$v < vs,y2$ - LHS eq.(4.5) is satisfied

$$su (4.9) = 0.22418173$$

$$Mu = MRc (4.14) = 1.5721E+008$$

$$u = su (4.1) = 1.8434312E-005$$

Calculation of ratio lb/ld

Inadequate Lap Length with $lb/ld = 0.30$

Calculation of Mu_{2+}

Calculation of ultimate curvature u according to 4.1, Biskinis/Fardis 2013:

$$u = 1.7651391E-005$$

$$Mu = 1.1247E+008$$

with full section properties:

$$b = 300.00$$

$$d = 358.00$$

$$d' = 43.00$$

$$v = 5.3853726E-005$$

$$N = 190.8684$$

$$fc = 33.00$$

$$co (5A.5, TBDY) = 0.002$$

$$\text{Final value of } cu: cu^* = \text{shear_factor} * \text{Max}(cu, cc) = 0.00553582$$

The Shear_factor is considered equal to 1 (pure moment strength)

$$\text{From (5.4b), TBDY: } cu = 0.00553582$$

$$we (5.4c) = 0.00259035$$

$$ase ((5.4d), TBDY) = 0.15672608$$

$$bo = 240.00$$

ho = 340.00

bi2 = 346400.00

psh,min = Min(psh,x , psh,y) = 0.00261799

Expression ((5.4d), TBDY) for psh,min has been multiplied by 0.3 according to 15.7.1.3 for members without earthquake detailing (90° closed stirrups)

psh,x (5.4d) = 0.00349066

Ash = Astir*ns = 78.53982

No stirups, ns = 2.00

bk = 300.00

psh,y (5.4d) = 0.00261799

Ash = Astir*ns = 78.53982

No stirups, ns = 2.00

bk = 400.00

s = 150.00

fywe = 694.45

fce = 33.00

From ((5.A5), TBDY), TBDY: cc = 0.002

c = confinement factor = 1.00

y1 = 0.00140044

sh1 = 0.0044814

ft1 = 466.8167

fy1 = 389.0139

su1 = 0.00512

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00

lo/lou,min = lb/lb = 0.30

su1 = 0.4*esu1_nominal ((5.5), TBDY) = 0.032

From table 5A.1, TBDY: esu1_nominal = 0.08,

For calculation of esu1_nominal and y1, sh1,ft1,fy1, it is considered
characteristic value fsy1 = fs/1.2, from table 5.1, TBDY.

y1, sh1,ft1,fy1, are also multiplied by Min(1,1.25*(lb/lb)^2/3), from 10.3.5, ASCE 41-17.

with fs1 = fs = 389.0139

with Es1 = Es = 200000.00

y2 = 0.00140044

sh2 = 0.0044814

ft2 = 466.8167

fy2 = 389.0139

su2 = 0.00512

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00

lo/lou,min = lb/lb,min = 0.30

su2 = 0.4*esu2_nominal ((5.5), TBDY) = 0.032

From table 5A.1, TBDY: esu2_nominal = 0.08,

For calculation of esu2_nominal and y2, sh2,ft2,fy2, it is considered
characteristic value fsy2 = fs/1.2, from table 5.1, TBDY.

y1, sh1,ft1,fy1, are also multiplied by Min(1,1.25*(lb/lb)^2/3), from 10.3.5, ASCE 41-17.

with fs2 = fs = 389.0139

with Es2 = Es = 200000.00

yv = 0.00140044

shv = 0.0044814

ftv = 466.8167

fyv = 389.0139

suv = 0.00512

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00

lo/lou,min = lb/lb = 0.30

suv = 0.4*esuv_nominal ((5.5), TBDY) = 0.032

From table 5A.1, TBDY: esuv_nominal = 0.08,

considering characteristic value fsyv = fsv/1.2, from table 5.1, TBDY

For calculation of esuv_nominal and yv, shv,ftv,fyv, it is considered
characteristic value fsyv = fsv/1.2, from table 5.1, TBDY.

y_1, sh_1, ft_1, fy_1 , are also multiplied by $\text{Min}(1, 1.25 \cdot (lb/d)^{2/3})$, from 10.3.5, ASCE 41-17.

with $f_{sv} = f_s = 389.0139$

with $E_{sv} = E_s = 200000.00$

$1 = A_{sl,ten}/(b \cdot d) \cdot (f_{s1}/f_c) = 0.06620611$

$2 = A_{sl,com}/(b \cdot d) \cdot (f_{s2}/f_c) = 0.1013781$

$v = A_{sl,mid}/(b \cdot d) \cdot (f_{sv}/f_c) = 0.0675854$

and confined core properties:

$b = 240.00$

$d = 328.00$

$d' = 13.00$

$f_{cc} \text{ (5A.2, TBDY)} = 33.00$

$cc \text{ (5A.5, TBDY)} = 0.002$

$c = \text{confinement factor} = 1.00$

$1 = A_{sl,ten}/(b \cdot d) \cdot (f_{s1}/f_c) = 0.09032693$

$2 = A_{sl,com}/(b \cdot d) \cdot (f_{s2}/f_c) = 0.13831311$

$v = A_{sl,mid}/(b \cdot d) \cdot (f_{sv}/f_c) = 0.09220874$

Case/Assumption: Unconfined full section - Steel rupture

' satisfies Eq. (4.3)

--->

$v < v_{s,y2}$ - LHS eq.(4.5) is satisfied

--->

$su \text{ (4.9)} = 0.18977061$

$Mu = MRc \text{ (4.14)} = 1.1247E+008$

$u = su \text{ (4.1)} = 1.7651391E-005$

Calculation of ratio lb/d

Inadequate Lap Length with $lb/d = 0.30$

Calculation of Mu_2 -

Calculation of ultimate curvature u according to 4.1, Biskinis/Fardis 2013:

$u = 1.8476637E-005$

$Mu = 1.5703E+008$

with full section properties:

$b = 300.00$

$d = 357.00$

$d' = 42.00$

$v = 5.4004576E-005$

$N = 190.8684$

$f_c = 33.00$

$co \text{ (5A.5, TBDY)} = 0.002$

Final value of cu : $cu^* = \text{shear_factor} \cdot \text{Max}(cu, cc) = 0.00553582$

The Shear_factor is considered equal to 1 (pure moment strength)

From (5.4b), TBDY: $cu = 0.00553582$

$w_e \text{ (5.4c)} = 0.00259035$

$a_{se} \text{ ((5.4d), TBDY)} = 0.15672608$

$bo = 240.00$

$ho = 340.00$

$bi_2 = 346400.00$

$psh_{,min} = \text{Min}(psh_x, psh_y) = 0.00261799$

Expression ((5.4d), TBDY) for $psh_{,min}$ has been multiplied by 0.3 according to 15.7.1.3 for members without earthquake detailing (90° closed stirrups)

 $psh_x \text{ (5.4d)} = 0.00349066$

$A_{sh} = A_{stir} \cdot ns = 78.53982$

No stirrups, $ns = 2.00$

$bk = 300.00$

$psh_y \text{ (5.4d)} = 0.00261799$

$A_{sh} = A_{stir} \cdot ns = 78.53982$

No stirrups, ns = 2.00
bk = 400.00

s = 150.00
fywe = 694.45
fce = 33.00

From ((5.A.5), TBDY), TBDY: cc = 0.002
c = confinement factor = 1.00

y1 = 0.00140044
sh1 = 0.0044814
ft1 = 466.8167
fy1 = 389.0139
su1 = 0.00512

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00

lo/lou,min = lb/lb = 0.30

su1 = 0.4*esu1_nominal ((5.5), TBDY) = 0.032

From table 5A.1, TBDY: esu1_nominal = 0.08,

For calculation of esu1_nominal and y1, sh1,ft1,fy1, it is considered
characteristic value fsy1 = fs1/1.2, from table 5.1, TBDY.

y1, sh1,ft1,fy1, are also multiplied by $\text{Min}(1, 1.25 \cdot (lb/lb)^{2/3})$, from 10.3.5, ASCE 41-17.

with fs1 = fs = 389.0139

with Es1 = Es = 200000.00

y2 = 0.00140044
sh2 = 0.0044814
ft2 = 466.8167
fy2 = 389.0139
su2 = 0.00512

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00

lo/lou,min = lb/lb,min = 0.30

su2 = 0.4*esu2_nominal ((5.5), TBDY) = 0.032

From table 5A.1, TBDY: esu2_nominal = 0.08,

For calculation of esu2_nominal and y2, sh2,ft2,fy2, it is considered
characteristic value fsy2 = fs2/1.2, from table 5.1, TBDY.

y1, sh1,ft1,fy1, are also multiplied by $\text{Min}(1, 1.25 \cdot (lb/lb)^{2/3})$, from 10.3.5, ASCE 41-17.

with fs2 = fs = 389.0139

with Es2 = Es = 200000.00

yv = 0.00140044
shv = 0.0044814
ftv = 466.8167
fyv = 389.0139
suv = 0.00512

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00

lo/lou,min = lb/lb = 0.30

suv = 0.4*esuv_nominal ((5.5), TBDY) = 0.032

From table 5A.1, TBDY: esuv_nominal = 0.08,

considering characteristic value fsyv = fsv/1.2, from table 5.1, TBDY

For calculation of esuv_nominal and yv, shv,ftv,fyv, it is considered
characteristic value fsyv = fsv/1.2, from table 5.1, TBDY.

y1, sh1,ft1,fy1, are also multiplied by $\text{Min}(1, 1.25 \cdot (lb/lb)^{2/3})$, from 10.3.5, ASCE 41-17.

with fsv = fs = 389.0139

with Esv = Es = 200000.00

1 = Asl,ten/(b*d)*(fs1/fc) = 0.10166207

2 = Asl,com/(b*d)*(fs2/fc) = 0.06639156

v = Asl,mid/(b*d)*(fsv/fc) = 0.06777471

and confined core properties:

b = 240.00
d = 327.00
d' = 12.00

fcc (5A.2, TBDY) = 33.00

cc (5A.5, TBDY) = 0.002

c = confinement factor = 1.00

$$1 = A_{s1,ten}/(b*d)*(f_{s1}/f_c) = 0.13873608$$

$$2 = A_{s1,com}/(b*d)*(f_{s2}/f_c) = 0.09060316$$

$$v = A_{s1,mid}/(b*d)*(f_{sv}/f_c) = 0.09249072$$

Case/Assumption: Unconfined full section - Steel rupture
' satisfies Eq. (4.3)

---->

$v < v_{s,y2}$ - LHS eq.(4.5) is satisfied

---->

$$s_u(4.9) = 0.22379076$$

$$\mu_u = M_{Rc}(4.14) = 1.5703E+008$$

$$u = s_u(4.1) = 1.8476637E-005$$

Calculation of ratio l_b/l_d

Inadequate Lap Length with $l_b/l_d = 0.30$

Calculation of Shear Strength $V_r = \text{Min}(V_{r1}, V_{r2}) = 289894.477$

Calculation of Shear Strength at edge 1, $V_{r1} = 289894.477$

$V_{r1} = V_n$ ((22.5.1.1), ACI 318-14)

NOTE: In expression (22.5.1.1) 'Vw' is replaced by 'Vw + f*Vf'
where Vf is the contribution of FRPs (11.3), ACI 440).

From Table (22.5.5.1), ACI 318-14: $V_c = 103724.534$

= 1 (normal-weight concrete)

$f'_c = 33.00$, but $f_c^{0.5} \leq 8.3$ MPa (22.5.3.1, ACI 318-14)

$\rho_w = A_s/(b_w*d) = 0.00949023$

A_s (tension reinf.) = 911.0619

$b_w = 300.00$

$d = 320.00$

$V_u*d/\mu_u < 1 = 1.00$

$\mu_u = 71267.116$

$V_u = 2771.021$

From (11.5.4.8), ACI 318-14: $V_s = 186169.943$

$A_v = 157079.633$

$f_y = 555.56$

$s = 150.00$

V_s has been multiplied by 1 ($s < d/2$, according to ASCE 41-17,10.3.4)

V_f ((11-3)-(11.4), ACI 440) = 0.00

From (11-11), ACI 440: $V_s + V_f \leq 366348.956$

Calculation of Shear Strength at edge 2, $V_{r2} = 289894.477$

$V_{r2} = V_n$ ((22.5.1.1), ACI 318-14)

NOTE: In expression (22.5.1.1) 'Vw' is replaced by 'Vw + f*Vf'
where Vf is the contribution of FRPs (11.3), ACI 440).

From Table (22.5.5.1), ACI 318-14: $V_c = 103724.534$

= 1 (normal-weight concrete)

$f'_c = 33.00$, but $f_c^{0.5} \leq 8.3$ MPa (22.5.3.1, ACI 318-14)

$\rho_w = A_s/(b_w*d) = 0.00949023$

A_s (tension reinf.) = 911.0619

$b_w = 300.00$

$d = 320.00$

$V_u*d/\mu_u < 1 = 1.00$

$\mu_u = 71267.116$

$V_u = 2771.021$

From (11.5.4.8), ACI 318-14: $V_s = 186169.943$

$A_v = 157079.633$

$f_y = 555.56$

$s = 150.00$

V_s has been multiplied by 1 ($s < d/2$, according to ASCE 41-17,10.3.4)

Vf ((11-3)-(11.4), ACI 440) = 0.00
From (11-11), ACI 440: Vs + Vf <= 366348.956

End Of Calculation of Shear Capacity ratio for element: beam B1 of floor 1
At local axis: 3

Start Of Calculation of Shear Capacity ratio for element: beam B1 of floor 1
At Shear local axis: 2
(Bending local axis: 3)
Section Type: rcars

Constant Properties

Knowledge Factor, = 1.00
Mean strength values are used for both shear and moment calculations.
Consequently:
New material of Secondary Member: Concrete Strength, fc = fcm = 33.00
New material of Secondary Member: Steel Strength, fs = fsm = 555.56
Concrete Elasticity, Ec = 26999.444
Steel Elasticity, Es = 200000.00

Note: Especially for the calculation of moment strengths,
the above steel re-bar strengths are multiplied by 1.25 according to R18.6.5, ACI 318-14
New material: Steel Strength, fs = 1.25*fsm = 694.45

Section Height, H = 400.00
Section Width, W = 300.00
Cover Thickness, c = 25.00
Mean Confinement Factor overall section = 1.00
Element Length, L = 1850.00
Secondary Member
Smooth Bars
Ductile Steel
Without Detailing for Earthquake Resistance (including stirrups not closed at 135°)
Longitudinal Bars With Ends Lapped Starting at the End Sections
Inadequate Lap Length with lo/lo,min = 0.30
No FRP Wrapping

Stepwise Properties

At local axis: 2
EDGE -A-
Shear Force, Va = 4.9160836E-020
EDGE -B-
Shear Force, Vb = -4.9160836E-020
BOTH EDGES
Axial Force, F = -190.8684
Longitudinal Reinforcement Area Distribution (in 2 divisions)
-Tension: Aslt = 911.0619
-Compression: Aslc = 1231.504
Longitudinal Reinforcement Area Distribution (in 3 divisions)
-Tension: Asl,ten = 816.8141
-Compression: Asl,com = 816.8141
-Middle: Asl,mid = 508.938

Calculation of Shear Capacity ratio , Ve/Vr = 0.54312483
Member Controlled by Flexure (Ve/Vr < 1)
Calculation of Shear Demand from fig. R18.6.5, ACI 318-14 Ve = (Mpr1 + Mpr2)/ln ± wu*ln/2 = 104799.778
with
Mpr1 = Max(Mu1+ , Mu1-) = 9.6940E+007

$Mu_{1+} = 9.6940E+007$, is the ultimate moment strength at the edge 1 of the member in the actual moment direction which is defined for the static loading combination

$Mu_{1-} = 9.6940E+007$, is the ultimate moment strength at the edge 1 of the member in the opposite moment direction which is defined for the static loading combination

$Mpr2 = \text{Max}(Mu_{2+}, Mu_{2-}) = 9.6940E+007$

$Mu_{2+} = 9.6940E+007$, is the ultimate moment strength at the edge 2 of the member in the actual moment direction which is defined for the the static loading combination

$Mu_{2-} = 9.6940E+007$, is the ultimate moment strength at the edge 2 of the member in the opposite moment direction which is defined for the the static loading combination

and

$\pm wu*ln = (|V1| + |V2|)/2$

with

$V1 = 4.9160836E-020$, is the shear force acting at edge 1 for the the static loading combination

$V2 = -4.9160836E-020$, is the shear force acting at edge 2 for the the static loading combination

Calculation of Mu_{1+}

Calculation of ultimate curvature u according to 4.1, Biskinis/Fardis 2013:

$u = 2.5454950E-005$

$Mu = 9.6940E+007$

with full section properties:

$b = 400.00$

$d = 258.00$

$d' = 42.00$

$v = 5.6045447E-005$

$N = 190.8684$

$fc = 33.00$

co (5A.5, TBDY) = 0.002

Final value of cu : $cu^* = \text{shear_factor} * \text{Max}(cu, cc) = 0.00553582$

The Shear_factor is considered equal to 1 (pure moment strength)

From (5.4b), TBDY: $cu = 0.00553582$

w_e (5.4c) = 0.00259035

a_{se} ((5.4d), TBDY) = 0.15672608

$bo = 240.00$

$ho = 340.00$

$bi^2 = 346400.00$

$psh, \min = \text{Min}(psh, x, psh, y) = 0.00261799$

Expression ((5.4d), TBDY) for psh, \min has been multiplied by 0.3 according to 15.7.1.3 for members without earthquake detailing (90° closed stirrups)

 psh, x (5.4d) = 0.00349066

$A_{sh} = A_{stir} * n_s = 78.53982$

No stirrups, $n_s = 2.00$

$b_k = 300.00$

psh, y (5.4d) = 0.00261799

$A_{sh} = A_{stir} * n_s = 78.53982$

No stirrups, $n_s = 2.00$

$b_k = 400.00$

$s = 150.00$

$fy_{we} = 694.45$

$f_{ce} = 33.00$

From ((5.A5), TBDY), TBDY: $cc = 0.002$

c = confinement factor = 1.00

$y_1 = 0.00140044$

$sh_1 = 0.0044814$

$ft_1 = 466.8167$

$fy_1 = 389.0139$

$su_1 = 0.00512$

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor

and also multiplied by the shear_factor according to 15.7.1.4, with

Shear_factor = 1.00

$$l_o/l_{o,min} = l_b/l_d = 0.30$$

$$s_u1 = 0.4 * e_{s1_nominal} ((5.5), TBDY) = 0.032$$

From table 5A.1, TBDY: $e_{s1_nominal} = 0.08$,

For calculation of $e_{s1_nominal}$ and y_1, sh_1, ft_1, fy_1 , it is considered characteristic value $f_{sy1} = f_{s1}/1.2$, from table 5.1, TBDY.

y_1, sh_1, ft_1, fy_1 , are also multiplied by $\text{Min}(1, 1.25 * (l_b/l_d)^{2/3})$, from 10.3.5, ASCE 41-17.

$$\text{with } f_{s1} = f_s = 389.0139$$

$$\text{with } E_{s1} = E_s = 200000.00$$

$$y_2 = 0.00140044$$

$$sh_2 = 0.0044814$$

$$ft_2 = 466.8167$$

$$fy_2 = 389.0139$$

$$s_u2 = 0.00512$$

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor

and also multiplied by the shear_factor according to 15.7.1.4, with

Shear_factor = 1.00

$$l_o/l_{o,min} = l_b/l_{b,min} = 0.30$$

$$s_u2 = 0.4 * e_{s2_nominal} ((5.5), TBDY) = 0.032$$

From table 5A.1, TBDY: $e_{s2_nominal} = 0.08$,

For calculation of $e_{s2_nominal}$ and y_2, sh_2, ft_2, fy_2 , it is considered characteristic value $f_{sy2} = f_{s2}/1.2$, from table 5.1, TBDY.

y_2, sh_2, ft_2, fy_2 , are also multiplied by $\text{Min}(1, 1.25 * (l_b/l_d)^{2/3})$, from 10.3.5, ASCE 41-17.

$$\text{with } f_{s2} = f_s = 389.0139$$

$$\text{with } E_{s2} = E_s = 200000.00$$

$$y_v = 0.00140044$$

$$sh_v = 0.0044814$$

$$ft_v = 466.8167$$

$$fy_v = 389.0139$$

$$s_{u,v} = 0.00512$$

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor

and also multiplied by the shear_factor according to 15.7.1.4, with

Shear_factor = 1.00

$$l_o/l_{o,min} = l_b/l_d = 0.30$$

$$s_{u,v} = 0.4 * e_{s_{u,v}_nominal} ((5.5), TBDY) = 0.032$$

From table 5A.1, TBDY: $e_{s_{u,v}_nominal} = 0.08$,

considering characteristic value $f_{s_{y,v}} = f_{s_{v}}/1.2$, from table 5.1, TBDY

For calculation of $e_{s_{u,v}_nominal}$ and y_v, sh_v, ft_v, fy_v , it is considered

characteristic value $f_{s_{y,v}} = f_{s_{v}}/1.2$, from table 5.1, TBDY.

y_1, sh_1, ft_1, fy_1 , are also multiplied by $\text{Min}(1, 1.25 * (l_b/l_d)^{2/3})$, from 10.3.5, ASCE 41-17.

$$\text{with } f_{s_{v}} = f_s = 389.0139$$

$$\text{with } E_{s_{v}} = E_s = 200000.00$$

$$1 = A_{s1,ten}/(b*d) * (f_{s1}/f_c) = 0.09330282$$

$$2 = A_{s1,com}/(b*d) * (f_{s2}/f_c) = 0.09330282$$

$$v = A_{s1,mid}/(b*d) * (f_{s_{v}}/f_c) = 0.05813483$$

and confined core properties:

$$b = 340.00$$

$$d = 228.00$$

$$d' = 12.00$$

$$f_{cc} (5A.2, TBDY) = 33.00$$

$$c_c (5A.5, TBDY) = 0.002$$

$$c = \text{confinement factor} = 1.00$$

$$1 = A_{s1,ten}/(b*d) * (f_{s1}/f_c) = 0.12421118$$

$$2 = A_{s1,com}/(b*d) * (f_{s2}/f_c) = 0.12421118$$

$$v = A_{s1,mid}/(b*d) * (f_{s_{v}}/f_c) = 0.07739312$$

Case/Assumption: Unconfined full section - Steel rupture

' satisfies Eq. (4.3)

--->

$v < v_{s,y2}$ - LHS eq.(4.5) is satisfied

--->

$$s_u (4.9) = 0.22038892$$

$$\mu = M_{Rc} (4.14) = 9.6940E+007$$

$$u = s_u (4.1) = 2.5454950E-005$$

Calculation of ratio l_b/l_d

Inadequate Lap Length with $l_b/l_d = 0.30$

Calculation of Mu1-

Calculation of ultimate curvature μ according to 4.1, Biskinis/Fardis 2013:

$$u = 2.5454950E-005$$

$$Mu = 9.6940E+007$$

with full section properties:

$$b = 400.00$$

$$d = 258.00$$

$$d' = 42.00$$

$$v = 5.6045447E-005$$

$$N = 190.8684$$

$$f_c = 33.00$$

$$c_o \text{ (5A.5, TBDY)} = 0.002$$

$$\text{Final value of } c_u: c_u^* = \text{shear_factor} * \text{Max}(c_u, c_c) = 0.00553582$$

The Shear_factor is considered equal to 1 (pure moment strength)

$$\text{From (5.4b), TBDY: } c_u = 0.00553582$$

$$w_e \text{ (5.4c)} = 0.00259035$$

$$a_{se} \text{ ((5.4d), TBDY)} = 0.15672608$$

$$b_o = 240.00$$

$$h_o = 340.00$$

$$b_{i2} = 346400.00$$

$$p_{sh,min} = \text{Min}(p_{sh,x}, p_{sh,y}) = 0.00261799$$

Expression ((5.4d), TBDY) for $p_{sh,min}$ has been multiplied by 0.3 according to 15.7.1.3 for members without earthquake detailing (90° closed stirrups)

$$p_{sh,x} \text{ (5.4d)} = 0.00349066$$

$$A_{sh} = A_{stir} * n_s = 78.53982$$

$$\text{No stirrups, } n_s = 2.00$$

$$b_k = 300.00$$

$$p_{sh,y} \text{ (5.4d)} = 0.00261799$$

$$A_{sh} = A_{stir} * n_s = 78.53982$$

$$\text{No stirrups, } n_s = 2.00$$

$$b_k = 400.00$$

$$s = 150.00$$

$$f_{ywe} = 694.45$$

$$f_{ce} = 33.00$$

$$\text{From ((5.A5), TBDY), TBDY: } c_c = 0.002$$

$$c = \text{confinement factor} = 1.00$$

$$y_1 = 0.00140044$$

$$sh_1 = 0.0044814$$

$$ft_1 = 466.8167$$

$$fy_1 = 389.0139$$

$$su_1 = 0.00512$$

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor and also multiplied by the shear_factor according to 15.7.1.4, with Shear_factor = 1.00

$$l_o/l_{o,min} = l_b/d = 0.30$$

$$su_1 = 0.4 * esu_1_{nominal} \text{ ((5.5), TBDY)} = 0.032$$

$$\text{From table 5A.1, TBDY: } esu_1_{nominal} = 0.08,$$

For calculation of $esu_1_{nominal}$ and y_1, sh_1, ft_1, fy_1 , it is considered characteristic value $fsy_1 = fs_1/1.2$, from table 5.1, TBDY.

$$y_1, sh_1, ft_1, fy_1, \text{ are also multiplied by } \text{Min}(1, 1.25 * (l_b/d)^{2/3}), \text{ from 10.3.5, ASCE 41-17.}$$

$$\text{with } fs_1 = fs = 389.0139$$

$$\text{with } Es_1 = Es = 200000.00$$

$$y_2 = 0.00140044$$

$$sh_2 = 0.0044814$$

$$ft_2 = 466.8167$$

$$fy_2 = 389.0139$$

$$su_2 = 0.00512$$

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00

lo/lou,min = lb/lb,min = 0.30

su2 = 0.4*esu2_nominal ((5.5), TBDY) = 0.032

From table 5A.1, TBDY: esu2_nominal = 0.08,

For calculation of esu2_nominal and y2, sh2,ft2,fy2, it is considered
characteristic value fsy2 = fs2/1.2, from table 5.1, TBDY.

y1, sh1,ft1,fy1, are also multiplied by $\text{Min}(1, 1.25 \cdot (lb/ld)^{2/3})$, from 10.3.5, ASCE 41-17.

with fs2 = fs = 389.0139

with Es2 = Es = 200000.00

yv = 0.00140044

shv = 0.0044814

ftv = 466.8167

fyv = 389.0139

suv = 0.00512

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00

lo/lou,min = lb/ld = 0.30

suv = 0.4*esuv_nominal ((5.5), TBDY) = 0.032

From table 5A.1, TBDY: esuv_nominal = 0.08,

considering characteristic value fsyv = fsv/1.2, from table 5.1, TBDY

For calculation of esuv_nominal and yv, shv,ftv,fyv, it is considered
characteristic value fsyv = fsv/1.2, from table 5.1, TBDY.

y1, sh1,ft1,fy1, are also multiplied by $\text{Min}(1, 1.25 \cdot (lb/ld)^{2/3})$, from 10.3.5, ASCE 41-17.

with fsv = fs = 389.0139

with Esv = Es = 200000.00

1 = Asl,ten/(b*d)*(fs1/fc) = 0.09330282

2 = Asl,com/(b*d)*(fs2/fc) = 0.09330282

v = Asl,mid/(b*d)*(fsv/fc) = 0.05813483

and confined core properties:

b = 340.00

d = 228.00

d' = 12.00

fcc (5A.2, TBDY) = 33.00

cc (5A.5, TBDY) = 0.002

c = confinement factor = 1.00

1 = Asl,ten/(b*d)*(fs1/fc) = 0.12421118

2 = Asl,com/(b*d)*(fs2/fc) = 0.12421118

v = Asl,mid/(b*d)*(fsv/fc) = 0.07739312

Case/Assumption: Unconfined full section - Steel rupture

' satisfies Eq. (4.3)

--->

v < vs,y2 - LHS eq.(4.5) is satisfied

--->

su (4.9) = 0.22038892

Mu = MRc (4.14) = 9.6940E+007

u = su (4.1) = 2.5454950E-005

Calculation of ratio lb/ld

Inadequate Lap Length with lb/ld = 0.30

Calculation of Mu2+

Calculation of ultimate curvature u according to 4.1, Biskinis/Fardis 2013:

u = 2.5454950E-005

Mu = 9.6940E+007

with full section properties:

b = 400.00

d = 258.00
d' = 42.00
v = 5.6045447E-005
N = 190.8684
fc = 33.00

co (5A.5, TBDY) = 0.002

Final value of cu: $cu^* = \text{shear_factor} * \text{Max}(cu, cc) = 0.00553582$

The Shear_factor is considered equal to 1 (pure moment strength)

From (5.4b), TBDY: $cu = 0.00553582$

we (5.4c) = 0.00259035

ase ((5.4d), TBDY) = 0.15672608

bo = 240.00

ho = 340.00

bi2 = 346400.00

psh,min = Min(psh,x , psh,y) = 0.00261799

Expression ((5.4d), TBDY) for psh,min has been multiplied by 0.3 according to 15.7.1.3 for members without earthquake detailing (90° closed stirrups)

psh,x (5.4d) = 0.00349066

Ash = Astir*ns = 78.53982

No stirrups, ns = 2.00

bk = 300.00

psh,y (5.4d) = 0.00261799

Ash = Astir*ns = 78.53982

No stirrups, ns = 2.00

bk = 400.00

s = 150.00

fywe = 694.45

fce = 33.00

From ((5.A5), TBDY), TBDY: $cc = 0.002$

c = confinement factor = 1.00

y1 = 0.00140044

sh1 = 0.0044814

ft1 = 466.8167

fy1 = 389.0139

su1 = 0.00512

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor and also multiplied by the shear_factor according to 15.7.1.4, with Shear_factor = 1.00

lo/lou,min = lb/lb,min = 0.30

su1 = $0.4 * \text{esu1_nominal} ((5.5), \text{TBDY}) = 0.032$

From table 5A.1, TBDY: $\text{esu1_nominal} = 0.08$,

For calculation of esu1_nominal and y1, sh1,ft1,fy1, it is considered characteristic value $\text{fsy1} = \text{fs1}/1.2$, from table 5.1, TBDY.

y1, sh1,ft1,fy1, are also multiplied by $\text{Min}(1, 1.25 * (\text{lb}/\text{ld})^{2/3})$, from 10.3.5, ASCE 41-17.

with $\text{fs1} = \text{fs} = 389.0139$

with $\text{Es1} = \text{Es} = 200000.00$

y2 = 0.00140044

sh2 = 0.0044814

ft2 = 466.8167

fy2 = 389.0139

su2 = 0.00512

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor and also multiplied by the shear_factor according to 15.7.1.4, with Shear_factor = 1.00

lo/lou,min = lb/lb,min = 0.30

su2 = $0.4 * \text{esu2_nominal} ((5.5), \text{TBDY}) = 0.032$

From table 5A.1, TBDY: $\text{esu2_nominal} = 0.08$,

For calculation of esu2_nominal and y2, sh2,ft2,fy2, it is considered characteristic value $\text{fsy2} = \text{fs2}/1.2$, from table 5.1, TBDY.

y1, sh1,ft1,fy1, are also multiplied by $\text{Min}(1, 1.25 * (\text{lb}/\text{ld})^{2/3})$, from 10.3.5, ASCE 41-17.

with $\text{fs2} = \text{fs} = 389.0139$

with $\text{Es2} = \text{Es} = 200000.00$

yv = 0.00140044

shv = 0.0044814

$$ftv = 466.8167$$

$$fyv = 389.0139$$

$$suv = 0.00512$$

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00

$$lo/lo_{u,min} = lb/d = 0.30$$

$$suv = 0.4 * esuv_{nominal} ((5.5), TBDY) = 0.032$$

From table 5A.1, TBDY: $esuv_{nominal} = 0.08$,

considering characteristic value $fsyv = fsv/1.2$, from table 5.1, TBDY

For calculation of $esuv_{nominal}$ and yv , shv , ftv , fyv , it is considered
characteristic value $fsyv = fsv/1.2$, from table 5.1, TBDY.

$y1$, $sh1$, $ft1$, $fy1$, are also multiplied by $\text{Min}(1, 1.25 * (lb/d)^{2/3})$, from 10.3.5, ASCE 41-17.

$$\text{with } fsv = fs = 389.0139$$

$$\text{with } Es = Es = 200000.00$$

$$1 = Asl_{ten}/(b*d)*(fs1/fc) = 0.09330282$$

$$2 = Asl_{com}/(b*d)*(fs2/fc) = 0.09330282$$

$$v = Asl_{mid}/(b*d)*(fsv/fc) = 0.05813483$$

and confined core properties:

$$b = 340.00$$

$$d = 228.00$$

$$d' = 12.00$$

$$fcc (5A.2, TBDY) = 33.00$$

$$cc (5A.5, TBDY) = 0.002$$

$$c = \text{confinement factor} = 1.00$$

$$1 = Asl_{ten}/(b*d)*(fs1/fc) = 0.12421118$$

$$2 = Asl_{com}/(b*d)*(fs2/fc) = 0.12421118$$

$$v = Asl_{mid}/(b*d)*(fsv/fc) = 0.07739312$$

Case/Assumption: Unconfined full section - Steel rupture

' satisfies Eq. (4.3)

$v < vs, y2$ - LHS eq.(4.5) is satisfied

$$su (4.9) = 0.22038892$$

$$Mu = MRc (4.14) = 9.6940E+007$$

$$u = su (4.1) = 2.5454950E-005$$

Calculation of ratio lb/d

Inadequate Lap Length with $lb/d = 0.30$

Calculation of $Mu2$ -

Calculation of ultimate curvature u according to 4.1, Biskinis/Fardis 2013:

$$u = 2.5454950E-005$$

$$Mu = 9.6940E+007$$

with full section properties:

$$b = 400.00$$

$$d = 258.00$$

$$d' = 42.00$$

$$v = 5.6045447E-005$$

$$N = 190.8684$$

$$fc = 33.00$$

$$co (5A.5, TBDY) = 0.002$$

$$\text{Final value of } cu: cu^* = \text{shear_factor} * \text{Max}(cu, cc) = 0.00553582$$

The Shear_factor is considered equal to 1 (pure moment strength)

$$\text{From (5.4b), TBDY: } cu = 0.00553582$$

$$we (5.4c) = 0.00259035$$

$$ase ((5.4d), TBDY) = 0.15672608$$

$$bo = 240.00$$

$$ho = 340.00$$

$$bi2 = 346400.00$$

$$psh,min = \text{Min}(psh,x, psh,y) = 0.00261799$$

Expression ((5.4d), TBDY) for psh,min has been multiplied by 0.3 according to 15.7.1.3 for members without earthquake detailing (90° closed stirrups)

$$psh,x (5.4d) = 0.00349066$$

$$Ash = Astir*ns = 78.53982$$

$$\text{No stirrups, } ns = 2.00$$

$$bk = 300.00$$

$$psh,y (5.4d) = 0.00261799$$

$$Ash = Astir*ns = 78.53982$$

$$\text{No stirrups, } ns = 2.00$$

$$bk = 400.00$$

$$s = 150.00$$

$$fywe = 694.45$$

$$fce = 33.00$$

From ((5.A5), TBDY), TBDY: $cc = 0.002$

$c = \text{confinement factor} = 1.00$

$$y1 = 0.00140044$$

$$sh1 = 0.0044814$$

$$ft1 = 466.8167$$

$$fy1 = 389.0139$$

$$su1 = 0.00512$$

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor and also multiplied by the shear_factor according to 15.7.1.4, with Shear_factor = 1.00

$$lo/lou,min = lb/l_d = 0.30$$

$$su1 = 0.4*esu1_nominal ((5.5), TBDY) = 0.032$$

From table 5A.1, TBDY: $esu1_nominal = 0.08$,

For calculation of $esu1_nominal$ and $y1, sh1, ft1, fy1$, it is considered characteristic value $fsy1 = fs1/1.2$, from table 5.1, TBDY.

$y1, sh1, ft1, fy1$, are also multiplied by $\text{Min}(1, 1.25*(lb/l_d)^{2/3})$, from 10.3.5, ASCE 41-17.

$$\text{with } fs1 = fs = 389.0139$$

$$\text{with } Es1 = Es = 200000.00$$

$$y2 = 0.00140044$$

$$sh2 = 0.0044814$$

$$ft2 = 466.8167$$

$$fy2 = 389.0139$$

$$su2 = 0.00512$$

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor and also multiplied by the shear_factor according to 15.7.1.4, with Shear_factor = 1.00

$$lo/lou,min = lb/l_{b,min} = 0.30$$

$$su2 = 0.4*esu2_nominal ((5.5), TBDY) = 0.032$$

From table 5A.1, TBDY: $esu2_nominal = 0.08$,

For calculation of $esu2_nominal$ and $y2, sh2, ft2, fy2$, it is considered characteristic value $fsy2 = fs2/1.2$, from table 5.1, TBDY.

$y2, sh2, ft2, fy2$, are also multiplied by $\text{Min}(1, 1.25*(lb/l_d)^{2/3})$, from 10.3.5, ASCE 41-17.

$$\text{with } fs2 = fs = 389.0139$$

$$\text{with } Es2 = Es = 200000.00$$

$$yv = 0.00140044$$

$$shv = 0.0044814$$

$$ftv = 466.8167$$

$$fyv = 389.0139$$

$$suv = 0.00512$$

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor and also multiplied by the shear_factor according to 15.7.1.4, with Shear_factor = 1.00

$$lo/lou,min = lb/l_d = 0.30$$

$$suv = 0.4*esuv_nominal ((5.5), TBDY) = 0.032$$

From table 5A.1, TBDY: $esuv_nominal = 0.08$,

considering characteristic value $fsyv = fsv/1.2$, from table 5.1, TBDY
For calculation of $esuv_nominal$ and yv, shv, ftv, fyv , it is considered

characteristic value $fsyv = fsv/1.2$, from table 5.1, TBDY.

$y1, sh1, ft1, fy1$, are also multiplied by $\text{Min}(1, 1.25*(lb/l_d)^{2/3})$, from 10.3.5, ASCE 41-17.

with $f_{sv} = f_s = 389.0139$

with $E_{sv} = E_s = 200000.00$

$1 = A_{s1,ten}/(b*d)*(f_{s1}/f_c) = 0.09330282$

$2 = A_{s1,com}/(b*d)*(f_{s2}/f_c) = 0.09330282$

$v = A_{s1,mid}/(b*d)*(f_{sv}/f_c) = 0.05813483$

and confined core properties:

$b = 340.00$

$d = 228.00$

$d' = 12.00$

$f_{cc} (5A.2, TBDY) = 33.00$

$cc (5A.5, TBDY) = 0.002$

$c = \text{confinement factor} = 1.00$

$1 = A_{s1,ten}/(b*d)*(f_{s1}/f_c) = 0.12421118$

$2 = A_{s1,com}/(b*d)*(f_{s2}/f_c) = 0.12421118$

$v = A_{s1,mid}/(b*d)*(f_{sv}/f_c) = 0.07739312$

Case/Assumption: Unconfined full section - Steel rupture

' satisfies Eq. (4.3)

--->

$v < v_{s,y2}$ - LHS eq.(4.5) is satisfied

--->

$su (4.9) = 0.22038892$

$Mu = MRc (4.14) = 9.6940E+007$

$u = su (4.1) = 2.5454950E-005$

Calculation of ratio l_b/d

Inadequate Lap Length with $l_b/d = 0.30$

Calculation of Shear Strength $V_r = \text{Min}(V_{r1}, V_{r2}) = 192957.075$

Calculation of Shear Strength at edge 1, $V_{r1} = 192957.075$

$V_{r1} = V_n ((22.5.1.1), ACI 318-14)$

NOTE: In expression (22.5.1.1) ' V_w ' is replaced by ' $V_w + f*V_f$ '
where V_f is the contribution of FRPs (11.3), ACI 440).

From Table (22.5.5.1), ACI 318-14: $V_c = 88236.482$

= 1 (normal-weight concrete)

$f_c' = 33.00$, but $f_c'^{0.5} \leq 8.3$ MPa (22.5.3.1, ACI 318-14)

$p_w = A_s/(b_w*d) = 0.00949023$

A_s (tension reinf.) = 911.0619

$b_w = 400.00$

$d = 240.00$

$V_u*d/Mu < 1 = 0.00$

$Mu = 3.3205266E-012$

$V_u = 4.9160836E-020$

From (11.5.4.8), ACI 318-14: $V_s = 104720.593$

$A_v = 157079.633$

$f_y = 555.56$

$s = 150.00$

V_s has been multiplied by $2(1-s/d)$ ($s > d/2$, according to ASCE 41-17, 10.3.4)

$2(1-s/d) = 0.75$

$V_f ((11-3)-(11.4), ACI 440) = 0.00$

From (11-11), ACI 440: $V_s + V_f \leq 366348.956$

Calculation of Shear Strength at edge 2, $V_{r2} = 192957.075$

$V_{r2} = V_n ((22.5.1.1), ACI 318-14)$

NOTE: In expression (22.5.1.1) ' V_w ' is replaced by ' $V_w + f*V_f$ '
where V_f is the contribution of FRPs (11.3), ACI 440).

From Table (22.5.5.1), ACI 318-14: $V_c = 88236.482$

= 1 (normal-weight concrete)

$f_c' = 33.00$, but $f_c'^{0.5} \leq 8.3$ MPa (22.5.3.1, ACI 318-14)

$\rho_w = A_s/(b_w \cdot d) = 0.00949023$

A_s (tension reinf.) = 911.0619

$b_w = 400.00$

$d = 240.00$

$V_u \cdot d / \mu_u < 1 = 0.00$

$\mu_u = 3.3203395E-012$

$V_u = 4.9160836E-020$

From (11.5.4.8), ACI 318-14: $V_s = 104720.593$

$A_v = 157079.633$

$f_y = 555.56$

$s = 150.00$

V_s has been multiplied by $2(1-s/d)$ ($s > d/2$, according to ASCE 41-17, 10.3.4)

$2(1-s/d) = 0.75$

V_f ((11-3)-(11.4), ACI 440) = 0.00

From (11-11), ACI 440: $V_s + V_f \leq 366348.956$

End Of Calculation of Shear Capacity ratio for element: beam B1 of floor 1

At local axis: 2

Start Of Calculation of Chord Rotation Capacity for element: beam B1 of floor 1

At local axis: 3

Integration Section: (b)

Section Type: rcars

Constant Properties

Knowledge Factor, $\gamma = 1.00$

Chord Rotation is generally considered as Deformation-Controlled Action according to Table C7-1, ASCE 41-17.

Mean strengths are used for Deformation-Controlled Actions according to 7.5.1.3, ASCE 41-17

Consequently:

New material of Secondary Member: Concrete Strength, $f_c = f_{cm} = 33.00$

New material of Secondary Member: Steel Strength, $f_s = f_{sm} = 555.56$

Concrete Elasticity, $E_c = 26999.444$

Steel Elasticity, $E_s = 200000.00$

Section Height, $H = 400.00$

Section Width, $W = 300.00$

Cover Thickness, $c = 25.00$

Element Length, $L = 1850.00$

Secondary Member

Smooth Bars

Ductile Steel

Without Detailing for Earthquake Resistance (including stirrups not closed at 135°)

Longitudinal Bars With Ends Lapped Starting at the End Sections

Inadequate Lap Length with $l_b/l_d = 0.30$

No FRP Wrapping

Stepwise Properties

Bending Moment, $M = 6.8346901E-011$

Shear Force, $V_2 = -5.3543557E-014$

Shear Force, $V_3 = 10227.447$

Axial Force, $F = -613.7698$

Longitudinal Reinforcement Area Distribution (in 2 divisions)

-Tension: $A_{st} = 923.6282$

-Compression: $A_{sc} = 1218.938$

Longitudinal Reinforcement Area Distribution (in 3 divisions)

-Tension: $A_{st,ten} = 816.8141$

-Compression: $A_{sc,com} = 816.8141$

-Middle: $A_{st,mid} = 508.938$

Mean Diameter of Tension Reinforcement, $DbL = 14.40$

New component: From table 7-7, ASCE 41_17: Final chord rotation Capacity $u_{,R} = 1.0^*$ $u = 0.00795075$
 $u = y + p = 0.00795075$

- Calculation of y -

$y = (M_y * L_s / 3) / E_{eff} = 0.00295075$ ((4.29), Biskinis Phd)
 $M_y = 6.9764E+007$
 $L_s = M/V$ (with $L_s > 0.1 * L$ and $L_s < 2 * L$) = 925.00
From table 10.5, ASCE 41_17: $E_{eff} = 0.3 * E_c * I_g = 7.2898E+012$

Calculation of Yielding Moment M_y

Calculation of y and M_y according to Annex 7 -

$y = \text{Min}(y_{ten}, y_{com})$
 $y_{ten} = 8.5720234E-006$
with ((10.1), ASCE 41-17) $f_y = \text{Min}(f_y, 1.25 * f_y * (l_b / d)^{2/3}) = 311.2112$
 $d = 258.00$
 $y = 0.29640604$
 $A = 0.02078041$
 $B = 0.01208963$
with $p_t = 0.00791487$
 $p_c = 0.00791487$
 $p_v = 0.00493157$
 $N = 613.7698$
 $b = 400.00$
 $" = 0.1627907$
 $y_{comp} = 2.8784095E-005$
with $f_c = 33.00$
 $E_c = 26999.444$
 $y = 0.29625066$
 $A = 0.02074778$
 $B = 0.01207052$
with $E_s = 200000.00$

Calculation of ratio l_b / d

Inadequate Lap Length with $l_b / d = 0.30$

- Calculation of p -

From table 10-7: $p = 0.005$

with:



- Condition iv occurred
Beam controlled by inadequate embedment into beam-column joint:
($l_b / d < 1$ and With Lapping in the Vicinity of the End Regions)
- Condition i occurred
Beam controlled by flexure: $V_p / V_o \leq 1$
shear control ratio $V_p / V_o = 0.54312483$
- Transverse Reinforcement: NC
- Stirrup Spacing $> d / 3$
- Low ductility demand, $\lambda / y < 2$ (table 10-6, ASCE 41-17)
 $= 1.0135391E-022$
- Stirrup Spacing $> d / 2$
 $d = 258.00$
 $s = 150.00$
- Strength provided by hoops $V_s < 3/4 * \text{design Shear}$
 $V_s = 139627.457$, already given in calculation of shear control ratio
design Shear = 5.3543557E-014

$\rho = \frac{A_{st}}{b_w d} = 0.00894989$
 Tension Reinf Area: $A_{st} = 923.6282$
 $\rho' = \frac{A_{sc}}{b_w d} = 0.01181141$
 Compression Reinf Area: $A_{sc} = 1218.938$
 From (B-1), ACI 318-11: $\rho_{bal} = 0.01704017$
 $f_c = 33.00$
 $f_y = 555.56$
 From 10.2.7.3, ACI 318-11: $\beta_1 = 0.65$
 From fig R10.3.3, ACI 318-11 (Ence 454, too): $\frac{c_b}{d_t} = \frac{87000}{87000 + f_y} = \frac{0.003}{0.003 + \rho} = 0.51922877$
 $c_b = 0.0027778$
 $\rho_{req} = \frac{V}{b_w d^2 f_c^{0.5}} = 1.0876616E-018$, NOTE: units in lb & in
 $b_w = 400.00$

End Of Calculation of Chord Rotation Capacity for element: beam B1 of floor 1
 At local axis: 3
 Integration Section: (b)

Calculation No. 9

beam B1, Floor 1
 Limit State: Life Safety (data interpolation between analysis steps 1 and 2)
 Analysis: Uniform +X
 Check: Shear capacity V_{Rd}
 Edge: Start
 Local Axis: (2)



Start Of Calculation of Shear Capacity for element: beam B1 of floor 1
 At local axis: 2
 Integration Section: (a)
 Section Type: rcars

Constant Properties

Knowledge Factor, $\gamma = 1.00$

Member Shear Force is generally considered as Force-Controlled Action according to Table C7-1, ASCE 41-17.
Lower-bound strengths are used for Force-Controlled Actions according to 7.5.1.3, ASCE 41-17
Consequently:
New material of Secondary Member: Concrete Strength, $f_c = f_{c_lower_bound} = 25.00$
New material of Secondary Member: Steel Strength, $f_s = f_{s_lower_bound} = 500.00$
Concrete Elasticity, $E_c = 26999.444$
Steel Elasticity, $E_s = 200000.00$
Section Height, $H = 400.00$
Section Width, $W = 300.00$
Cover Thickness, $c = 25.00$
Element Length, $L = 1850.00$
Secondary Member
Smooth Bars
Ductile Steel
Without Detailing for Earthquake Resistance (including stirrups not closed at 135°)
Longitudinal Bars With Ends Lapped Starting at the End Sections
Inadequate Lap Length with $l_o/l_{ou,min} = l_b/l_d = 0.30$
No FRP Wrapping

Stepwise Properties

EDGE -A-
Bending Moment, $M_a = 1.8089301E-011$
Shear Force, $V_a = 3.3781306E-014$
EDGE -B-
Bending Moment, $M_b = 4.4346397E-011$
Shear Force, $V_b = -3.3781306E-014$
BOTH EDGES
Axial Force, $F = -457.6821$
Longitudinal Reinforcement Area Distribution (in 2 divisions)
-Tension: $As_t = 911.0619$
-Compression: $As_c = 1231.504$
Longitudinal Reinforcement Area Distribution (in 3 divisions)
-Tension: $As_{t,ten} = 816.8141$
-Compression: $As_{c,com} = 816.8141$
-Middle: $As_{mid} = 508.938$
Mean Diameter of Tension Reinforcement, $Db_{L,ten} = 14.40$

New component: From table 7-7, ASCE 41_17: Final Shear Capacity $VR = 1.0 \cdot V_n = 171047.78$
 V_n ((22.5.1.1), ACI 318-14) = 171047.78

NOTE: In expression (22.5.1.1) ' V_w ' is replaced by ' $V_w + f \cdot V_f$ '
where V_f is the contribution of FRPs ((11.3), ACI 440).

From Table (22.5.5.1), ACI 318-14: $V_c = 76800.00$
= 1 (normal-weight concrete)
 $f_c' = 25.00$, but $f_c'^{0.5} \leq 8.3$ MPa (22.5.3.1, ACI 318-14)
 $\rho_w = A_s/(b_w \cdot d) = 0.00949023$
 A_s (tension reinf.) = 911.0619
 $b_w = 400.00$
 $d = 240.00$
 $V_u \cdot d / M_u < 1 = 0.00$
 $M_u = 1.8089301E-011$
 $V_u = 3.3781306E-014$



From (11.5.4.8), ACI 318-14: $V_s = 94247.78$
 $A_v = 157079.633$
 $f_y = 500.00$
 $s = 150.00$

V_s has been multiplied by $2(1-s/d)$ ($s > d/2$, according to ASCE 41-17, 10.3.4)
 $2(1-s/d) = 0.75$
 V_f ((11-3)-(11.4), ACI 440) = 0.00
From (11-11), ACI 440: $V_s + V_f \leq 318865.838$

End Of Calculation of Shear Capacity for element: beam B1 of floor 1
 At local axis: 2
 Integration Section: (a)

Calculation No. 10

beam B1, Floor 1
 Limit State: Life Safety (data interpolation between analysis steps 1 and 2)
 Analysis: Uniform +X
 Check: Chord rotation capacity (ϕ)
 Edge: Start
 Local Axis: (2)



Start Of Calculation of Shear Capacity ratio for element: beam B1 of floor 1
 At Shear local axis: 3
 (Bending local axis: 2)
 Section Type: rcars

Constant Properties

Knowledge Factor, $\gamma = 1.00$
 Mean strength values are used for both shear and moment calculations.
 Consequently:
 New material of Secondary Member: Concrete Strength, $f_c = f_{cm} = 33.00$
 New material of Secondary Member: Steel Strength, $f_s = f_{sm} = 555.56$
 Concrete Elasticity, $E_c = 26999.444$
 Steel Elasticity, $E_s = 200000.00$
 #####
 Note: Especially for the calculation of moment strengths,
 the above steel re-bar strengths are multiplied by 1.25 according to R18.6.5, ACI 318-14
 New material: Steel Strength, $f_s = 1.25 \cdot f_{sm} = 694.45$
 #####
 Section Height, $H = 400.00$
 Section Width, $W = 300.00$
 Cover Thickness, $c = 25.00$
 Mean Confinement Factor overall section = 1.00
 Element Length, $L = 1850.00$
 Secondary Member

Smooth Bars
Ductile Steel
Without Detailing for Earthquake Resistance (including stirrups not closed at 135°)
Longitudinal Bars With Ends Lapped Starting at the End Sections
Inadequate Lap Length with $l_o/l_{o,min} = 0.30$
No FRP Wrapping

Stepwise Properties

At local axis: 3
EDGE -A-
Shear Force, $V_a = 2771.021$
EDGE -B-
Shear Force, $V_b = 2771.021$
BOTH EDGES
Axial Force, $F = -190.8684$
Longitudinal Reinforcement Area Distribution (in 2 divisions)
-Tension: $A_{st} = 911.0619$
-Compression: $A_{sc} = 1231.504$
Longitudinal Reinforcement Area Distribution (in 3 divisions)
-Tension: $A_{st,ten} = 603.1858$
-Compression: $A_{sc,com} = 923.6282$
-Middle: $A_{sc,mid} = 615.7522$

Calculation of Shear Capacity ratio , $V_e/V_r = 0.59550037$
Member Controlled by Flexure ($V_e/V_r < 1$)
Calculation of Shear Demand from fig. R18.6.5, ACI 318-14 $V_e = (M_{pr1} + M_{pr2})/l_n \pm w_u \cdot l_n/2 = 172632.267$
with
 $M_{pr1} = \text{Max}(\mu_{u1+}, \mu_{u1-}) = 1.5721E+008$
 $\mu_{u1+} = 1.1233E+008$, is the ultimate moment strength at the edge 1 of the member in the actual moment direction which is defined for the static loading combination
 $\mu_{u1-} = 1.5721E+008$, is the ultimate moment strength at the edge 1 of the member in the opposite moment direction which is defined for the static loading combination
 $M_{pr2} = \text{Max}(\mu_{u2+}, \mu_{u2-}) = 1.5703E+008$
 $\mu_{u2+} = 1.1247E+008$, is the ultimate moment strength at the edge 2 of the member in the actual moment direction which is defined for the the static loading combination
 $\mu_{u2-} = 1.5703E+008$, is the ultimate moment strength at the edge 2 of the member in the opposite moment direction which is defined for the the static loading combination
and
 $\pm w_u \cdot l_n = (|V_1| + |V_2|)/2$
with
 $V_1 = 2771.021$, is the shear force acting at edge 1 for the the static loading combination
 $V_2 = 2771.021$, is the shear force acting at edge 2 for the the static loading combination

Calculation of μ_{u1+}

Calculation of ultimate curvature ϕ_u according to 4.1, Biskinis/Fardis 2013:
 $\phi_u = 1.7687265E-005$
 $M_u = 1.1233E+008$

with full section properties:

$b = 300.00$
 $d = 357.00$
 $d' = 42.00$
 $v = 5.4004576E-005$
 $N = 190.8684$
 $f_c = 33.00$
 $\omega (5A.5, TBDY) = 0.002$
Final value of ϕ_u : $\phi_u^* = \text{shear_factor} * \text{Max}(\phi_u, \phi_c) = 0.00553582$
The Shear_factor is considered equal to 1 (pure moment strength)

From (5.4b), TBDY: $c_u = 0.00553582$

w_e (5.4c) = 0.00259035

a_{se} ((5.4d), TBDY) = 0.15672608

$b_o = 240.00$

$b_h = 340.00$

$b_{i2} = 346400.00$

$p_{sh,min} = \text{Min}(p_{sh,x}, p_{sh,y}) = 0.00261799$

Expression ((5.4d), TBDY) for $p_{sh,min}$ has been multiplied by 0.3 according to 15.7.1.3 for members without earthquake detailing (90° closed stirrups)

 $p_{sh,x}$ (5.4d) = 0.00349066

$A_{sh} = A_{stir} * n_s = 78.53982$

No stirrups, $n_s = 2.00$

$b_k = 300.00$

$p_{sh,y}$ (5.4d) = 0.00261799

$A_{sh} = A_{stir} * n_s = 78.53982$

No stirrups, $n_s = 2.00$

$b_k = 400.00$

$s = 150.00$

$f_{ywe} = 694.45$

$f_{ce} = 33.00$

From ((5.A5), TBDY), TBDY: $c_c = 0.002$

$c = \text{confinement factor} = 1.00$

$y_1 = 0.00140044$

$sh_1 = 0.0044814$

$ft_1 = 466.8167$

$fy_1 = 389.0139$

$su_1 = 0.00512$

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00

$l_o/l_{o,min} = l_b/l_d = 0.30$

$su_1 = 0.4 * esu_{1,nominal}$ ((5.5), TBDY) = 0.032

From table 5A.1, TBDY: $esu_{1,nominal} = 0.08$,

For calculation of $esu_{1,nominal}$ and y_1, sh_1, ft_1, fy_1 , it is considered
characteristic value $fsy_1 = fs_1/1.2$, from table 5.1, TBDY.

y_1, sh_1, ft_1, fy_1 , are also multiplied by $\text{Min}(1, 1.25 * (l_b/l_d)^{2/3})$, from 10.3.5, ASCE 41-17.

with $fs_1 = fs = 389.0139$

with $Es_1 = Es = 200000.00$

$y_2 = 0.00140044$

$sh_2 = 0.0044814$

$ft_2 = 466.8167$

$fy_2 = 389.0139$

$su_2 = 0.00512$

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00

$l_o/l_{o,min} = l_b/l_{b,min} = 0.30$

$su_2 = 0.4 * esu_{2,nominal}$ ((5.5), TBDY) = 0.032

From table 5A.1, TBDY: $esu_{2,nominal} = 0.08$,

For calculation of $esu_{2,nominal}$ and y_2, sh_2, ft_2, fy_2 , it is considered
characteristic value $fsy_2 = fs_2/1.2$, from table 5.1, TBDY.

y_2, sh_2, ft_2, fy_2 , are also multiplied by $\text{Min}(1, 1.25 * (l_b/l_d)^{2/3})$, from 10.3.5, ASCE 41-17.

with $fs_2 = fs = 389.0139$

with $Es_2 = Es = 200000.00$

$y_v = 0.00140044$

$sh_v = 0.0044814$

$ft_v = 466.8167$

$fy_v = 389.0139$

$su_v = 0.00512$

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00

$l_o/l_{o,min} = l_b/l_d = 0.30$

$su_v = 0.4 * esu_{v,nominal}$ ((5.5), TBDY) = 0.032

From table 5A.1, TBDY: $e_{suv_nominal} = 0.08$,
 considering characteristic value $f_{sv} = f_{sv}/1.2$, from table 5.1, TBDY
 For calculation of $e_{suv_nominal}$ and y_v, sh_v, ft_v, fy_v , it is considered
 characteristic value $f_{sv} = f_{sv}/1.2$, from table 5.1, TBDY.
 y_1, sh_1, ft_1, fy_1 , are also multiplied by $\text{Min}(1, 1.25 \cdot (l_b/l_d)^{2/3})$, from 10.3.5, ASCE 41-17.
 with $f_{sv} = f_s = 389.0139$
 with $E_{sv} = E_s = 200000.00$
 $1 = A_{sl,ten}/(b \cdot d) \cdot (f_{s1}/f_c) = 0.06639156$
 $2 = A_{sl,com}/(b \cdot d) \cdot (f_{s2}/f_c) = 0.10166207$
 $v = A_{sl,mid}/(b \cdot d) \cdot (f_{sv}/f_c) = 0.06777471$

and confined core properties:

$b = 240.00$
 $d = 327.00$
 $d' = 12.00$
 f_{cc} (5A.2, TBDY) = 33.00
 cc (5A.5, TBDY) = 0.002
 $c = \text{confinement factor} = 1.00$
 $1 = A_{sl,ten}/(b \cdot d) \cdot (f_{s1}/f_c) = 0.09060316$
 $2 = A_{sl,com}/(b \cdot d) \cdot (f_{s2}/f_c) = 0.13873608$
 $v = A_{sl,mid}/(b \cdot d) \cdot (f_{sv}/f_c) = 0.09249072$

Case/Assumption: Unconfined full section - Steel rupture
 ' satisfies Eq. (4.3)

---->
 $v < v_{s,y2}$ - LHS eq.(4.5) is satisfied

---->
 su (4.9) = 0.189149
 $M_u = MR_c$ (4.14) = 1.1233E+008
 $u = su$ (4.1) = 1.7687265E-005

 Calculation of ratio l_b/l_d

 Inadequate Lap Length with $l_b/l_d = 0.30$

 Calculation of Mu_1 -

 Calculation of ultimate curvature u according to 4.1, Biskinis/Fardis 2013:

$u = 1.8434312E-005$
 $M_u = 1.5721E+008$

 with full section properties:

$b = 300.00$
 $d = 358.00$
 $d' = 43.00$
 $v = 5.3853726E-005$
 $N = 190.8684$
 $f_c = 33.00$
 cc (5A.5, TBDY) = 0.002
 Final value of cu : $cu^* = \text{shear_factor} \cdot \text{Max}(cu, cc) = 0.00553582$
 The Shear_factor is considered equal to 1 (pure moment strength)
 From (5.4b), TBDY: $cu = 0.00553582$
 w_e (5.4c) = 0.00259035
 a_{se} ((5.4d), TBDY) = 0.15672608
 $bo = 240.00$
 $ho = 340.00$
 $bi_2 = 346400.00$
 $p_{sh,min} = \text{Min}(p_{sh,x}, p_{sh,y}) = 0.00261799$

Expression ((5.4d), TBDY) for $p_{sh,min}$ has been multiplied by 0.3 according to 15.7.1.3 for members without
 earthquake detailing (90° closed stirrups)

 $p_{sh,x}$ (5.4d) = 0.00349066
 $A_{sh} = A_{stir} \cdot n_s = 78.53982$
 No stirrups, $n_s = 2.00$

bk = 300.00

psh,y (5.4d) = 0.00261799

Ash = Astir*ns = 78.53982

No stirups, ns = 2.00

bk = 400.00

s = 150.00

fywe = 694.45

fce = 33.00

From ((5.A5), TBDY), TBDY: cc = 0.002

c = confinement factor = 1.00

y1 = 0.00140044

sh1 = 0.0044814

ft1 = 466.8167

fy1 = 389.0139

su1 = 0.00512

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00

lo/lou,min = lb/d = 0.30

su1 = 0.4*esu1_nominal ((5.5), TBDY) = 0.032

From table 5A.1, TBDY: esu1_nominal = 0.08,

For calculation of esu1_nominal and y1, sh1,ft1,fy1, it is considered
characteristic value fsy1 = fs1/1.2, from table 5.1, TBDY.

y1, sh1,ft1,fy1, are also multiplied by $\text{Min}(1, 1.25 \cdot (lb/d)^{2/3})$, from 10.3.5, ASCE 41-17.

with fs1 = fs = 389.0139

with Es1 = Es = 200000.00

y2 = 0.00140044

sh2 = 0.0044814

ft2 = 466.8167

fy2 = 389.0139

su2 = 0.00512

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00

lo/lou,min = lb/lb,min = 0.30

su2 = 0.4*esu2_nominal ((5.5), TBDY) = 0.032

From table 5A.1, TBDY: esu2_nominal = 0.08,

For calculation of esu2_nominal and y2, sh2,ft2,fy2, it is considered
characteristic value fsy2 = fs2/1.2, from table 5.1, TBDY.

y1, sh1,ft1,fy1, are also multiplied by $\text{Min}(1, 1.25 \cdot (lb/d)^{2/3})$, from 10.3.5, ASCE 41-17.

with fs2 = fs = 389.0139

with Es2 = Es = 200000.00

yv = 0.00140044

shv = 0.0044814

ftv = 466.8167

fyv = 389.0139

suv = 0.00512

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00

lo/lou,min = lb/d = 0.30

suv = 0.4*esuv_nominal ((5.5), TBDY) = 0.032

From table 5A.1, TBDY: esuv_nominal = 0.08,

considering characteristic value fsyv = fsv/1.2, from table 5.1, TBDY
For calculation of esuv_nominal and yv, shv,ftv,fyv, it is considered
characteristic value fsyv = fsv/1.2, from table 5.1, TBDY.

y1, sh1,ft1,fy1, are also multiplied by $\text{Min}(1, 1.25 \cdot (lb/d)^{2/3})$, from 10.3.5, ASCE 41-17.

with fsv = fs = 389.0139

with Esv = Es = 200000.00

1 = Asl,ten/(b*d)*(fs1/fc) = 0.1013781

2 = Asl,com/(b*d)*(fs2/fc) = 0.06620611

v = Asl,mid/(b*d)*(fsv/fc) = 0.0675854

and confined core properties:

b = 240.00

d = 328.00

d' = 13.00
fcc (5A.2, TBDY) = 33.00
cc (5A.5, TBDY) = 0.002
c = confinement factor = 1.00
1 = Asl,ten/(b*d)*(fs1/fc) = 0.13831311
2 = Asl,com/(b*d)*(fs2/fc) = 0.09032693
v = Asl,mid/(b*d)*(fsv/fc) = 0.09220874
Case/Assumption: Unconfined full section - Steel rupture
' satisfies Eq. (4.3)

--->
v < vs,y2 - LHS eq.(4.5) is satisfied

--->
su (4.9) = 0.22418173
Mu = MRc (4.14) = 1.5721E+008
u = su (4.1) = 1.8434312E-005

Calculation of ratio lb/d

Inadequate Lap Length with lb/d = 0.30

Calculation of Mu2+

Calculation of ultimate curvature u according to 4.1, Biskinis/Fardis 2013:

u = 1.7651391E-005
Mu = 1.1247E+008

with full section properties:

b = 300.00
d = 358.00
d' = 43.00
v = 5.3853726E-005
N = 190.8684
fc = 33.00
co (5A.5, TBDY) = 0.002
Final value of cu: cu* = shear_factor * Max(cu, cc) = 0.00553582
The Shear_factor is considered equal to 1 (pure moment strength)
From (5.4b), TBDY: cu = 0.00553582
we (5.4c) = 0.00259035
ase ((5.4d), TBDY) = 0.15672608
bo = 240.00
ho = 340.00
bi2 = 346400.00
psh,min = Min(psh,x , psh,y) = 0.00261799

Expression ((5.4d), TBDY) for psh,min has been multiplied by 0.3 according to 15.7.1.3 for members without earthquake detailing (90° closed stirrups)

psh,x (5.4d) = 0.00349066
Ash = Astir*ns = 78.53982
No stirups, ns = 2.00
bk = 300.00

psh,y (5.4d) = 0.00261799
Ash = Astir*ns = 78.53982
No stirups, ns = 2.00
bk = 400.00

s = 150.00
fywe = 694.45
fce = 33.00
From ((5.A5), TBDY), TBDY: cc = 0.002
c = confinement factor = 1.00
y1 = 0.00140044

$sh1 = 0.0044814$
 $ft1 = 466.8167$
 $fy1 = 389.0139$
 $su1 = 0.00512$
 using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
 and also multiplied by the shear_factor according to 15.7.1.4, with
 $Shear_factor = 1.00$
 $lo/lou,min = lb/l_d = 0.30$
 $su1 = 0.4 * esu1_nominal ((5.5), TBDY) = 0.032$
 From table 5A.1, TBDY: $esu1_nominal = 0.08$,
 For calculation of $esu1_nominal$ and $y1, sh1, ft1, fy1$, it is considered
 characteristic value $fsy1 = fs1/1.2$, from table 5.1, TBDY.
 $y1, sh1, ft1, fy1$, are also multiplied by $Min(1, 1.25 * (lb/l_d)^{2/3})$, from 10.3.5, ASCE 41-17.
 with $fs1 = fs = 389.0139$
 with $Es1 = Es = 200000.00$
 $y2 = 0.00140044$
 $sh2 = 0.0044814$
 $ft2 = 466.8167$
 $fy2 = 389.0139$
 $su2 = 0.00512$
 using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
 and also multiplied by the shear_factor according to 15.7.1.4, with
 $Shear_factor = 1.00$
 $lo/lou,min = lb/l_b,min = 0.30$
 $su2 = 0.4 * esu2_nominal ((5.5), TBDY) = 0.032$
 From table 5A.1, TBDY: $esu2_nominal = 0.08$,
 For calculation of $esu2_nominal$ and $y2, sh2, ft2, fy2$, it is considered
 characteristic value $fsy2 = fs2/1.2$, from table 5.1, TBDY.
 $y1, sh1, ft1, fy1$, are also multiplied by $Min(1, 1.25 * (lb/l_d)^{2/3})$, from 10.3.5, ASCE 41-17.
 with $fs2 = fs = 389.0139$
 with $Es2 = Es = 200000.00$
 $yv = 0.00140044$
 $shv = 0.0044814$
 $ftv = 466.8167$
 $fyv = 389.0139$
 $suv = 0.00512$
 using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
 and also multiplied by the shear_factor according to 15.7.1.4, with
 $Shear_factor = 1.00$
 $lo/lou,min = lb/l_d = 0.30$
 $suv = 0.4 * esuv_nominal ((5.5), TBDY) = 0.032$
 From table 5A.1, TBDY: $esuv_nominal = 0.08$,
 considering characteristic value $fsyv = fsv/1.2$, from table 5.1, TBDY
 For calculation of $esuv_nominal$ and yv, shv, ftv, fyv , it is considered
 characteristic value $fsyv = fsv/1.2$, from table 5.1, TBDY.
 $y1, sh1, ft1, fy1$, are also multiplied by $Min(1, 1.25 * (lb/l_d)^{2/3})$, from 10.3.5, ASCE 41-17.
 with $fsv = fs = 389.0139$
 with $Esv = Es = 200000.00$
 $1 = Asl,ten / (b * d) * (fs1 / fc) = 0.06620611$
 $2 = Asl,com / (b * d) * (fs2 / fc) = 0.1013781$
 $v = Asl,mid / (b * d) * (fsv / fc) = 0.0675854$
 and confined core properties:
 $b = 240.00$
 $d = 328.00$
 $d' = 13.00$
 $fcc (5A.2, TBDY) = 33.00$
 $cc (5A.5, TBDY) = 0.002$
 $c = \text{confinement factor} = 1.00$
 $1 = Asl,ten / (b * d) * (fs1 / fc) = 0.09032693$
 $2 = Asl,com / (b * d) * (fs2 / fc) = 0.13831311$
 $v = Asl,mid / (b * d) * (fsv / fc) = 0.09220874$
 Case/Assumption: Unconfined full section - Steel rupture
 ' satisfies Eq. (4.3)
 --->
 $v < vs,y2$ - LHS eq.(4.5) is satisfied
 --->
 $su (4.9) = 0.18977061$

Mu = MRc (4.14) = 1.1247E+008
u = su (4.1) = 1.7651391E-005

Calculation of ratio lb/l_d

Inadequate Lap Length with lb/l_d = 0.30

Calculation of Mu₂-

Calculation of ultimate curvature u according to 4.1, Biskinis/Fardis 2013:

u = 1.8476637E-005
Mu = 1.5703E+008

with full section properties:

b = 300.00
d = 357.00
d' = 42.00
v = 5.4004576E-005
N = 190.8684
f_c = 33.00
co (5A.5, TBDY) = 0.002
Final value of cu: cu* = shear_factor * Max(cu, cc) = 0.00553582
The Shear_factor is considered equal to 1 (pure moment strength)
From (5.4b), TBDY: cu = 0.00553582
w_e (5.4c) = 0.00259035
a_{se} ((5.4d), TBDY) = 0.15672608
b_o = 240.00
h_o = 340.00
b_{i2} = 346400.00

psh,min = Min(psh,x , psh,y) = 0.00261799
Expression ((5.4d), TBDY) for psh,min has been multiplied by 0.3 according to 15.7.1.3 for members without earthquake detailing (90° closed stirrups)

psh,x (5.4d) = 0.00349066
A_{sh} = Astir*ns = 78.53982
No stirrups, ns = 2.00
b_k = 300.00

psh,y (5.4d) = 0.00261799
A_{sh} = Astir*ns = 78.53982
No stirrups, ns = 2.00
b_k = 400.00

s = 150.00
f_{ywe} = 694.45
f_{ce} = 33.00
From ((5.A5), TBDY), TBDY: cc = 0.002
c = confinement factor = 1.00
y₁ = 0.00140044
sh₁ = 0.0044814
ft₁ = 466.8167
fy₁ = 389.0139
su₁ = 0.00512

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00
lo/lou,min = lb/l_d = 0.30
su₁ = 0.4*esu_{1_nominal} ((5.5), TBDY) = 0.032
From table 5A.1, TBDY: esu_{1_nominal} = 0.08,
For calculation of esu_{1_nominal} and y₁, sh₁,ft₁,fy₁, it is considered
characteristic value fsy₁ = fs₁/1.2, from table 5.1, TBDY.
y₁, sh₁,ft₁,fy₁, are also multiplied by Min(1,1.25*(lb/l_d)^{2/3}), from 10.3.5, ASCE 41-17.

with $f_{s1} = f_s = 389.0139$
 with $E_{s1} = E_s = 200000.00$
 $y_2 = 0.00140044$
 $sh_2 = 0.0044814$
 $ft_2 = 466.8167$
 $fy_2 = 389.0139$
 $su_2 = 0.00512$
 using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
 and also multiplied by the shear_factor according to 15.7.1.4, with
 Shear_factor = 1.00
 $l_o/l_{o,min} = l_b/l_{b,min} = 0.30$
 $su_2 = 0.4 * esu_{2,nominal} ((5.5), TBDY) = 0.032$
 From table 5A.1, TBDY: $esu_{2,nominal} = 0.08$,
 For calculation of $esu_{2,nominal}$ and y_2, sh_2, ft_2, fy_2 , it is considered
 characteristic value $fsy_2 = fs_2/1.2$, from table 5.1, TBDY.
 y_1, sh_1, ft_1, fy_1 , are also multiplied by $Min(1, 1.25 * (l_b/l_d)^{2/3})$, from 10.3.5, ASCE 41-17.
 with $f_{s2} = f_s = 389.0139$
 with $E_{s2} = E_s = 200000.00$
 $y_v = 0.00140044$
 $sh_v = 0.0044814$
 $ft_v = 466.8167$
 $fy_v = 389.0139$
 $su_v = 0.00512$
 using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
 and also multiplied by the shear_factor according to 15.7.1.4, with
 Shear_factor = 1.00
 $l_o/l_{o,min} = l_b/l_d = 0.30$
 $su_v = 0.4 * esu_{v,nominal} ((5.5), TBDY) = 0.032$
 From table 5A.1, TBDY: $esu_{v,nominal} = 0.08$,
 considering characteristic value $fsy_v = f_{sv}/1.2$, from table 5.1, TBDY
 For calculation of $esu_{v,nominal}$ and y_v, sh_v, ft_v, fy_v , it is considered
 characteristic value $fsy_v = f_{sv}/1.2$, from table 5.1, TBDY.
 y_1, sh_1, ft_1, fy_1 , are also multiplied by $Min(1, 1.25 * (l_b/l_d)^{2/3})$, from 10.3.5, ASCE 41-17.
 with $f_{sv} = f_s = 389.0139$
 with $E_{sv} = E_s = 200000.00$
 $1 = A_{sl,ten}/(b*d) * (f_{s1}/f_c) = 0.10166207$
 $2 = A_{sl,com}/(b*d) * (f_{s2}/f_c) = 0.06639156$
 $v = A_{sl,mid}/(b*d) * (f_{sv}/f_c) = 0.06777471$

and confined core properties:

$b = 240.00$
 $d = 327.00$
 $d' = 12.00$
 $f_{cc} (5A.2, TBDY) = 33.00$
 $cc (5A.5, TBDY) = 0.002$
 $c = \text{confinement factor} = 1.00$
 $1 = A_{sl,ten}/(b*d) * (f_{s1}/f_c) = 0.13873608$
 $2 = A_{sl,com}/(b*d) * (f_{s2}/f_c) = 0.09060316$
 $v = A_{sl,mid}/(b*d) * (f_{sv}/f_c) = 0.09249072$

Case/Assumption: Unconfined full section - Steel rupture
 ' satisfies Eq. (4.3)

--->
 $v < v_s, y_2$ - LHS eq.(4.5) is satisfied
 --->
 $su (4.9) = 0.22379076$
 $M_u = MR_c (4.14) = 1.5703E+008$
 $u = su (4.1) = 1.8476637E-005$

 Calculation of ratio l_b/l_d

 Inadequate Lap Length with $l_b/l_d = 0.30$

 Calculation of Shear Strength $V_r = Min(V_{r1}, V_{r2}) = 289894.477$

Calculation of Shear Strength at edge 1, $V_{r1} = 289894.477$
 $V_{r1} = V_n$ ((22.5.1.1), ACI 318-14)

NOTE: In expression (22.5.1.1) ' V_w ' is replaced by ' $V_w + f \cdot V_f$ '
where V_f is the contribution of FRPs (11.3), ACI 440).

From Table (22.5.5.1), ACI 318-14: $V_c = 103724.534$
= 1 (normal-weight concrete)
 $f_c' = 33.00$, but $f_c'^{0.5} \leq 8.3$ MPa (22.5.3.1, ACI 318-14)
 $\rho_w = A_s / (b_w \cdot d) = 0.00949023$
 A_s (tension reinf.) = 911.0619
 $b_w = 300.00$
 $d = 320.00$
 $V_u \cdot d / \mu_u < 1 = 1.00$
 $\mu_u = 71267.116$
 $V_u = 2771.021$

From (11.5.4.8), ACI 318-14: $V_s = 186169.943$
 $A_v = 157079.633$
 $f_y = 555.56$
 $s = 150.00$
 V_s has been multiplied by 1 ($s < d/2$, according to ASCE 41-17,10.3.4)
 V_f ((11-3)-(11.4), ACI 440) = 0.00
From (11-11), ACI 440: $V_s + V_f \leq 366348.956$

Calculation of Shear Strength at edge 2, $V_{r2} = 289894.477$
 $V_{r2} = V_n$ ((22.5.1.1), ACI 318-14)

NOTE: In expression (22.5.1.1) ' V_w ' is replaced by ' $V_w + f \cdot V_f$ '
where V_f is the contribution of FRPs (11.3), ACI 440).

From Table (22.5.5.1), ACI 318-14: $V_c = 103724.534$
= 1 (normal-weight concrete)
 $f_c' = 33.00$, but $f_c'^{0.5} \leq 8.3$ MPa (22.5.3.1, ACI 318-14)
 $\rho_w = A_s / (b_w \cdot d) = 0.00949023$
 A_s (tension reinf.) = 911.0619
 $b_w = 300.00$
 $d = 320.00$
 $V_u \cdot d / \mu_u < 1 = 1.00$
 $\mu_u = 71267.116$
 $V_u = 2771.021$

From (11.5.4.8), ACI 318-14: $V_s = 186169.943$
 $A_v = 157079.633$
 $f_y = 555.56$
 $s = 150.00$
 V_s has been multiplied by 1 ($s < d/2$, according to ASCE 41-17,10.3.4)
 V_f ((11-3)-(11.4), ACI 440) = 0.00
From (11-11), ACI 440: $V_s + V_f \leq 366348.956$

End Of Calculation of Shear Capacity ratio for element: beam B1 of floor 1
At local axis: 3

Start Of Calculation of Shear Capacity ratio for element: beam B1 of floor 1
At Shear local axis: 2
(Bending local axis: 3)
Section Type: rcars

Constant Properties

Knowledge Factor, $\phi = 1.00$
Mean strength values are used for both shear and moment calculations.
Consequently:
New material of Secondary Member: Concrete Strength, $f_c = f_{cm} = 33.00$
New material of Secondary Member: Steel Strength, $f_s = f_{sm} = 555.56$
Concrete Elasticity, $E_c = 26999.444$

Steel Elasticity, $E_s = 200000.00$

#####

Note: Especially for the calculation of moment strengths,
the above steel re-bar strengths are multiplied by 1.25 according to R18.6.5, ACI 318-14
New material: Steel Strength, $f_s = 1.25 * f_{sm} = 694.45$

#####

Section Height, $H = 400.00$

Section Width, $W = 300.00$

Cover Thickness, $c = 25.00$

Mean Confinement Factor overall section = 1.00

Element Length, $L = 1850.00$

Secondary Member

Smooth Bars

Ductile Steel

Without Detailing for Earthquake Resistance (including stirrups not closed at 135°)

Longitudinal Bars With Ends Lapped Starting at the End Sections

Inadequate Lap Length with $l_o/l_{o,min} = 0.30$

No FRP Wrapping

Stepwise Properties

At local axis: 2

EDGE -A-

Shear Force, $V_a = 4.9160836E-020$

EDGE -B-

Shear Force, $V_b = -4.9160836E-020$

BOTH EDGES

Axial Force, $F = -190.8684$

Longitudinal Reinforcement Area Distribution (in 2 divisions)

-Tension: $A_{st} = 911.0619$

-Compression: $A_{sc} = 1231.504$

Longitudinal Reinforcement Area Distribution (in 3 divisions)

-Tension: $A_{st,ten} = 816.8141$

-Compression: $A_{sl,com} = 816.8141$

-Middle: $A_{sl,mid} = 508.938$

Calculation of Shear Capacity ratio , $V_e/V_r = 0.54312483$

Member Controlled by Flexure ($V_e/V_r < 1$)

Calculation of Shear Demand from fig. R18.6.5, ACI 318-14 $V_e = (M_{pr1} + M_{pr2})/l_n \pm w_u * l_n / 2 = 104799.778$
with

$M_{pr1} = \text{Max}(M_{u1+} , M_{u1-}) = 9.6940E+007$

$M_{u1+} = 9.6940E+007$, is the ultimate moment strength at the edge 1 of the member in the actual moment direction
which is defined for the static loading combination

$M_{u1-} = 9.6940E+007$, is the ultimate moment strength at the edge 1 of the member in the opposite moment
direction which is defined for the static loading combination

$M_{pr2} = \text{Max}(M_{u2+} , M_{u2-}) = 9.6940E+007$

$M_{u2+} = 9.6940E+007$, is the ultimate moment strength at the edge 2 of the member in the actual moment direction
which is defined for the the static loading combination

$M_{u2-} = 9.6940E+007$, is the ultimate moment strength at the edge 2 of the member in the opposite moment
direction which is defined for the the static loading combination

and

$\pm w_u * l_n = (|V_1| + |V_2|)/2$

with

$V_1 = 4.9160836E-020$, is the shear force acting at edge 1 for the the static loading combination

$V_2 = -4.9160836E-020$, is the shear force acting at edge 2 for the the static loading combination

Calculation of M_{u1+}

Calculation of ultimate curvature ϕ_u according to 4.1, Biskinis/Fardis 2013:

$\phi_u = 2.5454950E-005$

$$\text{Mu} = 9.6940\text{E}+007$$

with full section properties:

$$b = 400.00$$

$$d = 258.00$$

$$d' = 42.00$$

$$v = 5.6045447\text{E}-005$$

$$N = 190.8684$$

$$f_c = 33.00$$

$$c_o (5A.5, \text{TBDY}) = 0.002$$

$$\text{Final value of } c_u: c_u^* = \text{shear_factor} * \text{Max}(c_u, c_c) = 0.00553582$$

The Shear_factor is considered equal to 1 (pure moment strength)

$$\text{From (5.4b), TBDY: } c_u = 0.00553582$$

$$w_e (5.4c) = 0.00259035$$

$$a_{se} ((5.4d), \text{TBDY}) = 0.15672608$$

$$b_o = 240.00$$

$$h_o = 340.00$$

$$b_{i2} = 346400.00$$

$$p_{sh,min} = \text{Min}(p_{sh,x}, p_{sh,y}) = 0.00261799$$

Expression ((5.4d), TBDY) for $p_{sh,min}$ has been multiplied by 0.3 according to 15.7.1.3 for members without earthquake detailing (90° closed stirrups)

$$p_{sh,x} (5.4d) = 0.00349066$$

$$A_{sh} = A_{stir} * n_s = 78.53982$$

$$\text{No stirrups, } n_s = 2.00$$

$$b_k = 300.00$$

$$p_{sh,y} (5.4d) = 0.00261799$$

$$A_{sh} = A_{stir} * n_s = 78.53982$$

$$\text{No stirrups, } n_s = 2.00$$

$$b_k = 400.00$$

$$s = 150.00$$

$$f_{ywe} = 694.45$$

$$f_{ce} = 33.00$$

$$\text{From ((5.A5), TBDY), TBDY: } c_c = 0.002$$

$$c = \text{confinement factor} = 1.00$$

$$y_1 = 0.00140044$$

$$sh_1 = 0.0044814$$

$$f_{t1} = 466.8167$$

$$f_{y1} = 389.0139$$

$$s_{u1} = 0.00512$$

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor and also multiplied by the shear_factor according to 15.7.1.4, with Shear_factor = 1.00

$$l_o/l_{o,min} = l_b/l_d = 0.30$$

$$s_{u1} = 0.4 * e_{s_{u1,nominal}} ((5.5), \text{TBDY}) = 0.032$$

$$\text{From table 5A.1, TBDY: } e_{s_{u1,nominal}} = 0.08,$$

For calculation of $e_{s_{u1,nominal}}$ and $y_1, sh_1, f_{t1}, f_{y1}$, it is considered characteristic value $f_{s_{y1}} = f_{s1}/1.2$, from table 5.1, TBDY.

$y_1, sh_1, f_{t1}, f_{y1}$, are also multiplied by $\text{Min}(1, 1.25 * (l_b/l_d)^{2/3})$, from 10.3.5, ASCE 41-17.

$$\text{with } f_{s1} = f_s = 389.0139$$

$$\text{with } E_{s1} = E_s = 200000.00$$

$$y_2 = 0.00140044$$

$$sh_2 = 0.0044814$$

$$f_{t2} = 466.8167$$

$$f_{y2} = 389.0139$$

$$s_{u2} = 0.00512$$

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor and also multiplied by the shear_factor according to 15.7.1.4, with Shear_factor = 1.00

$$l_o/l_{o,min} = l_b/l_{b,min} = 0.30$$

$$s_{u2} = 0.4 * e_{s_{u2,nominal}} ((5.5), \text{TBDY}) = 0.032$$

$$\text{From table 5A.1, TBDY: } e_{s_{u2,nominal}} = 0.08,$$

For calculation of $e_{s_{u2,nominal}}$ and $y_2, sh_2, f_{t2}, f_{y2}$, it is considered characteristic value $f_{s_{y2}} = f_{s2}/1.2$, from table 5.1, TBDY.

$y_1, sh_1, f_{t1}, f_{y1}$, are also multiplied by $\text{Min}(1, 1.25 * (l_b/l_d)^{2/3})$, from 10.3.5, ASCE 41-17.

with $f_{s2} = f_s = 389.0139$
 with $E_{s2} = E_s = 200000.00$
 $y_v = 0.00140044$
 $sh_v = 0.0044814$
 $ft_v = 466.8167$
 $fy_v = 389.0139$
 $suv = 0.00512$
 using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
 and also multiplied by the shear_factor according to 15.7.1.4, with
 Shear_factor = 1.00
 $l_o/l_{o,min} = l_b/l_d = 0.30$
 $suv = 0.4 * esuv_{nominal} ((5.5), TBDY) = 0.032$
 From table 5A.1, TBDY: $esuv_{nominal} = 0.08$,
 considering characteristic value $f_{syv} = f_{sv}/1.2$, from table 5.1, TBDY
 For calculation of $esuv_{nominal}$ and y_v, sh_v, ft_v, fy_v , it is considered
 characteristic value $f_{syv} = f_{sv}/1.2$, from table 5.1, TBDY.
 y_1, sh_1, ft_1, fy_1 , are also multiplied by $Min(1, 1.25 * (l_b/l_d)^{2/3})$, from 10.3.5, ASCE 41-17.
 with $f_{sv} = f_s = 389.0139$
 with $E_{sv} = E_s = 200000.00$
 $1 = A_{sl,ten}/(b*d) * (f_{s1}/f_c) = 0.09330282$
 $2 = A_{sl,com}/(b*d) * (f_{s2}/f_c) = 0.09330282$
 $v = A_{sl,mid}/(b*d) * (f_{sv}/f_c) = 0.05813483$

and confined core properties:

$b = 340.00$
 $d = 228.00$
 $d' = 12.00$
 $f_{cc} (5A.2, TBDY) = 33.00$
 $cc (5A.5, TBDY) = 0.002$
 $c = \text{confinement factor} = 1.00$
 $1 = A_{sl,ten}/(b*d) * (f_{s1}/f_c) = 0.12421118$
 $2 = A_{sl,com}/(b*d) * (f_{s2}/f_c) = 0.12421118$
 $v = A_{sl,mid}/(b*d) * (f_{sv}/f_c) = 0.07739312$

Case/Assumption: Unconfined full section - Steel rupture
 ' satisfies Eq. (4.3)

--->
 $v < v_{s,y2}$ - LHS eq.(4.5) is satisfied
 --->
 $su (4.9) = 0.22038892$
 $Mu = MRc (4.14) = 9.6940E+007$
 $u = su (4.1) = 2.5454950E-005$

Calculation of ratio l_b/l_d

Inadequate Lap Length with $l_b/l_d = 0.30$

Calculation of Mu_1 -

Calculation of ultimate curvature u according to 4.1, Biskinis/Fardis 2013:
 $u = 2.5454950E-005$
 $Mu = 9.6940E+007$

with full section properties:

$b = 400.00$
 $d = 258.00$
 $d' = 42.00$
 $v = 5.6045447E-005$
 $N = 190.8684$
 $f_c = 33.00$
 $cc (5A.5, TBDY) = 0.002$
 Final value of cu : $cu^* = \text{shear_factor} * \text{Max}(cu, cc) = 0.00553582$
 The Shear_factor is considered equal to 1 (pure moment strength)
 From (5.4b), TBDY: $cu = 0.00553582$

we (5.4c) = 0.00259035
ase ((5.4d), TBDY) = 0.15672608
bo = 240.00
ho = 340.00
bi2 = 346400.00

psh,min = Min(psh,x , psh,y) = 0.00261799
Expression ((5.4d), TBDY) for psh,min has been multiplied by 0.3 according to 15.7.1.3 for members without earthquake detailing (90° closed stirrups)

psh,x (5.4d) = 0.00349066
Ash = Astir*ns = 78.53982
No stirrups, ns = 2.00
bk = 300.00

psh,y (5.4d) = 0.00261799
Ash = Astir*ns = 78.53982
No stirrups, ns = 2.00
bk = 400.00

s = 150.00
fywe = 694.45
fce = 33.00

From ((5.A5), TBDY), TBDY: cc = 0.002
c = confinement factor = 1.00

y1 = 0.00140044
sh1 = 0.0044814
ft1 = 466.8167
fy1 = 389.0139
su1 = 0.00512

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00

lo/lou,min = lb/d = 0.30

su1 = 0.4*esu1_nominal ((5.5), TBDY) = 0.032

From table 5A.1, TBDY: esu1_nominal = 0.08,

For calculation of esu1_nominal and y1, sh1,ft1,fy1, it is considered
characteristic value fsy1 = fs1/1.2, from table 5.1, TBDY.

y1, sh1,ft1,fy1, are also multiplied by Min(1,1.25*(lb/d)^ 2/3), from 10.3.5, ASCE 41-17.

with fs1 = fs = 389.0139

with Es1 = Es = 200000.00

y2 = 0.00140044
sh2 = 0.0044814
ft2 = 466.8167
fy2 = 389.0139
su2 = 0.00512

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00

lo/lou,min = lb/lb,min = 0.30

su2 = 0.4*esu2_nominal ((5.5), TBDY) = 0.032

From table 5A.1, TBDY: esu2_nominal = 0.08,

For calculation of esu2_nominal and y2, sh2,ft2,fy2, it is considered
characteristic value fsy2 = fs2/1.2, from table 5.1, TBDY.

y1, sh1,ft1,fy1, are also multiplied by Min(1,1.25*(lb/d)^ 2/3), from 10.3.5, ASCE 41-17.

with fs2 = fs = 389.0139

with Es2 = Es = 200000.00

yv = 0.00140044
shv = 0.0044814
ftv = 466.8167
fyv = 389.0139
suv = 0.00512

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00

lo/lou,min = lb/d = 0.30

suv = 0.4*esuv_nominal ((5.5), TBDY) = 0.032

From table 5A.1, TBDY: esuv_nominal = 0.08,

considering characteristic value $f_{sv} = f_{sv}/1.2$, from table 5.1, TBDY
For calculation of $e_{suv_nominal}$ and y_v , sh_v, ft_v, fy_v , it is considered characteristic value $f_{sv} = f_{sv}/1.2$, from table 5.1, TBDY.

y_1 , sh_1, ft_1, fy_1 , are also multiplied by $\text{Min}(1, 1.25 \cdot (l_b/l_d)^{2/3})$, from 10.3.5, ASCE 41-17.

with $f_{sv} = f_s = 389.0139$

with $E_{sv} = E_s = 200000.00$

1 = $A_{sl,ten}/(b \cdot d) \cdot (f_{s1}/f_c) = 0.09330282$

2 = $A_{sl,com}/(b \cdot d) \cdot (f_{s2}/f_c) = 0.09330282$

v = $A_{sl,mid}/(b \cdot d) \cdot (f_{sv}/f_c) = 0.05813483$

and confined core properties:

b = 340.00

d = 228.00

d' = 12.00

f_{cc} (5A.2, TBDY) = 33.00

cc (5A.5, TBDY) = 0.002

c = confinement factor = 1.00

1 = $A_{sl,ten}/(b \cdot d) \cdot (f_{s1}/f_c) = 0.12421118$

2 = $A_{sl,com}/(b \cdot d) \cdot (f_{s2}/f_c) = 0.12421118$

v = $A_{sl,mid}/(b \cdot d) \cdot (f_{sv}/f_c) = 0.07739312$

Case/Assumption: Unconfined full section - Steel rupture

' satisfies Eq. (4.3)

--->

v < $v_{s,y2}$ - LHS eq.(4.5) is satisfied

--->

su (4.9) = 0.22038892

Mu = MRc (4.14) = 9.6940E+007

u = su (4.1) = 2.5454950E-005

Calculation of ratio l_b/l_d

Inadequate Lap Length with $l_b/l_d = 0.30$

Calculation of Mu2+

Calculation of ultimate curvature u according to 4.1, Biskinis/Fardis 2013:

u = 2.5454950E-005

Mu = 9.6940E+007

with full section properties:

b = 400.00

d = 258.00

d' = 42.00

v = 5.6045447E-005

N = 190.8684

f_c = 33.00

co (5A.5, TBDY) = 0.002

Final value of cu : $cu^* = \text{shear_factor} \cdot \text{Max}(cu, cc) = 0.00553582$

The Shear_factor is considered equal to 1 (pure moment strength)

From (5.4b), TBDY: $cu = 0.00553582$

we (5.4c) = 0.00259035

ase ((5.4d), TBDY) = 0.15672608

bo = 240.00

ho = 340.00

bi2 = 346400.00

psh,min = $\text{Min}(psh,x, psh,y) = 0.00261799$

Expression ((5.4d), TBDY) for psh,min has been multiplied by 0.3 according to 15.7.1.3 for members without earthquake detailing (90° closed stirrups)

psh,x (5.4d) = 0.00349066

Ash = $A_{stir} \cdot n_s = 78.53982$

No stirrups, $n_s = 2.00$

bk = 300.00

psh,y (5.4d) = 0.00261799
Ash = Astir*ns = 78.53982
No stirups, ns = 2.00
bk = 400.00

s = 150.00
fywe = 694.45
fce = 33.00

From ((5.A5), TBDY), TBDY: cc = 0.002
c = confinement factor = 1.00

y1 = 0.00140044
sh1 = 0.0044814
ft1 = 466.8167
fy1 = 389.0139
su1 = 0.00512

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00

lo/lou,min = lb/d = 0.30

su1 = 0.4*esu1_nominal ((5.5), TBDY) = 0.032

From table 5A.1, TBDY: esu1_nominal = 0.08,

For calculation of esu1_nominal and y1, sh1,ft1,fy1, it is considered
characteristic value fsy1 = fs1/1.2, from table 5.1, TBDY.

y1, sh1,ft1,fy1, are also multiplied by $\text{Min}(1, 1.25 \cdot (lb/d)^{2/3})$, from 10.3.5, ASCE 41-17.

with fs1 = fs = 389.0139

with Es1 = Es = 200000.00

y2 = 0.00140044
sh2 = 0.0044814
ft2 = 466.8167
fy2 = 389.0139
su2 = 0.00512

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00

lo/lou,min = lb/lb,min = 0.30

su2 = 0.4*esu2_nominal ((5.5), TBDY) = 0.032

From table 5A.1, TBDY: esu2_nominal = 0.08,

For calculation of esu2_nominal and y2, sh2,ft2,fy2, it is considered
characteristic value fsy2 = fs2/1.2, from table 5.1, TBDY.

y1, sh1,ft1,fy1, are also multiplied by $\text{Min}(1, 1.25 \cdot (lb/d)^{2/3})$, from 10.3.5, ASCE 41-17.

with fs2 = fs = 389.0139

with Es2 = Es = 200000.00

yv = 0.00140044
shv = 0.0044814
ftv = 466.8167
fyv = 389.0139
suv = 0.00512

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00

lo/lou,min = lb/d = 0.30

suv = 0.4*esuv_nominal ((5.5), TBDY) = 0.032

From table 5A.1, TBDY: esuv_nominal = 0.08,

considering characteristic value fsyv = fsv/1.2, from table 5.1, TBDY

For calculation of esuv_nominal and yv, shv,ftv,fyv, it is considered
characteristic value fsyv = fsv/1.2, from table 5.1, TBDY.

y1, sh1,ft1,fy1, are also multiplied by $\text{Min}(1, 1.25 \cdot (lb/d)^{2/3})$, from 10.3.5, ASCE 41-17.

with fsv = fs = 389.0139

with Esv = Es = 200000.00

1 = Asl,ten/(b*d)*(fs1/fc) = 0.09330282

2 = Asl,com/(b*d)*(fs2/fc) = 0.09330282

v = Asl,mid/(b*d)*(fsv/fc) = 0.05813483

and confined core properties:

b = 340.00
d = 228.00
d' = 12.00

$$fcc (5A.2, TBDY) = 33.00$$

$$cc (5A.5, TBDY) = 0.002$$

$$c = \text{confinement factor} = 1.00$$

$$1 = Asl,ten/(b*d)*(fs1/fc) = 0.12421118$$

$$2 = Asl,com/(b*d)*(fs2/fc) = 0.12421118$$

$$v = Asl,mid/(b*d)*(fsv/fc) = 0.07739312$$

Case/Assumption: Unconfined full section - Steel rupture

' satisfies Eq. (4.3)

--->

$v < v_{s,y2}$ - LHS eq.(4.5) is satisfied

--->

$$su (4.9) = 0.22038892$$

$$Mu = MRc (4.14) = 9.6940E+007$$

$$u = su (4.1) = 2.5454950E-005$$

Calculation of ratio l_b/l_d

Inadequate Lap Length with $l_b/l_d = 0.30$

Calculation of Mu_2 -

Calculation of ultimate curvature u according to 4.1, Biskinis/Fardis 2013:

$$u = 2.5454950E-005$$

$$Mu = 9.6940E+007$$

with full section properties:

$$b = 400.00$$

$$d = 258.00$$

$$d' = 42.00$$

$$v = 5.6045447E-005$$

$$N = 190.8684$$

$$fc = 33.00$$

$$co (5A.5, TBDY) = 0.002$$

$$\text{Final value of } cu: cu^* = \text{shear_factor} * \text{Max}(cu, cc) = 0.00553582$$

The Shear_factor is considered equal to 1 (pure moment strength)

$$\text{From (5.4b), TBDY: } cu = 0.00553582$$

$$we (5.4c) = 0.00259035$$

$$ase ((5.4d), TBDY) = 0.15672608$$

$$bo = 240.00$$

$$ho = 340.00$$

$$bi2 = 346400.00$$

$$psh,min = \text{Min}(psh,x, psh,y) = 0.00261799$$

Expression ((5.4d), TBDY) for psh,min has been multiplied by 0.3 according to 15.7.1.3 for members without earthquake detailing (90° closed stirrups)

$$psh,x (5.4d) = 0.00349066$$

$$Ash = Astir*ns = 78.53982$$

$$\text{No stirups, } ns = 2.00$$

$$bk = 300.00$$

$$psh,y (5.4d) = 0.00261799$$

$$Ash = Astir*ns = 78.53982$$

$$\text{No stirups, } ns = 2.00$$

$$bk = 400.00$$

$$s = 150.00$$

$$fywe = 694.45$$

$$fce = 33.00$$

$$\text{From ((5.A5), TBDY), TBDY: } cc = 0.002$$

$$c = \text{confinement factor} = 1.00$$

$$y1 = 0.00140044$$

$$sh1 = 0.0044814$$

$$ft1 = 466.8167$$

$$fy1 = 389.0139$$

$$su1 = 0.00512$$

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00

$$lo/lou,min = lb/ld = 0.30$$

$$su1 = 0.4*esu1_nominal ((5.5), TBDY) = 0.032$$

From table 5A.1, TBDY: esu1_nominal = 0.08,

For calculation of esu1_nominal and y1, sh1,ft1,fy1, it is considered
characteristic value fsy1 = fs1/1.2, from table 5.1, TBDY.

y1, sh1,ft1,fy1, are also multiplied by $\text{Min}(1, 1.25*(lb/ld)^{2/3})$, from 10.3.5, ASCE 41-17.

$$\text{with } fs1 = fs = 389.0139$$

$$\text{with } Es1 = Es = 200000.00$$

$$y2 = 0.00140044$$

$$sh2 = 0.0044814$$

$$ft2 = 466.8167$$

$$fy2 = 389.0139$$

$$su2 = 0.00512$$

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00

$$lo/lou,min = lb/lb,min = 0.30$$

$$su2 = 0.4*esu2_nominal ((5.5), TBDY) = 0.032$$

From table 5A.1, TBDY: esu2_nominal = 0.08,

For calculation of esu2_nominal and y2, sh2,ft2,fy2, it is considered
characteristic value fsy2 = fs2/1.2, from table 5.1, TBDY.

y1, sh1,ft1,fy1, are also multiplied by $\text{Min}(1, 1.25*(lb/ld)^{2/3})$, from 10.3.5, ASCE 41-17.

$$\text{with } fs2 = fs = 389.0139$$

$$\text{with } Es2 = Es = 200000.00$$

$$yv = 0.00140044$$

$$shv = 0.0044814$$

$$ftv = 466.8167$$

$$fyv = 389.0139$$

$$suv = 0.00512$$

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00

$$lo/lou,min = lb/ld = 0.30$$

$$suv = 0.4*esuv_nominal ((5.5), TBDY) = 0.032$$

From table 5A.1, TBDY: esuv_nominal = 0.08,

considering characteristic value fsyv = fsv/1.2, from table 5.1, TBDY

For calculation of esuv_nominal and yv, shv,ftv,fyv, it is considered
characteristic value fsyv = fsv/1.2, from table 5.1, TBDY.

y1, sh1,ft1,fy1, are also multiplied by $\text{Min}(1, 1.25*(lb/ld)^{2/3})$, from 10.3.5, ASCE 41-17.

$$\text{with } fsv = fs = 389.0139$$

$$\text{with } Esv = Es = 200000.00$$

$$1 = Asl,ten/(b*d)*(fs1/fc) = 0.09330282$$

$$2 = Asl,com/(b*d)*(fs2/fc) = 0.09330282$$

$$v = Asl,mid/(b*d)*(fsv/fc) = 0.05813483$$

and confined core properties:

$$b = 340.00$$

$$d = 228.00$$

$$d' = 12.00$$

$$fcc (5A.2, TBDY) = 33.00$$

$$cc (5A.5, TBDY) = 0.002$$

$$c = \text{confinement factor} = 1.00$$

$$1 = Asl,ten/(b*d)*(fs1/fc) = 0.12421118$$

$$2 = Asl,com/(b*d)*(fs2/fc) = 0.12421118$$

$$v = Asl,mid/(b*d)*(fsv/fc) = 0.07739312$$

Case/Assumption: Unconfined full section - Steel rupture

' satisfies Eq. (4.3)

--->

v < vs,y2 - LHS eq.(4.5) is satisfied

--->

$$su (4.9) = 0.22038892$$

$$Mu = MRc (4.14) = 9.6940E+007$$

$$u = su(4.1) = 2.5454950E-005$$

Calculation of ratio l_b/d

Inadequate Lap Length with $l_b/d = 0.30$

Calculation of Shear Strength $V_r = \text{Min}(V_{r1}, V_{r2}) = 192957.075$

Calculation of Shear Strength at edge 1, $V_{r1} = 192957.075$
 $V_{r1} = V_n$ ((22.5.1.1), ACI 318-14)

NOTE: In expression (22.5.1.1) ' V_w ' is replaced by ' $V_w + f^*V_f$ '
where V_f is the contribution of FRPs (11.3), ACI 440).

From Table (22.5.5.1), ACI 318-14: $V_c = 88236.482$
= 1 (normal-weight concrete)
 $f_c' = 33.00$, but $f_c'^{0.5} \leq 8.3$ MPa (22.5.3.1, ACI 318-14)
 $\rho_w = A_s/(b_w*d) = 0.00949023$
 A_s (tension reinf.) = 911.0619
 $b_w = 400.00$
 $d = 240.00$
 $V_u*d/M_u < 1 = 0.00$
 $M_u = 3.3205266E-012$
 $V_u = 4.9160836E-020$

From (11.5.4.8), ACI 318-14: $V_s = 104720.593$
 $A_v = 157079.633$
 $f_y = 555.56$
 $s = 150.00$

V_s has been multiplied by $2(1-s/d)$ ($s > d/2$, according to ASCE 41-17,10.3.4)
 $2(1-s/d) = 0.75$
 V_f ((11-3)-(11.4), ACI 440) = 0.00
From (11-11), ACI 440: $V_s + V_f \leq 366348.956$

Calculation of Shear Strength at edge 2, $V_{r2} = 192957.075$
 $V_{r2} = V_n$ ((22.5.1.1), ACI 318-14)

NOTE: In expression (22.5.1.1) ' V_w ' is replaced by ' $V_w + f^*V_f$ '
where V_f is the contribution of FRPs (11.3), ACI 440).

From Table (22.5.5.1), ACI 318-14: $V_c = 88236.482$
= 1 (normal-weight concrete)
 $f_c' = 33.00$, but $f_c'^{0.5} \leq 8.3$ MPa (22.5.3.1, ACI 318-14)
 $\rho_w = A_s/(b_w*d) = 0.00949023$
 A_s (tension reinf.) = 911.0619
 $b_w = 400.00$
 $d = 240.00$
 $V_u*d/M_u < 1 = 0.00$
 $M_u = 3.3203395E-012$
 $V_u = 4.9160836E-020$

From (11.5.4.8), ACI 318-14: $V_s = 104720.593$
 $A_v = 157079.633$
 $f_y = 555.56$
 $s = 150.00$

V_s has been multiplied by $2(1-s/d)$ ($s > d/2$, according to ASCE 41-17,10.3.4)
 $2(1-s/d) = 0.75$
 V_f ((11-3)-(11.4), ACI 440) = 0.00
From (11-11), ACI 440: $V_s + V_f \leq 366348.956$

End Of Calculation of Shear Capacity ratio for element: beam B1 of floor 1
At local axis: 2

Start Of Calculation of Chord Rotation Capacity for element: beam B1 of floor 1

At local axis: 2

Integration Section: (a)

Section Type: rcars

Constant Properties

Knowledge Factor, $k = 1.00$

Chord Rotation is generally considered as Deformation-Controlled Action according to Table C7-1, ASCE 41-17.

Mean strengths are used for Deformation-Controlled Actions according to 7.5.1.3, ASCE 41-17

Consequently:

New material of Secondary Member: Concrete Strength, $f_c = f_{cm} = 33.00$

New material of Secondary Member: Steel Strength, $f_s = f_{sm} = 555.56$

Concrete Elasticity, $E_c = 26999.444$

Steel Elasticity, $E_s = 200000.00$

Section Height, $H = 400.00$

Section Width, $W = 300.00$

Cover Thickness, $c = 25.00$

Element Length, $L = 1850.00$

Secondary Member

Smooth Bars

Ductile Steel

Without Detailing for Earthquake Resistance (including stirrups not closed at 135°)

Longitudinal Bars With Ends Lapped Starting at the End Sections

Inadequate Lap Length with $l_b/l_d = 0.30$

No FRP Wrapping

Stepwise Properties

Bending Moment, $M = 4.3417E+006$

Shear Force, $V_2 = 3.3781306E-014$

Shear Force, $V_3 = -1933.33$

Axial Force, $F = -457.6821$

Longitudinal Reinforcement Area Distribution (in 2 divisions)

-Tension: $A_{st} = 911.0619$

-Compression: $A_{sc} = 1231.504$

Longitudinal Reinforcement Area Distribution (in 3 divisions)

-Tension: $A_{st,ten} = 603.1858$

-Compression: $A_{sc,com} = 923.6282$

-Middle: $A_{st,mid} = 615.7522$

Mean Diameter of Tension Reinforcement, $DbL = 16.00$

New component: From table 7-7, ASCE 41_17: Final chord rotation Capacity $u_{,R} = 1.0^* u = 0.0245991$

$u = y + p = 0.0245991$

- Calculation of y -

$y = (M_y * L_s / 3) / E_{eff} = 0.0045991$ ((4.29), Biskinis Phd)

$M_y = 7.9623E+007$

$L_s = M/V$ (with $L_s > 0.1 * L$ and $L_s < 2 * L$) = 2245.696

From table 10.5, ASCE 41_17: $E_{eff} = 0.3 * E_c * I_g = 1.2960E+013$

Calculation of Yielding Moment M_y

Calculation of y and M_y according to Annex 7 -

$y = \text{Min}(y_{ten}, y_{com})$

$y_{ten} = 5.9053460E-006$

with ((10.1), ASCE 41-17) $f_y = \text{Min}(f_y, 1.25 * f_y * (l_b/l_d)^{2/3}) = 311.2112$

d = 357.00
y = 0.26190614
A = 0.02001902
B = 0.00987316
with pt = 0.00563199
pc = 0.00862398
pv = 0.00574932
N = 457.6821
b = 300.00
" = 0.11764706
y_comp = 2.3542102E-005
with fc = 33.00
Ec = 26999.444
y = 0.26176897
A = 0.01999557
B = 0.00985943
with Es = 200000.00

Calculation of ratio lb/d

Inadequate Lap Length with lb/d = 0.30

- Calculation of p -

From table 10-7: p = 0.02

with:

- Condition iv occurred

Beam controlled by inadequate embedment into beam-column joint:
(lb/d < 1 and With Lapping in the Vicinity of the End Regions

- Condition i occurred

Beam controlled by flexure: $V_p/V_o \leq 1$
shear control ratio $V_p/V_o = 0.59550037$

- Transverse Reinforcement: NC

- Stirrup Spacing > d/3

- Low ductility demand, $\lambda / y < 2$ (table 10-6, ASCE 41-17)
= 4.5308668E-005

- Stirrup Spacing $\leq d/2$

d = 357.00

s = 150.00

- Strength provided by hoops $V_s < 3/4$ *design Shear

$V_s = 186169.943$, already given in calculation of shear control ratio
design Shear = 1933.33

- (-)/ bal = -0.17558466

= $A_{st}/(b_w*d) = 0.00850665$

Tension Reinf Area: $A_{st} = 911.0619$

' = $A_{sc}/(b_w*d) = 0.01149864$

Compression Reinf Area: $A_{sc} = 1231.504$

From (B-1), ACI 318-11: bal = 0.01704017

fc = 33.00

fy = 555.56

From 10.2.7.3, ACI 318-11: $\lambda = 0.65$

From fig R10.3.3, ACI 318-11 (Ence 454, too): $87000/(87000+fy) = c_b/dt = 0.003/(0.003+ y) = 0.51922877$
y = 0.0027778

- $V/(b_w*d*fc^{0.5}) = 0.03784275$, NOTE: units in lb & in

$b_w = 300.00$

End Of Calculation of Chord Rotation Capacity for element: beam B1 of floor 1

At local axis: 2

Integration Section: (a)

Calculation No. 11

beam B1, Floor 1



Limit State: Life Safety (data interpolation between analysis steps 1 and 2)

Analysis: Uniform +X

Check: Shear capacity VRd

Edge: Start

Local Axis: (3)



Start Of Calculation of Shear Capacity for element: beam B1 of floor 1

At local axis: 3

Integration Section: (a)

Section Type: rcars

Constant Properties

Knowledge Factor, $\gamma = 1.00$

Member Shear Force is generally considered as Force-Controlled Action according to Table C7-1, ASCE 41-17.

Lower-bound strengths are used for Force-Controlled Actions according to 7.5.1.3, ASCE 41-17

Consequently:

New material of Secondary Member: Concrete Strength, $f_c = f_{c_lower_bound} = 25.00$

New material of Secondary Member: Steel Strength, $f_s = f_{s_lower_bound} = 500.00$

Concrete Elasticity, $E_c = 26999.444$

Steel Elasticity, $E_s = 200000.00$

Section Height, $H = 400.00$

Section Width, $W = 300.00$

Cover Thickness, $c = 25.00$

Element Length, $L = 1850.00$

Secondary Member

Smooth Bars

Ductile Steel

Without Detailing for Earthquake Resistance (including stirrups not closed at 135°)

Longitudinal Bars With Ends Lapped Starting at the End Sections

Inadequate Lap Length with $l_o/l_{ou,min} = l_b/d = 0.30$

No FRP Wrapping

Stepwise Properties

EDGE -A-

Bending Moment, $M_a = 4.3417E+006$

Shear Force, $V_a = -1933.33$

EDGE -B-

Bending Moment, $M_b = 4.3614E+006$

Shear Force, $V_b = 7475.372$

BOTH EDGES

Axial Force, $F = -457.6821$

Longitudinal Reinforcement Area Distribution (in 2 divisions)

-Tension: $A_{s,t} = 911.0619$

-Compression: $A_{s,c} = 1231.504$

Longitudinal Reinforcement Area Distribution (in 3 divisions)

-Tension: $A_{s,ten} = 603.1858$

-Compression: $A_{s,com} = 923.6282$

-Middle: $A_{s,mid} = 615.7522$

Mean Diameter of Tension Reinforcement, $D_{bL,ten} = 16.00$

New component: From table 7-7, ASCE 41_17: Final Shear Capacity $V_R = 1.0 \cdot V_n = 246558.575$

V_n ((22.5.1.1), ACI 318-14) = 246558.575

NOTE: In expression (22.5.1.1) ' V_w ' is replaced by ' $V_w + f \cdot V_f$ ' where V_f is the contribution of FRPs (11.3), ACI 440).

From Table (22.5.5.1), ACI 318-14: $V_c = 79006.967$

= 1 (normal-weight concrete)

$f_c' = 25.00$, but $f_c'^{0.5} \leq 8.3$ MPa (22.5.3.1, ACI 318-14)

$\rho_w = A_s / (b_w \cdot d) = 0.00949023$

A_s (tension reinf.) = 911.0619

$b_w = 300.00$

$d = 320.00$

$V_u \cdot d / M_u < 1 = 0.1424948$

$M_u = 4.3417E+006$

$V_u = 1933.33$

From (11.5.4.8), ACI 318-14: $V_s = 167551.608$

$A_v = 157079.633$

$f_y = 500.00$

$s = 150.00$

V_s has been multiplied by 1 ($s < d/2$, according to ASCE 41-17,10.3.4)

V_f ((11-3)-(11.4), ACI 440) = 0.00

From (11-11), ACI 440: $V_s + V_f \leq 318865.838$

End Of Calculation of Shear Capacity for element: beam B1 of floor 1

At local axis: 3

Integration Section: (a)

Calculation No. 12

beam B1, Floor 1



Limit State: Life Safety (data interpolation between analysis steps 1 and 2)

Analysis: Uniform +X

Check: Chord rotation capacity (θ_u)

Edge: Start

Local Axis: (3)



Start Of Calculation of Shear Capacity ratio for element: beam B1 of floor 1

At Shear local axis: 3

(Bending local axis: 2)

Section Type: rcars

Constant Properties

Knowledge Factor, $\gamma = 1.00$

Mean strength values are used for both shear and moment calculations.

Consequently:

New material of Secondary Member: Concrete Strength, $f_c = f_{cm} = 33.00$

New material of Secondary Member: Steel Strength, $f_s = f_{sm} = 555.56$

Concrete Elasticity, $E_c = 26999.444$

Steel Elasticity, $E_s = 200000.00$

#####

Note: Especially for the calculation of moment strengths,

the above steel re-bar strengths are multiplied by 1.25 according to R18.6.5, ACI 318-14

New material: Steel Strength, $f_s = 1.25 \cdot f_{sm} = 694.45$

#####

Section Height, $H = 400.00$

Section Width, $W = 300.00$

Cover Thickness, $c = 25.00$

Mean Confinement Factor overall section = 1.00

Element Length, $L = 1850.00$

Secondary Member

Smooth Bars

Ductile Steel

Without Detailing for Earthquake Resistance (including stirrups not closed at 135°)

Longitudinal Bars With Ends Lapped Starting at the End Sections

Inadequate Lap Length with $l_o/l_{ou,min} = 0.30$

No FRP Wrapping

Stepwise Properties

At local axis: 3

EDGE -A-

Shear Force, $V_a = 2771.021$

EDGE -B-

Shear Force, $V_b = 2771.021$
BOTH EDGES
Axial Force, $F = -190.8684$
Longitudinal Reinforcement Area Distribution (in 2 divisions)
-Tension: $As_t = 911.0619$
-Compression: $As_c = 1231.504$
Longitudinal Reinforcement Area Distribution (in 3 divisions)
-Tension: $As_{t,ten} = 603.1858$
-Compression: $As_{c,com} = 923.6282$
-Middle: $As_{c,mid} = 615.7522$

Calculation of Shear Capacity ratio, $V_e/V_r = 0.59550037$
Member Controlled by Flexure ($V_e/V_r < 1$)
Calculation of Shear Demand from fig. R18.6.5, ACI 318-14 $V_e = (M_{pr1} + M_{pr2})/l_n \pm w_u \cdot l_n/2 = 172632.267$
with
 $M_{pr1} = \text{Max}(Mu_{1+}, Mu_{1-}) = 1.5721E+008$
 $Mu_{1+} = 1.1233E+008$, is the ultimate moment strength at the edge 1 of the member in the actual moment direction
which is defined for the static loading combination
 $Mu_{1-} = 1.5721E+008$, is the ultimate moment strength at the edge 1 of the member in the opposite moment
direction which is defined for the static loading combination
 $M_{pr2} = \text{Max}(Mu_{2+}, Mu_{2-}) = 1.5703E+008$
 $Mu_{2+} = 1.1247E+008$, is the ultimate moment strength at the edge 2 of the member in the actual moment direction
which is defined for the the static loading combination
 $Mu_{2-} = 1.5703E+008$, is the ultimate moment strength at the edge 2 of the member in the opposite moment
direction which is defined for the the static loading combination
and
 $\pm w_u \cdot l_n = (|V_1| + |V_2|)/2$
with
 $V_1 = 2771.021$, is the shear force acting at edge 1 for the the static loading combination
 $V_2 = 2771.021$, is the shear force acting at edge 2 for the the static loading combination

Calculation of Mu_{1+}

Calculation of ultimate curvature ϕ_u according to 4.1, Biskinis/Fardis 2013:
 $\phi_u = 1.7687265E-005$
 $Mu = 1.1233E+008$

with full section properties:

$b = 300.00$
 $d = 357.00$
 $d' = 42.00$
 $v = 5.4004576E-005$
 $N = 190.8684$
 $f_c = 33.00$
 ϕ_c (5A.5, TBDY) = 0.002
Final value of ϕ_u : $\phi_u^* = \text{shear_factor} \cdot \text{Max}(\phi_u, \phi_c) = 0.00553582$
The Shear_factor is considered equal to 1 (pure moment strength)
From (5.4b), TBDY: $\phi_u = 0.00553582$
 w_e (5.4c) = 0.00259035
 a_{se} ((5.4d), TBDY) = 0.15672608
 $b_o = 240.00$
 $h_o = 340.00$
 $bi_2 = 346400.00$
 $p_{sh,min} = \text{Min}(p_{sh,x}, p_{sh,y}) = 0.00261799$
Expression ((5.4d), TBDY) for $p_{sh,min}$ has been multiplied by 0.3 according to 15.7.1.3 for members without
earthquake detailing (90° closed stirrups)

 $p_{sh,x}$ (5.4d) = 0.00349066
 $A_{sh} = A_{stir} \cdot n_s = 78.53982$
No stirrups, $n_s = 2.00$
 $b_k = 300.00$

psh,y (5.4d) = 0.00261799
Ash = Astir*ns = 78.53982
No stirups, ns = 2.00
bk = 400.00

s = 150.00
fywe = 694.45
fce = 33.00

From ((5.A5), TBDY), TBDY: cc = 0.002
c = confinement factor = 1.00

y1 = 0.00140044
sh1 = 0.0044814
ft1 = 466.8167
fy1 = 389.0139
su1 = 0.00512

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00

lo/lou,min = lb/d = 0.30

su1 = 0.4*esu1_nominal ((5.5), TBDY) = 0.032

From table 5A.1, TBDY: esu1_nominal = 0.08,

For calculation of esu1_nominal and y1, sh1,ft1,fy1, it is considered
characteristic value fsy1 = fs1/1.2, from table 5.1, TBDY.

y1, sh1,ft1,fy1, are also multiplied by $\text{Min}(1, 1.25*(lb/d)^{2/3})$, from 10.3.5, ASCE 41-17.

with fs1 = fs = 389.0139

with Es1 = Es = 200000.00

y2 = 0.00140044
sh2 = 0.0044814
ft2 = 466.8167
fy2 = 389.0139
su2 = 0.00512

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00

lo/lou,min = lb/lb,min = 0.30

su2 = 0.4*esu2_nominal ((5.5), TBDY) = 0.032

From table 5A.1, TBDY: esu2_nominal = 0.08,

For calculation of esu2_nominal and y2, sh2,ft2,fy2, it is considered
characteristic value fsy2 = fs2/1.2, from table 5.1, TBDY.

y1, sh1,ft1,fy1, are also multiplied by $\text{Min}(1, 1.25*(lb/d)^{2/3})$, from 10.3.5, ASCE 41-17.

with fs2 = fs = 389.0139

with Es2 = Es = 200000.00

yv = 0.00140044
shv = 0.0044814
ftv = 466.8167
fyv = 389.0139
suv = 0.00512

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00

lo/lou,min = lb/d = 0.30

suv = 0.4*esuv_nominal ((5.5), TBDY) = 0.032

From table 5A.1, TBDY: esuv_nominal = 0.08,

considering characteristic value fsyv = fsv/1.2, from table 5.1, TBDY

For calculation of esuv_nominal and yv, shv,ftv,fyv, it is considered
characteristic value fsyv = fsv/1.2, from table 5.1, TBDY.

y1, sh1,ft1,fy1, are also multiplied by $\text{Min}(1, 1.25*(lb/d)^{2/3})$, from 10.3.5, ASCE 41-17.

with fsv = fs = 389.0139

with Esv = Es = 200000.00

1 = Asl,ten/(b*d)*(fs1/fc) = 0.06639156

2 = Asl,com/(b*d)*(fs2/fc) = 0.10166207

v = Asl,mid/(b*d)*(fsv/fc) = 0.06777471

and confined core properties:

b = 240.00
d = 327.00
d' = 12.00

$$fcc (5A.2, TBDY) = 33.00$$

$$cc (5A.5, TBDY) = 0.002$$

$$c = \text{confinement factor} = 1.00$$

$$1 = Asl,ten/(b*d)*(fs1/fc) = 0.09060316$$

$$2 = Asl,com/(b*d)*(fs2/fc) = 0.13873608$$

$$v = Asl,mid/(b*d)*(fsv/fc) = 0.09249072$$

Case/Assumption: Unconfined full section - Steel rupture
' satisfies Eq. (4.3)

---->

$v < vs,y2$ - LHS eq.(4.5) is satisfied

---->

$$su (4.9) = 0.189149$$

$$Mu = MRc (4.14) = 1.1233E+008$$

$$u = su (4.1) = 1.7687265E-005$$

Calculation of ratio lb/ld

Inadequate Lap Length with $lb/ld = 0.30$

Calculation of $Mu1$ -

Calculation of ultimate curvature u according to 4.1, Biskinis/Fardis 2013:

$$u = 1.8434312E-005$$

$$Mu = 1.5721E+008$$

with full section properties:

$$b = 300.00$$

$$d = 358.00$$

$$d' = 43.00$$

$$v = 5.3853726E-005$$

$$N = 190.8684$$

$$fc = 33.00$$

$$co (5A.5, TBDY) = 0.002$$

$$\text{Final value of } cu: cu^* = \text{shear_factor} * \text{Max}(cu, cc) = 0.00553582$$

The Shear_factor is considered equal to 1 (pure moment strength)

$$\text{From (5.4b), TBDY: } cu = 0.00553582$$

$$we (5.4c) = 0.00259035$$

$$ase ((5.4d), TBDY) = 0.15672608$$

$$bo = 240.00$$

$$ho = 340.00$$

$$bi2 = 346400.00$$

$$psh,min = \text{Min}(psh,x, psh,y) = 0.00261799$$

Expression ((5.4d), TBDY) for psh,min has been multiplied by 0.3 according to 15.7.1.3 for members without earthquake detailing (90° closed stirrups)

$$psh,x (5.4d) = 0.00349066$$

$$Ash = Astir*ns = 78.53982$$

$$\text{No stirups, } ns = 2.00$$

$$bk = 300.00$$

$$psh,y (5.4d) = 0.00261799$$

$$Ash = Astir*ns = 78.53982$$

$$\text{No stirups, } ns = 2.00$$

$$bk = 400.00$$

$$s = 150.00$$

$$fywe = 694.45$$

$$fce = 33.00$$

$$\text{From ((5.A5), TBDY), TBDY: } cc = 0.002$$

$$c = \text{confinement factor} = 1.00$$

$$y1 = 0.00140044$$

$$sh1 = 0.0044814$$

$$ft1 = 466.8167$$

$$fy1 = 389.0139$$

$$su1 = 0.00512$$

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00

$$lo/lou,min = lb/d = 0.30$$

$$su1 = 0.4*esu1_nominal ((5.5), TBDY) = 0.032$$

From table 5A.1, TBDY: esu1_nominal = 0.08,

For calculation of esu1_nominal and y1, sh1,ft1,fy1, it is considered
characteristic value fsy1 = fs1/1.2, from table 5.1, TBDY.

y1, sh1,ft1,fy1, are also multiplied by $\text{Min}(1, 1.25*(lb/d)^{2/3})$, from 10.3.5, ASCE 41-17.

$$\text{with } fs1 = fs = 389.0139$$

$$\text{with } Es1 = Es = 200000.00$$

$$y2 = 0.00140044$$

$$sh2 = 0.0044814$$

$$ft2 = 466.8167$$

$$fy2 = 389.0139$$

$$su2 = 0.00512$$

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00

$$lo/lou,min = lb/lb,min = 0.30$$

$$su2 = 0.4*esu2_nominal ((5.5), TBDY) = 0.032$$

From table 5A.1, TBDY: esu2_nominal = 0.08,

For calculation of esu2_nominal and y2, sh2,ft2,fy2, it is considered
characteristic value fsy2 = fs2/1.2, from table 5.1, TBDY.

y1, sh1,ft1,fy1, are also multiplied by $\text{Min}(1, 1.25*(lb/d)^{2/3})$, from 10.3.5, ASCE 41-17.

$$\text{with } fs2 = fs = 389.0139$$

$$\text{with } Es2 = Es = 200000.00$$

$$yv = 0.00140044$$

$$shv = 0.0044814$$

$$ftv = 466.8167$$

$$fyv = 389.0139$$

$$suv = 0.00512$$

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00

$$lo/lou,min = lb/d = 0.30$$

$$suv = 0.4*esuv_nominal ((5.5), TBDY) = 0.032$$

From table 5A.1, TBDY: esuv_nominal = 0.08,

considering characteristic value fsyv = fsv/1.2, from table 5.1, TBDY

For calculation of esuv_nominal and yv, shv,ftv,fyv, it is considered
characteristic value fsyv = fsv/1.2, from table 5.1, TBDY.

y1, sh1,ft1,fy1, are also multiplied by $\text{Min}(1, 1.25*(lb/d)^{2/3})$, from 10.3.5, ASCE 41-17.

$$\text{with } fsv = fs = 389.0139$$

$$\text{with } Esv = Es = 200000.00$$

$$1 = Asl,ten/(b*d)*(fs1/fc) = 0.1013781$$

$$2 = Asl,com/(b*d)*(fs2/fc) = 0.06620611$$

$$v = Asl,mid/(b*d)*(fsv/fc) = 0.0675854$$

and confined core properties:

$$b = 240.00$$

$$d = 328.00$$

$$d' = 13.00$$

$$fcc (5A.2, TBDY) = 33.00$$

$$cc (5A.5, TBDY) = 0.002$$

$$c = \text{confinement factor} = 1.00$$

$$1 = Asl,ten/(b*d)*(fs1/fc) = 0.13831311$$

$$2 = Asl,com/(b*d)*(fs2/fc) = 0.09032693$$

$$v = Asl,mid/(b*d)*(fsv/fc) = 0.09220874$$

Case/Assumption: Unconfined full section - Steel rupture

' satisfies Eq. (4.3)

--->

v < vs,y2 - LHS eq.(4.5) is satisfied

--->

$$su (4.9) = 0.22418173$$

$$Mu = MRc (4.14) = 1.5721E+008$$

$$u = s_u(4.1) = 1.8434312E-005$$

Calculation of ratio l_b/d

Inadequate Lap Length with $l_b/d = 0.30$

Calculation of μ_{2+}

Calculation of ultimate curvature μ according to 4.1, Biskinis/Fardis 2013:

$$u = 1.7651391E-005$$

$$\mu = 1.1247E+008$$

with full section properties:

$$b = 300.00$$

$$d = 358.00$$

$$d' = 43.00$$

$$v = 5.3853726E-005$$

$$N = 190.8684$$

$$f_c = 33.00$$

$$c_o(5A.5, \text{TB DY}) = 0.002$$

$$\text{Final value of } \mu: \mu^* = \text{shear_factor} * \text{Max}(\mu, c_c) = 0.00553582$$

The Shear_factor is considered equal to 1 (pure moment strength)

$$\text{From (5.4b), TB DY: } \mu = 0.00553582$$

$$w_e(5.4c) = 0.00259035$$

$$a_{se}((5.4d), \text{TB DY}) = 0.15672608$$

$$b_o = 240.00$$

$$h_o = 340.00$$

$$b_{i2} = 346400.00$$

$$p_{sh,min} = \text{Min}(p_{sh,x}, p_{sh,y}) = 0.00261799$$

Expression ((5.4d), TB DY) for $p_{sh,min}$ has been multiplied by 0.3 according to 15.7.1.3 for members without earthquake detailing (90° closed stirrups)

$$p_{sh,x}(5.4d) = 0.00349066$$

$$A_{sh} = A_{stir} * n_s = 78.53982$$

$$\text{No stirrups, } n_s = 2.00$$

$$b_k = 300.00$$

$$p_{sh,y}(5.4d) = 0.00261799$$

$$A_{sh} = A_{stir} * n_s = 78.53982$$

$$\text{No stirrups, } n_s = 2.00$$

$$b_k = 400.00$$

$$s = 150.00$$

$$f_{ywe} = 694.45$$

$$f_{ce} = 33.00$$

$$\text{From ((5.A5), TB DY), TB DY: } c_c = 0.002$$

$$c = \text{confinement factor} = 1.00$$

$$y_1 = 0.00140044$$

$$sh_1 = 0.0044814$$

$$ft_1 = 466.8167$$

$$fy_1 = 389.0139$$

$$su_1 = 0.00512$$

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor and also multiplied by the shear_factor according to 15.7.1.4, with Shear_factor = 1.00

$$l_o/l_{o,min} = l_b/d = 0.30$$

$$su_1 = 0.4 * esu_1_{nominal}((5.5), \text{TB DY}) = 0.032$$

From table 5A.1, TB DY: $esu_1_{nominal} = 0.08$,

For calculation of $esu_1_{nominal}$ and y_1, sh_1, ft_1, fy_1 , it is considered characteristic value $fsy_1 = fs_1/1.2$, from table 5.1, TB DY.

y_1, sh_1, ft_1, fy_1 , are also multiplied by $\text{Min}(1, 1.25 * (l_b/d)^{2/3})$, from 10.3.5, ASCE 41-17.

$$\text{with } fs_1 = fs = 389.0139$$

with $E_{s1} = E_s = 200000.00$
 $y_2 = 0.00140044$
 $sh_2 = 0.0044814$
 $ft_2 = 466.8167$
 $fy_2 = 389.0139$
 $su_2 = 0.00512$
 using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
 and also multiplied by the shear_factor according to 15.7.1.4, with
 Shear_factor = 1.00
 $l_0/l_{ou,min} = l_b/l_{b,min} = 0.30$
 $su_2 = 0.4 * esu_{2,nominal} ((5.5), TBDY) = 0.032$
 From table 5A.1, TBDY: $esu_{2,nominal} = 0.08$,
 For calculation of $esu_{2,nominal}$ and y_2, sh_2, ft_2, fy_2 , it is considered
 characteristic value $fs_2 = fs_2/1.2$, from table 5.1, TBDY.
 y_1, sh_1, ft_1, fy_1 , are also multiplied by $Min(1, 1.25 * (l_b/l_d)^{2/3})$, from 10.3.5, ASCE 41-17.
 with $fs_2 = fs = 389.0139$
 with $E_{s2} = E_s = 200000.00$
 $y_v = 0.00140044$
 $sh_v = 0.0044814$
 $ft_v = 466.8167$
 $fy_v = 389.0139$
 $suv = 0.00512$
 using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
 and also multiplied by the shear_factor according to 15.7.1.4, with
 Shear_factor = 1.00
 $l_0/l_{ou,min} = l_b/l_d = 0.30$
 $suv = 0.4 * esuv_{nominal} ((5.5), TBDY) = 0.032$
 From table 5A.1, TBDY: $esuv_{nominal} = 0.08$,
 considering characteristic value $fs_{yv} = fs_v/1.2$, from table 5.1, TBDY
 For calculation of $esuv_{nominal}$ and y_v, sh_v, ft_v, fy_v , it is considered
 characteristic value $fs_{yv} = fs_v/1.2$, from table 5.1, TBDY.
 y_1, sh_1, ft_1, fy_1 , are also multiplied by $Min(1, 1.25 * (l_b/l_d)^{2/3})$, from 10.3.5, ASCE 41-17.
 with $fs_v = fs = 389.0139$
 with $E_{sv} = E_s = 200000.00$
 $1 = A_{sl,ten}/(b*d) * (fs_1/f_c) = 0.06620611$
 $2 = A_{sl,com}/(b*d) * (fs_2/f_c) = 0.1013781$
 $v = A_{sl,mid}/(b*d) * (fs_v/f_c) = 0.0675854$
 and confined core properties:
 $b = 240.00$
 $d = 328.00$
 $d' = 13.00$
 $f_{cc} (5A.2, TBDY) = 33.00$
 $cc (5A.5, TBDY) = 0.002$
 $c = \text{confinement factor} = 1.00$
 $1 = A_{sl,ten}/(b*d) * (fs_1/f_c) = 0.09032693$
 $2 = A_{sl,com}/(b*d) * (fs_2/f_c) = 0.13831311$
 $v = A_{sl,mid}/(b*d) * (fs_v/f_c) = 0.09220874$
 Case/Assumption: Unconfined full section - Steel rupture
 ' satisfies Eq. (4.3)
 --->
 $v < v_s, y_2$ - LHS eq.(4.5) is satisfied
 --->
 $su (4.9) = 0.18977061$
 $Mu = MRc (4.14) = 1.1247E+008$
 $u = su (4.1) = 1.7651391E-005$

 Calculation of ratio l_b/l_d

Inadequate Lap Length with $l_b/l_d = 0.30$

Calculation of Mu_2 -

Calculation of ultimate curvature ϕ_u according to 4.1, Biskinis/Fardis 2013:

$$\mu = 1.8476637E-005$$

$$M_u = 1.5703E+008$$

with full section properties:

$$b = 300.00$$

$$d = 357.00$$

$$d' = 42.00$$

$$v = 5.4004576E-005$$

$$N = 190.8684$$

$$f_c = 33.00$$

$$c_o \text{ (5A.5, TBDY)} = 0.002$$

$$\text{Final value of } \phi_u: \phi_u^* = \text{shear_factor} * \text{Max}(\phi_{cu}, \phi_{cc}) = 0.00553582$$

The Shear_factor is considered equal to 1 (pure moment strength)

$$\text{From (5.4b), TBDY: } \phi_{cu} = 0.00553582$$

$$w_e \text{ (5.4c)} = 0.00259035$$

$$a_{se} \text{ ((5.4d), TBDY)} = 0.15672608$$

$$b_o = 240.00$$

$$h_o = 340.00$$

$$b_{i2} = 346400.00$$

$$\phi_{sh,min} = \text{Min}(\phi_{sh,x}, \phi_{sh,y}) = 0.00261799$$

Expression ((5.4d), TBDY) for $\phi_{sh,min}$ has been multiplied by 0.3 according to 15.7.1.3 for members without earthquake detailing (90° closed stirrups)

$$\phi_{sh,x} \text{ (5.4d)} = 0.00349066$$

$$A_{sh} = A_{stir} * n_s = 78.53982$$

$$\text{No stirrups, } n_s = 2.00$$

$$b_k = 300.00$$

$$\phi_{sh,y} \text{ (5.4d)} = 0.00261799$$

$$A_{sh} = A_{stir} * n_s = 78.53982$$

$$\text{No stirrups, } n_s = 2.00$$

$$b_k = 400.00$$

$$s = 150.00$$

$$f_{ywe} = 694.45$$

$$f_{ce} = 33.00$$

$$\text{From ((5.A5), TBDY), TBDY: } \phi_{cc} = 0.002$$

$$c = \text{confinement factor} = 1.00$$

$$y_1 = 0.00140044$$

$$sh_1 = 0.0044814$$

$$f_{t1} = 466.8167$$

$$f_{y1} = 389.0139$$

$$su_1 = 0.00512$$

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor and also multiplied by the shear_factor according to 15.7.1.4, with Shear_factor = 1.00

$$l_o/l_{o,min} = l_b/l_d = 0.30$$

$$su_1 = 0.4 * esu_{1,nominal} \text{ ((5.5), TBDY)} = 0.032$$

$$\text{From table 5A.1, TBDY: } esu_{1,nominal} = 0.08,$$

For calculation of $esu_{1,nominal}$ and $y_1, sh_1, f_{t1}, f_{y1}$, it is considered characteristic value $f_{s1} = f_s/1.2$, from table 5.1, TBDY.

$y_1, sh_1, f_{t1}, f_{y1}$, are also multiplied by $\text{Min}(1, 1.25 * (l_b/l_d)^{2/3})$, from 10.3.5, ASCE 41-17.

$$\text{with } f_{s1} = f_s = 389.0139$$

$$\text{with } E_{s1} = E_s = 200000.00$$

$$y_2 = 0.00140044$$

$$sh_2 = 0.0044814$$

$$f_{t2} = 466.8167$$

$$f_{y2} = 389.0139$$

$$su_2 = 0.00512$$

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor and also multiplied by the shear_factor according to 15.7.1.4, with Shear_factor = 1.00

$$l_o/l_{o,min} = l_b/l_{b,min} = 0.30$$

$$su_2 = 0.4 * esu_{2,nominal} \text{ ((5.5), TBDY)} = 0.032$$

$$\text{From table 5A.1, TBDY: } esu_{2,nominal} = 0.08,$$

For calculation of $esu_{2,nominal}$ and $y_2, sh_2, f_{t2}, f_{y2}$, it is considered

characteristic value $f_{s2} = f_s/1.2$, from table 5.1, TBDY.

y_1, sh_1, ft_1, f_{y1} , are also multiplied by $\text{Min}(1, 1.25 \cdot (l_b/l_d)^{2/3})$, from 10.3.5, ASCE 41-17.

with $f_{s2} = f_s = 389.0139$

with $E_{s2} = E_s = 200000.00$

$y_v = 0.00140044$

$sh_v = 0.0044814$

$ft_v = 466.8167$

$f_{yv} = 389.0139$

$s_{uv} = 0.00512$

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor

and also multiplied by the shear_factor according to 15.7.1.4, with

Shear_factor = 1.00

$l_o/l_{o,min} = l_b/l_d = 0.30$

$s_{uv} = 0.4 \cdot e_{suv,nominal} ((5.5), TBDY) = 0.032$

From table 5A.1, TBDY: $e_{suv,nominal} = 0.08$,

considering characteristic value $f_{sv} = f_{sv}/1.2$, from table 5.1, TBDY

For calculation of $e_{suv,nominal}$ and y_v, sh_v, ft_v, f_{yv} , it is considered

characteristic value $f_{sv} = f_{sv}/1.2$, from table 5.1, TBDY.

y_1, sh_1, ft_1, f_{y1} , are also multiplied by $\text{Min}(1, 1.25 \cdot (l_b/l_d)^{2/3})$, from 10.3.5, ASCE 41-17.

with $f_{sv} = f_s = 389.0139$

with $E_{sv} = E_s = 200000.00$

1 = $As_{l,ten}/(b \cdot d) \cdot (f_{s1}/f_c) = 0.10166207$

2 = $As_{l,com}/(b \cdot d) \cdot (f_{s2}/f_c) = 0.06639156$

v = $As_{l,mid}/(b \cdot d) \cdot (f_{sv}/f_c) = 0.06777471$

and confined core properties:

b = 240.00

d = 327.00

d' = 12.00

f_{cc} (5A.2, TBDY) = 33.00

cc (5A.5, TBDY) = 0.002

c = confinement factor = 1.00

1 = $As_{l,ten}/(b \cdot d) \cdot (f_{s1}/f_c) = 0.13873608$

2 = $As_{l,com}/(b \cdot d) \cdot (f_{s2}/f_c) = 0.09060316$

v = $As_{l,mid}/(b \cdot d) \cdot (f_{sv}/f_c) = 0.09249072$

Case/Assumption: Unconfined full section - Steel rupture

' satisfies Eq. (4.3)

v < v_{s,y2} - LHS eq.(4.5) is satisfied

su (4.9) = 0.22379076

Mu = MRc (4.14) = 1.5703E+008

u = su (4.1) = 1.8476637E-005

Calculation of ratio l_b/l_d

Inadequate Lap Length with $l_b/l_d = 0.30$

Calculation of Shear Strength $V_r = \text{Min}(V_{r1}, V_{r2}) = 289894.477$

Calculation of Shear Strength at edge 1, $V_{r1} = 289894.477$

$V_{r1} = V_n ((22.5.1.1), ACI 318-14)$

NOTE: In expression (22.5.1.1) 'V_w' is replaced by 'V_w+ f*V_f'
where V_f is the contribution of FRPs (11.3), ACI 440).

From Table (22.5.5.1), ACI 318-14: $V_c = 103724.534$

= 1 (normal-weight concrete)

$f_c' = 33.00$, but $f_c'^{0.5} \leq 8.3$ MPa (22.5.3.1, ACI 318-14)

$p_w = A_s/(b_w \cdot d) = 0.00949023$

A_s (tension reinf.) = 911.0619

$b_w = 300.00$

d = 320.00

$V_u \cdot d / \text{Mu} < 1 = 1.00$

Mu = 71267.116

Vu = 2771.021

From (11.5.4.8), ACI 318-14: Vs = 186169.943

Av = 157079.633

fy = 555.56

s = 150.00

Vs has been multiplied by 1 ($s < d/2$, according to ASCE 41-17,10.3.4)

Vf ((11-3)-(11.4), ACI 440) = 0.00

From (11-11), ACI 440: Vs + Vf <= 366348.956

Calculation of Shear Strength at edge 2, Vr2 = 289894.477

Vr2 = Vn ((22.5.1.1), ACI 318-14)

NOTE: In expression (22.5.1.1) 'Vw' is replaced by 'Vw+ f*Vf' where Vf is the contribution of FRPs (11.3), ACI 440).

From Table (22.5.5.1), ACI 318-14: Vc = 103724.534

= 1 (normal-weight concrete)

fc' = 33.00, but $fc'^{0.5} \leq 8.3$ MPa (22.5.3.1, ACI 318-14)

pw = As/(bw*d) = 0.00949023

As (tension reinf.) = 911.0619

bw = 300.00

d = 320.00

Vu*d/Mu < 1 = 1.00

Mu = 71267.116

Vu = 2771.021

From (11.5.4.8), ACI 318-14: Vs = 186169.943

Av = 157079.633

fy = 555.56

s = 150.00

Vs has been multiplied by 1 ($s < d/2$, according to ASCE 41-17,10.3.4)

Vf ((11-3)-(11.4), ACI 440) = 0.00

From (11-11), ACI 440: Vs + Vf <= 366348.956

End Of Calculation of Shear Capacity ratio for element: beam B1 of floor 1
At local axis: 3

Start Of Calculation of Shear Capacity ratio for element: beam B1 of floor 1
At Shear local axis: 2
(Bending local axis: 3)
Section Type: rcars

Constant Properties

Knowledge Factor, = 1.00

Mean strength values are used for both shear and moment calculations.

Consequently:

New material of Secondary Member: Concrete Strength, fc = fcm = 33.00

New material of Secondary Member: Steel Strength, fs = fsm = 555.56

Concrete Elasticity, Ec = 26999.444

Steel Elasticity, Es = 200000.00

#####

Note: Especially for the calculation of moment strengths,

the above steel re-bar strengths are multiplied by 1.25 according to R18.6.5, ACI 318-14

New material: Steel Strength, fs = 1.25*fsm = 694.45

#####

Section Height, H = 400.00

Section Width, W = 300.00

Cover Thickness, c = 25.00

Mean Confinement Factor overall section = 1.00

Element Length, L = 1850.00

Secondary Member

Smooth Bars

Ductile Steel

Without Detailing for Earthquake Resistance (including stirrups not closed at 135°)
Longitudinal Bars With Ends Lapped Starting at the End Sections
Inadequate Lap Length with $l_o/l_{ou,min} = 0.30$
No FRP Wrapping

Stepwise Properties

At local axis: 2
EDGE -A-
Shear Force, $V_a = 4.9160836E-020$
EDGE -B-
Shear Force, $V_b = -4.9160836E-020$
BOTH EDGES
Axial Force, $F = -190.8684$
Longitudinal Reinforcement Area Distribution (in 2 divisions)
-Tension: $A_{st} = 911.0619$
-Compression: $A_{sc} = 1231.504$
Longitudinal Reinforcement Area Distribution (in 3 divisions)
-Tension: $A_{st,ten} = 816.8141$
-Compression: $A_{sc,com} = 816.8141$
-Middle: $A_{sc,mid} = 508.938$

Calculation of Shear Capacity ratio , $V_e/V_r = 0.54312483$
Member Controlled by Flexure ($V_e/V_r < 1$)
Calculation of Shear Demand from fig. R18.6.5, ACI 318-14 $V_e = (M_{pr1} + M_{pr2})/l_n \pm w_u \cdot l_n/2 = 104799.778$
with
 $M_{pr1} = \text{Max}(\mu_{u1+}, \mu_{u1-}) = 9.6940E+007$
 $\mu_{u1+} = 9.6940E+007$, is the ultimate moment strength at the edge 1 of the member in the actual moment direction
which is defined for the static loading combination
 $\mu_{u1-} = 9.6940E+007$, is the ultimate moment strength at the edge 1 of the member in the opposite moment
direction which is defined for the static loading combination
 $M_{pr2} = \text{Max}(\mu_{u2+}, \mu_{u2-}) = 9.6940E+007$
 $\mu_{u2+} = 9.6940E+007$, is the ultimate moment strength at the edge 2 of the member in the actual moment direction
which is defined for the the static loading combination
 $\mu_{u2-} = 9.6940E+007$, is the ultimate moment strength at the edge 2 of the member in the opposite moment
direction which is defined for the the static loading combination
and
 $\pm w_u \cdot l_n = (|V_1| + |V_2|)/2$
with
 $V_1 = 4.9160836E-020$, is the shear force acting at edge 1 for the the static loading combination
 $V_2 = -4.9160836E-020$, is the shear force acting at edge 2 for the the static loading combination

Calculation of μ_{u1+}

Calculation of ultimate curvature μ_u according to 4.1, Biskinis/Fardis 2013:
 $\mu_u = 2.5454950E-005$
 $\mu_u = 9.6940E+007$

with full section properties:

$b = 400.00$
 $d = 258.00$
 $d' = 42.00$
 $v = 5.6045447E-005$
 $N = 190.8684$
 $f_c = 33.00$
 α_1 (5A.5, TBDY) = 0.002
Final value of μ_u : $\mu_u^* = \text{shear_factor} * \text{Max}(\mu_u, \mu_c) = 0.00553582$
The Shear_factor is considered equal to 1 (pure moment strength)
From (5.4b), TBDY: $\mu_u = 0.00553582$
 μ_w (5.4c) = 0.00259035

ase ((5.4d), TBDY) = 0.15672608

bo = 240.00

ho = 340.00

bi2 = 346400.00

psh,min = Min(psh,x , psh,y) = 0.00261799

Expression ((5.4d), TBDY) for psh,min has been multiplied by 0.3 according to 15.7.1.3 for members without earthquake detailing (90° closed stirrups)

psh,x (5.4d) = 0.00349066

Ash = Astir*ns = 78.53982

No stirrups, ns = 2.00

bk = 300.00

psh,y (5.4d) = 0.00261799

Ash = Astir*ns = 78.53982

No stirrups, ns = 2.00

bk = 400.00

s = 150.00

fywe = 694.45

fce = 33.00

From ((5.A5), TBDY), TBDY: cc = 0.002

c = confinement factor = 1.00

y1 = 0.00140044

sh1 = 0.0044814

ft1 = 466.8167

fy1 = 389.0139

su1 = 0.00512

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor and also multiplied by the shear_factor according to 15.7.1.4, with Shear_factor = 1.00

lo/lou,min = lb/d = 0.30

su1 = 0.4*esu1_nominal ((5.5), TBDY) = 0.032

From table 5A.1, TBDY: esu1_nominal = 0.08,

For calculation of esu1_nominal and y1, sh1,ft1,fy1, it is considered characteristic value fsy1 = fs1/1.2, from table 5.1, TBDY.

y1, sh1,ft1,fy1, are also multiplied by Min(1,1.25*(lb/d)^2/3), from 10.3.5, ASCE 41-17.

with fs1 = fs = 389.0139

with Es1 = Es = 200000.00

y2 = 0.00140044

sh2 = 0.0044814

ft2 = 466.8167

fy2 = 389.0139

su2 = 0.00512

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor and also multiplied by the shear_factor according to 15.7.1.4, with Shear_factor = 1.00

lo/lou,min = lb/lb,min = 0.30

su2 = 0.4*esu2_nominal ((5.5), TBDY) = 0.032

From table 5A.1, TBDY: esu2_nominal = 0.08,

For calculation of esu2_nominal and y2, sh2,ft2,fy2, it is considered characteristic value fsy2 = fs2/1.2, from table 5.1, TBDY.

y1, sh1,ft1,fy1, are also multiplied by Min(1,1.25*(lb/d)^2/3), from 10.3.5, ASCE 41-17.

with fs2 = fs = 389.0139

with Es2 = Es = 200000.00

yv = 0.00140044

shv = 0.0044814

ftv = 466.8167

fyv = 389.0139

suv = 0.00512

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor and also multiplied by the shear_factor according to 15.7.1.4, with Shear_factor = 1.00

lo/lou,min = lb/d = 0.30

suv = 0.4*esuv_nominal ((5.5), TBDY) = 0.032

From table 5A.1, TBDY: esuv_nominal = 0.08,

considering characteristic value fsyv = fsv/1.2, from table 5.1, TBDY

For calculation of $e_{sv_nominal}$ and γ_v , sh_v , ft_v , fy_v , it is considered characteristic value $f_{sv} = f_{sv}/1.2$, from table 5.1, TBDY.

γ_1 , sh_1 , ft_1 , fy_1 , are also multiplied by $\text{Min}(1, 1.25 \cdot (l_b/l_d)^{2/3})$, from 10.3.5, ASCE 41-17.

with $f_{sv} = f_s = 389.0139$

with $E_{sv} = E_s = 200000.00$

1 = $Asl_{ten}/(b \cdot d) \cdot (f_{s1}/f_c) = 0.09330282$

2 = $Asl_{com}/(b \cdot d) \cdot (f_{s2}/f_c) = 0.09330282$

$v = Asl_{mid}/(b \cdot d) \cdot (f_{sv}/f_c) = 0.05813483$

and confined core properties:

$b = 340.00$

$d = 228.00$

$d' = 12.00$

f_{cc} (5A.2, TBDY) = 33.00

cc (5A.5, TBDY) = 0.002

c = confinement factor = 1.00

1 = $Asl_{ten}/(b \cdot d) \cdot (f_{s1}/f_c) = 0.12421118$

2 = $Asl_{com}/(b \cdot d) \cdot (f_{s2}/f_c) = 0.12421118$

$v = Asl_{mid}/(b \cdot d) \cdot (f_{sv}/f_c) = 0.07739312$

Case/Assumption: Unconfined full section - Steel rupture

' satisfies Eq. (4.3)

--->

$v < v_{s,y2}$ - LHS eq.(4.5) is satisfied

--->

su (4.9) = 0.22038892

$Mu = MRc$ (4.14) = 9.6940E+007

$u = su$ (4.1) = 2.5454950E-005

Calculation of ratio l_b/l_d

Inadequate Lap Length with $l_b/l_d = 0.30$

Calculation of Mu_1 -

Calculation of ultimate curvature u according to 4.1, Biskinis/Fardis 2013:

$u = 2.5454950E-005$

$Mu = 9.6940E+007$

with full section properties:

$b = 400.00$

$d = 258.00$

$d' = 42.00$

$v = 5.6045447E-005$

$N = 190.8684$

$f_c = 33.00$

co (5A.5, TBDY) = 0.002

Final value of cu : $cu^* = \text{shear_factor} \cdot \text{Max}(cu, cc) = 0.00553582$

The Shear_factor is considered equal to 1 (pure moment strength)

From (5.4b), TBDY: $cu = 0.00553582$

w_e (5.4c) = 0.00259035

ase ((5.4d), TBDY) = 0.15672608

$bo = 240.00$

$ho = 340.00$

$bi_2 = 346400.00$

$psh_{min} = \text{Min}(psh_x, psh_y) = 0.00261799$

Expression ((5.4d), TBDY) for psh_{min} has been multiplied by 0.3 according to 15.7.1.3 for members without earthquake detailing (90° closed stirrups)

 psh_x (5.4d) = 0.00349066

$A_{stir} = A_{stir} \cdot n_s = 78.53982$

No stirrups, $n_s = 2.00$

$bk = 300.00$

psh,y (5.4d) = 0.00261799
Ash = Astir*ns = 78.53982
No stirups, ns = 2.00
bk = 400.00

s = 150.00
fywe = 694.45
fce = 33.00
From ((5.A.5), TBDY), TBDY: cc = 0.002
c = confinement factor = 1.00

y1 = 0.00140044
sh1 = 0.0044814
ft1 = 466.8167
fy1 = 389.0139
su1 = 0.00512

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00

lo/lou,min = lb/d = 0.30

su1 = 0.4*esu1_nominal ((5.5), TBDY) = 0.032

From table 5A.1, TBDY: esu1_nominal = 0.08,

For calculation of esu1_nominal and y1, sh1,ft1,fy1, it is considered
characteristic value fsy1 = fs1/1.2, from table 5.1, TBDY.

y1, sh1,ft1,fy1, are also multiplied by $\text{Min}(1, 1.25 \cdot (lb/d)^{2/3})$, from 10.3.5, ASCE 41-17.

with fs1 = fs = 389.0139

with Es1 = Es = 200000.00

y2 = 0.00140044
sh2 = 0.0044814
ft2 = 466.8167
fy2 = 389.0139
su2 = 0.00512

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00

lo/lou,min = lb/lb,min = 0.30

su2 = 0.4*esu2_nominal ((5.5), TBDY) = 0.032

From table 5A.1, TBDY: esu2_nominal = 0.08,

For calculation of esu2_nominal and y2, sh2,ft2,fy2, it is considered
characteristic value fsy2 = fs2/1.2, from table 5.1, TBDY.

y1, sh1,ft1,fy1, are also multiplied by $\text{Min}(1, 1.25 \cdot (lb/d)^{2/3})$, from 10.3.5, ASCE 41-17.

with fs2 = fs = 389.0139

with Es2 = Es = 200000.00

yv = 0.00140044
shv = 0.0044814
ftv = 466.8167
fyv = 389.0139
suv = 0.00512

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00

lo/lou,min = lb/d = 0.30

suv = 0.4*esuv_nominal ((5.5), TBDY) = 0.032

From table 5A.1, TBDY: esuv_nominal = 0.08,

considering characteristic value fsyv = fsv/1.2, from table 5.1, TBDY
For calculation of esuv_nominal and yv, shv,ftv,fyv, it is considered
characteristic value fsyv = fsv/1.2, from table 5.1, TBDY.

y1, sh1,ft1,fy1, are also multiplied by $\text{Min}(1, 1.25 \cdot (lb/d)^{2/3})$, from 10.3.5, ASCE 41-17.

with fsv = fs = 389.0139

with Esv = Es = 200000.00

1 = Asl,ten/(b*d)*(fs1/fc) = 0.09330282

2 = Asl,com/(b*d)*(fs2/fc) = 0.09330282

v = Asl,mid/(b*d)*(fsv/fc) = 0.05813483

and confined core properties:

b = 340.00

d = 228.00

d' = 12.00

fcc (5A.2, TBDY) = 33.00

$$cc \text{ (5A.5, TBDY)} = 0.002$$

$$c = \text{confinement factor} = 1.00$$

$$1 = Asl,ten/(b*d)*(fs1/fc) = 0.12421118$$

$$2 = Asl,com/(b*d)*(fs2/fc) = 0.12421118$$

$$v = Asl,mid/(b*d)*(fsv/fc) = 0.07739312$$

Case/Assumption: Unconfined full section - Steel rupture
' satisfies Eq. (4.3)

--->

$v < vs,y2$ - LHS eq.(4.5) is satisfied

--->

$$su \text{ (4.9)} = 0.22038892$$

$$Mu = MRc \text{ (4.14)} = 9.6940E+007$$

$$u = su \text{ (4.1)} = 2.5454950E-005$$

Calculation of ratio lb/ld

Inadequate Lap Length with $lb/ld = 0.30$

Calculation of $Mu2+$

Calculation of ultimate curvature u according to 4.1, Biskinis/Fardis 2013:

$$u = 2.5454950E-005$$

$$Mu = 9.6940E+007$$

with full section properties:

$$b = 400.00$$

$$d = 258.00$$

$$d' = 42.00$$

$$v = 5.6045447E-005$$

$$N = 190.8684$$

$$fc = 33.00$$

$$co \text{ (5A.5, TBDY)} = 0.002$$

$$\text{Final value of } cu: cu^* = \text{shear_factor} * \text{Max}(cu, cc) = 0.00553582$$

The Shear_factor is considered equal to 1 (pure moment strength)

$$\text{From (5.4b), TBDY: } cu = 0.00553582$$

$$we \text{ (5.4c)} = 0.00259035$$

$$ase \text{ ((5.4d), TBDY)} = 0.15672608$$

$$bo = 240.00$$

$$ho = 340.00$$

$$bi2 = 346400.00$$

$$psh,min = \text{Min}(psh,x, psh,y) = 0.00261799$$

Expression ((5.4d), TBDY) for psh,min has been multiplied by 0.3 according to 15.7.1.3 for members without earthquake detailing (90° closed stirrups)

$$psh,x \text{ (5.4d)} = 0.00349066$$

$$Ash = Astir*ns = 78.53982$$

$$\text{No stirups, } ns = 2.00$$

$$bk = 300.00$$

$$psh,y \text{ (5.4d)} = 0.00261799$$

$$Ash = Astir*ns = 78.53982$$

$$\text{No stirups, } ns = 2.00$$

$$bk = 400.00$$

$$s = 150.00$$

$$fywe = 694.45$$

$$fce = 33.00$$

$$\text{From ((5.A5), TBDY), TBDY: } cc = 0.002$$

$$c = \text{confinement factor} = 1.00$$

$$y1 = 0.00140044$$

$$sh1 = 0.0044814$$

$$ft1 = 466.8167$$

$f_{y1} = 389.0139$
 $s_{u1} = 0.00512$
 using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
 and also multiplied by the shear_factor according to 15.7.1.4, with
 Shear_factor = 1.00
 $l_o/l_{ou,min} = l_b/l_d = 0.30$
 $s_{u1} = 0.4 * e_{su1,nominal} ((5.5), TBDY) = 0.032$
 From table 5A.1, TBDY: $e_{su1,nominal} = 0.08$,
 For calculation of $e_{su1,nominal}$ and y_1, sh_1, ft_1, f_{y1} , it is considered
 characteristic value $f_{sy1} = f_{s1}/1.2$, from table 5.1, TBDY.
 y_1, sh_1, ft_1, f_{y1} , are also multiplied by $\text{Min}(1, 1.25 * (l_b/l_d)^{2/3})$, from 10.3.5, ASCE 41-17.
 with $f_{s1} = f_s = 389.0139$
 with $E_{s1} = E_s = 200000.00$
 $y_2 = 0.00140044$
 $sh_2 = 0.0044814$
 $ft_2 = 466.8167$
 $f_{y2} = 389.0139$
 $s_{u2} = 0.00512$
 using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
 and also multiplied by the shear_factor according to 15.7.1.4, with
 Shear_factor = 1.00
 $l_o/l_{ou,min} = l_b/l_{b,min} = 0.30$
 $s_{u2} = 0.4 * e_{su2,nominal} ((5.5), TBDY) = 0.032$
 From table 5A.1, TBDY: $e_{su2,nominal} = 0.08$,
 For calculation of $e_{su2,nominal}$ and y_2, sh_2, ft_2, f_{y2} , it is considered
 characteristic value $f_{sy2} = f_{s2}/1.2$, from table 5.1, TBDY.
 y_2, sh_2, ft_2, f_{y2} , are also multiplied by $\text{Min}(1, 1.25 * (l_b/l_d)^{2/3})$, from 10.3.5, ASCE 41-17.
 with $f_{s2} = f_s = 389.0139$
 with $E_{s2} = E_s = 200000.00$
 $y_v = 0.00140044$
 $sh_v = 0.0044814$
 $ft_v = 466.8167$
 $f_{y_v} = 389.0139$
 $s_{u_v} = 0.00512$
 using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
 and also multiplied by the shear_factor according to 15.7.1.4, with
 Shear_factor = 1.00
 $l_o/l_{ou,min} = l_b/l_d = 0.30$
 $s_{u_v} = 0.4 * e_{su_v,nominal} ((5.5), TBDY) = 0.032$
 From table 5A.1, TBDY: $e_{su_v,nominal} = 0.08$,
 considering characteristic value $f_{sy_v} = f_{sv}/1.2$, from table 5.1, TBDY
 For calculation of $e_{su_v,nominal}$ and y_v, sh_v, ft_v, f_{y_v} , it is considered
 characteristic value $f_{sy_v} = f_{sv}/1.2$, from table 5.1, TBDY.
 y_1, sh_1, ft_1, f_{y1} , are also multiplied by $\text{Min}(1, 1.25 * (l_b/l_d)^{2/3})$, from 10.3.5, ASCE 41-17.
 with $f_{sv} = f_s = 389.0139$
 with $E_{sv} = E_s = 200000.00$
 $1 = A_{sl,ten}/(b*d)*(f_{s1}/f_c) = 0.09330282$
 $2 = A_{sl,com}/(b*d)*(f_{s2}/f_c) = 0.09330282$
 $v = A_{sl,mid}/(b*d)*(f_{sv}/f_c) = 0.05813483$
 and confined core properties:
 $b = 340.00$
 $d = 228.00$
 $d' = 12.00$
 $f_{cc} (5A.2, TBDY) = 33.00$
 $cc (5A.5, TBDY) = 0.002$
 $c = \text{confinement factor} = 1.00$
 $1 = A_{sl,ten}/(b*d)*(f_{s1}/f_c) = 0.12421118$
 $2 = A_{sl,com}/(b*d)*(f_{s2}/f_c) = 0.12421118$
 $v = A_{sl,mid}/(b*d)*(f_{sv}/f_c) = 0.07739312$
 Case/Assumption: Unconfined full section - Steel rupture
 ' satisfies Eq. (4.3)
 --->
 $v < v_{s,y2}$ - LHS eq.(4.5) is satisfied
 --->
 $s_u (4.9) = 0.22038892$
 $M_u = M_{Rc} (4.14) = 9.6940E+007$
 $u = s_u (4.1) = 2.5454950E-005$

Calculation of ratio l_b/l_d

Inadequate Lap Length with $l_b/l_d = 0.30$

Calculation of μ_2

Calculation of ultimate curvature μ according to 4.1, Biskinis/Fardis 2013:

$\mu = 2.5454950E-005$

$\mu_2 = 9.6940E+007$

with full section properties:

$b = 400.00$

$d = 258.00$

$d' = 42.00$

$v = 5.6045447E-005$

$N = 190.8684$

$f_c = 33.00$

ϕ_c (5A.5, TBDY) = 0.002

Final value of ϕ_{cu} : $\phi_{cu}^* = \text{shear_factor} * \text{Max}(\phi_{cu}, \phi_{cc}) = 0.00553582$

The Shear_factor is considered equal to 1 (pure moment strength)

From (5.4b), TBDY: $\phi_{cu} = 0.00553582$

ϕ_{we} (5.4c) = 0.00259035

ϕ_{ase} ((5.4d), TBDY) = 0.15672608

$b_o = 240.00$

$h_o = 340.00$

$b_i^2 = 346400.00$

$\phi_{psh,min} = \text{Min}(\phi_{psh,x}, \phi_{psh,y}) = 0.00261799$

Expression ((5.4d), TBDY) for $\phi_{psh,min}$ has been multiplied by 0.3 according to 15.7.1.3 for members without earthquake detailing (90° closed stirrups)

$\phi_{psh,x}$ (5.4d) = 0.00349066

$A_{sh} = A_{stir} * n_s = 78.53982$

No stirrups, $n_s = 2.00$

$b_k = 300.00$

$\phi_{psh,y}$ (5.4d) = 0.00261799

$A_{sh} = A_{stir} * n_s = 78.53982$

No stirrups, $n_s = 2.00$

$b_k = 400.00$

$s = 150.00$

$f_{ywe} = 694.45$

$f_{ce} = 33.00$

From ((5.A.5), TBDY), TBDY: $\phi_{cc} = 0.002$

$c = \text{confinement factor} = 1.00$

$\gamma_1 = 0.00140044$

$\gamma_{sh1} = 0.0044814$

$f_{t1} = 466.8167$

$f_{y1} = 389.0139$

$\gamma_{su1} = 0.00512$

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor and also multiplied by the shear_factor according to 15.7.1.4, with Shear_factor = 1.00

$l_o/l_{o,min} = l_b/l_d = 0.30$

$\gamma_{su1} = 0.4 * \gamma_{su1_nominal}$ ((5.5), TBDY) = 0.032

From table 5A.1, TBDY: $\gamma_{su1_nominal} = 0.08$,

For calculation of $\gamma_{su1_nominal}$ and $\gamma_1, \gamma_{sh1}, f_{t1}, f_{y1}$, it is considered characteristic value $f_{s\gamma1} = f_{s1}/1.2$, from table 5.1, TBDY.

$\gamma_1, \gamma_{sh1}, f_{t1}, f_{y1}$, are also multiplied by $\text{Min}(1, 1.25 * (l_b/l_d)^{2/3})$, from 10.3.5, ASCE 41-17.

with $f_{s1} = f_s = 389.0139$

with $E_{s1} = E_s = 200000.00$

y2 = 0.00140044
sh2 = 0.0044814
ft2 = 466.8167
fy2 = 389.0139
su2 = 0.00512

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00

lo/lou,min = lb/lb,min = 0.30

su2 = 0.4*esu2_nominal ((5.5), TBDY) = 0.032

From table 5A.1, TBDY: esu2_nominal = 0.08,

For calculation of esu2_nominal and y2, sh2,ft2,fy2, it is considered
characteristic value fsy2 = fs2/1.2, from table 5.1, TBDY.

y1, sh1,ft1,fy1, are also multiplied by $\text{Min}(1, 1.25 \cdot (lb/ld)^{2/3})$, from 10.3.5, ASCE 41-17.

with fs2 = fs = 389.0139

with Es2 = Es = 200000.00

yv = 0.00140044

shv = 0.0044814

ftv = 466.8167

fyv = 389.0139

suv = 0.00512

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00

lo/lou,min = lb/ld = 0.30

suv = 0.4*esuv_nominal ((5.5), TBDY) = 0.032

From table 5A.1, TBDY: esuv_nominal = 0.08,

considering characteristic value fsyv = fsv/1.2, from table 5.1, TBDY

For calculation of esuv_nominal and yv, shv,ftv,fyv, it is considered
characteristic value fsyv = fsv/1.2, from table 5.1, TBDY.

y1, sh1,ft1,fy1, are also multiplied by $\text{Min}(1, 1.25 \cdot (lb/ld)^{2/3})$, from 10.3.5, ASCE 41-17.

with fsv = fs = 389.0139

with Esv = Es = 200000.00

1 = Asl,ten/(b*d)*(fs1/fc) = 0.09330282

2 = Asl,com/(b*d)*(fs2/fc) = 0.09330282

v = Asl,mid/(b*d)*(fsv/fc) = 0.05813483

and confined core properties:

b = 340.00

d = 228.00

d' = 12.00

fcc (5A.2, TBDY) = 33.00

cc (5A.5, TBDY) = 0.002

c = confinement factor = 1.00

1 = Asl,ten/(b*d)*(fs1/fc) = 0.12421118

2 = Asl,com/(b*d)*(fs2/fc) = 0.12421118

v = Asl,mid/(b*d)*(fsv/fc) = 0.07739312

Case/Assumption: Unconfined full section - Steel rupture

' satisfies Eq. (4.3)

--->

v < vs,y2 - LHS eq.(4.5) is satisfied

--->

su (4.9) = 0.22038892

Mu = MRc (4.14) = 9.6940E+007

u = su (4.1) = 2.5454950E-005

Calculation of ratio lb/ld

Inadequate Lap Length with lb/ld = 0.30

Calculation of Shear Strength Vr = Min(Vr1,Vr2) = 192957.075

Calculation of Shear Strength at edge 1, Vr1 = 192957.075

Vr1 = Vn ((22.5.1.1), ACI 318-14)

NOTE: In expression (22.5.1.1) 'Vw' is replaced by 'Vw+ f*Vf'
where Vf is the contribution of FRPs (11.3), ACI 440).

From Table (22.5.5.1), ACI 318-14: $V_c = 88236.482$
= 1 (normal-weight concrete)
 $f_c' = 33.00$, but $f_c'^{0.5} \leq 8.3$ MPa (22.5.3.1, ACI 318-14)
 $\rho_w = A_s/(b_w*d) = 0.00949023$
 A_s (tension reinf.) = 911.0619
 $b_w = 400.00$
 $d = 240.00$
 $V_u*d/M_u < 1 = 0.00$
 $M_u = 3.3205266E-012$
 $V_u = 4.9160836E-020$

From (11.5.4.8), ACI 318-14: $V_s = 104720.593$
 $A_v = 157079.633$
 $f_y = 555.56$
 $s = 150.00$
 V_s has been multiplied by $2(1-s/d)$ ($s > d/2$, according to ASCE 41-17,10.3.4)
 $2(1-s/d) = 0.75$
 V_f ((11-3)-(11.4), ACI 440) = 0.00
From (11-11), ACI 440: $V_s + V_f \leq 366348.956$

Calculation of Shear Strength at edge 2, $V_{r2} = 192957.075$
 $V_{r2} = V_n$ ((22.5.1.1), ACI 318-14)

NOTE: In expression (22.5.1.1) 'Vw' is replaced by 'Vw+ f*Vf'
where Vf is the contribution of FRPs (11.3), ACI 440).

From Table (22.5.5.1), ACI 318-14: $V_c = 88236.482$
= 1 (normal-weight concrete)
 $f_c' = 33.00$, but $f_c'^{0.5} \leq 8.3$ MPa (22.5.3.1, ACI 318-14)
 $\rho_w = A_s/(b_w*d) = 0.00949023$
 A_s (tension reinf.) = 911.0619
 $b_w = 400.00$
 $d = 240.00$
 $V_u*d/M_u < 1 = 0.00$
 $M_u = 3.3203395E-012$
 $V_u = 4.9160836E-020$

From (11.5.4.8), ACI 318-14: $V_s = 104720.593$
 $A_v = 157079.633$
 $f_y = 555.56$
 $s = 150.00$
 V_s has been multiplied by $2(1-s/d)$ ($s > d/2$, according to ASCE 41-17,10.3.4)
 $2(1-s/d) = 0.75$
 V_f ((11-3)-(11.4), ACI 440) = 0.00
From (11-11), ACI 440: $V_s + V_f \leq 366348.956$

End Of Calculation of Shear Capacity ratio for element: beam B1 of floor 1
At local axis: 2

Start Of Calculation of Chord Rotation Capacity for element: beam B1 of floor 1
At local axis: 3
Integration Section: (a)
Section Type: rcars

Constant Properties

Knowledge Factor, = 1.00
Chord Rotation is generally considered as Deformation-Controlled Action according to Table C7-1, ASCE 41-17.
Mean strengths are used for Deformation-Controlled Actions according to 7.5.1.3, ASCE 41-17
Consequently:
New material of Secondary Member: Concrete Strength, $f_c = f_{cm} = 33.00$
New material of Secondary Member: Steel Strength, $f_s = f_{sm} = 555.56$

Concrete Elasticity, $E_c = 26999.444$
Steel Elasticity, $E_s = 200000.00$
Section Height, $H = 400.00$
Section Width, $W = 300.00$
Cover Thickness, $c = 25.00$
Element Length, $L = 1850.00$
Secondary Member
Smooth Bars
Ductile Steel
Without Detailing for Earthquake Resistance (including stirrups not closed at 135°)
Longitudinal Bars With Ends Lapped Starting at the End Sections
Inadequate Lap Length with $l_b/l_d = 0.30$
No FRP Wrapping

Stepwise Properties

Bending Moment, $M = 1.8089301E-011$
Shear Force, $V_2 = 3.3781306E-014$
Shear Force, $V_3 = -1933.33$
Axial Force, $F = -457.6821$
Longitudinal Reinforcement Area Distribution (in 2 divisions)
-Tension: $A_{st} = 911.0619$
-Compression: $A_{sc} = 1231.504$
Longitudinal Reinforcement Area Distribution (in 3 divisions)
-Tension: $A_{s,ten} = 816.8141$
-Compression: $A_{s,com} = 816.8141$
-Middle: $A_{s,mid} = 508.938$
Mean Diameter of Tension Reinforcement, $D_bL = 14.40$

New component: From table 7-7, ASCE 41_17: Final chord rotation Capacity $u_{,R} = 1.0^*$ $u = 0.02295003$
 $u = y + p = 0.02295003$

- Calculation of y -

$y = (M_y * L_s / 3) / E_{eff} = 0.00295003$ ((4.29), Biskinis Phd)
 $M_y = 6.9747E+007$
 $L_s = M/V$ (with $L_s > 0.1 * L$ and $L_s < 2 * L$) = 925.00
From table 10.5, ASCE 41_17: $E_{eff} = 0.3 * E_c * I_g = 7.2898E+012$

Calculation of Yielding Moment M_y

Calculation of y and M_y according to Annex 7 -

$y = \text{Min}(y_{ten}, y_{com})$
 $y_{ten} = 8.5713381E-006$
with ((10.1), ASCE 41-17) $f_y = \text{Min}(f_y, 1.25 * f_y * (l_b/l_d)^{2/3}) = 311.2112$
 $d = 258.00$
 $y = 0.29634979$
 $A = 0.02077555$
 $B = 0.01208477$
with $p_t = 0.00791487$
 $p_c = 0.00791487$
 $p_v = 0.00493157$
 $N = 457.6821$
 $b = 400.00$
 $" = 0.1627907$
 $y_{comp} = 2.8785724E-005$
with $f_c = 33.00$
 $E_c = 26999.444$
 $y = 0.2962339$

A = 0.02075122
B = 0.01207052
with Es = 200000.00

Calculation of ratio l_b/d

Inadequate Lap Length with $l_b/d = 0.30$

- Calculation of ρ -

From table 10-7: $\rho = 0.02$

with:

- Condition iv occurred

Beam controlled by inadequate embedment into beam-column joint:
($l_b/d < 1$ and With Lapping in the Vicinity of the End Regions

- Condition i occurred

Beam controlled by flexure: $V_p/V_o \leq 1$

shear control ratio $V_p/V_o = 0.54312483$

- Transverse Reinforcement: NC

- Stirrup Spacing $> d/3$

- Low ductility demand, $\lambda / y < 2$ (table 10-6, ASCE 41-17)

= -1.1216772E-023

- Stirrup Spacing $> d/2$

d = 258.00

s = 150.00

- Strength provided by hoops $V_s < 3/4$ *design Shear

$V_s = 139627.457$, already given in calculation of shear control ratio

design Shear = 3.3781306E-014

- ($\rho - \rho'$)/ bal = -0.18222013

= $A_{st}/(b_w*d) = 0.00882812$

Tension Reinf Area: $A_{st} = 911.0619$

$\rho' = A_{sc}/(b_w*d) = 0.01193318$

Compression Reinf Area: $A_{sc} = 1231.504$

From (B-1), ACI 318-11: bal = 0.01704017

$f_c = 33.00$

$f_y = 555.56$

From 10.2.7.3, ACI 318-11: $\lambda = 0.65$

From fig R10.3.3, ACI 318-11 (Ence 454, too): $87000/(87000+f_y) = c_b/d_t = 0.003/(0.003+ \lambda) = 0.51922877$

$\lambda = 0.0027778$

- $V/(b_w*d*f_c^{0.5}) = 6.8621941E-019$, NOTE: units in lb & in

$b_w = 400.00$

End Of Calculation of Chord Rotation Capacity for element: beam B1 of floor 1

At local axis: 3

Integration Section: (a)

Calculation No. 13

beam B1, Floor 1



Limit State: Life Safety (data interpolation between analysis steps 1 and 2)

Analysis: Uniform +X

Check: Shear capacity VRd

Edge: End

Local Axis: (2)



Start Of Calculation of Shear Capacity for element: beam B1 of floor 1

At local axis: 2

Integration Section: (b)

Section Type: rcars

Constant Properties

Knowledge Factor, $\gamma = 1.00$

Member Shear Force is generally considered as Force-Controlled Action according to Table C7-1, ASCE 41-17.

Lower-bound strengths are used for Force-Controlled Actions according to 7.5.1.3, ASCE 41-17

Consequently:

New material of Secondary Member: Concrete Strength, $f_c = f_{c_lower_bound} = 25.00$

New material of Secondary Member: Steel Strength, $f_s = f_{s_lower_bound} = 500.00$

Concrete Elasticity, $E_c = 26999.444$

Steel Elasticity, $E_s = 200000.00$

Section Height, $H = 400.00$

Section Width, $W = 300.00$

Cover Thickness, $c = 25.00$

Element Length, $L = 1850.00$

Secondary Member

Smooth Bars

Ductile Steel

Without Detailing for Earthquake Resistance (including stirrups not closed at 135°)

Longitudinal Bars With Ends Lapped Starting at the End Sections

Inadequate Lap Length with $l_o/l_{o,min} = l_b/l_d = 0.30$

No FRP Wrapping

Stepwise Properties

EDGE -A-

Bending Moment, $M_a = 1.8089301E-011$

Shear Force, $V_a = 3.3781306E-014$

EDGE -B-

Bending Moment, $M_b = 4.4346397E-011$

Shear Force, $V_b = -3.3781306E-014$

BOTH EDGES

Axial Force, $F = -457.6821$

Longitudinal Reinforcement Area Distribution (in 2 divisions)

-Tension: $As_t = 923.6282$
-Compression: $As_c = 1218.938$
Longitudinal Reinforcement Area Distribution (in 3 divisions)
-Tension: $As_{t,ten} = 816.8141$
-Compression: $As_{l,com} = 816.8141$
-Middle: $As_{l,mid} = 508.938$
Mean Diameter of Tension Reinforcement, $Db_{L,ten} = 14.40$

New component: From table 7-7, ASCE 41_17: Final Shear Capacity $VR = 1.0 \cdot V_n = 171047.78$
 V_n ((22.5.1.1), ACI 318-14) = 171047.78

NOTE: In expression (22.5.1.1) ' V_w ' is replaced by ' $V_w + f \cdot V_f$ '
where V_f is the contribution of FRPs (11.3), ACI 440).

From Table (22.5.5.1), ACI 318-14: $V_c = 76800.00$
= 1 (normal-weight concrete)
 $f_c' = 25.00$, but $f_c'^{0.5} \leq 8.3$ MPa (22.5.3.1, ACI 318-14)
 $\rho_w = As/(b_w \cdot d) = 0.00962113$
 As (tension reinf.) = 923.6282
 $b_w = 400.00$
 $d = 240.00$
 $V_u \cdot d / M_u < 1 = 0.00$
 $M_u = 4.4346397E-011$
 $V_u = 3.3781306E-014$

From (11.5.4.8), ACI 318-14: $V_s = 94247.78$
 $A_v = 157079.633$
 $f_y = 500.00$
 $s = 150.00$

V_s has been multiplied by $2(1-s/d)$ ($s > d/2$, according to ASCE 41-17,10.3.4)

$2(1-s/d) = 0.75$

V_f ((11-3)-(11.4), ACI 440) = 0.00

From (11-11), ACI 440: $V_s + V_f \leq 318865.838$

End Of Calculation of Shear Capacity for element: beam B1 of floor 1
At local axis: 2
Integration Section: (b)

Calculation No. 14

beam B1, Floor 1



Limit State: Life Safety (data interpolation between analysis steps 1 and 2)

Analysis: Uniform +X

Check: Chord rotation capacity (θ)

Edge: End

Local Axis: (2)



Start Of Calculation of Shear Capacity ratio for element: beam B1 of floor 1

At Shear local axis: 3
 (Bending local axis: 2)
 Section Type: rcars

Constant Properties

 Knowledge Factor, $\gamma = 1.00$
 Mean strength values are used for both shear and moment calculations.
 Consequently:
 New material of Secondary Member: Concrete Strength, $f_c = f_{cm} = 33.00$
 New material of Secondary Member: Steel Strength, $f_s = f_{sm} = 555.56$
 Concrete Elasticity, $E_c = 26999.444$
 Steel Elasticity, $E_s = 200000.00$

 Note: Especially for the calculation of moment strengths,
 the above steel re-bar strengths are multiplied by 1.25 according to R18.6.5, ACI 318-14
 New material: Steel Strength, $f_s = 1.25 \cdot f_{sm} = 694.45$

 Section Height, $H = 400.00$
 Section Width, $W = 300.00$
 Cover Thickness, $c = 25.00$
 Mean Confinement Factor overall section = 1.00
 Element Length, $L = 1850.00$
 Secondary Member
 Smooth Bars
 Ductile Steel
 Without Detailing for Earthquake Resistance (including stirrups not closed at 135°)
 Longitudinal Bars With Ends Lapped Starting at the End Sections
 Inadequate Lap Length with $l_o/l_{ou,min} = 0.30$
 No FRP Wrapping

 Stepwise Properties

 At local axis: 3
 EDGE -A-
 Shear Force, $V_a = 2771.021$
 EDGE -B-
 Shear Force, $V_b = 2771.021$
 BOTH EDGES
 Axial Force, $F = -190.8684$
 Longitudinal Reinforcement Area Distribution (in 2 divisions)
 -Tension: $A_{sl,t} = 911.0619$
 -Compression: $A_{sl,c} = 1231.504$
 Longitudinal Reinforcement Area Distribution (in 3 divisions)
 -Tension: $A_{sl,ten} = 603.1858$
 -Compression: $A_{sl,com} = 923.6282$
 -Middle: $A_{sl,mid} = 615.7522$

Calculation of Shear Capacity ratio , $V_e/V_r = 0.59550037$

Member Controlled by Flexure ($V_e/V_r < 1$)

Calculation of Shear Demand from fig. R18.6.5, ACI 318-14 $V_e = (M_{pr1} + M_{pr2})/l_n \pm w_u \cdot l_n/2 = 172632.267$
with

$M_{pr1} = \text{Max}(M_{u1+} , M_{u1-}) = 1.5721E+008$

$M_{u1+} = 1.1233E+008$, is the ultimate moment strength at the edge 1 of the member in the actual moment direction which is defined for the static loading combination

$M_{u1-} = 1.5721E+008$, is the ultimate moment strength at the edge 1 of the member in the opposite moment direction which is defined for the static loading combination

$M_{pr2} = \text{Max}(M_{u2+} , M_{u2-}) = 1.5703E+008$

$M_{u2+} = 1.1247E+008$, is the ultimate moment strength at the edge 2 of the member in the actual moment direction which is defined for the the static loading combination

$M_{u2-} = 1.5703E+008$, is the ultimate moment strength at the edge 2 of the member in the opposite moment direction which is defined for the the static loading combination

and

$\pm w_u \cdot l_n = (|V_1| + |V_2|)/2$

with

$V_1 = 2771.021$, is the shear force acting at edge 1 for the the static loading combination

$V_2 = 2771.021$, is the shear force acting at edge 2 for the the static loading combination

Calculation of M_{u1+}

Calculation of ultimate curvature ϕ_u according to 4.1, Biskinis/Fardis 2013:

$\phi_u = 1.7687265E-005$

$M_u = 1.1233E+008$

with full section properties:

$b = 300.00$

$d = 357.00$

$d' = 42.00$

$v = 5.4004576E-005$

$N = 190.8684$

$f_c = 33.00$

ϕ_c (5A.5, TBDY) = 0.002

Final value of ϕ_u : $\phi_u^* = \text{shear_factor} * \text{Max}(\phi_c, \phi_c) = 0.00553582$

The Shear_factor is considered equal to 1 (pure moment strength)

From (5.4b), TBDY: $\phi_u = 0.00553582$

w_e (5.4c) = 0.00259035

a_{se} ((5.4d), TBDY) = 0.15672608

$b_o = 240.00$

$h_o = 340.00$

$b_{i2} = 346400.00$

$\phi_{sh,min} = \text{Min}(\phi_{sh,x} , \phi_{sh,y}) = 0.00261799$

Expression ((5.4d), TBDY) for $\phi_{sh,min}$ has been multiplied by 0.3 according to 15.7.1.3 for members without earthquake detailing (90° closed stirrups)

 $\phi_{sh,x}$ (5.4d) = 0.00349066

$A_{sh} = A_{stir} \cdot n_s = 78.53982$

No stirrups, $n_s = 2.00$

$b_k = 300.00$

 $\phi_{sh,y}$ (5.4d) = 0.00261799

$A_{sh} = A_{stir} \cdot n_s = 78.53982$

No stirrups, $n_s = 2.00$

$b_k = 400.00$

 $s = 150.00$

$f_{ywe} = 694.45$

$f_{ce} = 33.00$

From ((5.A5), TBDY), TBDY: $\phi_c = 0.002$

$c = \text{confinement factor} = 1.00$

$y_1 = 0.00140044$

$sh_1 = 0.0044814$

$$ft1 = 466.8167$$

$$fy1 = 389.0139$$

$$su1 = 0.00512$$

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00

$$lo/lou,min = lb/d = 0.30$$

$$su1 = 0.4*esu1_nominal ((5.5), TBDY) = 0.032$$

From table 5A.1, TBDY: esu1_nominal = 0.08,

For calculation of esu1_nominal and y1, sh1,ft1,fy1, it is considered
characteristic value fsy1 = fs1/1.2, from table 5.1, TBDY.

y1, sh1,ft1,fy1, are also multiplied by $\text{Min}(1, 1.25*(lb/d)^{2/3})$, from 10.3.5, ASCE 41-17.

$$\text{with } fs1 = fs = 389.0139$$

$$\text{with } Es1 = Es = 200000.00$$

$$y2 = 0.00140044$$

$$sh2 = 0.0044814$$

$$ft2 = 466.8167$$

$$fy2 = 389.0139$$

$$su2 = 0.00512$$

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00

$$lo/lou,min = lb/lb,min = 0.30$$

$$su2 = 0.4*esu2_nominal ((5.5), TBDY) = 0.032$$

From table 5A.1, TBDY: esu2_nominal = 0.08,

For calculation of esu2_nominal and y2, sh2,ft2,fy2, it is considered
characteristic value fsy2 = fs2/1.2, from table 5.1, TBDY.

y1, sh1,ft1,fy1, are also multiplied by $\text{Min}(1, 1.25*(lb/d)^{2/3})$, from 10.3.5, ASCE 41-17.

$$\text{with } fs2 = fs = 389.0139$$

$$\text{with } Es2 = Es = 200000.00$$

$$yv = 0.00140044$$

$$shv = 0.0044814$$

$$ftv = 466.8167$$

$$fyv = 389.0139$$

$$suv = 0.00512$$

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00

$$lo/lou,min = lb/d = 0.30$$

$$suv = 0.4*esuv_nominal ((5.5), TBDY) = 0.032$$

From table 5A.1, TBDY: esuv_nominal = 0.08,

considering characteristic value fsyv = fsv/1.2, from table 5.1, TBDY

For calculation of esuv_nominal and yv, shv,ftv,fyv, it is considered
characteristic value fsyv = fsv/1.2, from table 5.1, TBDY.

y1, sh1,ft1,fy1, are also multiplied by $\text{Min}(1, 1.25*(lb/d)^{2/3})$, from 10.3.5, ASCE 41-17.

$$\text{with } fsv = fs = 389.0139$$

$$\text{with } Esv = Es = 200000.00$$

$$1 = Asl,ten/(b*d)*(fs1/fc) = 0.06639156$$

$$2 = Asl,com/(b*d)*(fs2/fc) = 0.10166207$$

$$v = Asl,mid/(b*d)*(fsv/fc) = 0.06777471$$

and confined core properties:

$$b = 240.00$$

$$d = 327.00$$

$$d' = 12.00$$

$$fcc (5A.2, TBDY) = 33.00$$

$$cc (5A.5, TBDY) = 0.002$$

$$c = \text{confinement factor} = 1.00$$

$$1 = Asl,ten/(b*d)*(fs1/fc) = 0.09060316$$

$$2 = Asl,com/(b*d)*(fs2/fc) = 0.13873608$$

$$v = Asl,mid/(b*d)*(fsv/fc) = 0.09249072$$

Case/Assumption: Unconfined full section - Steel rupture

' satisfies Eq. (4.3)

--->

v < vs,y2 - LHS eq.(4.5) is satisfied

--->

$$su (4.9) = 0.189149$$

$$Mu = MRc (4.14) = 1.1233E+008$$

$$u = s_u(4.1) = 1.7687265E-005$$

Calculation of ratio l_b/d

Inadequate Lap Length with $l_b/d = 0.30$

Calculation of μ_1 -

Calculation of ultimate curvature μ according to 4.1, Biskinis/Fardis 2013:

$$u = 1.8434312E-005$$

$$\mu = 1.5721E+008$$

with full section properties:

$$b = 300.00$$

$$d = 358.00$$

$$d' = 43.00$$

$$v = 5.3853726E-005$$

$$N = 190.8684$$

$$f_c = 33.00$$

$$c_o(5A.5, \text{TB DY}) = 0.002$$

$$\text{Final value of } c_u: c_u^* = \text{shear_factor} * \text{Max}(c_u, c_c) = 0.00553582$$

The Shear_factor is considered equal to 1 (pure moment strength)

$$\text{From (5.4b), TB DY: } c_u = 0.00553582$$

$$w_e(5.4c) = 0.00259035$$

$$a_{se}((5.4d), \text{TB DY}) = 0.15672608$$

$$b_o = 240.00$$

$$h_o = 340.00$$

$$b_{i2} = 346400.00$$

$$p_{sh,min} = \text{Min}(p_{sh,x}, p_{sh,y}) = 0.00261799$$

Expression ((5.4d), TB DY) for $p_{sh,min}$ has been multiplied by 0.3 according to 15.7.1.3 for members without earthquake detailing (90° closed stirrups)

$$p_{sh,x}(5.4d) = 0.00349066$$

$$A_{sh} = A_{stir} * n_s = 78.53982$$

$$\text{No stirrups, } n_s = 2.00$$

$$b_k = 300.00$$

$$p_{sh,y}(5.4d) = 0.00261799$$

$$A_{sh} = A_{stir} * n_s = 78.53982$$

$$\text{No stirrups, } n_s = 2.00$$

$$b_k = 400.00$$

$$s = 150.00$$

$$f_{ywe} = 694.45$$

$$f_{ce} = 33.00$$

$$\text{From ((5.A5), TB DY), TB DY: } c_c = 0.002$$

$$c = \text{confinement factor} = 1.00$$

$$y_1 = 0.00140044$$

$$sh_1 = 0.0044814$$

$$ft_1 = 466.8167$$

$$fy_1 = 389.0139$$

$$su_1 = 0.00512$$

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor and also multiplied by the shear_factor according to 15.7.1.4, with Shear_factor = 1.00

$$l_o/l_{o,min} = l_b/d = 0.30$$

$$su_1 = 0.4 * esu_1_{nominal}((5.5), \text{TB DY}) = 0.032$$

$$\text{From table 5A.1, TB DY: } esu_1_{nominal} = 0.08,$$

For calculation of $esu_1_{nominal}$ and y_1, sh_1, ft_1, fy_1 , it is considered characteristic value $fsy_1 = fs_1/1.2$, from table 5.1, TB DY.

y_1, sh_1, ft_1, fy_1 , are also multiplied by $\text{Min}(1, 1.25 * (l_b/d)^{2/3})$, from 10.3.5, ASCE 41-17.

$$\text{with } fs_1 = fs = 389.0139$$

with $E_{s1} = E_s = 200000.00$
 $y_2 = 0.00140044$
 $sh_2 = 0.0044814$
 $ft_2 = 466.8167$
 $fy_2 = 389.0139$
 $su_2 = 0.00512$
 using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
 and also multiplied by the shear_factor according to 15.7.1.4, with
 Shear_factor = 1.00
 $l_0/l_{ou,min} = l_b/l_{b,min} = 0.30$
 $su_2 = 0.4 * esu_{2,nominal} ((5.5), TBDY) = 0.032$
 From table 5A.1, TBDY: $esu_{2,nominal} = 0.08$,
 For calculation of $esu_{2,nominal}$ and y_2, sh_2, ft_2, fy_2 , it is considered
 characteristic value $fs_2 = fs_2/1.2$, from table 5.1, TBDY.
 y_1, sh_1, ft_1, fy_1 , are also multiplied by $Min(1, 1.25 * (l_b/l_d)^{2/3})$, from 10.3.5, ASCE 41-17.
 with $fs_2 = fs = 389.0139$
 with $E_{s2} = E_s = 200000.00$
 $y_v = 0.00140044$
 $sh_v = 0.0044814$
 $ft_v = 466.8167$
 $fy_v = 389.0139$
 $suv = 0.00512$
 using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
 and also multiplied by the shear_factor according to 15.7.1.4, with
 Shear_factor = 1.00
 $l_0/l_{ou,min} = l_b/l_d = 0.30$
 $suv = 0.4 * esuv_{nominal} ((5.5), TBDY) = 0.032$
 From table 5A.1, TBDY: $esuv_{nominal} = 0.08$,
 considering characteristic value $fs_{yv} = fs_v/1.2$, from table 5.1, TBDY
 For calculation of $esuv_{nominal}$ and y_v, sh_v, ft_v, fy_v , it is considered
 characteristic value $fs_{yv} = fs_v/1.2$, from table 5.1, TBDY.
 y_1, sh_1, ft_1, fy_1 , are also multiplied by $Min(1, 1.25 * (l_b/l_d)^{2/3})$, from 10.3.5, ASCE 41-17.
 with $fs_v = fs = 389.0139$
 with $E_{sv} = E_s = 200000.00$
 $1 = A_{sl,ten}/(b*d) * (fs_1/f_c) = 0.1013781$
 $2 = A_{sl,com}/(b*d) * (fs_2/f_c) = 0.06620611$
 $v = A_{sl,mid}/(b*d) * (fs_v/f_c) = 0.0675854$
 and confined core properties:
 $b = 240.00$
 $d = 328.00$
 $d' = 13.00$
 $f_{cc} (5A.2, TBDY) = 33.00$
 $cc (5A.5, TBDY) = 0.002$
 $c = \text{confinement factor} = 1.00$
 $1 = A_{sl,ten}/(b*d) * (fs_1/f_c) = 0.13831311$
 $2 = A_{sl,com}/(b*d) * (fs_2/f_c) = 0.09032693$
 $v = A_{sl,mid}/(b*d) * (fs_v/f_c) = 0.09220874$
 Case/Assumption: Unconfined full section - Steel rupture
 ' satisfies Eq. (4.3)
 --->
 $v < v_s, y_2$ - LHS eq.(4.5) is satisfied
 --->
 $su (4.9) = 0.22418173$
 $Mu = MRc (4.14) = 1.5721E+008$
 $u = su (4.1) = 1.8434312E-005$

 Calculation of ratio l_b/l_d

Inadequate Lap Length with $l_b/l_d = 0.30$

Calculation of Mu_{2+}

Calculation of ultimate curvature ϕ_u according to 4.1, Biskinis/Fardis 2013:

$$u = 1.7651391E-005$$

$$Mu = 1.1247E+008$$

with full section properties:

$$b = 300.00$$

$$d = 358.00$$

$$d' = 43.00$$

$$v = 5.3853726E-005$$

$$N = 190.8684$$

$$f_c = 33.00$$

$$c_o \text{ (5A.5, TBDY)} = 0.002$$

$$\text{Final value of } \phi_u: \phi_u^* = \text{shear_factor} * \text{Max}(\phi_u, \phi_c) = 0.00553582$$

The Shear_factor is considered equal to 1 (pure moment strength)

$$\text{From (5.4b), TBDY: } \phi_u = 0.00553582$$

$$w_e \text{ (5.4c)} = 0.00259035$$

$$a_{se} \text{ ((5.4d), TBDY)} = 0.15672608$$

$$b_o = 240.00$$

$$h_o = 340.00$$

$$b_{i2} = 346400.00$$

$$\text{psh,min} = \text{Min}(\text{psh,x}, \text{psh,y}) = 0.00261799$$

Expression ((5.4d), TBDY) for psh,min has been multiplied by 0.3 according to 15.7.1.3 for members without earthquake detailing (90° closed stirrups)

$$\text{psh,x (5.4d)} = 0.00349066$$

$$A_{sh} = A_{stir} * n_s = 78.53982$$

$$\text{No stirrups, } n_s = 2.00$$

$$b_k = 300.00$$

$$\text{psh,y (5.4d)} = 0.00261799$$

$$A_{sh} = A_{stir} * n_s = 78.53982$$

$$\text{No stirrups, } n_s = 2.00$$

$$b_k = 400.00$$

$$s = 150.00$$

$$f_{ywe} = 694.45$$

$$f_{ce} = 33.00$$

$$\text{From ((5.A5), TBDY), TBDY: } \phi_c = 0.002$$

$$c = \text{confinement factor} = 1.00$$

$$y_1 = 0.00140044$$

$$sh_1 = 0.0044814$$

$$ft_1 = 466.8167$$

$$fy_1 = 389.0139$$

$$su_1 = 0.00512$$

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00

$$l_o/l_{o,u,min} = l_b/l_d = 0.30$$

$$su_1 = 0.4 * \text{esu1_nominal} \text{ ((5.5), TBDY)} = 0.032$$

$$\text{From table 5A.1, TBDY: } \text{esu1_nominal} = 0.08,$$

For calculation of esu1_nominal and y_1, sh_1, ft_1, fy_1 , it is considered
characteristic value $fs_1 = fs_1/1.2$, from table 5.1, TBDY.

$$y_1, sh_1, ft_1, fy_1, \text{ are also multiplied by } \text{Min}(1, 1.25 * (l_b/l_d)^{2/3}), \text{ from 10.3.5, ASCE 41-17.}$$

$$\text{with } fs_1 = fs = 389.0139$$

$$\text{with } E_{s1} = E_s = 200000.00$$

$$y_2 = 0.00140044$$

$$sh_2 = 0.0044814$$

$$ft_2 = 466.8167$$

$$fy_2 = 389.0139$$

$$su_2 = 0.00512$$

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00

$$l_o/l_{o,u,min} = l_b/l_{b,min} = 0.30$$

$$su_2 = 0.4 * \text{esu2_nominal} \text{ ((5.5), TBDY)} = 0.032$$

$$\text{From table 5A.1, TBDY: } \text{esu2_nominal} = 0.08,$$

For calculation of esu2_nominal and y_2, sh_2, ft_2, fy_2 , it is considered

characteristic value $f_{sy2} = f_{s2}/1.2$, from table 5.1, TBDY.

y_1, sh_1, ft_1, f_{y1} , are also multiplied by $\text{Min}(1, 1.25 \cdot (l_b/l_d)^{2/3})$, from 10.3.5, ASCE 41-17.

with $f_{s2} = f_s = 389.0139$

with $E_{s2} = E_s = 200000.00$

$y_v = 0.00140044$

$sh_v = 0.0044814$

$ft_v = 466.8167$

$f_{yv} = 389.0139$

$s_{uv} = 0.00512$

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor

and also multiplied by the shear_factor according to 15.7.1.4, with

Shear_factor = 1.00

$l_o/l_{o,min} = l_b/l_d = 0.30$

$s_{uv} = 0.4 \cdot e_{suv,nominal} ((5.5), TBDY) = 0.032$

From table 5A.1, TBDY: $e_{suv,nominal} = 0.08$,

considering characteristic value $f_{syv} = f_{sv}/1.2$, from table 5.1, TBDY

For calculation of $e_{suv,nominal}$ and y_v, sh_v, ft_v, f_{yv} , it is considered

characteristic value $f_{syv} = f_{sv}/1.2$, from table 5.1, TBDY.

y_1, sh_1, ft_1, f_{y1} , are also multiplied by $\text{Min}(1, 1.25 \cdot (l_b/l_d)^{2/3})$, from 10.3.5, ASCE 41-17.

with $f_{sv} = f_s = 389.0139$

with $E_{sv} = E_s = 200000.00$

1 = $As_{l,ten}/(b \cdot d) \cdot (f_{s1}/f_c) = 0.06620611$

2 = $As_{l,com}/(b \cdot d) \cdot (f_{s2}/f_c) = 0.1013781$

v = $As_{l,mid}/(b \cdot d) \cdot (f_{sv}/f_c) = 0.0675854$

and confined core properties:

b = 240.00

d = 328.00

d' = 13.00

f_{cc} (5A.2, TBDY) = 33.00

cc (5A.5, TBDY) = 0.002

c = confinement factor = 1.00

1 = $As_{l,ten}/(b \cdot d) \cdot (f_{s1}/f_c) = 0.09032693$

2 = $As_{l,com}/(b \cdot d) \cdot (f_{s2}/f_c) = 0.13831311$

v = $As_{l,mid}/(b \cdot d) \cdot (f_{sv}/f_c) = 0.09220874$

Case/Assumption: Unconfined full section - Steel rupture

' satisfies Eq. (4.3)

--->

v < v_{s,y2} - LHS eq.(4.5) is satisfied

--->

su (4.9) = 0.18977061

Mu = MRc (4.14) = 1.1247E+008

u = su (4.1) = 1.7651391E-005

Calculation of ratio l_b/l_d

Inadequate Lap Length with $l_b/l_d = 0.30$

Calculation of Mu2-

Calculation of ultimate curvature ϕ_u according to 4.1, Biskinis/Fardis 2013:

u = 1.8476637E-005

Mu = 1.5703E+008

with full section properties:

b = 300.00

d = 357.00

d' = 42.00

v = 5.4004576E-005

N = 190.8684

f_c = 33.00

co (5A.5, TBDY) = 0.002

Final value of ϕ_u : $\phi_u^* = \text{shear_factor} \cdot \text{Max}(\phi_u, \phi_c) = 0.00553582$

The Shear_factor is considered equal to 1 (pure moment strength)

From (5.4b), TBDY: $c_u = 0.00553582$

w_e (5.4c) = 0.00259035

a_{se} ((5.4d), TBDY) = 0.15672608

$b_o = 240.00$

$h_o = 340.00$

$b_{i2} = 346400.00$

$p_{sh,min} = \text{Min}(p_{sh,x}, p_{sh,y}) = 0.00261799$

Expression ((5.4d), TBDY) for $p_{sh,min}$ has been multiplied by 0.3 according to 15.7.1.3 for members without earthquake detailing (90° closed stirrups)

 $p_{sh,x}$ (5.4d) = 0.00349066

$A_{sh} = A_{stir} * n_s = 78.53982$

No stirrups, $n_s = 2.00$

$b_k = 300.00$

 $p_{sh,y}$ (5.4d) = 0.00261799

$A_{sh} = A_{stir} * n_s = 78.53982$

No stirrups, $n_s = 2.00$

$b_k = 400.00$

 $s = 150.00$

$f_{ywe} = 694.45$

$f_{ce} = 33.00$

From ((5.A5), TBDY), TBDY: $c_c = 0.002$

$c = \text{confinement factor} = 1.00$

$y_1 = 0.00140044$

$sh_1 = 0.0044814$

$ft_1 = 466.8167$

$fy_1 = 389.0139$

$su_1 = 0.00512$

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00

$l_o/l_{ou,min} = l_b/l_d = 0.30$

$su_1 = 0.4 * esu1_{nominal}$ ((5.5), TBDY) = 0.032

From table 5A.1, TBDY: $esu1_{nominal} = 0.08$,

For calculation of $esu1_{nominal}$ and y_1, sh_1, ft_1, fy_1 , it is considered
characteristic value $fsy_1 = fs_1/1.2$, from table 5.1, TBDY.

y_1, sh_1, ft_1, fy_1 , are also multiplied by $\text{Min}(1, 1.25 * (l_b/l_d)^{2/3})$, from 10.3.5, ASCE 41-17.

with $fs_1 = fs = 389.0139$

with $Es_1 = Es = 200000.00$

$y_2 = 0.00140044$

$sh_2 = 0.0044814$

$ft_2 = 466.8167$

$fy_2 = 389.0139$

$su_2 = 0.00512$

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00

$l_o/l_{ou,min} = l_b/l_{b,min} = 0.30$

$su_2 = 0.4 * esu2_{nominal}$ ((5.5), TBDY) = 0.032

From table 5A.1, TBDY: $esu2_{nominal} = 0.08$,

For calculation of $esu2_{nominal}$ and y_2, sh_2, ft_2, fy_2 , it is considered
characteristic value $fsy_2 = fs_2/1.2$, from table 5.1, TBDY.

y_2, sh_2, ft_2, fy_2 , are also multiplied by $\text{Min}(1, 1.25 * (l_b/l_d)^{2/3})$, from 10.3.5, ASCE 41-17.

with $fs_2 = fs = 389.0139$

with $Es_2 = Es = 200000.00$

$y_v = 0.00140044$

$sh_v = 0.0044814$

$ft_v = 466.8167$

$fy_v = 389.0139$

$su_v = 0.00512$

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00

$l_o/l_{ou,min} = l_b/l_d = 0.30$

$$suv = 0.4 * esuv_nominal ((5.5), TBDY) = 0.032$$

From table 5A.1, TBDY: $esuv_nominal = 0.08$,

considering characteristic value $fsyv = fsv/1.2$, from table 5.1, TBDY

For calculation of $esuv_nominal$ and yv , shv,ftv,fyv , it is considered characteristic value $fsyv = fsv/1.2$, from table 5.1, TBDY.

$y1$, $sh1,ft1,fy1$, are also multiplied by $\text{Min}(1, 1.25 * (lb/ld)^{2/3})$, from 10.3.5, ASCE 41-17.

with $fsv = fs = 389.0139$

with $Esv = Es = 200000.00$

$$1 = Asl,ten/(b*d)*(fs1/fc) = 0.10166207$$

$$2 = Asl,com/(b*d)*(fs2/fc) = 0.06639156$$

$$v = Asl,mid/(b*d)*(fsv/fc) = 0.06777471$$

and confined core properties:

$$b = 240.00$$

$$d = 327.00$$

$$d' = 12.00$$

$$fcc (5A.2, TBDY) = 33.00$$

$$cc (5A.5, TBDY) = 0.002$$

$c =$ confinement factor = 1.00

$$1 = Asl,ten/(b*d)*(fs1/fc) = 0.13873608$$

$$2 = Asl,com/(b*d)*(fs2/fc) = 0.09060316$$

$$v = Asl,mid/(b*d)*(fsv/fc) = 0.09249072$$

Case/Assumption: Unconfined full section - Steel rupture
' satisfies Eq. (4.3)

--->

$v < vs,y2$ - LHS eq.(4.5) is satisfied

--->

$$su (4.9) = 0.22379076$$

$$Mu = MRc (4.14) = 1.5703E+008$$

$$u = su (4.1) = 1.8476637E-005$$

Calculation of ratio lb/ld

Inadequate Lap Length with $lb/ld = 0.30$

Calculation of Shear Strength $Vr = \text{Min}(Vr1, Vr2) = 289894.477$

Calculation of Shear Strength at edge 1, $Vr1 = 289894.477$

$Vr1 = Vn$ ((22.5.1.1), ACI 318-14)

NOTE: In expression (22.5.1.1) ' Vw ' is replaced by ' $Vw + f*Vf$ '
where Vf is the contribution of FRPs (11.3), ACI 440).

From Table (22.5.5.1), ACI 318-14: $Vc = 103724.534$

= 1 (normal-weight concrete)

$fc' = 33.00$, but $fc^{0.5} <= 8.3$ MPa (22.5.3.1, ACI 318-14)

$$pw = As/(bw*d) = 0.00949023$$

As (tension reinf.) = 911.0619

$bw = 300.00$

$d = 320.00$

$$Vu*d/Mu < 1 = 1.00$$

$Mu = 71267.116$

$Vu = 2771.021$

From (11.5.4.8), ACI 318-14: $Vs = 186169.943$

$Av = 157079.633$

$fy = 555.56$

$s = 150.00$

Vs has been multiplied by 1 ($s < d/2$, according to ASCE 41-17,10.3.4)

Vf ((11-3)-(11.4), ACI 440) = 0.00

From (11-11), ACI 440: $Vs + Vf <= 366348.956$

Calculation of Shear Strength at edge 2, $Vr2 = 289894.477$

$Vr2 = Vn$ ((22.5.1.1), ACI 318-14)

NOTE: In expression (22.5.1.1) 'Vw' is replaced by 'Vw+ f*Vf'
where Vf is the contribution of FRPs (11.3), ACI 440).

From Table (22.5.5.1), ACI 318-14: $V_c = 103724.534$
= 1 (normal-weight concrete)
 $f'_c = 33.00$, but $f'_c^{0.5} \leq 8.3$ MPa (22.5.3.1, ACI 318-14)
 $\rho_w = A_s/(b_w*d) = 0.00949023$
As (tension reinf.) = 911.0619
bw = 300.00
d = 320.00
 $V_u*d/M_u < 1 = 1.00$
Mu = 71267.116
Vu = 2771.021
From (11.5.4.8), ACI 318-14: $V_s = 186169.943$
Av = 157079.633
fy = 555.56
s = 150.00
Vs has been multiplied by 1 ($s < d/2$, according to ASCE 41-17,10.3.4)
Vf ((11-3)-(11.4), ACI 440) = 0.00
From (11-11), ACI 440: $V_s + V_f \leq 366348.956$

End Of Calculation of Shear Capacity ratio for element: beam B1 of floor 1
At local axis: 3

Start Of Calculation of Shear Capacity ratio for element: beam B1 of floor 1
At Shear local axis: 2
(Bending local axis: 3)
Section Type: rcars

Constant Properties

Knowledge Factor, = 1.00
Mean strength values are used for both shear and moment calculations.
Consequently:
New material of Secondary Member: Concrete Strength, $f_c = f_{cm} = 33.00$
New material of Secondary Member: Steel Strength, $f_s = f_{sm} = 555.56$
Concrete Elasticity, $E_c = 26999.444$
Steel Elasticity, $E_s = 200000.00$

Note: Especially for the calculation of moment strengths,
the above steel re-bar strengths are multiplied by 1.25 according to R18.6.5, ACI 318-14
New material: Steel Strength, $f_s = 1.25*f_{sm} = 694.45$

Section Height, H = 400.00
Section Width, W = 300.00
Cover Thickness, c = 25.00
Mean Confinement Factor overall section = 1.00
Element Length, L = 1850.00
Secondary Member
Smooth Bars
Ductile Steel
Without Detailing for Earthquake Resistance (including stirrups not closed at 135°)
Longitudinal Bars With Ends Lapped Starting at the End Sections
Inadequate Lap Length with $l_o/l_{ou,min} = 0.30$
No FRP Wrapping

Stepwise Properties

At local axis: 2
EDGE -A-
Shear Force, Va = 4.9160836E-020
EDGE -B-
Shear Force, Vb = -4.9160836E-020

BOTH EDGES

Axial Force, $F = -190.8684$

Longitudinal Reinforcement Area Distribution (in 2 divisions)

-Tension: $As_t = 911.0619$

-Compression: $As_c = 1231.504$

Longitudinal Reinforcement Area Distribution (in 3 divisions)

-Tension: $As_{t,ten} = 816.8141$

-Compression: $As_{c,com} = 816.8141$

-Middle: $As_{mid} = 508.938$

Calculation of Shear Capacity ratio, $V_e/V_r = 0.54312483$

Member Controlled by Flexure ($V_e/V_r < 1$)

Calculation of Shear Demand from fig. R18.6.5, ACI 318-14 $V_e = (M_{pr1} + M_{pr2})/l_n \pm w_u \cdot l_n/2 = 104799.778$
with

$M_{pr1} = \text{Max}(Mu_{1+}, Mu_{1-}) = 9.6940E+007$

$Mu_{1+} = 9.6940E+007$, is the ultimate moment strength at the edge 1 of the member in the actual moment direction which is defined for the static loading combination

$Mu_{1-} = 9.6940E+007$, is the ultimate moment strength at the edge 1 of the member in the opposite moment direction which is defined for the static loading combination

$M_{pr2} = \text{Max}(Mu_{2+}, Mu_{2-}) = 9.6940E+007$

$Mu_{2+} = 9.6940E+007$, is the ultimate moment strength at the edge 2 of the member in the actual moment direction which is defined for the the static loading combination

$Mu_{2-} = 9.6940E+007$, is the ultimate moment strength at the edge 2 of the member in the opposite moment direction which is defined for the the static loading combination

and

$\pm w_u \cdot l_n = (|V_1| + |V_2|)/2$

with

$V_1 = 4.9160836E-020$, is the shear force acting at edge 1 for the the static loading combination

$V_2 = -4.9160836E-020$, is the shear force acting at edge 2 for the the static loading combination

Calculation of Mu_{1+}

Calculation of ultimate curvature ϕ_u according to 4.1, Biskinis/Fardis 2013:

$\phi_u = 2.5454950E-005$

$M_u = 9.6940E+007$

with full section properties:

$b = 400.00$

$d = 258.00$

$d' = 42.00$

$v = 5.6045447E-005$

$N = 190.8684$

$f_c = 33.00$

ϕ_c (5A.5, TBDY) = 0.002

Final value of ϕ_c : $\phi_c^* = \text{shear_factor} \cdot \text{Max}(\phi_c, \phi_c) = 0.00553582$

The Shear_factor is considered equal to 1 (pure moment strength)

From (5.4b), TBDY: $\phi_c = 0.00553582$

w_e (5.4c) = 0.00259035

a_{se} ((5.4d), TBDY) = 0.15672608

$b_o = 240.00$

$h_o = 340.00$

$bi_2 = 346400.00$

$\phi_{sh,min} = \text{Min}(\phi_{sh,x}, \phi_{sh,y}) = 0.00261799$

Expression ((5.4d), TBDY) for $\phi_{sh,min}$ has been multiplied by 0.3 according to 15.7.1.3 for members without earthquake detailing (90° closed stirrups)

$\phi_{sh,x}$ (5.4d) = 0.00349066

$A_{sh} = A_{stir} \cdot n_s = 78.53982$

No stirrups, $n_s = 2.00$

$b_k = 300.00$

psh,y (5.4d) = 0.00261799
Ash = Astir*ns = 78.53982
No stirups, ns = 2.00
bk = 400.00

s = 150.00
fywe = 694.45
fce = 33.00

From ((5.A.5), TBDY), TBDY: cc = 0.002
c = confinement factor = 1.00

y1 = 0.00140044
sh1 = 0.0044814
ft1 = 466.8167
fy1 = 389.0139
su1 = 0.00512

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00

lo/lou,min = lb/d = 0.30

su1 = 0.4*esu1_nominal ((5.5), TBDY) = 0.032

From table 5A.1, TBDY: esu1_nominal = 0.08,

For calculation of esu1_nominal and y1, sh1,ft1,fy1, it is considered
characteristic value fsy1 = fs1/1.2, from table 5.1, TBDY.

y1, sh1,ft1,fy1, are also multiplied by $\text{Min}(1, 1.25 \cdot (lb/d)^{2/3})$, from 10.3.5, ASCE 41-17.

with fs1 = fs = 389.0139

with Es1 = Es = 200000.00

y2 = 0.00140044
sh2 = 0.0044814
ft2 = 466.8167
fy2 = 389.0139
su2 = 0.00512

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00

lo/lou,min = lb/lb,min = 0.30

su2 = 0.4*esu2_nominal ((5.5), TBDY) = 0.032

From table 5A.1, TBDY: esu2_nominal = 0.08,

For calculation of esu2_nominal and y2, sh2,ft2,fy2, it is considered
characteristic value fsy2 = fs2/1.2, from table 5.1, TBDY.

y1, sh1,ft1,fy1, are also multiplied by $\text{Min}(1, 1.25 \cdot (lb/d)^{2/3})$, from 10.3.5, ASCE 41-17.

with fs2 = fs = 389.0139

with Es2 = Es = 200000.00

yv = 0.00140044
shv = 0.0044814
ftv = 466.8167
fyv = 389.0139
suv = 0.00512

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00

lo/lou,min = lb/d = 0.30

suv = 0.4*esuv_nominal ((5.5), TBDY) = 0.032

From table 5A.1, TBDY: esuv_nominal = 0.08,

considering characteristic value fsyv = fsv/1.2, from table 5.1, TBDY
For calculation of esuv_nominal and yv, shv,ftv,fyv, it is considered
characteristic value fsyv = fsv/1.2, from table 5.1, TBDY.

y1, sh1,ft1,fy1, are also multiplied by $\text{Min}(1, 1.25 \cdot (lb/d)^{2/3})$, from 10.3.5, ASCE 41-17.

with fsv = fs = 389.0139

with Esv = Es = 200000.00

1 = Asl,ten/(b*d)*(fs1/fc) = 0.09330282
2 = Asl,com/(b*d)*(fs2/fc) = 0.09330282
v = Asl,mid/(b*d)*(fsv/fc) = 0.05813483

and confined core properties:

b = 340.00
d = 228.00
d' = 12.00
fcc (5A.2, TBDY) = 33.00

$$cc \text{ (5A.5, TBDY)} = 0.002$$

$$c = \text{confinement factor} = 1.00$$

$$1 = \text{Asl,ten}/(b*d)*(fs1/fc) = 0.12421118$$

$$2 = \text{Asl,com}/(b*d)*(fs2/fc) = 0.12421118$$

$$v = \text{Asl,mid}/(b*d)*(fsv/fc) = 0.07739312$$

Case/Assumption: Unconfined full section - Steel rupture
' satisfies Eq. (4.3)

--->

$v < v_{s,y2}$ - LHS eq.(4.5) is satisfied

--->

$$su \text{ (4.9)} = 0.22038892$$

$$Mu = MRc \text{ (4.14)} = 9.6940E+007$$

$$u = su \text{ (4.1)} = 2.5454950E-005$$

Calculation of ratio l_b/l_d

Inadequate Lap Length with $l_b/l_d = 0.30$

Calculation of $Mu1$ -

Calculation of ultimate curvature u according to 4.1, Biskinis/Fardis 2013:

$$u = 2.5454950E-005$$

$$Mu = 9.6940E+007$$

with full section properties:

$$b = 400.00$$

$$d = 258.00$$

$$d' = 42.00$$

$$v = 5.6045447E-005$$

$$N = 190.8684$$

$$fc = 33.00$$

$$co \text{ (5A.5, TBDY)} = 0.002$$

$$\text{Final value of } cu: cu^* = \text{shear_factor} * \text{Max}(cu, cc) = 0.00553582$$

The Shear_factor is considered equal to 1 (pure moment strength)

$$\text{From (5.4b), TBDY: } cu = 0.00553582$$

$$we \text{ (5.4c)} = 0.00259035$$

$$ase \text{ ((5.4d), TBDY)} = 0.15672608$$

$$bo = 240.00$$

$$ho = 340.00$$

$$bi2 = 346400.00$$

$$psh,min = \text{Min}(psh,x, psh,y) = 0.00261799$$

Expression ((5.4d), TBDY) for psh,min has been multiplied by 0.3 according to 15.7.1.3 for members without earthquake detailing (90° closed stirrups)

$$psh,x \text{ (5.4d)} = 0.00349066$$

$$Ash = \text{Astir}*ns = 78.53982$$

$$\text{No stirups, } ns = 2.00$$

$$bk = 300.00$$

$$psh,y \text{ (5.4d)} = 0.00261799$$

$$Ash = \text{Astir}*ns = 78.53982$$

$$\text{No stirups, } ns = 2.00$$

$$bk = 400.00$$

$$s = 150.00$$

$$fywe = 694.45$$

$$fce = 33.00$$

$$\text{From ((5.A5), TBDY), TBDY: } cc = 0.002$$

$$c = \text{confinement factor} = 1.00$$

$$y1 = 0.00140044$$

$$sh1 = 0.0044814$$

$$ft1 = 466.8167$$

$f_{y1} = 389.0139$
 $s_{u1} = 0.00512$
 using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
 and also multiplied by the shear_factor according to 15.7.1.4, with
 Shear_factor = 1.00
 $l_o/l_{ou,min} = l_b/l_d = 0.30$
 $s_{u1} = 0.4 * e_{su1,nominal} ((5.5), TBDY) = 0.032$
 From table 5A.1, TBDY: $e_{su1,nominal} = 0.08$,
 For calculation of $e_{su1,nominal}$ and y_1, sh_1, ft_1, f_{y1} , it is considered
 characteristic value $f_{sy1} = f_{s1}/1.2$, from table 5.1, TBDY.
 y_1, sh_1, ft_1, f_{y1} , are also multiplied by $\text{Min}(1, 1.25 * (l_b/l_d)^{2/3})$, from 10.3.5, ASCE 41-17.
 with $f_{s1} = f_s = 389.0139$
 with $E_{s1} = E_s = 200000.00$
 $y_2 = 0.00140044$
 $sh_2 = 0.0044814$
 $ft_2 = 466.8167$
 $f_{y2} = 389.0139$
 $s_{u2} = 0.00512$
 using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
 and also multiplied by the shear_factor according to 15.7.1.4, with
 Shear_factor = 1.00
 $l_o/l_{ou,min} = l_b/l_{b,min} = 0.30$
 $s_{u2} = 0.4 * e_{su2,nominal} ((5.5), TBDY) = 0.032$
 From table 5A.1, TBDY: $e_{su2,nominal} = 0.08$,
 For calculation of $e_{su2,nominal}$ and y_2, sh_2, ft_2, f_{y2} , it is considered
 characteristic value $f_{sy2} = f_{s2}/1.2$, from table 5.1, TBDY.
 y_1, sh_1, ft_1, f_{y1} , are also multiplied by $\text{Min}(1, 1.25 * (l_b/l_d)^{2/3})$, from 10.3.5, ASCE 41-17.
 with $f_{s2} = f_s = 389.0139$
 with $E_{s2} = E_s = 200000.00$
 $y_v = 0.00140044$
 $sh_v = 0.0044814$
 $ft_v = 466.8167$
 $f_{yv} = 389.0139$
 $s_{uv} = 0.00512$
 using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
 and also multiplied by the shear_factor according to 15.7.1.4, with
 Shear_factor = 1.00
 $l_o/l_{ou,min} = l_b/l_d = 0.30$
 $s_{uv} = 0.4 * e_{suv,nominal} ((5.5), TBDY) = 0.032$
 From table 5A.1, TBDY: $e_{suv,nominal} = 0.08$,
 considering characteristic value $f_{sv} = f_{sv}/1.2$, from table 5.1, TBDY
 For calculation of $e_{suv,nominal}$ and y_v, sh_v, ft_v, f_{yv} , it is considered
 characteristic value $f_{sv} = f_{sv}/1.2$, from table 5.1, TBDY.
 y_1, sh_1, ft_1, f_{y1} , are also multiplied by $\text{Min}(1, 1.25 * (l_b/l_d)^{2/3})$, from 10.3.5, ASCE 41-17.
 with $f_{sv} = f_s = 389.0139$
 with $E_{sv} = E_s = 200000.00$
 $1 = A_{sl,ten}/(b*d)*(f_{s1}/f_c) = 0.09330282$
 $2 = A_{sl,com}/(b*d)*(f_{s2}/f_c) = 0.09330282$
 $v = A_{sl,mid}/(b*d)*(f_{sv}/f_c) = 0.05813483$
 and confined core properties:
 $b = 340.00$
 $d = 228.00$
 $d' = 12.00$
 $f_{cc} (5A.2, TBDY) = 33.00$
 $cc (5A.5, TBDY) = 0.002$
 $c = \text{confinement factor} = 1.00$
 $1 = A_{sl,ten}/(b*d)*(f_{s1}/f_c) = 0.12421118$
 $2 = A_{sl,com}/(b*d)*(f_{s2}/f_c) = 0.12421118$
 $v = A_{sl,mid}/(b*d)*(f_{sv}/f_c) = 0.07739312$
 Case/Assumption: Unconfined full section - Steel rupture
 ' satisfies Eq. (4.3)
 --->
 $v < v_{s,y2}$ - LHS eq.(4.5) is satisfied
 --->
 $s_u (4.9) = 0.22038892$
 $M_u = M_{Rc} (4.14) = 9.6940E+007$
 $u = s_u (4.1) = 2.5454950E-005$

Calculation of ratio l_b/d

Inadequate Lap Length with $l_b/d = 0.30$

Calculation of μ_{2+}

Calculation of ultimate curvature μ according to 4.1, Biskinis/Fardis 2013:

$$\mu = 2.5454950E-005$$

$$\mu_{2+} = 9.6940E+007$$

with full section properties:

$$b = 400.00$$

$$d = 258.00$$

$$d' = 42.00$$

$$v = 5.6045447E-005$$

$$N = 190.8684$$

$$f_c = 33.00$$

$$c_o \text{ (5A.5, TBDY)} = 0.002$$

$$\text{Final value of } \mu_{cu}: \mu_{cu}^* = \text{shear_factor} * \text{Max}(\mu_{cu}, \mu_{cc}) = 0.00553582$$

The Shear_factor is considered equal to 1 (pure moment strength)

$$\text{From (5.4b), TBDY: } \mu_{cu} = 0.00553582$$

$$\mu_{we} \text{ (5.4c)} = 0.00259035$$

$$\mu_{ase} \text{ ((5.4d), TBDY)} = 0.15672608$$

$$b_o = 240.00$$

$$h_o = 340.00$$

$$b_{i2} = 346400.00$$

$$\mu_{psh,min} = \text{Min}(\mu_{psh,x}, \mu_{psh,y}) = 0.00261799$$

Expression ((5.4d), TBDY) for $\mu_{psh,min}$ has been multiplied by 0.3 according to 15.7.1.3 for members without earthquake detailing (90° closed stirrups)

$$\mu_{psh,x} \text{ (5.4d)} = 0.00349066$$

$$A_{sh} = A_{stir} * n_s = 78.53982$$

$$\text{No stirrups, } n_s = 2.00$$

$$b_k = 300.00$$

$$\mu_{psh,y} \text{ (5.4d)} = 0.00261799$$

$$A_{sh} = A_{stir} * n_s = 78.53982$$

$$\text{No stirrups, } n_s = 2.00$$

$$b_k = 400.00$$

$$s = 150.00$$

$$f_{ywe} = 694.45$$

$$f_{ce} = 33.00$$

$$\text{From ((5.A5), TBDY), TBDY: } \mu_{cc} = 0.002$$

$$c = \text{confinement factor} = 1.00$$

$$y_1 = 0.00140044$$

$$sh_1 = 0.0044814$$

$$ft_1 = 466.8167$$

$$fy_1 = 389.0139$$

$$su_1 = 0.00512$$

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor and also multiplied by the shear_factor according to 15.7.1.4, with Shear_factor = 1.00

$$l_o/l_{o,min} = l_b/d = 0.30$$

$$\mu_{su_1} = 0.4 * \mu_{su_1,nominal} \text{ ((5.5), TBDY)} = 0.032$$

$$\text{From table 5A.1, TBDY: } \mu_{su_1,nominal} = 0.08,$$

For calculation of $\mu_{su_1,nominal}$ and y_1, sh_1, ft_1, fy_1 , it is considered characteristic value $f_{sy1} = f_{s1}/1.2$, from table 5.1, TBDY.

y_1, sh_1, ft_1, fy_1 , are also multiplied by $\text{Min}(1, 1.25 * (l_b/d)^{2/3})$, from 10.3.5, ASCE 41-17.

$$\text{with } f_{s1} = f_s = 389.0139$$

$$\text{with } E_{s1} = E_s = 200000.00$$

y2 = 0.00140044
sh2 = 0.0044814
ft2 = 466.8167
fy2 = 389.0139
su2 = 0.00512

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00

lo/lou,min = lb/lb,min = 0.30

su2 = 0.4*esu2_nominal ((5.5), TBDY) = 0.032

From table 5A.1, TBDY: esu2_nominal = 0.08,

For calculation of esu2_nominal and y2, sh2,ft2,fy2, it is considered
characteristic value fsy2 = fs2/1.2, from table 5.1, TBDY.

y1, sh1,ft1,fy1, are also multiplied by $\text{Min}(1, 1.25 \cdot (lb/ld)^{2/3})$, from 10.3.5, ASCE 41-17.

with fs2 = fs = 389.0139

with Es2 = Es = 200000.00

yv = 0.00140044
shv = 0.0044814

ftv = 466.8167

fyv = 389.0139

suv = 0.00512

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00

lo/lou,min = lb/ld = 0.30

suv = 0.4*esuv_nominal ((5.5), TBDY) = 0.032

From table 5A.1, TBDY: esuv_nominal = 0.08,

considering characteristic value fsyv = fsv/1.2, from table 5.1, TBDY

For calculation of esuv_nominal and yv, shv,ftv,fyv, it is considered
characteristic value fsyv = fsv/1.2, from table 5.1, TBDY.

y1, sh1,ft1,fy1, are also multiplied by $\text{Min}(1, 1.25 \cdot (lb/ld)^{2/3})$, from 10.3.5, ASCE 41-17.

with fsv = fs = 389.0139

with Esv = Es = 200000.00

1 = Asl,ten/(b*d)*(fs1/fc) = 0.09330282

2 = Asl,com/(b*d)*(fs2/fc) = 0.09330282

v = Asl,mid/(b*d)*(fsv/fc) = 0.05813483

and confined core properties:

b = 340.00

d = 228.00

d' = 12.00

fcc (5A.2, TBDY) = 33.00

cc (5A.5, TBDY) = 0.002

c = confinement factor = 1.00

1 = Asl,ten/(b*d)*(fs1/fc) = 0.12421118

2 = Asl,com/(b*d)*(fs2/fc) = 0.12421118

v = Asl,mid/(b*d)*(fsv/fc) = 0.07739312

Case/Assumption: Unconfined full section - Steel rupture

' satisfies Eq. (4.3)

v < vs,y2 - LHS eq.(4.5) is satisfied

su (4.9) = 0.22038892

Mu = MRc (4.14) = 9.6940E+007

u = su (4.1) = 2.5454950E-005

Calculation of ratio lb/ld

Inadequate Lap Length with lb/ld = 0.30

Calculation of Mu2-

Calculation of ultimate curvature u according to 4.1, Biskinis/Fardis 2013:

u = 2.5454950E-005
Mu = 9.6940E+007

with full section properties:

b = 400.00
d = 258.00
d' = 42.00
v = 5.6045447E-005
N = 190.8684
fc = 33.00
co (5A.5, TBDY) = 0.002
Final value of cu: cu* = shear_factor * Max(cu, cc) = 0.00553582
The Shear_factor is considered equal to 1 (pure moment strength)
From (5.4b), TBDY: cu = 0.00553582
we (5.4c) = 0.00259035
ase ((5.4d), TBDY) = 0.15672608
bo = 240.00
ho = 340.00
bi2 = 346400.00
psh,min = Min(psh,x , psh,y) = 0.00261799
Expression ((5.4d), TBDY) for psh,min has been multiplied by 0.3 according to 15.7.1.3 for members without earthquake detailing (90° closed stirrups)

psh,x (5.4d) = 0.00349066
Ash = Astir*ns = 78.53982
No stirrups, ns = 2.00
bk = 300.00

psh,y (5.4d) = 0.00261799
Ash = Astir*ns = 78.53982
No stirrups, ns = 2.00
bk = 400.00

s = 150.00
fywe = 694.45
fce = 33.00
From ((5.A5), TBDY), TBDY: cc = 0.002
c = confinement factor = 1.00
y1 = 0.00140044
sh1 = 0.0044814
ft1 = 466.8167
fy1 = 389.0139
su1 = 0.00512

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00
lo/lou,min = lb/d = 0.30
su1 = 0.4*esu1_nominal ((5.5), TBDY) = 0.032
From table 5A.1, TBDY: esu1_nominal = 0.08,
For calculation of esu1_nominal and y1, sh1,ft1,fy1, it is considered
characteristic value fsy1 = fs1/1.2, from table 5.1, TBDY.
y1, sh1,ft1,fy1, are also multiplied by Min(1,1.25*(lb/d)^ 2/3), from 10.3.5, ASCE 41-17.
with fs1 = fs = 389.0139
with Es1 = Es = 200000.00

y2 = 0.00140044
sh2 = 0.0044814
ft2 = 466.8167
fy2 = 389.0139
su2 = 0.00512

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00
lo/lou,min = lb/lb,min = 0.30
su2 = 0.4*esu2_nominal ((5.5), TBDY) = 0.032
From table 5A.1, TBDY: esu2_nominal = 0.08,
For calculation of esu2_nominal and y2, sh2,ft2,fy2, it is considered
characteristic value fsy2 = fs2/1.2, from table 5.1, TBDY.

y_1, sh_1, ft_1, fy_1 , are also multiplied by $\text{Min}(1, 1.25 \cdot (l_b/l_d)^{2/3})$, from 10.3.5, ASCE 41-17.

with $fs_2 = fs = 389.0139$

with $Es_2 = Es = 200000.00$

$y_v = 0.00140044$

$sh_v = 0.0044814$

$ft_v = 466.8167$

$fy_v = 389.0139$

$suv = 0.00512$

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor

and also multiplied by the shear_factor according to 15.7.1.4, with

Shear_factor = 1.00

$l_o/l_{o,min} = l_b/l_d = 0.30$

$suv = 0.4 \cdot esuv_{nominal} ((5.5), TBDY) = 0.032$

From table 5A.1, TBDY: $esuv_{nominal} = 0.08$,

considering characteristic value $fsyv = fsv/1.2$, from table 5.1, TBDY

For calculation of $esuv_{nominal}$ and y_v, sh_v, ft_v, fy_v , it is considered

characteristic value $fsyv = fsv/1.2$, from table 5.1, TBDY.

y_1, sh_1, ft_1, fy_1 , are also multiplied by $\text{Min}(1, 1.25 \cdot (l_b/l_d)^{2/3})$, from 10.3.5, ASCE 41-17.

with $fsv = fs = 389.0139$

with $Es_v = Es = 200000.00$

1 = $Asl_{ten}/(b \cdot d) \cdot (fs_1/fc) = 0.09330282$

2 = $Asl_{com}/(b \cdot d) \cdot (fs_2/fc) = 0.09330282$

v = $Asl_{mid}/(b \cdot d) \cdot (fsv/fc) = 0.05813483$

and confined core properties:

b = 340.00

d = 228.00

d' = 12.00

fcc (5A.2, TBDY) = 33.00

cc (5A.5, TBDY) = 0.002

c = confinement factor = 1.00

1 = $Asl_{ten}/(b \cdot d) \cdot (fs_1/fc) = 0.12421118$

2 = $Asl_{com}/(b \cdot d) \cdot (fs_2/fc) = 0.12421118$

v = $Asl_{mid}/(b \cdot d) \cdot (fsv/fc) = 0.07739312$

Case/Assumption: Unconfined full section - Steel rupture

' satisfies Eq. (4.3)

--->

$v < v_{s,y2}$ - LHS eq.(4.5) is satisfied

--->

su (4.9) = 0.22038892

$Mu = MRc$ (4.14) = 9.6940E+007

u = su (4.1) = 2.5454950E-005

Calculation of ratio l_b/l_d

Inadequate Lap Length with $l_b/l_d = 0.30$

Calculation of Shear Strength $V_r = \text{Min}(V_{r1}, V_{r2}) = 192957.075$

Calculation of Shear Strength at edge 1, $V_{r1} = 192957.075$

$V_{r1} = V_n$ ((22.5.1.1), ACI 318-14)

NOTE: In expression (22.5.1.1) ' V_w ' is replaced by ' $V_w + f \cdot V_f$ '
where V_f is the contribution of FRPs (11.3), ACI 440).

From Table (22.5.5.1), ACI 318-14: $V_c = 88236.482$

= 1 (normal-weight concrete)

$fc' = 33.00$, but $fc'^{0.5} \leq 8.3$ MPa (22.5.3.1, ACI 318-14)

$pw = As/(b_w \cdot d) = 0.00949023$

As (tension reinf.) = 911.0619

$b_w = 400.00$

$d = 240.00$

$V_u \cdot d / Mu < 1 = 0.00$

$Mu = 3.3205266E-012$

$$V_u = 4.9160836E-020$$

From (11.5.4.8), ACI 318-14: $V_s = 104720.593$

$$A_v = 157079.633$$

$$f_y = 555.56$$

$$s = 150.00$$

V_s has been multiplied by $2(1-s/d)$ ($s > d/2$, according to ASCE 41-17,10.3.4)

$$2(1-s/d) = 0.75$$

$$V_f ((11-3)-(11.4), ACI 440) = 0.00$$

$$\text{From (11-11), ACI 440: } V_s + V_f \leq 366348.956$$

Calculation of Shear Strength at edge 2, $V_{r2} = 192957.075$

$$V_{r2} = V_n ((22.5.1.1), ACI 318-14)$$

NOTE: In expression (22.5.1.1) ' V_w ' is replaced by ' $V_w + f \cdot V_f$ ' where V_f is the contribution of FRPs (11.3), ACI 440).

From Table (22.5.5.1), ACI 318-14: $V_c = 88236.482$

= 1 (normal-weight concrete)

$$f_c' = 33.00, \text{ but } f_c'^{0.5} \leq 8.3 \text{ MPa (22.5.3.1, ACI 318-14)}$$

$$p_w = A_s / (b_w \cdot d) = 0.00949023$$

$$A_s (\text{tension reinf.}) = 911.0619$$

$$b_w = 400.00$$

$$d = 240.00$$

$$V_u \cdot d / M_u < 1 = 0.00$$

$$M_u = 3.3203395E-012$$

$$V_u = 4.9160836E-020$$

From (11.5.4.8), ACI 318-14: $V_s = 104720.593$

$$A_v = 157079.633$$

$$f_y = 555.56$$

$$s = 150.00$$

V_s has been multiplied by $2(1-s/d)$ ($s > d/2$, according to ASCE 41-17,10.3.4)

$$2(1-s/d) = 0.75$$

$$V_f ((11-3)-(11.4), ACI 440) = 0.00$$

$$\text{From (11-11), ACI 440: } V_s + V_f \leq 366348.956$$

End Of Calculation of Shear Capacity ratio for element: beam B1 of floor 1

At local axis: 2

Start Of Calculation of Chord Rotation Capacity for element: beam B1 of floor 1

At local axis: 2

Integration Section: (b)

Section Type: rcars

Constant Properties

Knowledge Factor, = 1.00

Chord Rotation is generally considered as Deformation-Controlled Action according to Table C7-1, ASCE 41-17.

Mean strengths are used for Deformation-Controlled Actions according to 7.5.1.3, ASCE 41-17

Consequently:

New material of Secondary Member: Concrete Strength, $f_c = f_{cm} = 33.00$

New material of Secondary Member: Steel Strength, $f_s = f_{sm} = 555.56$

Concrete Elasticity, $E_c = 26999.444$

Steel Elasticity, $E_s = 200000.00$

Section Height, $H = 400.00$

Section Width, $W = 300.00$

Cover Thickness, $c = 25.00$

Element Length, $L = 1850.00$

Secondary Member

Smooth Bars

Ductile Steel

Without Detailing for Earthquake Resistance (including stirrups not closed at 135°)

Longitudinal Bars With Ends Lapped Starting at the End Sections

Inadequate Lap Length with $l_b / l_d = 0.30$

No FRP Wrapping

Stepwise Properties

Bending Moment, $M = 4.3614E+006$
Shear Force, $V2 = -3.3781306E-014$
Shear Force, $V3 = 7475.372$
Axial Force, $F = -457.6821$
Longitudinal Reinforcement Area Distribution (in 2 divisions)
-Tension: $As_t = 923.6282$
-Compression: $As_c = 1218.938$
Longitudinal Reinforcement Area Distribution (in 3 divisions)
-Tension: $As_{,ten} = 923.6282$
-Compression: $As_{,com} = 603.1858$
-Middle: $As_{,mid} = 615.7522$
Mean Diameter of Tension Reinforcement, $Db_L = 14.00$

New component: From table 7-7, ASCE 41_17: Final chord rotation Capacity $u_{,R} = 1.0^*$ $u = 0.02165027$
 $u = y + p = 0.02165027$

- Calculation of y -

$y = (M_y * L_s / 3) / E_{eff} = 0.00165027$ ((4.29), Biskinis Phd)
 $M_y = 1.0997E+008$
 $L_s = M/V$ (with $L_s > 0.1 * L$ and $L_s < 2 * L$) = 583.4319
From table 10.5, ASCE 41_17: $E_{eff} = 0.3 * E_c * I_g = 1.2960E+013$

Calculation of Yielding Moment M_y

Calculation of y and M_y according to Annex 7 -

$y = \text{Min}(y_{,ten}, y_{,com})$
 $y_{,ten} = 6.2733322E-006$
with ((10.1), ASCE 41-17) $f_y = \text{Min}(f_y, 1.25 * f_y * (l_b/d)^{2/3}) = 311.2112$
 $d = 358.00$
 $y = 0.30714263$
 $A = 0.0199631$
 $B = 0.01249911$
with $p_t = 0.00859989$
 $p_c = 0.00561626$
 $p_v = 0.00573326$
 $N = 457.6821$
 $b = 300.00$
 $" = 0.12011173$
 $y_{,comp} = 2.0015134E-005$
with $f_c = 33.00$
 $E_c = 26999.444$
 $y = 0.30703655$
 $A = 0.01993972$
 $B = 0.01248541$
with $E_s = 200000.00$

Calculation of ratio l_b/d

Inadequate Lap Length with $l_b/d = 0.30$

- Calculation of p -

From table 10-7: $p = 0.02$

with:

- Condition iv occurred

Beam controlled by inadequate embedment into beam-column joint:
($b/d < 1$ and With Lapping in the Vicinity of the End Regions)

- Condition i occurred

Beam controlled by flexure: $V_p/V_o \leq 1$

shear control ratio $V_p/V_o = 0.59550037$

- Transverse Reinforcement: NC

- Stirrup Spacing $> d/3$

- Low ductility demand, $\lambda / \gamma < 2$ (table 10-6, ASCE 41-17)

$$= 1.0394078E-005$$

- Stirrup Spacing $\leq d/2$

$$d = 358.00$$

$$s = 150.00$$

- Strength provided by hoops $V_s < 3/4 * \text{design Shear}$

$V_s = 186169.943$, already given in calculation of shear control ratio

design Shear = 7475.372

- ($\lambda - \gamma$)/ bal = -0.16136132

$$= A_{st}/(b_w * d) = 0.00859989$$

Tension Reinf Area: $A_{st} = 923.6282$

$$\lambda = A_{sc}/(b_w * d) = 0.01134952$$

Compression Reinf Area: $A_{sc} = 1218.938$

From (B-1), ACI 318-11: bal = 0.01704017

$$f_c = 33.00$$

$$f_y = 555.56$$

From 10.2.7.3, ACI 318-11: $\lambda = 0.65$

From fig R10.3.3, ACI 318-11 (Ence 454, too): $87000/(87000 + f_y) = c_b/d_t = 0.003/(0.003 + \gamma) = 0.51922877$

$$\gamma = 0.0027778$$

- $V/(b_w * d * f_c^{0.5}) = 0.14591327$, NOTE: units in lb & in

$$b_w = 300.00$$

End Of Calculation of Chord Rotation Capacity for element: beam B1 of floor 1

At local axis: 2

Integration Section: (b)

Calculation No. 15

beam B1, Floor 1



Limit State: Life Safety (data interpolation between analysis steps 1 and 2)

Analysis: Uniform +X

Check: Shear capacity V_{Rd}

Edge: End

Local Axis: (3)



Start Of Calculation of Shear Capacity for element: beam B1 of floor 1

At local axis: 3

Integration Section: (b)

Section Type: rcars

Constant Properties

Knowledge Factor, $\gamma = 1.00$

Member Shear Force is generally considered as Force-Controlled Action according to Table C7-1, ASCE 41-17.

Lower-bound strengths are used for Force-Controlled Actions according to 7.5.1.3, ASCE 41-17

Consequently:

New material of Secondary Member: Concrete Strength, $f_c = f_{c_lower_bound} = 25.00$

New material of Secondary Member: Steel Strength, $f_s = f_{s_lower_bound} = 500.00$

Concrete Elasticity, $E_c = 26999.444$

Steel Elasticity, $E_s = 200000.00$

Section Height, $H = 400.00$

Section Width, $W = 300.00$

Cover Thickness, $c = 25.00$

Element Length, $L = 1850.00$

Secondary Member

Smooth Bars

Ductile Steel

Without Detailing for Earthquake Resistance (including stirrups not closed at 135°)

Longitudinal Bars With Ends Lapped Starting at the End Sections

Inadequate Lap Length with $l_o/l_{o,min} = l_b/l_d = 0.30$

No FRP Wrapping

Stepwise Properties

EDGE -A-

Bending Moment, $M_a = 4.3417E+006$

Shear Force, $V_a = -1933.33$

EDGE -B-

Bending Moment, $M_b = 4.3614E+006$

Shear Force, $V_b = 7475.372$

BOTH EDGES

Axial Force, $F = -457.6821$

Longitudinal Reinforcement Area Distribution (in 2 divisions)

-Tension: $A_{sl,t} = 923.6282$

-Compression: $A_{sl,c} = 1218.938$

Longitudinal Reinforcement Area Distribution (in 3 divisions)

-Tension: $A_{sl,ten} = 923.6282$

-Compression: $A_{sl,com} = 603.1858$

-Middle: $A_{sl,mid} = 615.7522$

Mean Diameter of Tension Reinforcement, $Db_{L,ten} = 14.00$

New component: From table 7-7, ASCE 41_17: Final Shear Capacity $VR = 1.0 \cdot V_n = 252963.646$

V_n ((22.5.1.1), ACI 318-14) = 252963.646

NOTE: In expression (22.5.1.1) 'Vw' is replaced by 'Vw+ f*Vf' where Vf is the contribution of FRPs (11.3), ACI 440).

From Table (22.5.5.1), ACI 318-14: $V_c = 85412.038$
= 1 (normal-weight concrete)
 $f'_c = 25.00$, but $f'_c^{0.5} \leq 8.3$ MPa (22.5.3.1, ACI 318-14)
 $\rho_w = A_s/(b_w*d) = 0.00962113$
 A_s (tension reinf.) = 923.6282
 $b_w = 300.00$
 $d = 320.00$
 $V_u*d/\mu < 1 = 0.54847876$
 $\mu = 4.3614E+006$
 $V_u = 7475.372$

From (11.5.4.8), ACI 318-14: $V_s = 167551.608$
 $A_v = 157079.633$
 $f_y = 500.00$
 $s = 150.00$

V_s has been multiplied by 1 ($s < d/2$, according to ASCE 41-17,10.3.4)

V_f ((11-3)-(11.4), ACI 440) = 0.00

From (11-11), ACI 440: $V_s + V_f \leq 318865.838$

End Of Calculation of Shear Capacity for element: beam B1 of floor 1
At local axis: 3
Integration Section: (b)

Calculation No. 16

beam B1, Floor 1



Limit State: Life Safety (data interpolation between analysis steps 1 and 2)

Analysis: Uniform +X

Check: Chord rotation capacity (θ_u)

Edge: End

Local Axis: (3)



Start Of Calculation of Shear Capacity ratio for element: beam B1 of floor 1
At Shear local axis: 3
(Bending local axis: 2)

Section Type: rcars

Constant Properties

Knowledge Factor, $\phi = 1.00$

Mean strength values are used for both shear and moment calculations.

Consequently:

New material of Secondary Member: Concrete Strength, $f_c = f_{cm} = 33.00$

New material of Secondary Member: Steel Strength, $f_s = f_{sm} = 555.56$

Concrete Elasticity, $E_c = 26999.444$

Steel Elasticity, $E_s = 200000.00$

#####

Note: Especially for the calculation of moment strengths,

the above steel re-bar strengths are multiplied by 1.25 according to R18.6.5, ACI 318-14

New material: Steel Strength, $f_s = 1.25 * f_{sm} = 694.45$

#####

Section Height, $H = 400.00$

Section Width, $W = 300.00$

Cover Thickness, $c = 25.00$

Mean Confinement Factor overall section = 1.00

Element Length, $L = 1850.00$

Secondary Member

Smooth Bars

Ductile Steel

Without Detailing for Earthquake Resistance (including stirrups not closed at 135°)

Longitudinal Bars With Ends Lapped Starting at the End Sections

Inadequate Lap Length with $l_o/l_{o,min} = 0.30$

No FRP Wrapping

Stepwise Properties

At local axis: 3

EDGE -A-

Shear Force, $V_a = 2771.021$

EDGE -B-

Shear Force, $V_b = 2771.021$

BOTH EDGES

Axial Force, $F = -190.8684$

Longitudinal Reinforcement Area Distribution (in 2 divisions)

-Tension: $A_{sl,t} = 911.0619$

-Compression: $A_{sl,c} = 1231.504$

Longitudinal Reinforcement Area Distribution (in 3 divisions)

-Tension: $A_{sl,ten} = 603.1858$

-Compression: $A_{sl,com} = 923.6282$

-Middle: $A_{sl,mid} = 615.7522$

Calculation of Shear Capacity ratio, $V_e/V_r = 0.59550037$

Member Controlled by Flexure ($V_e/V_r < 1$)

Calculation of Shear Demand from fig. R18.6.5, ACI 318-14 $V_e = (M_{pr1} + M_{pr2})/l_n \pm w_u * l_n / 2 = 172632.267$

with

$M_{pr1} = \text{Max}(M_{u1+}, M_{u1-}) = 1.5721E+008$

$M_{u1+} = 1.1233E+008$, is the ultimate moment strength at the edge 1 of the member in the actual moment direction which is defined for the static loading combination

$M_{u1-} = 1.5721E+008$, is the ultimate moment strength at the edge 1 of the member in the opposite moment direction which is defined for the static loading combination

$M_{pr2} = \text{Max}(M_{u2+}, M_{u2-}) = 1.5703E+008$

$M_{u2+} = 1.1247E+008$, is the ultimate moment strength at the edge 2 of the member in the actual moment direction which is defined for the the static loading combination

$M_{u2-} = 1.5703E+008$, is the ultimate moment strength at the edge 2 of the member in the opposite moment direction which is defined for the the static loading combination

and

$\pm w_u * l_n = (|V_1| + |V_2|) / 2$

with

V1 = 2771.021, is the shear force acting at edge 1 for the the static loading combination
V2 = 2771.021, is the shear force acting at edge 2 for the the static loading combination

Calculation of Mu1+

Calculation of ultimate curvature ϕ_u according to 4.1, Biskinis/Fardis 2013:

$$u = 1.7687265E-005$$

$$Mu = 1.1233E+008$$

with full section properties:

$$b = 300.00$$

$$d = 357.00$$

$$d' = 42.00$$

$$v = 5.4004576E-005$$

$$N = 190.8684$$

$$f_c = 33.00$$

$$c_o \text{ (5A.5, TBDY)} = 0.002$$

$$\text{Final value of } c_u: c_u^* = \text{shear_factor} * \text{Max}(c_u, c_c) = 0.00553582$$

The Shear_factor is considered equal to 1 (pure moment strength)

$$\text{From (5.4b), TBDY: } c_u = 0.00553582$$

$$w_e \text{ (5.4c)} = 0.00259035$$

$$a_{se} \text{ ((5.4d), TBDY)} = 0.15672608$$

$$b_o = 240.00$$

$$h_o = 340.00$$

$$b_{i2} = 346400.00$$

$$p_{sh,min} = \text{Min}(p_{sh,x}, p_{sh,y}) = 0.00261799$$

Expression ((5.4d), TBDY) for $p_{sh,min}$ has been multiplied by 0.3 according to 15.7.1.3 for members without earthquake detailing (90° closed stirrups)

$$p_{sh,x} \text{ (5.4d)} = 0.00349066$$

$$A_{sh} = A_{stir} * n_s = 78.53982$$

$$\text{No stirrups, } n_s = 2.00$$

$$b_k = 300.00$$

$$p_{sh,y} \text{ (5.4d)} = 0.00261799$$

$$A_{sh} = A_{stir} * n_s = 78.53982$$

$$\text{No stirrups, } n_s = 2.00$$

$$b_k = 400.00$$

$$s = 150.00$$

$$f_{ywe} = 694.45$$

$$f_{ce} = 33.00$$

$$\text{From ((5.A5), TBDY), TBDY: } c_c = 0.002$$

$$c = \text{confinement factor} = 1.00$$

$$y_1 = 0.00140044$$

$$sh_1 = 0.0044814$$

$$ft_1 = 466.8167$$

$$fy_1 = 389.0139$$

$$su_1 = 0.00512$$

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00

$$l_o/l_{o,min} = l_b/l_d = 0.30$$

$$su_1 = 0.4 * esu_{1,nominal} \text{ ((5.5), TBDY)} = 0.032$$

$$\text{From table 5A.1, TBDY: } esu_{1,nominal} = 0.08,$$

For calculation of $esu_{1,nominal}$ and y_1, sh_1, ft_1, fy_1 , it is considered
characteristic value $fsy_1 = fs_1/1.2$, from table 5.1, TBDY.

$$y_1, sh_1, ft_1, fy_1, \text{ are also multiplied by } \text{Min}(1, 1.25 * (l_b/l_d)^{2/3}), \text{ from 10.3.5, ASCE 41-17.}$$

$$\text{with } fs_1 = fs = 389.0139$$

$$\text{with } Es_1 = Es = 200000.00$$

$$y_2 = 0.00140044$$

$$sh_2 = 0.0044814$$

$$ft_2 = 466.8167$$

$$fy_2 = 389.0139$$

$$su_2 = 0.00512$$

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00

$$l_o/l_{o,min} = l_b/l_{b,min} = 0.30$$

$$su_2 = 0.4 * esu_{2,nominal} ((5.5), TBDY) = 0.032$$

From table 5A.1, TBDY: $esu_{2,nominal} = 0.08$,

For calculation of $esu_{2,nominal}$ and y_2, sh_2, ft_2, fy_2 , it is considered
characteristic value $fs_2 = fs_2/1.2$, from table 5.1, TBDY.

y_1, sh_1, ft_1, fy_1 , are also multiplied by $\text{Min}(1, 1.25 * (l_b/l_d)^{2/3})$, from 10.3.5, ASCE 41-17.

$$\text{with } fs_2 = fs = 389.0139$$

$$\text{with } Es_2 = Es = 200000.00$$

$$y_v = 0.00140044$$

$$sh_v = 0.0044814$$

$$ft_v = 466.8167$$

$$fy_v = 389.0139$$

$$suv = 0.00512$$

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00

$$l_o/l_{o,min} = l_b/l_d = 0.30$$

$$suv = 0.4 * esuv_{nominal} ((5.5), TBDY) = 0.032$$

From table 5A.1, TBDY: $esuv_{nominal} = 0.08$,

considering characteristic value $fs_v = fs_v/1.2$, from table 5.1, TBDY

For calculation of $esuv_{nominal}$ and y_v, sh_v, ft_v, fy_v , it is considered
characteristic value $fs_v = fs_v/1.2$, from table 5.1, TBDY.

y_1, sh_1, ft_1, fy_1 , are also multiplied by $\text{Min}(1, 1.25 * (l_b/l_d)^{2/3})$, from 10.3.5, ASCE 41-17.

$$\text{with } fs_v = fs = 389.0139$$

$$\text{with } Es_v = Es = 200000.00$$

$$1 = A_{sl,ten}/(b * d) * (fs_1/f_c) = 0.06639156$$

$$2 = A_{sl,com}/(b * d) * (fs_2/f_c) = 0.10166207$$

$$v = A_{sl,mid}/(b * d) * (fs_v/f_c) = 0.06777471$$

and confined core properties:

$$b = 240.00$$

$$d = 327.00$$

$$d' = 12.00$$

$$fcc (5A.2, TBDY) = 33.00$$

$$cc (5A.5, TBDY) = 0.002$$

$$c = \text{confinement factor} = 1.00$$

$$1 = A_{sl,ten}/(b * d) * (fs_1/f_c) = 0.09060316$$

$$2 = A_{sl,com}/(b * d) * (fs_2/f_c) = 0.13873608$$

$$v = A_{sl,mid}/(b * d) * (fs_v/f_c) = 0.09249072$$

Case/Assumption: Unconfined full section - Steel rupture
' satisfies Eq. (4.3)

--->

$v < v_{s,y2}$ - LHS eq.(4.5) is satisfied

--->

$$su (4.9) = 0.189149$$

$$Mu = MRc (4.14) = 1.1233E+008$$

$$u = su (4.1) = 1.7687265E-005$$

Calculation of ratio l_b/l_d

Inadequate Lap Length with $l_b/l_d = 0.30$

Calculation of Mu_1 -

Calculation of ultimate curvature u according to 4.1, Biskinis/Fardis 2013:

$$u = 1.8434312E-005$$

$$Mu = 1.5721E+008$$

with full section properties:

b = 300.00
d = 358.00
d' = 43.00
v = 5.3853726E-005
N = 190.8684

fc = 33.00
co (5A.5, TBDY) = 0.002

Final value of cu: $cu^* = \text{shear_factor} * \text{Max}(cu, cc) = 0.00553582$
The Shear_factor is considered equal to 1 (pure moment strength)

From (5.4b), TBDY: $cu = 0.00553582$

we (5.4c) = 0.00259035

ase ((5.4d), TBDY) = 0.15672608

bo = 240.00

ho = 340.00

bi2 = 346400.00

psh,min = Min(psh,x , psh,y) = 0.00261799

Expression ((5.4d), TBDY) for psh,min has been multiplied by 0.3 according to 15.7.1.3 for members without earthquake detailing (90° closed stirrups)

psh,x (5.4d) = 0.00349066

Ash = Astir*ns = 78.53982

No stirrups, ns = 2.00

bk = 300.00

psh,y (5.4d) = 0.00261799

Ash = Astir*ns = 78.53982

No stirrups, ns = 2.00

bk = 400.00

s = 150.00

fywe = 694.45

fce = 33.00

From ((5.A5), TBDY), TBDY: $cc = 0.002$

c = confinement factor = 1.00

y1 = 0.00140044

sh1 = 0.0044814

ft1 = 466.8167

fy1 = 389.0139

su1 = 0.00512

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor and also multiplied by the shear_factor according to 15.7.1.4, with Shear_factor = 1.00

lo/lou,min = lb/d = 0.30

su1 = $0.4 * \text{esu1_nominal} ((5.5), \text{TBDY}) = 0.032$

From table 5A.1, TBDY: $\text{esu1_nominal} = 0.08$,

For calculation of esu1_nominal and y1, sh1,ft1,fy1, it is considered characteristic value $\text{fsy1} = \text{fs1}/1.2$, from table 5.1, TBDY.

y1, sh1,ft1,fy1, are also multiplied by $\text{Min}(1, 1.25 * (\text{lb}/\text{d})^{2/3})$, from 10.3.5, ASCE 41-17.

with $\text{fs1} = \text{fs} = 389.0139$

with $\text{Es1} = \text{Es} = 200000.00$

y2 = 0.00140044

sh2 = 0.0044814

ft2 = 466.8167

fy2 = 389.0139

su2 = 0.00512

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor and also multiplied by the shear_factor according to 15.7.1.4, with Shear_factor = 1.00

lo/lou,min = lb/lb,min = 0.30

su2 = $0.4 * \text{esu2_nominal} ((5.5), \text{TBDY}) = 0.032$

From table 5A.1, TBDY: $\text{esu2_nominal} = 0.08$,

For calculation of esu2_nominal and y2, sh2,ft2,fy2, it is considered characteristic value $\text{fsy2} = \text{fs2}/1.2$, from table 5.1, TBDY.

y1, sh1,ft1,fy1, are also multiplied by $\text{Min}(1, 1.25 * (\text{lb}/\text{d})^{2/3})$, from 10.3.5, ASCE 41-17.

with $\text{fs2} = \text{fs} = 389.0139$

with $\text{Es2} = \text{Es} = 200000.00$

yv = 0.00140044

$$shv = 0.0044814$$

$$ftv = 466.8167$$

$$fyv = 389.0139$$

$$suv = 0.00512$$

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00

$$lo/lo_{u,min} = lb/ld = 0.30$$

$$suv = 0.4 * esuv_{nominal} ((5.5), TBDY) = 0.032$$

From table 5A.1, TBDY: $esuv_{nominal} = 0.08$,

considering characteristic value $fsyv = fsv/1.2$, from table 5.1, TBDY

For calculation of $esuv_{nominal}$ and yv , shv,ftv,fyv , it is considered
characteristic value $fsyv = fsv/1.2$, from table 5.1, TBDY.

$y1, sh1,ft1,fy1$, are also multiplied by $Min(1, 1.25 * (lb/ld)^{2/3})$, from 10.3.5, ASCE 41-17.

$$\text{with } fsv = fs = 389.0139$$

$$\text{with } Es = Es = 200000.00$$

$$1 = Asl_{ten}/(b*d)*(fs1/fc) = 0.1013781$$

$$2 = Asl_{com}/(b*d)*(fs2/fc) = 0.06620611$$

$$v = Asl_{mid}/(b*d)*(fsv/fc) = 0.0675854$$

and confined core properties:

$$b = 240.00$$

$$d = 328.00$$

$$d' = 13.00$$

$$fcc (5A.2, TBDY) = 33.00$$

$$cc (5A.5, TBDY) = 0.002$$

$$c = \text{confinement factor} = 1.00$$

$$1 = Asl_{ten}/(b*d)*(fs1/fc) = 0.13831311$$

$$2 = Asl_{com}/(b*d)*(fs2/fc) = 0.09032693$$

$$v = Asl_{mid}/(b*d)*(fsv/fc) = 0.09220874$$

Case/Assumption: Unconfined full section - Steel rupture

' satisfies Eq. (4.3)

$v < vs,y2$ - LHS eq.(4.5) is satisfied

$$su (4.9) = 0.22418173$$

$$Mu = MRc (4.14) = 1.5721E+008$$

$$u = su (4.1) = 1.8434312E-005$$

Calculation of ratio lb/ld

Inadequate Lap Length with $lb/ld = 0.30$

Calculation of Mu_{2+}

Calculation of ultimate curvature u according to 4.1, Biskinis/Fardis 2013:

$$u = 1.7651391E-005$$

$$Mu = 1.1247E+008$$

with full section properties:

$$b = 300.00$$

$$d = 358.00$$

$$d' = 43.00$$

$$v = 5.3853726E-005$$

$$N = 190.8684$$

$$fc = 33.00$$

$$co (5A.5, TBDY) = 0.002$$

$$\text{Final value of } cu: cu^* = \text{shear_factor} * \text{Max}(cu, cc) = 0.00553582$$

The Shear_factor is considered equal to 1 (pure moment strength)

$$\text{From (5.4b), TBDY: } cu = 0.00553582$$

$$we (5.4c) = 0.00259035$$

$$ase ((5.4d), TBDY) = 0.15672608$$

$$bo = 240.00$$

ho = 340.00

bi2 = 346400.00

psh,min = Min(psh,x , psh,y) = 0.00261799

Expression ((5.4d), TBDY) for psh,min has been multiplied by 0.3 according to 15.7.1.3 for members without earthquake detailing (90° closed stirrups)

psh,x (5.4d) = 0.00349066

Ash = Astir*ns = 78.53982

No stirrups, ns = 2.00

bk = 300.00

psh,y (5.4d) = 0.00261799

Ash = Astir*ns = 78.53982

No stirrups, ns = 2.00

bk = 400.00

s = 150.00

fywe = 694.45

fce = 33.00

From ((5.A5), TBDY), TBDY: cc = 0.002

c = confinement factor = 1.00

y1 = 0.00140044

sh1 = 0.0044814

ft1 = 466.8167

fy1 = 389.0139

su1 = 0.00512

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00

lo/lou,min = lb/lb = 0.30

su1 = 0.4*esu1_nominal ((5.5), TBDY) = 0.032

From table 5A.1, TBDY: esu1_nominal = 0.08,

For calculation of esu1_nominal and y1, sh1,ft1,fy1, it is considered
characteristic value fsy1 = fs1/1.2, from table 5.1, TBDY.

y1, sh1,ft1,fy1, are also multiplied by Min(1,1.25*(lb/lb)^2/3), from 10.3.5, ASCE 41-17.

with fs1 = fs = 389.0139

with Es1 = Es = 200000.00

y2 = 0.00140044

sh2 = 0.0044814

ft2 = 466.8167

fy2 = 389.0139

su2 = 0.00512

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00

lo/lou,min = lb/lb,min = 0.30

su2 = 0.4*esu2_nominal ((5.5), TBDY) = 0.032

From table 5A.1, TBDY: esu2_nominal = 0.08,

For calculation of esu2_nominal and y2, sh2,ft2,fy2, it is considered
characteristic value fsy2 = fs2/1.2, from table 5.1, TBDY.

y1, sh1,ft1,fy1, are also multiplied by Min(1,1.25*(lb/lb)^2/3), from 10.3.5, ASCE 41-17.

with fs2 = fs = 389.0139

with Es2 = Es = 200000.00

yv = 0.00140044

shv = 0.0044814

ftv = 466.8167

fyv = 389.0139

suv = 0.00512

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00

lo/lou,min = lb/lb = 0.30

suv = 0.4*esuv_nominal ((5.5), TBDY) = 0.032

From table 5A.1, TBDY: esuv_nominal = 0.08,

considering characteristic value fsyv = fsv/1.2, from table 5.1, TBDY
For calculation of esuv_nominal and yv, shv,ftv,fyv, it is considered

characteristic value fsyv = fsv/1.2, from table 5.1, TBDY.

y_1, sh_1, ft_1, fy_1 , are also multiplied by $\text{Min}(1, 1.25 \cdot (lb/d)^{2/3})$, from 10.3.5, ASCE 41-17.

with $f_{sv} = f_s = 389.0139$

with $E_{sv} = E_s = 200000.00$

$1 = A_{sl,ten}/(b \cdot d) \cdot (f_{s1}/f_c) = 0.06620611$

$2 = A_{sl,com}/(b \cdot d) \cdot (f_{s2}/f_c) = 0.1013781$

$v = A_{sl,mid}/(b \cdot d) \cdot (f_{sv}/f_c) = 0.0675854$

and confined core properties:

$b = 240.00$

$d = 328.00$

$d' = 13.00$

$f_{cc} \text{ (5A.2, TBDY)} = 33.00$

$cc \text{ (5A.5, TBDY)} = 0.002$

$c = \text{confinement factor} = 1.00$

$1 = A_{sl,ten}/(b \cdot d) \cdot (f_{s1}/f_c) = 0.09032693$

$2 = A_{sl,com}/(b \cdot d) \cdot (f_{s2}/f_c) = 0.13831311$

$v = A_{sl,mid}/(b \cdot d) \cdot (f_{sv}/f_c) = 0.09220874$

Case/Assumption: Unconfined full section - Steel rupture

' satisfies Eq. (4.3)

--->

$v < v_{s,y2}$ - LHS eq.(4.5) is satisfied

--->

$su \text{ (4.9)} = 0.18977061$

$Mu = MRc \text{ (4.14)} = 1.1247E+008$

$u = su \text{ (4.1)} = 1.7651391E-005$

Calculation of ratio lb/d

Inadequate Lap Length with $lb/d = 0.30$

Calculation of Mu_2 -

Calculation of ultimate curvature u according to 4.1, Biskinis/Fardis 2013:

$u = 1.8476637E-005$

$Mu = 1.5703E+008$

with full section properties:

$b = 300.00$

$d = 357.00$

$d' = 42.00$

$v = 5.4004576E-005$

$N = 190.8684$

$f_c = 33.00$

$co \text{ (5A.5, TBDY)} = 0.002$

Final value of cu : $cu^* = \text{shear_factor} \cdot \text{Max}(cu, cc) = 0.00553582$

The Shear_factor is considered equal to 1 (pure moment strength)

From (5.4b), TBDY: $cu = 0.00553582$

$w_e \text{ (5.4c)} = 0.00259035$

$ase \text{ ((5.4d), TBDY)} = 0.15672608$

$bo = 240.00$

$ho = 340.00$

$bi_2 = 346400.00$

$psh,min = \text{Min}(psh,x, psh,y) = 0.00261799$

Expression ((5.4d), TBDY) for psh,min has been multiplied by 0.3 according to 15.7.1.3 for members without earthquake detailing (90° closed stirrups)

 $psh,x \text{ (5.4d)} = 0.00349066$

$A_{sh} = A_{stir} \cdot ns = 78.53982$

No stirrups, $ns = 2.00$

$bk = 300.00$

$psh,y \text{ (5.4d)} = 0.00261799$

$A_{sh} = A_{stir} \cdot ns = 78.53982$

No stirrups, ns = 2.00
bk = 400.00

s = 150.00
fywe = 694.45
fce = 33.00

From ((5.A.5), TBDY), TBDY: cc = 0.002
c = confinement factor = 1.00

y1 = 0.00140044
sh1 = 0.0044814
ft1 = 466.8167
fy1 = 389.0139
su1 = 0.00512

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00

lo/lou,min = lb/ld = 0.30

su1 = 0.4*esu1_nominal ((5.5), TBDY) = 0.032

From table 5A.1, TBDY: esu1_nominal = 0.08,

For calculation of esu1_nominal and y1, sh1,ft1,fy1, it is considered
characteristic value fsy1 = fs1/1.2, from table 5.1, TBDY.

y1, sh1,ft1,fy1, are also multiplied by $\text{Min}(1, 1.25 \cdot (lb/ld)^{2/3})$, from 10.3.5, ASCE 41-17.

with fs1 = fs = 389.0139

with Es1 = Es = 200000.00

y2 = 0.00140044
sh2 = 0.0044814
ft2 = 466.8167
fy2 = 389.0139
su2 = 0.00512

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00

lo/lou,min = lb/lb,min = 0.30

su2 = 0.4*esu2_nominal ((5.5), TBDY) = 0.032

From table 5A.1, TBDY: esu2_nominal = 0.08,

For calculation of esu2_nominal and y2, sh2,ft2,fy2, it is considered
characteristic value fsy2 = fs2/1.2, from table 5.1, TBDY.

y1, sh1,ft1,fy1, are also multiplied by $\text{Min}(1, 1.25 \cdot (lb/ld)^{2/3})$, from 10.3.5, ASCE 41-17.

with fs2 = fs = 389.0139

with Es2 = Es = 200000.00

yv = 0.00140044
shv = 0.0044814
ftv = 466.8167
fyv = 389.0139
suv = 0.00512

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00

lo/lou,min = lb/ld = 0.30

suv = 0.4*esuv_nominal ((5.5), TBDY) = 0.032

From table 5A.1, TBDY: esuv_nominal = 0.08,

considering characteristic value fsyv = fsv/1.2, from table 5.1, TBDY
For calculation of esuv_nominal and yv, shv,ftv,fyv, it is considered
characteristic value fsyv = fsv/1.2, from table 5.1, TBDY.

y1, sh1,ft1,fy1, are also multiplied by $\text{Min}(1, 1.25 \cdot (lb/ld)^{2/3})$, from 10.3.5, ASCE 41-17.

with fsv = fs = 389.0139

with Esv = Es = 200000.00

1 = Asl,ten/(b*d)*(fs1/fc) = 0.10166207

2 = Asl,com/(b*d)*(fs2/fc) = 0.06639156

v = Asl,mid/(b*d)*(fsv/fc) = 0.06777471

and confined core properties:

b = 240.00
d = 327.00
d' = 12.00

fcc (5A.2, TBDY) = 33.00

cc (5A.5, TBDY) = 0.002

c = confinement factor = 1.00

$$1 = A_{s1,ten}/(b*d)*(f_{s1}/f_c) = 0.13873608$$

$$2 = A_{s1,com}/(b*d)*(f_{s2}/f_c) = 0.09060316$$

$$v = A_{s1,mid}/(b*d)*(f_{sv}/f_c) = 0.09249072$$

Case/Assumption: Unconfined full section - Steel rupture
satisfies Eq. (4.3)

--->
 $v < v_{s,y2}$ - LHS eq.(4.5) is satisfied

$$s_u(4.9) = 0.22379076$$

$$\mu_u = M_{Rc}(4.14) = 1.5703E+008$$

$$u = s_u(4.1) = 1.8476637E-005$$

Calculation of ratio l_b/l_d

Inadequate Lap Length with $l_b/l_d = 0.30$

Calculation of Shear Strength $V_r = \min(V_{r1}, V_{r2}) = 289894.477$

Calculation of Shear Strength at edge 1, $V_{r1} = 289894.477$
 $V_{r1} = V_n$ ((22.5.1.1), ACI 318-14)

NOTE: In expression (22.5.1.1) 'V_w' is replaced by 'V_w + f*V_f'
where V_f is the contribution of FRPs (11.3), ACI 440).

From Table (22.5.5.1), ACI 318-14: $V_c = 103724.534$
= 1 (normal-weight concrete)
 $f'_c = 33.00$, but $f_c^{0.5} \leq 8.3$ MPa (22.5.3.1, ACI 318-14)
 $\rho_w = A_s/(b_w*d) = 0.00949023$
 A_s (tension reinf.) = 911.0619
 $b_w = 300.00$
 $d = 320.00$
 $V_u*d/\mu_u < 1 = 1.00$
 $\mu_u = 71267.116$
 $V_u = 2771.021$

From (11.5.4.8), ACI 318-14: $V_s = 186169.943$
 $A_v = 157079.633$
 $f_y = 555.56$
 $s = 150.00$
 V_s has been multiplied by 1 ($s < d/2$, according to ASCE 41-17,10.3.4)
 V_f ((11-3)-(11.4), ACI 440) = 0.00
From (11-11), ACI 440: $V_s + V_f \leq 366348.956$

Calculation of Shear Strength at edge 2, $V_{r2} = 289894.477$
 $V_{r2} = V_n$ ((22.5.1.1), ACI 318-14)

NOTE: In expression (22.5.1.1) 'V_w' is replaced by 'V_w + f*V_f'
where V_f is the contribution of FRPs (11.3), ACI 440).

From Table (22.5.5.1), ACI 318-14: $V_c = 103724.534$
= 1 (normal-weight concrete)
 $f'_c = 33.00$, but $f_c^{0.5} \leq 8.3$ MPa (22.5.3.1, ACI 318-14)
 $\rho_w = A_s/(b_w*d) = 0.00949023$
 A_s (tension reinf.) = 911.0619
 $b_w = 300.00$
 $d = 320.00$
 $V_u*d/\mu_u < 1 = 1.00$
 $\mu_u = 71267.116$
 $V_u = 2771.021$

From (11.5.4.8), ACI 318-14: $V_s = 186169.943$
 $A_v = 157079.633$
 $f_y = 555.56$
 $s = 150.00$
 V_s has been multiplied by 1 ($s < d/2$, according to ASCE 41-17,10.3.4)

Vf ((11-3)-(11.4), ACI 440) = 0.00
From (11-11), ACI 440: Vs + Vf <= 366348.956

End Of Calculation of Shear Capacity ratio for element: beam B1 of floor 1
At local axis: 3

Start Of Calculation of Shear Capacity ratio for element: beam B1 of floor 1
At Shear local axis: 2
(Bending local axis: 3)
Section Type: rcars

Constant Properties

Knowledge Factor, = 1.00
Mean strength values are used for both shear and moment calculations.
Consequently:
New material of Secondary Member: Concrete Strength, fc = fcm = 33.00
New material of Secondary Member: Steel Strength, fs = fsm = 555.56
Concrete Elasticity, Ec = 26999.444
Steel Elasticity, Es = 200000.00

Note: Especially for the calculation of moment strengths,
the above steel re-bar strengths are multiplied by 1.25 according to R18.6.5, ACI 318-14
New material: Steel Strength, fs = 1.25*fsm = 694.45

Section Height, H = 400.00
Section Width, W = 300.00
Cover Thickness, c = 25.00
Mean Confinement Factor overall section = 1.00
Element Length, L = 1850.00
Secondary Member
Smooth Bars
Ductile Steel
Without Detailing for Earthquake Resistance (including stirrups not closed at 135°)
Longitudinal Bars With Ends Lapped Starting at the End Sections
Inadequate Lap Length with lo/lo,min = 0.30
No FRP Wrapping

Stepwise Properties

At local axis: 2
EDGE -A-
Shear Force, Va = 4.9160836E-020
EDGE -B-
Shear Force, Vb = -4.9160836E-020
BOTH EDGES
Axial Force, F = -190.8684
Longitudinal Reinforcement Area Distribution (in 2 divisions)
-Tension: Aslt = 911.0619
-Compression: Aslc = 1231.504
Longitudinal Reinforcement Area Distribution (in 3 divisions)
-Tension: Asl,ten = 816.8141
-Compression: Asl,com = 816.8141
-Middle: Asl,mid = 508.938

Calculation of Shear Capacity ratio , Ve/Vr = 0.54312483
Member Controlled by Flexure (Ve/Vr < 1)
Calculation of Shear Demand from fig. R18.6.5, ACI 318-14 Ve = (Mpr1 + Mpr2)/ln ± wu*ln/2 = 104799.778
with
Mpr1 = Max(Mu1+ , Mu1-) = 9.6940E+007

Mu1+ = 9.6940E+007, is the ultimate moment strength at the edge 1 of the member in the actual moment direction which is defined for the static loading combination

Mu1- = 9.6940E+007, is the ultimate moment strength at the edge 1 of the member in the opposite moment direction which is defined for the static loading combination

Mpr2 = Max(Mu2+ , Mu2-) = 9.6940E+007

Mu2+ = 9.6940E+007, is the ultimate moment strength at the edge 2 of the member in the actual moment direction which is defined for the the static loading combination

Mu2- = 9.6940E+007, is the ultimate moment strength at the edge 2 of the member in the opposite moment direction which is defined for the the static loading combination

and

$\pm wu*ln = (|V1| + |V2|)/2$

with

V1 = 4.9160836E-020, is the shear force acting at edge 1 for the the static loading combination

V2 = -4.9160836E-020, is the shear force acting at edge 2 for the the static loading combination

Calculation of Mu1+

Calculation of ultimate curvature u according to 4.1, Biskinis/Fardis 2013:

$u = 2.5454950E-005$

$Mu = 9.6940E+007$

with full section properties:

$b = 400.00$

$d = 258.00$

$d' = 42.00$

$v = 5.6045447E-005$

$N = 190.8684$

$fc = 33.00$

$co (5A.5, TBDY) = 0.002$

Final value of cu : $cu^* = shear_factor * Max(cu, cc) = 0.00553582$

The Shear_factor is considered equal to 1 (pure moment strength)

From (5.4b), TBDY: $cu = 0.00553582$

$w_e (5.4c) = 0.00259035$

$ase ((5.4d), TBDY) = 0.15672608$

$bo = 240.00$

$ho = 340.00$

$bi2 = 346400.00$

$psh,min = Min(psh,x, psh,y) = 0.00261799$

Expression ((5.4d), TBDY) for psh,min has been multiplied by 0.3 according to 15.7.1.3 for members without earthquake detailing (90° closed stirrups)

 $psh,x (5.4d) = 0.00349066$

$Ash = Astir*ns = 78.53982$

No stirrups, $ns = 2.00$

$bk = 300.00$

 $psh,y (5.4d) = 0.00261799$

$Ash = Astir*ns = 78.53982$

No stirrups, $ns = 2.00$

$bk = 400.00$

 $s = 150.00$

$fywe = 694.45$

$fce = 33.00$

From ((5A5), TBDY), TBDY: $cc = 0.002$

$c = confinement\ factor = 1.00$

$y1 = 0.00140044$

$sh1 = 0.0044814$

$ft1 = 466.8167$

$fy1 = 389.0139$

$su1 = 0.00512$

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor

and also multiplied by the shear_factor according to 15.7.1.4, with

Shear_factor = 1.00

$$l_o/l_{o,min} = l_b/l_d = 0.30$$

$$s_u1 = 0.4 * e_{s1_nominal} ((5.5), TBDY) = 0.032$$

$$\text{From table 5A.1, TBDY: } e_{s1_nominal} = 0.08,$$

For calculation of $e_{s1_nominal}$ and y_1, sh_1, ft_1, fy_1 , it is considered characteristic value $f_{sy1} = f_s/1.2$, from table 5.1, TBDY.

y_1, sh_1, ft_1, fy_1 , are also multiplied by $\text{Min}(1, 1.25 * (l_b/l_d)^{2/3})$, from 10.3.5, ASCE 41-17.

$$\text{with } f_{s1} = f_s = 389.0139$$

$$\text{with } E_{s1} = E_s = 200000.00$$

$$y_2 = 0.00140044$$

$$sh_2 = 0.0044814$$

$$ft_2 = 466.8167$$

$$fy_2 = 389.0139$$

$$s_u2 = 0.00512$$

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor

and also multiplied by the shear_factor according to 15.7.1.4, with

$$\text{Shear_factor} = 1.00$$

$$l_o/l_{o,min} = l_b/l_{b,min} = 0.30$$

$$s_u2 = 0.4 * e_{s2_nominal} ((5.5), TBDY) = 0.032$$

$$\text{From table 5A.1, TBDY: } e_{s2_nominal} = 0.08,$$

For calculation of $e_{s2_nominal}$ and y_2, sh_2, ft_2, fy_2 , it is considered characteristic value $f_{sy2} = f_{s2}/1.2$, from table 5.1, TBDY.

y_2, sh_2, ft_2, fy_2 , are also multiplied by $\text{Min}(1, 1.25 * (l_b/l_d)^{2/3})$, from 10.3.5, ASCE 41-17.

$$\text{with } f_{s2} = f_s = 389.0139$$

$$\text{with } E_{s2} = E_s = 200000.00$$

$$y_v = 0.00140044$$

$$sh_v = 0.0044814$$

$$ft_v = 466.8167$$

$$fy_v = 389.0139$$

$$s_{u,v} = 0.00512$$

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor

and also multiplied by the shear_factor according to 15.7.1.4, with

$$\text{Shear_factor} = 1.00$$

$$l_o/l_{o,min} = l_b/l_d = 0.30$$

$$s_{u,v} = 0.4 * e_{s_{u,v}}_{nominal} ((5.5), TBDY) = 0.032$$

$$\text{From table 5A.1, TBDY: } e_{s_{u,v}}_{nominal} = 0.08,$$

considering characteristic value $f_{s_{y,v}} = f_{s_{v}}/1.2$, from table 5.1, TBDY

For calculation of $e_{s_{u,v}}_{nominal}$ and y_v, sh_v, ft_v, fy_v , it is considered characteristic value $f_{s_{y,v}} = f_{s_{v}}/1.2$, from table 5.1, TBDY.

y_1, sh_1, ft_1, fy_1 , are also multiplied by $\text{Min}(1, 1.25 * (l_b/l_d)^{2/3})$, from 10.3.5, ASCE 41-17.

$$\text{with } f_{s_{v}} = f_s = 389.0139$$

$$\text{with } E_{s_{v}} = E_s = 200000.00$$

$$1 = A_{s1,ten}/(b*d) * (f_{s1}/f_c) = 0.09330282$$

$$2 = A_{s1,com}/(b*d) * (f_{s2}/f_c) = 0.09330282$$

$$v = A_{s1,mid}/(b*d) * (f_{s_{v}}/f_c) = 0.05813483$$

and confined core properties:

$$b = 340.00$$

$$d = 228.00$$

$$d' = 12.00$$

$$f_{cc} (5A.2, TBDY) = 33.00$$

$$c_c (5A.5, TBDY) = 0.002$$

$$c = \text{confinement factor} = 1.00$$

$$1 = A_{s1,ten}/(b*d) * (f_{s1}/f_c) = 0.12421118$$

$$2 = A_{s1,com}/(b*d) * (f_{s2}/f_c) = 0.12421118$$

$$v = A_{s1,mid}/(b*d) * (f_{s_{v}}/f_c) = 0.07739312$$

Case/Assumption: Unconfined full section - Steel rupture

' satisfies Eq. (4.3)

--->

$v < v_{s,y2}$ - LHS eq.(4.5) is satisfied

--->

$$s_u (4.9) = 0.22038892$$

$$\mu = M_{Rc} (4.14) = 9.6940E+007$$

$$u = s_u (4.1) = 2.5454950E-005$$

Calculation of ratio l_b/l_d

Inadequate Lap Length with $l_b/l_d = 0.30$

Calculation of Mu1-

Calculation of ultimate curvature μ according to 4.1, Biskinis/Fardis 2013:

$$\mu = 2.5454950E-005$$

$$Mu = 9.6940E+007$$

with full section properties:

$$b = 400.00$$

$$d = 258.00$$

$$d' = 42.00$$

$$v = 5.6045447E-005$$

$$N = 190.8684$$

$$f_c = 33.00$$

$$c_o \text{ (5A.5, TBDY)} = 0.002$$

$$\text{Final value of } c_u: c_u^* = \text{shear_factor} * \text{Max}(c_u, c_c) = 0.00553582$$

The Shear_factor is considered equal to 1 (pure moment strength)

$$\text{From (5.4b), TBDY: } c_u = 0.00553582$$

$$w_e \text{ (5.4c)} = 0.00259035$$

$$a_{se} \text{ ((5.4d), TBDY)} = 0.15672608$$

$$b_o = 240.00$$

$$h_o = 340.00$$

$$b_{i2} = 346400.00$$

$$p_{sh,min} = \text{Min}(p_{sh,x}, p_{sh,y}) = 0.00261799$$

Expression ((5.4d), TBDY) for $p_{sh,min}$ has been multiplied by 0.3 according to 15.7.1.3 for members without earthquake detailing (90° closed stirrups)

$$p_{sh,x} \text{ (5.4d)} = 0.00349066$$

$$A_{sh} = A_{stir} * n_s = 78.53982$$

$$\text{No stirrups, } n_s = 2.00$$

$$b_k = 300.00$$

$$p_{sh,y} \text{ (5.4d)} = 0.00261799$$

$$A_{sh} = A_{stir} * n_s = 78.53982$$

$$\text{No stirrups, } n_s = 2.00$$

$$b_k = 400.00$$

$$s = 150.00$$

$$f_{ywe} = 694.45$$

$$f_{ce} = 33.00$$

$$\text{From ((5.A5), TBDY), TBDY: } c_c = 0.002$$

$$c = \text{confinement factor} = 1.00$$

$$y_1 = 0.00140044$$

$$sh_1 = 0.0044814$$

$$ft_1 = 466.8167$$

$$fy_1 = 389.0139$$

$$su_1 = 0.00512$$

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor and also multiplied by the shear_factor according to 15.7.1.4, with Shear_factor = 1.00

$$l_o/l_{ou,min} = l_b/d = 0.30$$

$$su_1 = 0.4 * esu_1_{nominal} \text{ ((5.5), TBDY)} = 0.032$$

$$\text{From table 5A.1, TBDY: } esu_1_{nominal} = 0.08,$$

For calculation of $esu_1_{nominal}$ and y_1, sh_1, ft_1, fy_1 , it is considered characteristic value $fsy_1 = fs_1/1.2$, from table 5.1, TBDY.

y_1, sh_1, ft_1, fy_1 , are also multiplied by $\text{Min}(1, 1.25 * (l_b/d)^{2/3})$, from 10.3.5, ASCE 41-17.

$$\text{with } fs_1 = fs = 389.0139$$

$$\text{with } Es_1 = Es = 200000.00$$

$$y_2 = 0.00140044$$

$$sh_2 = 0.0044814$$

$$ft_2 = 466.8167$$

$$fy_2 = 389.0139$$

$$su_2 = 0.00512$$

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00
 $l_o/l_{o,min} = l_b/l_{b,min} = 0.30$
 $su_2 = 0.4 * esu_{2,nominal} ((5.5), TBDY) = 0.032$
From table 5A.1, TBDY: $esu_{2,nominal} = 0.08$,
For calculation of $esu_{2,nominal}$ and y_2, sh_2, ft_2, fy_2 , it is considered
characteristic value $fsy_2 = fs_2/1.2$, from table 5.1, TBDY.
 y_1, sh_1, ft_1, fy_1 , are also multiplied by $Min(1, 1.25 * (l_b/l_d)^{2/3})$, from 10.3.5, ASCE 41-17.
with $fs_2 = fs = 389.0139$
with $Es_2 = Es = 200000.00$

$y_v = 0.00140044$
 $sh_v = 0.0044814$
 $ft_v = 466.8167$
 $fy_v = 389.0139$
 $su_v = 0.00512$

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00
 $l_o/l_{o,min} = l_b/l_d = 0.30$
 $su_v = 0.4 * esu_{v,nominal} ((5.5), TBDY) = 0.032$
From table 5A.1, TBDY: $esu_{v,nominal} = 0.08$,
considering characteristic value $fsy_v = fsv/1.2$, from table 5.1, TBDY
For calculation of $esu_{v,nominal}$ and y_v, sh_v, ft_v, fy_v , it is considered
characteristic value $fsy_v = fsv/1.2$, from table 5.1, TBDY.
 y_1, sh_1, ft_1, fy_1 , are also multiplied by $Min(1, 1.25 * (l_b/l_d)^{2/3})$, from 10.3.5, ASCE 41-17.
with $fsv = fs = 389.0139$
with $Es_v = Es = 200000.00$

$1 = A_{sl,ten}/(b*d) * (fs_1/f_c) = 0.09330282$
 $2 = A_{sl,com}/(b*d) * (fs_2/f_c) = 0.09330282$
 $v = A_{sl,mid}/(b*d) * (fsv/f_c) = 0.05813483$

and confined core properties:

$b = 340.00$
 $d = 228.00$
 $d' = 12.00$
 $f_{cc} (5A.2, TBDY) = 33.00$
 $cc (5A.5, TBDY) = 0.002$
 $c = \text{confinement factor} = 1.00$
 $1 = A_{sl,ten}/(b*d) * (fs_1/f_c) = 0.12421118$
 $2 = A_{sl,com}/(b*d) * (fs_2/f_c) = 0.12421118$
 $v = A_{sl,mid}/(b*d) * (fsv/f_c) = 0.07739312$

Case/Assumption: Unconfined full section - Steel rupture
satisfies Eq. (4.3)

--->
 $v < v_{s,y2}$ - LHS eq.(4.5) is satisfied

--->
 $su (4.9) = 0.22038892$
 $Mu = MRc (4.14) = 9.6940E+007$
 $u = su (4.1) = 2.5454950E-005$

Calculation of ratio l_b/l_d

Inadequate Lap Length with $l_b/l_d = 0.30$

Calculation of Mu_{2+}

Calculation of ultimate curvature u according to 4.1, Biskinis/Fardis 2013:

$u = 2.5454950E-005$
 $Mu = 9.6940E+007$

with full section properties:

$b = 400.00$

d = 258.00
d' = 42.00
v = 5.6045447E-005
N = 190.8684
fc = 33.00

co (5A.5, TBDY) = 0.002

Final value of cu: $cu^* = \text{shear_factor} * \text{Max}(cu, cc) = 0.00553582$

The Shear_factor is considered equal to 1 (pure moment strength)

From (5.4b), TBDY: $cu = 0.00553582$

we (5.4c) = 0.00259035

ase ((5.4d), TBDY) = 0.15672608

bo = 240.00

ho = 340.00

bi2 = 346400.00

psh,min = $\text{Min}(psh,x, psh,y) = 0.00261799$

Expression ((5.4d), TBDY) for psh,min has been multiplied by 0.3 according to 15.7.1.3 for members without earthquake detailing (90° closed stirrups)

psh,x (5.4d) = 0.00349066

Ash = $\text{Astir} * ns = 78.53982$

No stirrups, ns = 2.00

bk = 300.00

psh,y (5.4d) = 0.00261799

Ash = $\text{Astir} * ns = 78.53982$

No stirrups, ns = 2.00

bk = 400.00

s = 150.00

fywe = 694.45

fce = 33.00

From ((5.A5), TBDY), TBDY: $cc = 0.002$

c = confinement factor = 1.00

y1 = 0.00140044

sh1 = 0.0044814

ft1 = 466.8167

fy1 = 389.0139

su1 = 0.00512

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor and also multiplied by the shear_factor according to 15.7.1.4, with Shear_factor = 1.00

lo/lou,min = $lb/ld = 0.30$

su1 = $0.4 * esu1_nominal$ ((5.5), TBDY) = 0.032

From table 5A.1, TBDY: $esu1_nominal = 0.08$,

For calculation of $esu1_nominal$ and $y1, sh1, ft1, fy1$, it is considered characteristic value $fsy1 = fs1/1.2$, from table 5.1, TBDY.

$y1, sh1, ft1, fy1$, are also multiplied by $\text{Min}(1, 1.25 * (lb/ld)^{2/3})$, from 10.3.5, ASCE 41-17.

with $fs1 = fs = 389.0139$

with $Es1 = Es = 200000.00$

y2 = 0.00140044

sh2 = 0.0044814

ft2 = 466.8167

fy2 = 389.0139

su2 = 0.00512

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor and also multiplied by the shear_factor according to 15.7.1.4, with Shear_factor = 1.00

lo/lou,min = $lb/lb,min = 0.30$

su2 = $0.4 * esu2_nominal$ ((5.5), TBDY) = 0.032

From table 5A.1, TBDY: $esu2_nominal = 0.08$,

For calculation of $esu2_nominal$ and $y2, sh2, ft2, fy2$, it is considered characteristic value $fsy2 = fs2/1.2$, from table 5.1, TBDY.

$y2, sh2, ft2, fy2$, are also multiplied by $\text{Min}(1, 1.25 * (lb/ld)^{2/3})$, from 10.3.5, ASCE 41-17.

with $fs2 = fs = 389.0139$

with $Es2 = Es = 200000.00$

yv = 0.00140044

shv = 0.0044814

$$ftv = 466.8167$$

$$fyv = 389.0139$$

$$suv = 0.00512$$

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00

$$lo/lo_{u,min} = lb/d = 0.30$$

$$suv = 0.4 * esuv_{nominal} ((5.5), TBDY) = 0.032$$

From table 5A.1, TBDY: $esuv_{nominal} = 0.08$,

considering characteristic value $fsyv = fsv/1.2$, from table 5.1, TBDY

For calculation of $esuv_{nominal}$ and yv , shv , ftv , fyv , it is considered
characteristic value $fsyv = fsv/1.2$, from table 5.1, TBDY.

$y1$, $sh1$, $ft1$, $fy1$, are also multiplied by $\text{Min}(1, 1.25 * (lb/d)^{2/3})$, from 10.3.5, ASCE 41-17.

$$\text{with } fsv = fs = 389.0139$$

$$\text{with } Esv = Es = 200000.00$$

$$1 = Asl_{ten}/(b*d)*(fs1/fc) = 0.09330282$$

$$2 = Asl_{com}/(b*d)*(fs2/fc) = 0.09330282$$

$$v = Asl_{mid}/(b*d)*(fsv/fc) = 0.05813483$$

and confined core properties:

$$b = 340.00$$

$$d = 228.00$$

$$d' = 12.00$$

$$fcc (5A.2, TBDY) = 33.00$$

$$cc (5A.5, TBDY) = 0.002$$

$$c = \text{confinement factor} = 1.00$$

$$1 = Asl_{ten}/(b*d)*(fs1/fc) = 0.12421118$$

$$2 = Asl_{com}/(b*d)*(fs2/fc) = 0.12421118$$

$$v = Asl_{mid}/(b*d)*(fsv/fc) = 0.07739312$$

Case/Assumption: Unconfined full section - Steel rupture

' satisfies Eq. (4.3)

$v < vs, y2$ - LHS eq.(4.5) is satisfied

$$su (4.9) = 0.22038892$$

$$Mu = MRc (4.14) = 9.6940E+007$$

$$u = su (4.1) = 2.5454950E-005$$

Calculation of ratio lb/d

Inadequate Lap Length with $lb/d = 0.30$

Calculation of $Mu2$ -

Calculation of ultimate curvature u according to 4.1, Biskinis/Fardis 2013:

$$u = 2.5454950E-005$$

$$Mu = 9.6940E+007$$

with full section properties:

$$b = 400.00$$

$$d = 258.00$$

$$d' = 42.00$$

$$v = 5.6045447E-005$$

$$N = 190.8684$$

$$fc = 33.00$$

$$co (5A.5, TBDY) = 0.002$$

$$\text{Final value of } cu: cu^* = \text{shear_factor} * \text{Max}(cu, cc) = 0.00553582$$

The Shear_factor is considered equal to 1 (pure moment strength)

$$\text{From (5.4b), TBDY: } cu = 0.00553582$$

$$we (5.4c) = 0.00259035$$

$$ase ((5.4d), TBDY) = 0.15672608$$

$$bo = 240.00$$

$$ho = 340.00$$

$$bi2 = 346400.00$$

$$psh,min = \text{Min}(psh,x, psh,y) = 0.00261799$$

Expression ((5.4d), TBDY) for psh,min has been multiplied by 0.3 according to 15.7.1.3 for members without earthquake detailing (90° closed stirrups)

$$psh,x (5.4d) = 0.00349066$$

$$Ash = Astir*ns = 78.53982$$

$$\text{No stirrups, } ns = 2.00$$

$$bk = 300.00$$

$$psh,y (5.4d) = 0.00261799$$

$$Ash = Astir*ns = 78.53982$$

$$\text{No stirrups, } ns = 2.00$$

$$bk = 400.00$$

$$s = 150.00$$

$$fywe = 694.45$$

$$fce = 33.00$$

From ((5.A5), TBDY), TBDY: $cc = 0.002$

$c =$ confinement factor = 1.00

$$y1 = 0.00140044$$

$$sh1 = 0.0044814$$

$$ft1 = 466.8167$$

$$fy1 = 389.0139$$

$$su1 = 0.00512$$

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor and also multiplied by the shear_factor according to 15.7.1.4, with Shear_factor = 1.00

$$lo/lou,min = lb/l_d = 0.30$$

$$su1 = 0.4*esu1_nominal ((5.5), TBDY) = 0.032$$

From table 5A.1, TBDY: $esu1_nominal = 0.08$,

For calculation of $esu1_nominal$ and $y1, sh1, ft1, fy1$, it is considered characteristic value $fsy1 = fs1/1.2$, from table 5.1, TBDY.

$y1, sh1, ft1, fy1$, are also multiplied by $\text{Min}(1, 1.25*(lb/l_d)^{2/3})$, from 10.3.5, ASCE 41-17.

$$\text{with } fs1 = fs = 389.0139$$

$$\text{with } Es1 = Es = 200000.00$$

$$y2 = 0.00140044$$

$$sh2 = 0.0044814$$

$$ft2 = 466.8167$$

$$fy2 = 389.0139$$

$$su2 = 0.00512$$

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor and also multiplied by the shear_factor according to 15.7.1.4, with Shear_factor = 1.00

$$lo/lou,min = lb/l_{b,min} = 0.30$$

$$su2 = 0.4*esu2_nominal ((5.5), TBDY) = 0.032$$

From table 5A.1, TBDY: $esu2_nominal = 0.08$,

For calculation of $esu2_nominal$ and $y2, sh2, ft2, fy2$, it is considered characteristic value $fsy2 = fs2/1.2$, from table 5.1, TBDY.

$y2, sh2, ft2, fy2$, are also multiplied by $\text{Min}(1, 1.25*(lb/l_d)^{2/3})$, from 10.3.5, ASCE 41-17.

$$\text{with } fs2 = fs = 389.0139$$

$$\text{with } Es2 = Es = 200000.00$$

$$yv = 0.00140044$$

$$shv = 0.0044814$$

$$ftv = 466.8167$$

$$fyv = 389.0139$$

$$suv = 0.00512$$

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor and also multiplied by the shear_factor according to 15.7.1.4, with Shear_factor = 1.00

$$lo/lou,min = lb/l_d = 0.30$$

$$suv = 0.4*esuv_nominal ((5.5), TBDY) = 0.032$$

From table 5A.1, TBDY: $esuv_nominal = 0.08$,

considering characteristic value $fsyv = fsv/1.2$, from table 5.1, TBDY

For calculation of $esuv_nominal$ and yv, shv, ftv, fyv , it is considered characteristic value $fsyv = fsv/1.2$, from table 5.1, TBDY.

$y1, sh1, ft1, fy1$, are also multiplied by $\text{Min}(1, 1.25*(lb/l_d)^{2/3})$, from 10.3.5, ASCE 41-17.

with $f_{sv} = f_s = 389.0139$
with $E_{sv} = E_s = 200000.00$
 $1 = A_{sl,ten}/(b*d)*(f_{s1}/f_c) = 0.09330282$
 $2 = A_{sl,com}/(b*d)*(f_{s2}/f_c) = 0.09330282$
 $v = A_{sl,mid}/(b*d)*(f_{sv}/f_c) = 0.05813483$

and confined core properties:

$b = 340.00$
 $d = 228.00$
 $d' = 12.00$
 $f_{cc} (5A.2, TBDY) = 33.00$
 $cc (5A.5, TBDY) = 0.002$
 $c = \text{confinement factor} = 1.00$
 $1 = A_{sl,ten}/(b*d)*(f_{s1}/f_c) = 0.12421118$
 $2 = A_{sl,com}/(b*d)*(f_{s2}/f_c) = 0.12421118$
 $v = A_{sl,mid}/(b*d)*(f_{sv}/f_c) = 0.07739312$

Case/Assumption: Unconfined full section - Steel rupture
' satisfies Eq. (4.3)

--->
 $v < v_{s,y2}$ - LHS eq.(4.5) is satisfied

--->
 $su (4.9) = 0.22038892$
 $\mu_u = MR_c (4.14) = 9.6940E+007$
 $u = su (4.1) = 2.5454950E-005$

Calculation of ratio l_b/d

Inadequate Lap Length with $l_b/d = 0.30$

Calculation of Shear Strength $V_r = \text{Min}(V_{r1}, V_{r2}) = 192957.075$

Calculation of Shear Strength at edge 1, $V_{r1} = 192957.075$
 $V_{r1} = V_n ((22.5.1.1), ACI 318-14)$

NOTE: In expression (22.5.1.1) ' V_w ' is replaced by ' $V_w + f*V_f$ '
where V_f is the contribution of FRPs (11.3), ACI 440).

From Table (22.5.5.1), ACI 318-14: $V_c = 88236.482$
 $= 1$ (normal-weight concrete)
 $f_c' = 33.00$, but $f_c'^{0.5} \leq 8.3$ MPa (22.5.3.1, ACI 318-14)
 $p_w = A_s/(b_w*d) = 0.00949023$
 A_s (tension reinf.) = 911.0619
 $b_w = 400.00$
 $d = 240.00$
 $V_u*d/\mu_u < 1 = 0.00$
 $\mu_u = 3.3205266E-012$
 $V_u = 4.9160836E-020$

From (11.5.4.8), ACI 318-14: $V_s = 104720.593$
 $A_v = 157079.633$
 $f_y = 555.56$
 $s = 150.00$
 V_s has been multiplied by $2(1-s/d)$ ($s > d/2$, according to ASCE 41-17, 10.3.4)
 $2(1-s/d) = 0.75$
 $V_f ((11-3)-(11.4), ACI 440) = 0.00$
From (11-11), ACI 440: $V_s + V_f \leq 366348.956$

Calculation of Shear Strength at edge 2, $V_{r2} = 192957.075$
 $V_{r2} = V_n ((22.5.1.1), ACI 318-14)$

NOTE: In expression (22.5.1.1) ' V_w ' is replaced by ' $V_w + f*V_f$ '
where V_f is the contribution of FRPs (11.3), ACI 440).

From Table (22.5.5.1), ACI 318-14: $V_c = 88236.482$
 $= 1$ (normal-weight concrete)

$f_c' = 33.00$, but $f_c^{0.5} \leq 8.3$ MPa (22.5.3.1, ACI 318-14)

$\rho_w = A_s/(b_w \cdot d) = 0.00949023$

A_s (tension reinf.) = 911.0619

$b_w = 400.00$

$d = 240.00$

$V_u \cdot d / \mu_u < 1 = 0.00$

$\mu_u = 3.3203395E-012$

$V_u = 4.9160836E-020$

From (11.5.4.8), ACI 318-14: $V_s = 104720.593$

$A_v = 157079.633$

$f_y = 555.56$

$s = 150.00$

V_s has been multiplied by $2(1-s/d)$ ($s > d/2$, according to ASCE 41-17, 10.3.4)

$2(1-s/d) = 0.75$

V_f ((11-3)-(11.4), ACI 440) = 0.00

From (11-11), ACI 440: $V_s + V_f \leq 366348.956$

End Of Calculation of Shear Capacity ratio for element: beam B1 of floor 1

At local axis: 2

Start Of Calculation of Chord Rotation Capacity for element: beam B1 of floor 1

At local axis: 3

Integration Section: (b)

Section Type: rcars

Constant Properties

Knowledge Factor, $\gamma = 1.00$

Chord Rotation is generally considered as Deformation-Controlled Action according to Table C7-1, ASCE 41-17.

Mean strengths are used for Deformation-Controlled Actions according to 7.5.1.3, ASCE 41-17

Consequently:

New material of Secondary Member: Concrete Strength, $f_c = f_{cm} = 33.00$

New material of Secondary Member: Steel Strength, $f_s = f_{sm} = 555.56$

Concrete Elasticity, $E_c = 26999.444$

Steel Elasticity, $E_s = 200000.00$

Section Height, $H = 400.00$

Section Width, $W = 300.00$

Cover Thickness, $c = 25.00$

Element Length, $L = 1850.00$

Secondary Member

Smooth Bars

Ductile Steel

Without Detailing for Earthquake Resistance (including stirrups not closed at 135°)

Longitudinal Bars With Ends Lapped Starting at the End Sections

Inadequate Lap Length with $l_b / l_d = 0.30$

No FRP Wrapping

Stepwise Properties

Bending Moment, $M = 4.4346397E-011$

Shear Force, $V_2 = -3.3781306E-014$

Shear Force, $V_3 = 7475.372$

Axial Force, $F = -457.6821$

Longitudinal Reinforcement Area Distribution (in 2 divisions)

-Tension: $A_{st} = 923.6282$

-Compression: $A_{sc} = 1218.938$

Longitudinal Reinforcement Area Distribution (in 3 divisions)

-Tension: $A_{st,ten} = 816.8141$

-Compression: $A_{sc,com} = 816.8141$

-Middle: $A_{sl,mid} = 508.938$

Mean Diameter of Tension Reinforcement, $DbL = 14.40$

New component: From table 7-7, ASCE 41_17: Final chord rotation Capacity $u_{,R} = 1.0^*$ $u = 0.02295003$
 $u = y + p = 0.02295003$

- Calculation of y -

$y = (M_y * L_s / 3) / E_{eff} = 0.00295003$ ((4.29), Biskinis Phd))
 $M_y = 6.9747E+007$
 $L_s = M/V$ (with $L_s > 0.1 * L$ and $L_s < 2 * L$) = 925.00
From table 10.5, ASCE 41_17: $E_{eff} = 0.3 * E_c * I_g = 7.2898E+012$

Calculation of Yielding Moment M_y

Calculation of y and M_y according to Annex 7 -

$y = \text{Min}(y_{ten}, y_{com})$
 $y_{ten} = 8.5713381E-006$
with ((10.1), ASCE 41-17) $f_y = \text{Min}(f_y, 1.25 * f_y * (l_b / d)^{2/3}) = 311.2112$
 $d = 258.00$
 $y = 0.29634979$
 $A = 0.02077555$
 $B = 0.01208477$
with $p_t = 0.00791487$
 $p_c = 0.00791487$
 $p_v = 0.00493157$
 $N = 457.6821$
 $b = 400.00$
 $" = 0.1627907$
 $y_{comp} = 2.8785724E-005$
with $f_c = 33.00$
 $E_c = 26999.444$
 $y = 0.2962339$
 $A = 0.02075122$
 $B = 0.01207052$
with $E_s = 200000.00$

Calculation of ratio l_b / d

Inadequate Lap Length with $l_b / d = 0.30$

- Calculation of p -

From table 10-7: $p = 0.02$

with:

- Condition iv occurred
Beam controlled by inadequate embedment into beam-column joint:
($l_b / d < 1$ and With Lapping in the Vicinity of the End Regions)
- Condition i occurred
Beam controlled by flexure: $V_p / V_o \leq 1$
shear control ratio $V_p / V_o = 0.54312483$
- Transverse Reinforcement: NC
- Stirrup Spacing $> d / 3$
- Low ductility demand, $\lambda / y < 2$ (table 10-6, ASCE 41-17)
 $= 6.1862139E-024$
- Stirrup Spacing $> d / 2$
 $d = 258.00$
 $s = 150.00$
- Strength provided by hoops $V_s < 3/4 * \text{design Shear}$
 $V_s = 139627.457$, already given in calculation of shear control ratio
design Shear = $3.3781306E-014$

- (- ')/ bal = -0.16792835
= Aslt/(bw*d) = 0.00894989
Tension Reinf Area: Aslt = 923.6282
' = Aslc/(bw*d) = 0.01181141
Compression Reinf Area: Aslc = 1218.938
From (B-1), ACI 318-11: bal = 0.01704017
fc = 33.00
fy = 555.56
From 10.2.7.3, ACI 318-11: 1 = 0.65
From fig R10.3.3, ACI 318-11 (Ence 454, too): $87000/(87000+fy) = cb/dt = 0.003/(0.003+ y) = 0.51922877$
y = 0.0027778
- $V/(bw*d*fc^{0.5}) = 6.8621941E-019$, NOTE: units in lb & in
bw = 400.00

End Of Calculation of Chord Rotation Capacity for element: beam B1 of floor 1
At local axis: 3
Integration Section: (b)
