

Detailed Member Calculations

Units: N&mm

Regulation: ASCE 41-17

Calculation No. 1

beam B1, Floor 1



Limit State: Operational Level (data interpolation between analysis steps 1 and 2)

Analysis: Uniform +X

Check: Shear capacity V_{Rd}

Edge: Start

Local Axis: (2)



Start Of Calculation of Shear Capacity for element: beam B1 of floor 1

At local axis: 2

Integration Section: (a)

Section Type: rcars

Constant Properties

Knowledge Factor, $\gamma = 1.00$

Member Shear Force is generally considered as Force-Controlled Action according to Table C7-1, ASCE 41-17.

Lower-bound strengths are used for Force-Controlled Actions according to 7.5.1.3, ASCE 41-17

Consequently:

Existing material of Primary Member: Concrete Strength, $f_c = f_{c_lower_bound} = 16.00$

Existing material of Primary Member: Steel Strength, $f_s = f_{s_lower_bound} = 420.00$

Concrete Elasticity, $E_c = 23025.204$

Steel Elasticity, $E_s = 200000.00$
Section Height, $H = 400.00$
Section Width, $W = 300.00$
Cover Thickness, $c = 25.00$
Element Length, $L = 1850.00$
Primary Member
Smooth Bars
Ductile Steel
With Detailing for Earthquake Resistance (including stirrups closed at 135°)
Longitudinal Bars With Ends Lapped Starting at the End Sections
Adequate Lap Length ($l_o/l_{o,u,min} = l_b/l_d >= 1$)
No FRP Wrapping

Stepwise Properties

EDGE -A-
Bending Moment, $M_a = -1.1664849E-011$
Shear Force, $V_a = 3.0430585E-014$
EDGE -B-
Bending Moment, $M_b = 6.7903689E-011$
Shear Force, $V_b = -3.0430585E-014$
BOTH EDGES
Axial Force, $F = -560.8745$
Longitudinal Reinforcement Area Distribution (in 2 divisions)
-Tension: $A_{s,t} = 603.1858$
-Compression: $A_{s,c} = 923.6282$
Longitudinal Reinforcement Area Distribution (in 3 divisions)
-Tension: $A_{s,ten} = 508.938$
-Compression: $A_{s,com} = 508.938$
-Middle: $A_{s,mid} = 508.938$
Mean Diameter of Tension Reinforcement, $Db_{L,ten} = 14.66667$

Existing component: From table 7-7, ASCE 41_17: Final Shear Capacity $V_R = V_n = 140608.135$
 V_n ((22.5.1.1), ACI 318-14) = 140608.135

NOTE: In expression (22.5.1.1) 'Vw' is replaced by 'Vw + f*Vf'
where Vf is the contribution of FRPs (11.3), ACI 440).

From Table (22.5.5.1), ACI 318-14: $V_c = 61440.00$
= 1 (normal-weight concrete)
 $f_c' = 16.00$, but $f_c'^{0.5} <= 8.3$ MPa (22.5.3.1, ACI 318-14)
 $\rho_w = A_s/(b_w*d) = 0.00628319$
 A_s (tension reinf.) = 603.1858
 $b_w = 400.00$
 $d = 240.00$
 $V_u*d/M_u < 1 = 0.00$
 $M_u = 1.1664849E-011$
 $V_u = 3.0430585E-014$
From (11.5.4.8), ACI 318-14: $V_s = 79168.135$
 $A_v = 157079.633$
 $f_y = 420.00$
 $s = 150.00$
 V_s has been multiplied by $2(1-s/d)$ ($s > d/2$, according to ASCE 41-17, 10.3.4)
 $2(1-s/d) = 0.75$
 V_f ((11-3)-(11.4), ACI 440) = 0.00
From (11-11), ACI 440: $V_s + V_f <= 255092.67$

End Of Calculation of Shear Capacity for element: beam B1 of floor 1
At local axis: 2
Integration Section: (a)

Calculation No. 2

beam B1, Floor 1



Limit State: Operational Level (data interpolation between analysis steps 1 and 2)

Analysis: Uniform +X

Check: Chord rotation capacity (θ_r)

Edge: Start

Local Axis: (2)



Start Of Calculation of Shear Capacity ratio for element: beam B1 of floor 1

At Shear local axis: 3

(Bending local axis: 2)

Section Type: rcars

Constant Properties

Knowledge Factor, $\gamma = 1.00$

Mean strength values are used for both shear and moment calculations.

Consequently:

Existing material of Primary Member: Concrete Strength, $f_c = f_{cm} = 24.00$

Existing material of Primary Member: Steel Strength, $f_s = f_{sm} = 525.00$

Concrete Elasticity, $E_c = 23025.204$

Steel Elasticity, $E_s = 200000.00$

#####

Note: Especially for the calculation of moment strengths,

the above steel re-bar strengths are multiplied by 1.25 according to R18.6.5, ACI 318-14

Existing material: Steel Strength, $f_s = 1.25 \cdot f_{sm} = 656.25$

#####

Section Height, $H = 400.00$

Section Width, $W = 300.00$

Cover Thickness, $c = 25.00$

Mean Confinement Factor overall section = 1.09003

Element Length, $L = 1850.00$

Primary Member

Smooth Bars

Ductile Steel

With Detailing for Earthquake Resistance (including stirrups closed at 135°)

Longitudinal Bars With Ends Lapped Starting at the End Sections

Adequate Lap Length ($l_o/l_{o,u,min} \geq 1$)

No FRP Wrapping

Stepwise Properties

At local axis: 3

EDGE -A-

Shear Force, $V_a = 2740.265$

EDGE -B-

Shear Force, $V_b = 2740.264$

BOTH EDGES

Axial Force, $F = -211.0849$

Longitudinal Reinforcement Area Distribution (in 2 divisions)

-Tension: $As_t = 603.1858$

-Compression: $As_c = 923.6282$

Longitudinal Reinforcement Area Distribution (in 3 divisions)

-Tension: $As_{t,ten} = 603.1858$

-Compression: $As_{l,com} = 615.7522$

-Middle: $As_{l,mid} = 307.8761$

Calculation of Shear Capacity ratio, $V_e/V_r = 0.78793176$

Member Controlled by Flexure ($V_e/V_r < 1$)

Calculation of Shear Demand from fig. R18.6.5, ACI 318-14 $V_e = (M_{pr1} + M_{pr2})/l_n \pm w_u \cdot l_n / 2 = 205990.317$
with

$M_{pr1} = \text{Max}(M_{u1+}, M_{u1-}) = 1.8802E+008$

$M_{u1+} = 1.8495E+008$, is the ultimate moment strength at the edge 1 of the member in the actual moment direction which is defined for the static loading combination

$M_{u1-} = 1.8802E+008$, is the ultimate moment strength at the edge 1 of the member in the opposite moment direction which is defined for the static loading combination

$M_{pr2} = \text{Max}(M_{u2+}, M_{u2-}) = 1.8800E+008$

$M_{u2+} = 1.8498E+008$, is the ultimate moment strength at the edge 2 of the member in the actual moment direction which is defined for the the static loading combination

$M_{u2-} = 1.8800E+008$, is the ultimate moment strength at the edge 2 of the member in the opposite moment direction which is defined for the the static loading combination

and

$\pm w_u \cdot l_n = (|V_1| + |V_2|)/2$

with

$V_1 = 2740.265$, is the shear force acting at edge 1 for the the static loading combination

$V_2 = 2740.264$, is the shear force acting at edge 2 for the the static loading combination

Calculation of M_{u1+}

Calculation of ultimate curvature ϕ_u according to 4.1, Biskinis/Fardis 2013:

$\phi_u = 0.0001071$

$M_u = 1.8495E+008$

with full section properties:

$b = 300.00$

$d = 357.00$

$d' = 42.00$

$v = 8.2121432E-005$

$N = 211.0849$

$f_c = 24.00$

$\phi_{co} (5A.5, TBDY) = 0.002$

Final value of ϕ_{cu} : $\phi_{cu}^* = \text{shear_factor} * \text{Max}(\phi_{cu}, \phi_{cc}) = 0.00773686$

The Shear_factor is considered equal to 1 (pure moment strength)

From (5.4b), TBDY: $\phi_{cu} = 0.00773686$

$\phi_{we} (5.4c) = 0.01121936$

$\phi_{ase} ((5.4d), TBDY) = 0.15672608$

$\phi_{bo} = 240.00$

$\phi_{ho} = 340.00$

$\phi_{bi2} = 346400.00$

$$psh,min = \text{Min}(psh,x, psh,y) = 0.00261799$$

$$psh,x (5.4d) = 0.00349066$$

$$\text{Ash} = \text{Astir} * ns = 78.53982$$

$$\text{No stirups, ns} = 2.00$$

$$bk = 300.00$$

$$psh,y (5.4d) = 0.00261799$$

$$\text{Ash} = \text{Astir} * ns = 78.53982$$

$$\text{No stirups, ns} = 2.00$$

$$bk = 400.00$$

$$s = 150.00$$

$$fywe = 656.25$$

$$fce = 24.00$$

$$\text{From } ((5.A5), \text{TBDY}), \text{TBDY: } cc = 0.00290026$$

$$c = \text{confinement factor} = 1.09003$$

$$y1 = 0.0025$$

$$sh1 = 0.008$$

$$ft1 = 787.50$$

$$fy1 = 656.25$$

$$su1 = 0.032$$

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00

$$lo/lou,min = lb/ld = 1.00$$

$$su1 = 0.4 * esu1_nominal ((5.5), \text{TBDY}) = 0.032$$

From table 5A.1, TBDY: esu1_nominal = 0.08,

For calculation of esu1_nominal and y1, sh1,ft1,fy1, it is considered
characteristic value fsy1 = fs1/1.2, from table 5.1, TBDY.

y1, sh1,ft1,fy1, are also multiplied by $\text{Min}(1, 1.25 * (lb/ld)^{2/3})$, from 10.3.5, ASCE 41-17.

$$\text{with } fs1 = fs = 656.25$$

$$\text{with } Es1 = Es = 200000.00$$

$$y2 = 0.0025$$

$$sh2 = 0.008$$

$$ft2 = 787.50$$

$$fy2 = 656.25$$

$$su2 = 0.032$$

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00

$$lo/lou,min = lb/lb,min = 1.00$$

$$su2 = 0.4 * esu2_nominal ((5.5), \text{TBDY}) = 0.032$$

From table 5A.1, TBDY: esu2_nominal = 0.08,

For calculation of esu2_nominal and y2, sh2,ft2,fy2, it is considered
characteristic value fsy2 = fs2/1.2, from table 5.1, TBDY.

y1, sh1,ft1,fy1, are also multiplied by $\text{Min}(1, 1.25 * (lb/ld)^{2/3})$, from 10.3.5, ASCE 41-17.

$$\text{with } fs2 = fs = 656.25$$

$$\text{with } Es2 = Es = 200000.00$$

$$yv = 0.0025$$

$$shv = 0.008$$

$$ftv = 787.50$$

$$fyv = 656.25$$

$$suv = 0.032$$

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00

$$lo/lou,min = lb/ld = 1.00$$

$$suv = 0.4 * esuv_nominal ((5.5), \text{TBDY}) = 0.032$$

From table 5A.1, TBDY: esuv_nominal = 0.08,

considering characteristic value fsyv = fsv/1.2, from table 5.1, TBDY

For calculation of esuv_nominal and yv, shv,ftv,fyv, it is considered
characteristic value fsyv = fsv/1.2, from table 5.1, TBDY.

y1, sh1,ft1,fy1, are also multiplied by $\text{Min}(1, 1.25 * (lb/ld)^{2/3})$, from 10.3.5, ASCE 41-17.

$$\text{with } fsv = fs = 656.25$$

$$\text{with } Esv = Es = 200000.00$$

$$1 = \text{Asl,ten}/(b*d) * (fs1/fc) = 0.15399964$$

$$2 = A_{sl,com}/(b*d)*(f_s2/f_c) = 0.15720797$$

$$v = A_{sl,mid}/(b*d)*(f_{sv}/f_c) = 0.07860398$$

and confined core properties:

$$b = 240.00$$

$$d = 327.00$$

$$d' = 12.00$$

$$f_{cc} (5A.2, TBDY) = 26.16063$$

$$c_c (5A.5, TBDY) = 0.00290026$$

$$c = \text{confinement factor} = 1.09003$$

$$1 = A_{sl,ten}/(b*d)*(f_{s1}/f_c) = 0.21016006$$

$$2 = A_{sl,com}/(b*d)*(f_s2/f_c) = 0.21453839$$

$$v = A_{sl,mid}/(b*d)*(f_{sv}/f_c) = 0.1072692$$

Case/Assumption: Unconfined full section - Steel rupture

' satisfies Eq. (4.3)

--->

$v < v_{s,y2}$ - LHS eq.(4.5) is satisfied

--->

$$s_u (4.9) = 0.1630814$$

$$M_u = M_{Rc} (4.14) = 1.8495E+008$$

$$u = s_u (4.1) = 0.0001071$$

Calculation of ratio l_b/d

Adequate Lap Length: $l_b/d \geq 1$

Calculation of μ_{u1} -

Calculation of ultimate curvature μ_u according to 4.1, Biskinis/Fardis 2013:

$$u = 0.00010722$$

$$M_u = 1.8802E+008$$

with full section properties:

$$b = 300.00$$

$$d = 358.00$$

$$d' = 43.00$$

$$v = 8.1892042E-005$$

$$N = 211.0849$$

$$f_c = 24.00$$

$$c_c (5A.5, TBDY) = 0.002$$

$$\text{Final value of } c_u: c_u^* = \text{shear_factor} * \text{Max}(c_u, c_c) = 0.00773686$$

The Shear_factor is considered equal to 1 (pure moment strength)

$$\text{From (5.4b), TBDY: } c_u = 0.00773686$$

$$w_e (5.4c) = 0.01121936$$

$$a_{se} ((5.4d), TBDY) = 0.15672608$$

$$b_o = 240.00$$

$$h_o = 340.00$$

$$b_{i2} = 346400.00$$

$$p_{sh,min} = \text{Min}(p_{sh,x}, p_{sh,y}) = 0.00261799$$

$$p_{sh,x} (5.4d) = 0.00349066$$

$$A_{sh} = A_{stir} * n_s = 78.53982$$

$$\text{No stirups, } n_s = 2.00$$

$$b_k = 300.00$$

$$p_{sh,y} (5.4d) = 0.00261799$$

$$A_{sh} = A_{stir} * n_s = 78.53982$$

$$\text{No stirups, } n_s = 2.00$$

$$b_k = 400.00$$

$$s = 150.00$$

$$f_{ywe} = 656.25$$

$$f_{ce} = 24.00$$

From ((5.A.5), TBDY), TBDY: $cc = 0.00290026$
 $c = \text{confinement factor} = 1.09003$

$y1 = 0.0025$
 $sh1 = 0.008$
 $ft1 = 787.50$
 $fy1 = 656.25$
 $su1 = 0.032$

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00

$lo/lou,min = lb/ld = 1.00$

$su1 = 0.4 * esu1_nominal ((5.5), TBDY) = 0.032$

From table 5A.1, TBDY: $esu1_nominal = 0.08$,

For calculation of $esu1_nominal$ and $y1, sh1, ft1, fy1$, it is considered
characteristic value $fsy1 = fs1/1.2$, from table 5.1, TBDY.

$y1, sh1, ft1, fy1$, are also multiplied by $\text{Min}(1, 1.25 * (lb/ld)^{2/3})$, from 10.3.5, ASCE 41-17.

with $fs1 = fs = 656.25$

with $Es1 = Es = 200000.00$

$y2 = 0.0025$
 $sh2 = 0.008$
 $ft2 = 787.50$
 $fy2 = 656.25$
 $su2 = 0.032$

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00

$lo/lou,min = lb/lb,min = 1.00$

$su2 = 0.4 * esu2_nominal ((5.5), TBDY) = 0.032$

From table 5A.1, TBDY: $esu2_nominal = 0.08$,

For calculation of $esu2_nominal$ and $y2, sh2, ft2, fy2$, it is considered
characteristic value $fsy2 = fs2/1.2$, from table 5.1, TBDY.

$y1, sh1, ft1, fy1$, are also multiplied by $\text{Min}(1, 1.25 * (lb/ld)^{2/3})$, from 10.3.5, ASCE 41-17.

with $fs2 = fs = 656.25$

with $Es2 = Es = 200000.00$

$yv = 0.0025$
 $shv = 0.008$
 $ftv = 787.50$
 $fyv = 656.25$
 $suv = 0.032$

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00

$lo/lou,min = lb/ld = 1.00$

$suv = 0.4 * esuv_nominal ((5.5), TBDY) = 0.032$

From table 5A.1, TBDY: $esuv_nominal = 0.08$,

considering characteristic value $fsyv = fsv/1.2$, from table 5.1, TBDY
For calculation of $esuv_nominal$ and yv, shv, ftv, fyv , it is considered
characteristic value $fsyv = fsv/1.2$, from table 5.1, TBDY.

$y1, sh1, ft1, fy1$, are also multiplied by $\text{Min}(1, 1.25 * (lb/ld)^{2/3})$, from 10.3.5, ASCE 41-17.

with $fsv = fs = 656.25$

with $Esv = Es = 200000.00$

$1 = Asl,ten / (b * d) * (fs1 / fc) = 0.15676884$

$2 = Asl,com / (b * d) * (fs2 / fc) = 0.15356947$

$v = Asl,mid / (b * d) * (fsv / fc) = 0.07838442$

and confined core properties:

$b = 240.00$

$d = 328.00$

$d' = 13.00$

$fcc (5A.2, TBDY) = 26.16063$

$cc (5A.5, TBDY) = 0.00290026$

$c = \text{confinement factor} = 1.09003$

$1 = Asl,ten / (b * d) * (fs1 / fc) = 0.21388431$

$2 = Asl,com / (b * d) * (fs2 / fc) = 0.20951933$

$v = Asl,mid / (b * d) * (fsv / fc) = 0.10694216$

Case/Assumption: Unconfined full section - Steel rupture

' satisfies Eq. (4.3)

--->

$v < v_{s,y2}$ - LHS eq.(4.5) is satisfied

--->

$$s_u(4.9) = 0.16631328$$

$$\mu_u = M_{Rc}(4.14) = 1.8802E+008$$

$$u = s_u(4.1) = 0.00010722$$

Calculation of ratio l_b/d

Adequate Lap Length: $l_b/d \geq 1$

Calculation of μ_{u2+}

Calculation of ultimate curvature μ_u according to 4.1, Biskinis/Fardis 2013:

$$u = 0.00010701$$

$$\mu_u = 1.8498E+008$$

with full section properties:

$$b = 300.00$$

$$d = 358.00$$

$$d' = 43.00$$

$$v = 8.1892042E-005$$

$$N = 211.0849$$

$$f_c = 24.00$$

$$c_o(5A.5, TBDY) = 0.002$$

$$\text{Final value of } c_u: c_u^* = \text{shear_factor} * \text{Max}(c_u, c_c) = 0.00773686$$

The Shear_factor is considered equal to 1 (pure moment strength)

$$\text{From (5.4b), TBDY: } c_u = 0.00773686$$

$$w_e(5.4c) = 0.01121936$$

$$a_{se}((5.4d), TBDY) = 0.15672608$$

$$b_o = 240.00$$

$$h_o = 340.00$$

$$b_{i2} = 346400.00$$

$$p_{sh,min} = \text{Min}(p_{sh,x}, p_{sh,y}) = 0.00261799$$

 $p_{sh,x}(5.4d) = 0.00349066$

$$A_{sh} = A_{stir} * n_s = 78.53982$$

No stirrups, $n_s = 2.00$

$$b_k = 300.00$$

 $p_{sh,y}(5.4d) = 0.00261799$

$$A_{sh} = A_{stir} * n_s = 78.53982$$

No stirrups, $n_s = 2.00$

$$b_k = 400.00$$

 $s = 150.00$

$$f_{ywe} = 656.25$$

$$f_{ce} = 24.00$$

$$\text{From ((5.A5), TBDY), TBDY: } c_c = 0.00290026$$

$$c = \text{confinement factor} = 1.09003$$

$$y_1 = 0.0025$$

$$sh_1 = 0.008$$

$$ft_1 = 787.50$$

$$fy_1 = 656.25$$

$$s_{u1} = 0.032$$

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00

$$l_o/l_{o,min} = l_b/d = 1.00$$

$$s_{u1} = 0.4 * s_{u1_nominal}((5.5), TBDY) = 0.032$$

From table 5A.1, TBDY: $s_{u1_nominal} = 0.08$,

For calculation of $s_{u1_nominal}$ and y_1, sh_1, ft_1, fy_1 , it is considered
characteristic value $f_{sy1} = f_{s1}/1.2$, from table 5.1, TBDY.

y_1, sh_1, ft_1, fy_1 , are also multiplied by $\text{Min}(1, 1.25 \cdot (lb/ld)^{2/3})$, from 10.3.5, ASCE 41-17.

with $fs_1 = fs = 656.25$

with $Es_1 = Es = 200000.00$

$y_2 = 0.0025$

$sh_2 = 0.008$

$ft_2 = 787.50$

$fy_2 = 656.25$

$su_2 = 0.032$

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor

and also multiplied by the shear_factor according to 15.7.1.4, with

Shear_factor = 1.00

$lo/lo_{u,min} = lb/lb_{u,min} = 1.00$

$su_2 = 0.4 \cdot esu_{2,nominal} ((5.5), TBDY) = 0.032$

From table 5A.1, TBDY: $esu_{2,nominal} = 0.08$,

For calculation of $esu_{2,nominal}$ and y_2, sh_2, ft_2, fy_2 , it is considered characteristic value $fsy_2 = fs_2/1.2$, from table 5.1, TBDY.

y_1, sh_1, ft_1, fy_1 , are also multiplied by $\text{Min}(1, 1.25 \cdot (lb/ld)^{2/3})$, from 10.3.5, ASCE 41-17.

with $fs_2 = fs = 656.25$

with $Es_2 = Es = 200000.00$

$y_v = 0.0025$

$sh_v = 0.008$

$ft_v = 787.50$

$fy_v = 656.25$

$su_v = 0.032$

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor

and also multiplied by the shear_factor according to 15.7.1.4, with

Shear_factor = 1.00

$lo/lo_{u,min} = lb/ld = 1.00$

$su_v = 0.4 \cdot esuv_{nominal} ((5.5), TBDY) = 0.032$

From table 5A.1, TBDY: $esuv_{nominal} = 0.08$,

considering characteristic value $fsyv = fsv/1.2$, from table 5.1, TBDY

For calculation of $esuv_{nominal}$ and y_v, sh_v, ft_v, fy_v , it is considered characteristic value $fsyv = fsv/1.2$, from table 5.1, TBDY.

y_1, sh_1, ft_1, fy_1 , are also multiplied by $\text{Min}(1, 1.25 \cdot (lb/ld)^{2/3})$, from 10.3.5, ASCE 41-17.

with $fsv = fs = 656.25$

with $Esv = Es = 200000.00$

$1 = Asl_{ten}/(b \cdot d) \cdot (fs_1/fc) = 0.15356947$

$2 = Asl_{com}/(b \cdot d) \cdot (fs_2/fc) = 0.15676884$

$v = Asl_{mid}/(b \cdot d) \cdot (fsv/fc) = 0.07838442$

and confined core properties:

$b = 240.00$

$d = 328.00$

$d' = 13.00$

$f_{cc} (5A.2, TBDY) = 26.16063$

$cc (5A.5, TBDY) = 0.00290026$

$c = \text{confinement factor} = 1.09003$

$1 = Asl_{ten}/(b \cdot d) \cdot (fs_1/fc) = 0.20951933$

$2 = Asl_{com}/(b \cdot d) \cdot (fs_2/fc) = 0.21388431$

$v = Asl_{mid}/(b \cdot d) \cdot (fsv/fc) = 0.10694216$

Case/Assumption: Unconfined full section - Steel rupture

' satisfies Eq. (4.3)

--->

$v < v_{s,y_2}$ - LHS eq.(4.5) is satisfied

--->

$su (4.9) = 0.16466458$

$Mu = MRc (4.14) = 1.8498E+008$

$u = su (4.1) = 0.00010701$

Calculation of ratio lb/ld

Adequate Lap Length: $lb/ld \geq 1$

Calculation of Mu_2 -

Calculation of ultimate curvature ϕ_u according to 4.1, Biskinis/Fardis 2013:

$$u = 0.00010732$$
$$\mu = 1.8800E+008$$

with full section properties:

$$b = 300.00$$
$$d = 357.00$$
$$d' = 42.00$$
$$v = 8.2121432E-005$$
$$N = 211.0849$$

$$f_c = 24.00$$
$$c_o(5A.5, \text{TBDY}) = 0.002$$

Final value of ϕ_u : $\phi_u^* = \text{shear_factor} * \text{Max}(\phi_u, \phi_c) = 0.00773686$
The Shear_factor is considered equal to 1 (pure moment strength)

From (5.4b), TBDY: $\phi_u = 0.00773686$

$$w_e(5.4c) = 0.01121936$$

$$a_{se}((5.4d), \text{TBDY}) = 0.15672608$$

$$b_o = 240.00$$

$$h_o = 340.00$$

$$b_{i2} = 346400.00$$

$$\phi_{sh,min} = \text{Min}(\phi_{sh,x}, \phi_{sh,y}) = 0.00261799$$

$$\phi_{sh,x}(5.4d) = 0.00349066$$

$$A_{sh} = A_{stir} * n_s = 78.53982$$

$$\text{No stirups, } n_s = 2.00$$

$$b_k = 300.00$$

$$\phi_{sh,y}(5.4d) = 0.00261799$$

$$A_{sh} = A_{stir} * n_s = 78.53982$$

$$\text{No stirups, } n_s = 2.00$$

$$b_k = 400.00$$

$$s = 150.00$$

$$f_{ywe} = 656.25$$

$$f_{ce} = 24.00$$

From ((5.A5), TBDY), TBDY: $\phi_c = 0.00290026$

$$c = \text{confinement factor} = 1.09003$$

$$y_1 = 0.0025$$

$$sh_1 = 0.008$$

$$ft_1 = 787.50$$

$$fy_1 = 656.25$$

$$su_1 = 0.032$$

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00

$$l_o/l_{o,min} = l_b/l_d = 1.00$$

$$su_1 = 0.4 * esu_{1,nominal}((5.5), \text{TBDY}) = 0.032$$

From table 5A.1, TBDY: $esu_{1,nominal} = 0.08$,

For calculation of $esu_{1,nominal}$ and y_1, sh_1, ft_1, fy_1 , it is considered
characteristic value $fs_1 = fs_1/1.2$, from table 5.1, TBDY.

y_1, sh_1, ft_1, fy_1 , are also multiplied by $\text{Min}(1, 1.25 * (l_b/l_d)^{2/3})$, from 10.3.5, ASCE 41-17.

$$\text{with } fs_1 = fs = 656.25$$

$$\text{with } E_{s1} = E_s = 200000.00$$

$$y_2 = 0.0025$$

$$sh_2 = 0.008$$

$$ft_2 = 787.50$$

$$fy_2 = 656.25$$

$$su_2 = 0.032$$

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00

$$l_o/l_{o,min} = l_b/l_{b,min} = 1.00$$

$$su_2 = 0.4 * esu_{2,nominal}((5.5), \text{TBDY}) = 0.032$$

From table 5A.1, TBDY: $esu_{2,nominal} = 0.08$,

For calculation of $esu_{2,nominal}$ and y_2, sh_2, ft_2, fy_2 , it is considered

characteristic value $f_{s2} = f_s/1.2$, from table 5.1, TBDY.

y_1, sh_1, ft_1, f_{y1} , are also multiplied by $\text{Min}(1, 1.25 \cdot (l_b/d)^{2/3})$, from 10.3.5, ASCE 41-17.

with $f_{s2} = f_s = 656.25$

with $E_{s2} = E_s = 200000.00$

$y_v = 0.0025$

$sh_v = 0.008$

$ft_v = 787.50$

$f_{yv} = 656.25$

$s_{uv} = 0.032$

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00

$l_o/l_{o,min} = l_b/d = 1.00$

$s_{uv} = 0.4 \cdot e_{suv,nominal} ((5.5), TBDY) = 0.032$

From table 5A.1, TBDY: $e_{suv,nominal} = 0.08$,

considering characteristic value $f_{sv} = f_{sv}/1.2$, from table 5.1, TBDY

For calculation of $e_{suv,nominal}$ and y_v, sh_v, ft_v, f_{yv} , it is considered
characteristic value $f_{sv} = f_{sv}/1.2$, from table 5.1, TBDY.

y_1, sh_1, ft_1, f_{y1} , are also multiplied by $\text{Min}(1, 1.25 \cdot (l_b/d)^{2/3})$, from 10.3.5, ASCE 41-17.

with $f_{sv} = f_s = 656.25$

with $E_{sv} = E_s = 200000.00$

1 = $A_{s1,ten}/(b \cdot d) \cdot (f_{s1}/f_c) = 0.15720797$

2 = $A_{s2,com}/(b \cdot d) \cdot (f_{s2}/f_c) = 0.15399964$

v = $A_{s,mid}/(b \cdot d) \cdot (f_{sv}/f_c) = 0.07860398$

and confined core properties:

$b = 240.00$

$d = 327.00$

$d' = 12.00$

$f_{cc} (5A.2, TBDY) = 26.16063$

$cc (5A.5, TBDY) = 0.00290026$

c = confinement factor = 1.09003

1 = $A_{s1,ten}/(b \cdot d) \cdot (f_{s1}/f_c) = 0.21453839$

2 = $A_{s2,com}/(b \cdot d) \cdot (f_{s2}/f_c) = 0.21016006$

v = $A_{s,mid}/(b \cdot d) \cdot (f_{sv}/f_c) = 0.1072692$

Case/Assumption: Unconfined full section - Steel rupture

' satisfies Eq. (4.3)

--->

$v < v_{s,y2}$ - LHS eq.(4.5) is satisfied

--->

$\mu_u (4.9) = 0.16474284$

$\mu_u = M_{Rc} (4.14) = 1.8800E+008$

$u = \mu_u (4.1) = 0.00010732$

Calculation of ratio l_b/d

Adequate Lap Length: $l_b/d \geq 1$

Calculation of Shear Strength $V_r = \text{Min}(V_{r1}, V_{r2}) = 261431.672$

Calculation of Shear Strength at edge 1, $V_{r1} = 261431.672$

$V_{r1} = V_n ((22.5.1.1), ACI 318-14)$

NOTE: In expression (22.5.1.1) ' V_w ' is replaced by ' $V_w + f \cdot V_f$ '
where V_f is the contribution of FRPs (11.3), ACI 440).

From Table (22.5.5.1), ACI 318-14: $V_c = 85502.483$

= 1 (normal-weight concrete)

$f_c' = 24.00$, but $f_c'^{0.5} \leq 8.3$ MPa (22.5.3.1, ACI 318-14)

$p_w = A_s/(b_w \cdot d) = 0.00628319$

A_s (tension reinf.) = 603.1858

$b_w = 300.00$

$d = 320.00$

$V_u \cdot d / \mu_u < 1 = 1.00$

Mu = 30114.962

Vu = 2740.265

From (11.5.4.8), ACI 318-14: Vs = 175929.189

Av = 157079.633

fy = 525.00

s = 150.00

Vs has been multiplied by 1 ($s < d/2$, according to ASCE 41-17,10.3.4)

Vf ((11-3)-(11.4), ACI 440) = 0.00

From (11-11), ACI 440: Vs + Vf <= 312423.44

Calculation of Shear Strength at edge 2, Vr2 = 261431.672

Vr2 = Vn ((22.5.1.1), ACI 318-14)

NOTE: In expression (22.5.1.1) 'Vw' is replaced by 'Vw+ f*Vf' where Vf is the contribution of FRPs (11.3), ACI 440).

From Table (22.5.5.1), ACI 318-14: Vc = 85502.483

= 1 (normal-weight concrete)

fc' = 24.00, but $fc'^{0.5} <= 8.3$ MPa (22.5.3.1, ACI 318-14)

pw = As/(bw*d) = 0.00628319

As (tension reinf.) = 603.1858

bw = 300.00

d = 320.00

Vu*d/Mu < 1 = 1.00

Mu = 30115.665

Vu = 2740.264

From (11.5.4.8), ACI 318-14: Vs = 175929.189

Av = 157079.633

fy = 525.00

s = 150.00

Vs has been multiplied by 1 ($s < d/2$, according to ASCE 41-17,10.3.4)

Vf ((11-3)-(11.4), ACI 440) = 0.00

From (11-11), ACI 440: Vs + Vf <= 312423.44

End Of Calculation of Shear Capacity ratio for element: beam B1 of floor 1
At local axis: 3

Start Of Calculation of Shear Capacity ratio for element: beam B1 of floor 1
At Shear local axis: 2
(Bending local axis: 3)
Section Type: rcars

Constant Properties

Knowledge Factor, = 1.00

Mean strength values are used for both shear and moment calculations.

Consequently:

Existing material of Primary Member: Concrete Strength, fc = fcm = 24.00

Existing material of Primary Member: Steel Strength, fs = fsm = 525.00

Concrete Elasticity, Ec = 23025.204

Steel Elasticity, Es = 200000.00

#####

Note: Especially for the calculation of moment strengths, the above steel re-bar strengths are multiplied by 1.25 according to R18.6.5, ACI 318-14

Existing material: Steel Strength, fs = 1.25*fsm = 656.25

#####

Section Height, H = 400.00

Section Width, W = 300.00

Cover Thickness, c = 25.00

Mean Confinement Factor overall section = 1.09003

Element Length, L = 1850.00

Primary Member

Smooth Bars

Ductile Steel

With Detailing for Earthquake Resistance (including stirrups closed at 135°)
Longitudinal Bars With Ends Lapped Starting at the End Sections
Adequate Lap Length ($l_o/l_{ou, \min} >= 1$)
No FRP Wrapping

Stepwise Properties

At local axis: 2
EDGE -A-
Shear Force, $V_a = -3.6870970E-015$
EDGE -B-
Shear Force, $V_b = 3.6870970E-015$
BOTH EDGES
Axial Force, $F = -211.0849$
Longitudinal Reinforcement Area Distribution (in 2 divisions)
-Tension: $A_{st} = 603.1858$
-Compression: $A_{sc} = 923.6282$
Longitudinal Reinforcement Area Distribution (in 3 divisions)
-Tension: $A_{st, \text{ten}} = 508.938$
-Compression: $A_{sc, \text{com}} = 508.938$
-Middle: $A_{sc, \text{mid}} = 508.938$

Calculation of Shear Capacity ratio , $V_e/V_r = 0.79211753$
Member Controlled by Flexure ($V_e/V_r < 1$)
Calculation of Shear Demand from fig. R18.6.5, ACI 318-14 $V_e = (M_{pr1} + M_{pr2})/l_n \pm w_u \cdot l_n / 2 = 137993.601$
with
 $M_{pr1} = \text{Max}(\mu_{u1+}, \mu_{u1-}) = 1.2764E+008$
 $\mu_{u1+} = 1.2764E+008$, is the ultimate moment strength at the edge 1 of the member in the actual moment direction
which is defined for the static loading combination
 $\mu_{u1-} = 1.2764E+008$, is the ultimate moment strength at the edge 1 of the member in the opposite moment
direction which is defined for the static loading combination
 $M_{pr2} = \text{Max}(\mu_{u2+}, \mu_{u2-}) = 1.2764E+008$
 $\mu_{u2+} = 1.2764E+008$, is the ultimate moment strength at the edge 2 of the member in the actual moment direction
which is defined for the the static loading combination
 $\mu_{u2-} = 1.2764E+008$, is the ultimate moment strength at the edge 2 of the member in the opposite moment
direction which is defined for the the static loading combination
and
 $\pm w_u \cdot l_n = (|V_1| + |V_2|)/2$
with
 $V_1 = -3.6870970E-015$, is the shear force acting at edge 1 for the the static loading combination
 $V_2 = 3.6870970E-015$, is the shear force acting at edge 2 for the the static loading combination

Calculation of μ_{u1+}

Calculation of ultimate curvature ϕ_u according to 4.1, Biskinis/Fardis 2013:
 $\phi_u = 0.00015613$
 $\mu_u = 1.2764E+008$

with full section properties:

$b = 400.00$
 $d = 258.00$
 $d' = 42.00$
 $v = 8.5224858E-005$
 $N = 211.0849$
 $f_c = 24.00$
 $\phi_{co} \text{ (5A.5, TBDY)} = 0.002$
Final value of ϕ_{cu} : $\phi_{cu}^* = \text{shear_factor} * \text{Max}(\phi_{cu}, \phi_{cc}) = 0.00773686$
The Shear_factor is considered equal to 1 (pure moment strength)
From (5.4b), TBDY: $\phi_{cu} = 0.00773686$
 $\phi_{we} \text{ (5.4c)} = 0.01121936$

ase ((5.4d), TBDY) = 0.15672608
bo = 240.00
ho = 340.00
bi2 = 346400.00
psh,min = Min(psh,x , psh,y) = 0.00261799

psh,x (5.4d) = 0.00349066
Ash = Astir*ns = 78.53982
No stirups, ns = 2.00
bk = 300.00

psh,y (5.4d) = 0.00261799
Ash = Astir*ns = 78.53982
No stirups, ns = 2.00
bk = 400.00

s = 150.00
fywe = 656.25
fce = 24.00

From ((5.A5), TBDY), TBDY: cc = 0.00290026
c = confinement factor = 1.09003

y1 = 0.0025
sh1 = 0.008
ft1 = 787.50
fy1 = 656.25
su1 = 0.032

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00

lo/lou,min = lb/lb = 1.00

su1 = 0.4*esu1_nominal ((5.5), TBDY) = 0.032

From table 5A.1, TBDY: esu1_nominal = 0.08,

For calculation of esu1_nominal and y1, sh1,ft1,fy1, it is considered
characteristic value fsy1 = fs1/1.2, from table 5.1, TBDY.

y1, sh1,ft1,fy1, are also multiplied by Min(1,1.25*(lb/lb)^ 2/3), from 10.3.5, ASCE 41-17.

with fs1 = fs = 656.25

with Es1 = Es = 200000.00

y2 = 0.0025
sh2 = 0.008
ft2 = 787.50
fy2 = 656.25
su2 = 0.032

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00

lo/lou,min = lb/lb,min = 1.00

su2 = 0.4*esu2_nominal ((5.5), TBDY) = 0.032

From table 5A.1, TBDY: esu2_nominal = 0.08,

For calculation of esu2_nominal and y2, sh2,ft2,fy2, it is considered
characteristic value fsy2 = fs2/1.2, from table 5.1, TBDY.

y1, sh1,ft1,fy1, are also multiplied by Min(1,1.25*(lb/lb)^ 2/3), from 10.3.5, ASCE 41-17.

with fs2 = fs = 656.25

with Es2 = Es = 200000.00

yv = 0.0025
shv = 0.008
ftv = 787.50
fyv = 656.25
suv = 0.032

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00

lo/lou,min = lb/lb = 1.00

suv = 0.4*esuv_nominal ((5.5), TBDY) = 0.032

From table 5A.1, TBDY: esuv_nominal = 0.08,

considering characteristic value fsyv = fsv/1.2, from table 5.1, TBDY

For calculation of esuv_nominal and yv, shv,ftv,fyv, it is considered
characteristic value fsyv = fsv/1.2, from table 5.1, TBDY.

y_1, sh_1, ft_1, fy_1 , are also multiplied by $\text{Min}(1, 1.25 \cdot (lb/d)^{2/3})$, from 10.3.5, ASCE 41-17.

with $f_{sv} = f_s = 656.25$

with $E_{sv} = E_s = 200000.00$

$1 = A_{sl,ten}/(b \cdot d) \cdot (f_{s1}/f_c) = 0.13484761$

$2 = A_{sl,com}/(b \cdot d) \cdot (f_{s2}/f_c) = 0.13484761$

$v = A_{sl,mid}/(b \cdot d) \cdot (f_{sv}/f_c) = 0.13484761$

and confined core properties:

$b = 340.00$

$d = 228.00$

$d' = 12.00$

$f_{cc} \text{ (5A.2, TBDY)} = 26.16063$

$cc \text{ (5A.5, TBDY)} = 0.00290026$

$c = \text{confinement factor} = 1.09003$

$1 = A_{sl,ten}/(b \cdot d) \cdot (f_{s1}/f_c) = 0.17951849$

$2 = A_{sl,com}/(b \cdot d) \cdot (f_{s2}/f_c) = 0.17951849$

$v = A_{sl,mid}/(b \cdot d) \cdot (f_{sv}/f_c) = 0.17951849$

Case/Assumption: Unconfined full section - Steel rupture

' does not satisfy Eq. (4.3)

--->

$v < v_{s,c}$ - RHS eq.(4.5) is satisfied

--->

$su \text{ (4.9)} = 0.20560388$

$Mu = MRc \text{ (4.14)} = 1.2764E+008$

$u = su \text{ (4.1)} = 0.00015613$

Calculation of ratio lb/d

Adequate Lap Length: $lb/d \geq 1$

Calculation of Mu_1 -

Calculation of ultimate curvature u according to 4.1, Biskinis/Fardis 2013:

$u = 0.00015613$

$Mu = 1.2764E+008$

with full section properties:

$b = 400.00$

$d = 258.00$

$d' = 42.00$

$v = 8.5224858E-005$

$N = 211.0849$

$f_c = 24.00$

$co \text{ (5A.5, TBDY)} = 0.002$

Final value of cu : $cu^* = \text{shear_factor} \cdot \text{Max}(cu, cc) = 0.00773686$

The Shear_factor is considered equal to 1 (pure moment strength)

From (5.4b), TBDY: $cu = 0.00773686$

$w_e \text{ (5.4c)} = 0.01121936$

$ase \text{ ((5.4d), TBDY)} = 0.15672608$

$bo = 240.00$

$ho = 340.00$

$bi_2 = 346400.00$

$psh_{,min} = \text{Min}(psh_x, psh_y) = 0.00261799$

 $psh_x \text{ (5.4d)} = 0.00349066$

$A_{sh} = A_{stir} \cdot n_s = 78.53982$

No stirups, $n_s = 2.00$

$bk = 300.00$

 $psh_y \text{ (5.4d)} = 0.00261799$

$A_{sh} = A_{stir} \cdot n_s = 78.53982$

No stirups, $n_s = 2.00$

$bk = 400.00$

$$s = 150.00$$

$$fywe = 656.25$$

$$fce = 24.00$$

From ((5.A5), TBDY), TBDY: $cc = 0.00290026$

$$c = \text{confinement factor} = 1.09003$$

$$y1 = 0.0025$$

$$sh1 = 0.008$$

$$ft1 = 787.50$$

$$fy1 = 656.25$$

$$su1 = 0.032$$

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00

$$lo/lou,min = lb/d = 1.00$$

$$su1 = 0.4 * esu1_nominal ((5.5), TBDY) = 0.032$$

From table 5A.1, TBDY: $esu1_nominal = 0.08$,

For calculation of $esu1_nominal$ and $y1, sh1, ft1, fy1$, it is considered
characteristic value $fsy1 = fs1/1.2$, from table 5.1, TBDY.

$y1, sh1, ft1, fy1$, are also multiplied by $\text{Min}(1, 1.25 * (lb/d)^{2/3})$, from 10.3.5, ASCE 41-17.

$$\text{with } fs1 = fs = 656.25$$

$$\text{with } Es1 = Es = 200000.00$$

$$y2 = 0.0025$$

$$sh2 = 0.008$$

$$ft2 = 787.50$$

$$fy2 = 656.25$$

$$su2 = 0.032$$

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00

$$lo/lou,min = lb/lb,min = 1.00$$

$$su2 = 0.4 * esu2_nominal ((5.5), TBDY) = 0.032$$

From table 5A.1, TBDY: $esu2_nominal = 0.08$,

For calculation of $esu2_nominal$ and $y2, sh2, ft2, fy2$, it is considered
characteristic value $fsy2 = fs2/1.2$, from table 5.1, TBDY.

$y1, sh1, ft1, fy1$, are also multiplied by $\text{Min}(1, 1.25 * (lb/d)^{2/3})$, from 10.3.5, ASCE 41-17.

$$\text{with } fs2 = fs = 656.25$$

$$\text{with } Es2 = Es = 200000.00$$

$$yv = 0.0025$$

$$shv = 0.008$$

$$ftv = 787.50$$

$$fyv = 656.25$$

$$suv = 0.032$$

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00

$$lo/lou,min = lb/d = 1.00$$

$$suv = 0.4 * esuv_nominal ((5.5), TBDY) = 0.032$$

From table 5A.1, TBDY: $esuv_nominal = 0.08$,

considering characteristic value $fsyv = fsv/1.2$, from table 5.1, TBDY
For calculation of $esuv_nominal$ and yv, shv, ftv, fyv , it is considered

characteristic value $fsyv = fsv/1.2$, from table 5.1, TBDY.

$y1, sh1, ft1, fy1$, are also multiplied by $\text{Min}(1, 1.25 * (lb/d)^{2/3})$, from 10.3.5, ASCE 41-17.

$$\text{with } fsv = fs = 656.25$$

$$\text{with } Esv = Es = 200000.00$$

$$1 = Asl,ten/(b*d)*(fs1/fc) = 0.13484761$$

$$2 = Asl,com/(b*d)*(fs2/fc) = 0.13484761$$

$$v = Asl,mid/(b*d)*(fsv/fc) = 0.13484761$$

and confined core properties:

$$b = 340.00$$

$$d = 228.00$$

$$d' = 12.00$$

$$fcc (5A.2, TBDY) = 26.16063$$

$$cc (5A.5, TBDY) = 0.00290026$$

$$c = \text{confinement factor} = 1.09003$$

$$1 = Asl,ten/(b*d)*(fs1/fc) = 0.17951849$$

$$2 = Asl,com/(b*d)*(fs2/fc) = 0.17951849$$

$$v = A_{sl, mid} / (b \cdot d) \cdot (f_{sv} / f_c) = 0.17951849$$

Case/Assumption: Unconfined full section - Steel rupture
' does not satisfy Eq. (4.3)

--->

$v < v_{s,c}$ - RHS eq.(4.5) is satisfied

--->

$$s_u(4.9) = 0.20560388$$

$$\mu = M_{Rc}(4.14) = 1.2764E+008$$

$$u = s_u(4.1) = 0.00015613$$

Calculation of ratio l_b/l_d

Adequate Lap Length: $l_b/l_d \geq 1$

Calculation of μ_{2+}

Calculation of ultimate curvature u according to 4.1, Biskinis/Fardis 2013:

$$u = 0.00015613$$

$$\mu = 1.2764E+008$$

with full section properties:

$$b = 400.00$$

$$d = 258.00$$

$$d' = 42.00$$

$$v = 8.5224858E-005$$

$$N = 211.0849$$

$$f_c = 24.00$$

$$c_o(5A.5, TBDY) = 0.002$$

$$\text{Final value of } c_u: c_u^* = \text{shear_factor} \cdot \text{Max}(c_u, c_c) = 0.00773686$$

The Shear_factor is considered equal to 1 (pure moment strength)

$$\text{From (5.4b), TBDY: } c_u = 0.00773686$$

$$w_e(5.4c) = 0.01121936$$

$$a_{se}((5.4d), TBDY) = 0.15672608$$

$$b_o = 240.00$$

$$h_o = 340.00$$

$$b_{i2} = 346400.00$$

$$p_{sh, min} = \text{Min}(p_{sh, x}, p_{sh, y}) = 0.00261799$$

$$p_{sh, x}(5.4d) = 0.00349066$$

$$A_{sh} = A_{stir} \cdot n_s = 78.53982$$

$$\text{No stirups, } n_s = 2.00$$

$$b_k = 300.00$$

$$p_{sh, y}(5.4d) = 0.00261799$$

$$A_{sh} = A_{stir} \cdot n_s = 78.53982$$

$$\text{No stirups, } n_s = 2.00$$

$$b_k = 400.00$$

$$s = 150.00$$

$$f_{ywe} = 656.25$$

$$f_{ce} = 24.00$$

$$\text{From ((5.A5), TBDY), TBDY: } c_c = 0.00290026$$

$$c = \text{confinement factor} = 1.09003$$

$$y_1 = 0.0025$$

$$sh_1 = 0.008$$

$$f_{t1} = 787.50$$

$$f_{y1} = 656.25$$

$$s_{u1} = 0.032$$

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00

$$l_o/l_{ou, min} = l_b/l_d = 1.00$$

$$su1 = 0.4 * esu1_nominal ((5.5, TBDY) = 0.032$$

From table 5A.1, TBDY: $esu1_nominal = 0.08$,

For calculation of $esu1_nominal$ and $y1, sh1, ft1, fy1$, it is considered characteristic value $fsy1 = fs1/1.2$, from table 5.1, TBDY.

$y1, sh1, ft1, fy1$, are also multiplied by $\text{Min}(1, 1.25 * (lb/ld)^{2/3})$, from 10.3.5, ASCE 41-17.

with $fs1 = fs = 656.25$

with $Es1 = Es = 200000.00$

$$y2 = 0.0025$$

$$sh2 = 0.008$$

$$ft2 = 787.50$$

$$fy2 = 656.25$$

$$su2 = 0.032$$

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor and also multiplied by the shear_factor according to 15.7.1.4, with Shear_factor = 1.00

$lo/lou, min = lb/lb, min = 1.00$

$$su2 = 0.4 * esu2_nominal ((5.5, TBDY) = 0.032$$

From table 5A.1, TBDY: $esu2_nominal = 0.08$,

For calculation of $esu2_nominal$ and $y2, sh2, ft2, fy2$, it is considered characteristic value $fsy2 = fs2/1.2$, from table 5.1, TBDY.

$y1, sh1, ft1, fy1$, are also multiplied by $\text{Min}(1, 1.25 * (lb/ld)^{2/3})$, from 10.3.5, ASCE 41-17.

with $fs2 = fs = 656.25$

with $Es2 = Es = 200000.00$

$$yv = 0.0025$$

$$shv = 0.008$$

$$ftv = 787.50$$

$$fyv = 656.25$$

$$suv = 0.032$$

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor and also multiplied by the shear_factor according to 15.7.1.4, with Shear_factor = 1.00

$lo/lou, min = lb/ld = 1.00$

$$suv = 0.4 * esuv_nominal ((5.5, TBDY) = 0.032$$

From table 5A.1, TBDY: $esuv_nominal = 0.08$,

considering characteristic value $fsyv = fsv/1.2$, from table 5.1, TBDY

For calculation of $esuv_nominal$ and yv, shv, ftv, fyv , it is considered characteristic value $fsyv = fsv/1.2$, from table 5.1, TBDY.

$y1, sh1, ft1, fy1$, are also multiplied by $\text{Min}(1, 1.25 * (lb/ld)^{2/3})$, from 10.3.5, ASCE 41-17.

with $fsv = fs = 656.25$

with $Esv = Es = 200000.00$

$$1 = Asl, ten / (b * d) * (fs1 / fc) = 0.13484761$$

$$2 = Asl, com / (b * d) * (fs2 / fc) = 0.13484761$$

$$v = Asl, mid / (b * d) * (fsv / fc) = 0.13484761$$

and confined core properties:

$$b = 340.00$$

$$d = 228.00$$

$$d' = 12.00$$

$$fcc (5A.2, TBDY) = 26.16063$$

$$cc (5A.5, TBDY) = 0.00290026$$

$c =$ confinement factor = 1.09003

$$1 = Asl, ten / (b * d) * (fs1 / fc) = 0.17951849$$

$$2 = Asl, com / (b * d) * (fs2 / fc) = 0.17951849$$

$$v = Asl, mid / (b * d) * (fsv / fc) = 0.17951849$$

Case/Assumption: Unconfined full section - Steel rupture

' does not satisfy Eq. (4.3)

$v < vs, c$ - RHS eq.(4.5) is satisfied

$$su (4.9) = 0.20560388$$

$$Mu = MRc (4.14) = 1.2764E+008$$

$$u = su (4.1) = 0.00015613$$

Calculation of ratio lb/ld

Adequate Lap Length: $lb/ld \geq 1$

Calculation of Mu2-

Calculation of ultimate curvature μ according to 4.1, Biskinis/Fardis 2013:

$$\mu = 0.00015613$$

$$Mu = 1.2764E+008$$

with full section properties:

$$b = 400.00$$

$$d = 258.00$$

$$d' = 42.00$$

$$v = 8.5224858E-005$$

$$N = 211.0849$$

$$f_c = 24.00$$

$$c_o (5A.5, TBDY) = 0.002$$

$$\text{Final value of } c_u: c_u^* = \text{shear_factor} * \text{Max}(c_u, c_c) = 0.00773686$$

The Shear_factor is considered equal to 1 (pure moment strength)

$$\text{From (5.4b), TBDY: } c_u = 0.00773686$$

$$w_e (5.4c) = 0.01121936$$

$$a_{se} ((5.4d), TBDY) = 0.15672608$$

$$b_o = 240.00$$

$$h_o = 340.00$$

$$b_{i2} = 346400.00$$

$$p_{sh,min} = \text{Min}(p_{sh,x}, p_{sh,y}) = 0.00261799$$

$$p_{sh,x} (5.4d) = 0.00349066$$

$$A_{sh} = A_{stir} * n_s = 78.53982$$

$$\text{No stirups, } n_s = 2.00$$

$$b_k = 300.00$$

$$p_{sh,y} (5.4d) = 0.00261799$$

$$A_{sh} = A_{stir} * n_s = 78.53982$$

$$\text{No stirups, } n_s = 2.00$$

$$b_k = 400.00$$

$$s = 150.00$$

$$f_{ywe} = 656.25$$

$$f_{ce} = 24.00$$

$$\text{From ((5.A5), TBDY), TBDY: } c_c = 0.00290026$$

$$c = \text{confinement factor} = 1.09003$$

$$y_1 = 0.0025$$

$$sh_1 = 0.008$$

$$ft_1 = 787.50$$

$$fy_1 = 656.25$$

$$su_1 = 0.032$$

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor and also multiplied by the shear_factor according to 15.7.1.4, with Shear_factor = 1.00

$$l_o/l_{ou,min} = l_b/l_d = 1.00$$

$$su_1 = 0.4 * esu_{1,nominal} ((5.5), TBDY) = 0.032$$

$$\text{From table 5A.1, TBDY: } esu_{1,nominal} = 0.08,$$

For calculation of $esu_{1,nominal}$ and y_1, sh_1, ft_1, fy_1 , it is considered characteristic value $fsy_1 = fs_1/1.2$, from table 5.1, TBDY.

y_1, sh_1, ft_1, fy_1 , are also multiplied by $\text{Min}(1, 1.25 * (l_b/l_d)^{2/3})$, from 10.3.5, ASCE 41-17.

$$\text{with } fs_1 = fs = 656.25$$

$$\text{with } Es_1 = Es = 200000.00$$

$$y_2 = 0.0025$$

$$sh_2 = 0.008$$

$$ft_2 = 787.50$$

$$fy_2 = 656.25$$

$$su_2 = 0.032$$

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor and also multiplied by the shear_factor according to 15.7.1.4, with Shear_factor = 1.00

$$l_o/l_{o,min} = l_b/l_{b,min} = 1.00$$

$$s_u2 = 0.4 * e_{su2_nominal} ((5.5), TBDY) = 0.032$$

From table 5A.1, TBDY: $e_{su2_nominal} = 0.08$,

For calculation of $e_{su2_nominal}$ and y_2, sh_2, ft_2, fy_2 , it is considered characteristic value $f_{sy2} = f_{s2}/1.2$, from table 5.1, TBDY.

y_1, sh_1, ft_1, fy_1 , are also multiplied by $\text{Min}(1, 1.25 * (l_b/l_d)^{2/3})$, from 10.3.5, ASCE 41-17.

$$\text{with } f_{s2} = f_s = 656.25$$

$$\text{with } E_{s2} = E_s = 200000.00$$

$$y_v = 0.0025$$

$$sh_v = 0.008$$

$$ft_v = 787.50$$

$$fy_v = 656.25$$

$$s_{uv} = 0.032$$

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor

and also multiplied by the shear_factor according to 15.7.1.4, with Shear_factor = 1.00

$$l_o/l_{o,min} = l_b/l_d = 1.00$$

$$s_{uv} = 0.4 * e_{suv_nominal} ((5.5), TBDY) = 0.032$$

From table 5A.1, TBDY: $e_{suv_nominal} = 0.08$,

considering characteristic value $f_{sv} = f_{sv}/1.2$, from table 5.1, TBDY

For calculation of $e_{suv_nominal}$ and y_v, sh_v, ft_v, fy_v , it is considered characteristic value $f_{sv} = f_{sv}/1.2$, from table 5.1, TBDY.

y_1, sh_1, ft_1, fy_1 , are also multiplied by $\text{Min}(1, 1.25 * (l_b/l_d)^{2/3})$, from 10.3.5, ASCE 41-17.

$$\text{with } f_{sv} = f_s = 656.25$$

$$\text{with } E_{sv} = E_s = 200000.00$$

$$1 = A_{sl,ten}/(b*d)*(f_{s1}/f_c) = 0.13484761$$

$$2 = A_{sl,com}/(b*d)*(f_{s2}/f_c) = 0.13484761$$

$$v = A_{sl,mid}/(b*d)*(f_{sv}/f_c) = 0.13484761$$

and confined core properties:

$$b = 340.00$$

$$d = 228.00$$

$$d' = 12.00$$

$$f_{cc} (5A.2, TBDY) = 26.16063$$

$$c_c (5A.5, TBDY) = 0.00290026$$

$$c = \text{confinement factor} = 1.09003$$

$$1 = A_{sl,ten}/(b*d)*(f_{s1}/f_c) = 0.17951849$$

$$2 = A_{sl,com}/(b*d)*(f_{s2}/f_c) = 0.17951849$$

$$v = A_{sl,mid}/(b*d)*(f_{sv}/f_c) = 0.17951849$$

Case/Assumption: Unconfined full section - Steel rupture

' does not satisfy Eq. (4.3)

---->

$v < v_{s,c}$ - RHS eq.(4.5) is satisfied

---->

$$s_u (4.9) = 0.20560388$$

$$M_u = M_{Rc} (4.14) = 1.2764E+008$$

$$u = s_u (4.1) = 0.00015613$$

Calculation of ratio l_b/l_d

Adequate Lap Length: $l_b/l_d \geq 1$

Calculation of Shear Strength $V_r = \text{Min}(V_{r1}, V_{r2}) = 174208.493$

Calculation of Shear Strength at edge 1, $V_{r1} = 174208.493$

$$V_{r1} = V_n ((22.5.1.1), ACI 318-14)$$

NOTE: In expression (22.5.1.1) 'V_w' is replaced by 'V_w + f*V_f'
where V_f is the contribution of FRPs (11.3), ACI 440).

$$\text{From Table (22.5.5.1), ACI 318-14: } V_c = 75248.325$$

= 1 (normal-weight concrete)

$$f'_c = 24.00, \text{ but } f_c^{0.5} \leq 8.3 \text{ MPa (22.5.3.1, ACI 318-14)}$$

$$p_w = A_s/(b_w*d) = 0.00628319$$

As (tension reinf.) = 603.1858

bw = 400.00

d = 240.00

$V_u*d/M_u < 1 = 0.00$

$M_u = 7.6252677E-012$

$V_u = 3.6870970E-015$

From (11.5.4.8), ACI 318-14: $V_s = 98960.169$

$A_v = 157079.633$

$f_y = 525.00$

$s = 150.00$

V_s has been multiplied by $2(1-s/d)$ ($s > d/2$, according to ASCE 41-17,10.3.4)

$2(1-s/d) = 0.75$

V_f ((11-3)-(11.4), ACI 440) = 0.00

From (11-11), ACI 440: $V_s + V_f \leq 312423.44$

Calculation of Shear Strength at edge 2, $V_{r2} = 174208.493$

$V_{r2} = V_n$ ((22.5.1.1), ACI 318-14)

NOTE: In expression (22.5.1.1) 'Vw' is replaced by 'Vw+ f*Vf' where Vf is the contribution of FRPs (11.3), ACI 440).

From Table (22.5.5.1), ACI 318-14: $V_c = 75248.325$

= 1 (normal-weight concrete)

$f_c' = 24.00$, but $f_c'^{0.5} \leq 8.3$ MPa (22.5.3.1, ACI 318-14)

$p_w = A_s/(b_w*d) = 0.00628319$

As (tension reinf.) = 603.1858

bw = 400.00

d = 240.00

$V_u*d/M_u < 1 = 0.00$

$M_u = 8.0393416E-013$

$V_u = 3.6870970E-015$

From (11.5.4.8), ACI 318-14: $V_s = 98960.169$

$A_v = 157079.633$

$f_y = 525.00$

$s = 150.00$

V_s has been multiplied by $2(1-s/d)$ ($s > d/2$, according to ASCE 41-17,10.3.4)

$2(1-s/d) = 0.75$

V_f ((11-3)-(11.4), ACI 440) = 0.00

From (11-11), ACI 440: $V_s + V_f \leq 312423.44$

End Of Calculation of Shear Capacity ratio for element: beam B1 of floor 1

At local axis: 2

Start Of Calculation of Chord Rotation Capacity for element: beam B1 of floor 1

At local axis: 2

Integration Section: (a)

Section Type: rcars

Constant Properties

Knowledge Factor, = 1.00

Chord Rotation is generally considered as Deformation-Controlled Action according to Table C7-1, ASCE 41-17.

Mean strengths are used for Deformation-Controlled Actions according to 7.5.1.3, ASCE 41-17

Consequently:

Existing material of Primary Member: Concrete Strength, $f_c = f_{cm} = 24.00$

Existing material of Primary Member: Steel Strength, $f_s = f_{sm} = 525.00$

Concrete Elasticity, $E_c = 23025.204$

Steel Elasticity, $E_s = 200000.00$

Section Height, $H = 400.00$

Section Width, $W = 300.00$

Cover Thickness, $c = 25.00$

Element Length, $L = 1850.00$

Primary Member

Smooth Bars

Ductile Steel

With Detailing for Earthquake Resistance (including stirrups closed at 135°)

Longitudinal Bars With Ends Lapped Starting at the End Sections

Adequate Lap Length ($l_b/l_d \geq 1$)

No FRP Wrapping

Stepwise Properties

Bending Moment, $M = 5.4177E+006$

Shear Force, $V2 = 3.0430585E-014$

Shear Force, $V3 = -3205.137$

Axial Force, $F = -560.8745$

Longitudinal Reinforcement Area Distribution (in 2 divisions)

-Tension: $Asl_t = 603.1858$

-Compression: $Asl_c = 923.6282$

Longitudinal Reinforcement Area Distribution (in 3 divisions)

-Tension: $Asl_{ten} = 603.1858$

-Compression: $Asl_{com} = 615.7522$

-Middle: $Asl_{mid} = 307.8761$

Mean Diameter of Tension Reinforcement, $DbL = 16.00$

Existing component: From table 7-7, ASCE 41_17: Final chord rotation Capacity $u_{R} = \gamma + \rho = 0.01103074$

$u = \gamma + \rho = 0.01103074$

- Calculation of γ -

$\gamma = (M \cdot L_s / 3) / E_{eff} = 0.00603074$ ((4.29), Biskinis Phd))

$M_y = 1.1830E+008$

$L_s = M/V$ (with $L_s > 0.1 \cdot L$ and $L_s < 2 \cdot L$) = 1690.313

From table 10.5, ASCE 41_17: $E_{eff} = 0.3 \cdot E_c \cdot I_g = 1.1052E+013$

Calculation of Yielding Moment M_y

Calculation of γ and M_y according to Annex 7 -

$\gamma = \text{Min}(\gamma_{ten}, \gamma_{com})$

$\gamma_{ten} = 1.0034997E-005$

with $f_y = 525.00$

$d = 357.00$

$\gamma = 0.2672702$

$A = 0.01426594$

$B = 0.00792478$

with $p_t = 0.00563199$

$p_c = 0.00574932$

$p_v = 0.00287466$

$N = 560.8745$

$b = 300.00$

$\gamma = 0.11764706$

$\gamma_{comp} = 1.9669384E-005$

with $f_c = 24.00$

$E_c = 23025.204$

$\gamma = 0.26719068$

$A = 0.01424201$

$B = 0.00791481$

with $E_s = 200000.00$

Calculation of ratio l_b/l_d

Adequate Lap Length: $l_b/l_d \geq 1$

- Calculation of ρ -

From table 10-7: $\rho = 0.005$

with:

- Condition i occurred

Beam controlled by flexure: $V_p/V_o \leq 1$

shear control ratio $V_p/V_o = 0.78793176$

- Transverse Reinforcement: NC

- Stirrup Spacing $> d/3$

- Low ductility demand, $\lambda / \gamma < 2$ (table 10-6, ASCE 41-17)

$= 5.9520362E-005$

- Stirrup Spacing $\leq d/2$

$d = 357.00$

$s = 150.00$

- Strength provided by hoops $V_s < 3/4$ *design Shear

$V_s = 175929.189$, already given in calculation of shear control ratio

design Shear = 3205.137

- ($\rho - \rho'$)/ $\rho_{bal} = -0.16985254$

$= A_{st}/(b_w*d) = 0.00563199$

Tension Reinf Area: $A_{st} = 603.1858$

$\rho' = A_{sc}/(b_w*d) = 0.00862398$

Compression Reinf Area: $A_{sc} = 923.6282$

From (B-1), ACI 318-11: $\rho_{bal} = 0.01761524$

$f_c = 24.00$

$f_y = 525.00$

From 10.2.7.3, ACI 318-11: $\lambda = 0.85$

From fig R10.3.3, ACI 318-11 (Ence 454, too): $87000/(87000 + f_y) = c_b/d_t = 0.003/(0.003 + \gamma) = 0.53333333$

$\gamma = 0.002625$

- $V/(b_w*d*f_c^{0.5}) = 0.0735656$, NOTE: units in lb & in

$b_w = 300.00$

End Of Calculation of Chord Rotation Capacity for element: beam B1 of floor 1

At local axis: 2

Integration Section: (a)

Calculation No. 3

beam B1, Floor 1



Limit State: Operational Level (data interpolation between analysis steps 1 and 2)

Analysis: Uniform +X

Check: Shear capacity V_{Rd}

Edge: Start

Local Axis: (3)



Start Of Calculation of Shear Capacity for element: beam B1 of floor 1

At local axis: 3

Integration Section: (a)

Section Type: rcars

Constant Properties

Knowledge Factor, $\gamma = 1.00$

Member Shear Force is generally considered as Force-Controlled Action according to Table C7-1, ASCE 41-17.

Lower-bound strengths are used for Force-Controlled Actions according to 7.5.1.3, ASCE 41-17

Consequently:

Existing material of Primary Member: Concrete Strength, $f_c = f_{c_lower_bound} = 16.00$

Existing material of Primary Member: Steel Strength, $f_s = f_{s_lower_bound} = 420.00$

Concrete Elasticity, $E_c = 23025.204$

Steel Elasticity, $E_s = 200000.00$

Section Height, $H = 400.00$

Section Width, $W = 300.00$

Cover Thickness, $c = 25.00$

Element Length, $L = 1850.00$

Primary Member

Smooth Bars

Ductile Steel

With Detailing for Earthquake Resistance (including stirrups closed at 135°)

Longitudinal Bars With Ends Lapped Starting at the End Sections

Adequate Lap Length ($l_o/l_{o,min} = l_b/l_d \geq 1$)

No FRP Wrapping

Stepwise Properties

EDGE -A-

Bending Moment, $M_a = 5.4177E+006$

Shear Force, $V_a = -3205.137$

EDGE -B-

Bending Moment, $M_b = 5.5813E+006$

Shear Force, $V_b = 8685.666$

BOTH EDGES

Axial Force, $F = -560.8745$

Longitudinal Reinforcement Area Distribution (in 2 divisions)

-Tension: $A_{st} = 603.1858$

-Compression: $A_{sc} = 923.6282$

Longitudinal Reinforcement Area Distribution (in 3 divisions)

-Tension: $A_{st,ten} = 603.1858$

-Compression: $A_{st,com} = 615.7522$

-Middle: $A_{st,mid} = 307.8761$

Mean Diameter of Tension Reinforcement, $D_{bL,ten} = 16.00$

Existing component: From table 7-7, ASCE 41_17: Final Shear Capacity $V_R = *V_n = 204124.607$

$V_n ((22.5.1.1), ACI 318-14) = 204124.607$

NOTE: In expression (22.5.1.1) 'Vw' is replaced by 'Vw+ f*Vf' where Vf is the contribution of FRPs (11.3), ACI 440).

From Table (22.5.5.1), ACI 318-14: $V_c = 63381.256$
= 1 (normal-weight concrete)
 $f'_c = 16.00$, but $f'_c^{0.5} \leq 8.3$ MPa (22.5.3.1, ACI 318-14)
 $\rho_w = A_s/(b_w*d) = 0.00628319$
 A_s (tension reinf.) = 603.1858
 $b_w = 300.00$
 $d = 320.00$
 $V_u*d/\mu < 1 = 0.18931407$
 $\mu = 5.4177E+006$
 $V_u = 3205.137$

From (11.5.4.8), ACI 318-14: $V_s = 140743.351$
 $A_v = 157079.633$
 $f_y = 420.00$
 $s = 150.00$
 V_s has been multiplied by 1 ($s < d/2$, according to ASCE 41-17,10.3.4)
 V_f ((11-3)-(11.4), ACI 440) = 0.00
From (11-11), ACI 440: $V_s + V_f \leq 255092.67$

End Of Calculation of Shear Capacity for element: beam B1 of floor 1
At local axis: 3
Integration Section: (a)

Calculation No. 4

beam B1, Floor 1



Limit State: Operational Level (data interpolation between analysis steps 1 and 2)

Analysis: Uniform +X

Check: Chord rotation capacity (μ)

Edge: Start

Local Axis: (3)



Start Of Calculation of Shear Capacity ratio for element: beam B1 of floor 1
At Shear local axis: 3
(Bending local axis: 2)

Section Type: rcars

Constant Properties

Knowledge Factor, $\gamma = 1.00$

Mean strength values are used for both shear and moment calculations.

Consequently:

Existing material of Primary Member: Concrete Strength, $f_c = f_{cm} = 24.00$

Existing material of Primary Member: Steel Strength, $f_s = f_{sm} = 525.00$

Concrete Elasticity, $E_c = 23025.204$

Steel Elasticity, $E_s = 200000.00$

#####

Note: Especially for the calculation of moment strengths,

the above steel re-bar strengths are multiplied by 1.25 according to R18.6.5, ACI 318-14

Existing material: Steel Strength, $f_s = 1.25 \cdot f_{sm} = 656.25$

#####

Section Height, $H = 400.00$

Section Width, $W = 300.00$

Cover Thickness, $c = 25.00$

Mean Confinement Factor overall section = 1.09003

Element Length, $L = 1850.00$

Primary Member

Smooth Bars

Ductile Steel

With Detailing for Earthquake Resistance (including stirrups closed at 135°)

Longitudinal Bars With Ends Lapped Starting at the End Sections

Adequate Lap Length ($l_o/l_{ou}, \min > = 1$)

No FRP Wrapping

Stepwise Properties

At local axis: 3

EDGE -A-

Shear Force, $V_a = 2740.265$

EDGE -B-

Shear Force, $V_b = 2740.264$

BOTH EDGES

Axial Force, $F = -211.0849$

Longitudinal Reinforcement Area Distribution (in 2 divisions)

-Tension: $A_{sl,t} = 603.1858$

-Compression: $A_{sl,c} = 923.6282$

Longitudinal Reinforcement Area Distribution (in 3 divisions)

-Tension: $A_{sl,ten} = 603.1858$

-Compression: $A_{sl,com} = 615.7522$

-Middle: $A_{sl,mid} = 307.8761$

Calculation of Shear Capacity ratio, $V_e/V_r = 0.78793176$

Member Controlled by Flexure ($V_e/V_r < 1$)

Calculation of Shear Demand from fig. R18.6.5, ACI 318-14 $V_e = (M_{pr1} + M_{pr2})/l_n \pm w_u \cdot l_n/2 = 205990.317$

with

$M_{pr1} = \max(\mu_{1+}, \mu_{1-}) = 1.8802E+008$

$\mu_{1+} = 1.8495E+008$, is the ultimate moment strength at the edge 1 of the member in the actual moment direction which is defined for the static loading combination

$\mu_{1-} = 1.8802E+008$, is the ultimate moment strength at the edge 1 of the member in the opposite moment direction which is defined for the static loading combination

$M_{pr2} = \max(\mu_{2+}, \mu_{2-}) = 1.8800E+008$

$\mu_{2+} = 1.8498E+008$, is the ultimate moment strength at the edge 2 of the member in the actual moment direction which is defined for the the static loading combination

$\mu_{2-} = 1.8800E+008$, is the ultimate moment strength at the edge 2 of the member in the opposite moment direction which is defined for the the static loading combination

and

$\pm w_u \cdot l_n = (|V_1| + |V_2|)/2$

with

V1 = 2740.265, is the shear force acting at edge 1 for the the static loading combination
V2 = 2740.264, is the shear force acting at edge 2 for the the static loading combination

Calculation of Mu1+

Calculation of ultimate curvature ϕ_u according to 4.1, Biskinis/Fardis 2013:

$$u = 0.0001071$$

$$Mu = 1.8495E+008$$

with full section properties:

$$b = 300.00$$

$$d = 357.00$$

$$d' = 42.00$$

$$v = 8.2121432E-005$$

$$N = 211.0849$$

$$f_c = 24.00$$

$$c_o \text{ (5A.5, TBDY)} = 0.002$$

$$\text{Final value of } c_u: c_u^* = \text{shear_factor} * \text{Max}(c_u, c_c) = 0.00773686$$

The Shear_factor is considered equal to 1 (pure moment strength)

$$\text{From (5.4b), TBDY: } c_u = 0.00773686$$

$$w_e \text{ (5.4c)} = 0.01121936$$

$$a_{se} \text{ ((5.4d), TBDY)} = 0.15672608$$

$$b_o = 240.00$$

$$h_o = 340.00$$

$$b_{i2} = 346400.00$$

$$p_{sh,min} = \text{Min}(p_{sh,x}, p_{sh,y}) = 0.00261799$$

 $p_{sh,x} \text{ (5.4d)} = 0.00349066$

$$A_{sh} = A_{stir} * n_s = 78.53982$$

$$\text{No stirups, } n_s = 2.00$$

$$b_k = 300.00$$

 $p_{sh,y} \text{ (5.4d)} = 0.00261799$

$$A_{sh} = A_{stir} * n_s = 78.53982$$

$$\text{No stirups, } n_s = 2.00$$

$$b_k = 400.00$$

 $s = 150.00$

$$f_{ywe} = 656.25$$

$$f_{ce} = 24.00$$

$$\text{From ((5.A5), TBDY), TBDY: } c_c = 0.00290026$$

$$c = \text{confinement factor} = 1.09003$$

$$y_1 = 0.0025$$

$$sh_1 = 0.008$$

$$ft_1 = 787.50$$

$$fy_1 = 656.25$$

$$su_1 = 0.032$$

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00

$$l_o/l_{ou,min} = l_b/l_d = 1.00$$

$$su_1 = 0.4 * esu_1_{nominal} \text{ ((5.5), TBDY)} = 0.032$$

$$\text{From table 5A.1, TBDY: } esu_1_{nominal} = 0.08,$$

For calculation of $esu_1_{nominal}$ and y_1, sh_1, ft_1, fy_1 , it is considered
characteristic value $fsy_1 = fs_1/1.2$, from table 5.1, TBDY.

$$y_1, sh_1, ft_1, fy_1, \text{ are also multiplied by } \text{Min}(1, 1.25 * (l_b/l_d)^{2/3}), \text{ from 10.3.5, ASCE 41-17.}$$

$$\text{with } fs_1 = fs = 656.25$$

$$\text{with } E_{s1} = E_s = 200000.00$$

$$y_2 = 0.0025$$

$$sh_2 = 0.008$$

$$ft_2 = 787.50$$

$$fy_2 = 656.25$$

$$su_2 = 0.032$$

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor

and also multiplied by the shear_factor according to 15.7.1.4, with

Shear_factor = 1.00

lo/lou,min = lb/lb,min = 1.00

su2 = 0.4*esu2_nominal ((5.5), TBDY) = 0.032

From table 5A.1, TBDY: esu2_nominal = 0.08,

For calculation of esu2_nominal and y2, sh2,ft2,fy2, it is considered characteristic value fsy2 = fs2/1.2, from table 5.1, TBDY.

y1, sh1,ft1,fy1, are also multiplied by $\text{Min}(1, 1.25 \cdot (lb/ld)^{2/3})$, from 10.3.5, ASCE 41-17.

with fs2 = fs = 656.25

with Es2 = Es = 200000.00

yv = 0.0025

shv = 0.008

ftv = 787.50

fyv = 656.25

suv = 0.032

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor

and also multiplied by the shear_factor according to 15.7.1.4, with

Shear_factor = 1.00

lo/lou,min = lb/ld = 1.00

suv = 0.4*esuv_nominal ((5.5), TBDY) = 0.032

From table 5A.1, TBDY: esuv_nominal = 0.08,

considering characteristic value fsyv = fsv/1.2, from table 5.1, TBDY

For calculation of esuv_nominal and yv, shv,ftv,fyv, it is considered characteristic value fsyv = fsv/1.2, from table 5.1, TBDY.

y1, sh1,ft1,fy1, are also multiplied by $\text{Min}(1, 1.25 \cdot (lb/ld)^{2/3})$, from 10.3.5, ASCE 41-17.

with fsv = fs = 656.25

with Esv = Es = 200000.00

1 = Asl,ten/(b*d)*(fs1/fc) = 0.15399964

2 = Asl,com/(b*d)*(fs2/fc) = 0.15720797

v = Asl,mid/(b*d)*(fsv/fc) = 0.07860398

and confined core properties:

b = 240.00

d = 327.00

d' = 12.00

fcc (5A.2, TBDY) = 26.16063

cc (5A.5, TBDY) = 0.00290026

c = confinement factor = 1.09003

1 = Asl,ten/(b*d)*(fs1/fc) = 0.21016006

2 = Asl,com/(b*d)*(fs2/fc) = 0.21453839

v = Asl,mid/(b*d)*(fsv/fc) = 0.1072692

Case/Assumption: Unconfined full section - Steel rupture

' satisfies Eq. (4.3)

--->

v < vs,y2 - LHS eq.(4.5) is satisfied

--->

su (4.9) = 0.1630814

Mu = MRc (4.14) = 1.8495E+008

u = su (4.1) = 0.0001071

Calculation of ratio lb/ld

Adequate Lap Length: lb/ld >= 1

Calculation of Mu1-

Calculation of ultimate curvature u according to 4.1, Biskinis/Fardis 2013:

u = 0.00010722

Mu = 1.8802E+008

with full section properties:

b = 300.00

d = 358.00

d' = 43.00
v = 8.1892042E-005
N = 211.0849
fc = 24.00
co (5A.5, TBDY) = 0.002
Final value of cu: cu* = shear_factor * Max(cu, cc) = 0.00773686
The Shear_factor is considered equal to 1 (pure moment strength)
From (5.4b), TBDY: cu = 0.00773686
we (5.4c) = 0.01121936
ase ((5.4d), TBDY) = 0.15672608
bo = 240.00
ho = 340.00
bi2 = 346400.00
psh,min = Min(psh,x , psh,y) = 0.00261799

psh,x (5.4d) = 0.00349066
Ash = Astir*ns = 78.53982
No stirups, ns = 2.00
bk = 300.00

psh,y (5.4d) = 0.00261799
Ash = Astir*ns = 78.53982
No stirups, ns = 2.00
bk = 400.00

s = 150.00
fywe = 656.25
fce = 24.00
From ((5.A5), TBDY), TBDY: cc = 0.00290026
c = confinement factor = 1.09003
y1 = 0.0025
sh1 = 0.008
ft1 = 787.50
fy1 = 656.25
su1 = 0.032

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00
lo/lou,min = lb/d = 1.00
su1 = 0.4*esu1_nominal ((5.5), TBDY) = 0.032
From table 5A.1, TBDY: esu1_nominal = 0.08,
For calculation of esu1_nominal and y1, sh1,ft1,fy1, it is considered
characteristic value fsy1 = fs1/1.2, from table 5.1, TBDY.
y1, sh1,ft1,fy1, are also multiplied by Min(1,1.25*(lb/d)^ 2/3), from 10.3.5, ASCE 41-17.
with fs1 = fs = 656.25
with Es1 = Es = 200000.00

y2 = 0.0025
sh2 = 0.008
ft2 = 787.50
fy2 = 656.25
su2 = 0.032
using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00
lo/lou,min = lb/lb,min = 1.00
su2 = 0.4*esu2_nominal ((5.5), TBDY) = 0.032
From table 5A.1, TBDY: esu2_nominal = 0.08,
For calculation of esu2_nominal and y2, sh2,ft2,fy2, it is considered
characteristic value fsy2 = fs2/1.2, from table 5.1, TBDY.
y1, sh1,ft1,fy1, are also multiplied by Min(1,1.25*(lb/d)^ 2/3), from 10.3.5, ASCE 41-17.
with fs2 = fs = 656.25
with Es2 = Es = 200000.00

yv = 0.0025
shv = 0.008
ftv = 787.50
fyv = 656.25
suv = 0.032

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00

$l_0/l_{0u,min} = l_b/l_d = 1.00$

$s_{uv} = 0.4 * e_{suv,nominal} ((5.5), TBDY) = 0.032$

From table 5A.1, TBDY: $e_{suv,nominal} = 0.08$,

considering characteristic value $f_{syv} = f_{sv}/1.2$, from table 5.1, TBDY

For calculation of $e_{suv,nominal}$ and γ_v , sh_v, ft_v, fy_v , it is considered
characteristic value $f_{syv} = f_{sv}/1.2$, from table 5.1, TBDY.

γ_1 , sh_1, ft_1, fy_1 , are also multiplied by $\text{Min}(1, 1.25 * (l_b/l_d)^{2/3})$, from 10.3.5, ASCE 41-17.

with $f_{sv} = f_s = 656.25$

with $E_{sv} = E_s = 200000.00$

$1 = A_{sl,ten}/(b*d) * (f_{s1}/f_c) = 0.15676884$

$2 = A_{sl,com}/(b*d) * (f_{s2}/f_c) = 0.15356947$

$v = A_{sl,mid}/(b*d) * (f_{sv}/f_c) = 0.07838442$

and confined core properties:

$b = 240.00$

$d = 328.00$

$d' = 13.00$

$f_{cc} (5A.2, TBDY) = 26.16063$

$cc (5A.5, TBDY) = 0.00290026$

$c = \text{confinement factor} = 1.09003$

$1 = A_{sl,ten}/(b*d) * (f_{s1}/f_c) = 0.21388431$

$2 = A_{sl,com}/(b*d) * (f_{s2}/f_c) = 0.20951933$

$v = A_{sl,mid}/(b*d) * (f_{sv}/f_c) = 0.10694216$

Case/Assumption: Unconfined full section - Steel rupture

' satisfies Eq. (4.3)

$v < v_{s,y2}$ - LHS eq.(4.5) is satisfied

$s_u (4.9) = 0.16631328$

$M_u = M_{Rc} (4.14) = 1.8802E+008$

$u = s_u (4.1) = 0.00010722$

Calculation of ratio l_b/l_d

Adequate Lap Length: $l_b/l_d \geq 1$

Calculation of M_{u2+}

Calculation of ultimate curvature u according to 4.1, Biskinis/Fardis 2013:

$u = 0.00010701$

$M_u = 1.8498E+008$

with full section properties:

$b = 300.00$

$d = 358.00$

$d' = 43.00$

$v = 8.1892042E-005$

$N = 211.0849$

$f_c = 24.00$

$co (5A.5, TBDY) = 0.002$

Final value of cu : $cu^* = \text{shear_factor} * \text{Max}(cu, cc) = 0.00773686$

The Shear_factor is considered equal to 1 (pure moment strength)

From (5.4b), TBDY: $cu = 0.00773686$

$w_e (5.4c) = 0.01121936$

$ase ((5.4d), TBDY) = 0.15672608$

$bo = 240.00$

$ho = 340.00$

$bi_2 = 346400.00$

$p_{sh,min} = \text{Min}(p_{sh,x}, p_{sh,y}) = 0.00261799$

psh,x (5.4d) = 0.00349066
Ash = Astir*ns = 78.53982
No stirups, ns = 2.00
bk = 300.00

psh,y (5.4d) = 0.00261799
Ash = Astir*ns = 78.53982
No stirups, ns = 2.00
bk = 400.00

s = 150.00
fywe = 656.25
fce = 24.00

From ((5.A.5), TBDY), TBDY: cc = 0.00290026
c = confinement factor = 1.09003

y1 = 0.0025
sh1 = 0.008
ft1 = 787.50
fy1 = 656.25
su1 = 0.032

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00

lo/lou,min = lb/ld = 1.00

su1 = 0.4*esu1_nominal ((5.5), TBDY) = 0.032

From table 5A.1, TBDY: esu1_nominal = 0.08,

For calculation of esu1_nominal and y1, sh1,ft1,fy1, it is considered
characteristic value fsy1 = fs1/1.2, from table 5.1, TBDY.

y1, sh1,ft1,fy1, are also multiplied by Min(1,1.25*(lb/ld)^2/3), from 10.3.5, ASCE 41-17.

with fs1 = fs = 656.25

with Es1 = Es = 200000.00

y2 = 0.0025
sh2 = 0.008
ft2 = 787.50
fy2 = 656.25
su2 = 0.032

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00

lo/lou,min = lb/lb,min = 1.00

su2 = 0.4*esu2_nominal ((5.5), TBDY) = 0.032

From table 5A.1, TBDY: esu2_nominal = 0.08,

For calculation of esu2_nominal and y2, sh2,ft2,fy2, it is considered
characteristic value fsy2 = fs2/1.2, from table 5.1, TBDY.

y1, sh1,ft1,fy1, are also multiplied by Min(1,1.25*(lb/ld)^2/3), from 10.3.5, ASCE 41-17.

with fs2 = fs = 656.25

with Es2 = Es = 200000.00

yv = 0.0025
shv = 0.008
ftv = 787.50
fyv = 656.25
suv = 0.032

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00

lo/lou,min = lb/ld = 1.00

suv = 0.4*esuv_nominal ((5.5), TBDY) = 0.032

From table 5A.1, TBDY: esuv_nominal = 0.08,

considering characteristic value fsyv = fsv/1.2, from table 5.1, TBDY

For calculation of esuv_nominal and yv, shv,ftv,fyv, it is considered
characteristic value fsyv = fsv/1.2, from table 5.1, TBDY.

y1, sh1,ft1,fy1, are also multiplied by Min(1,1.25*(lb/ld)^2/3), from 10.3.5, ASCE 41-17.

with fsv = fs = 656.25

with Esv = Es = 200000.00

1 = Asl,ten/(b*d)*(fs1/fc) = 0.15356947

2 = Asl,com/(b*d)*(fs2/fc) = 0.15676884

v = Asl,mid/(b*d)*(fsv/fc) = 0.07838442

and confined core properties:

$$b = 240.00$$

$$d = 328.00$$

$$d' = 13.00$$

$$fcc (5A.2, TBDY) = 26.16063$$

$$cc (5A.5, TBDY) = 0.00290026$$

$$c = \text{confinement factor} = 1.09003$$

$$1 = A_{sl,ten}/(b*d)*(f_{s1}/f_c) = 0.20951933$$

$$2 = A_{sl,com}/(b*d)*(f_{s2}/f_c) = 0.21388431$$

$$v = A_{sl,mid}/(b*d)*(f_{sv}/f_c) = 0.10694216$$

Case/Assumption: Unconfined full section - Steel rupture

' satisfies Eq. (4.3)

--->

$v < v_{s,y2}$ - LHS eq.(4.5) is satisfied

--->

$$s_u (4.9) = 0.16466458$$

$$\mu_u = M_{Rc} (4.14) = 1.8498E+008$$

$$u = s_u (4.1) = 0.00010701$$

Calculation of ratio l_b/d

Adequate Lap Length: $l_b/d \geq 1$

Calculation of μ_{u2} -

Calculation of ultimate curvature μ_u according to 4.1, Biskinis/Fardis 2013:

$$u = 0.00010732$$

$$\mu_u = 1.8800E+008$$

with full section properties:

$$b = 300.00$$

$$d = 357.00$$

$$d' = 42.00$$

$$v = 8.2121432E-005$$

$$N = 211.0849$$

$$f_c = 24.00$$

$$c_o (5A.5, TBDY) = 0.002$$

$$\text{Final value of } c_u: c_u^* = \text{shear_factor} * \text{Max}(c_u, c_c) = 0.00773686$$

The Shear_factor is considered equal to 1 (pure moment strength)

$$\text{From (5.4b), TBDY: } c_u = 0.00773686$$

$$w_e (5.4c) = 0.01121936$$

$$a_{se} ((5.4d), TBDY) = 0.15672608$$

$$b_o = 240.00$$

$$h_o = 340.00$$

$$b_{i2} = 346400.00$$

$$p_{sh,min} = \text{Min}(p_{sh,x}, p_{sh,y}) = 0.00261799$$

$$p_{sh,x} (5.4d) = 0.00349066$$

$$A_{sh} = A_{stir} * n_s = 78.53982$$

$$\text{No stirups, } n_s = 2.00$$

$$b_k = 300.00$$

$$p_{sh,y} (5.4d) = 0.00261799$$

$$A_{sh} = A_{stir} * n_s = 78.53982$$

$$\text{No stirups, } n_s = 2.00$$

$$b_k = 400.00$$

$$s = 150.00$$

$$f_{ywe} = 656.25$$

$$f_{ce} = 24.00$$

$$\text{From ((5.A5), TBDY), TBDY: } c_c = 0.00290026$$

$$c = \text{confinement factor} = 1.09003$$

y1 = 0.0025
sh1 = 0.008
ft1 = 787.50
fy1 = 656.25
su1 = 0.032

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00

lo/lou,min = lb/d = 1.00

su1 = 0.4*esu1_nominal ((5.5), TBDY) = 0.032

From table 5A.1, TBDY: esu1_nominal = 0.08,

For calculation of esu1_nominal and y1, sh1,ft1,fy1, it is considered
characteristic value fsy1 = fs1/1.2, from table 5.1, TBDY.

y1, sh1,ft1,fy1, are also multiplied by $\text{Min}(1, 1.25 \cdot (lb/d)^{2/3})$, from 10.3.5, ASCE 41-17.

with fs1 = fs = 656.25

with Es1 = Es = 200000.00

y2 = 0.0025
sh2 = 0.008
ft2 = 787.50
fy2 = 656.25
su2 = 0.032

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00

lo/lou,min = lb/lb,min = 1.00

su2 = 0.4*esu2_nominal ((5.5), TBDY) = 0.032

From table 5A.1, TBDY: esu2_nominal = 0.08,

For calculation of esu2_nominal and y2, sh2,ft2,fy2, it is considered
characteristic value fsy2 = fs2/1.2, from table 5.1, TBDY.

y1, sh1,ft1,fy1, are also multiplied by $\text{Min}(1, 1.25 \cdot (lb/d)^{2/3})$, from 10.3.5, ASCE 41-17.

with fs2 = fs = 656.25

with Es2 = Es = 200000.00

yv = 0.0025
shv = 0.008
ftv = 787.50
fyv = 656.25
suv = 0.032

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00

lo/lou,min = lb/d = 1.00

suv = 0.4*esuv_nominal ((5.5), TBDY) = 0.032

From table 5A.1, TBDY: esuv_nominal = 0.08,

considering characteristic value fsyv = fsv/1.2, from table 5.1, TBDY

For calculation of esuv_nominal and yv, shv,ftv,fyv, it is considered
characteristic value fsyv = fsv/1.2, from table 5.1, TBDY.

y1, sh1,ft1,fy1, are also multiplied by $\text{Min}(1, 1.25 \cdot (lb/d)^{2/3})$, from 10.3.5, ASCE 41-17.

with fsv = fs = 656.25

with Esv = Es = 200000.00

1 = Asl,ten/(b*d)*(fs1/fc) = 0.15720797

2 = Asl,com/(b*d)*(fs2/fc) = 0.15399964

v = Asl,mid/(b*d)*(fsv/fc) = 0.07860398

and confined core properties:

b = 240.00

d = 327.00

d' = 12.00

fcc (5A.2, TBDY) = 26.16063

cc (5A.5, TBDY) = 0.00290026

c = confinement factor = 1.09003

1 = Asl,ten/(b*d)*(fs1/fc) = 0.21453839

2 = Asl,com/(b*d)*(fs2/fc) = 0.21016006

v = Asl,mid/(b*d)*(fsv/fc) = 0.1072692

Case/Assumption: Unconfined full section - Steel rupture

' satisfies Eq. (4.3)

---->

v < vs,y2 - LHS eq.(4.5) is satisfied

---->

su (4.9) = 0.16474284
Mu = MRc (4.14) = 1.8800E+008
u = su (4.1) = 0.00010732

Calculation of ratio lb/l_d

Adequate Lap Length: lb/l_d >= 1

Calculation of Shear Strength Vr = Min(Vr1,Vr2) = 261431.672

Calculation of Shear Strength at edge 1, Vr1 = 261431.672
Vr1 = Vn ((22.5.1.1), ACI 318-14)

NOTE: In expression (22.5.1.1) 'Vw' is replaced by 'Vw+ f*Vf'
where Vf is the contribution of FRPs (11.3), ACI 440).

From Table (22.5.5.1), ACI 318-14: Vc = 85502.483
= 1 (normal-weight concrete)
fc' = 24.00, but fc'^0.5 <= 8.3 MPa (22.5.3.1, ACI 318-14)
pw = As/(bw*d) = 0.00628319
As (tension reinf.) = 603.1858
bw = 300.00
d = 320.00
Vu*d/Mu < 1 = 1.00
Mu = 30114.962
Vu = 2740.265

From (11.5.4.8), ACI 318-14: Vs = 175929.189
Av = 157079.633
fy = 525.00
s = 150.00

Vs has been multiplied by 1 (s<d/2, according to ASCE 41-17,10.3.4)
Vf ((11-3)-(11.4), ACI 440) = 0.00
From (11-11), ACI 440: Vs + Vf <= 312423.44

Calculation of Shear Strength at edge 2, Vr2 = 261431.672
Vr2 = Vn ((22.5.1.1), ACI 318-14)

NOTE: In expression (22.5.1.1) 'Vw' is replaced by 'Vw+ f*Vf'
where Vf is the contribution of FRPs (11.3), ACI 440).

From Table (22.5.5.1), ACI 318-14: Vc = 85502.483
= 1 (normal-weight concrete)
fc' = 24.00, but fc'^0.5 <= 8.3 MPa (22.5.3.1, ACI 318-14)
pw = As/(bw*d) = 0.00628319
As (tension reinf.) = 603.1858
bw = 300.00
d = 320.00
Vu*d/Mu < 1 = 1.00
Mu = 30115.665
Vu = 2740.264

From (11.5.4.8), ACI 318-14: Vs = 175929.189
Av = 157079.633
fy = 525.00
s = 150.00

Vs has been multiplied by 1 (s<d/2, according to ASCE 41-17,10.3.4)
Vf ((11-3)-(11.4), ACI 440) = 0.00
From (11-11), ACI 440: Vs + Vf <= 312423.44

End Of Calculation of Shear Capacity ratio for element: beam B1 of floor 1
At local axis: 3

Start Of Calculation of Shear Capacity ratio for element: beam B1 of floor 1

At Shear local axis: 2

(Bending local axis: 3)

Section Type: rcars

Constant Properties

Knowledge Factor, $\gamma = 1.00$

Mean strength values are used for both shear and moment calculations.

Consequently:

Existing material of Primary Member: Concrete Strength, $f_c = f_{cm} = 24.00$

Existing material of Primary Member: Steel Strength, $f_s = f_{sm} = 525.00$

Concrete Elasticity, $E_c = 23025.204$

Steel Elasticity, $E_s = 200000.00$

#####

Note: Especially for the calculation of moment strengths,

the above steel re-bar strengths are multiplied by 1.25 according to R18.6.5, ACI 318-14

Existing material: Steel Strength, $f_s = 1.25 \cdot f_{sm} = 656.25$

#####

Section Height, $H = 400.00$

Section Width, $W = 300.00$

Cover Thickness, $c = 25.00$

Mean Confinement Factor overall section = 1.09003

Element Length, $L = 1850.00$

Primary Member

Smooth Bars

Ductile Steel

With Detailing for Earthquake Resistance (including stirrups closed at 135°)

Longitudinal Bars With Ends Lapped Starting at the End Sections

Adequate Lap Length ($l_o/l_{ou}, \min >= 1$)

No FRP Wrapping

Stepwise Properties

At local axis: 2

EDGE -A-

Shear Force, $V_a = -3.6870970E-015$

EDGE -B-

Shear Force, $V_b = 3.6870970E-015$

BOTH EDGES

Axial Force, $F = -211.0849$

Longitudinal Reinforcement Area Distribution (in 2 divisions)

-Tension: $A_{st} = 603.1858$

-Compression: $A_{sc} = 923.6282$

Longitudinal Reinforcement Area Distribution (in 3 divisions)

-Tension: $A_{st,ten} = 508.938$

-Compression: $A_{sc,com} = 508.938$

-Middle: $A_{st,mid} = 508.938$

Calculation of Shear Capacity ratio, $V_e/V_r = 0.79211753$

Member Controlled by Flexure ($V_e/V_r < 1$)

Calculation of Shear Demand from fig. R18.6.5, ACI 318-14 $V_e = (M_{pr1} + M_{pr2})/l_n \pm w_u \cdot l_n/2 = 137993.601$
with

$M_{pr1} = \text{Max}(M_{u1+}, M_{u1-}) = 1.2764E+008$

$M_{u1+} = 1.2764E+008$, is the ultimate moment strength at the edge 1 of the member in the actual moment direction which is defined for the static loading combination

$M_{u1-} = 1.2764E+008$, is the ultimate moment strength at the edge 1 of the member in the opposite moment direction which is defined for the static loading combination

$M_{pr2} = \text{Max}(M_{u2+}, M_{u2-}) = 1.2764E+008$

$M_{u2+} = 1.2764E+008$, is the ultimate moment strength at the edge 2 of the member in the actual moment direction which is defined for the static loading combination

$M_{u2-} = 1.2764E+008$, is the ultimate moment strength at the edge 2 of the member in the opposite moment

direction which is defined for the the static loading combination
and

$$\pm wu*ln = (|V1| + |V2|)/2$$

with

V1 = -3.6870970E-015, is the shear force acting at edge 1 for the the static loading combination

V2 = 3.6870970E-015, is the shear force acting at edge 2 for the the static loading combination

Calculation of Mu1+

Calculation of ultimate curvature ϕ_u according to 4.1, Biskinis/Fardis 2013:

$$u = 0.00015613$$

$$Mu = 1.2764E+008$$

with full section properties:

$$b = 400.00$$

$$d = 258.00$$

$$d' = 42.00$$

$$v = 8.5224858E-005$$

$$N = 211.0849$$

$$fc = 24.00$$

$$co \text{ (5A.5, TBDY)} = 0.002$$

$$\text{Final value of } \phi_u: \phi_u^* = \text{shear_factor} * \text{Max}(\phi_u, \phi_c) = 0.00773686$$

The Shear_factor is considered equal to 1 (pure moment strength)

$$\text{From (5.4b), TBDY: } \phi_u = 0.00773686$$

$$\phi_{ue} \text{ (5.4c)} = 0.01121936$$

$$\phi_{ase} \text{ ((5.4d), TBDY)} = 0.15672608$$

$$b_o = 240.00$$

$$h_o = 340.00$$

$$b_i^2 = 346400.00$$

$$\phi_{sh,min} = \text{Min}(\phi_{sh,x}, \phi_{sh,y}) = 0.00261799$$

 $\phi_{sh,x} \text{ (5.4d)} = 0.00349066$

$$A_{sh} = A_{stir} * n_s = 78.53982$$

$$\text{No stirups, } n_s = 2.00$$

$$b_k = 300.00$$

 $\phi_{sh,y} \text{ (5.4d)} = 0.00261799$

$$A_{sh} = A_{stir} * n_s = 78.53982$$

$$\text{No stirups, } n_s = 2.00$$

$$b_k = 400.00$$

 $s = 150.00$

$$f_{ywe} = 656.25$$

$$f_{ce} = 24.00$$

$$\text{From ((5.A5), TBDY), TBDY: } \phi_c = 0.00290026$$

$$c = \text{confinement factor} = 1.09003$$

$$y_1 = 0.0025$$

$$sh_1 = 0.008$$

$$ft_1 = 787.50$$

$$fy_1 = 656.25$$

$$su_1 = 0.032$$

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor

and also multiplied by the shear_factor according to 15.7.1.4, with

Shear_factor = 1.00

$$l_o/l_{ou,min} = l_b/l_d = 1.00$$

$$su_1 = 0.4 * esu_{1,nominal} \text{ ((5.5), TBDY)} = 0.032$$

$$\text{From table 5A.1, TBDY: } esu_{1,nominal} = 0.08,$$

For calculation of $esu_{1,nominal}$ and y_1, sh_1, ft_1, fy_1 , it is considered

characteristic value $fsy_1 = fs_1/1.2$, from table 5.1, TBDY.

y_1, sh_1, ft_1, fy_1 , are also multiplied by $\text{Min}(1, 1.25 * (l_b/l_d)^{2/3})$, from 10.3.5, ASCE 41-17.

$$\text{with } fs_1 = fs = 656.25$$

$$\text{with } Es_1 = Es = 200000.00$$

$$y_2 = 0.0025$$

$$sh_2 = 0.008$$

$$ft2 = 787.50$$

$$fy2 = 656.25$$

$$su2 = 0.032$$

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00

$$lo/lou,min = lb/lb,min = 1.00$$

$$su2 = 0.4 * esu2_nominal ((5.5), TBDY) = 0.032$$

From table 5A.1, TBDY: esu2_nominal = 0.08,

For calculation of esu2_nominal and y2, sh2,ft2,fy2, it is considered
characteristic value fsy2 = fs2/1.2, from table 5.1, TBDY.

y1, sh1,ft1,fy1, are also multiplied by $\text{Min}(1, 1.25 * (lb/ld)^{2/3})$, from 10.3.5, ASCE 41-17.

$$\text{with } fs2 = fs = 656.25$$

$$\text{with } Es2 = Es = 200000.00$$

$$yv = 0.0025$$

$$shv = 0.008$$

$$ftv = 787.50$$

$$fyv = 656.25$$

$$suv = 0.032$$

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00

$$lo/lou,min = lb/ld = 1.00$$

$$suv = 0.4 * esuv_nominal ((5.5), TBDY) = 0.032$$

From table 5A.1, TBDY: esuv_nominal = 0.08,

considering characteristic value fsyv = fsv/1.2, from table 5.1, TBDY

For calculation of esuv_nominal and yv, shv,ftv,fyv, it is considered
characteristic value fsyv = fsv/1.2, from table 5.1, TBDY.

y1, sh1,ft1,fy1, are also multiplied by $\text{Min}(1, 1.25 * (lb/ld)^{2/3})$, from 10.3.5, ASCE 41-17.

$$\text{with } fsv = fs = 656.25$$

$$\text{with } Esv = Es = 200000.00$$

$$1 = Asl,ten / (b * d) * (fs1 / fc) = 0.13484761$$

$$2 = Asl,com / (b * d) * (fs2 / fc) = 0.13484761$$

$$v = Asl,mid / (b * d) * (fsv / fc) = 0.13484761$$

and confined core properties:

$$b = 340.00$$

$$d = 228.00$$

$$d' = 12.00$$

$$fcc (5A.2, TBDY) = 26.16063$$

$$cc (5A.5, TBDY) = 0.00290026$$

$$c = \text{confinement factor} = 1.09003$$

$$1 = Asl,ten / (b * d) * (fs1 / fc) = 0.17951849$$

$$2 = Asl,com / (b * d) * (fs2 / fc) = 0.17951849$$

$$v = Asl,mid / (b * d) * (fsv / fc) = 0.17951849$$

Case/Assumption: Unconfined full section - Steel rupture

' does not satisfy Eq. (4.3)

---->

$v < vs,c$ - RHS eq.(4.5) is satisfied

---->

$$su (4.9) = 0.20560388$$

$$Mu = MRc (4.14) = 1.2764E+008$$

$$u = su (4.1) = 0.00015613$$

Calculation of ratio lb/ld

Adequate Lap Length: $lb/ld \geq 1$

Calculation of Mu1-

Calculation of ultimate curvature u according to 4.1, Biskinis/Fardis 2013:

$$u = 0.00015613$$

$$Mu = 1.2764E+008$$

with full section properties:

$$b = 400.00$$

$$d = 258.00$$

$$d' = 42.00$$

$$v = 8.5224858E-005$$

$$N = 211.0849$$

$$f_c = 24.00$$

$$c_o (5A.5, TBDY) = 0.002$$

$$\text{Final value of } c_u: c_u^* = \text{shear_factor} * \text{Max}(c_u, c_c) = 0.00773686$$

The Shear_factor is considered equal to 1 (pure moment strength)

$$\text{From (5.4b), TBDY: } c_u = 0.00773686$$

$$w_e (5.4c) = 0.01121936$$

$$a_{se} ((5.4d), TBDY) = 0.15672608$$

$$b_o = 240.00$$

$$h_o = 340.00$$

$$b_{i2} = 346400.00$$

$$p_{sh,min} = \text{Min}(p_{sh,x}, p_{sh,y}) = 0.00261799$$

$$p_{sh,x} (5.4d) = 0.00349066$$

$$A_{sh} = A_{stir} * n_s = 78.53982$$

No stirrups, $n_s = 2.00$

$$b_k = 300.00$$

$$p_{sh,y} (5.4d) = 0.00261799$$

$$A_{sh} = A_{stir} * n_s = 78.53982$$

No stirrups, $n_s = 2.00$

$$b_k = 400.00$$

$$s = 150.00$$

$$f_{ywe} = 656.25$$

$$f_{ce} = 24.00$$

$$\text{From ((5.A5), TBDY), TBDY: } c_c = 0.00290026$$

$$c = \text{confinement factor} = 1.09003$$

$$y_1 = 0.0025$$

$$sh_1 = 0.008$$

$$ft_1 = 787.50$$

$$fy_1 = 656.25$$

$$su_1 = 0.032$$

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor and also multiplied by the shear_factor according to 15.7.1.4, with Shear_factor = 1.00

$$l_o/l_{o,min} = l_b/d = 1.00$$

$$su_1 = 0.4 * esu_{1,nominal} ((5.5), TBDY) = 0.032$$

$$\text{From table 5A.1, TBDY: } esu_{1,nominal} = 0.08,$$

For calculation of $esu_{1,nominal}$ and y_1, sh_1, ft_1, fy_1 , it is considered characteristic value $fsy_1 = fs_1/1.2$, from table 5.1, TBDY.

y_1, sh_1, ft_1, fy_1 , are also multiplied by $\text{Min}(1, 1.25 * (l_b/d)^{2/3})$, from 10.3.5, ASCE 41-17.

$$\text{with } fs_1 = fs = 656.25$$

$$\text{with } Es_1 = Es = 200000.00$$

$$y_2 = 0.0025$$

$$sh_2 = 0.008$$

$$ft_2 = 787.50$$

$$fy_2 = 656.25$$

$$su_2 = 0.032$$

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor and also multiplied by the shear_factor according to 15.7.1.4, with Shear_factor = 1.00

$$l_o/l_{o,min} = l_b/l_{b,min} = 1.00$$

$$su_2 = 0.4 * esu_{2,nominal} ((5.5), TBDY) = 0.032$$

$$\text{From table 5A.1, TBDY: } esu_{2,nominal} = 0.08,$$

For calculation of $esu_{2,nominal}$ and y_2, sh_2, ft_2, fy_2 , it is considered characteristic value $fsy_2 = fs_2/1.2$, from table 5.1, TBDY.

y_1, sh_1, ft_1, fy_1 , are also multiplied by $\text{Min}(1, 1.25 * (l_b/d)^{2/3})$, from 10.3.5, ASCE 41-17.

$$\text{with } fs_2 = fs = 656.25$$

$$\text{with } Es_2 = Es = 200000.00$$

$$y_v = 0.0025$$

$shv = 0.008$
 $ftv = 787.50$
 $fyv = 656.25$
 $suv = 0.032$
 using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
 and also multiplied by the shear_factor according to 15.7.1.4, with
 $Shear_factor = 1.00$
 $lo/lou,min = lb/ld = 1.00$
 $suv = 0.4 * esuv_nominal ((5.5), TBDY) = 0.032$
 From table 5A.1, TBDY: $esuv_nominal = 0.08$,
 considering characteristic value $fsyv = fsv/1.2$, from table 5.1, TBDY
 For calculation of $esuv_nominal$ and yv , shv,ftv,fyv , it is considered
 characteristic value $fsyv = fsv/1.2$, from table 5.1, TBDY.
 $y1, sh1,ft1,fy1$, are also multiplied by $Min(1,1.25*(lb/ld)^{2/3})$, from 10.3.5, ASCE 41-17.
 with $fsv = fs = 656.25$
 with $Esv = Es = 200000.00$
 $1 = Asl,ten/(b*d)*(fs1/fc) = 0.13484761$
 $2 = Asl,com/(b*d)*(fs2/fc) = 0.13484761$
 $v = Asl,mid/(b*d)*(fsv/fc) = 0.13484761$
 and confined core properties:
 $b = 340.00$
 $d = 228.00$
 $d' = 12.00$
 $fcc (5A.2, TBDY) = 26.16063$
 $cc (5A.5, TBDY) = 0.00290026$
 $c = \text{confinement factor} = 1.09003$
 $1 = Asl,ten/(b*d)*(fs1/fc) = 0.17951849$
 $2 = Asl,com/(b*d)*(fs2/fc) = 0.17951849$
 $v = Asl,mid/(b*d)*(fsv/fc) = 0.17951849$
 Case/Assumption: Unconfined full section - Steel rupture
 ' does not satisfy Eq. (4.3)
 --->
 $v < vs,c$ - RHS eq.(4.5) is satisfied
 --->
 $su (4.9) = 0.20560388$
 $Mu = MRc (4.14) = 1.2764E+008$
 $u = su (4.1) = 0.00015613$

 Calculation of ratio lb/ld

Adequate Lap Length: $lb/ld \geq 1$

 Calculation of $Mu2+$

 Calculation of ultimate curvature u according to 4.1, Biskinis/Fardis 2013:

$u = 0.00015613$
 $Mu = 1.2764E+008$

with full section properties:

$b = 400.00$
 $d = 258.00$
 $d' = 42.00$
 $v = 8.5224858E-005$
 $N = 211.0849$
 $fc = 24.00$
 $co (5A.5, TBDY) = 0.002$
 Final value of cu : $cu^* = shear_factor * Max(cu, cc) = 0.00773686$
 The Shear_factor is considered equal to 1 (pure moment strength)
 From (5.4b), TBDY: $cu = 0.00773686$
 $we (5.4c) = 0.01121936$
 $ase ((5.4d), TBDY) = 0.15672608$
 $bo = 240.00$

ho = 340.00
bi2 = 346400.00
psh,min = Min(psh,x , psh,y) = 0.00261799

psh,x (5.4d) = 0.00349066
Ash = Astir*ns = 78.53982
No stirups, ns = 2.00
bk = 300.00

psh,y (5.4d) = 0.00261799
Ash = Astir*ns = 78.53982
No stirups, ns = 2.00
bk = 400.00

s = 150.00
fywe = 656.25
fce = 24.00
From ((5.A5), TBDY), TBDY: cc = 0.00290026
c = confinement factor = 1.09003
y1 = 0.0025
sh1 = 0.008
ft1 = 787.50
fy1 = 656.25
su1 = 0.032

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00

lo/lou,min = lb/d = 1.00

su1 = 0.4*esu1_nominal ((5.5), TBDY) = 0.032

From table 5A.1, TBDY: esu1_nominal = 0.08,

For calculation of esu1_nominal and y1, sh1,ft1,fy1, it is considered
characteristic value fsy1 = fs/1.2, from table 5.1, TBDY.

y1, sh1,ft1,fy1, are also multiplied by Min(1,1.25*(lb/d)^ 2/3), from 10.3.5, ASCE 41-17.

with fs1 = fs = 656.25

with Es1 = Es = 200000.00

y2 = 0.0025
sh2 = 0.008
ft2 = 787.50
fy2 = 656.25
su2 = 0.032

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00

lo/lou,min = lb/lb,min = 1.00

su2 = 0.4*esu2_nominal ((5.5), TBDY) = 0.032

From table 5A.1, TBDY: esu2_nominal = 0.08,

For calculation of esu2_nominal and y2, sh2,ft2,fy2, it is considered
characteristic value fsy2 = fs/1.2, from table 5.1, TBDY.

y1, sh1,ft1,fy1, are also multiplied by Min(1,1.25*(lb/d)^ 2/3), from 10.3.5, ASCE 41-17.

with fs2 = fs = 656.25

with Es2 = Es = 200000.00

yv = 0.0025
shv = 0.008
ftv = 787.50
fyv = 656.25
suv = 0.032

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00

lo/lou,min = lb/d = 1.00

suv = 0.4*esuv_nominal ((5.5), TBDY) = 0.032

From table 5A.1, TBDY: esuv_nominal = 0.08,

considering characteristic value fsyv = fsv/1.2, from table 5.1, TBDY

For calculation of esuv_nominal and yv, shv,ftv,fyv, it is considered
characteristic value fsyv = fsv/1.2, from table 5.1, TBDY.

y1, sh1,ft1,fy1, are also multiplied by Min(1,1.25*(lb/d)^ 2/3), from 10.3.5, ASCE 41-17.

with fsv = fs = 656.25

with $E_{sv} = E_s = 200000.00$

$$1 = A_{sl,ten}/(b*d)*(f_{s1}/f_c) = 0.13484761$$

$$2 = A_{sl,com}/(b*d)*(f_{s2}/f_c) = 0.13484761$$

$$v = A_{sl,mid}/(b*d)*(f_{sv}/f_c) = 0.13484761$$

and confined core properties:

$$b = 340.00$$

$$d = 228.00$$

$$d' = 12.00$$

$$f_{cc} (5A.2, TBDY) = 26.16063$$

$$c_c (5A.5, TBDY) = 0.00290026$$

$$c = \text{confinement factor} = 1.09003$$

$$1 = A_{sl,ten}/(b*d)*(f_{s1}/f_c) = 0.17951849$$

$$2 = A_{sl,com}/(b*d)*(f_{s2}/f_c) = 0.17951849$$

$$v = A_{sl,mid}/(b*d)*(f_{sv}/f_c) = 0.17951849$$

Case/Assumption: Unconfined full section - Steel rupture

' does not satisfy Eq. (4.3)

--->

$v < v_{s,c}$ - RHS eq.(4.5) is satisfied

--->

$$s_u (4.9) = 0.20560388$$

$$M_u = M_{Rc} (4.14) = 1.2764E+008$$

$$u = s_u (4.1) = 0.00015613$$

Calculation of ratio l_b/d

Adequate Lap Length: $l_b/d \geq 1$

Calculation of M_{u2} -

Calculation of ultimate curvature u according to 4.1, Biskinis/Fardis 2013:

$$u = 0.00015613$$

$$M_u = 1.2764E+008$$

with full section properties:

$$b = 400.00$$

$$d = 258.00$$

$$d' = 42.00$$

$$v = 8.5224858E-005$$

$$N = 211.0849$$

$$f_c = 24.00$$

$$c_c (5A.5, TBDY) = 0.002$$

$$\text{Final value of } c_u: c_u^* = \text{shear_factor} * \text{Max}(c_u, c_c) = 0.00773686$$

The Shear_factor is considered equal to 1 (pure moment strength)

$$\text{From (5.4b), TBDY: } c_u = 0.00773686$$

$$w_e (5.4c) = 0.01121936$$

$$a_{se} ((5.4d), TBDY) = 0.15672608$$

$$b_o = 240.00$$

$$h_o = 340.00$$

$$b_{i2} = 346400.00$$

$$p_{sh,min} = \text{Min}(p_{sh,x}, p_{sh,y}) = 0.00261799$$

$$p_{sh,x} (5.4d) = 0.00349066$$

$$A_{sh} = A_{stir} * n_s = 78.53982$$

$$\text{No stirups, } n_s = 2.00$$

$$b_k = 300.00$$

$$p_{sh,y} (5.4d) = 0.00261799$$

$$A_{sh} = A_{stir} * n_s = 78.53982$$

$$\text{No stirups, } n_s = 2.00$$

$$b_k = 400.00$$

$$s = 150.00$$

$$fy_{we} = 656.25$$

$$f_{ce} = 24.00$$

From (5A.5), TBDY, TBDY: $cc = 0.00290026$

$$c = \text{confinement factor} = 1.09003$$

$$y_1 = 0.0025$$

$$sh_1 = 0.008$$

$$ft_1 = 787.50$$

$$fy_1 = 656.25$$

$$su_1 = 0.032$$

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00

$$lo/lou, \min = lb/ld = 1.00$$

$$su_1 = 0.4 * esu_{1_nominal} ((5.5), TBDY) = 0.032$$

From table 5A.1, TBDY: $esu_{1_nominal} = 0.08$,

For calculation of $esu_{1_nominal}$ and y_1, sh_1, ft_1, fy_1 , it is considered
characteristic value $fsy_1 = fs_1/1.2$, from table 5.1, TBDY.

y_1, sh_1, ft_1, fy_1 , are also multiplied by $\text{Min}(1, 1.25 * (lb/ld)^{2/3})$, from 10.3.5, ASCE 41-17.

$$\text{with } fs_1 = fs = 656.25$$

$$\text{with } Es_1 = Es = 200000.00$$

$$y_2 = 0.0025$$

$$sh_2 = 0.008$$

$$ft_2 = 787.50$$

$$fy_2 = 656.25$$

$$su_2 = 0.032$$

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00

$$lo/lou, \min = lb/lb, \min = 1.00$$

$$su_2 = 0.4 * esu_{2_nominal} ((5.5), TBDY) = 0.032$$

From table 5A.1, TBDY: $esu_{2_nominal} = 0.08$,

For calculation of $esu_{2_nominal}$ and y_2, sh_2, ft_2, fy_2 , it is considered
characteristic value $fsy_2 = fs_2/1.2$, from table 5.1, TBDY.

y_1, sh_1, ft_1, fy_1 , are also multiplied by $\text{Min}(1, 1.25 * (lb/ld)^{2/3})$, from 10.3.5, ASCE 41-17.

$$\text{with } fs_2 = fs = 656.25$$

$$\text{with } Es_2 = Es = 200000.00$$

$$y_v = 0.0025$$

$$sh_v = 0.008$$

$$ft_v = 787.50$$

$$fy_v = 656.25$$

$$su_v = 0.032$$

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00

$$lo/lou, \min = lb/ld = 1.00$$

$$su_v = 0.4 * esu_{v_nominal} ((5.5), TBDY) = 0.032$$

From table 5A.1, TBDY: $esu_{v_nominal} = 0.08$,

considering characteristic value $fsy_v = fs_v/1.2$, from table 5.1, TBDY
For calculation of $esu_{v_nominal}$ and y_v, sh_v, ft_v, fy_v , it is considered
characteristic value $fsy_v = fs_v/1.2$, from table 5.1, TBDY.

y_1, sh_1, ft_1, fy_1 , are also multiplied by $\text{Min}(1, 1.25 * (lb/ld)^{2/3})$, from 10.3.5, ASCE 41-17.

$$\text{with } fs_v = fs = 656.25$$

$$\text{with } Es_v = Es = 200000.00$$

$$1 = Asl, \text{ten} / (b * d) * (fs_1 / fc) = 0.13484761$$

$$2 = Asl, \text{com} / (b * d) * (fs_2 / fc) = 0.13484761$$

$$v = Asl, \text{mid} / (b * d) * (fs_v / fc) = 0.13484761$$

and confined core properties:

$$b = 340.00$$

$$d = 228.00$$

$$d' = 12.00$$

$$fcc (5A.2, TBDY) = 26.16063$$

$$cc (5A.5, TBDY) = 0.00290026$$

$$c = \text{confinement factor} = 1.09003$$

$$1 = Asl, \text{ten} / (b * d) * (fs_1 / fc) = 0.17951849$$

$$2 = Asl, \text{com} / (b * d) * (fs_2 / fc) = 0.17951849$$

$$v = Asl, \text{mid} / (b * d) * (fs_v / fc) = 0.17951849$$

Case/Assumption: Unconfinedsd full section - Steel rupture

' does not satisfy Eq. (4.3)

---->

$v < v_{s,c}$ - RHS eq.(4.5) is satisfied

---->

μ_u (4.9) = 0.20560388

$M_u = M_{Rc}$ (4.14) = 1.2764E+008

$u = \mu_u$ (4.1) = 0.00015613

Calculation of ratio l_b/d

Adequate Lap Length: $l_b/d \geq 1$

Calculation of Shear Strength $V_r = \text{Min}(V_{r1}, V_{r2}) = 174208.493$

Calculation of Shear Strength at edge 1, $V_{r1} = 174208.493$

$V_{r1} = V_n$ ((22.5.1.1), ACI 318-14)

NOTE: In expression (22.5.1.1) ' V_w ' is replaced by ' $V_w + f \cdot V_f$ '
where V_f is the contribution of FRPs (11.3), ACI 440).

From Table (22.5.5.1), ACI 318-14: $V_c = 75248.325$

= 1 (normal-weight concrete)

$f_c' = 24.00$, but $f_c'^{0.5} \leq 8.3$ MPa (22.5.3.1, ACI 318-14)

$\rho_w = A_s/(b_w \cdot d) = 0.00628319$

A_s (tension reinf.) = 603.1858

$b_w = 400.00$

$d = 240.00$

$V_u \cdot d / M_u < 1 = 0.00$

$M_u = 7.6252677E-012$

$V_u = 3.6870970E-015$

From (11.5.4.8), ACI 318-14: $V_s = 98960.169$

$A_v = 157079.633$

$f_y = 525.00$

$s = 150.00$

V_s has been multiplied by $2(1-s/d)$ ($s > d/2$, according to ASCE 41-17,10.3.4)

$2(1-s/d) = 0.75$

V_f ((11-3)-(11.4), ACI 440) = 0.00

From (11-11), ACI 440: $V_s + V_f \leq 312423.44$

Calculation of Shear Strength at edge 2, $V_{r2} = 174208.493$

$V_{r2} = V_n$ ((22.5.1.1), ACI 318-14)

NOTE: In expression (22.5.1.1) ' V_w ' is replaced by ' $V_w + f \cdot V_f$ '
where V_f is the contribution of FRPs (11.3), ACI 440).

From Table (22.5.5.1), ACI 318-14: $V_c = 75248.325$

= 1 (normal-weight concrete)

$f_c' = 24.00$, but $f_c'^{0.5} \leq 8.3$ MPa (22.5.3.1, ACI 318-14)

$\rho_w = A_s/(b_w \cdot d) = 0.00628319$

A_s (tension reinf.) = 603.1858

$b_w = 400.00$

$d = 240.00$

$V_u \cdot d / M_u < 1 = 0.00$

$M_u = 8.0393416E-013$

$V_u = 3.6870970E-015$

From (11.5.4.8), ACI 318-14: $V_s = 98960.169$

$A_v = 157079.633$

$f_y = 525.00$

$s = 150.00$

V_s has been multiplied by $2(1-s/d)$ ($s > d/2$, according to ASCE 41-17,10.3.4)

$2(1-s/d) = 0.75$

V_f ((11-3)-(11.4), ACI 440) = 0.00

From (11-11), ACI 440: $V_s + V_f \leq 312423.44$

End Of Calculation of Shear Capacity ratio for element: beam B1 of floor 1
At local axis: 2

Start Of Calculation of Chord Rotation Capacity for element: beam B1 of floor 1
At local axis: 3
Integration Section: (a)
Section Type: rcars

Constant Properties

Knowledge Factor, $\gamma = 1.00$
Chord Rotation is generally considered as Deformation-Controlled Action according to Table C7-1, ASCE 41-17.
Mean strengths are used for Deformation-Controlled Actions according to 7.5.1.3, ASCE 41-17
Consequently:
Existing material of Primary Member: Concrete Strength, $f_c = f_{cm} = 24.00$
Existing material of Primary Member: Steel Strength, $f_s = f_{sm} = 525.00$
Concrete Elasticity, $E_c = 23025.204$
Steel Elasticity, $E_s = 200000.00$
Section Height, $H = 400.00$
Section Width, $W = 300.00$
Cover Thickness, $c = 25.00$
Element Length, $L = 1850.00$
Primary Member
Smooth Bars
Ductile Steel
With Detailing for Earthquake Resistance (including stirrups closed at 135°)
Longitudinal Bars With Ends Lapped Starting at the End Sections
Adequate Lap Length ($l_b/d >= 1$)
No FRP Wrapping

Stepwise Properties

Bending Moment, $M = -1.1664849E-011$
Shear Force, $V_2 = 3.0430585E-014$
Shear Force, $V_3 = -3205.137$
Axial Force, $F = -560.8745$
Longitudinal Reinforcement Area Distribution (in 2 divisions)
-Tension: $A_{sl} = 603.1858$
-Compression: $A_{sc} = 923.6282$
Longitudinal Reinforcement Area Distribution (in 3 divisions)
-Tension: $A_{sl,ten} = 508.938$
-Compression: $A_{sl,com} = 508.938$
-Middle: $A_{sl,mid} = 508.938$
Mean Diameter of Tension Reinforcement, $D_bL = 14.66667$

Existing component: From table 7-7, ASCE 41_17: Final chord rotation Capacity $u_{,R} = \gamma \cdot u = 0.00904335$
 $u = \gamma \cdot u_{,p} = 0.00904335$

- Calculation of γ -

$\gamma = (M_y \cdot L_s / 3) / E_{eff} = 0.00404335$ ((4.29), Biskinis Phd)
 $M_y = 8.1525E+007$
 $L_s = M/V$ (with $L_s > 0.1 \cdot L$ and $L_s < 2 \cdot L$) = 925.00
From table 10.5, ASCE 41_17: $E_{eff} = 0.3 \cdot E_c \cdot I_g = 6.2168E+012$

Calculation of Yielding Moment M_y

Calculation of ρ_y and M_y according to Annex 7 -

$y = \text{Min}(y_{\text{ten}}, y_{\text{com}})$
 $y_{\text{ten}} = 1.4111768\text{E-}005$
with $f_y = 525.00$
 $d = 258.00$
 $y = 0.27901178$
 $A = 0.01480506$
 $B = 0.00861193$
with $p_t = 0.00493157$
 $p_c = 0.00493157$
 $p_v = 0.00493157$
 $N = 560.8745$
 $b = 400.00$
 $\rho = 0.1627907$
 $y_{\text{comp}} = 2.6070636\text{E-}005$
with $f_c = 24.00$
 $E_c = 23025.204$
 $y = 0.2789388$
 $A = 0.01478023$
 $B = 0.00860158$
with $E_s = 200000.00$

Calculation of ratio I_b/I_d

Adequate Lap Length: $I_b/I_d \geq 1$

- Calculation of ρ_p -

From table 10-7: $\rho_p = 0.005$

with:

- Condition i occurred

Beam controlled by flexure: $V_p/V_o \leq 1$

shear control ratio $V_p/V_o = 0.79211753$

- Transverse Reinforcement: NC

- Stirrup Spacing $> d/3$

- Low ductility demand, $\rho_p / y < 2$ (table 10-6, ASCE 41-17)

$= -2.5453052\text{E-}021$

- Stirrup Spacing $> d/2$

$d = 258.00$

$s = 150.00$

- Strength provided by hoops $V_s < 3/4$ *design Shear

$V_s = 131946.891$, already given in calculation of shear control ratio

design Shear = $3.0430585\text{E-}014$

- ($\rho_p - \rho_p'$)/ $\rho_{\text{bal}} = -0.17627139$

$= A_{s1}/(b_w*d) = 0.00584482$

Tension Reinf Area: $A_{s1} = 603.1858$

$\rho_p' = A_{s2}/(b_w*d) = 0.00894989$

Compression Reinf Area: $A_{s2} = 923.6282$

From (B-1), ACI 318-11: $\rho_{\text{bal}} = 0.01761524$

$f_c = 24.00$

$f_y = 525.00$

From 10.2.7.3, ACI 318-11: $\rho_p = 0.85$

From fig R10.3.3, ACI 318-11 (Ence 454, too): $87000/(87000 + f_y) = c_b/d_t = 0.003/(0.003 + y) = 0.53333333$

$y = 0.002625$

- $V/(b_w*d*f_c^{0.5}) = 7.2485011\text{E-}019$, NOTE: units in lb & in

$b_w = 400.00$

End Of Calculation of Chord Rotation Capacity for element: beam B1 of floor 1

At local axis: 3

Integration Section: (a)

Calculation No. 5

beam B1, Floor 1



Limit State: Operational Level (data interpolation between analysis steps 1 and 2)

Analysis: Uniform +X

Check: Shear capacity VRd

Edge: End

Local Axis: (2)



Start Of Calculation of Shear Capacity for element: beam B1 of floor 1

At local axis: 2

Integration Section: (b)

Section Type: rcars

Constant Properties

Knowledge Factor, $\gamma = 1.00$

Member Shear Force is generally considered as Force-Controlled Action according to Table C7-1, ASCE 41-17.

Lower-bound strengths are used for Force-Controlled Actions according to 7.5.1.3, ASCE 41-17

Consequently:

Existing material of Primary Member: Concrete Strength, $f_c = f_{c_lower_bound} = 16.00$

Existing material of Primary Member: Steel Strength, $f_s = f_{s_lower_bound} = 420.00$

Concrete Elasticity, $E_c = 23025.204$

Steel Elasticity, $E_s = 200000.00$

Section Height, $H = 400.00$

Section Width, $W = 300.00$

Cover Thickness, $c = 25.00$

Element Length, $L = 1850.00$

Primary Member

Smooth Bars

Ductile Steel

With Detailing for Earthquake Resistance (including stirrups closed at 135°)

Longitudinal Bars With Ends Lapped Starting at the End Sections

Adequate Lap Length ($l_o/l_{o,min} = l_b/d \geq 1$)

No FRP Wrapping

Stepwise Properties

EDGE -A-

Bending Moment, $M_a = -1.1664849E-011$

Shear Force, $V_a = 3.0430585E-014$

EDGE -B-

Bending Moment, $M_b = 6.7903689E-011$

Shear Force, $V_b = -3.0430585E-014$

BOTH EDGES

Axial Force, $F = -560.8745$

Longitudinal Reinforcement Area Distribution (in 2 divisions)

-Tension: $A_{st} = 615.7522$

-Compression: $A_{sc} = 911.0619$

Longitudinal Reinforcement Area Distribution (in 3 divisions)

-Tension: $A_{st,ten} = 508.938$

-Compression: $A_{sc,com} = 508.938$

-Middle: $A_{st,mid} = 508.938$

Mean Diameter of Tension Reinforcement, $D_{bL,ten} = 14.66667$

Existing component: From table 7-7, ASCE 41_17: Final Shear Capacity $V_R = V_n = 140608.135$
 V_n ((22.5.1.1), ACI 318-14) = 140608.135

NOTE: In expression (22.5.1.1) ' V_w ' is replaced by ' $V_w + V_f$ '
where V_f is the contribution of FRPs (11.3), ACI 440).

From Table (22.5.5.1), ACI 318-14: $V_c = 61440.00$
= 1 (normal-weight concrete)

$f_c' = 16.00$, but $f_c'^{0.5} \leq 8.3$ MPa (22.5.3.1, ACI 318-14)

$\rho_w = A_s/(b_w \cdot d) = 0.00641409$

A_s (tension reinf.) = 615.7522

$b_w = 400.00$

$d = 240.00$

$V_u \cdot d / M_u < 1 = 0.00$

$M_u = 6.7903689E-011$

$V_u = 3.0430585E-014$

From (11.5.4.8), ACI 318-14: $V_s = 79168.135$

$A_v = 157079.633$

$f_y = 420.00$

$s = 150.00$

V_s has been multiplied by $2(1-s/d)$ ($s > d/2$, according to ASCE 41-17,10.3.4)

$2(1-s/d) = 0.75$

V_f ((11-3)-(11.4), ACI 440) = 0.00

From (11-11), ACI 440: $V_s + V_f \leq 255092.67$

End Of Calculation of Shear Capacity for element: beam B1 of floor 1

At local axis: 2

Integration Section: (b)

Calculation No. 6

beam B1, Floor 1



Limit State: Operational Level (data interpolation between analysis steps 1 and 2)

Analysis: Uniform +X

Check: Chord rotation capacity (θ_r)

Edge: End

Local Axis: (2)



Start Of Calculation of Shear Capacity ratio for element: beam B1 of floor 1

At Shear local axis: 3

(Bending local axis: 2)

Section Type: rcars

Constant Properties

Knowledge Factor, $\gamma = 1.00$

Mean strength values are used for both shear and moment calculations.

Consequently:

Existing material of Primary Member: Concrete Strength, $f_c = f_{cm} = 24.00$

Existing material of Primary Member: Steel Strength, $f_s = f_{sm} = 525.00$

Concrete Elasticity, $E_c = 23025.204$

Steel Elasticity, $E_s = 200000.00$

#####

Note: Especially for the calculation of moment strengths,

the above steel re-bar strengths are multiplied by 1.25 according to R18.6.5, ACI 318-14

Existing material: Steel Strength, $f_s = 1.25 \cdot f_{sm} = 656.25$

#####

Section Height, $H = 400.00$

Section Width, $W = 300.00$

Cover Thickness, $c = 25.00$

Mean Confinement Factor overall section = 1.09003

Element Length, $L = 1850.00$

Primary Member

Smooth Bars

Ductile Steel

With Detailing for Earthquake Resistance (including stirrups closed at 135°)

Longitudinal Bars With Ends Lapped Starting at the End Sections

Adequate Lap Length ($l_o/l_{o,u,min} \geq 1$)

No FRP Wrapping

Stepwise Properties

At local axis: 3

EDGE -A-

Shear Force, $V_a = 2740.265$

EDGE -B-

Shear Force, $V_b = 2740.264$
BOTH EDGES
Axial Force, $F = -211.0849$
Longitudinal Reinforcement Area Distribution (in 2 divisions)
-Tension: $As_t = 603.1858$
-Compression: $As_c = 923.6282$
Longitudinal Reinforcement Area Distribution (in 3 divisions)
-Tension: $As_{t,ten} = 603.1858$
-Compression: $As_{c,com} = 615.7522$
-Middle: $As_{c,mid} = 307.8761$

Calculation of Shear Capacity ratio, $V_e/V_r = 0.78793176$
Member Controlled by Flexure ($V_e/V_r < 1$)
Calculation of Shear Demand from fig. R18.6.5, ACI 318-14 $V_e = (M_{pr1} + M_{pr2})/l_n \pm w_u \cdot l_n/2 = 205990.317$
with
 $M_{pr1} = \text{Max}(Mu_{1+}, Mu_{1-}) = 1.8802E+008$
 $Mu_{1+} = 1.8495E+008$, is the ultimate moment strength at the edge 1 of the member in the actual moment direction
which is defined for the static loading combination
 $Mu_{1-} = 1.8802E+008$, is the ultimate moment strength at the edge 1 of the member in the opposite moment
direction which is defined for the static loading combination
 $M_{pr2} = \text{Max}(Mu_{2+}, Mu_{2-}) = 1.8800E+008$
 $Mu_{2+} = 1.8498E+008$, is the ultimate moment strength at the edge 2 of the member in the actual moment direction
which is defined for the the static loading combination
 $Mu_{2-} = 1.8800E+008$, is the ultimate moment strength at the edge 2 of the member in the opposite moment
direction which is defined for the the static loading combination
and
 $\pm w_u \cdot l_n = (|V_1| + |V_2|)/2$
with
 $V_1 = 2740.265$, is the shear force acting at edge 1 for the the static loading combination
 $V_2 = 2740.264$, is the shear force acting at edge 2 for the the static loading combination

Calculation of Mu_{1+}

Calculation of ultimate curvature ϕ_u according to 4.1, Biskinis/Fardis 2013:
 $\phi_u = 0.0001071$
 $Mu = 1.8495E+008$

with full section properties:

$b = 300.00$
 $d = 357.00$
 $d' = 42.00$
 $v = 8.2121432E-005$
 $N = 211.0849$
 $f_c = 24.00$

ϕ_c (5A.5, TBDY) = 0.002

Final value of ϕ_u : $\phi_u^* = \text{shear_factor} \cdot \text{Max}(\phi_u, \phi_c) = 0.00773686$

The Shear_factor is considered equal to 1 (pure moment strength)

From (5.4b), TBDY: $\phi_u = 0.00773686$

w_e (5.4c) = 0.01121936

a_{se} ((5.4d), TBDY) = 0.15672608

$b_o = 240.00$

$h_o = 340.00$

$bi_2 = 346400.00$

$p_{sh,min} = \text{Min}(p_{sh,x}, p_{sh,y}) = 0.00261799$

 $p_{sh,x}$ (5.4d) = 0.00349066

$A_{sh} = A_{stir} \cdot n_s = 78.53982$

No stirups, $n_s = 2.00$

$b_k = 300.00$

 $p_{sh,y}$ (5.4d) = 0.00261799

Ash = Astir*ns = 78.53982
No stirrups, ns = 2.00
bk = 400.00

s = 150.00
fywe = 656.25
fce = 24.00

From ((5.A.5), TBDY), TBDY: cc = 0.00290026
c = confinement factor = 1.09003

y1 = 0.0025
sh1 = 0.008
ft1 = 787.50
fy1 = 656.25
su1 = 0.032

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00

lo/lou,min = lb/lb,min = 1.00

su1 = 0.4*esu1_nominal ((5.5), TBDY) = 0.032

From table 5A.1, TBDY: esu1_nominal = 0.08,

For calculation of esu1_nominal and y1, sh1,ft1,fy1, it is considered
characteristic value fsy1 = fs1/1.2, from table 5.1, TBDY.

y1, sh1,ft1,fy1, are also multiplied by $\text{Min}(1, 1.25 \cdot (lb/lb)^{2/3})$, from 10.3.5, ASCE 41-17.

with fs1 = fs = 656.25

with Es1 = Es = 200000.00

y2 = 0.0025
sh2 = 0.008
ft2 = 787.50
fy2 = 656.25
su2 = 0.032

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00

lo/lou,min = lb/lb,min = 1.00

su2 = 0.4*esu2_nominal ((5.5), TBDY) = 0.032

From table 5A.1, TBDY: esu2_nominal = 0.08,

For calculation of esu2_nominal and y2, sh2,ft2,fy2, it is considered
characteristic value fsy2 = fs2/1.2, from table 5.1, TBDY.

y1, sh1,ft1,fy1, are also multiplied by $\text{Min}(1, 1.25 \cdot (lb/lb)^{2/3})$, from 10.3.5, ASCE 41-17.

with fs2 = fs = 656.25

with Es2 = Es = 200000.00

yv = 0.0025
shv = 0.008
ftv = 787.50
fyv = 656.25
suv = 0.032

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00

lo/lou,min = lb/lb,min = 1.00

suv = 0.4*esuv_nominal ((5.5), TBDY) = 0.032

From table 5A.1, TBDY: esuv_nominal = 0.08,

considering characteristic value fsyv = fsv/1.2, from table 5.1, TBDY
For calculation of esuv_nominal and yv, shv,ftv,fyv, it is considered

characteristic value fsyv = fsv/1.2, from table 5.1, TBDY.

y1, sh1,ft1,fy1, are also multiplied by $\text{Min}(1, 1.25 \cdot (lb/lb)^{2/3})$, from 10.3.5, ASCE 41-17.

with fsv = fs = 656.25

with Esv = Es = 200000.00

1 = Asl,ten/(b*d)*(fs1/fc) = 0.15399964

2 = Asl,com/(b*d)*(fs2/fc) = 0.15720797

v = Asl,mid/(b*d)*(fsv/fc) = 0.07860398

and confined core properties:

b = 240.00
d = 327.00
d' = 12.00

fcc (5A.2, TBDY) = 26.16063

cc (5A.5, TBDY) = 0.00290026

c = confinement factor = 1.09003

1 = $Asl,ten/(b*d)*(fs1/fc) = 0.21016006$

2 = $Asl,com/(b*d)*(fs2/fc) = 0.21453839$

v = $Asl,mid/(b*d)*(fsv/fc) = 0.1072692$

Case/Assumption: Unconfined full section - Steel rupture

' satisfies Eq. (4.3)

v < vs,y2 - LHS eq.(4.5) is satisfied

su (4.9) = 0.1630814

Mu = MRc (4.14) = 1.8495E+008

u = su (4.1) = 0.0001071

Calculation of ratio lb/l_d

Adequate Lap Length: lb/l_d >= 1

Calculation of Mu1-

Calculation of ultimate curvature u according to 4.1, Biskinis/Fardis 2013:

u = 0.00010722

Mu = 1.8802E+008

with full section properties:

b = 300.00

d = 358.00

d' = 43.00

v = 8.1892042E-005

N = 211.0849

fc = 24.00

co (5A.5, TBDY) = 0.002

Final value of cu: $cu^* = shear_factor * Max(cu, cc) = 0.00773686$

The Shear_factor is considered equal to 1 (pure moment strength)

From (5.4b), TBDY: cu = 0.00773686

we (5.4c) = 0.01121936

ase ((5.4d), TBDY) = 0.15672608

bo = 240.00

ho = 340.00

bi2 = 346400.00

psh,min = Min(psh,x , psh,y) = 0.00261799

psh,x (5.4d) = 0.00349066

Ash = Astir*ns = 78.53982

No stirups, ns = 2.00

bk = 300.00

psh,y (5.4d) = 0.00261799

Ash = Astir*ns = 78.53982

No stirups, ns = 2.00

bk = 400.00

s = 150.00

fywe = 656.25

fce = 24.00

From ((5.A5), TBDY), TBDY: cc = 0.00290026

c = confinement factor = 1.09003

y1 = 0.0025

sh1 = 0.008

ft1 = 787.50

fy1 = 656.25

su1 = 0.032

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor

and also multiplied by the shear_factor according to 15.7.1.4, with

Shear_factor = 1.00

lo/lou,min = lb/d = 1.00

su1 = 0.4*esu1_nominal ((5.5), TBDY) = 0.032

From table 5A.1, TBDY: esu1_nominal = 0.08,

For calculation of esu1_nominal and y1, sh1,ft1,fy1, it is considered characteristic value fsy1 = fs1/1.2, from table 5.1, TBDY.

y1, sh1,ft1,fy1, are also multiplied by Min(1,1.25*(lb/d)^ 2/3), from 10.3.5, ASCE 41-17.

with fs1 = fs = 656.25

with Es1 = Es = 200000.00

y2 = 0.0025

sh2 = 0.008

ft2 = 787.50

fy2 = 656.25

su2 = 0.032

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor

and also multiplied by the shear_factor according to 15.7.1.4, with

Shear_factor = 1.00

lo/lou,min = lb/lb,min = 1.00

su2 = 0.4*esu2_nominal ((5.5), TBDY) = 0.032

From table 5A.1, TBDY: esu2_nominal = 0.08,

For calculation of esu2_nominal and y2, sh2,ft2,fy2, it is considered characteristic value fsy2 = fs2/1.2, from table 5.1, TBDY.

y1, sh1,ft1,fy1, are also multiplied by Min(1,1.25*(lb/d)^ 2/3), from 10.3.5, ASCE 41-17.

with fs2 = fs = 656.25

with Es2 = Es = 200000.00

yv = 0.0025

shv = 0.008

ftv = 787.50

fyv = 656.25

suv = 0.032

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor

and also multiplied by the shear_factor according to 15.7.1.4, with

Shear_factor = 1.00

lo/lou,min = lb/d = 1.00

suv = 0.4*esuv_nominal ((5.5), TBDY) = 0.032

From table 5A.1, TBDY: esuv_nominal = 0.08,

considering characteristic value fsyv = fsv/1.2, from table 5.1, TBDY

For calculation of esuv_nominal and yv, shv,ftv,fyv, it is considered characteristic value fsyv = fsv/1.2, from table 5.1, TBDY.

y1, sh1,ft1,fy1, are also multiplied by Min(1,1.25*(lb/d)^ 2/3), from 10.3.5, ASCE 41-17.

with fsv = fs = 656.25

with Esv = Es = 200000.00

1 = Asl,ten/(b*d)*(fs1/fc) = 0.15676884

2 = Asl,com/(b*d)*(fs2/fc) = 0.15356947

v = Asl,mid/(b*d)*(fsv/fc) = 0.07838442

and confined core properties:

b = 240.00

d = 328.00

d' = 13.00

fcc (5A.2, TBDY) = 26.16063

cc (5A.5, TBDY) = 0.00290026

c = confinement factor = 1.09003

1 = Asl,ten/(b*d)*(fs1/fc) = 0.21388431

2 = Asl,com/(b*d)*(fs2/fc) = 0.20951933

v = Asl,mid/(b*d)*(fsv/fc) = 0.10694216

Case/Assumption: Unconfined full section - Steel rupture

' satisfies Eq. (4.3)

--->

v < vs,y2 - LHS eq.(4.5) is satisfied

--->

su (4.9) = 0.16631328

Mu = MRc (4.14) = 1.8802E+008

u = su (4.1) = 0.00010722

Calculation of ratio lb/d

Adequate Lap Length: $l_b/d \geq 1$

Calculation of μ_{2+}

Calculation of ultimate curvature μ according to 4.1, Biskinis/Fardis 2013:

$$u = 0.00010701$$

$$\mu = 1.8498E+008$$

with full section properties:

$$b = 300.00$$

$$d = 358.00$$

$$d' = 43.00$$

$$v = 8.1892042E-005$$

$$N = 211.0849$$

$$f_c = 24.00$$

$$c_o \text{ (5A.5, TBDY)} = 0.002$$

$$\text{Final value of } c_u: c_u^* = \text{shear_factor} * \text{Max}(c_u, c_c) = 0.00773686$$

The Shear_factor is considered equal to 1 (pure moment strength)

$$\text{From (5.4b), TBDY: } c_u = 0.00773686$$

$$w_e \text{ (5.4c)} = 0.01121936$$

$$a_{se} \text{ ((5.4d), TBDY)} = 0.15672608$$

$$b_o = 240.00$$

$$h_o = 340.00$$

$$b_{i2} = 346400.00$$

$$p_{sh,min} = \text{Min}(p_{sh,x}, p_{sh,y}) = 0.00261799$$

$$p_{sh,x} \text{ (5.4d)} = 0.00349066$$

$$A_{sh} = A_{stir} * n_s = 78.53982$$

$$\text{No stirups, } n_s = 2.00$$

$$b_k = 300.00$$

$$p_{sh,y} \text{ (5.4d)} = 0.00261799$$

$$A_{sh} = A_{stir} * n_s = 78.53982$$

$$\text{No stirups, } n_s = 2.00$$

$$b_k = 400.00$$

$$s = 150.00$$

$$f_{ywe} = 656.25$$

$$f_{ce} = 24.00$$

$$\text{From ((5.A5), TBDY), TBDY: } c_c = 0.00290026$$

$$c = \text{confinement factor} = 1.09003$$

$$y_1 = 0.0025$$

$$sh_1 = 0.008$$

$$ft_1 = 787.50$$

$$fy_1 = 656.25$$

$$su_1 = 0.032$$

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor and also multiplied by the shear_factor according to 15.7.1.4, with Shear_factor = 1.00

$$l_o/l_{ou,min} = l_b/d = 1.00$$

$$su_1 = 0.4 * esu_{1,nominal} \text{ ((5.5), TBDY)} = 0.032$$

$$\text{From table 5A.1, TBDY: } esu_{1,nominal} = 0.08,$$

For calculation of $esu_{1,nominal}$ and y_1, sh_1, ft_1, fy_1 , it is considered characteristic value $fsy_1 = fs_1/1.2$, from table 5.1, TBDY.

$$y_1, sh_1, ft_1, fy_1, \text{ are also multiplied by } \text{Min}(1, 1.25 * (l_b/d)^{2/3}), \text{ from 10.3.5, ASCE 41-17.}$$

$$\text{with } fs_1 = fs = 656.25$$

$$\text{with } Es_1 = Es = 200000.00$$

$$y_2 = 0.0025$$

$$sh_2 = 0.008$$

$$ft_2 = 787.50$$

$$fy_2 = 656.25$$

$$su_2 = 0.032$$

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00

$l_o/l_{o,min} = l_b/l_{b,min} = 1.00$

$su_2 = 0.4 * esu_{2,nominal} ((5.5), TBDY) = 0.032$

From table 5A.1, TBDY: $esu_{2,nominal} = 0.08$,

For calculation of $esu_{2,nominal}$ and y_2, sh_2, ft_2, fy_2 , it is considered
characteristic value $fsy_2 = fs_2/1.2$, from table 5.1, TBDY.

y_1, sh_1, ft_1, fy_1 , are also multiplied by $Min(1, 1.25 * (l_b/l_d)^{2/3})$, from 10.3.5, ASCE 41-17.

with $fs_2 = fs = 656.25$

with $Es_2 = Es = 200000.00$

$y_v = 0.0025$

$sh_v = 0.008$

$ft_v = 787.50$

$fy_v = 656.25$

$suv = 0.032$

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00

$l_o/l_{o,min} = l_b/l_d = 1.00$

$suv = 0.4 * esuv_{nominal} ((5.5), TBDY) = 0.032$

From table 5A.1, TBDY: $esuv_{nominal} = 0.08$,

considering characteristic value $fsyv = fsv/1.2$, from table 5.1, TBDY

For calculation of $esuv_{nominal}$ and y_v, sh_v, ft_v, fy_v , it is considered
characteristic value $fsyv = fsv/1.2$, from table 5.1, TBDY.

y_1, sh_1, ft_1, fy_1 , are also multiplied by $Min(1, 1.25 * (l_b/l_d)^{2/3})$, from 10.3.5, ASCE 41-17.

with $fsv = fs = 656.25$

with $Es_v = Es = 200000.00$

$1 = A_{sl,ten}/(b*d) * (fs_1/f_c) = 0.15356947$

$2 = A_{sl,com}/(b*d) * (fs_2/f_c) = 0.15676884$

$v = A_{sl,mid}/(b*d) * (fsv/f_c) = 0.07838442$

and confined core properties:

$b = 240.00$

$d = 328.00$

$d' = 13.00$

$f_{cc} (5A.2, TBDY) = 26.16063$

$cc (5A.5, TBDY) = 0.00290026$

$c =$ confinement factor $= 1.09003$

$1 = A_{sl,ten}/(b*d) * (fs_1/f_c) = 0.20951933$

$2 = A_{sl,com}/(b*d) * (fs_2/f_c) = 0.21388431$

$v = A_{sl,mid}/(b*d) * (fsv/f_c) = 0.10694216$

Case/Assumption: Unconfined full section - Steel rupture

' satisfies Eq. (4.3)

--->

$v < v_{s,y2}$ - LHS eq.(4.5) is satisfied

--->

$su (4.9) = 0.16466458$

$Mu = MRc (4.14) = 1.8498E+008$

$u = su (4.1) = 0.00010701$

Calculation of ratio l_b/l_d

Adequate Lap Length: $l_b/l_d \geq 1$

Calculation of Mu_2 -

Calculation of ultimate curvature u according to 4.1, Biskinis/Fardis 2013:

$u = 0.00010732$

$Mu = 1.8800E+008$

with full section properties:

$b = 300.00$

d = 357.00
d' = 42.00
v = 8.2121432E-005
N = 211.0849
fc = 24.00
co (5A.5, TBDY) = 0.002
Final value of cu: $cu^* = \text{shear_factor} * \text{Max}(cu, cc) = 0.00773686$
The Shear_factor is considered equal to 1 (pure moment strength)
From (5.4b), TBDY: $cu = 0.00773686$
we (5.4c) = 0.01121936
ase ((5.4d), TBDY) = 0.15672608
bo = 240.00
ho = 340.00
bi2 = 346400.00
psh,min = $\text{Min}(psh,x, psh,y) = 0.00261799$

psh,x (5.4d) = 0.00349066
Ash = $\text{Astir} * ns = 78.53982$
No stirups, ns = 2.00
bk = 300.00

psh,y (5.4d) = 0.00261799
Ash = $\text{Astir} * ns = 78.53982$
No stirups, ns = 2.00
bk = 400.00

s = 150.00
fywe = 656.25
fce = 24.00
From ((5.A.5), TBDY), TBDY: $cc = 0.00290026$
c = confinement factor = 1.09003
y1 = 0.0025
sh1 = 0.008
ft1 = 787.50
fy1 = 656.25
su1 = 0.032

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00
 $lo/lou,min = lb/ld = 1.00$
 $su1 = 0.4 * esu1_nominal ((5.5), TBDY) = 0.032$
From table 5A.1, TBDY: $esu1_nominal = 0.08$,
For calculation of $esu1_nominal$ and $y1, sh1, ft1, fy1$, it is considered
characteristic value $fsy1 = fs1/1.2$, from table 5.1, TBDY.
 $y1, sh1, ft1, fy1$, are also multiplied by $\text{Min}(1, 1.25 * (lb/ld)^{2/3})$, from 10.3.5, ASCE 41-17.
with $fs1 = fs = 656.25$
with $Es1 = Es = 200000.00$

y2 = 0.0025
sh2 = 0.008
ft2 = 787.50
fy2 = 656.25
su2 = 0.032
using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00
 $lo/lou,min = lb/lb,min = 1.00$
 $su2 = 0.4 * esu2_nominal ((5.5), TBDY) = 0.032$
From table 5A.1, TBDY: $esu2_nominal = 0.08$,
For calculation of $esu2_nominal$ and $y2, sh2, ft2, fy2$, it is considered
characteristic value $fsy2 = fs2/1.2$, from table 5.1, TBDY.
 $y1, sh1, ft1, fy1$, are also multiplied by $\text{Min}(1, 1.25 * (lb/ld)^{2/3})$, from 10.3.5, ASCE 41-17.
with $fs2 = fs = 656.25$
with $Es2 = Es = 200000.00$

yv = 0.0025
shv = 0.008
ftv = 787.50
fyv = 656.25

suv = 0.032

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00

lo/lou,min = lb/d = 1.00

suv = 0.4*esuv_nominal ((5.5), TBDY) = 0.032

From table 5A.1, TBDY: esuv_nominal = 0.08,

considering characteristic value fsyv = fsv/1.2, from table 5.1, TBDY

For calculation of esuv_nominal and yv, shv,ftv,fyv, it is considered
characteristic value fsyv = fsv/1.2, from table 5.1, TBDY.

y1, sh1,ft1,fy1, are also multiplied by $\text{Min}(1, 1.25 \cdot (lb/d)^{2/3})$, from 10.3.5, ASCE 41-17.

with fsv = fs = 656.25

with Esv = Es = 200000.00

1 = Asl,ten/(b*d)*(fs1/fc) = 0.15720797

2 = Asl,com/(b*d)*(fs2/fc) = 0.15399964

v = Asl,mid/(b*d)*(fsv/fc) = 0.07860398

and confined core properties:

b = 240.00

d = 327.00

d' = 12.00

fcc (5A.2, TBDY) = 26.16063

cc (5A.5, TBDY) = 0.00290026

c = confinement factor = 1.09003

1 = Asl,ten/(b*d)*(fs1/fc) = 0.21453839

2 = Asl,com/(b*d)*(fs2/fc) = 0.21016006

v = Asl,mid/(b*d)*(fsv/fc) = 0.1072692

Case/Assumption: Unconfined full section - Steel rupture

' satisfies Eq. (4.3)

v < vs,y2 - LHS eq.(4.5) is satisfied

su (4.9) = 0.16474284

Mu = MRc (4.14) = 1.8800E+008

u = su (4.1) = 0.00010732

Calculation of ratio lb/d

Adequate Lap Length: lb/d >= 1

Calculation of Shear Strength Vr = Min(Vr1,Vr2) = 261431.672

Calculation of Shear Strength at edge 1, Vr1 = 261431.672

Vr1 = Vn ((22.5.1.1), ACI 318-14)

NOTE: In expression (22.5.1.1) 'Vw' is replaced by 'Vw+ f*Vf'
where Vf is the contribution of FRPs (11.3), ACI 440).

From Table (22.5.5.1), ACI 318-14: Vc = 85502.483

= 1 (normal-weight concrete)

fc' = 24.00, but $fc^{0.5} \leq 8.3$ MPa (22.5.3.1, ACI 318-14)

pw = As/(bw*d) = 0.00628319

As (tension reinf.) = 603.1858

bw = 300.00

d = 320.00

Vu*d/Mu < 1 = 1.00

Mu = 30114.962

Vu = 2740.265

From (11.5.4.8), ACI 318-14: Vs = 175929.189

Av = 157079.633

fy = 525.00

s = 150.00

Vs has been multiplied by 1 (s < d/2, according to ASCE 41-17,10.3.4)

Vf ((11-3)-(11.4), ACI 440) = 0.00

From (11-11), ACI 440: $V_s + V_f \leq 312423.44$

Calculation of Shear Strength at edge 2, $V_{r2} = 261431.672$
 $V_{r2} = V_n$ ((22.5.1.1), ACI 318-14)

NOTE: In expression (22.5.1.1) 'Vw' is replaced by 'Vw + f*Vf'
where Vf is the contribution of FRPs (11.3), ACI 440).

From Table (22.5.5.1), ACI 318-14: $V_c = 85502.483$
= 1 (normal-weight concrete)
 $f'_c = 24.00$, but $f'_c^{0.5} \leq 8.3$ MPa (22.5.3.1, ACI 318-14)
 $\rho_w = A_s / (b_w * d) = 0.00628319$
 A_s (tension reinf.) = 603.1858
 $b_w = 300.00$
 $d = 320.00$
 $V_u * d / M_u < 1 = 1.00$
 $M_u = 30115.665$
 $V_u = 2740.264$

From (11.5.4.8), ACI 318-14: $V_s = 175929.189$
 $A_v = 157079.633$
 $f_y = 525.00$
 $s = 150.00$
 V_s has been multiplied by 1 ($s < d/2$, according to ASCE 41-17,10.3.4)
 V_f ((11-3)-(11.4), ACI 440) = 0.00
From (11-11), ACI 440: $V_s + V_f \leq 312423.44$

End Of Calculation of Shear Capacity ratio for element: beam B1 of floor 1
At local axis: 3

Start Of Calculation of Shear Capacity ratio for element: beam B1 of floor 1
At Shear local axis: 2
(Bending local axis: 3)
Section Type: rcars

Constant Properties

Knowledge Factor, $\phi = 1.00$
Mean strength values are used for both shear and moment calculations.
Consequently:
Existing material of Primary Member: Concrete Strength, $f_c = f_{cm} = 24.00$
Existing material of Primary Member: Steel Strength, $f_s = f_{sm} = 525.00$
Concrete Elasticity, $E_c = 23025.204$
Steel Elasticity, $E_s = 200000.00$

Note: Especially for the calculation of moment strengths,
the above steel re-bar strengths are multiplied by 1.25 according to R18.6.5, ACI 318-14
Existing material: Steel Strength, $f_s = 1.25 * f_{sm} = 656.25$

Section Height, $H = 400.00$
Section Width, $W = 300.00$
Cover Thickness, $c = 25.00$
Mean Confinement Factor overall section = 1.09003
Element Length, $L = 1850.00$
Primary Member
Smooth Bars
Ductile Steel
With Detailing for Earthquake Resistance (including stirrups closed at 135°)
Longitudinal Bars With Ends Lapped Starting at the End Sections
Adequate Lap Length ($l_o / l_{ou, min} > 1$)
No FRP Wrapping

Stepwise Properties

At local axis: 2

EDGE -A-

Shear Force, $V_a = -3.6870970E-015$

EDGE -B-

Shear Force, $V_b = 3.6870970E-015$

BOTH EDGES

Axial Force, $F = -211.0849$

Longitudinal Reinforcement Area Distribution (in 2 divisions)

-Tension: $A_{sl,t} = 603.1858$

-Compression: $A_{sl,c} = 923.6282$

Longitudinal Reinforcement Area Distribution (in 3 divisions)

-Tension: $A_{sl,ten} = 508.938$

-Compression: $A_{sl,com} = 508.938$

-Middle: $A_{sl,mid} = 508.938$

Calculation of Shear Capacity ratio, $V_e/V_r = 0.79211753$

Member Controlled by Flexure ($V_e/V_r < 1$)

Calculation of Shear Demand from fig. R18.6.5, ACI 318-14 $V_e = (M_{pr1} + M_{pr2})/l_n \pm w_u \cdot l_n/2 = 137993.601$

with

$M_{pr1} = \text{Max}(M_{u1+}, M_{u1-}) = 1.2764E+008$

$M_{u1+} = 1.2764E+008$, is the ultimate moment strength at the edge 1 of the member in the actual moment direction which is defined for the static loading combination

$M_{u1-} = 1.2764E+008$, is the ultimate moment strength at the edge 1 of the member in the opposite moment direction which is defined for the static loading combination

$M_{pr2} = \text{Max}(M_{u2+}, M_{u2-}) = 1.2764E+008$

$M_{u2+} = 1.2764E+008$, is the ultimate moment strength at the edge 2 of the member in the actual moment direction which is defined for the the static loading combination

$M_{u2-} = 1.2764E+008$, is the ultimate moment strength at the edge 2 of the member in the opposite moment direction which is defined for the the static loading combination

and

$\pm w_u \cdot l_n = (|V_1| + |V_2|)/2$

with

$V_1 = -3.6870970E-015$, is the shear force acting at edge 1 for the the static loading combination

$V_2 = 3.6870970E-015$, is the shear force acting at edge 2 for the the static loading combination

Calculation of M_{u1+}

Calculation of ultimate curvature ϕ_u according to 4.1, Biskinis/Fardis 2013:

$\phi_u = 0.00015613$

$M_u = 1.2764E+008$

with full section properties:

$b = 400.00$

$d = 258.00$

$d' = 42.00$

$v = 8.5224858E-005$

$N = 211.0849$

$f_c = 24.00$

$\phi_{co} (5A.5, TBDY) = 0.002$

Final value of ϕ_{cu} : $\phi_{cu}^* = \text{shear_factor} \cdot \text{Max}(\phi_{cu}, \phi_{cc}) = 0.00773686$

The Shear_factor is considered equal to 1 (pure moment strength)

From (5.4b), TBDY: $\phi_{cu} = 0.00773686$

$w_e (5.4c) = 0.01121936$

$a_{se} ((5.4d), TBDY) = 0.15672608$

$b_o = 240.00$

$h_o = 340.00$

$b_{i2} = 346400.00$

$p_{sh,min} = \text{Min}(p_{sh,x}, p_{sh,y}) = 0.00261799$

$p_{sh,x} (5.4d) = 0.00349066$

$A_{sh} = A_{stir} \cdot n_s = 78.53982$

No stirrups, ns = 2.00
bk = 300.00

psh,y (5.4d) = 0.00261799
Ash = Astir*ns = 78.53982
No stirrups, ns = 2.00
bk = 400.00

s = 150.00
fywe = 656.25
fce = 24.00

From ((5.A5), TBDY), TBDY: cc = 0.00290026
c = confinement factor = 1.09003

y1 = 0.0025
sh1 = 0.008
ft1 = 787.50
fy1 = 656.25
su1 = 0.032

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00

lo/lou,min = lb/d = 1.00

su1 = 0.4*esu1_nominal ((5.5), TBDY) = 0.032

From table 5A.1, TBDY: esu1_nominal = 0.08,

For calculation of esu1_nominal and y1, sh1,ft1,fy1, it is considered
characteristic value fsy1 = fs1/1.2, from table 5.1, TBDY.

y1, sh1,ft1,fy1, are also multiplied by $\text{Min}(1, 1.25 \cdot (lb/d)^{2/3})$, from 10.3.5, ASCE 41-17.

with fs1 = fs = 656.25

with Es1 = Es = 200000.00

y2 = 0.0025
sh2 = 0.008
ft2 = 787.50
fy2 = 656.25
su2 = 0.032

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00

lo/lou,min = lb/lb,min = 1.00

su2 = 0.4*esu2_nominal ((5.5), TBDY) = 0.032

From table 5A.1, TBDY: esu2_nominal = 0.08,

For calculation of esu2_nominal and y2, sh2,ft2,fy2, it is considered
characteristic value fsy2 = fs2/1.2, from table 5.1, TBDY.

y1, sh1,ft1,fy1, are also multiplied by $\text{Min}(1, 1.25 \cdot (lb/d)^{2/3})$, from 10.3.5, ASCE 41-17.

with fs2 = fs = 656.25

with Es2 = Es = 200000.00

yv = 0.0025
shv = 0.008
ftv = 787.50
fyv = 656.25
suv = 0.032

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00

lo/lou,min = lb/d = 1.00

suv = 0.4*esuv_nominal ((5.5), TBDY) = 0.032

From table 5A.1, TBDY: esuv_nominal = 0.08,

considering characteristic value fsyv = fsv/1.2, from table 5.1, TBDY
For calculation of esuv_nominal and yv, shv,ftv,fyv, it is considered
characteristic value fsyv = fsv/1.2, from table 5.1, TBDY.

y1, sh1,ft1,fy1, are also multiplied by $\text{Min}(1, 1.25 \cdot (lb/d)^{2/3})$, from 10.3.5, ASCE 41-17.

with fsv = fs = 656.25

with Esv = Es = 200000.00

1 = Asl,ten/(b*d)*(fs1/fc) = 0.13484761

2 = Asl,com/(b*d)*(fs2/fc) = 0.13484761

v = Asl,mid/(b*d)*(fsv/fc) = 0.13484761

and confined core properties:

b = 340.00

d = 228.00
d' = 12.00
fcc (5A.2, TBDY) = 26.16063
cc (5A.5, TBDY) = 0.00290026
c = confinement factor = 1.09003
1 = Asl,ten/(b*d)*(fs1/fc) = 0.17951849
2 = Asl,com/(b*d)*(fs2/fc) = 0.17951849
v = Asl,mid/(b*d)*(fsv/fc) = 0.17951849
Case/Assumption: Unconfined full section - Steel rupture
' does not satisfy Eq. (4.3)

--->
v < vs,c - RHS eq.(4.5) is satisfied
--->
su (4.9) = 0.20560388
Mu = MRc (4.14) = 1.2764E+008
u = su (4.1) = 0.00015613

Calculation of ratio lb/ld

Adequate Lap Length: lb/ld >= 1

Calculation of Mu1-

Calculation of ultimate curvature u according to 4.1, Biskinis/Fardis 2013:
u = 0.00015613
Mu = 1.2764E+008

with full section properties:

b = 400.00
d = 258.00
d' = 42.00
v = 8.5224858E-005
N = 211.0849
fc = 24.00
co (5A.5, TBDY) = 0.002
Final value of cu: cu* = shear_factor * Max(cu, cc) = 0.00773686
The Shear_factor is considered equal to 1 (pure moment strength)
From (5.4b), TBDY: cu = 0.00773686
we (5.4c) = 0.01121936
ase ((5.4d), TBDY) = 0.15672608
bo = 240.00
ho = 340.00
bi2 = 346400.00
psh,min = Min(psh,x , psh,y) = 0.00261799

psh,x (5.4d) = 0.00349066
Ash = Astir*ns = 78.53982
No stirups, ns = 2.00
bk = 300.00

psh,y (5.4d) = 0.00261799
Ash = Astir*ns = 78.53982
No stirups, ns = 2.00
bk = 400.00

s = 150.00
fywe = 656.25
fce = 24.00
From ((5.A5), TBDY), TBDY: cc = 0.00290026
c = confinement factor = 1.09003
y1 = 0.0025
sh1 = 0.008

$$ft1 = 787.50$$

$$fy1 = 656.25$$

$$su1 = 0.032$$

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00

$$lo/lou,min = lb/d = 1.00$$

$$su1 = 0.4*esu1_nominal ((5.5), TBDY) = 0.032$$

From table 5A.1, TBDY: esu1_nominal = 0.08,

For calculation of esu1_nominal and y1, sh1,ft1,fy1, it is considered
characteristic value fsy1 = fs1/1.2, from table 5.1, TBDY.

y1, sh1,ft1,fy1, are also multiplied by $\text{Min}(1, 1.25*(lb/d)^{2/3})$, from 10.3.5, ASCE 41-17.

$$\text{with } fs1 = fs = 656.25$$

$$\text{with } Es1 = Es = 200000.00$$

$$y2 = 0.0025$$

$$sh2 = 0.008$$

$$ft2 = 787.50$$

$$fy2 = 656.25$$

$$su2 = 0.032$$

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00

$$lo/lou,min = lb/lb,min = 1.00$$

$$su2 = 0.4*esu2_nominal ((5.5), TBDY) = 0.032$$

From table 5A.1, TBDY: esu2_nominal = 0.08,

For calculation of esu2_nominal and y2, sh2,ft2,fy2, it is considered
characteristic value fsy2 = fs2/1.2, from table 5.1, TBDY.

y1, sh1,ft1,fy1, are also multiplied by $\text{Min}(1, 1.25*(lb/d)^{2/3})$, from 10.3.5, ASCE 41-17.

$$\text{with } fs2 = fs = 656.25$$

$$\text{with } Es2 = Es = 200000.00$$

$$yv = 0.0025$$

$$shv = 0.008$$

$$ftv = 787.50$$

$$fyv = 656.25$$

$$suv = 0.032$$

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00

$$lo/lou,min = lb/d = 1.00$$

$$suv = 0.4*esuv_nominal ((5.5), TBDY) = 0.032$$

From table 5A.1, TBDY: esuv_nominal = 0.08,

considering characteristic value fsyv = fsv/1.2, from table 5.1, TBDY

For calculation of esuv_nominal and yv, shv,ftv,fyv, it is considered
characteristic value fsyv = fsv/1.2, from table 5.1, TBDY.

y1, sh1,ft1,fy1, are also multiplied by $\text{Min}(1, 1.25*(lb/d)^{2/3})$, from 10.3.5, ASCE 41-17.

$$\text{with } fsv = fs = 656.25$$

$$\text{with } Esv = Es = 200000.00$$

$$1 = Asl,ten/(b*d)*(fs1/fc) = 0.13484761$$

$$2 = Asl,com/(b*d)*(fs2/fc) = 0.13484761$$

$$v = Asl,mid/(b*d)*(fsv/fc) = 0.13484761$$

and confined core properties:

$$b = 340.00$$

$$d = 228.00$$

$$d' = 12.00$$

$$fcc (5A.2, TBDY) = 26.16063$$

$$cc (5A.5, TBDY) = 0.00290026$$

$$c = \text{confinement factor} = 1.09003$$

$$1 = Asl,ten/(b*d)*(fs1/fc) = 0.17951849$$

$$2 = Asl,com/(b*d)*(fs2/fc) = 0.17951849$$

$$v = Asl,mid/(b*d)*(fsv/fc) = 0.17951849$$

Case/Assumption: Unconfined full section - Steel rupture

' does not satisfy Eq. (4.3)

--->

v < vs,c - RHS eq.(4.5) is satisfied

--->

$$su (4.9) = 0.20560388$$

$$Mu = MRc (4.14) = 1.2764E+008$$

$$u = s_u(4.1) = 0.00015613$$

Calculation of ratio l_b/d

Adequate Lap Length: $l_b/d \geq 1$

Calculation of μ_{2+}

Calculation of ultimate curvature μ according to 4.1, Biskinis/Fardis 2013:

$$u = 0.00015613$$

$$\mu = 1.2764E+008$$

with full section properties:

$$b = 400.00$$

$$d = 258.00$$

$$d' = 42.00$$

$$v = 8.5224858E-005$$

$$N = 211.0849$$

$$f_c = 24.00$$

$$c_o(5A.5, \text{TBDY}) = 0.002$$

$$\text{Final value of } \mu: \mu^* = \text{shear_factor} * \text{Max}(\mu_c, \mu_{cc}) = 0.00773686$$

The Shear_factor is considered equal to 1 (pure moment strength)

$$\text{From (5.4b), TBDY: } \mu_c = 0.00773686$$

$$\mu_{cc} \text{ (5.4c)} = 0.01121936$$

$$a_{se} \text{ ((5.4d), TBDY)} = 0.15672608$$

$$b_o = 240.00$$

$$h_o = 340.00$$

$$b_i^2 = 346400.00$$

$$\mu_{sh,min} = \text{Min}(\mu_{sh,x}, \mu_{sh,y}) = 0.00261799$$

$$\mu_{sh,x} \text{ (5.4d)} = 0.00349066$$

$$A_{sh} = A_{stir} * n_s = 78.53982$$

$$\text{No stirups, } n_s = 2.00$$

$$b_k = 300.00$$

$$\mu_{sh,y} \text{ (5.4d)} = 0.00261799$$

$$A_{sh} = A_{stir} * n_s = 78.53982$$

$$\text{No stirups, } n_s = 2.00$$

$$b_k = 400.00$$

$$s = 150.00$$

$$f_{ywe} = 656.25$$

$$f_{ce} = 24.00$$

$$\text{From ((5.A5), TBDY), TBDY: } \mu_{cc} = 0.00290026$$

$$c = \text{confinement factor} = 1.09003$$

$$y_1 = 0.0025$$

$$sh_1 = 0.008$$

$$ft_1 = 787.50$$

$$fy_1 = 656.25$$

$$s_{u1} = 0.032$$

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor and also multiplied by the shear_factor according to 15.7.1.4, with Shear_factor = 1.00

$$l_o/l_{o,min} = l_b/d = 1.00$$

$$s_{u1} = 0.4 * e_{s_{u1,nominal}} \text{ ((5.5), TBDY)} = 0.032$$

$$\text{From table 5A.1, TBDY: } e_{s_{u1,nominal}} = 0.08,$$

For calculation of $e_{s_{u1,nominal}}$ and y_1, sh_1, ft_1, fy_1 , it is considered characteristic value $f_{sy1} = f_{s1}/1.2$, from table 5.1, TBDY.

y_1, sh_1, ft_1, fy_1 , are also multiplied by $\text{Min}(1, 1.25 * (l_b/d)^{2/3})$, from 10.3.5, ASCE 41-17.

$$\text{with } f_{s1} = f_s = 656.25$$

$$\text{with } E_{s1} = E_s = 200000.00$$

$$y_2 = 0.0025$$

$$sh_2 = 0.008$$

$$ft_2 = 787.50$$

$$fy_2 = 656.25$$

$$su_2 = 0.032$$

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00

$$lo/lo_{min} = lb/lb_{min} = 1.00$$

$$su_2 = 0.4 * esu_{2_nominal} ((5.5), TBDY) = 0.032$$

From table 5A.1, TBDY: $esu_{2_nominal} = 0.08$,

For calculation of $esu_{2_nominal}$ and y_2 , sh_2, ft_2, fy_2 , it is considered
characteristic value $fsy_2 = fs_2/1.2$, from table 5.1, TBDY.

y_1 , sh_1, ft_1, fy_1 , are also multiplied by $\text{Min}(1, 1.25 * (lb/ld)^{2/3})$, from 10.3.5, ASCE 41-17.

$$\text{with } fs_2 = fs = 656.25$$

$$\text{with } Es_2 = Es = 200000.00$$

$$yv = 0.0025$$

$$shv = 0.008$$

$$ftv = 787.50$$

$$fyv = 656.25$$

$$suv = 0.032$$

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00

$$lo/lo_{min} = lb/ld = 1.00$$

$$suv = 0.4 * esuv_{nominal} ((5.5), TBDY) = 0.032$$

From table 5A.1, TBDY: $esuv_{nominal} = 0.08$,

considering characteristic value $fsyv = fsv/1.2$, from table 5.1, TBDY

For calculation of $esuv_{nominal}$ and yv , shv, ftv, fyv , it is considered
characteristic value $fsyv = fsv/1.2$, from table 5.1, TBDY.

y_1 , sh_1, ft_1, fy_1 , are also multiplied by $\text{Min}(1, 1.25 * (lb/ld)^{2/3})$, from 10.3.5, ASCE 41-17.

$$\text{with } fsv = fs = 656.25$$

$$\text{with } Esv = Es = 200000.00$$

$$1 = Asl_{ten}/(b*d) * (fs_1/fc) = 0.13484761$$

$$2 = Asl_{com}/(b*d) * (fs_2/fc) = 0.13484761$$

$$v = Asl_{mid}/(b*d) * (fsv/fc) = 0.13484761$$

and confined core properties:

$$b = 340.00$$

$$d = 228.00$$

$$d' = 12.00$$

$$fcc (5A.2, TBDY) = 26.16063$$

$$cc (5A.5, TBDY) = 0.00290026$$

$$c = \text{confinement factor} = 1.09003$$

$$1 = Asl_{ten}/(b*d) * (fs_1/fc) = 0.17951849$$

$$2 = Asl_{com}/(b*d) * (fs_2/fc) = 0.17951849$$

$$v = Asl_{mid}/(b*d) * (fsv/fc) = 0.17951849$$

Case/Assumption: Unconfined full section - Steel rupture

' does not satisfy Eq. (4.3)

--->

$v < v_{s,c}$ - RHS eq.(4.5) is satisfied

--->

$$su (4.9) = 0.20560388$$

$$\mu_u = MR_c (4.14) = 1.2764E+008$$

$$u = su (4.1) = 0.00015613$$

Calculation of ratio lb/ld

Adequate Lap Length: $lb/ld \geq 1$

Calculation of μ_{u2} -

Calculation of ultimate curvature u according to 4.1, Biskinis/Fardis 2013:

$$u = 0.00015613$$

Mu = 1.2764E+008

with full section properties:

b = 400.00

d = 258.00

d' = 42.00

v = 8.5224858E-005

N = 211.0849

fc = 24.00

co (5A.5, TBDY) = 0.002

Final value of cu: $cu^* = \text{shear_factor} * \text{Max}(cu, cc) = 0.00773686$

The Shear_factor is considered equal to 1 (pure moment strength)

From (5.4b), TBDY: $cu = 0.00773686$

we (5.4c) = 0.01121936

ase ((5.4d), TBDY) = 0.15672608

bo = 240.00

ho = 340.00

bi2 = 346400.00

psh,min = $\text{Min}(psh,x, psh,y) = 0.00261799$

psh,x (5.4d) = 0.00349066

Ash = $\text{Astir} * ns = 78.53982$

No stirups, ns = 2.00

bk = 300.00

psh,y (5.4d) = 0.00261799

Ash = $\text{Astir} * ns = 78.53982$

No stirups, ns = 2.00

bk = 400.00

s = 150.00

fywe = 656.25

fce = 24.00

From ((5.A5), TBDY), TBDY: $cc = 0.00290026$

c = confinement factor = 1.09003

y1 = 0.0025

sh1 = 0.008

ft1 = 787.50

fy1 = 656.25

su1 = 0.032

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00

lo/lou,min = lb/d = 1.00

su1 = $0.4 * \text{esu1_nominal} ((5.5), \text{TBDY}) = 0.032$

From table 5A.1, TBDY: $\text{esu1_nominal} = 0.08$,

For calculation of esu1_nominal and y1, sh1,ft1,fy1, it is considered
characteristic value $\text{fsy1} = \text{fs1}/1.2$, from table 5.1, TBDY.

y1, sh1,ft1,fy1, are also multiplied by $\text{Min}(1, 1.25 * (lb/d)^{2/3})$, from 10.3.5, ASCE 41-17.

with $\text{fs1} = \text{fs} = 656.25$

with $\text{Es1} = \text{Es} = 200000.00$

y2 = 0.0025

sh2 = 0.008

ft2 = 787.50

fy2 = 656.25

su2 = 0.032

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00

lo/lou,min = lb/lb,min = 1.00

su2 = $0.4 * \text{esu2_nominal} ((5.5), \text{TBDY}) = 0.032$

From table 5A.1, TBDY: $\text{esu2_nominal} = 0.08$,

For calculation of esu2_nominal and y2, sh2,ft2,fy2, it is considered
characteristic value $\text{fsy2} = \text{fs2}/1.2$, from table 5.1, TBDY.

y1, sh1,ft1,fy1, are also multiplied by $\text{Min}(1, 1.25 * (lb/d)^{2/3})$, from 10.3.5, ASCE 41-17.

with $\text{fs2} = \text{fs} = 656.25$

with $\text{Es2} = \text{Es} = 200000.00$

yv = 0.0025
shv = 0.008
ftv = 787.50
fyv = 656.25
suv = 0.032

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00

lo/lou,min = lb/d = 1.00

suv = 0.4*esuv_nominal ((5.5), TBDY) = 0.032

From table 5A.1, TBDY: esuv_nominal = 0.08,

considering characteristic value fsyv = fsv/1.2, from table 5.1, TBDY

For calculation of esuv_nominal and yv, shv,ftv,fyv, it is considered
characteristic value fsyv = fsv/1.2, from table 5.1, TBDY.

y1, sh1,ft1,fy1, are also multiplied by $\text{Min}(1, 1.25 \cdot (lb/d)^{2/3})$, from 10.3.5, ASCE 41-17.

with fsv = fs = 656.25

with Esv = Es = 200000.00

1 = Asl,ten/(b*d)*(fs1/fc) = 0.13484761

2 = Asl,com/(b*d)*(fs2/fc) = 0.13484761

v = Asl,mid/(b*d)*(fsv/fc) = 0.13484761

and confined core properties:

b = 340.00

d = 228.00

d' = 12.00

fcc (5A.2, TBDY) = 26.16063

cc (5A.5, TBDY) = 0.00290026

c = confinement factor = 1.09003

1 = Asl,ten/(b*d)*(fs1/fc) = 0.17951849

2 = Asl,com/(b*d)*(fs2/fc) = 0.17951849

v = Asl,mid/(b*d)*(fsv/fc) = 0.17951849

Case/Assumption: Unconfined full section - Steel rupture

' does not satisfy Eq. (4.3)

v < vs,c - RHS eq.(4.5) is satisfied

su (4.9) = 0.20560388

Mu = MRc (4.14) = 1.2764E+008

u = su (4.1) = 0.00015613

Calculation of ratio lb/d

Adequate Lap Length: lb/d >= 1

Calculation of Shear Strength Vr = Min(Vr1,Vr2) = 174208.493

Calculation of Shear Strength at edge 1, Vr1 = 174208.493

Vr1 = Vn ((22.5.1.1), ACI 318-14)

NOTE: In expression (22.5.1.1) 'Vw' is replaced by 'Vw+ f*Vf'
where Vf is the contribution of FRPs (11.3), ACI 440).

From Table (22.5.5.1), ACI 318-14: Vc = 75248.325

= 1 (normal-weight concrete)

fc' = 24.00, but $fc'^{0.5} \leq 8.3$ MPa (22.5.3.1, ACI 318-14)

pw = As/(bw*d) = 0.00628319

As (tension reinf.) = 603.1858

bw = 400.00

d = 240.00

Vu*d/Mu < 1 = 0.00

Mu = 7.6252677E-012

Vu = 3.6870970E-015

From (11.5.4.8), ACI 318-14: Vs = 98960.169

Av = 157079.633

$$f_y = 525.00$$

$$s = 150.00$$

Vs has been multiplied by $2(1-s/d)$ ($s > d/2$, according to ASCE 41-17,10.3.4)

$$2(1-s/d) = 0.75$$

$$V_f ((11-3)-(11.4), \text{ACI 440}) = 0.00$$

$$\text{From (11-11), ACI 440: } V_s + V_f \leq 312423.44$$

Calculation of Shear Strength at edge 2, $V_{r2} = 174208.493$

$$V_{r2} = V_n ((22.5.1.1), \text{ACI 318-14})$$

NOTE: In expression (22.5.1.1) 'Vw' is replaced by 'Vw + f*Vf'

where Vf is the contribution of FRPs (11.3), ACI 440).

From Table (22.5.5.1), ACI 318-14: $V_c = 75248.325$

= 1 (normal-weight concrete)

$$f_c' = 24.00, \text{ but } f_c'^{0.5} \leq 8.3 \text{ MPa (22.5.3.1, ACI 318-14)}$$

$$p_w = A_s / (b_w * d) = 0.00628319$$

$$A_s (\text{tension reinf.}) = 603.1858$$

$$b_w = 400.00$$

$$d = 240.00$$

$$V_u * d / \mu_u < 1 = 0.00$$

$$\mu_u = 8.0393416E-013$$

$$V_u = 3.6870970E-015$$

From (11.5.4.8), ACI 318-14: $V_s = 98960.169$

$$A_v = 157079.633$$

$$f_y = 525.00$$

$$s = 150.00$$

Vs has been multiplied by $2(1-s/d)$ ($s > d/2$, according to ASCE 41-17,10.3.4)

$$2(1-s/d) = 0.75$$

$$V_f ((11-3)-(11.4), \text{ACI 440}) = 0.00$$

$$\text{From (11-11), ACI 440: } V_s + V_f \leq 312423.44$$

End Of Calculation of Shear Capacity ratio for element: beam B1 of floor 1

At local axis: 2

Start Of Calculation of Chord Rotation Capacity for element: beam B1 of floor 1

At local axis: 2

Integration Section: (b)

Section Type: rcars

Constant Properties

Knowledge Factor, = 1.00

Chord Rotation is generally considered as Deformation-Controlled Action according to Table C7-1, ASCE 41-17.

Mean strengths are used for Deformation-Controlled Actions according to 7.5.1.3, ASCE 41-17

Consequently:

Existing material of Primary Member: Concrete Strength, $f_c = f_{cm} = 24.00$

Existing material of Primary Member: Steel Strength, $f_s = f_{sm} = 525.00$

Concrete Elasticity, $E_c = 23025.204$

Steel Elasticity, $E_s = 200000.00$

Section Height, $H = 400.00$

Section Width, $W = 300.00$

Cover Thickness, $c = 25.00$

Element Length, $L = 1850.00$

Primary Member

Smooth Bars

Ductile Steel

With Detailing for Earthquake Resistance (including stirrups closed at 135°)

Longitudinal Bars With Ends Lapped Starting at the End Sections

Adequate Lap Length ($l_b / l_d > 1$)

No FRP Wrapping

Stepwise Properties

Bending Moment, $M = 5.5813E+006$
Shear Force, $V2 = -3.0430585E-014$
Shear Force, $V3 = 8685.666$
Axial Force, $F = -560.8745$
Longitudinal Reinforcement Area Distribution (in 2 divisions)
-Tension: $As_t = 615.7522$
-Compression: $As_c = 911.0619$
Longitudinal Reinforcement Area Distribution (in 3 divisions)
-Tension: $As_{,ten} = 615.7522$
-Compression: $As_{,com} = 603.1858$
-Middle: $As_{,mid} = 307.8761$
Mean Diameter of Tension Reinforcement, $Db_L = 14.00$

Existing component: From table 7-7, ASCE 41_17: Final chord rotation Capacity $u_{,R} = \phi \cdot u = 0.00733824$
 $u = y + p = 0.00733824$

- Calculation of y -

$y = (M_y \cdot L_s / 3) / E_{eff} = 0.00233824$ ((4.29), Biskinis Phd))
 $M_y = 1.2065E+008$
 $L_s = M/V$ (with $L_s > 0.1 \cdot L$ and $L_s < 2 \cdot L$) = 642.5872
From table 10.5, ASCE 41_17: $E_{eff} = 0.3 \cdot E_c \cdot I_g = 1.1052E+013$

Calculation of Yielding Moment M_y

Calculation of y and M_y according to Annex 7 -

$y = \text{Min}(y_{,ten}, y_{,com})$
 $y_{,ten} = 1.0040096E-005$
with $f_y = 525.00$
 $d = 358.00$
 $y = 0.26968803$
 $A = 0.01422609$
 $B = 0.00802326$
with $p_t = 0.00573326$
 $p_c = 0.00561626$
 $p_v = 0.00286663$
 $N = 560.8745$
 $b = 300.00$
 $\mu = 0.12011173$
 $y_{,comp} = 1.9438402E-005$
with $f_c = 24.00$
 $E_c = 23025.204$
 $y = 0.26961043$
 $A = 0.01420223$
 $B = 0.00801331$
with $E_s = 200000.00$

Calculation of ratio l_b/d

Adequate Lap Length: $l_b/d \geq 1$

- Calculation of p -

From table 10-7: $p = 0.005$

with:

- Condition i occurred

Beam controlled by flexure: $V_p/V_o \leq 1$

shear control ratio $V_p/V_o = 0.78793176$

- Transverse Reinforcement: NC
- Stirrup Spacing $> d/3$
- Low ductility demand, $\lambda / y < 2$ (table 10-6, ASCE 41-17)
 $= 2.2582492E-005$
- Stirrup Spacing $\leq d/2$
 $d = 358.00$
 $s = 150.00$
- Strength provided by hoops $V_s < 3/4 * \text{design Shear}$
 $V_s = 175929.189$, already given in calculation of shear control ratio
design Shear = 8685.666
- ($\lambda - \lambda'$)/ bal = -0.15609354
 $= A_{st}/(b_w * d) = 0.00573326$
Tension Reinf Area: $A_{st} = 615.7522$
 $\lambda' = A_{sc}/(b_w * d) = 0.00848289$
Compression Reinf Area: $A_{sc} = 911.0619$
- From (B-1), ACI 318-11: bal = 0.01761524
 $f_c = 24.00$
 $f_y = 525.00$
From 10.2.7.3, ACI 318-11: $\lambda = 0.85$
From fig R10.3.3, ACI 318-11 (Ence 454, too): $87000/(87000 + f_y) = c_b/d_t = 0.003/(0.003 + \lambda) = 0.53333333$
 $y = 0.002625$
- $V/(b_w * d * f_c^{0.5}) = 0.19880004$, NOTE: units in lb & in
 $b_w = 300.00$

End Of Calculation of Chord Rotation Capacity for element: beam B1 of floor 1
At local axis: 2
Integration Section: (b)

Calculation No. 7

beam B1, Floor 1



Limit State: Operational Level (data interpolation between analysis steps 1 and 2)

Analysis: Uniform +X

Check: Shear capacity V_{Rd}

Edge: End

Local Axis: (3)



Start Of Calculation of Shear Capacity for element: beam B1 of floor 1

At local axis: 3

Integration Section: (b)

Section Type: rcars

Constant Properties

Knowledge Factor, $\gamma = 1.00$

Member Shear Force is generally considered as Force-Controlled Action according to Table C7-1, ASCE 41-17.

Lower-bound strengths are used for Force-Controlled Actions according to 7.5.1.3, ASCE 41-17

Consequently:

Existing material of Primary Member: Concrete Strength, $f_c = f_{c_lower_bound} = 16.00$

Existing material of Primary Member: Steel Strength, $f_s = f_{s_lower_bound} = 420.00$

Concrete Elasticity, $E_c = 23025.204$

Steel Elasticity, $E_s = 200000.00$

Section Height, $H = 400.00$

Section Width, $W = 300.00$

Cover Thickness, $c = 25.00$

Element Length, $L = 1850.00$

Primary Member

Smooth Bars

Ductile Steel

With Detailing for Earthquake Resistance (including stirrups closed at 135°)

Longitudinal Bars With Ends Lapped Starting at the End Sections

Adequate Lap Length ($l_o/l_{o,min} = l_b/l_d \geq 1$)

No FRP Wrapping

Stepwise Properties

EDGE -A-

Bending Moment, $M_a = 5.4177E+006$

Shear Force, $V_a = -3205.137$

EDGE -B-

Bending Moment, $M_b = 5.5813E+006$

Shear Force, $V_b = 8685.666$

BOTH EDGES

Axial Force, $F = -560.8745$

Longitudinal Reinforcement Area Distribution (in 2 divisions)

-Tension: $A_{sl,ten} = 615.7522$

-Compression: $A_{sl,com} = 911.0619$

Longitudinal Reinforcement Area Distribution (in 3 divisions)

-Tension: $A_{sl,ten} = 615.7522$

-Compression: $A_{sl,com} = 603.1858$

-Middle: $A_{sl,mid} = 307.8761$

Mean Diameter of Tension Reinforcement, $Db_{L,ten} = 14.00$

Existing component: From table 7-7, ASCE 41_17: Final Shear Capacity $V_R = *V_n = 207396.171$

$V_n ((22.5.1.1), ACI 318-14) = 207396.171$

NOTE: In expression (22.5.1.1) 'Vw' is replaced by 'Vw+ f*Vf' where Vf is the contribution of FRPs (11.3), ACI 440).

From Table (22.5.5.1), ACI 318-14: $V_c = 66652.82$
= 1 (normal-weight concrete)
 $f'_c = 16.00$, but $f'_c^{0.5} \leq 8.3$ MPa (22.5.3.1, ACI 318-14)
 $\rho_w = A_s/(b_w*d) = 0.00641409$
 A_s (tension reinf.) = 615.7522
 $b_w = 300.00$
 $d = 320.00$
 $V_u*d/\mu < 1 = 0.49798685$
 $\mu = 5.5813E+006$
 $V_u = 8685.666$
From (11.5.4.8), ACI 318-14: $V_s = 140743.351$
 $A_v = 157079.633$
 $f_y = 420.00$
 $s = 150.00$
 V_s has been multiplied by 1 ($s < d/2$, according to ASCE 41-17,10.3.4)
 V_f ((11-3)-(11.4), ACI 440) = 0.00
From (11-11), ACI 440: $V_s + V_f \leq 255092.67$

End Of Calculation of Shear Capacity for element: beam B1 of floor 1
At local axis: 3
Integration Section: (b)

Calculation No. 8

beam B1, Floor 1



Limit State: Operational Level (data interpolation between analysis steps 1 and 2)

Analysis: Uniform +X

Check: Chord rotation capacity (μ)

Edge: End

Local Axis: (3)



Start Of Calculation of Shear Capacity ratio for element: beam B1 of floor 1
At Shear local axis: 3
(Bending local axis: 2)

Section Type: rcars

Constant Properties

Knowledge Factor, $\gamma = 1.00$

Mean strength values are used for both shear and moment calculations.

Consequently:

Existing material of Primary Member: Concrete Strength, $f_c = f_{cm} = 24.00$

Existing material of Primary Member: Steel Strength, $f_s = f_{sm} = 525.00$

Concrete Elasticity, $E_c = 23025.204$

Steel Elasticity, $E_s = 200000.00$

#####

Note: Especially for the calculation of moment strengths,

the above steel re-bar strengths are multiplied by 1.25 according to R18.6.5, ACI 318-14

Existing material: Steel Strength, $f_s = 1.25 \cdot f_{sm} = 656.25$

#####

Section Height, $H = 400.00$

Section Width, $W = 300.00$

Cover Thickness, $c = 25.00$

Mean Confinement Factor overall section = 1.09003

Element Length, $L = 1850.00$

Primary Member

Smooth Bars

Ductile Steel

With Detailing for Earthquake Resistance (including stirrups closed at 135°)

Longitudinal Bars With Ends Lapped Starting at the End Sections

Adequate Lap Length ($l_o/l_{ou, \min} >= 1$)

No FRP Wrapping

Stepwise Properties

At local axis: 3

EDGE -A-

Shear Force, $V_a = 2740.265$

EDGE -B-

Shear Force, $V_b = 2740.264$

BOTH EDGES

Axial Force, $F = -211.0849$

Longitudinal Reinforcement Area Distribution (in 2 divisions)

-Tension: $A_{sl, \text{ten}} = 603.1858$

-Compression: $A_{sl, \text{com}} = 923.6282$

Longitudinal Reinforcement Area Distribution (in 3 divisions)

-Tension: $A_{sl, \text{ten}} = 603.1858$

-Compression: $A_{sl, \text{com}} = 615.7522$

-Middle: $A_{sl, \text{mid}} = 307.8761$

Calculation of Shear Capacity ratio, $V_e/V_r = 0.78793176$

Member Controlled by Flexure ($V_e/V_r < 1$)

Calculation of Shear Demand from fig. R18.6.5, ACI 318-14 $V_e = (M_{pr1} + M_{pr2})/l_n \pm w_u \cdot l_n / 2 = 205990.317$

with

$M_{pr1} = \text{Max}(M_{u1+}, M_{u1-}) = 1.8802E+008$

$M_{u1+} = 1.8495E+008$, is the ultimate moment strength at the edge 1 of the member in the actual moment direction which is defined for the static loading combination

$M_{u1-} = 1.8802E+008$, is the ultimate moment strength at the edge 1 of the member in the opposite moment direction which is defined for the static loading combination

$M_{pr2} = \text{Max}(M_{u2+}, M_{u2-}) = 1.8800E+008$

$M_{u2+} = 1.8498E+008$, is the ultimate moment strength at the edge 2 of the member in the actual moment direction which is defined for the the static loading combination

$M_{u2-} = 1.8800E+008$, is the ultimate moment strength at the edge 2 of the member in the opposite moment direction which is defined for the the static loading combination

and

$\pm w_u \cdot l_n = (|V_1| + |V_2|)/2$

with

V1 = 2740.265, is the shear force acting at edge 1 for the the static loading combination
V2 = 2740.264, is the shear force acting at edge 2 for the the static loading combination

Calculation of Mu1+

Calculation of ultimate curvature μ according to 4.1, Biskinis/Fardis 2013:

$$\mu = 0.0001071$$

$$Mu = 1.8495E+008$$

with full section properties:

$$b = 300.00$$

$$d = 357.00$$

$$d' = 42.00$$

$$v = 8.2121432E-005$$

$$N = 211.0849$$

$$f_c = 24.00$$

$$c_o \text{ (5A.5, TBDY)} = 0.002$$

$$\text{Final value of } c_u: c_u^* = \text{shear_factor} * \text{Max}(c_u, c_c) = 0.00773686$$

The Shear_factor is considered equal to 1 (pure moment strength)

$$\text{From (5.4b), TBDY: } c_u = 0.00773686$$

$$w_e \text{ (5.4c)} = 0.01121936$$

$$a_{se} \text{ ((5.4d), TBDY)} = 0.15672608$$

$$b_o = 240.00$$

$$h_o = 340.00$$

$$b_{i2} = 346400.00$$

$$p_{sh,min} = \text{Min}(p_{sh,x}, p_{sh,y}) = 0.00261799$$

 $p_{sh,x} \text{ (5.4d)} = 0.00349066$

$$A_{sh} = A_{stir} * n_s = 78.53982$$

$$\text{No stirups, } n_s = 2.00$$

$$b_k = 300.00$$

 $p_{sh,y} \text{ (5.4d)} = 0.00261799$

$$A_{sh} = A_{stir} * n_s = 78.53982$$

$$\text{No stirups, } n_s = 2.00$$

$$b_k = 400.00$$

 $s = 150.00$

$$f_{ywe} = 656.25$$

$$f_{ce} = 24.00$$

$$\text{From ((5.A5), TBDY), TBDY: } c_c = 0.00290026$$

$$c = \text{confinement factor} = 1.09003$$

$$y_1 = 0.0025$$

$$sh_1 = 0.008$$

$$ft_1 = 787.50$$

$$fy_1 = 656.25$$

$$su_1 = 0.032$$

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00

$$l_o/l_{ou,min} = l_b/l_d = 1.00$$

$$su_1 = 0.4 * esu_1_{nominal} \text{ ((5.5), TBDY)} = 0.032$$

$$\text{From table 5A.1, TBDY: } esu_1_{nominal} = 0.08,$$

For calculation of $esu_1_{nominal}$ and y_1, sh_1, ft_1, fy_1 , it is considered
characteristic value $fsy_1 = fs_1/1.2$, from table 5.1, TBDY.

$$y_1, sh_1, ft_1, fy_1, \text{ are also multiplied by } \text{Min}(1, 1.25 * (l_b/l_d)^{2/3}), \text{ from 10.3.5, ASCE 41-17.}$$

$$\text{with } fs_1 = fs = 656.25$$

$$\text{with } Es_1 = Es = 200000.00$$

$$y_2 = 0.0025$$

$$sh_2 = 0.008$$

$$ft_2 = 787.50$$

$$fy_2 = 656.25$$

$$su_2 = 0.032$$

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor

and also multiplied by the shear_factor according to 15.7.1.4, with

Shear_factor = 1.00

lo/lou,min = lb/lb,min = 1.00

su2 = 0.4*esu2_nominal ((5.5), TBDY) = 0.032

From table 5A.1, TBDY: esu2_nominal = 0.08,

For calculation of esu2_nominal and y2, sh2,ft2,fy2, it is considered characteristic value fsy2 = fs2/1.2, from table 5.1, TBDY.

y1, sh1,ft1,fy1, are also multiplied by $\text{Min}(1, 1.25 \cdot (lb/ld)^{2/3})$, from 10.3.5, ASCE 41-17.

with fs2 = fs = 656.25

with Es2 = Es = 200000.00

yv = 0.0025

shv = 0.008

ftv = 787.50

fyv = 656.25

suv = 0.032

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor

and also multiplied by the shear_factor according to 15.7.1.4, with

Shear_factor = 1.00

lo/lou,min = lb/ld = 1.00

suv = 0.4*esuv_nominal ((5.5), TBDY) = 0.032

From table 5A.1, TBDY: esuv_nominal = 0.08,

considering characteristic value fsyv = fsv/1.2, from table 5.1, TBDY

For calculation of esuv_nominal and yv, shv,ftv,fyv, it is considered characteristic value fsyv = fsv/1.2, from table 5.1, TBDY.

y1, sh1,ft1,fy1, are also multiplied by $\text{Min}(1, 1.25 \cdot (lb/ld)^{2/3})$, from 10.3.5, ASCE 41-17.

with fsv = fs = 656.25

with Esv = Es = 200000.00

1 = Asl,ten/(b*d)*(fs1/fc) = 0.15399964

2 = Asl,com/(b*d)*(fs2/fc) = 0.15720797

v = Asl,mid/(b*d)*(fsv/fc) = 0.07860398

and confined core properties:

b = 240.00

d = 327.00

d' = 12.00

fcc (5A.2, TBDY) = 26.16063

cc (5A.5, TBDY) = 0.00290026

c = confinement factor = 1.09003

1 = Asl,ten/(b*d)*(fs1/fc) = 0.21016006

2 = Asl,com/(b*d)*(fs2/fc) = 0.21453839

v = Asl,mid/(b*d)*(fsv/fc) = 0.1072692

Case/Assumption: Unconfined full section - Steel rupture

' satisfies Eq. (4.3)

--->

v < vs,y2 - LHS eq.(4.5) is satisfied

--->

su (4.9) = 0.1630814

Mu = MRc (4.14) = 1.8495E+008

u = su (4.1) = 0.0001071

Calculation of ratio lb/ld

Adequate Lap Length: lb/ld >= 1

Calculation of Mu1-

Calculation of ultimate curvature u according to 4.1, Biskinis/Fardis 2013:

u = 0.00010722

Mu = 1.8802E+008

with full section properties:

b = 300.00

d = 358.00

d' = 43.00
v = 8.1892042E-005
N = 211.0849
fc = 24.00
co (5A.5, TBDY) = 0.002
Final value of cu: cu* = shear_factor * Max(cu, cc) = 0.00773686
The Shear_factor is considered equal to 1 (pure moment strength)
From (5.4b), TBDY: cu = 0.00773686
we (5.4c) = 0.01121936
ase ((5.4d), TBDY) = 0.15672608
bo = 240.00
ho = 340.00
bi2 = 346400.00
psh,min = Min(psh,x , psh,y) = 0.00261799

psh,x (5.4d) = 0.00349066
Ash = Astir*ns = 78.53982
No stirups, ns = 2.00
bk = 300.00

psh,y (5.4d) = 0.00261799
Ash = Astir*ns = 78.53982
No stirups, ns = 2.00
bk = 400.00

s = 150.00
fywe = 656.25
fce = 24.00
From ((5.A5), TBDY), TBDY: cc = 0.00290026
c = confinement factor = 1.09003
y1 = 0.0025
sh1 = 0.008
ft1 = 787.50
fy1 = 656.25
su1 = 0.032

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00
lo/lou,min = lb/d = 1.00
su1 = 0.4*esu1_nominal ((5.5), TBDY) = 0.032
From table 5A.1, TBDY: esu1_nominal = 0.08,
For calculation of esu1_nominal and y1, sh1,ft1,fy1, it is considered
characteristic value fsy1 = fs1/1.2, from table 5.1, TBDY.
y1, sh1,ft1,fy1, are also multiplied by Min(1,1.25*(lb/d)^ 2/3), from 10.3.5, ASCE 41-17.
with fs1 = fs = 656.25
with Es1 = Es = 200000.00

y2 = 0.0025
sh2 = 0.008
ft2 = 787.50
fy2 = 656.25
su2 = 0.032
using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00
lo/lou,min = lb/lb,min = 1.00
su2 = 0.4*esu2_nominal ((5.5), TBDY) = 0.032
From table 5A.1, TBDY: esu2_nominal = 0.08,
For calculation of esu2_nominal and y2, sh2,ft2,fy2, it is considered
characteristic value fsy2 = fs2/1.2, from table 5.1, TBDY.
y1, sh1,ft1,fy1, are also multiplied by Min(1,1.25*(lb/d)^ 2/3), from 10.3.5, ASCE 41-17.
with fs2 = fs = 656.25
with Es2 = Es = 200000.00

yv = 0.0025
shv = 0.008
ftv = 787.50
fyv = 656.25
suv = 0.032

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00

lo/lo,min = lb/d = 1.00

su = 0.4*esuv_nominal ((5.5), TBDY) = 0.032

From table 5A.1, TBDY: esuv_nominal = 0.08,

considering characteristic value fsyv = fsv/1.2, from table 5.1, TBDY

For calculation of esuv_nominal and yv, shv,ftv,fyv, it is considered
characteristic value fsyv = fsv/1.2, from table 5.1, TBDY.

y1, sh1,ft1,fy1, are also multiplied by $\text{Min}(1, 1.25 \cdot (lb/d)^{2/3})$, from 10.3.5, ASCE 41-17.

with fsv = fs = 656.25

with Esv = Es = 200000.00

1 = Asl,ten/(b*d)*(fs1/fc) = 0.15676884

2 = Asl,com/(b*d)*(fs2/fc) = 0.15356947

v = Asl,mid/(b*d)*(fsv/fc) = 0.07838442

and confined core properties:

b = 240.00

d = 328.00

d' = 13.00

fcc (5A.2, TBDY) = 26.16063

cc (5A.5, TBDY) = 0.00290026

c = confinement factor = 1.09003

1 = Asl,ten/(b*d)*(fs1/fc) = 0.21388431

2 = Asl,com/(b*d)*(fs2/fc) = 0.20951933

v = Asl,mid/(b*d)*(fsv/fc) = 0.10694216

Case/Assumption: Unconfined full section - Steel rupture

' satisfies Eq. (4.3)

v < vs,y2 - LHS eq.(4.5) is satisfied

su (4.9) = 0.16631328

Mu = MRc (4.14) = 1.8802E+008

u = su (4.1) = 0.00010722

Calculation of ratio lb/d

Adequate Lap Length: lb/d >= 1

Calculation of Mu2+

Calculation of ultimate curvature u according to 4.1, Biskinis/Fardis 2013:

u = 0.00010701

Mu = 1.8498E+008

with full section properties:

b = 300.00

d = 358.00

d' = 43.00

v = 8.1892042E-005

N = 211.0849

fc = 24.00

co (5A.5, TBDY) = 0.002

Final value of cu: cu* = shear_factor * Max(cu, cc) = 0.00773686

The Shear_factor is considered equal to 1 (pure moment strength)

From (5.4b), TBDY: cu = 0.00773686

we (5.4c) = 0.01121936

ase ((5.4d), TBDY) = 0.15672608

bo = 240.00

ho = 340.00

bi2 = 346400.00

psh,min = Min(psh,x, psh,y) = 0.00261799

psh,x (5.4d) = 0.00349066
Ash = Astir*ns = 78.53982
No stirups, ns = 2.00
bk = 300.00

psh,y (5.4d) = 0.00261799
Ash = Astir*ns = 78.53982
No stirups, ns = 2.00
bk = 400.00

s = 150.00
fywe = 656.25
fce = 24.00

From ((5.A.5), TBDY), TBDY: cc = 0.00290026
c = confinement factor = 1.09003

y1 = 0.0025
sh1 = 0.008
ft1 = 787.50
fy1 = 656.25
su1 = 0.032

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00

lo/lou,min = lb/ld = 1.00

su1 = 0.4*esu1_nominal ((5.5), TBDY) = 0.032

From table 5A.1, TBDY: esu1_nominal = 0.08,

For calculation of esu1_nominal and y1, sh1,ft1,fy1, it is considered
characteristic value fsy1 = fs1/1.2, from table 5.1, TBDY.

y1, sh1,ft1,fy1, are also multiplied by Min(1,1.25*(lb/ld)^ 2/3), from 10.3.5, ASCE 41-17.

with fs1 = fs = 656.25

with Es1 = Es = 200000.00

y2 = 0.0025
sh2 = 0.008
ft2 = 787.50
fy2 = 656.25
su2 = 0.032

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00

lo/lou,min = lb/lb,min = 1.00

su2 = 0.4*esu2_nominal ((5.5), TBDY) = 0.032

From table 5A.1, TBDY: esu2_nominal = 0.08,

For calculation of esu2_nominal and y2, sh2,ft2,fy2, it is considered
characteristic value fsy2 = fs2/1.2, from table 5.1, TBDY.

y1, sh1,ft1,fy1, are also multiplied by Min(1,1.25*(lb/ld)^ 2/3), from 10.3.5, ASCE 41-17.

with fs2 = fs = 656.25

with Es2 = Es = 200000.00

yv = 0.0025
shv = 0.008
ftv = 787.50
fyv = 656.25
suv = 0.032

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00

lo/lou,min = lb/ld = 1.00

suv = 0.4*esuv_nominal ((5.5), TBDY) = 0.032

From table 5A.1, TBDY: esuv_nominal = 0.08,

considering characteristic value fsyv = fsv/1.2, from table 5.1, TBDY

For calculation of esuv_nominal and yv, shv,ftv,fyv, it is considered
characteristic value fsyv = fsv/1.2, from table 5.1, TBDY.

y1, sh1,ft1,fy1, are also multiplied by Min(1,1.25*(lb/ld)^ 2/3), from 10.3.5, ASCE 41-17.

with fsv = fs = 656.25

with Esv = Es = 200000.00

1 = Asl,ten/(b*d)*(fs1/fc) = 0.15356947

2 = Asl,com/(b*d)*(fs2/fc) = 0.15676884

v = Asl,mid/(b*d)*(fsv/fc) = 0.07838442

and confined core properties:

$$b = 240.00$$

$$d = 328.00$$

$$d' = 13.00$$

$$fcc (5A.2, TBDY) = 26.16063$$

$$cc (5A.5, TBDY) = 0.00290026$$

$$c = \text{confinement factor} = 1.09003$$

$$1 = A_{sl,ten}/(b*d)*(f_{s1}/f_c) = 0.20951933$$

$$2 = A_{sl,com}/(b*d)*(f_{s2}/f_c) = 0.21388431$$

$$v = A_{sl,mid}/(b*d)*(f_{sv}/f_c) = 0.10694216$$

Case/Assumption: Unconfined full section - Steel rupture

' satisfies Eq. (4.3)

--->

$v < v_{s,y2}$ - LHS eq.(4.5) is satisfied

--->

$$s_u (4.9) = 0.16466458$$

$$\mu_u = M_{Rc} (4.14) = 1.8498E+008$$

$$u = s_u (4.1) = 0.00010701$$

Calculation of ratio l_b/d

Adequate Lap Length: $l_b/d \geq 1$

Calculation of μ_{u2} -

Calculation of ultimate curvature μ_u according to 4.1, Biskinis/Fardis 2013:

$$u = 0.00010732$$

$$\mu_u = 1.8800E+008$$

with full section properties:

$$b = 300.00$$

$$d = 357.00$$

$$d' = 42.00$$

$$v = 8.2121432E-005$$

$$N = 211.0849$$

$$f_c = 24.00$$

$$c_o (5A.5, TBDY) = 0.002$$

$$\text{Final value of } c_u: c_u^* = \text{shear_factor} * \text{Max}(c_u, c_c) = 0.00773686$$

The Shear_factor is considered equal to 1 (pure moment strength)

$$\text{From (5.4b), TBDY: } c_u = 0.00773686$$

$$w_e (5.4c) = 0.01121936$$

$$a_{se} ((5.4d), TBDY) = 0.15672608$$

$$b_o = 240.00$$

$$h_o = 340.00$$

$$b_{i2} = 346400.00$$

$$p_{sh,min} = \text{Min}(p_{sh,x}, p_{sh,y}) = 0.00261799$$

$$p_{sh,x} (5.4d) = 0.00349066$$

$$A_{sh} = A_{stir} * n_s = 78.53982$$

$$\text{No stirups, } n_s = 2.00$$

$$b_k = 300.00$$

$$p_{sh,y} (5.4d) = 0.00261799$$

$$A_{sh} = A_{stir} * n_s = 78.53982$$

$$\text{No stirups, } n_s = 2.00$$

$$b_k = 400.00$$

$$s = 150.00$$

$$f_{ywe} = 656.25$$

$$f_{ce} = 24.00$$

$$\text{From ((5.A5), TBDY), TBDY: } c_c = 0.00290026$$

$$c = \text{confinement factor} = 1.09003$$

y1 = 0.0025
sh1 = 0.008
ft1 = 787.50
fy1 = 656.25
su1 = 0.032

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00

lo/lou,min = lb/d = 1.00

su1 = 0.4*esu1_nominal ((5.5), TBDY) = 0.032

From table 5A.1, TBDY: esu1_nominal = 0.08,

For calculation of esu1_nominal and y1, sh1,ft1,fy1, it is considered
characteristic value fsy1 = fs1/1.2, from table 5.1, TBDY.

y1, sh1,ft1,fy1, are also multiplied by $\text{Min}(1, 1.25 \cdot (lb/d)^{2/3})$, from 10.3.5, ASCE 41-17.

with fs1 = fs = 656.25

with Es1 = Es = 200000.00

y2 = 0.0025
sh2 = 0.008
ft2 = 787.50
fy2 = 656.25
su2 = 0.032

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00

lo/lou,min = lb/lb,min = 1.00

su2 = 0.4*esu2_nominal ((5.5), TBDY) = 0.032

From table 5A.1, TBDY: esu2_nominal = 0.08,

For calculation of esu2_nominal and y2, sh2,ft2,fy2, it is considered
characteristic value fsy2 = fs2/1.2, from table 5.1, TBDY.

y1, sh1,ft1,fy1, are also multiplied by $\text{Min}(1, 1.25 \cdot (lb/d)^{2/3})$, from 10.3.5, ASCE 41-17.

with fs2 = fs = 656.25

with Es2 = Es = 200000.00

yv = 0.0025
shv = 0.008
ftv = 787.50
fyv = 656.25
suv = 0.032

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00

lo/lou,min = lb/d = 1.00

suv = 0.4*esuv_nominal ((5.5), TBDY) = 0.032

From table 5A.1, TBDY: esuv_nominal = 0.08,

considering characteristic value fsyv = fsv/1.2, from table 5.1, TBDY

For calculation of esuv_nominal and yv, shv,ftv,fyv, it is considered
characteristic value fsyv = fsv/1.2, from table 5.1, TBDY.

y1, sh1,ft1,fy1, are also multiplied by $\text{Min}(1, 1.25 \cdot (lb/d)^{2/3})$, from 10.3.5, ASCE 41-17.

with fsv = fs = 656.25

with Esv = Es = 200000.00

1 = Asl,ten/(b*d)*(fs1/fc) = 0.15720797

2 = Asl,com/(b*d)*(fs2/fc) = 0.15399964

v = Asl,mid/(b*d)*(fsv/fc) = 0.07860398

and confined core properties:

b = 240.00

d = 327.00

d' = 12.00

fcc (5A.2, TBDY) = 26.16063

cc (5A.5, TBDY) = 0.00290026

c = confinement factor = 1.09003

1 = Asl,ten/(b*d)*(fs1/fc) = 0.21453839

2 = Asl,com/(b*d)*(fs2/fc) = 0.21016006

v = Asl,mid/(b*d)*(fsv/fc) = 0.1072692

Case/Assumption: Unconfined full section - Steel rupture

' satisfies Eq. (4.3)

---->

v < vs,y2 - LHS eq.(4.5) is satisfied

---->

su (4.9) = 0.16474284
Mu = MRc (4.14) = 1.8800E+008
u = su (4.1) = 0.00010732

Calculation of ratio lb/l_d

Adequate Lap Length: lb/l_d >= 1

Calculation of Shear Strength Vr = Min(Vr1,Vr2) = 261431.672

Calculation of Shear Strength at edge 1, Vr1 = 261431.672
Vr1 = Vn ((22.5.1.1), ACI 318-14)

NOTE: In expression (22.5.1.1) 'Vw' is replaced by 'Vw+ f*Vf'
where Vf is the contribution of FRPs (11.3), ACI 440).

From Table (22.5.5.1), ACI 318-14: Vc = 85502.483
= 1 (normal-weight concrete)
fc' = 24.00, but fc'^0.5 <= 8.3 MPa (22.5.3.1, ACI 318-14)
pw = As/(bw*d) = 0.00628319
As (tension reinf.) = 603.1858
bw = 300.00
d = 320.00
Vu*d/Mu < 1 = 1.00
Mu = 30114.962
Vu = 2740.265

From (11.5.4.8), ACI 318-14: Vs = 175929.189
Av = 157079.633
fy = 525.00
s = 150.00

Vs has been multiplied by 1 (s<d/2, according to ASCE 41-17,10.3.4)
Vf ((11-3)-(11.4), ACI 440) = 0.00
From (11-11), ACI 440: Vs + Vf <= 312423.44

Calculation of Shear Strength at edge 2, Vr2 = 261431.672
Vr2 = Vn ((22.5.1.1), ACI 318-14)

NOTE: In expression (22.5.1.1) 'Vw' is replaced by 'Vw+ f*Vf'
where Vf is the contribution of FRPs (11.3), ACI 440).

From Table (22.5.5.1), ACI 318-14: Vc = 85502.483
= 1 (normal-weight concrete)
fc' = 24.00, but fc'^0.5 <= 8.3 MPa (22.5.3.1, ACI 318-14)
pw = As/(bw*d) = 0.00628319
As (tension reinf.) = 603.1858
bw = 300.00
d = 320.00
Vu*d/Mu < 1 = 1.00
Mu = 30115.665
Vu = 2740.264

From (11.5.4.8), ACI 318-14: Vs = 175929.189
Av = 157079.633
fy = 525.00
s = 150.00

Vs has been multiplied by 1 (s<d/2, according to ASCE 41-17,10.3.4)
Vf ((11-3)-(11.4), ACI 440) = 0.00
From (11-11), ACI 440: Vs + Vf <= 312423.44

End Of Calculation of Shear Capacity ratio for element: beam B1 of floor 1
At local axis: 3

Start Of Calculation of Shear Capacity ratio for element: beam B1 of floor 1

At Shear local axis: 2

(Bending local axis: 3)

Section Type: rcars

Constant Properties

Knowledge Factor, $\gamma = 1.00$

Mean strength values are used for both shear and moment calculations.

Consequently:

Existing material of Primary Member: Concrete Strength, $f_c = f_{cm} = 24.00$

Existing material of Primary Member: Steel Strength, $f_s = f_{sm} = 525.00$

Concrete Elasticity, $E_c = 23025.204$

Steel Elasticity, $E_s = 200000.00$

#####

Note: Especially for the calculation of moment strengths,

the above steel re-bar strengths are multiplied by 1.25 according to R18.6.5, ACI 318-14

Existing material: Steel Strength, $f_s = 1.25 \cdot f_{sm} = 656.25$

#####

Section Height, $H = 400.00$

Section Width, $W = 300.00$

Cover Thickness, $c = 25.00$

Mean Confinement Factor overall section = 1.09003

Element Length, $L = 1850.00$

Primary Member

Smooth Bars

Ductile Steel

With Detailing for Earthquake Resistance (including stirrups closed at 135°)

Longitudinal Bars With Ends Lapped Starting at the End Sections

Adequate Lap Length ($l_o/l_{ou}, \min >= 1$)

No FRP Wrapping

Stepwise Properties

At local axis: 2

EDGE -A-

Shear Force, $V_a = -3.6870970E-015$

EDGE -B-

Shear Force, $V_b = 3.6870970E-015$

BOTH EDGES

Axial Force, $F = -211.0849$

Longitudinal Reinforcement Area Distribution (in 2 divisions)

-Tension: $A_{st} = 603.1858$

-Compression: $A_{sc} = 923.6282$

Longitudinal Reinforcement Area Distribution (in 3 divisions)

-Tension: $A_{st,ten} = 508.938$

-Compression: $A_{sc,com} = 508.938$

-Middle: $A_{st,mid} = 508.938$

Calculation of Shear Capacity ratio, $V_e/V_r = 0.79211753$

Member Controlled by Flexure ($V_e/V_r < 1$)

Calculation of Shear Demand from fig. R18.6.5, ACI 318-14 $V_e = (M_{pr1} + M_{pr2})/l_n \pm w_u \cdot l_n/2 = 137993.601$
with

$M_{pr1} = \text{Max}(M_{u1+}, M_{u1-}) = 1.2764E+008$

$M_{u1+} = 1.2764E+008$, is the ultimate moment strength at the edge 1 of the member in the actual moment direction which is defined for the static loading combination

$M_{u1-} = 1.2764E+008$, is the ultimate moment strength at the edge 1 of the member in the opposite moment direction which is defined for the static loading combination

$M_{pr2} = \text{Max}(M_{u2+}, M_{u2-}) = 1.2764E+008$

$M_{u2+} = 1.2764E+008$, is the ultimate moment strength at the edge 2 of the member in the actual moment direction which is defined for the static loading combination

$M_{u2-} = 1.2764E+008$, is the ultimate moment strength at the edge 2 of the member in the opposite moment

direction which is defined for the the static loading combination
and

$$\pm wu*ln = (|V1| + |V2|)/2$$

with

V1 = -3.6870970E-015, is the shear force acting at edge 1 for the the static loading combination

V2 = 3.6870970E-015, is the shear force acting at edge 2 for the the static loading combination

Calculation of Mu1+

Calculation of ultimate curvature ϕ_u according to 4.1, Biskinis/Fardis 2013:

$$u = 0.00015613$$

$$Mu = 1.2764E+008$$

with full section properties:

$$b = 400.00$$

$$d = 258.00$$

$$d' = 42.00$$

$$v = 8.5224858E-005$$

$$N = 211.0849$$

$$fc = 24.00$$

$$co \text{ (5A.5, TBDY)} = 0.002$$

$$\text{Final value of } \phi_u: \phi_u^* = \text{shear_factor} * \text{Max}(\phi_u, \phi_c) = 0.00773686$$

The Shear_factor is considered equal to 1 (pure moment strength)

$$\text{From (5.4b), TBDY: } \phi_u = 0.00773686$$

$$\phi_{ue} \text{ (5.4c)} = 0.01121936$$

$$\phi_{ase} \text{ ((5.4d), TBDY)} = 0.15672608$$

$$b_o = 240.00$$

$$h_o = 340.00$$

$$b_i^2 = 346400.00$$

$$\phi_{sh,min} = \text{Min}(\phi_{sh,x}, \phi_{sh,y}) = 0.00261799$$

 $\phi_{sh,x} \text{ (5.4d)} = 0.00349066$

$$A_{sh} = A_{stir} * n_s = 78.53982$$

$$\text{No stirups, } n_s = 2.00$$

$$b_k = 300.00$$

 $\phi_{sh,y} \text{ (5.4d)} = 0.00261799$

$$A_{sh} = A_{stir} * n_s = 78.53982$$

$$\text{No stirups, } n_s = 2.00$$

$$b_k = 400.00$$

 $s = 150.00$

$$f_{ywe} = 656.25$$

$$f_{ce} = 24.00$$

$$\text{From ((5.A5), TBDY), TBDY: } \phi_c = 0.00290026$$

$$c = \text{confinement factor} = 1.09003$$

$$y_1 = 0.0025$$

$$sh_1 = 0.008$$

$$ft_1 = 787.50$$

$$fy_1 = 656.25$$

$$su_1 = 0.032$$

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor

and also multiplied by the shear_factor according to 15.7.1.4, with

Shear_factor = 1.00

$$l_o/l_{ou,min} = l_b/l_d = 1.00$$

$$su_1 = 0.4 * esu_{1,nominal} \text{ ((5.5), TBDY)} = 0.032$$

$$\text{From table 5A.1, TBDY: } esu_{1,nominal} = 0.08,$$

For calculation of $esu_{1,nominal}$ and y_1, sh_1, ft_1, fy_1 , it is considered

characteristic value $fsy_1 = fs_1/1.2$, from table 5.1, TBDY.

y_1, sh_1, ft_1, fy_1 , are also multiplied by $\text{Min}(1, 1.25 * (l_b/l_d)^{2/3})$, from 10.3.5, ASCE 41-17.

$$\text{with } fs_1 = fs = 656.25$$

$$\text{with } Es_1 = Es = 200000.00$$

$$y_2 = 0.0025$$

$$sh_2 = 0.008$$

$$ft2 = 787.50$$

$$fy2 = 656.25$$

$$su2 = 0.032$$

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00

$$lo/lou,min = lb/lb,min = 1.00$$

$$su2 = 0.4 * esu2_nominal ((5.5), TBDY) = 0.032$$

From table 5A.1, TBDY: esu2_nominal = 0.08,

For calculation of esu2_nominal and y2, sh2,ft2,fy2, it is considered
characteristic value fsy2 = fs2/1.2, from table 5.1, TBDY.

y1, sh1,ft1,fy1, are also multiplied by $\text{Min}(1, 1.25 * (lb/ld)^{2/3})$, from 10.3.5, ASCE 41-17.

$$\text{with } fs2 = fs = 656.25$$

$$\text{with } Es2 = Es = 200000.00$$

$$yv = 0.0025$$

$$shv = 0.008$$

$$ftv = 787.50$$

$$fyv = 656.25$$

$$suv = 0.032$$

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00

$$lo/lou,min = lb/ld = 1.00$$

$$suv = 0.4 * esuv_nominal ((5.5), TBDY) = 0.032$$

From table 5A.1, TBDY: esuv_nominal = 0.08,

considering characteristic value fsyv = fsv/1.2, from table 5.1, TBDY

For calculation of esuv_nominal and yv, shv,ftv,fyv, it is considered
characteristic value fsyv = fsv/1.2, from table 5.1, TBDY.

y1, sh1,ft1,fy1, are also multiplied by $\text{Min}(1, 1.25 * (lb/ld)^{2/3})$, from 10.3.5, ASCE 41-17.

$$\text{with } fsv = fs = 656.25$$

$$\text{with } Esv = Es = 200000.00$$

$$1 = Asl,ten/(b*d)*(fs1/fc) = 0.13484761$$

$$2 = Asl,com/(b*d)*(fs2/fc) = 0.13484761$$

$$v = Asl,mid/(b*d)*(fsv/fc) = 0.13484761$$

and confined core properties:

$$b = 340.00$$

$$d = 228.00$$

$$d' = 12.00$$

$$fcc (5A.2, TBDY) = 26.16063$$

$$cc (5A.5, TBDY) = 0.00290026$$

$$c = \text{confinement factor} = 1.09003$$

$$1 = Asl,ten/(b*d)*(fs1/fc) = 0.17951849$$

$$2 = Asl,com/(b*d)*(fs2/fc) = 0.17951849$$

$$v = Asl,mid/(b*d)*(fsv/fc) = 0.17951849$$

Case/Assumption: Unconfined full section - Steel rupture

' does not satisfy Eq. (4.3)

---->

$v < vs,c$ - RHS eq.(4.5) is satisfied

---->

$$su (4.9) = 0.20560388$$

$$Mu = MRc (4.14) = 1.2764E+008$$

$$u = su (4.1) = 0.00015613$$

Calculation of ratio lb/ld

Adequate Lap Length: $lb/ld \geq 1$

Calculation of Mu1-

Calculation of ultimate curvature u according to 4.1, Biskinis/Fardis 2013:

$$u = 0.00015613$$

$$Mu = 1.2764E+008$$

with full section properties:

$$b = 400.00$$

$$d = 258.00$$

$$d' = 42.00$$

$$v = 8.5224858E-005$$

$$N = 211.0849$$

$$f_c = 24.00$$

$$c_o (5A.5, TBDY) = 0.002$$

$$\text{Final value of } c_u: c_u^* = \text{shear_factor} * \text{Max}(c_u, c_c) = 0.00773686$$

The Shear_factor is considered equal to 1 (pure moment strength)

$$\text{From (5.4b), TBDY: } c_u = 0.00773686$$

$$w_e (5.4c) = 0.01121936$$

$$a_{se} ((5.4d), TBDY) = 0.15672608$$

$$b_o = 240.00$$

$$h_o = 340.00$$

$$b_i^2 = 346400.00$$

$$p_{sh,min} = \text{Min}(p_{sh,x}, p_{sh,y}) = 0.00261799$$

$$p_{sh,x} (5.4d) = 0.00349066$$

$$A_{sh} = A_{stir} * n_s = 78.53982$$

No stirrups, $n_s = 2.00$

$$b_k = 300.00$$

$$p_{sh,y} (5.4d) = 0.00261799$$

$$A_{sh} = A_{stir} * n_s = 78.53982$$

No stirrups, $n_s = 2.00$

$$b_k = 400.00$$

$$s = 150.00$$

$$f_{ywe} = 656.25$$

$$f_{ce} = 24.00$$

$$\text{From ((5.A5), TBDY), TBDY: } c_c = 0.00290026$$

$$c = \text{confinement factor} = 1.09003$$

$$y_1 = 0.0025$$

$$sh_1 = 0.008$$

$$ft_1 = 787.50$$

$$fy_1 = 656.25$$

$$su_1 = 0.032$$

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor and also multiplied by the shear_factor according to 15.7.1.4, with Shear_factor = 1.00

$$l_o/l_{o,min} = l_b/d = 1.00$$

$$su_1 = 0.4 * esu_{1,nominal} ((5.5), TBDY) = 0.032$$

$$\text{From table 5A.1, TBDY: } esu_{1,nominal} = 0.08,$$

For calculation of $esu_{1,nominal}$ and y_1, sh_1, ft_1, fy_1 , it is considered characteristic value $fsy_1 = fs_1/1.2$, from table 5.1, TBDY.

$$y_1, sh_1, ft_1, fy_1, \text{ are also multiplied by } \text{Min}(1, 1.25 * (l_b/d)^{2/3}), \text{ from 10.3.5, ASCE 41-17.}$$

$$\text{with } fs_1 = fs = 656.25$$

$$\text{with } Es_1 = Es = 200000.00$$

$$y_2 = 0.0025$$

$$sh_2 = 0.008$$

$$ft_2 = 787.50$$

$$fy_2 = 656.25$$

$$su_2 = 0.032$$

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor and also multiplied by the shear_factor according to 15.7.1.4, with Shear_factor = 1.00

$$l_o/l_{o,min} = l_b/l_{b,min} = 1.00$$

$$su_2 = 0.4 * esu_{2,nominal} ((5.5), TBDY) = 0.032$$

$$\text{From table 5A.1, TBDY: } esu_{2,nominal} = 0.08,$$

For calculation of $esu_{2,nominal}$ and y_2, sh_2, ft_2, fy_2 , it is considered characteristic value $fsy_2 = fs_2/1.2$, from table 5.1, TBDY.

$$y_2, sh_2, ft_2, fy_2, \text{ are also multiplied by } \text{Min}(1, 1.25 * (l_b/d)^{2/3}), \text{ from 10.3.5, ASCE 41-17.}$$

$$\text{with } fs_2 = fs = 656.25$$

$$\text{with } Es_2 = Es = 200000.00$$

$$y_v = 0.0025$$

$shv = 0.008$
 $ftv = 787.50$
 $fyv = 656.25$
 $suv = 0.032$
 using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
 and also multiplied by the shear_factor according to 15.7.1.4, with
 $Shear_factor = 1.00$
 $lo/lou,min = lb/ld = 1.00$
 $suv = 0.4 * esuv_nominal ((5.5), TBDY) = 0.032$
 From table 5A.1, TBDY: $esuv_nominal = 0.08$,
 considering characteristic value $fsyv = fsv/1.2$, from table 5.1, TBDY
 For calculation of $esuv_nominal$ and yv , shv,ftv,fyv , it is considered
 characteristic value $fsyv = fsv/1.2$, from table 5.1, TBDY.
 $y1, sh1,ft1,fy1$, are also multiplied by $Min(1,1.25*(lb/ld)^{2/3})$, from 10.3.5, ASCE 41-17.
 with $fsv = fs = 656.25$
 with $Esv = Es = 200000.00$
 $1 = Asl,ten/(b*d)*(fs1/fc) = 0.13484761$
 $2 = Asl,com/(b*d)*(fs2/fc) = 0.13484761$
 $v = Asl,mid/(b*d)*(fsv/fc) = 0.13484761$
 and confined core properties:
 $b = 340.00$
 $d = 228.00$
 $d' = 12.00$
 $fcc (5A.2, TBDY) = 26.16063$
 $cc (5A.5, TBDY) = 0.00290026$
 $c = confinement\ factor = 1.09003$
 $1 = Asl,ten/(b*d)*(fs1/fc) = 0.17951849$
 $2 = Asl,com/(b*d)*(fs2/fc) = 0.17951849$
 $v = Asl,mid/(b*d)*(fsv/fc) = 0.17951849$
 Case/Assumption: Unconfined full section - Steel rupture
 ' does not satisfy Eq. (4.3)
 --->
 $v < vs,c$ - RHS eq.(4.5) is satisfied
 --->
 $su (4.9) = 0.20560388$
 $Mu = MRc (4.14) = 1.2764E+008$
 $u = su (4.1) = 0.00015613$

 Calculation of ratio lb/ld

Adequate Lap Length: $lb/ld \geq 1$

 Calculation of $Mu2+$

 Calculation of ultimate curvature u according to 4.1, Biskinis/Fardis 2013:

$u = 0.00015613$
 $Mu = 1.2764E+008$

with full section properties:

$b = 400.00$
 $d = 258.00$
 $d' = 42.00$
 $v = 8.5224858E-005$
 $N = 211.0849$
 $fc = 24.00$
 $co (5A.5, TBDY) = 0.002$
 Final value of cu : $cu^* = shear_factor * Max(cu, cc) = 0.00773686$
 The Shear_factor is considered equal to 1 (pure moment strength)
 From (5.4b), TBDY: $cu = 0.00773686$
 $we (5.4c) = 0.01121936$
 $ase ((5.4d), TBDY) = 0.15672608$
 $bo = 240.00$

ho = 340.00
bi2 = 346400.00
psh,min = Min(psh,x , psh,y) = 0.00261799

psh,x (5.4d) = 0.00349066
Ash = Astir*ns = 78.53982
No stirups, ns = 2.00
bk = 300.00

psh,y (5.4d) = 0.00261799
Ash = Astir*ns = 78.53982
No stirups, ns = 2.00
bk = 400.00

s = 150.00
fywe = 656.25
fce = 24.00
From ((5.A5), TBDY), TBDY: cc = 0.00290026
c = confinement factor = 1.09003
y1 = 0.0025
sh1 = 0.008
ft1 = 787.50
fy1 = 656.25
su1 = 0.032

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00

lo/lou,min = lb/d = 1.00

su1 = 0.4*esu1_nominal ((5.5), TBDY) = 0.032

From table 5A.1, TBDY: esu1_nominal = 0.08,

For calculation of esu1_nominal and y1, sh1,ft1,fy1, it is considered
characteristic value fsy1 = fs1/1.2, from table 5.1, TBDY.

y1, sh1,ft1,fy1, are also multiplied by Min(1,1.25*(lb/d)^ 2/3), from 10.3.5, ASCE 41-17.

with fs1 = fs = 656.25

with Es1 = Es = 200000.00

y2 = 0.0025
sh2 = 0.008
ft2 = 787.50
fy2 = 656.25
su2 = 0.032

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00

lo/lou,min = lb/lb,min = 1.00

su2 = 0.4*esu2_nominal ((5.5), TBDY) = 0.032

From table 5A.1, TBDY: esu2_nominal = 0.08,

For calculation of esu2_nominal and y2, sh2,ft2,fy2, it is considered
characteristic value fsy2 = fs2/1.2, from table 5.1, TBDY.

y1, sh1,ft1,fy1, are also multiplied by Min(1,1.25*(lb/d)^ 2/3), from 10.3.5, ASCE 41-17.

with fs2 = fs = 656.25

with Es2 = Es = 200000.00

yv = 0.0025
shv = 0.008
ftv = 787.50
fyv = 656.25
suv = 0.032

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00

lo/lou,min = lb/d = 1.00

suv = 0.4*esuv_nominal ((5.5), TBDY) = 0.032

From table 5A.1, TBDY: esuv_nominal = 0.08,

considering characteristic value fsyv = fsv/1.2, from table 5.1, TBDY

For calculation of esuv_nominal and yv, shv,ftv,fyv, it is considered
characteristic value fsyv = fsv/1.2, from table 5.1, TBDY.

y1, sh1,ft1,fy1, are also multiplied by Min(1,1.25*(lb/d)^ 2/3), from 10.3.5, ASCE 41-17.

with fsv = fs = 656.25

with $E_{sv} = E_s = 200000.00$

$$1 = A_{sl,ten}/(b*d)*(f_{s1}/f_c) = 0.13484761$$

$$2 = A_{sl,com}/(b*d)*(f_{s2}/f_c) = 0.13484761$$

$$v = A_{sl,mid}/(b*d)*(f_{sv}/f_c) = 0.13484761$$

and confined core properties:

$$b = 340.00$$

$$d = 228.00$$

$$d' = 12.00$$

$$f_{cc} (5A.2, TBDY) = 26.16063$$

$$c_c (5A.5, TBDY) = 0.00290026$$

$$c = \text{confinement factor} = 1.09003$$

$$1 = A_{sl,ten}/(b*d)*(f_{s1}/f_c) = 0.17951849$$

$$2 = A_{sl,com}/(b*d)*(f_{s2}/f_c) = 0.17951849$$

$$v = A_{sl,mid}/(b*d)*(f_{sv}/f_c) = 0.17951849$$

Case/Assumption: Unconfined full section - Steel rupture

' does not satisfy Eq. (4.3)

--->

$v < v_{s,c}$ - RHS eq.(4.5) is satisfied

--->

$$s_u (4.9) = 0.20560388$$

$$M_u = M_{Rc} (4.14) = 1.2764E+008$$

$$u = s_u (4.1) = 0.00015613$$

Calculation of ratio l_b/d

Adequate Lap Length: $l_b/d \geq 1$

Calculation of M_{u2}

Calculation of ultimate curvature ϕ_u according to 4.1, Biskinis/Fardis 2013:

$$u = 0.00015613$$

$$M_u = 1.2764E+008$$

with full section properties:

$$b = 400.00$$

$$d = 258.00$$

$$d' = 42.00$$

$$v = 8.5224858E-005$$

$$N = 211.0849$$

$$f_c = 24.00$$

$$c_c (5A.5, TBDY) = 0.002$$

$$\text{Final value of } \phi_u: \phi_u^* = \text{shear_factor} * \text{Max}(\phi_{cu}, \phi_{cc}) = 0.00773686$$

The Shear_factor is considered equal to 1 (pure moment strength)

$$\text{From (5.4b), TBDY: } \phi_{cu} = 0.00773686$$

$$\phi_{we} (5.4c) = 0.01121936$$

$$\phi_{ase} ((5.4d), TBDY) = 0.15672608$$

$$b_o = 240.00$$

$$h_o = 340.00$$

$$b_{i2} = 346400.00$$

$$\phi_{psh,min} = \text{Min}(\phi_{psh,x}, \phi_{psh,y}) = 0.00261799$$

$$\phi_{psh,x} (5.4d) = 0.00349066$$

$$A_{sh} = A_{stir} * n_s = 78.53982$$

$$\text{No stirups, } n_s = 2.00$$

$$b_k = 300.00$$

$$\phi_{psh,y} (5.4d) = 0.00261799$$

$$A_{sh} = A_{stir} * n_s = 78.53982$$

$$\text{No stirups, } n_s = 2.00$$

$$b_k = 400.00$$

$$s = 150.00$$

$$fy_{we} = 656.25$$

$$f_{ce} = 24.00$$

From (5A.5), TBDY, TBDY: $cc = 0.00290026$

$$c = \text{confinement factor} = 1.09003$$

$$y_1 = 0.0025$$

$$sh_1 = 0.008$$

$$ft_1 = 787.50$$

$$fy_1 = 656.25$$

$$su_1 = 0.032$$

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00

$$lo/lou, \min = lb/ld = 1.00$$

$$su_1 = 0.4 * esu_{1_nominal} ((5.5), TBDY) = 0.032$$

From table 5A.1, TBDY: $esu_{1_nominal} = 0.08$,

For calculation of $esu_{1_nominal}$ and y_1, sh_1, ft_1, fy_1 , it is considered
characteristic value $fsy_1 = fs_1/1.2$, from table 5.1, TBDY.

y_1, sh_1, ft_1, fy_1 , are also multiplied by $\text{Min}(1, 1.25 * (lb/ld)^{2/3})$, from 10.3.5, ASCE 41-17.

$$\text{with } fs_1 = fs = 656.25$$

$$\text{with } Es_1 = Es = 200000.00$$

$$y_2 = 0.0025$$

$$sh_2 = 0.008$$

$$ft_2 = 787.50$$

$$fy_2 = 656.25$$

$$su_2 = 0.032$$

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00

$$lo/lou, \min = lb/lb, \min = 1.00$$

$$su_2 = 0.4 * esu_{2_nominal} ((5.5), TBDY) = 0.032$$

From table 5A.1, TBDY: $esu_{2_nominal} = 0.08$,

For calculation of $esu_{2_nominal}$ and y_2, sh_2, ft_2, fy_2 , it is considered
characteristic value $fsy_2 = fs_2/1.2$, from table 5.1, TBDY.

y_1, sh_1, ft_1, fy_1 , are also multiplied by $\text{Min}(1, 1.25 * (lb/ld)^{2/3})$, from 10.3.5, ASCE 41-17.

$$\text{with } fs_2 = fs = 656.25$$

$$\text{with } Es_2 = Es = 200000.00$$

$$y_v = 0.0025$$

$$sh_v = 0.008$$

$$ft_v = 787.50$$

$$fy_v = 656.25$$

$$su_v = 0.032$$

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00

$$lo/lou, \min = lb/ld = 1.00$$

$$su_v = 0.4 * esu_{v_nominal} ((5.5), TBDY) = 0.032$$

From table 5A.1, TBDY: $esu_{v_nominal} = 0.08$,

considering characteristic value $fsy_v = fsv/1.2$, from table 5.1, TBDY
For calculation of $esu_{v_nominal}$ and y_v, sh_v, ft_v, fy_v , it is considered
characteristic value $fsy_v = fsv/1.2$, from table 5.1, TBDY.

y_1, sh_1, ft_1, fy_1 , are also multiplied by $\text{Min}(1, 1.25 * (lb/ld)^{2/3})$, from 10.3.5, ASCE 41-17.

$$\text{with } fsv = fs = 656.25$$

$$\text{with } Es_v = Es = 200000.00$$

$$1 = Asl, \text{ten} / (b * d) * (fs_1 / f_c) = 0.13484761$$

$$2 = Asl, \text{com} / (b * d) * (fs_2 / f_c) = 0.13484761$$

$$v = Asl, \text{mid} / (b * d) * (fsv / f_c) = 0.13484761$$

and confined core properties:

$$b = 340.00$$

$$d = 228.00$$

$$d' = 12.00$$

$$fcc (5A.2, TBDY) = 26.16063$$

$$cc (5A.5, TBDY) = 0.00290026$$

$$c = \text{confinement factor} = 1.09003$$

$$1 = Asl, \text{ten} / (b * d) * (fs_1 / f_c) = 0.17951849$$

$$2 = Asl, \text{com} / (b * d) * (fs_2 / f_c) = 0.17951849$$

$$v = Asl, \text{mid} / (b * d) * (fsv / f_c) = 0.17951849$$

Case/Assumption: Unconfinedsd full section - Steel rupture

' does not satisfy Eq. (4.3)

---->

$v < v_{s,c}$ - RHS eq.(4.5) is satisfied

---->

μ_u (4.9) = 0.20560388

$M_u = M_{Rc}$ (4.14) = 1.2764E+008

$u = \mu_u$ (4.1) = 0.00015613

Calculation of ratio l_b/d

Adequate Lap Length: $l_b/d \geq 1$

Calculation of Shear Strength $V_r = \text{Min}(V_{r1}, V_{r2}) = 174208.493$

Calculation of Shear Strength at edge 1, $V_{r1} = 174208.493$

$V_{r1} = V_n$ ((22.5.1.1), ACI 318-14)

NOTE: In expression (22.5.1.1) ' V_w ' is replaced by ' $V_w + f \cdot V_f$ '
where V_f is the contribution of FRPs (11.3), ACI 440).

From Table (22.5.5.1), ACI 318-14: $V_c = 75248.325$

= 1 (normal-weight concrete)

$f_c' = 24.00$, but $f_c'^{0.5} \leq 8.3$ MPa (22.5.3.1, ACI 318-14)

$\rho_w = A_s/(b_w \cdot d) = 0.00628319$

A_s (tension reinf.) = 603.1858

$b_w = 400.00$

$d = 240.00$

$V_u \cdot d / M_u < 1 = 0.00$

$M_u = 7.6252677E-012$

$V_u = 3.6870970E-015$

From (11.5.4.8), ACI 318-14: $V_s = 98960.169$

$A_v = 157079.633$

$f_y = 525.00$

$s = 150.00$

V_s has been multiplied by $2(1-s/d)$ ($s > d/2$, according to ASCE 41-17,10.3.4)

$2(1-s/d) = 0.75$

V_f ((11-3)-(11.4), ACI 440) = 0.00

From (11-11), ACI 440: $V_s + V_f \leq 312423.44$

Calculation of Shear Strength at edge 2, $V_{r2} = 174208.493$

$V_{r2} = V_n$ ((22.5.1.1), ACI 318-14)

NOTE: In expression (22.5.1.1) ' V_w ' is replaced by ' $V_w + f \cdot V_f$ '
where V_f is the contribution of FRPs (11.3), ACI 440).

From Table (22.5.5.1), ACI 318-14: $V_c = 75248.325$

= 1 (normal-weight concrete)

$f_c' = 24.00$, but $f_c'^{0.5} \leq 8.3$ MPa (22.5.3.1, ACI 318-14)

$\rho_w = A_s/(b_w \cdot d) = 0.00628319$

A_s (tension reinf.) = 603.1858

$b_w = 400.00$

$d = 240.00$

$V_u \cdot d / M_u < 1 = 0.00$

$M_u = 8.0393416E-013$

$V_u = 3.6870970E-015$

From (11.5.4.8), ACI 318-14: $V_s = 98960.169$

$A_v = 157079.633$

$f_y = 525.00$

$s = 150.00$

V_s has been multiplied by $2(1-s/d)$ ($s > d/2$, according to ASCE 41-17,10.3.4)

$2(1-s/d) = 0.75$

V_f ((11-3)-(11.4), ACI 440) = 0.00

From (11-11), ACI 440: $V_s + V_f \leq 312423.44$

End Of Calculation of Shear Capacity ratio for element: beam B1 of floor 1
At local axis: 2

Start Of Calculation of Chord Rotation Capacity for element: beam B1 of floor 1
At local axis: 3
Integration Section: (b)
Section Type: rcars

Constant Properties

Knowledge Factor, $\gamma = 1.00$
Chord Rotation is generally considered as Deformation-Controlled Action according to Table C7-1, ASCE 41-17.
Mean strengths are used for Deformation-Controlled Actions according to 7.5.1.3, ASCE 41-17
Consequently:
Existing material of Primary Member: Concrete Strength, $f_c = f_{cm} = 24.00$
Existing material of Primary Member: Steel Strength, $f_s = f_{sm} = 525.00$
Concrete Elasticity, $E_c = 23025.204$
Steel Elasticity, $E_s = 200000.00$
Section Height, $H = 400.00$
Section Width, $W = 300.00$
Cover Thickness, $c = 25.00$
Element Length, $L = 1850.00$
Primary Member
Smooth Bars
Ductile Steel
With Detailing for Earthquake Resistance (including stirrups closed at 135°)
Longitudinal Bars With Ends Lapped Starting at the End Sections
Adequate Lap Length ($l_b/d >= 1$)
No FRP Wrapping

Stepwise Properties

Bending Moment, $M = 6.7903689E-011$
Shear Force, $V_2 = -3.0430585E-014$
Shear Force, $V_3 = 8685.666$
Axial Force, $F = -560.8745$
Longitudinal Reinforcement Area Distribution (in 2 divisions)
-Tension: $A_{sl,t} = 615.7522$
-Compression: $A_{sl,c} = 911.0619$
Longitudinal Reinforcement Area Distribution (in 3 divisions)
-Tension: $A_{sl,ten} = 508.938$
-Compression: $A_{sl,com} = 508.938$
-Middle: $A_{sl,mid} = 508.938$
Mean Diameter of Tension Reinforcement, $DbL = 14.66667$

Existing component: From table 7-7, ASCE 41_17: Final chord rotation Capacity $u_{,R} = \gamma \cdot u = 0.00904335$
 $u = \gamma \cdot u + p = 0.00904335$

- Calculation of γ -

$\gamma = (M_y \cdot L_s / 3) / E_{eff} = 0.00404335$ ((4.29), Biskinis Phd)
 $M_y = 8.1525E+007$
 $L_s = M/V$ (with $L_s > 0.1 \cdot L$ and $L_s < 2 \cdot L$) = 925.00
From table 10.5, ASCE 41_17: $E_{eff} = 0.3 \cdot E_c \cdot I_g = 6.2168E+012$

Calculation of Yielding Moment M_y

Calculation of ϕ_y and M_y according to Annex 7 -

$y = \text{Min}(y_{\text{ten}}, y_{\text{com}})$
 $y_{\text{ten}} = 1.4111768\text{E-}005$
with $f_y = 525.00$
 $d = 258.00$
 $y = 0.27901178$
 $A = 0.01480506$
 $B = 0.00861193$
with $p_t = 0.00493157$
 $p_c = 0.00493157$
 $p_v = 0.00493157$
 $N = 560.8745$
 $b = 400.00$
 $\phi = 0.1627907$
 $y_{\text{comp}} = 2.6070636\text{E-}005$
with $f_c = 24.00$
 $E_c = 23025.204$
 $y = 0.2789388$
 $A = 0.01478023$
 $B = 0.00860158$
with $E_s = 200000.00$

Calculation of ratio l_b/d

Adequate Lap Length: $l_b/d \geq 1$

- Calculation of ρ_p -

From table 10-7: $\rho_p = 0.005$

with:

- Condition i occurred

Beam controlled by flexure: $V_p/V_o \leq 1$

shear control ratio $V_p/V_o = 0.79211753$

- Transverse Reinforcement: NC

- Stirrup Spacing $> d/3$

- Low ductility demand, $\phi_y < 2$ (table 10-6, ASCE 41-17)

$= 7.1684405\text{E-}022$

- Stirrup Spacing $> d/2$

$d = 258.00$

$s = 150.00$

- Strength provided by hoops $V_s < 3/4$ *design Shear

$V_s = 131946.891$, already given in calculation of shear control ratio

design Shear = $3.0430585\text{E-}014$

- ($\rho_p - \rho_{\text{bal}}$) / $\rho_{\text{bal}} = -0.16244618$

$= A_{s1}/(b_w*d) = 0.00596659$

Tension Reinf Area: $A_{s1} = 615.7522$

$\rho_c = A_{s2}/(b_w*d) = 0.00882812$

Compression Reinf Area: $A_{s2} = 911.0619$

From (B-1), ACI 318-11: $\rho_{\text{bal}} = 0.01761524$

$f_c = 24.00$

$f_y = 525.00$

From 10.2.7.3, ACI 318-11: $\phi = 0.85$

From fig R10.3.3, ACI 318-11 (Ence 454, too): $87000/(87000 + f_y) = c_b/d_t = 0.003/(0.003 + \phi_y) = 0.53333333$

$\phi_y = 0.002625$

- $V/(b_w*d*f_c^{0.5}) = 7.2485011\text{E-}019$, NOTE: units in lb & in

$b_w = 400.00$

End Of Calculation of Chord Rotation Capacity for element: beam B1 of floor 1

At local axis: 3

Integration Section: (b)

Calculation No. 9

beam B1, Floor 1



Limit State: Life Safety (data interpolation between analysis steps 1 and 2)

Analysis: Uniform +X

Check: Shear capacity VRd

Edge: Start

Local Axis: (2)



Start Of Calculation of Shear Capacity for element: beam B1 of floor 1

At local axis: 2

Integration Section: (a)

Section Type: rcars

Constant Properties

Knowledge Factor, $\gamma = 1.00$

Member Shear Force is generally considered as Force-Controlled Action according to Table C7-1, ASCE 41-17.

Lower-bound strengths are used for Force-Controlled Actions according to 7.5.1.3, ASCE 41-17

Consequently:

Existing material of Primary Member: Concrete Strength, $f_c = f_{c_lower_bound} = 16.00$

Existing material of Primary Member: Steel Strength, $f_s = f_{s_lower_bound} = 420.00$

Concrete Elasticity, $E_c = 23025.204$

Steel Elasticity, $E_s = 200000.00$

Section Height, $H = 400.00$

Section Width, $W = 300.00$

Cover Thickness, $c = 25.00$

Element Length, $L = 1850.00$

Primary Member

Smooth Bars

Ductile Steel

With Detailing for Earthquake Resistance (including stirrups closed at 135°)

Longitudinal Bars With Ends Lapped Starting at the End Sections

Adequate Lap Length ($l_o/l_{o,min} = l_b/d \geq 1$)

No FRP Wrapping

Stepwise Properties

EDGE -A-

Bending Moment, $M_a = -1.0854113E-011$

Shear Force, $V_a = 2.3583230E-014$

EDGE -B-

Bending Moment, $M_b = 5.4436895E-011$

Shear Force, $V_b = -2.3583230E-014$

BOTH EDGES

Axial Force, $F = -490.6724$

Longitudinal Reinforcement Area Distribution (in 2 divisions)

-Tension: $A_{st} = 603.1858$

-Compression: $A_{sc} = 923.6282$

Longitudinal Reinforcement Area Distribution (in 3 divisions)

-Tension: $A_{s,ten} = 508.938$

-Compression: $A_{s,com} = 508.938$

-Middle: $A_{s,mid} = 508.938$

Mean Diameter of Tension Reinforcement, $D_{bL,ten} = 14.66667$

Existing component: From table 7-7, ASCE 41_17: Final Shear Capacity $V_R = V_n = 140608.135$
 V_n ((22.5.1.1), ACI 318-14) = 140608.135

NOTE: In expression (22.5.1.1) ' V_w ' is replaced by ' $V_w + f \cdot V_f$ '
where V_f is the contribution of FRPs (11.3), ACI 440).

From Table (22.5.5.1), ACI 318-14: $V_c = 61440.00$
= 1 (normal-weight concrete)

$f_c' = 16.00$, but $f_c'^{0.5} \leq 8.3$ MPa (22.5.3.1, ACI 318-14)

$\rho_w = A_s / (b_w \cdot d) = 0.00628319$

A_s (tension reinf.) = 603.1858

$b_w = 400.00$

$d = 240.00$

$V_u \cdot d / M_u < 1 = 0.00$

$M_u = 1.0854113E-011$

$V_u = 2.3583230E-014$

From (11.5.4.8), ACI 318-14: $V_s = 79168.135$

$A_v = 157079.633$

$f_y = 420.00$

$s = 150.00$

V_s has been multiplied by $2(1-s/d)$ ($s > d/2$, according to ASCE 41-17,10.3.4)

$2(1-s/d) = 0.75$

V_f ((11-3)-(11.4), ACI 440) = 0.00

From (11-11), ACI 440: $V_s + V_f \leq 255092.67$

End Of Calculation of Shear Capacity for element: beam B1 of floor 1

At local axis: 2

Integration Section: (a)

Calculation No. 10

beam B1, Floor 1



Limit State: Life Safety (data interpolation between analysis steps 1 and 2)

Analysis: Uniform +X

Check: Chord rotation capacity (θ_r)

Edge: Start

Local Axis: (2)



Start Of Calculation of Shear Capacity ratio for element: beam B1 of floor 1

At Shear local axis: 3

(Bending local axis: 2)

Section Type: rcars

Constant Properties

Knowledge Factor, $\gamma = 1.00$

Mean strength values are used for both shear and moment calculations.

Consequently:

Existing material of Primary Member: Concrete Strength, $f_c = f_{cm} = 24.00$

Existing material of Primary Member: Steel Strength, $f_s = f_{sm} = 525.00$

Concrete Elasticity, $E_c = 23025.204$

Steel Elasticity, $E_s = 200000.00$

#####

Note: Especially for the calculation of moment strengths,

the above steel re-bar strengths are multiplied by 1.25 according to R18.6.5, ACI 318-14

Existing material: Steel Strength, $f_s = 1.25 \cdot f_{sm} = 656.25$

#####

Section Height, $H = 400.00$

Section Width, $W = 300.00$

Cover Thickness, $c = 25.00$

Mean Confinement Factor overall section = 1.09003

Element Length, $L = 1850.00$

Primary Member

Smooth Bars

Ductile Steel

With Detailing for Earthquake Resistance (including stirrups closed at 135°)

Longitudinal Bars With Ends Lapped Starting at the End Sections

Adequate Lap Length ($l_o/l_{o,u,min} \geq 1$)

No FRP Wrapping

Stepwise Properties

At local axis: 3

EDGE -A-

Shear Force, $V_a = 2740.265$

EDGE -B-

Shear Force, $V_b = 2740.264$
BOTH EDGES
Axial Force, $F = -211.0849$
Longitudinal Reinforcement Area Distribution (in 2 divisions)
-Tension: $As_t = 603.1858$
-Compression: $As_c = 923.6282$
Longitudinal Reinforcement Area Distribution (in 3 divisions)
-Tension: $As_{t,ten} = 603.1858$
-Compression: $As_{c,com} = 615.7522$
-Middle: $As_{c,mid} = 307.8761$

Calculation of Shear Capacity ratio, $V_e/V_r = 0.78793176$
Member Controlled by Flexure ($V_e/V_r < 1$)
Calculation of Shear Demand from fig. R18.6.5, ACI 318-14 $V_e = (M_{pr1} + M_{pr2})/l_n \pm w_u \cdot l_n/2 = 205990.317$
with
 $M_{pr1} = \text{Max}(Mu_{1+}, Mu_{1-}) = 1.8802E+008$
 $Mu_{1+} = 1.8495E+008$, is the ultimate moment strength at the edge 1 of the member in the actual moment direction
which is defined for the static loading combination
 $Mu_{1-} = 1.8802E+008$, is the ultimate moment strength at the edge 1 of the member in the opposite moment
direction which is defined for the static loading combination
 $M_{pr2} = \text{Max}(Mu_{2+}, Mu_{2-}) = 1.8800E+008$
 $Mu_{2+} = 1.8498E+008$, is the ultimate moment strength at the edge 2 of the member in the actual moment direction
which is defined for the the static loading combination
 $Mu_{2-} = 1.8800E+008$, is the ultimate moment strength at the edge 2 of the member in the opposite moment
direction which is defined for the the static loading combination
and
 $\pm w_u \cdot l_n = (|V_1| + |V_2|)/2$
with
 $V_1 = 2740.265$, is the shear force acting at edge 1 for the the static loading combination
 $V_2 = 2740.264$, is the shear force acting at edge 2 for the the static loading combination

Calculation of Mu_{1+}

Calculation of ultimate curvature ϕ_u according to 4.1, Biskinis/Fardis 2013:
 $\phi_u = 0.0001071$
 $Mu = 1.8495E+008$

with full section properties:

$b = 300.00$
 $d = 357.00$
 $d' = 42.00$
 $v = 8.2121432E-005$
 $N = 211.0849$
 $f_c = 24.00$

ϕ_c (5A.5, TBDY) = 0.002

Final value of ϕ_u : $\phi_u^* = \text{shear_factor} \cdot \text{Max}(\phi_u, \phi_c) = 0.00773686$

The Shear_factor is considered equal to 1 (pure moment strength)

From (5.4b), TBDY: $\phi_u = 0.00773686$

w_e (5.4c) = 0.01121936

a_{se} ((5.4d), TBDY) = 0.15672608

$b_o = 240.00$

$h_o = 340.00$

$bi_2 = 346400.00$

$p_{sh,min} = \text{Min}(p_{sh,x}, p_{sh,y}) = 0.00261799$

 $p_{sh,x}$ (5.4d) = 0.00349066

$A_{sh} = A_{stir} \cdot n_s = 78.53982$

No stirups, $n_s = 2.00$

$b_k = 300.00$

 $p_{sh,y}$ (5.4d) = 0.00261799

Ash = Astir*ns = 78.53982
No stirups, ns = 2.00
bk = 400.00

s = 150.00
fywe = 656.25
fce = 24.00

From ((5.A.5), TBDY), TBDY: cc = 0.00290026
c = confinement factor = 1.09003

y1 = 0.0025
sh1 = 0.008
ft1 = 787.50
fy1 = 656.25
su1 = 0.032

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00

lo/lou,min = lb/lb,min = 1.00

su1 = 0.4*esu1_nominal ((5.5), TBDY) = 0.032

From table 5A.1, TBDY: esu1_nominal = 0.08,

For calculation of esu1_nominal and y1, sh1,ft1,fy1, it is considered
characteristic value fsy1 = fs1/1.2, from table 5.1, TBDY.

y1, sh1,ft1,fy1, are also multiplied by $\text{Min}(1, 1.25 \cdot (lb/lb)^{2/3})$, from 10.3.5, ASCE 41-17.

with fs1 = fs = 656.25

with Es1 = Es = 200000.00

y2 = 0.0025
sh2 = 0.008
ft2 = 787.50
fy2 = 656.25
su2 = 0.032

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00

lo/lou,min = lb/lb,min = 1.00

su2 = 0.4*esu2_nominal ((5.5), TBDY) = 0.032

From table 5A.1, TBDY: esu2_nominal = 0.08,

For calculation of esu2_nominal and y2, sh2,ft2,fy2, it is considered
characteristic value fsy2 = fs2/1.2, from table 5.1, TBDY.

y1, sh1,ft1,fy1, are also multiplied by $\text{Min}(1, 1.25 \cdot (lb/lb)^{2/3})$, from 10.3.5, ASCE 41-17.

with fs2 = fs = 656.25

with Es2 = Es = 200000.00

yv = 0.0025
shv = 0.008
ftv = 787.50
fyv = 656.25
suv = 0.032

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00

lo/lou,min = lb/lb,min = 1.00

suv = 0.4*esuv_nominal ((5.5), TBDY) = 0.032

From table 5A.1, TBDY: esuv_nominal = 0.08,

considering characteristic value fsyv = fsv/1.2, from table 5.1, TBDY
For calculation of esuv_nominal and yv, shv,ftv,fyv, it is considered
characteristic value fsyv = fsv/1.2, from table 5.1, TBDY.

y1, sh1,ft1,fy1, are also multiplied by $\text{Min}(1, 1.25 \cdot (lb/lb)^{2/3})$, from 10.3.5, ASCE 41-17.

with fsv = fs = 656.25

with Esv = Es = 200000.00

1 = Asl,ten/(b*d)*(fs1/fc) = 0.15399964

2 = Asl,com/(b*d)*(fs2/fc) = 0.15720797

v = Asl,mid/(b*d)*(fsv/fc) = 0.07860398

and confined core properties:

b = 240.00
d = 327.00
d' = 12.00

fcc (5A.2, TBDY) = 26.16063

cc (5A.5, TBDY) = 0.00290026

c = confinement factor = 1.09003

1 = $Asl,ten/(b*d)*(fs1/fc) = 0.21016006$

2 = $Asl,com/(b*d)*(fs2/fc) = 0.21453839$

v = $Asl,mid/(b*d)*(fsv/fc) = 0.1072692$

Case/Assumption: Unconfined full section - Steel rupture

' satisfies Eq. (4.3)

v < vs,y2 - LHS eq.(4.5) is satisfied

su (4.9) = 0.1630814

Mu = MRc (4.14) = 1.8495E+008

u = su (4.1) = 0.0001071

Calculation of ratio lb/l_d

Adequate Lap Length: lb/l_d >= 1

Calculation of Mu1-

Calculation of ultimate curvature u according to 4.1, Biskinis/Fardis 2013:

u = 0.00010722

Mu = 1.8802E+008

with full section properties:

b = 300.00

d = 358.00

d' = 43.00

v = 8.1892042E-005

N = 211.0849

fc = 24.00

co (5A.5, TBDY) = 0.002

Final value of cu: $cu^* = shear_factor * Max(cu, cc) = 0.00773686$

The Shear_factor is considered equal to 1 (pure moment strength)

From (5.4b), TBDY: cu = 0.00773686

we (5.4c) = 0.01121936

ase ((5.4d), TBDY) = 0.15672608

bo = 240.00

ho = 340.00

bi2 = 346400.00

psh,min = Min(psh,x , psh,y) = 0.00261799

psh,x (5.4d) = 0.00349066

Ash = Astir*ns = 78.53982

No stirups, ns = 2.00

bk = 300.00

psh,y (5.4d) = 0.00261799

Ash = Astir*ns = 78.53982

No stirups, ns = 2.00

bk = 400.00

s = 150.00

fywe = 656.25

fce = 24.00

From ((5.A5), TBDY), TBDY: cc = 0.00290026

c = confinement factor = 1.09003

y1 = 0.0025

sh1 = 0.008

ft1 = 787.50

fy1 = 656.25

su1 = 0.032

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor

and also multiplied by the shear_factor according to 15.7.1.4, with

Shear_factor = 1.00

lo/lou,min = lb/d = 1.00

su1 = 0.4*esu1_nominal ((5.5), TBDY) = 0.032

From table 5A.1, TBDY: esu1_nominal = 0.08,

For calculation of esu1_nominal and y1, sh1,ft1,fy1, it is considered characteristic value fsy1 = fs1/1.2, from table 5.1, TBDY.

y1, sh1,ft1,fy1, are also multiplied by Min(1,1.25*(lb/d)^2/3), from 10.3.5, ASCE 41-17.

with fs1 = fs = 656.25

with Es1 = Es = 200000.00

y2 = 0.0025

sh2 = 0.008

ft2 = 787.50

fy2 = 656.25

su2 = 0.032

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor

and also multiplied by the shear_factor according to 15.7.1.4, with

Shear_factor = 1.00

lo/lou,min = lb/lb,min = 1.00

su2 = 0.4*esu2_nominal ((5.5), TBDY) = 0.032

From table 5A.1, TBDY: esu2_nominal = 0.08,

For calculation of esu2_nominal and y2, sh2,ft2,fy2, it is considered characteristic value fsy2 = fs2/1.2, from table 5.1, TBDY.

y1, sh1,ft1,fy1, are also multiplied by Min(1,1.25*(lb/d)^2/3), from 10.3.5, ASCE 41-17.

with fs2 = fs = 656.25

with Es2 = Es = 200000.00

yv = 0.0025

shv = 0.008

ftv = 787.50

fyv = 656.25

suv = 0.032

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor

and also multiplied by the shear_factor according to 15.7.1.4, with

Shear_factor = 1.00

lo/lou,min = lb/d = 1.00

suv = 0.4*esuv_nominal ((5.5), TBDY) = 0.032

From table 5A.1, TBDY: esuv_nominal = 0.08,

considering characteristic value fsyv = fsv/1.2, from table 5.1, TBDY

For calculation of esuv_nominal and yv, shv,ftv,fyv, it is considered characteristic value fsyv = fsv/1.2, from table 5.1, TBDY.

y1, sh1,ft1,fy1, are also multiplied by Min(1,1.25*(lb/d)^2/3), from 10.3.5, ASCE 41-17.

with fsv = fs = 656.25

with Esv = Es = 200000.00

1 = Asl,ten/(b*d)*(fs1/fc) = 0.15676884

2 = Asl,com/(b*d)*(fs2/fc) = 0.15356947

v = Asl,mid/(b*d)*(fsv/fc) = 0.07838442

and confined core properties:

b = 240.00

d = 328.00

d' = 13.00

fcc (5A.2, TBDY) = 26.16063

cc (5A.5, TBDY) = 0.00290026

c = confinement factor = 1.09003

1 = Asl,ten/(b*d)*(fs1/fc) = 0.21388431

2 = Asl,com/(b*d)*(fs2/fc) = 0.20951933

v = Asl,mid/(b*d)*(fsv/fc) = 0.10694216

Case/Assumption: Unconfined full section - Steel rupture

' satisfies Eq. (4.3)

--->

v < vs,y2 - LHS eq.(4.5) is satisfied

--->

su (4.9) = 0.16631328

Mu = MRc (4.14) = 1.8802E+008

u = su (4.1) = 0.00010722

Calculation of ratio lb/d

Adequate Lap Length: $l_b/d \geq 1$

Calculation of μ_{2+}

Calculation of ultimate curvature μ according to 4.1, Biskinis/Fardis 2013:

$$u = 0.00010701$$

$$\mu = 1.8498E+008$$

with full section properties:

$$b = 300.00$$

$$d = 358.00$$

$$d' = 43.00$$

$$v = 8.1892042E-005$$

$$N = 211.0849$$

$$f_c = 24.00$$

$$c_o \text{ (5A.5, TBDY)} = 0.002$$

$$\text{Final value of } c_u: c_u^* = \text{shear_factor} * \text{Max}(c_u, c_c) = 0.00773686$$

The Shear_factor is considered equal to 1 (pure moment strength)

$$\text{From (5.4b), TBDY: } c_u = 0.00773686$$

$$w_e \text{ (5.4c)} = 0.01121936$$

$$a_{se} \text{ ((5.4d), TBDY)} = 0.15672608$$

$$b_o = 240.00$$

$$h_o = 340.00$$

$$b_{i2} = 346400.00$$

$$p_{sh,min} = \text{Min}(p_{sh,x}, p_{sh,y}) = 0.00261799$$

$$p_{sh,x} \text{ (5.4d)} = 0.00349066$$

$$A_{sh} = A_{stir} * n_s = 78.53982$$

$$\text{No stirups, } n_s = 2.00$$

$$b_k = 300.00$$

$$p_{sh,y} \text{ (5.4d)} = 0.00261799$$

$$A_{sh} = A_{stir} * n_s = 78.53982$$

$$\text{No stirups, } n_s = 2.00$$

$$b_k = 400.00$$

$$s = 150.00$$

$$f_{ywe} = 656.25$$

$$f_{ce} = 24.00$$

$$\text{From ((5.A5), TBDY), TBDY: } c_c = 0.00290026$$

$$c = \text{confinement factor} = 1.09003$$

$$y_1 = 0.0025$$

$$sh_1 = 0.008$$

$$ft_1 = 787.50$$

$$fy_1 = 656.25$$

$$su_1 = 0.032$$

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor and also multiplied by the shear_factor according to 15.7.1.4, with Shear_factor = 1.00

$$l_o/l_{ou,min} = l_b/d = 1.00$$

$$su_1 = 0.4 * esu_{1,nominal} \text{ ((5.5), TBDY)} = 0.032$$

$$\text{From table 5A.1, TBDY: } esu_{1,nominal} = 0.08,$$

For calculation of $esu_{1,nominal}$ and y_1, sh_1, ft_1, fy_1 , it is considered characteristic value $fsy_1 = fs_1/1.2$, from table 5.1, TBDY.

y_1, sh_1, ft_1, fy_1 , are also multiplied by $\text{Min}(1, 1.25 * (l_b/d)^{2/3})$, from 10.3.5, ASCE 41-17.

$$\text{with } fs_1 = fs = 656.25$$

$$\text{with } Es_1 = Es = 200000.00$$

$$y_2 = 0.0025$$

$$sh_2 = 0.008$$

$$ft_2 = 787.50$$

$$fy_2 = 656.25$$

$$su_2 = 0.032$$

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00

lo/lou,min = lb/lb,min = 1.00

su2 = 0.4*esu2_nominal ((5.5), TBDY) = 0.032

From table 5A.1, TBDY: esu2_nominal = 0.08,

For calculation of esu2_nominal and y2, sh2,ft2,fy2, it is considered
characteristic value fsy2 = fs2/1.2, from table 5.1, TBDY.

y1, sh1,ft1,fy1, are also multiplied by $\text{Min}(1, 1.25 \cdot (lb/ld)^{2/3})$, from 10.3.5, ASCE 41-17.

with fs2 = fs = 656.25

with Es2 = Es = 200000.00

yv = 0.0025

shv = 0.008

ftv = 787.50

fyv = 656.25

suv = 0.032

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00

lo/lou,min = lb/ld = 1.00

suv = 0.4*esuv_nominal ((5.5), TBDY) = 0.032

From table 5A.1, TBDY: esuv_nominal = 0.08,

considering characteristic value fsyv = fsv/1.2, from table 5.1, TBDY

For calculation of esuv_nominal and yv, shv,ftv,fyv, it is considered
characteristic value fsyv = fsv/1.2, from table 5.1, TBDY.

y1, sh1,ft1,fy1, are also multiplied by $\text{Min}(1, 1.25 \cdot (lb/ld)^{2/3})$, from 10.3.5, ASCE 41-17.

with fsv = fs = 656.25

with Esv = Es = 200000.00

1 = Asl,ten/(b*d)*(fs1/fc) = 0.15356947

2 = Asl,com/(b*d)*(fs2/fc) = 0.15676884

v = Asl,mid/(b*d)*(fsv/fc) = 0.07838442

and confined core properties:

b = 240.00

d = 328.00

d' = 13.00

fcc (5A.2, TBDY) = 26.16063

cc (5A.5, TBDY) = 0.00290026

c = confinement factor = 1.09003

1 = Asl,ten/(b*d)*(fs1/fc) = 0.20951933

2 = Asl,com/(b*d)*(fs2/fc) = 0.21388431

v = Asl,mid/(b*d)*(fsv/fc) = 0.10694216

Case/Assumption: Unconfined full section - Steel rupture

' satisfies Eq. (4.3)

--->

v < vs,y2 - LHS eq.(4.5) is satisfied

--->

su (4.9) = 0.16466458

Mu = MRc (4.14) = 1.8498E+008

u = su (4.1) = 0.00010701

Calculation of ratio lb/ld

Adequate Lap Length: lb/ld >= 1

Calculation of Mu2-

Calculation of ultimate curvature u according to 4.1, Biskinis/Fardis 2013:

u = 0.00010732

Mu = 1.8800E+008

with full section properties:

b = 300.00

d = 357.00
d' = 42.00
v = 8.2121432E-005
N = 211.0849
fc = 24.00
co (5A.5, TBDY) = 0.002
Final value of cu: $cu^* = \text{shear_factor} * \text{Max}(cu, cc) = 0.00773686$
The Shear_factor is considered equal to 1 (pure moment strength)
From (5.4b), TBDY: $cu = 0.00773686$
we (5.4c) = 0.01121936
ase ((5.4d), TBDY) = 0.15672608
bo = 240.00
ho = 340.00
bi2 = 346400.00
psh,min = $\text{Min}(psh,x, psh,y) = 0.00261799$

psh,x (5.4d) = 0.00349066
Ash = $\text{Astir} * ns = 78.53982$
No stirups, ns = 2.00
bk = 300.00

psh,y (5.4d) = 0.00261799
Ash = $\text{Astir} * ns = 78.53982$
No stirups, ns = 2.00
bk = 400.00

s = 150.00
fywe = 656.25
fce = 24.00
From ((5.A.5), TBDY), TBDY: $cc = 0.00290026$
c = confinement factor = 1.09003

y1 = 0.0025
sh1 = 0.008
ft1 = 787.50
fy1 = 656.25
su1 = 0.032

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00

lo/lou,min = $lb/ld = 1.00$

su1 = $0.4 * \text{esu1_nominal} ((5.5), \text{TBDY}) = 0.032$

From table 5A.1, TBDY: $\text{esu1_nominal} = 0.08$,

For calculation of esu1_nominal and $y1, sh1, ft1, fy1$, it is considered
characteristic value $\text{fsy1} = \text{fs1}/1.2$, from table 5.1, TBDY.

$y1, sh1, ft1, fy1$, are also multiplied by $\text{Min}(1, 1.25 * (lb/ld)^{2/3})$, from 10.3.5, ASCE 41-17.

with $\text{fs1} = \text{fs} = 656.25$

with $\text{Es1} = \text{Es} = 200000.00$

y2 = 0.0025
sh2 = 0.008
ft2 = 787.50
fy2 = 656.25
su2 = 0.032

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00

lo/lou,min = $lb/lb, \text{min} = 1.00$

su2 = $0.4 * \text{esu2_nominal} ((5.5), \text{TBDY}) = 0.032$

From table 5A.1, TBDY: $\text{esu2_nominal} = 0.08$,

For calculation of esu2_nominal and $y2, sh2, ft2, fy2$, it is considered
characteristic value $\text{fsy2} = \text{fs2}/1.2$, from table 5.1, TBDY.

$y1, sh1, ft1, fy1$, are also multiplied by $\text{Min}(1, 1.25 * (lb/ld)^{2/3})$, from 10.3.5, ASCE 41-17.

with $\text{fs2} = \text{fs} = 656.25$

with $\text{Es2} = \text{Es} = 200000.00$

yv = 0.0025
shv = 0.008
ftv = 787.50
fyv = 656.25

suv = 0.032

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00

lo/lou,min = lb/d = 1.00

suv = 0.4*esuv_nominal ((5.5), TBDY) = 0.032

From table 5A.1, TBDY: esuv_nominal = 0.08,

considering characteristic value fsyv = fsv/1.2, from table 5.1, TBDY

For calculation of esuv_nominal and yv, shv,ftv,fyv, it is considered
characteristic value fsyv = fsv/1.2, from table 5.1, TBDY.

y1, sh1,ft1,fy1, are also multiplied by $\text{Min}(1, 1.25 \cdot (lb/d)^{2/3})$, from 10.3.5, ASCE 41-17.

with fsv = fs = 656.25

with Esv = Es = 200000.00

1 = Asl,ten/(b*d)*(fs1/fc) = 0.15720797

2 = Asl,com/(b*d)*(fs2/fc) = 0.15399964

v = Asl,mid/(b*d)*(fsv/fc) = 0.07860398

and confined core properties:

b = 240.00

d = 327.00

d' = 12.00

fcc (5A.2, TBDY) = 26.16063

cc (5A.5, TBDY) = 0.00290026

c = confinement factor = 1.09003

1 = Asl,ten/(b*d)*(fs1/fc) = 0.21453839

2 = Asl,com/(b*d)*(fs2/fc) = 0.21016006

v = Asl,mid/(b*d)*(fsv/fc) = 0.1072692

Case/Assumption: Unconfined full section - Steel rupture

' satisfies Eq. (4.3)

v < vs,y2 - LHS eq.(4.5) is satisfied

su (4.9) = 0.16474284

Mu = MRc (4.14) = 1.8800E+008

u = su (4.1) = 0.00010732

Calculation of ratio lb/d

Adequate Lap Length: lb/d >= 1

Calculation of Shear Strength Vr = Min(Vr1,Vr2) = 261431.672

Calculation of Shear Strength at edge 1, Vr1 = 261431.672

Vr1 = Vn ((22.5.1.1), ACI 318-14)

NOTE: In expression (22.5.1.1) 'Vw' is replaced by 'Vw+ f*Vf'
where Vf is the contribution of FRPs (11.3), ACI 440).

From Table (22.5.5.1), ACI 318-14: Vc = 85502.483

= 1 (normal-weight concrete)

fc' = 24.00, but $fc^{0.5} \leq 8.3$ MPa (22.5.3.1, ACI 318-14)

pw = As/(bw*d) = 0.00628319

As (tension reinf.) = 603.1858

bw = 300.00

d = 320.00

Vu*d/Mu < 1 = 1.00

Mu = 30114.962

Vu = 2740.265

From (11.5.4.8), ACI 318-14: Vs = 175929.189

Av = 157079.633

fy = 525.00

s = 150.00

Vs has been multiplied by 1 (s < d/2, according to ASCE 41-17,10.3.4)

Vf ((11-3)-(11.4), ACI 440) = 0.00

From (11-11), ACI 440: $V_s + V_f \leq 312423.44$

Calculation of Shear Strength at edge 2, $V_{r2} = 261431.672$
 $V_{r2} = V_n$ ((22.5.1.1), ACI 318-14)

NOTE: In expression (22.5.1.1) 'Vw' is replaced by 'Vw + f*Vf'
where Vf is the contribution of FRPs (11.3), ACI 440).

From Table (22.5.5.1), ACI 318-14: $V_c = 85502.483$
= 1 (normal-weight concrete)
 $f'_c = 24.00$, but $f'_c^{0.5} \leq 8.3$ MPa (22.5.3.1, ACI 318-14)
 $\rho_w = A_s / (b_w * d) = 0.00628319$
 A_s (tension reinf.) = 603.1858
 $b_w = 300.00$
 $d = 320.00$
 $V_u * d / M_u < 1 = 1.00$
 $M_u = 30115.665$
 $V_u = 2740.264$

From (11.5.4.8), ACI 318-14: $V_s = 175929.189$
 $A_v = 157079.633$
 $f_y = 525.00$
 $s = 150.00$

V_s has been multiplied by 1 ($s < d/2$, according to ASCE 41-17,10.3.4)
 V_f ((11-3)-(11.4), ACI 440) = 0.00
From (11-11), ACI 440: $V_s + V_f \leq 312423.44$

End Of Calculation of Shear Capacity ratio for element: beam B1 of floor 1
At local axis: 3

Start Of Calculation of Shear Capacity ratio for element: beam B1 of floor 1
At Shear local axis: 2
(Bending local axis: 3)
Section Type: rcars

Constant Properties

Knowledge Factor, $\phi = 1.00$
Mean strength values are used for both shear and moment calculations.
Consequently:
Existing material of Primary Member: Concrete Strength, $f_c = f_{cm} = 24.00$
Existing material of Primary Member: Steel Strength, $f_s = f_{sm} = 525.00$
Concrete Elasticity, $E_c = 23025.204$
Steel Elasticity, $E_s = 200000.00$

Note: Especially for the calculation of moment strengths,
the above steel re-bar strengths are multiplied by 1.25 according to R18.6.5, ACI 318-14
Existing material: Steel Strength, $f_s = 1.25 * f_{sm} = 656.25$

Section Height, $H = 400.00$
Section Width, $W = 300.00$
Cover Thickness, $c = 25.00$
Mean Confinement Factor overall section = 1.09003
Element Length, $L = 1850.00$
Primary Member
Smooth Bars
Ductile Steel
With Detailing for Earthquake Resistance (including stirrups closed at 135°)
Longitudinal Bars With Ends Lapped Starting at the End Sections
Adequate Lap Length ($l_o / l_{ou, min} > 1$)
No FRP Wrapping

Stepwise Properties

At local axis: 2

EDGE -A-

Shear Force, $V_a = -3.6870970E-015$

EDGE -B-

Shear Force, $V_b = 3.6870970E-015$

BOTH EDGES

Axial Force, $F = -211.0849$

Longitudinal Reinforcement Area Distribution (in 2 divisions)

-Tension: $A_{sl,t} = 603.1858$

-Compression: $A_{sl,c} = 923.6282$

Longitudinal Reinforcement Area Distribution (in 3 divisions)

-Tension: $A_{sl,ten} = 508.938$

-Compression: $A_{sl,com} = 508.938$

-Middle: $A_{sl,mid} = 508.938$

Calculation of Shear Capacity ratio , $V_e/V_r = 0.79211753$

Member Controlled by Flexure ($V_e/V_r < 1$)

Calculation of Shear Demand from fig. R18.6.5, ACI 318-14 $V_e = (M_{pr1} + M_{pr2})/l_n \pm w_u * l_n / 2 = 137993.601$

with

$M_{pr1} = \text{Max}(M_{u1+}, M_{u1-}) = 1.2764E+008$

$M_{u1+} = 1.2764E+008$, is the ultimate moment strength at the edge 1 of the member in the actual moment direction which is defined for the static loading combination

$M_{u1-} = 1.2764E+008$, is the ultimate moment strength at the edge 1 of the member in the opposite moment direction which is defined for the static loading combination

$M_{pr2} = \text{Max}(M_{u2+}, M_{u2-}) = 1.2764E+008$

$M_{u2+} = 1.2764E+008$, is the ultimate moment strength at the edge 2 of the member in the actual moment direction which is defined for the the static loading combination

$M_{u2-} = 1.2764E+008$, is the ultimate moment strength at the edge 2 of the member in the opposite moment direction which is defined for the the static loading combination

and

$\pm w_u * l_n = (|V_1| + |V_2|) / 2$

with

$V_1 = -3.6870970E-015$, is the shear force acting at edge 1 for the the static loading combination

$V_2 = 3.6870970E-015$, is the shear force acting at edge 2 for the the static loading combination

Calculation of M_{u1+}

Calculation of ultimate curvature ϕ_u according to 4.1, Biskinis/Fardis 2013:

$\phi_u = 0.00015613$

$M_u = 1.2764E+008$

with full section properties:

$b = 400.00$

$d = 258.00$

$d' = 42.00$

$v = 8.5224858E-005$

$N = 211.0849$

$f_c = 24.00$

$\phi_{co} (5A.5, TBDY) = 0.002$

Final value of ϕ_{cu} : $\phi_{cu}^* = \text{shear_factor} * \text{Max}(\phi_{cu}, \phi_{cc}) = 0.00773686$

The Shear_factor is considered equal to 1 (pure moment strength)

From (5.4b), TBDY: $\phi_{cu} = 0.00773686$

$w_e (5.4c) = 0.01121936$

$a_{se} ((5.4d), TBDY) = 0.15672608$

$b_o = 240.00$

$h_o = 340.00$

$b_{i2} = 346400.00$

$p_{sh,min} = \text{Min}(p_{sh,x}, p_{sh,y}) = 0.00261799$

$p_{sh,x} (5.4d) = 0.00349066$

$A_{sh} = A_{stir} * n_s = 78.53982$

No stirrups, ns = 2.00
bk = 300.00

psh,y (5.4d) = 0.00261799
Ash = Astir*ns = 78.53982
No stirrups, ns = 2.00
bk = 400.00

s = 150.00
fywe = 656.25
fce = 24.00

From ((5.A5), TBDY), TBDY: cc = 0.00290026
c = confinement factor = 1.09003

y1 = 0.0025
sh1 = 0.008
ft1 = 787.50
fy1 = 656.25
su1 = 0.032

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00

lo/lou,min = lb/d = 1.00

su1 = 0.4*esu1_nominal ((5.5), TBDY) = 0.032

From table 5A.1, TBDY: esu1_nominal = 0.08,

For calculation of esu1_nominal and y1, sh1,ft1,fy1, it is considered
characteristic value fsy1 = fs1/1.2, from table 5.1, TBDY.

y1, sh1,ft1,fy1, are also multiplied by $\text{Min}(1, 1.25 \cdot (lb/d)^{2/3})$, from 10.3.5, ASCE 41-17.

with fs1 = fs = 656.25

with Es1 = Es = 200000.00

y2 = 0.0025
sh2 = 0.008
ft2 = 787.50
fy2 = 656.25
su2 = 0.032

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00

lo/lou,min = lb/lb,min = 1.00

su2 = 0.4*esu2_nominal ((5.5), TBDY) = 0.032

From table 5A.1, TBDY: esu2_nominal = 0.08,

For calculation of esu2_nominal and y2, sh2,ft2,fy2, it is considered
characteristic value fsy2 = fs2/1.2, from table 5.1, TBDY.

y1, sh1,ft1,fy1, are also multiplied by $\text{Min}(1, 1.25 \cdot (lb/d)^{2/3})$, from 10.3.5, ASCE 41-17.

with fs2 = fs = 656.25

with Es2 = Es = 200000.00

yv = 0.0025
shv = 0.008
ftv = 787.50
fyv = 656.25
suv = 0.032

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00

lo/lou,min = lb/d = 1.00

suv = 0.4*esuv_nominal ((5.5), TBDY) = 0.032

From table 5A.1, TBDY: esuv_nominal = 0.08,

considering characteristic value fsyv = fsv/1.2, from table 5.1, TBDY

For calculation of esuv_nominal and yv, shv,ftv,fyv, it is considered
characteristic value fsyv = fsv/1.2, from table 5.1, TBDY.

y1, sh1,ft1,fy1, are also multiplied by $\text{Min}(1, 1.25 \cdot (lb/d)^{2/3})$, from 10.3.5, ASCE 41-17.

with fsv = fs = 656.25

with Esv = Es = 200000.00

1 = Asl,ten/(b*d)*(fs1/fc) = 0.13484761

2 = Asl,com/(b*d)*(fs2/fc) = 0.13484761

v = Asl,mid/(b*d)*(fsv/fc) = 0.13484761

and confined core properties:

b = 340.00

d = 228.00
d' = 12.00
fcc (5A.2, TBDY) = 26.16063
cc (5A.5, TBDY) = 0.00290026
c = confinement factor = 1.09003
1 = Asl,ten/(b*d)*(fs1/fc) = 0.17951849
2 = Asl,com/(b*d)*(fs2/fc) = 0.17951849
v = Asl,mid/(b*d)*(fsv/fc) = 0.17951849
Case/Assumption: Unconfined full section - Steel rupture
' does not satisfy Eq. (4.3)

--->
v < vs,c - RHS eq.(4.5) is satisfied
--->
su (4.9) = 0.20560388
Mu = MRc (4.14) = 1.2764E+008
u = su (4.1) = 0.00015613

Calculation of ratio lb/ld

Adequate Lap Length: lb/ld >= 1

Calculation of Mu1-

Calculation of ultimate curvature u according to 4.1, Biskinis/Fardis 2013:
u = 0.00015613
Mu = 1.2764E+008

with full section properties:

b = 400.00
d = 258.00
d' = 42.00
v = 8.5224858E-005
N = 211.0849
fc = 24.00
co (5A.5, TBDY) = 0.002
Final value of cu: cu* = shear_factor * Max(cu, cc) = 0.00773686
The Shear_factor is considered equal to 1 (pure moment strength)
From (5.4b), TBDY: cu = 0.00773686
we (5.4c) = 0.01121936
ase ((5.4d), TBDY) = 0.15672608
bo = 240.00
ho = 340.00
bi2 = 346400.00
psh,min = Min(psh,x , psh,y) = 0.00261799

psh,x (5.4d) = 0.00349066
Ash = Astir*ns = 78.53982
No stirups, ns = 2.00
bk = 300.00

psh,y (5.4d) = 0.00261799
Ash = Astir*ns = 78.53982
No stirups, ns = 2.00
bk = 400.00

s = 150.00
fywe = 656.25
fce = 24.00
From ((5.A5), TBDY), TBDY: cc = 0.00290026
c = confinement factor = 1.09003
y1 = 0.0025
sh1 = 0.008

$$ft1 = 787.50$$

$$fy1 = 656.25$$

$$su1 = 0.032$$

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00

$$lo/lou,min = lb/l_d = 1.00$$

$$su1 = 0.4 * esu1_nominal ((5.5), TBDY) = 0.032$$

From table 5A.1, TBDY: esu1_nominal = 0.08,

For calculation of esu1_nominal and y1, sh1,ft1,fy1, it is considered
characteristic value fsy1 = fs1/1.2, from table 5.1, TBDY.

y1, sh1,ft1,fy1, are also multiplied by $\text{Min}(1, 1.25 * (lb/l_d)^{2/3})$, from 10.3.5, ASCE 41-17.

$$\text{with } fs1 = fs = 656.25$$

$$\text{with } Es1 = Es = 200000.00$$

$$y2 = 0.0025$$

$$sh2 = 0.008$$

$$ft2 = 787.50$$

$$fy2 = 656.25$$

$$su2 = 0.032$$

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00

$$lo/lou,min = lb/l_b,min = 1.00$$

$$su2 = 0.4 * esu2_nominal ((5.5), TBDY) = 0.032$$

From table 5A.1, TBDY: esu2_nominal = 0.08,

For calculation of esu2_nominal and y2, sh2,ft2,fy2, it is considered
characteristic value fsy2 = fs2/1.2, from table 5.1, TBDY.

y1, sh1,ft1,fy1, are also multiplied by $\text{Min}(1, 1.25 * (lb/l_d)^{2/3})$, from 10.3.5, ASCE 41-17.

$$\text{with } fs2 = fs = 656.25$$

$$\text{with } Es2 = Es = 200000.00$$

$$yv = 0.0025$$

$$shv = 0.008$$

$$ftv = 787.50$$

$$fyv = 656.25$$

$$suv = 0.032$$

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00

$$lo/lou,min = lb/l_d = 1.00$$

$$suv = 0.4 * esuv_nominal ((5.5), TBDY) = 0.032$$

From table 5A.1, TBDY: esuv_nominal = 0.08,

considering characteristic value fsyv = fsv/1.2, from table 5.1, TBDY

For calculation of esuv_nominal and yv, shv,ftv,fyv, it is considered
characteristic value fsyv = fsv/1.2, from table 5.1, TBDY.

y1, sh1,ft1,fy1, are also multiplied by $\text{Min}(1, 1.25 * (lb/l_d)^{2/3})$, from 10.3.5, ASCE 41-17.

$$\text{with } fsv = fs = 656.25$$

$$\text{with } Esv = Es = 200000.00$$

$$1 = Asl,ten / (b * d) * (fs1 / fc) = 0.13484761$$

$$2 = Asl,com / (b * d) * (fs2 / fc) = 0.13484761$$

$$v = Asl,mid / (b * d) * (fsv / fc) = 0.13484761$$

and confined core properties:

$$b = 340.00$$

$$d = 228.00$$

$$d' = 12.00$$

$$fcc (5A.2, TBDY) = 26.16063$$

$$cc (5A.5, TBDY) = 0.00290026$$

$$c = \text{confinement factor} = 1.09003$$

$$1 = Asl,ten / (b * d) * (fs1 / fc) = 0.17951849$$

$$2 = Asl,com / (b * d) * (fs2 / fc) = 0.17951849$$

$$v = Asl,mid / (b * d) * (fsv / fc) = 0.17951849$$

Case/Assumption: Unconfined full section - Steel rupture

' does not satisfy Eq. (4.3)

--->

v < vs,c - RHS eq.(4.5) is satisfied

--->

$$su (4.9) = 0.20560388$$

$$Mu = MRc (4.14) = 1.2764E+008$$

$$u = s_u(4.1) = 0.00015613$$

Calculation of ratio l_b/d

Adequate Lap Length: $l_b/d \geq 1$

Calculation of μ_{2+}

Calculation of ultimate curvature μ according to 4.1, Biskinis/Fardis 2013:

$$u = 0.00015613$$

$$\mu = 1.2764E+008$$

with full section properties:

$$b = 400.00$$

$$d = 258.00$$

$$d' = 42.00$$

$$v = 8.5224858E-005$$

$$N = 211.0849$$

$$f_c = 24.00$$

$$c_o(5A.5, \text{TBDY}) = 0.002$$

$$\text{Final value of } c_u: c_u^* = \text{shear_factor} * \text{Max}(c_u, c_c) = 0.00773686$$

The Shear_factor is considered equal to 1 (pure moment strength)

$$\text{From (5.4b), TBDY: } c_u = 0.00773686$$

$$w_e(5.4c) = 0.01121936$$

$$a_{se}((5.4d), \text{TBDY}) = 0.15672608$$

$$b_o = 240.00$$

$$h_o = 340.00$$

$$b_{i2} = 346400.00$$

$$p_{sh,min} = \text{Min}(p_{sh,x}, p_{sh,y}) = 0.00261799$$

$$p_{sh,x}(5.4d) = 0.00349066$$

$$A_{sh} = A_{stir} * n_s = 78.53982$$

$$\text{No stirups, } n_s = 2.00$$

$$b_k = 300.00$$

$$p_{sh,y}(5.4d) = 0.00261799$$

$$A_{sh} = A_{stir} * n_s = 78.53982$$

$$\text{No stirups, } n_s = 2.00$$

$$b_k = 400.00$$

$$s = 150.00$$

$$f_{ywe} = 656.25$$

$$f_{ce} = 24.00$$

$$\text{From ((5.A5), TBDY), TBDY: } c_c = 0.00290026$$

$$c = \text{confinement factor} = 1.09003$$

$$y_1 = 0.0025$$

$$sh_1 = 0.008$$

$$ft_1 = 787.50$$

$$fy_1 = 656.25$$

$$s_{u1} = 0.032$$

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor and also multiplied by the shear_factor according to 15.7.1.4, with Shear_factor = 1.00

$$l_o/l_{o,min} = l_b/d = 1.00$$

$$s_{u1} = 0.4 * e_{s_{u1,nominal}}((5.5), \text{TBDY}) = 0.032$$

$$\text{From table 5A.1, TBDY: } e_{s_{u1,nominal}} = 0.08,$$

For calculation of $e_{s_{u1,nominal}}$ and y_1, sh_1, ft_1, fy_1 , it is considered characteristic value $f_{sy1} = f_{s1}/1.2$, from table 5.1, TBDY.

y_1, sh_1, ft_1, fy_1 , are also multiplied by $\text{Min}(1, 1.25 * (l_b/d)^{2/3})$, from 10.3.5, ASCE 41-17.

$$\text{with } f_{s1} = f_s = 656.25$$

$$\text{with } E_{s1} = E_s = 200000.00$$

$$y_2 = 0.0025$$

$$sh_2 = 0.008$$

$$ft_2 = 787.50$$

$$fy_2 = 656.25$$

$$su_2 = 0.032$$

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00

$$lo/lo_{u,min} = lb/lb_{u,min} = 1.00$$

$$su_2 = 0.4 * esu_{2,nominal} ((5.5), TBDY) = 0.032$$

From table 5A.1, TBDY: $esu_{2,nominal} = 0.08$,

For calculation of $esu_{2,nominal}$ and y_2 , sh_2, ft_2, fy_2 , it is considered
characteristic value $fsy_2 = fs_2/1.2$, from table 5.1, TBDY.

y_1 , sh_1, ft_1, fy_1 , are also multiplied by $\text{Min}(1, 1.25 * (lb/ld)^{2/3})$, from 10.3.5, ASCE 41-17.

$$\text{with } fs_2 = fs = 656.25$$

$$\text{with } Es_2 = Es = 200000.00$$

$$yv = 0.0025$$

$$shv = 0.008$$

$$ftv = 787.50$$

$$fyv = 656.25$$

$$suv = 0.032$$

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00

$$lo/lo_{u,min} = lb/ld = 1.00$$

$$suv = 0.4 * esuv_{nominal} ((5.5), TBDY) = 0.032$$

From table 5A.1, TBDY: $esuv_{nominal} = 0.08$,

considering characteristic value $fsyv = fsv/1.2$, from table 5.1, TBDY

For calculation of $esuv_{nominal}$ and yv , shv, ftv, fyv , it is considered
characteristic value $fsyv = fsv/1.2$, from table 5.1, TBDY.

y_1 , sh_1, ft_1, fy_1 , are also multiplied by $\text{Min}(1, 1.25 * (lb/ld)^{2/3})$, from 10.3.5, ASCE 41-17.

$$\text{with } fsv = fs = 656.25$$

$$\text{with } Esv = Es = 200000.00$$

$$1 = Asl_{ten}/(b*d) * (fs_1/fc) = 0.13484761$$

$$2 = Asl_{com}/(b*d) * (fs_2/fc) = 0.13484761$$

$$v = Asl_{mid}/(b*d) * (fsv/fc) = 0.13484761$$

and confined core properties:

$$b = 340.00$$

$$d = 228.00$$

$$d' = 12.00$$

$$fcc (5A.2, TBDY) = 26.16063$$

$$cc (5A.5, TBDY) = 0.00290026$$

$$c = \text{confinement factor} = 1.09003$$

$$1 = Asl_{ten}/(b*d) * (fs_1/fc) = 0.17951849$$

$$2 = Asl_{com}/(b*d) * (fs_2/fc) = 0.17951849$$

$$v = Asl_{mid}/(b*d) * (fsv/fc) = 0.17951849$$

Case/Assumption: Unconfined full section - Steel rupture

' does not satisfy Eq. (4.3)

--->

$v < v_{s,c}$ - RHS eq.(4.5) is satisfied

--->

$$su (4.9) = 0.20560388$$

$$Mu = MRc (4.14) = 1.2764E+008$$

$$u = su (4.1) = 0.00015613$$

Calculation of ratio lb/ld

Adequate Lap Length: $lb/ld \geq 1$

Calculation of Mu_2 -

Calculation of ultimate curvature u according to 4.1, Biskinis/Fardis 2013:

$$u = 0.00015613$$

Mu = 1.2764E+008

with full section properties:

b = 400.00

d = 258.00

d' = 42.00

v = 8.5224858E-005

N = 211.0849

fc = 24.00

co (5A.5, TBDY) = 0.002

Final value of cu: $cu^* = \text{shear_factor} * \text{Max}(cu, cc) = 0.00773686$

The Shear_factor is considered equal to 1 (pure moment strength)

From (5.4b), TBDY: $cu = 0.00773686$

we (5.4c) = 0.01121936

ase ((5.4d), TBDY) = 0.15672608

bo = 240.00

ho = 340.00

bi2 = 346400.00

psh,min = $\text{Min}(psh,x, psh,y) = 0.00261799$

psh,x (5.4d) = 0.00349066

Ash = $\text{Astir} * ns = 78.53982$

No stirups, ns = 2.00

bk = 300.00

psh,y (5.4d) = 0.00261799

Ash = $\text{Astir} * ns = 78.53982$

No stirups, ns = 2.00

bk = 400.00

s = 150.00

fywe = 656.25

fce = 24.00

From ((5.A5), TBDY), TBDY: $cc = 0.00290026$

c = confinement factor = 1.09003

y1 = 0.0025

sh1 = 0.008

ft1 = 787.50

fy1 = 656.25

su1 = 0.032

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00

lo/lou,min = lb/d = 1.00

su1 = $0.4 * \text{esu1_nominal} ((5.5), \text{TBDY}) = 0.032$

From table 5A.1, TBDY: $\text{esu1_nominal} = 0.08$,

For calculation of esu1_nominal and y1, sh1,ft1,fy1, it is considered
characteristic value $fsy1 = fs1/1.2$, from table 5.1, TBDY.

y1, sh1,ft1,fy1, are also multiplied by $\text{Min}(1, 1.25 * (lb/d)^{2/3})$, from 10.3.5, ASCE 41-17.

with $fs1 = fs = 656.25$

with $Es1 = Es = 200000.00$

y2 = 0.0025

sh2 = 0.008

ft2 = 787.50

fy2 = 656.25

su2 = 0.032

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00

lo/lou,min = lb/lb,min = 1.00

su2 = $0.4 * \text{esu2_nominal} ((5.5), \text{TBDY}) = 0.032$

From table 5A.1, TBDY: $\text{esu2_nominal} = 0.08$,

For calculation of esu2_nominal and y2, sh2,ft2,fy2, it is considered
characteristic value $fsy2 = fs2/1.2$, from table 5.1, TBDY.

y1, sh1,ft1,fy1, are also multiplied by $\text{Min}(1, 1.25 * (lb/d)^{2/3})$, from 10.3.5, ASCE 41-17.

with $fs2 = fs = 656.25$

with $Es2 = Es = 200000.00$

yv = 0.0025
shv = 0.008
ftv = 787.50
fyv = 656.25
suv = 0.032

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00

lo/lou,min = lb/d = 1.00

suv = 0.4*esuv_nominal ((5.5), TBDY) = 0.032

From table 5A.1, TBDY: esuv_nominal = 0.08,

considering characteristic value fsyv = fsv/1.2, from table 5.1, TBDY

For calculation of esuv_nominal and yv, shv,ftv,fyv, it is considered
characteristic value fsyv = fsv/1.2, from table 5.1, TBDY.

y1, sh1,ft1,fy1, are also multiplied by $\text{Min}(1, 1.25 \cdot (lb/d)^{2/3})$, from 10.3.5, ASCE 41-17.

with fsv = fs = 656.25

with Esv = Es = 200000.00

1 = Asl,ten/(b*d)*(fs1/fc) = 0.13484761

2 = Asl,com/(b*d)*(fs2/fc) = 0.13484761

v = Asl,mid/(b*d)*(fsv/fc) = 0.13484761

and confined core properties:

b = 340.00

d = 228.00

d' = 12.00

fcc (5A.2, TBDY) = 26.16063

cc (5A.5, TBDY) = 0.00290026

c = confinement factor = 1.09003

1 = Asl,ten/(b*d)*(fs1/fc) = 0.17951849

2 = Asl,com/(b*d)*(fs2/fc) = 0.17951849

v = Asl,mid/(b*d)*(fsv/fc) = 0.17951849

Case/Assumption: Unconfined full section - Steel rupture

' does not satisfy Eq. (4.3)

--->

v < vs,c - RHS eq.(4.5) is satisfied

--->

su (4.9) = 0.20560388

Mu = MRc (4.14) = 1.2764E+008

u = su (4.1) = 0.00015613

Calculation of ratio lb/d

Adequate Lap Length: lb/d >= 1

Calculation of Shear Strength Vr = Min(Vr1,Vr2) = 174208.493

Calculation of Shear Strength at edge 1, Vr1 = 174208.493

Vr1 = Vn ((22.5.1.1), ACI 318-14)

NOTE: In expression (22.5.1.1) 'Vw' is replaced by 'Vw+ f*Vf'
where Vf is the contribution of FRPs (11.3), ACI 440).

From Table (22.5.5.1), ACI 318-14: Vc = 75248.325

= 1 (normal-weight concrete)

fc' = 24.00, but $fc'^{0.5} \leq 8.3$ MPa (22.5.3.1, ACI 318-14)

pw = As/(bw*d) = 0.00628319

As (tension reinf.) = 603.1858

bw = 400.00

d = 240.00

Vu*d/Mu < 1 = 0.00

Mu = 7.6252677E-012

Vu = 3.6870970E-015

From (11.5.4.8), ACI 318-14: Vs = 98960.169

Av = 157079.633

$$f_y = 525.00$$

$$s = 150.00$$

Vs has been multiplied by $2(1-s/d)$ ($s > d/2$, according to ASCE 41-17,10.3.4)

$$2(1-s/d) = 0.75$$

$$V_f ((11-3)-(11.4), \text{ACI 440}) = 0.00$$

$$\text{From (11-11), ACI 440: } V_s + V_f \leq 312423.44$$

Calculation of Shear Strength at edge 2, $V_{r2} = 174208.493$

$$V_{r2} = V_n ((22.5.1.1), \text{ACI 318-14})$$

NOTE: In expression (22.5.1.1) 'Vw' is replaced by 'Vw + f*Vf'

where Vf is the contribution of FRPs (11.3), ACI 440).

From Table (22.5.5.1), ACI 318-14: $V_c = 75248.325$

= 1 (normal-weight concrete)

$$f_c' = 24.00, \text{ but } f_c'^{0.5} \leq 8.3 \text{ MPa (22.5.3.1, ACI 318-14)}$$

$$p_w = A_s / (b_w * d) = 0.00628319$$

$$A_s (\text{tension reinf.}) = 603.1858$$

$$b_w = 400.00$$

$$d = 240.00$$

$$V_u * d / M_u < 1 = 0.00$$

$$M_u = 8.0393416E-013$$

$$V_u = 3.6870970E-015$$

From (11.5.4.8), ACI 318-14: $V_s = 98960.169$

$$A_v = 157079.633$$

$$f_y = 525.00$$

$$s = 150.00$$

Vs has been multiplied by $2(1-s/d)$ ($s > d/2$, according to ASCE 41-17,10.3.4)

$$2(1-s/d) = 0.75$$

$$V_f ((11-3)-(11.4), \text{ACI 440}) = 0.00$$

$$\text{From (11-11), ACI 440: } V_s + V_f \leq 312423.44$$

End Of Calculation of Shear Capacity ratio for element: beam B1 of floor 1

At local axis: 2

Start Of Calculation of Chord Rotation Capacity for element: beam B1 of floor 1

At local axis: 2

Integration Section: (a)

Section Type: rcars

Constant Properties

Knowledge Factor, = 1.00

Chord Rotation is generally considered as Deformation-Controlled Action according to Table C7-1, ASCE 41-17.

Mean strengths are used for Deformation-Controlled Actions according to 7.5.1.3, ASCE 41-17

Consequently:

Existing material of Primary Member: Concrete Strength, $f_c = f_{cm} = 24.00$

Existing material of Primary Member: Steel Strength, $f_s = f_{sm} = 525.00$

Concrete Elasticity, $E_c = 23025.204$

Steel Elasticity, $E_s = 200000.00$

Section Height, $H = 400.00$

Section Width, $W = 300.00$

Cover Thickness, $c = 25.00$

Element Length, $L = 1850.00$

Primary Member

Smooth Bars

Ductile Steel

With Detailing for Earthquake Resistance (including stirrups closed at 135°)

Longitudinal Bars With Ends Lapped Starting at the End Sections

Adequate Lap Length ($l_b / l_d > 1$)

No FRP Wrapping

Stepwise Properties

Bending Moment, $M = 4.3364E+006$
Shear Force, $V2 = 2.3583230E-014$
Shear Force, $V3 = -2011.906$
Axial Force, $F = -490.6724$
Longitudinal Reinforcement Area Distribution (in 2 divisions)
-Tension: $Asl_t = 603.1858$
-Compression: $Asl_c = 923.6282$
Longitudinal Reinforcement Area Distribution (in 3 divisions)
-Tension: $Asl_{ten} = 603.1858$
-Compression: $Asl_{com} = 615.7522$
-Middle: $Asl_{mid} = 307.8761$
Mean Diameter of Tension Reinforcement, $DbL = 16.00$

Existing component: From table 7-7, ASCE 41_17: Final chord rotation Capacity $u_{R} = \gamma + p = 0.02768931$

- Calculation of γ -

$\gamma = (M \cdot L_s / 3) / E_{eff} = 0.00768931$ ((4.29), Biskinis Phd)
 $M_y = 1.1829E+008$
 $L_s = M/V$ (with $L_s > 0.1 \cdot L$ and $L_s < 2 \cdot L$) = 2155.373
From table 10.5, ASCE 41_17: $E_{eff} = 0.3 \cdot E_c \cdot I_g = 1.1052E+013$

Calculation of Yielding Moment M_y

Calculation of γ and M_y according to Annex 7 -

$\gamma = \text{Min}(\gamma_{ten}, \gamma_{com})$
 $\gamma_{ten} = 1.0034719E-005$
with $f_y = 525.00$
 $d = 357.00$
 $\gamma = 0.26724988$
 $A = 0.01426469$
 $B = 0.00792353$
with $p_t = 0.00563199$
 $p_c = 0.00574932$
 $p_v = 0.00287466$
 $N = 490.6724$
 $b = 300.00$
 $\gamma = 0.11764706$
 $\gamma_{comp} = 1.9670147E-005$
with $f_c = 24.00$
 $E_c = 23025.204$
 $\gamma = 0.26718031$
 $A = 0.01424376$
 $B = 0.00791481$
with $E_s = 200000.00$

Calculation of ratio l_b/d

Adequate Lap Length: $l_b/d \geq 1$

- Calculation of p -

From table 10-7: $p = 0.02$

with:

- Condition i occurred

Beam controlled by flexure: $V_p/V_o \leq 1$



shear control ratio $V_p/V_o = 0.78793176$

- Transverse Reinforcement: NC
- Stirrup Spacing $> d/3$
- Low ductility demand, $\lambda / y < 2$ (table 10-6, ASCE 41-17)
 $= 5.1824485E-005$
- Stirrup Spacing $\leq d/2$
 $d = 357.00$
 $s = 150.00$
- Strength provided by hoops $V_s < 3/4 * \text{design Shear}$
 $V_s = 175929.189$, already given in calculation of shear control ratio
design Shear = 2011.906
- ($\lambda - \lambda'$)/ bal = -0.16985254
 $= A_{st}/(b_w * d) = 0.00563199$
Tension Reinf Area: $A_{st} = 603.1858$
 $\lambda' = A_{sc}/(b_w * d) = 0.00862398$
Compression Reinf Area: $A_{sc} = 923.6282$
- From (B-1), ACI 318-11: bal = 0.01761524
 $f_c = 24.00$
 $f_y = 525.00$
From 10.2.7.3, ACI 318-11: $\lambda = 0.85$
From fig R10.3.3, ACI 318-11 (Ence 454, too): $87000/(87000 + f_y) = c_b/d_t = 0.003/(0.003 + \lambda) = 0.53333333$
 $y = 0.002625$
- $V/(b_w * d * f_c^{0.5}) = 0.04617809$, NOTE: units in lb & in
 $b_w = 300.00$

End Of Calculation of Chord Rotation Capacity for element: beam B1 of floor 1
At local axis: 2
Integration Section: (a)

Calculation No. 11

beam B1, Floor 1
Limit State: Life Safety (data interpolation between analysis steps 1 and 2)
Analysis: Uniform +X
Check: Shear capacity V_{Rd}
Edge: Start
Local Axis: (3)



Start Of Calculation of Shear Capacity for element: beam B1 of floor 1

At local axis: 3

Integration Section: (a)

Section Type: rcars

Constant Properties

Knowledge Factor, $\gamma = 1.00$

Member Shear Force is generally considered as Force-Controlled Action according to Table C7-1, ASCE 41-17.

Lower-bound strengths are used for Force-Controlled Actions according to 7.5.1.3, ASCE 41-17

Consequently:

Existing material of Primary Member: Concrete Strength, $f_c = f_{c_lower_bound} = 16.00$

Existing material of Primary Member: Steel Strength, $f_s = f_{s_lower_bound} = 420.00$

Concrete Elasticity, $E_c = 23025.204$

Steel Elasticity, $E_s = 200000.00$

Section Height, $H = 400.00$

Section Width, $W = 300.00$

Cover Thickness, $c = 25.00$

Element Length, $L = 1850.00$

Primary Member

Smooth Bars

Ductile Steel

With Detailing for Earthquake Resistance (including stirrups closed at 135°)

Longitudinal Bars With Ends Lapped Starting at the End Sections

Adequate Lap Length ($l_o/l_{o,min} = l_b/l_d \geq 1$)

No FRP Wrapping

Stepwise Properties

EDGE -A-

Bending Moment, $M_a = 4.3364E+006$

Shear Force, $V_a = -2011.906$

EDGE -B-

Bending Moment, $M_b = 4.4551E+006$

Shear Force, $V_b = 7492.435$

BOTH EDGES

Axial Force, $F = -490.6724$

Longitudinal Reinforcement Area Distribution (in 2 divisions)

-Tension: $A_{s,t} = 603.1858$

-Compression: $A_{s,c} = 923.6282$

Longitudinal Reinforcement Area Distribution (in 3 divisions)

-Tension: $A_{s,ten} = 603.1858$

-Compression: $A_{s,com} = 615.7522$

-Middle: $A_{s,mid} = 307.8761$

Mean Diameter of Tension Reinforcement, $D_{bL,ten} = 16.00$

Existing component: From table 7-7, ASCE 41_17: Final Shear Capacity $V_R = *V_n = 203705.746$

$V_n ((22.5.1.1), ACI 318-14) = 203705.746$

NOTE: In expression (22.5.1.1) 'Vw' is replaced by 'Vw+ f*Vf' where Vf is the contribution of FRPs (11.3), ACI 440).

From Table (22.5.5.1), ACI 318-14: $V_c = 62962.395$
= 1 (normal-weight concrete)
 $f'_c = 16.00$, but $f'_c^{0.5} \leq 8.3$ MPa (22.5.3.1, ACI 318-14)
 $\rho_w = A_s/(b_w*d) = 0.00628319$
 A_s (tension reinf.) = 603.1858
 $b_w = 300.00$
 $d = 320.00$
 $V_u*d/\mu < 1 = 0.14846615$
 $\mu = 4.3364E+006$
 $V_u = 2011.906$

From (11.5.4.8), ACI 318-14: $V_s = 140743.351$
 $A_v = 157079.633$
 $f_y = 420.00$
 $s = 150.00$

V_s has been multiplied by 1 ($s < d/2$, according to ASCE 41-17,10.3.4)

V_f ((11-3)-(11.4), ACI 440) = 0.00

From (11-11), ACI 440: $V_s + V_f \leq 255092.67$

End Of Calculation of Shear Capacity for element: beam B1 of floor 1

At local axis: 3

Integration Section: (a)

Calculation No. 12

beam B1, Floor 1



Limit State: Life Safety (data interpolation between analysis steps 1 and 2)

Analysis: Uniform +X

Check: Chord rotation capacity (θ_u)

Edge: Start

Local Axis: (3)



Start Of Calculation of Shear Capacity ratio for element: beam B1 of floor 1

At Shear local axis: 3

(Bending local axis: 2)

Section Type: rcars

Constant Properties

Knowledge Factor, $\gamma = 1.00$

Mean strength values are used for both shear and moment calculations.

Consequently:

Existing material of Primary Member: Concrete Strength, $f_c = f_{cm} = 24.00$

Existing material of Primary Member: Steel Strength, $f_s = f_{sm} = 525.00$

Concrete Elasticity, $E_c = 23025.204$

Steel Elasticity, $E_s = 200000.00$

#####

Note: Especially for the calculation of moment strengths,

the above steel re-bar strengths are multiplied by 1.25 according to R18.6.5, ACI 318-14

Existing material: Steel Strength, $f_s = 1.25 \cdot f_{sm} = 656.25$

#####

Section Height, $H = 400.00$

Section Width, $W = 300.00$

Cover Thickness, $c = 25.00$

Mean Confinement Factor overall section = 1.09003

Element Length, $L = 1850.00$

Primary Member

Smooth Bars

Ductile Steel

With Detailing for Earthquake Resistance (including stirrups closed at 135°)

Longitudinal Bars With Ends Lapped Starting at the End Sections

Adequate Lap Length ($l_o/l_{ou, \min} > 1$)

No FRP Wrapping

Stepwise Properties

At local axis: 3

EDGE -A-

Shear Force, $V_a = 2740.265$

EDGE -B-

Shear Force, $V_b = 2740.264$

BOTH EDGES

Axial Force, $F = -211.0849$

Longitudinal Reinforcement Area Distribution (in 2 divisions)

-Tension: $A_{sl, t} = 603.1858$

-Compression: $A_{sl, c} = 923.6282$

Longitudinal Reinforcement Area Distribution (in 3 divisions)

-Tension: $A_{sl, ten} = 603.1858$

-Compression: $A_{sl, com} = 615.7522$

-Middle: $A_{sl, mid} = 307.8761$

Calculation of Shear Capacity ratio, $V_e/V_r = 0.78793176$

Member Controlled by Flexure ($V_e/V_r < 1$)

Calculation of Shear Demand from fig. R18.6.5, ACI 318-14 $V_e = (M_{pr1} + M_{pr2})/l_n \pm w_u \cdot l_n/2 = 205990.317$

with

$M_{pr1} = \text{Max}(M_{u1+}, M_{u1-}) = 1.8802E+008$

$M_{u1+} = 1.8495E+008$, is the ultimate moment strength at the edge 1 of the member in the actual moment direction which is defined for the static loading combination

$M_{u1-} = 1.8802E+008$, is the ultimate moment strength at the edge 1 of the member in the opposite moment direction which is defined for the static loading combination

$M_{pr2} = \text{Max}(M_{u2+}, M_{u2-}) = 1.8800E+008$

$M_{u2+} = 1.8498E+008$, is the ultimate moment strength at the edge 2 of the member in the actual moment direction which is defined for the the static loading combination

$M_{u2-} = 1.8800E+008$, is the ultimate moment strength at the edge 2 of the member in the opposite moment direction which is defined for the the static loading combination

and

$\pm w_u \cdot l_n = (|V_1| + |V_2|)/2$

with

V1 = 2740.265, is the shear force acting at edge 1 for the the static loading combination
V2 = 2740.264, is the shear force acting at edge 2 for the the static loading combination

Calculation of Mu1+

Calculation of ultimate curvature μ according to 4.1, Biskinis/Fardis 2013:

$$\mu = 0.0001071$$

$$Mu = 1.8495E+008$$

with full section properties:

$$b = 300.00$$

$$d = 357.00$$

$$d' = 42.00$$

$$v = 8.2121432E-005$$

$$N = 211.0849$$

$$f_c = 24.00$$

$$c_o \text{ (5A.5, TBDY)} = 0.002$$

$$\text{Final value of } c_u: c_u^* = \text{shear_factor} * \text{Max}(c_u, c_c) = 0.00773686$$

The Shear_factor is considered equal to 1 (pure moment strength)

$$\text{From (5.4b), TBDY: } c_u = 0.00773686$$

$$w_e \text{ (5.4c)} = 0.01121936$$

$$a_{se} \text{ ((5.4d), TBDY)} = 0.15672608$$

$$b_o = 240.00$$

$$h_o = 340.00$$

$$b_{i2} = 346400.00$$

$$p_{sh,min} = \text{Min}(p_{sh,x}, p_{sh,y}) = 0.00261799$$

 $p_{sh,x} \text{ (5.4d)} = 0.00349066$

$$A_{sh} = A_{stir} * n_s = 78.53982$$

$$\text{No stirups, } n_s = 2.00$$

$$b_k = 300.00$$

 $p_{sh,y} \text{ (5.4d)} = 0.00261799$

$$A_{sh} = A_{stir} * n_s = 78.53982$$

$$\text{No stirups, } n_s = 2.00$$

$$b_k = 400.00$$

 $s = 150.00$

$$f_{ywe} = 656.25$$

$$f_{ce} = 24.00$$

$$\text{From ((5.A5), TBDY), TBDY: } c_c = 0.00290026$$

$$c = \text{confinement factor} = 1.09003$$

$$y_1 = 0.0025$$

$$sh_1 = 0.008$$

$$ft_1 = 787.50$$

$$fy_1 = 656.25$$

$$su_1 = 0.032$$

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00

$$l_o/l_{ou,min} = l_b/l_d = 1.00$$

$$su_1 = 0.4 * esu_1_{nominal} \text{ ((5.5), TBDY)} = 0.032$$

$$\text{From table 5A.1, TBDY: } esu_1_{nominal} = 0.08,$$

For calculation of $esu_1_{nominal}$ and y_1, sh_1, ft_1, fy_1 , it is considered
characteristic value $fsy_1 = fs_1/1.2$, from table 5.1, TBDY.

$$y_1, sh_1, ft_1, fy_1, \text{ are also multiplied by } \text{Min}(1, 1.25 * (l_b/l_d)^{2/3}), \text{ from 10.3.5, ASCE 41-17.}$$

$$\text{with } fs_1 = fs = 656.25$$

$$\text{with } E_{s1} = E_s = 200000.00$$

$$y_2 = 0.0025$$

$$sh_2 = 0.008$$

$$ft_2 = 787.50$$

$$fy_2 = 656.25$$

$$su_2 = 0.032$$

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor

and also multiplied by the shear_factor according to 15.7.1.4, with

Shear_factor = 1.00

lo/lou,min = lb/lb,min = 1.00

su2 = 0.4*esu2_nominal ((5.5), TBDY) = 0.032

From table 5A.1, TBDY: esu2_nominal = 0.08,

For calculation of esu2_nominal and y2, sh2,ft2,fy2, it is considered

characteristic value fsy2 = fs2/1.2, from table 5.1, TBDY.

y1, sh1,ft1,fy1, are also multiplied by $\text{Min}(1, 1.25 \cdot (lb/ld)^{2/3})$, from 10.3.5, ASCE 41-17.

with fs2 = fs = 656.25

with Es2 = Es = 200000.00

yv = 0.0025

shv = 0.008

ftv = 787.50

fyv = 656.25

suv = 0.032

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor

and also multiplied by the shear_factor according to 15.7.1.4, with

Shear_factor = 1.00

lo/lou,min = lb/ld = 1.00

suv = 0.4*esuv_nominal ((5.5), TBDY) = 0.032

From table 5A.1, TBDY: esuv_nominal = 0.08,

considering characteristic value fsyv = fsv/1.2, from table 5.1, TBDY

For calculation of esuv_nominal and yv, shv,ftv,fyv, it is considered

characteristic value fsyv = fsv/1.2, from table 5.1, TBDY.

y1, sh1,ft1,fy1, are also multiplied by $\text{Min}(1, 1.25 \cdot (lb/ld)^{2/3})$, from 10.3.5, ASCE 41-17.

with fsv = fs = 656.25

with Esv = Es = 200000.00

1 = Asl,ten/(b*d)*(fs1/fc) = 0.15399964

2 = Asl,com/(b*d)*(fs2/fc) = 0.15720797

v = Asl,mid/(b*d)*(fsv/fc) = 0.07860398

and confined core properties:

b = 240.00

d = 327.00

d' = 12.00

fcc (5A.2, TBDY) = 26.16063

cc (5A.5, TBDY) = 0.00290026

c = confinement factor = 1.09003

1 = Asl,ten/(b*d)*(fs1/fc) = 0.21016006

2 = Asl,com/(b*d)*(fs2/fc) = 0.21453839

v = Asl,mid/(b*d)*(fsv/fc) = 0.1072692

Case/Assumption: Unconfined full section - Steel rupture

' satisfies Eq. (4.3)

--->

v < vs,y2 - LHS eq.(4.5) is satisfied

--->

su (4.9) = 0.1630814

Mu = MRc (4.14) = 1.8495E+008

u = su (4.1) = 0.0001071

Calculation of ratio lb/ld

Adequate Lap Length: lb/ld >= 1

Calculation of Mu1-

Calculation of ultimate curvature u according to 4.1, Biskinis/Fardis 2013:

u = 0.00010722

Mu = 1.8802E+008

with full section properties:

b = 300.00

d = 358.00

d' = 43.00
v = 8.1892042E-005
N = 211.0849
fc = 24.00
co (5A.5, TBDY) = 0.002
Final value of cu: cu* = shear_factor * Max(cu, cc) = 0.00773686
The Shear_factor is considered equal to 1 (pure moment strength)
From (5.4b), TBDY: cu = 0.00773686
we (5.4c) = 0.01121936
ase ((5.4d), TBDY) = 0.15672608
bo = 240.00
ho = 340.00
bi2 = 346400.00
psh,min = Min(psh,x , psh,y) = 0.00261799

psh,x (5.4d) = 0.00349066
Ash = Astir*ns = 78.53982
No stirups, ns = 2.00
bk = 300.00

psh,y (5.4d) = 0.00261799
Ash = Astir*ns = 78.53982
No stirups, ns = 2.00
bk = 400.00

s = 150.00
fywe = 656.25
fce = 24.00
From ((5.A5), TBDY), TBDY: cc = 0.00290026
c = confinement factor = 1.09003
y1 = 0.0025
sh1 = 0.008
ft1 = 787.50
fy1 = 656.25
su1 = 0.032

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00
lo/lou,min = lb/d = 1.00
su1 = 0.4*esu1_nominal ((5.5), TBDY) = 0.032
From table 5A.1, TBDY: esu1_nominal = 0.08,
For calculation of esu1_nominal and y1, sh1,ft1,fy1, it is considered
characteristic value fsy1 = fs1/1.2, from table 5.1, TBDY.
y1, sh1,ft1,fy1, are also multiplied by Min(1,1.25*(lb/d)^ 2/3), from 10.3.5, ASCE 41-17.
with fs1 = fs = 656.25
with Es1 = Es = 200000.00

y2 = 0.0025
sh2 = 0.008
ft2 = 787.50
fy2 = 656.25
su2 = 0.032
using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00
lo/lou,min = lb/lb,min = 1.00
su2 = 0.4*esu2_nominal ((5.5), TBDY) = 0.032
From table 5A.1, TBDY: esu2_nominal = 0.08,
For calculation of esu2_nominal and y2, sh2,ft2,fy2, it is considered
characteristic value fsy2 = fs2/1.2, from table 5.1, TBDY.
y1, sh1,ft1,fy1, are also multiplied by Min(1,1.25*(lb/d)^ 2/3), from 10.3.5, ASCE 41-17.
with fs2 = fs = 656.25
with Es2 = Es = 200000.00

yv = 0.0025
shv = 0.008
ftv = 787.50
fyv = 656.25
suv = 0.032

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00

$l_0/l_{ou,min} = l_b/l_d = 1.00$

$s_{uv} = 0.4 * e_{suv_nominal} ((5.5), TBDY) = 0.032$

From table 5A.1, TBDY: $e_{suv_nominal} = 0.08$,

considering characteristic value $f_{sv} = f_{sv}/1.2$, from table 5.1, TBDY

For calculation of $e_{suv_nominal}$ and γ_v , sh_v, ft_v, fy_v , it is considered
characteristic value $f_{sv} = f_{sv}/1.2$, from table 5.1, TBDY.

γ_1 , sh_1, ft_1, fy_1 , are also multiplied by $\text{Min}(1, 1.25 * (l_b/l_d)^{2/3})$, from 10.3.5, ASCE 41-17.

with $f_{sv} = f_s = 656.25$

with $E_{sv} = E_s = 200000.00$

$1 = A_{sl,ten}/(b*d) * (f_{s1}/f_c) = 0.15676884$

$2 = A_{sl,com}/(b*d) * (f_{s2}/f_c) = 0.15356947$

$v = A_{sl,mid}/(b*d) * (f_{sv}/f_c) = 0.07838442$

and confined core properties:

$b = 240.00$

$d = 328.00$

$d' = 13.00$

$f_{cc} (5A.2, TBDY) = 26.16063$

$cc (5A.5, TBDY) = 0.00290026$

$c = \text{confinement factor} = 1.09003$

$1 = A_{sl,ten}/(b*d) * (f_{s1}/f_c) = 0.21388431$

$2 = A_{sl,com}/(b*d) * (f_{s2}/f_c) = 0.20951933$

$v = A_{sl,mid}/(b*d) * (f_{sv}/f_c) = 0.10694216$

Case/Assumption: Unconfined full section - Steel rupture

' satisfies Eq. (4.3)

$v < v_{s,y2}$ - LHS eq.(4.5) is satisfied

$s_u (4.9) = 0.16631328$

$M_u = M_{Rc} (4.14) = 1.8802E+008$

$u = s_u (4.1) = 0.00010722$

Calculation of ratio l_b/l_d

Adequate Lap Length: $l_b/l_d \geq 1$

Calculation of M_{u2+}

Calculation of ultimate curvature u according to 4.1, Biskinis/Fardis 2013:

$u = 0.00010701$

$M_u = 1.8498E+008$

with full section properties:

$b = 300.00$

$d = 358.00$

$d' = 43.00$

$v = 8.1892042E-005$

$N = 211.0849$

$f_c = 24.00$

$co (5A.5, TBDY) = 0.002$

Final value of cu : $cu^* = \text{shear_factor} * \text{Max}(cu, cc) = 0.00773686$

The Shear_factor is considered equal to 1 (pure moment strength)

From (5.4b), TBDY: $cu = 0.00773686$

$w_e (5.4c) = 0.01121936$

$ase ((5.4d), TBDY) = 0.15672608$

$bo = 240.00$

$ho = 340.00$

$bi_2 = 346400.00$

$p_{sh,min} = \text{Min}(p_{sh,x}, p_{sh,y}) = 0.00261799$

psh,x (5.4d) = 0.00349066
Ash = Astir*ns = 78.53982
No stirups, ns = 2.00
bk = 300.00

psh,y (5.4d) = 0.00261799
Ash = Astir*ns = 78.53982
No stirups, ns = 2.00
bk = 400.00

s = 150.00
fywe = 656.25
fce = 24.00

From ((5.A.5), TBDY), TBDY: cc = 0.00290026
c = confinement factor = 1.09003

y1 = 0.0025
sh1 = 0.008
ft1 = 787.50
fy1 = 656.25
su1 = 0.032

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00

lo/lou,min = lb/ld = 1.00

su1 = 0.4*esu1_nominal ((5.5), TBDY) = 0.032

From table 5A.1, TBDY: esu1_nominal = 0.08,

For calculation of esu1_nominal and y1, sh1,ft1,fy1, it is considered
characteristic value fsy1 = fs1/1.2, from table 5.1, TBDY.

y1, sh1,ft1,fy1, are also multiplied by Min(1,1.25*(lb/ld)^ 2/3), from 10.3.5, ASCE 41-17.

with fs1 = fs = 656.25

with Es1 = Es = 200000.00

y2 = 0.0025
sh2 = 0.008
ft2 = 787.50
fy2 = 656.25
su2 = 0.032

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00

lo/lou,min = lb/lb,min = 1.00

su2 = 0.4*esu2_nominal ((5.5), TBDY) = 0.032

From table 5A.1, TBDY: esu2_nominal = 0.08,

For calculation of esu2_nominal and y2, sh2,ft2,fy2, it is considered
characteristic value fsy2 = fs2/1.2, from table 5.1, TBDY.

y1, sh1,ft1,fy1, are also multiplied by Min(1,1.25*(lb/ld)^ 2/3), from 10.3.5, ASCE 41-17.

with fs2 = fs = 656.25

with Es2 = Es = 200000.00

yv = 0.0025
shv = 0.008
ftv = 787.50
fyv = 656.25
suv = 0.032

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00

lo/lou,min = lb/ld = 1.00

suv = 0.4*esuv_nominal ((5.5), TBDY) = 0.032

From table 5A.1, TBDY: esuv_nominal = 0.08,

considering characteristic value fsyv = fsv/1.2, from table 5.1, TBDY

For calculation of esuv_nominal and yv, shv,ftv,fyv, it is considered
characteristic value fsyv = fsv/1.2, from table 5.1, TBDY.

y1, sh1,ft1,fy1, are also multiplied by Min(1,1.25*(lb/ld)^ 2/3), from 10.3.5, ASCE 41-17.

with fsv = fs = 656.25

with Esv = Es = 200000.00

1 = Asl,ten/(b*d)*(fs1/fc) = 0.15356947

2 = Asl,com/(b*d)*(fs2/fc) = 0.15676884

v = Asl,mid/(b*d)*(fsv/fc) = 0.07838442

and confined core properties:

$$b = 240.00$$

$$d = 328.00$$

$$d' = 13.00$$

$$fcc (5A.2, TBDY) = 26.16063$$

$$cc (5A.5, TBDY) = 0.00290026$$

$$c = \text{confinement factor} = 1.09003$$

$$1 = A_{sl,ten}/(b*d)*(f_{s1}/f_c) = 0.20951933$$

$$2 = A_{sl,com}/(b*d)*(f_{s2}/f_c) = 0.21388431$$

$$v = A_{sl,mid}/(b*d)*(f_{sv}/f_c) = 0.10694216$$

Case/Assumption: Unconfined full section - Steel rupture

' satisfies Eq. (4.3)

--->

$v < v_{s,y2}$ - LHS eq.(4.5) is satisfied

--->

$$s_u (4.9) = 0.16466458$$

$$\mu_u = M_{Rc} (4.14) = 1.8498E+008$$

$$u = s_u (4.1) = 0.00010701$$

Calculation of ratio l_b/d

Adequate Lap Length: $l_b/d \geq 1$

Calculation of μ_{u2} -

Calculation of ultimate curvature μ_u according to 4.1, Biskinis/Fardis 2013:

$$u = 0.00010732$$

$$\mu_u = 1.8800E+008$$

with full section properties:

$$b = 300.00$$

$$d = 357.00$$

$$d' = 42.00$$

$$v = 8.2121432E-005$$

$$N = 211.0849$$

$$f_c = 24.00$$

$$c_o (5A.5, TBDY) = 0.002$$

$$\text{Final value of } c_u: c_u^* = \text{shear_factor} * \text{Max}(c_u, c_c) = 0.00773686$$

The Shear_factor is considered equal to 1 (pure moment strength)

$$\text{From (5.4b), TBDY: } c_u = 0.00773686$$

$$w_e (5.4c) = 0.01121936$$

$$a_{se} ((5.4d), TBDY) = 0.15672608$$

$$b_o = 240.00$$

$$h_o = 340.00$$

$$b_{i2} = 346400.00$$

$$p_{sh,min} = \text{Min}(p_{sh,x}, p_{sh,y}) = 0.00261799$$

$$p_{sh,x} (5.4d) = 0.00349066$$

$$A_{sh} = A_{stir} * n_s = 78.53982$$

$$\text{No stirups, } n_s = 2.00$$

$$b_k = 300.00$$

$$p_{sh,y} (5.4d) = 0.00261799$$

$$A_{sh} = A_{stir} * n_s = 78.53982$$

$$\text{No stirups, } n_s = 2.00$$

$$b_k = 400.00$$

$$s = 150.00$$

$$f_{ywe} = 656.25$$

$$f_{ce} = 24.00$$

$$\text{From ((5.A5), TBDY), TBDY: } c_c = 0.00290026$$

$$c = \text{confinement factor} = 1.09003$$

y1 = 0.0025
sh1 = 0.008
ft1 = 787.50
fy1 = 656.25
su1 = 0.032

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00

lo/lou,min = lb/d = 1.00

su1 = 0.4*esu1_nominal ((5.5), TBDY) = 0.032

From table 5A.1, TBDY: esu1_nominal = 0.08,

For calculation of esu1_nominal and y1, sh1,ft1,fy1, it is considered
characteristic value fsy1 = fs1/1.2, from table 5.1, TBDY.

y1, sh1,ft1,fy1, are also multiplied by $\text{Min}(1, 1.25 \cdot (lb/d)^{2/3})$, from 10.3.5, ASCE 41-17.

with fs1 = fs = 656.25

with Es1 = Es = 200000.00

y2 = 0.0025
sh2 = 0.008
ft2 = 787.50
fy2 = 656.25
su2 = 0.032

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00

lo/lou,min = lb/lb,min = 1.00

su2 = 0.4*esu2_nominal ((5.5), TBDY) = 0.032

From table 5A.1, TBDY: esu2_nominal = 0.08,

For calculation of esu2_nominal and y2, sh2,ft2,fy2, it is considered
characteristic value fsy2 = fs2/1.2, from table 5.1, TBDY.

y1, sh1,ft1,fy1, are also multiplied by $\text{Min}(1, 1.25 \cdot (lb/d)^{2/3})$, from 10.3.5, ASCE 41-17.

with fs2 = fs = 656.25

with Es2 = Es = 200000.00

yv = 0.0025
shv = 0.008
ftv = 787.50
fyv = 656.25
suv = 0.032

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00

lo/lou,min = lb/d = 1.00

suv = 0.4*esuv_nominal ((5.5), TBDY) = 0.032

From table 5A.1, TBDY: esuv_nominal = 0.08,

considering characteristic value fsyv = fsv/1.2, from table 5.1, TBDY

For calculation of esuv_nominal and yv, shv,ftv,fyv, it is considered
characteristic value fsyv = fsv/1.2, from table 5.1, TBDY.

y1, sh1,ft1,fy1, are also multiplied by $\text{Min}(1, 1.25 \cdot (lb/d)^{2/3})$, from 10.3.5, ASCE 41-17.

with fsv = fs = 656.25

with Esv = Es = 200000.00

1 = Asl,ten/(b*d)*(fs1/fc) = 0.15720797

2 = Asl,com/(b*d)*(fs2/fc) = 0.15399964

v = Asl,mid/(b*d)*(fsv/fc) = 0.07860398

and confined core properties:

b = 240.00

d = 327.00

d' = 12.00

fcc (5A.2, TBDY) = 26.16063

cc (5A.5, TBDY) = 0.00290026

c = confinement factor = 1.09003

1 = Asl,ten/(b*d)*(fs1/fc) = 0.21453839

2 = Asl,com/(b*d)*(fs2/fc) = 0.21016006

v = Asl,mid/(b*d)*(fsv/fc) = 0.1072692

Case/Assumption: Unconfined full section - Steel rupture

' satisfies Eq. (4.3)

---->

v < vs,y2 - LHS eq.(4.5) is satisfied

---->

su (4.9) = 0.16474284
Mu = MRc (4.14) = 1.8800E+008
u = su (4.1) = 0.00010732

Calculation of ratio lb/l_d

Adequate Lap Length: lb/l_d >= 1

Calculation of Shear Strength Vr = Min(Vr1,Vr2) = 261431.672

Calculation of Shear Strength at edge 1, Vr1 = 261431.672
Vr1 = Vn ((22.5.1.1), ACI 318-14)

NOTE: In expression (22.5.1.1) 'Vw' is replaced by 'Vw+ f*Vf'
where Vf is the contribution of FRPs (11.3), ACI 440).

From Table (22.5.5.1), ACI 318-14: Vc = 85502.483
= 1 (normal-weight concrete)
fc' = 24.00, but fc'^0.5 <= 8.3 MPa (22.5.3.1, ACI 318-14)
pw = As/(bw*d) = 0.00628319
As (tension reinf.) = 603.1858
bw = 300.00
d = 320.00
Vu*d/Mu < 1 = 1.00
Mu = 30114.962
Vu = 2740.265

From (11.5.4.8), ACI 318-14: Vs = 175929.189
Av = 157079.633
fy = 525.00
s = 150.00

Vs has been multiplied by 1 (s<d/2, according to ASCE 41-17,10.3.4)
Vf ((11-3)-(11.4), ACI 440) = 0.00
From (11-11), ACI 440: Vs + Vf <= 312423.44

Calculation of Shear Strength at edge 2, Vr2 = 261431.672
Vr2 = Vn ((22.5.1.1), ACI 318-14)

NOTE: In expression (22.5.1.1) 'Vw' is replaced by 'Vw+ f*Vf'
where Vf is the contribution of FRPs (11.3), ACI 440).

From Table (22.5.5.1), ACI 318-14: Vc = 85502.483
= 1 (normal-weight concrete)
fc' = 24.00, but fc'^0.5 <= 8.3 MPa (22.5.3.1, ACI 318-14)
pw = As/(bw*d) = 0.00628319
As (tension reinf.) = 603.1858
bw = 300.00
d = 320.00
Vu*d/Mu < 1 = 1.00
Mu = 30115.665
Vu = 2740.264

From (11.5.4.8), ACI 318-14: Vs = 175929.189
Av = 157079.633
fy = 525.00
s = 150.00

Vs has been multiplied by 1 (s<d/2, according to ASCE 41-17,10.3.4)
Vf ((11-3)-(11.4), ACI 440) = 0.00
From (11-11), ACI 440: Vs + Vf <= 312423.44

End Of Calculation of Shear Capacity ratio for element: beam B1 of floor 1
At local axis: 3

Start Of Calculation of Shear Capacity ratio for element: beam B1 of floor 1

At Shear local axis: 2

(Bending local axis: 3)

Section Type: rcars

Constant Properties

Knowledge Factor, $\gamma = 1.00$

Mean strength values are used for both shear and moment calculations.

Consequently:

Existing material of Primary Member: Concrete Strength, $f_c = f_{cm} = 24.00$

Existing material of Primary Member: Steel Strength, $f_s = f_{sm} = 525.00$

Concrete Elasticity, $E_c = 23025.204$

Steel Elasticity, $E_s = 200000.00$

#####

Note: Especially for the calculation of moment strengths,

the above steel re-bar strengths are multiplied by 1.25 according to R18.6.5, ACI 318-14

Existing material: Steel Strength, $f_s = 1.25 \cdot f_{sm} = 656.25$

#####

Section Height, $H = 400.00$

Section Width, $W = 300.00$

Cover Thickness, $c = 25.00$

Mean Confinement Factor overall section = 1.09003

Element Length, $L = 1850.00$

Primary Member

Smooth Bars

Ductile Steel

With Detailing for Earthquake Resistance (including stirrups closed at 135°)

Longitudinal Bars With Ends Lapped Starting at the End Sections

Adequate Lap Length ($l_o/l_{ou}, \min >= 1$)

No FRP Wrapping

Stepwise Properties

At local axis: 2

EDGE -A-

Shear Force, $V_a = -3.6870970E-015$

EDGE -B-

Shear Force, $V_b = 3.6870970E-015$

BOTH EDGES

Axial Force, $F = -211.0849$

Longitudinal Reinforcement Area Distribution (in 2 divisions)

-Tension: $A_{st} = 603.1858$

-Compression: $A_{sc} = 923.6282$

Longitudinal Reinforcement Area Distribution (in 3 divisions)

-Tension: $A_{st,ten} = 508.938$

-Compression: $A_{sc,com} = 508.938$

-Middle: $A_{st,mid} = 508.938$

Calculation of Shear Capacity ratio, $V_e/V_r = 0.79211753$

Member Controlled by Flexure ($V_e/V_r < 1$)

Calculation of Shear Demand from fig. R18.6.5, ACI 318-14 $V_e = (M_{pr1} + M_{pr2})/l_n \pm w_u \cdot l_n/2 = 137993.601$
with

$M_{pr1} = \text{Max}(M_{u1+}, M_{u1-}) = 1.2764E+008$

$M_{u1+} = 1.2764E+008$, is the ultimate moment strength at the edge 1 of the member in the actual moment direction which is defined for the static loading combination

$M_{u1-} = 1.2764E+008$, is the ultimate moment strength at the edge 1 of the member in the opposite moment direction which is defined for the static loading combination

$M_{pr2} = \text{Max}(M_{u2+}, M_{u2-}) = 1.2764E+008$

$M_{u2+} = 1.2764E+008$, is the ultimate moment strength at the edge 2 of the member in the actual moment direction which is defined for the static loading combination

$M_{u2-} = 1.2764E+008$, is the ultimate moment strength at the edge 2 of the member in the opposite moment

direction which is defined for the the static loading combination
and

$$\pm wu*ln = (|V1| + |V2|)/2$$

with

V1 = -3.6870970E-015, is the shear force acting at edge 1 for the the static loading combination

V2 = 3.6870970E-015, is the shear force acting at edge 2 for the the static loading combination

Calculation of Mu1+

Calculation of ultimate curvature ϕ_u according to 4.1, Biskinis/Fardis 2013:

$$u = 0.00015613$$

$$Mu = 1.2764E+008$$

with full section properties:

$$b = 400.00$$

$$d = 258.00$$

$$d' = 42.00$$

$$v = 8.5224858E-005$$

$$N = 211.0849$$

$$fc = 24.00$$

$$co \text{ (5A.5, TBDY)} = 0.002$$

$$\text{Final value of } \phi_u: \phi_u^* = \text{shear_factor} * \text{Max}(\phi_u, \phi_c) = 0.00773686$$

The Shear_factor is considered equal to 1 (pure moment strength)

$$\text{From (5.4b), TBDY: } \phi_u = 0.00773686$$

$$\phi_{ue} \text{ (5.4c)} = 0.01121936$$

$$\phi_{ase} \text{ ((5.4d), TBDY)} = 0.15672608$$

$$b_o = 240.00$$

$$h_o = 340.00$$

$$b_i^2 = 346400.00$$

$$\phi_{sh,min} = \text{Min}(\phi_{sh,x}, \phi_{sh,y}) = 0.00261799$$

 $\phi_{sh,x} \text{ (5.4d)} = 0.00349066$

$$A_{sh} = A_{stir} * n_s = 78.53982$$

$$\text{No stirups, } n_s = 2.00$$

$$b_k = 300.00$$

 $\phi_{sh,y} \text{ (5.4d)} = 0.00261799$

$$A_{sh} = A_{stir} * n_s = 78.53982$$

$$\text{No stirups, } n_s = 2.00$$

$$b_k = 400.00$$

 $s = 150.00$

$$f_{ywe} = 656.25$$

$$f_{ce} = 24.00$$

$$\text{From ((5.A5), TBDY), TBDY: } \phi_c = 0.00290026$$

$$c = \text{confinement factor} = 1.09003$$

$$y_1 = 0.0025$$

$$sh_1 = 0.008$$

$$ft_1 = 787.50$$

$$fy_1 = 656.25$$

$$su_1 = 0.032$$

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor

and also multiplied by the shear_factor according to 15.7.1.4, with

Shear_factor = 1.00

$$l_o/l_{ou,min} = l_b/l_d = 1.00$$

$$su_1 = 0.4 * esu_{1,nominal} \text{ ((5.5), TBDY)} = 0.032$$

$$\text{From table 5A.1, TBDY: } esu_{1,nominal} = 0.08,$$

For calculation of $esu_{1,nominal}$ and y_1, sh_1, ft_1, fy_1 , it is considered

characteristic value $fsy_1 = fs_1/1.2$, from table 5.1, TBDY.

y_1, sh_1, ft_1, fy_1 , are also multiplied by $\text{Min}(1, 1.25 * (l_b/l_d)^{2/3})$, from 10.3.5, ASCE 41-17.

$$\text{with } fs_1 = fs = 656.25$$

$$\text{with } Es_1 = Es = 200000.00$$

$$y_2 = 0.0025$$

$$sh_2 = 0.008$$

$$ft2 = 787.50$$

$$fy2 = 656.25$$

$$su2 = 0.032$$

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00

$$lo/lou,min = lb/lb,min = 1.00$$

$$su2 = 0.4 * esu2_nominal ((5.5), TBDY) = 0.032$$

From table 5A.1, TBDY: esu2_nominal = 0.08,

For calculation of esu2_nominal and y2, sh2,ft2,fy2, it is considered
characteristic value fsy2 = fs2/1.2, from table 5.1, TBDY.

y1, sh1,ft1,fy1, are also multiplied by $\text{Min}(1, 1.25 * (lb/ld)^{2/3})$, from 10.3.5, ASCE 41-17.

$$\text{with } fs2 = fs = 656.25$$

$$\text{with } Es2 = Es = 200000.00$$

$$yv = 0.0025$$

$$shv = 0.008$$

$$ftv = 787.50$$

$$fyv = 656.25$$

$$suv = 0.032$$

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00

$$lo/lou,min = lb/ld = 1.00$$

$$suv = 0.4 * esuv_nominal ((5.5), TBDY) = 0.032$$

From table 5A.1, TBDY: esuv_nominal = 0.08,

considering characteristic value fsyv = fsv/1.2, from table 5.1, TBDY

For calculation of esuv_nominal and yv, shv,ftv,fyv, it is considered
characteristic value fsyv = fsv/1.2, from table 5.1, TBDY.

y1, sh1,ft1,fy1, are also multiplied by $\text{Min}(1, 1.25 * (lb/ld)^{2/3})$, from 10.3.5, ASCE 41-17.

$$\text{with } fsv = fs = 656.25$$

$$\text{with } Esv = Es = 200000.00$$

$$1 = Asl,ten/(b*d)*(fs1/fc) = 0.13484761$$

$$2 = Asl,com/(b*d)*(fs2/fc) = 0.13484761$$

$$v = Asl,mid/(b*d)*(fsv/fc) = 0.13484761$$

and confined core properties:

$$b = 340.00$$

$$d = 228.00$$

$$d' = 12.00$$

$$fcc (5A.2, TBDY) = 26.16063$$

$$cc (5A.5, TBDY) = 0.00290026$$

$$c = \text{confinement factor} = 1.09003$$

$$1 = Asl,ten/(b*d)*(fs1/fc) = 0.17951849$$

$$2 = Asl,com/(b*d)*(fs2/fc) = 0.17951849$$

$$v = Asl,mid/(b*d)*(fsv/fc) = 0.17951849$$

Case/Assumption: Unconfined full section - Steel rupture

' does not satisfy Eq. (4.3)

---->

$v < vs,c$ - RHS eq.(4.5) is satisfied

---->

$$su (4.9) = 0.20560388$$

$$Mu = MRc (4.14) = 1.2764E+008$$

$$u = su (4.1) = 0.00015613$$

Calculation of ratio lb/ld

Adequate Lap Length: $lb/ld \geq 1$

Calculation of Mu1-

Calculation of ultimate curvature u according to 4.1, Biskinis/Fardis 2013:

$$u = 0.00015613$$

$$Mu = 1.2764E+008$$

with full section properties:

$$b = 400.00$$

$$d = 258.00$$

$$d' = 42.00$$

$$v = 8.5224858E-005$$

$$N = 211.0849$$

$$f_c = 24.00$$

$$c_o(5A.5, \text{TBDY}) = 0.002$$

$$\text{Final value of } c_u: c_u^* = \text{shear_factor} * \text{Max}(c_u, c_c) = 0.00773686$$

The Shear_factor is considered equal to 1 (pure moment strength)

$$\text{From (5.4b), TBDY: } c_u = 0.00773686$$

$$w_e(5.4c) = 0.01121936$$

$$a_{se}((5.4d), \text{TBDY}) = 0.15672608$$

$$b_o = 240.00$$

$$h_o = 340.00$$

$$b_i^2 = 346400.00$$

$$p_{sh,min} = \text{Min}(p_{sh,x}, p_{sh,y}) = 0.00261799$$

$$p_{sh,x}(5.4d) = 0.00349066$$

$$A_{sh} = A_{stir} * n_s = 78.53982$$

No stirrups, $n_s = 2.00$

$$b_k = 300.00$$

$$p_{sh,y}(5.4d) = 0.00261799$$

$$A_{sh} = A_{stir} * n_s = 78.53982$$

No stirrups, $n_s = 2.00$

$$b_k = 400.00$$

$$s = 150.00$$

$$f_{ywe} = 656.25$$

$$f_{ce} = 24.00$$

$$\text{From ((5.A5), TBDY), TBDY: } c_c = 0.00290026$$

$$c = \text{confinement factor} = 1.09003$$

$$y_1 = 0.0025$$

$$sh_1 = 0.008$$

$$ft_1 = 787.50$$

$$fy_1 = 656.25$$

$$su_1 = 0.032$$

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor and also multiplied by the shear_factor according to 15.7.1.4, with Shear_factor = 1.00

$$l_o/l_{o,min} = l_b/d = 1.00$$

$$su_1 = 0.4 * esu_1_{nominal}((5.5), \text{TBDY}) = 0.032$$

$$\text{From table 5A.1, TBDY: } esu_1_{nominal} = 0.08,$$

For calculation of $esu_1_{nominal}$ and y_1, sh_1, ft_1, fy_1 , it is considered characteristic value $fsy_1 = fs_1/1.2$, from table 5.1, TBDY.

y_1, sh_1, ft_1, fy_1 , are also multiplied by $\text{Min}(1, 1.25 * (l_b/d)^{2/3})$, from 10.3.5, ASCE 41-17.

$$\text{with } fs_1 = fs = 656.25$$

$$\text{with } Es_1 = Es = 200000.00$$

$$y_2 = 0.0025$$

$$sh_2 = 0.008$$

$$ft_2 = 787.50$$

$$fy_2 = 656.25$$

$$su_2 = 0.032$$

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor and also multiplied by the shear_factor according to 15.7.1.4, with Shear_factor = 1.00

$$l_o/l_{o,min} = l_b/l_{b,min} = 1.00$$

$$su_2 = 0.4 * esu_2_{nominal}((5.5), \text{TBDY}) = 0.032$$

$$\text{From table 5A.1, TBDY: } esu_2_{nominal} = 0.08,$$

For calculation of $esu_2_{nominal}$ and y_2, sh_2, ft_2, fy_2 , it is considered characteristic value $fsy_2 = fs_2/1.2$, from table 5.1, TBDY.

y_2, sh_2, ft_2, fy_2 , are also multiplied by $\text{Min}(1, 1.25 * (l_b/d)^{2/3})$, from 10.3.5, ASCE 41-17.

$$\text{with } fs_2 = fs = 656.25$$

$$\text{with } Es_2 = Es = 200000.00$$

$$y_v = 0.0025$$

$shv = 0.008$
 $ftv = 787.50$
 $fyv = 656.25$
 $suv = 0.032$
 using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
 and also multiplied by the shear_factor according to 15.7.1.4, with
 $Shear_factor = 1.00$
 $lo/lou,min = lb/ld = 1.00$
 $suv = 0.4 * esuv_nominal ((5.5), TBDY) = 0.032$
 From table 5A.1, TBDY: $esuv_nominal = 0.08$,
 considering characteristic value $fsyv = fsv/1.2$, from table 5.1, TBDY
 For calculation of $esuv_nominal$ and yv , shv,ftv,fyv , it is considered
 characteristic value $fsyv = fsv/1.2$, from table 5.1, TBDY.
 $y1, sh1,ft1,fy1$, are also multiplied by $Min(1,1.25*(lb/ld)^{2/3})$, from 10.3.5, ASCE 41-17.
 with $fsv = fs = 656.25$
 with $Esv = Es = 200000.00$
 $1 = Asl,ten/(b*d)*(fs1/fc) = 0.13484761$
 $2 = Asl,com/(b*d)*(fs2/fc) = 0.13484761$
 $v = Asl,mid/(b*d)*(fsv/fc) = 0.13484761$
 and confined core properties:
 $b = 340.00$
 $d = 228.00$
 $d' = 12.00$
 $fcc (5A.2, TBDY) = 26.16063$
 $cc (5A.5, TBDY) = 0.00290026$
 $c = confinement\ factor = 1.09003$
 $1 = Asl,ten/(b*d)*(fs1/fc) = 0.17951849$
 $2 = Asl,com/(b*d)*(fs2/fc) = 0.17951849$
 $v = Asl,mid/(b*d)*(fsv/fc) = 0.17951849$
 Case/Assumption: Unconfined full section - Steel rupture
 ' does not satisfy Eq. (4.3)
 --->
 $v < vs,c$ - RHS eq.(4.5) is satisfied
 --->
 $su (4.9) = 0.20560388$
 $Mu = MRc (4.14) = 1.2764E+008$
 $u = su (4.1) = 0.00015613$

 Calculation of ratio lb/ld

Adequate Lap Length: $lb/ld \geq 1$

Calculation of $Mu2+$

Calculation of ultimate curvature u according to 4.1, Biskinis/Fardis 2013:

$u = 0.00015613$
 $Mu = 1.2764E+008$

with full section properties:

$b = 400.00$
 $d = 258.00$
 $d' = 42.00$
 $v = 8.5224858E-005$
 $N = 211.0849$
 $fc = 24.00$
 $co (5A.5, TBDY) = 0.002$
 Final value of cu : $cu^* = shear_factor * Max(cu, cc) = 0.00773686$
 The Shear_factor is considered equal to 1 (pure moment strength)
 From (5.4b), TBDY: $cu = 0.00773686$
 $we (5.4c) = 0.01121936$
 $ase ((5.4d), TBDY) = 0.15672608$
 $bo = 240.00$

ho = 340.00
bi2 = 346400.00
psh,min = Min(psh,x , psh,y) = 0.00261799

psh,x (5.4d) = 0.00349066
Ash = Astir*ns = 78.53982
No stirups, ns = 2.00
bk = 300.00

psh,y (5.4d) = 0.00261799
Ash = Astir*ns = 78.53982
No stirups, ns = 2.00
bk = 400.00

s = 150.00
fywe = 656.25
fce = 24.00
From ((5.A5), TBDY), TBDY: cc = 0.00290026
c = confinement factor = 1.09003
y1 = 0.0025
sh1 = 0.008
ft1 = 787.50
fy1 = 656.25
su1 = 0.032

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00
lo/lou,min = lb/d = 1.00
su1 = 0.4*esu1_nominal ((5.5), TBDY) = 0.032
From table 5A.1, TBDY: esu1_nominal = 0.08,
For calculation of esu1_nominal and y1, sh1,ft1,fy1, it is considered
characteristic value fsy1 = fs1/1.2, from table 5.1, TBDY.
y1, sh1,ft1,fy1, are also multiplied by Min(1,1.25*(lb/d)^ 2/3), from 10.3.5, ASCE 41-17.
with fs1 = fs = 656.25
with Es1 = Es = 200000.00

y2 = 0.0025
sh2 = 0.008
ft2 = 787.50
fy2 = 656.25
su2 = 0.032

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00
lo/lou,min = lb/lb,min = 1.00
su2 = 0.4*esu2_nominal ((5.5), TBDY) = 0.032
From table 5A.1, TBDY: esu2_nominal = 0.08,
For calculation of esu2_nominal and y2, sh2,ft2,fy2, it is considered
characteristic value fsy2 = fs2/1.2, from table 5.1, TBDY.
y1, sh1,ft1,fy1, are also multiplied by Min(1,1.25*(lb/d)^ 2/3), from 10.3.5, ASCE 41-17.
with fs2 = fs = 656.25
with Es2 = Es = 200000.00

yv = 0.0025
shv = 0.008
ftv = 787.50
fyv = 656.25
suv = 0.032

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00
lo/lou,min = lb/d = 1.00
suv = 0.4*esuv_nominal ((5.5), TBDY) = 0.032
From table 5A.1, TBDY: esuv_nominal = 0.08,
considering characteristic value fsyv = fsv/1.2, from table 5.1, TBDY
For calculation of esuv_nominal and yv, shv,ftv,fyv, it is considered
characteristic value fsyv = fsv/1.2, from table 5.1, TBDY.
y1, sh1,ft1,fy1, are also multiplied by Min(1,1.25*(lb/d)^ 2/3), from 10.3.5, ASCE 41-17.
with fsv = fs = 656.25

with $E_{sv} = E_s = 200000.00$

$$1 = A_{sl,ten}/(b*d)*(f_{s1}/f_c) = 0.13484761$$

$$2 = A_{sl,com}/(b*d)*(f_{s2}/f_c) = 0.13484761$$

$$v = A_{sl,mid}/(b*d)*(f_{sv}/f_c) = 0.13484761$$

and confined core properties:

$$b = 340.00$$

$$d = 228.00$$

$$d' = 12.00$$

$$f_{cc} (5A.2, TBDY) = 26.16063$$

$$c_c (5A.5, TBDY) = 0.00290026$$

$$c = \text{confinement factor} = 1.09003$$

$$1 = A_{sl,ten}/(b*d)*(f_{s1}/f_c) = 0.17951849$$

$$2 = A_{sl,com}/(b*d)*(f_{s2}/f_c) = 0.17951849$$

$$v = A_{sl,mid}/(b*d)*(f_{sv}/f_c) = 0.17951849$$

Case/Assumption: Unconfined full section - Steel rupture

' does not satisfy Eq. (4.3)

--->

$v < v_{s,c}$ - RHS eq.(4.5) is satisfied

--->

$$s_u (4.9) = 0.20560388$$

$$M_u = M_{Rc} (4.14) = 1.2764E+008$$

$$u = s_u (4.1) = 0.00015613$$

Calculation of ratio l_b/d

Adequate Lap Length: $l_b/d \geq 1$

Calculation of M_{u2}

Calculation of ultimate curvature u according to 4.1, Biskinis/Fardis 2013:

$$u = 0.00015613$$

$$M_u = 1.2764E+008$$

with full section properties:

$$b = 400.00$$

$$d = 258.00$$

$$d' = 42.00$$

$$v = 8.5224858E-005$$

$$N = 211.0849$$

$$f_c = 24.00$$

$$c_c (5A.5, TBDY) = 0.002$$

$$\text{Final value of } c_u: c_u^* = \text{shear_factor} * \text{Max}(c_u, c_c) = 0.00773686$$

The Shear_factor is considered equal to 1 (pure moment strength)

$$\text{From (5.4b), TBDY: } c_u = 0.00773686$$

$$w_e (5.4c) = 0.01121936$$

$$a_{se} ((5.4d), TBDY) = 0.15672608$$

$$b_o = 240.00$$

$$h_o = 340.00$$

$$b_{i2} = 346400.00$$

$$p_{sh,min} = \text{Min}(p_{sh,x}, p_{sh,y}) = 0.00261799$$

$$p_{sh,x} (5.4d) = 0.00349066$$

$$A_{sh} = A_{stir} * n_s = 78.53982$$

$$\text{No stirups, } n_s = 2.00$$

$$b_k = 300.00$$

$$p_{sh,y} (5.4d) = 0.00261799$$

$$A_{sh} = A_{stir} * n_s = 78.53982$$

$$\text{No stirups, } n_s = 2.00$$

$$b_k = 400.00$$

$$s = 150.00$$

$$fywe = 656.25$$

$$fce = 24.00$$

From ((5.A.5), TBDY), TBDY: $cc = 0.00290026$

$$c = \text{confinement factor} = 1.09003$$

$$y1 = 0.0025$$

$$sh1 = 0.008$$

$$ft1 = 787.50$$

$$fy1 = 656.25$$

$$su1 = 0.032$$

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00

$$lo/lou,min = lb/ld = 1.00$$

$$su1 = 0.4 * esu1_nominal ((5.5), TBDY) = 0.032$$

From table 5A.1, TBDY: $esu1_nominal = 0.08$,

For calculation of $esu1_nominal$ and $y1, sh1, ft1, fy1$, it is considered
characteristic value $fsy1 = fs1/1.2$, from table 5.1, TBDY.

$y1, sh1, ft1, fy1$, are also multiplied by $\text{Min}(1, 1.25 * (lb/ld)^{2/3})$, from 10.3.5, ASCE 41-17.

$$\text{with } fs1 = fs = 656.25$$

$$\text{with } Es1 = Es = 200000.00$$

$$y2 = 0.0025$$

$$sh2 = 0.008$$

$$ft2 = 787.50$$

$$fy2 = 656.25$$

$$su2 = 0.032$$

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00

$$lo/lou,min = lb/lb,min = 1.00$$

$$su2 = 0.4 * esu2_nominal ((5.5), TBDY) = 0.032$$

From table 5A.1, TBDY: $esu2_nominal = 0.08$,

For calculation of $esu2_nominal$ and $y2, sh2, ft2, fy2$, it is considered
characteristic value $fsy2 = fs2/1.2$, from table 5.1, TBDY.

$y1, sh1, ft1, fy1$, are also multiplied by $\text{Min}(1, 1.25 * (lb/ld)^{2/3})$, from 10.3.5, ASCE 41-17.

$$\text{with } fs2 = fs = 656.25$$

$$\text{with } Es2 = Es = 200000.00$$

$$yv = 0.0025$$

$$shv = 0.008$$

$$ftv = 787.50$$

$$fyv = 656.25$$

$$suv = 0.032$$

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00

$$lo/lou,min = lb/ld = 1.00$$

$$suv = 0.4 * esuv_nominal ((5.5), TBDY) = 0.032$$

From table 5A.1, TBDY: $esuv_nominal = 0.08$,

considering characteristic value $fsyv = fsv/1.2$, from table 5.1, TBDY
For calculation of $esuv_nominal$ and yv, shv, ftv, fyv , it is considered
characteristic value $fsyv = fsv/1.2$, from table 5.1, TBDY.

$y1, sh1, ft1, fy1$, are also multiplied by $\text{Min}(1, 1.25 * (lb/ld)^{2/3})$, from 10.3.5, ASCE 41-17.

$$\text{with } fsv = fs = 656.25$$

$$\text{with } Esv = Es = 200000.00$$

$$1 = Asl,ten/(b*d)*(fs1/fc) = 0.13484761$$

$$2 = Asl,com/(b*d)*(fs2/fc) = 0.13484761$$

$$v = Asl,mid/(b*d)*(fsv/fc) = 0.13484761$$

and confined core properties:

$$b = 340.00$$

$$d = 228.00$$

$$d' = 12.00$$

$$fcc (5A.2, TBDY) = 26.16063$$

$$cc (5A.5, TBDY) = 0.00290026$$

$$c = \text{confinement factor} = 1.09003$$

$$1 = Asl,ten/(b*d)*(fs1/fc) = 0.17951849$$

$$2 = Asl,com/(b*d)*(fs2/fc) = 0.17951849$$

$$v = Asl,mid/(b*d)*(fsv/fc) = 0.17951849$$

Case/Assumption: Unconfinedsd full section - Steel rupture

' does not satisfy Eq. (4.3)

---->

$v < v_{s,c}$ - RHS eq.(4.5) is satisfied

---->

μ_u (4.9) = 0.20560388

$M_u = M_{Rc}$ (4.14) = 1.2764E+008

$u = \mu_u$ (4.1) = 0.00015613

Calculation of ratio l_b/d

Adequate Lap Length: $l_b/d \geq 1$

Calculation of Shear Strength $V_r = \text{Min}(V_{r1}, V_{r2}) = 174208.493$

Calculation of Shear Strength at edge 1, $V_{r1} = 174208.493$

$V_{r1} = V_n$ ((22.5.1.1), ACI 318-14)

NOTE: In expression (22.5.1.1) ' V_w ' is replaced by ' $V_w + f \cdot V_f$ '
where V_f is the contribution of FRPs (11.3), ACI 440).

From Table (22.5.5.1), ACI 318-14: $V_c = 75248.325$

= 1 (normal-weight concrete)

$f_c' = 24.00$, but $f_c'^{0.5} \leq 8.3$ MPa (22.5.3.1, ACI 318-14)

$\rho_w = A_s/(b_w \cdot d) = 0.00628319$

A_s (tension reinf.) = 603.1858

$b_w = 400.00$

$d = 240.00$

$V_u \cdot d / M_u < 1 = 0.00$

$M_u = 7.6252677E-012$

$V_u = 3.6870970E-015$

From (11.5.4.8), ACI 318-14: $V_s = 98960.169$

$A_v = 157079.633$

$f_y = 525.00$

$s = 150.00$

V_s has been multiplied by $2(1-s/d)$ ($s > d/2$, according to ASCE 41-17,10.3.4)

$2(1-s/d) = 0.75$

V_f ((11-3)-(11.4), ACI 440) = 0.00

From (11-11), ACI 440: $V_s + V_f \leq 312423.44$

Calculation of Shear Strength at edge 2, $V_{r2} = 174208.493$

$V_{r2} = V_n$ ((22.5.1.1), ACI 318-14)

NOTE: In expression (22.5.1.1) ' V_w ' is replaced by ' $V_w + f \cdot V_f$ '
where V_f is the contribution of FRPs (11.3), ACI 440).

From Table (22.5.5.1), ACI 318-14: $V_c = 75248.325$

= 1 (normal-weight concrete)

$f_c' = 24.00$, but $f_c'^{0.5} \leq 8.3$ MPa (22.5.3.1, ACI 318-14)

$\rho_w = A_s/(b_w \cdot d) = 0.00628319$

A_s (tension reinf.) = 603.1858

$b_w = 400.00$

$d = 240.00$

$V_u \cdot d / M_u < 1 = 0.00$

$M_u = 8.0393416E-013$

$V_u = 3.6870970E-015$

From (11.5.4.8), ACI 318-14: $V_s = 98960.169$

$A_v = 157079.633$

$f_y = 525.00$

$s = 150.00$

V_s has been multiplied by $2(1-s/d)$ ($s > d/2$, according to ASCE 41-17,10.3.4)

$2(1-s/d) = 0.75$

V_f ((11-3)-(11.4), ACI 440) = 0.00

From (11-11), ACI 440: $V_s + V_f \leq 312423.44$

End Of Calculation of Shear Capacity ratio for element: beam B1 of floor 1
At local axis: 2

Start Of Calculation of Chord Rotation Capacity for element: beam B1 of floor 1
At local axis: 3
Integration Section: (a)
Section Type: rcars

Constant Properties

Knowledge Factor, $\gamma = 1.00$
Chord Rotation is generally considered as Deformation-Controlled Action according to Table C7-1, ASCE 41-17.
Mean strengths are used for Deformation-Controlled Actions according to 7.5.1.3, ASCE 41-17
Consequently:
Existing material of Primary Member: Concrete Strength, $f_c = f_{cm} = 24.00$
Existing material of Primary Member: Steel Strength, $f_s = f_{sm} = 525.00$
Concrete Elasticity, $E_c = 23025.204$
Steel Elasticity, $E_s = 200000.00$
Section Height, $H = 400.00$
Section Width, $W = 300.00$
Cover Thickness, $c = 25.00$
Element Length, $L = 1850.00$
Primary Member
Smooth Bars
Ductile Steel
With Detailing for Earthquake Resistance (including stirrups closed at 135°)
Longitudinal Bars With Ends Lapped Starting at the End Sections
Adequate Lap Length ($l_b/d >= 1$)
No FRP Wrapping

Stepwise Properties

Bending Moment, $M = -1.0854113E-011$
Shear Force, $V_2 = 2.3583230E-014$
Shear Force, $V_3 = -2011.906$
Axial Force, $F = -490.6724$
Longitudinal Reinforcement Area Distribution (in 2 divisions)
-Tension: $A_{st} = 603.1858$
-Compression: $A_{sc} = 923.6282$
Longitudinal Reinforcement Area Distribution (in 3 divisions)
-Tension: $A_{st,ten} = 508.938$
-Compression: $A_{st,com} = 508.938$
-Middle: $A_{st,mid} = 508.938$
Mean Diameter of Tension Reinforcement, $D_bL = 14.66667$

Existing component: From table 7-7, ASCE 41_17: Final chord rotation Capacity $u_{,R} = \gamma \cdot u = 0.02404297$
 $u = \gamma \cdot u + p = 0.02404297$

- Calculation of γ -

$\gamma = (M_y \cdot L_s / 3) / E_{eff} = 0.00404297$ ((4.29), Biskinis Phd)
 $M_y = 8.1517E+007$
 $L_s = M/V$ (with $L_s > 0.1 \cdot L$ and $L_s < 2 \cdot L$) = 925.00
From table 10.5, ASCE 41_17: $E_{eff} = 0.3 \cdot E_c \cdot I_g = 6.2168E+012$

Calculation of Yielding Moment M_y

Calculation of ρ_y and M_y according to Annex 7 -

$y = \text{Min}(y_{\text{ten}}, y_{\text{com}})$
 $y_{\text{ten}} = 1.4111379\text{E-}005$
with $f_y = 525.00$
 $d = 258.00$
 $y = 0.27899188$
 $A = 0.01480377$
 $B = 0.00861063$
with $p_t = 0.00493157$
 $p_c = 0.00493157$
 $p_v = 0.00493157$
 $N = 490.6724$
 $b = 400.00$
 $\rho = 0.1627907$
 $y_{\text{comp}} = 2.6071644\text{E-}005$
with $f_c = 24.00$
 $E_c = 23025.204$
 $y = 0.27892802$
 $A = 0.01478204$
 $B = 0.00860158$
with $E_s = 200000.00$

Calculation of ratio I_b/I_d

Adequate Lap Length: $I_b/I_d \geq 1$

- Calculation of ρ_p -

From table 10-7: $\rho_p = 0.02$

with:

- Condition i occurred

Beam controlled by flexure: $V_p/V_o \leq 1$

shear control ratio $V_p/V_o = 0.79211753$

- Transverse Reinforcement: NC

- Stirrup Spacing $> d/3$

- Low ductility demand, $\rho_p / y < 2$ (table 10-6, ASCE 41-17)

$= -2.0351495\text{E-}021$

- Stirrup Spacing $> d/2$

$d = 258.00$

$s = 150.00$

- Strength provided by hoops $V_s < 3/4$ *design Shear

$V_s = 131946.891$, already given in calculation of shear control ratio

design Shear = $2.3583230\text{E-}014$

- ($\rho_p - \rho_p'$)/ $\rho_{\text{bal}} = -0.17627139$

$= A_{s1}/(b_w*d) = 0.00584482$

Tension Reinf Area: $A_{s1} = 603.1858$

$\rho_p' = A_{s2}/(b_w*d) = 0.00894989$

Compression Reinf Area: $A_{s2} = 923.6282$

From (B-1), ACI 318-11: $\rho_{\text{bal}} = 0.01761524$

$f_c = 24.00$

$f_y = 525.00$

From 10.2.7.3, ACI 318-11: $\rho_p = 0.85$

From fig R10.3.3, ACI 318-11 (Ence 454, too): $87000/(87000 + f_y) = c_b/d_t = 0.003/(0.003 + \rho_p) = 0.53333333$

$\rho_p = 0.002625$

- $V/(b_w*d*f_c^{0.5}) = 5.6174758\text{E-}019$, NOTE: units in lb & in

$b_w = 400.00$

End Of Calculation of Chord Rotation Capacity for element: beam B1 of floor 1

At local axis: 3

Integration Section: (a)

Calculation No. 13

beam B1, Floor 1



Limit State: Life Safety (data interpolation between analysis steps 1 and 2)

Analysis: Uniform +X

Check: Shear capacity VRd

Edge: End

Local Axis: (2)



Start Of Calculation of Shear Capacity for element: beam B1 of floor 1

At local axis: 2

Integration Section: (b)

Section Type: rcars

Constant Properties

Knowledge Factor, $\gamma = 1.00$

Member Shear Force is generally considered as Force-Controlled Action according to Table C7-1, ASCE 41-17.

Lower-bound strengths are used for Force-Controlled Actions according to 7.5.1.3, ASCE 41-17

Consequently:

Existing material of Primary Member: Concrete Strength, $f_c = f_{c_lower_bound} = 16.00$

Existing material of Primary Member: Steel Strength, $f_s = f_{s_lower_bound} = 420.00$

Concrete Elasticity, $E_c = 23025.204$

Steel Elasticity, $E_s = 200000.00$

Section Height, $H = 400.00$

Section Width, $W = 300.00$

Cover Thickness, $c = 25.00$

Element Length, $L = 1850.00$

Primary Member

Smooth Bars

Ductile Steel

With Detailing for Earthquake Resistance (including stirrups closed at 135°)

Longitudinal Bars With Ends Lapped Starting at the End Sections

Adequate Lap Length ($l_o/l_{o,min} = l_b/d \geq 1$)

No FRP Wrapping

Stepwise Properties

EDGE -A-

Bending Moment, $M_a = -1.0854113E-011$

Shear Force, $V_a = 2.3583230E-014$

EDGE -B-

Bending Moment, $M_b = 5.4436895E-011$

Shear Force, $V_b = -2.3583230E-014$

BOTH EDGES

Axial Force, $F = -490.6724$

Longitudinal Reinforcement Area Distribution (in 2 divisions)

-Tension: $A_{st} = 615.7522$

-Compression: $A_{sc} = 911.0619$

Longitudinal Reinforcement Area Distribution (in 3 divisions)

-Tension: $A_{st,ten} = 508.938$

-Compression: $A_{sc,com} = 508.938$

-Middle: $A_{st,mid} = 508.938$

Mean Diameter of Tension Reinforcement, $D_{bL,ten} = 14.66667$

Existing component: From table 7-7, ASCE 41_17: Final Shear Capacity $V_R = V_n = 140608.135$
 V_n ((22.5.1.1), ACI 318-14) = 140608.135

NOTE: In expression (22.5.1.1) ' V_w ' is replaced by ' $V_w + f_v V_f$ '
where V_f is the contribution of FRPs (11.3), ACI 440).

From Table (22.5.5.1), ACI 318-14: $V_c = 61440.00$
= 1 (normal-weight concrete)

$f_c' = 16.00$, but $f_c'^{0.5} \leq 8.3$ MPa (22.5.3.1, ACI 318-14)

$\rho_w = A_s / (b_w \cdot d) = 0.00641409$

A_s (tension reinf.) = 615.7522

$b_w = 400.00$

$d = 240.00$

$V_u \cdot d / M_u < 1 = 0.00$

$M_u = 5.4436895E-011$

$V_u = 2.3583230E-014$

From (11.5.4.8), ACI 318-14: $V_s = 79168.135$

$A_v = 157079.633$

$f_y = 420.00$

$s = 150.00$

V_s has been multiplied by $2(1-s/d)$ ($s > d/2$, according to ASCE 41-17,10.3.4)

$2(1-s/d) = 0.75$

V_f ((11-3)-(11.4), ACI 440) = 0.00

From (11-11), ACI 440: $V_s + V_f \leq 255092.67$

End Of Calculation of Shear Capacity for element: beam B1 of floor 1

At local axis: 2

Integration Section: (b)

Calculation No. 14

beam B1, Floor 1



Limit State: Life Safety (data interpolation between analysis steps 1 and 2)

Analysis: Uniform +X

Check: Chord rotation capacity (θ_u)

Edge: End

Local Axis: (2)



Start Of Calculation of Shear Capacity ratio for element: beam B1 of floor 1

At Shear local axis: 3

(Bending local axis: 2)

Section Type: rcars

Constant Properties

Knowledge Factor, $\gamma = 1.00$

Mean strength values are used for both shear and moment calculations.

Consequently:

Existing material of Primary Member: Concrete Strength, $f_c = f_{cm} = 24.00$

Existing material of Primary Member: Steel Strength, $f_s = f_{sm} = 525.00$

Concrete Elasticity, $E_c = 23025.204$

Steel Elasticity, $E_s = 200000.00$

#####

Note: Especially for the calculation of moment strengths,

the above steel re-bar strengths are multiplied by 1.25 according to R18.6.5, ACI 318-14

Existing material: Steel Strength, $f_s = 1.25 \cdot f_{sm} = 656.25$

#####

Section Height, $H = 400.00$

Section Width, $W = 300.00$

Cover Thickness, $c = 25.00$

Mean Confinement Factor overall section = 1.09003

Element Length, $L = 1850.00$

Primary Member

Smooth Bars

Ductile Steel

With Detailing for Earthquake Resistance (including stirrups closed at 135°)

Longitudinal Bars With Ends Lapped Starting at the End Sections

Adequate Lap Length ($l_o/l_{o,u,min} \geq 1$)

No FRP Wrapping

Stepwise Properties

At local axis: 3

EDGE -A-

Shear Force, $V_a = 2740.265$

EDGE -B-

Shear Force, $V_b = 2740.264$
BOTH EDGES
Axial Force, $F = -211.0849$
Longitudinal Reinforcement Area Distribution (in 2 divisions)
-Tension: $As_t = 603.1858$
-Compression: $As_c = 923.6282$
Longitudinal Reinforcement Area Distribution (in 3 divisions)
-Tension: $As_{t,ten} = 603.1858$
-Compression: $As_{c,com} = 615.7522$
-Middle: $As_{c,mid} = 307.8761$

Calculation of Shear Capacity ratio, $V_e/V_r = 0.78793176$
Member Controlled by Flexure ($V_e/V_r < 1$)
Calculation of Shear Demand from fig. R18.6.5, ACI 318-14 $V_e = (M_{pr1} + M_{pr2})/l_n \pm w_u \cdot l_n/2 = 205990.317$
with
 $M_{pr1} = \text{Max}(Mu_{1+}, Mu_{1-}) = 1.8802E+008$
 $Mu_{1+} = 1.8495E+008$, is the ultimate moment strength at the edge 1 of the member in the actual moment direction
which is defined for the static loading combination
 $Mu_{1-} = 1.8802E+008$, is the ultimate moment strength at the edge 1 of the member in the opposite moment
direction which is defined for the static loading combination
 $M_{pr2} = \text{Max}(Mu_{2+}, Mu_{2-}) = 1.8800E+008$
 $Mu_{2+} = 1.8498E+008$, is the ultimate moment strength at the edge 2 of the member in the actual moment direction
which is defined for the the static loading combination
 $Mu_{2-} = 1.8800E+008$, is the ultimate moment strength at the edge 2 of the member in the opposite moment
direction which is defined for the the static loading combination
and
 $\pm w_u \cdot l_n = (|V_1| + |V_2|)/2$
with
 $V_1 = 2740.265$, is the shear force acting at edge 1 for the the static loading combination
 $V_2 = 2740.264$, is the shear force acting at edge 2 for the the static loading combination

Calculation of Mu_{1+}

Calculation of ultimate curvature ϕ_u according to 4.1, Biskinis/Fardis 2013:
 $\phi_u = 0.0001071$
 $Mu = 1.8495E+008$

with full section properties:

$b = 300.00$
 $d = 357.00$
 $d' = 42.00$
 $v = 8.2121432E-005$
 $N = 211.0849$
 $f_c = 24.00$

ϕ_c (5A.5, TBDY) = 0.002

Final value of ϕ_u : $\phi_u^* = \text{shear_factor} \cdot \text{Max}(\phi_c, \phi_c) = 0.00773686$

The Shear_factor is considered equal to 1 (pure moment strength)

From (5.4b), TBDY: $\phi_u = 0.00773686$

w_e (5.4c) = 0.01121936

a_{se} ((5.4d), TBDY) = 0.15672608

$b_o = 240.00$

$h_o = 340.00$

$bi_2 = 346400.00$

$p_{sh,min} = \text{Min}(p_{sh,x}, p_{sh,y}) = 0.00261799$

 $p_{sh,x}$ (5.4d) = 0.00349066

$A_{sh} = A_{stir} \cdot n_s = 78.53982$

No stirups, $n_s = 2.00$

$b_k = 300.00$

 $p_{sh,y}$ (5.4d) = 0.00261799

Ash = Astir*ns = 78.53982
No stirrups, ns = 2.00
bk = 400.00

s = 150.00
fywe = 656.25
fce = 24.00

From ((5.A.5), TBDY), TBDY: cc = 0.00290026
c = confinement factor = 1.09003

y1 = 0.0025
sh1 = 0.008
ft1 = 787.50
fy1 = 656.25
su1 = 0.032

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00

lo/lou,min = lb/lb,min = 1.00

su1 = 0.4*esu1_nominal ((5.5), TBDY) = 0.032

From table 5A.1, TBDY: esu1_nominal = 0.08,

For calculation of esu1_nominal and y1, sh1,ft1,fy1, it is considered
characteristic value fsy1 = fs1/1.2, from table 5.1, TBDY.

y1, sh1,ft1,fy1, are also multiplied by $\text{Min}(1, 1.25 \cdot (lb/ld)^{2/3})$, from 10.3.5, ASCE 41-17.

with fs1 = fs = 656.25

with Es1 = Es = 200000.00

y2 = 0.0025
sh2 = 0.008
ft2 = 787.50
fy2 = 656.25
su2 = 0.032

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00

lo/lou,min = lb/lb,min = 1.00

su2 = 0.4*esu2_nominal ((5.5), TBDY) = 0.032

From table 5A.1, TBDY: esu2_nominal = 0.08,

For calculation of esu2_nominal and y2, sh2,ft2,fy2, it is considered
characteristic value fsy2 = fs2/1.2, from table 5.1, TBDY.

y1, sh1,ft1,fy1, are also multiplied by $\text{Min}(1, 1.25 \cdot (lb/ld)^{2/3})$, from 10.3.5, ASCE 41-17.

with fs2 = fs = 656.25

with Es2 = Es = 200000.00

yv = 0.0025
shv = 0.008
ftv = 787.50
fyv = 656.25
suv = 0.032

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00

lo/lou,min = lb/lb,min = 1.00

suv = 0.4*esuv_nominal ((5.5), TBDY) = 0.032

From table 5A.1, TBDY: esuv_nominal = 0.08,

considering characteristic value fsyv = fsv/1.2, from table 5.1, TBDY
For calculation of esuv_nominal and yv, shv,ftv,fyv, it is considered

characteristic value fsyv = fsv/1.2, from table 5.1, TBDY.

y1, sh1,ft1,fy1, are also multiplied by $\text{Min}(1, 1.25 \cdot (lb/ld)^{2/3})$, from 10.3.5, ASCE 41-17.

with fsv = fs = 656.25

with Esv = Es = 200000.00

1 = Asl,ten/(b*d)*(fs1/fc) = 0.15399964

2 = Asl,com/(b*d)*(fs2/fc) = 0.15720797

v = Asl,mid/(b*d)*(fsv/fc) = 0.07860398

and confined core properties:

b = 240.00
d = 327.00
d' = 12.00

fcc (5A.2, TBDY) = 26.16063

cc (5A.5, TBDY) = 0.00290026

c = confinement factor = 1.09003

1 = $Asl,ten/(b*d)*(fs1/fc) = 0.21016006$

2 = $Asl,com/(b*d)*(fs2/fc) = 0.21453839$

v = $Asl,mid/(b*d)*(fsv/fc) = 0.1072692$

Case/Assumption: Unconfined full section - Steel rupture

' satisfies Eq. (4.3)

v < vs,y2 - LHS eq.(4.5) is satisfied

su (4.9) = 0.1630814

Mu = MRc (4.14) = 1.8495E+008

u = su (4.1) = 0.0001071

Calculation of ratio lb/l_d

Adequate Lap Length: lb/l_d >= 1

Calculation of Mu1-

Calculation of ultimate curvature u according to 4.1, Biskinis/Fardis 2013:

u = 0.00010722

Mu = 1.8802E+008

with full section properties:

b = 300.00

d = 358.00

d' = 43.00

v = 8.1892042E-005

N = 211.0849

fc = 24.00

co (5A.5, TBDY) = 0.002

Final value of cu: cu* = shear_factor * Max(cu, cc) = 0.00773686

The Shear_factor is considered equal to 1 (pure moment strength)

From (5.4b), TBDY: cu = 0.00773686

we (5.4c) = 0.01121936

ase ((5.4d), TBDY) = 0.15672608

bo = 240.00

ho = 340.00

bi2 = 346400.00

psh,min = Min(psh,x , psh,y) = 0.00261799

psh,x (5.4d) = 0.00349066

Ash = Astir*ns = 78.53982

No stirups, ns = 2.00

bk = 300.00

psh,y (5.4d) = 0.00261799

Ash = Astir*ns = 78.53982

No stirups, ns = 2.00

bk = 400.00

s = 150.00

fywe = 656.25

fce = 24.00

From ((5.A5), TBDY), TBDY: cc = 0.00290026

c = confinement factor = 1.09003

y1 = 0.0025

sh1 = 0.008

ft1 = 787.50

fy1 = 656.25

su1 = 0.032

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor

and also multiplied by the shear_factor according to 15.7.1.4, with

Shear_factor = 1.00

lo/lou,min = lb/d = 1.00

su1 = 0.4*esu1_nominal ((5.5), TBDY) = 0.032

From table 5A.1, TBDY: esu1_nominal = 0.08,

For calculation of esu1_nominal and y1, sh1,ft1,fy1, it is considered characteristic value fsy1 = fs1/1.2, from table 5.1, TBDY.

y1, sh1,ft1,fy1, are also multiplied by Min(1,1.25*(lb/d)^2/3), from 10.3.5, ASCE 41-17.

with fs1 = fs = 656.25

with Es1 = Es = 200000.00

y2 = 0.0025

sh2 = 0.008

ft2 = 787.50

fy2 = 656.25

su2 = 0.032

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor

and also multiplied by the shear_factor according to 15.7.1.4, with

Shear_factor = 1.00

lo/lou,min = lb/lb,min = 1.00

su2 = 0.4*esu2_nominal ((5.5), TBDY) = 0.032

From table 5A.1, TBDY: esu2_nominal = 0.08,

For calculation of esu2_nominal and y2, sh2,ft2,fy2, it is considered characteristic value fsy2 = fs2/1.2, from table 5.1, TBDY.

y1, sh1,ft1,fy1, are also multiplied by Min(1,1.25*(lb/d)^2/3), from 10.3.5, ASCE 41-17.

with fs2 = fs = 656.25

with Es2 = Es = 200000.00

yv = 0.0025

shv = 0.008

ftv = 787.50

fyv = 656.25

suv = 0.032

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor

and also multiplied by the shear_factor according to 15.7.1.4, with

Shear_factor = 1.00

lo/lou,min = lb/d = 1.00

suv = 0.4*esuv_nominal ((5.5), TBDY) = 0.032

From table 5A.1, TBDY: esuv_nominal = 0.08,

considering characteristic value fsyv = fsv/1.2, from table 5.1, TBDY

For calculation of esuv_nominal and yv, shv,ftv,fyv, it is considered characteristic value fsyv = fsv/1.2, from table 5.1, TBDY.

y1, sh1,ft1,fy1, are also multiplied by Min(1,1.25*(lb/d)^2/3), from 10.3.5, ASCE 41-17.

with fsv = fs = 656.25

with Esv = Es = 200000.00

1 = Asl,ten/(b*d)*(fs1/fc) = 0.15676884

2 = Asl,com/(b*d)*(fs2/fc) = 0.15356947

v = Asl,mid/(b*d)*(fsv/fc) = 0.07838442

and confined core properties:

b = 240.00

d = 328.00

d' = 13.00

fcc (5A.2, TBDY) = 26.16063

cc (5A.5, TBDY) = 0.00290026

c = confinement factor = 1.09003

1 = Asl,ten/(b*d)*(fs1/fc) = 0.21388431

2 = Asl,com/(b*d)*(fs2/fc) = 0.20951933

v = Asl,mid/(b*d)*(fsv/fc) = 0.10694216

Case/Assumption: Unconfined full section - Steel rupture

' satisfies Eq. (4.3)

--->

v < vs,y2 - LHS eq.(4.5) is satisfied

--->

su (4.9) = 0.16631328

Mu = MRc (4.14) = 1.8802E+008

u = su (4.1) = 0.00010722

Calculation of ratio lb/d

Adequate Lap Length: $l_b/d \geq 1$

Calculation of μ_{2+}

Calculation of ultimate curvature μ according to 4.1, Biskinis/Fardis 2013:

$$u = 0.00010701$$

$$\mu = 1.8498E+008$$

with full section properties:

$$b = 300.00$$

$$d = 358.00$$

$$d' = 43.00$$

$$v = 8.1892042E-005$$

$$N = 211.0849$$

$$f_c = 24.00$$

$$c_o \text{ (5A.5, TBDY)} = 0.002$$

$$\text{Final value of } c_u: c_u^* = \text{shear_factor} * \text{Max}(c_u, c_c) = 0.00773686$$

The Shear_factor is considered equal to 1 (pure moment strength)

$$\text{From (5.4b), TBDY: } c_u = 0.00773686$$

$$w_e \text{ (5.4c)} = 0.01121936$$

$$a_{se} \text{ ((5.4d), TBDY)} = 0.15672608$$

$$b_o = 240.00$$

$$h_o = 340.00$$

$$b_{i2} = 346400.00$$

$$p_{sh,min} = \text{Min}(p_{sh,x}, p_{sh,y}) = 0.00261799$$

$$p_{sh,x} \text{ (5.4d)} = 0.00349066$$

$$A_{sh} = A_{stir} * n_s = 78.53982$$

$$\text{No stirups, } n_s = 2.00$$

$$b_k = 300.00$$

$$p_{sh,y} \text{ (5.4d)} = 0.00261799$$

$$A_{sh} = A_{stir} * n_s = 78.53982$$

$$\text{No stirups, } n_s = 2.00$$

$$b_k = 400.00$$

$$s = 150.00$$

$$f_{ywe} = 656.25$$

$$f_{ce} = 24.00$$

$$\text{From ((5.A5), TBDY), TBDY: } c_c = 0.00290026$$

$$c = \text{confinement factor} = 1.09003$$

$$y_1 = 0.0025$$

$$sh_1 = 0.008$$

$$ft_1 = 787.50$$

$$fy_1 = 656.25$$

$$su_1 = 0.032$$

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor and also multiplied by the shear_factor according to 15.7.1.4, with Shear_factor = 1.00

$$l_o/l_{ou,min} = l_b/d = 1.00$$

$$su_1 = 0.4 * esu_{1,nominal} \text{ ((5.5), TBDY)} = 0.032$$

$$\text{From table 5A.1, TBDY: } esu_{1,nominal} = 0.08,$$

For calculation of $esu_{1,nominal}$ and y_1, sh_1, ft_1, fy_1 , it is considered characteristic value $fsy_1 = fs_1/1.2$, from table 5.1, TBDY.

$$y_1, sh_1, ft_1, fy_1, \text{ are also multiplied by } \text{Min}(1, 1.25 * (l_b/d)^{2/3}), \text{ from 10.3.5, ASCE 41-17.}$$

$$\text{with } fs_1 = fs = 656.25$$

$$\text{with } Es_1 = Es = 200000.00$$

$$y_2 = 0.0025$$

$$sh_2 = 0.008$$

$$ft_2 = 787.50$$

$$fy_2 = 656.25$$

$$su_2 = 0.032$$

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00

lo/lou,min = lb/lb,min = 1.00

su2 = 0.4*esu2_nominal ((5.5), TBDY) = 0.032

From table 5A.1, TBDY: esu2_nominal = 0.08,

For calculation of esu2_nominal and y2, sh2,ft2,fy2, it is considered
characteristic value fsy2 = fs2/1.2, from table 5.1, TBDY.

y1, sh1,ft1,fy1, are also multiplied by $\text{Min}(1, 1.25 \cdot (lb/ld)^{2/3})$, from 10.3.5, ASCE 41-17.

with fs2 = fs = 656.25

with Es2 = Es = 200000.00

yv = 0.0025

shv = 0.008

ftv = 787.50

fyv = 656.25

suv = 0.032

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00

lo/lou,min = lb/ld = 1.00

suv = 0.4*esuv_nominal ((5.5), TBDY) = 0.032

From table 5A.1, TBDY: esuv_nominal = 0.08,

considering characteristic value fsyv = fsv/1.2, from table 5.1, TBDY

For calculation of esuv_nominal and yv, shv,ftv,fyv, it is considered
characteristic value fsyv = fsv/1.2, from table 5.1, TBDY.

y1, sh1,ft1,fy1, are also multiplied by $\text{Min}(1, 1.25 \cdot (lb/ld)^{2/3})$, from 10.3.5, ASCE 41-17.

with fsv = fs = 656.25

with Esv = Es = 200000.00

1 = Asl,ten/(b*d)*(fs1/fc) = 0.15356947

2 = Asl,com/(b*d)*(fs2/fc) = 0.15676884

v = Asl,mid/(b*d)*(fsv/fc) = 0.07838442

and confined core properties:

b = 240.00

d = 328.00

d' = 13.00

fcc (5A.2, TBDY) = 26.16063

cc (5A.5, TBDY) = 0.00290026

c = confinement factor = 1.09003

1 = Asl,ten/(b*d)*(fs1/fc) = 0.20951933

2 = Asl,com/(b*d)*(fs2/fc) = 0.21388431

v = Asl,mid/(b*d)*(fsv/fc) = 0.10694216

Case/Assumption: Unconfined full section - Steel rupture

' satisfies Eq. (4.3)

--->

v < vs,y2 - LHS eq.(4.5) is satisfied

--->

su (4.9) = 0.16466458

Mu = MRc (4.14) = 1.8498E+008

u = su (4.1) = 0.00010701

Calculation of ratio lb/ld

Adequate Lap Length: lb/ld >= 1

Calculation of Mu2-

Calculation of ultimate curvature u according to 4.1, Biskinis/Fardis 2013:

u = 0.00010732

Mu = 1.8800E+008

with full section properties:

b = 300.00

d = 357.00
d' = 42.00
v = 8.2121432E-005
N = 211.0849
fc = 24.00
co (5A.5, TBDY) = 0.002
Final value of cu: $cu^* = \text{shear_factor} * \text{Max}(cu, cc) = 0.00773686$
The Shear_factor is considered equal to 1 (pure moment strength)
From (5.4b), TBDY: $cu = 0.00773686$
we (5.4c) = 0.01121936
ase ((5.4d), TBDY) = 0.15672608
bo = 240.00
ho = 340.00
bi2 = 346400.00
psh,min = $\text{Min}(psh,x, psh,y) = 0.00261799$

psh,x (5.4d) = 0.00349066
Ash = $\text{Astir} * ns = 78.53982$
No stirups, ns = 2.00
bk = 300.00

psh,y (5.4d) = 0.00261799
Ash = $\text{Astir} * ns = 78.53982$
No stirups, ns = 2.00
bk = 400.00

s = 150.00
fywe = 656.25
fce = 24.00
From ((5.A.5), TBDY), TBDY: $cc = 0.00290026$
c = confinement factor = 1.09003

y1 = 0.0025
sh1 = 0.008
ft1 = 787.50
fy1 = 656.25
su1 = 0.032

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00

lo/lou,min = $lb/ld = 1.00$

su1 = $0.4 * \text{esu1_nominal} ((5.5), \text{TBDY}) = 0.032$

From table 5A.1, TBDY: $\text{esu1_nominal} = 0.08$,

For calculation of esu1_nominal and $y1, sh1, ft1, fy1$, it is considered
characteristic value $\text{fsy1} = \text{fs1}/1.2$, from table 5.1, TBDY.

$y1, sh1, ft1, fy1$, are also multiplied by $\text{Min}(1, 1.25 * (lb/ld)^{2/3})$, from 10.3.5, ASCE 41-17.

with $\text{fs1} = \text{fs} = 656.25$

with $\text{Es1} = \text{Es} = 200000.00$

y2 = 0.0025
sh2 = 0.008
ft2 = 787.50
fy2 = 656.25
su2 = 0.032

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00

lo/lou,min = $lb/lb, \text{min} = 1.00$

su2 = $0.4 * \text{esu2_nominal} ((5.5), \text{TBDY}) = 0.032$

From table 5A.1, TBDY: $\text{esu2_nominal} = 0.08$,

For calculation of esu2_nominal and $y2, sh2, ft2, fy2$, it is considered
characteristic value $\text{fsy2} = \text{fs2}/1.2$, from table 5.1, TBDY.

$y1, sh1, ft1, fy1$, are also multiplied by $\text{Min}(1, 1.25 * (lb/ld)^{2/3})$, from 10.3.5, ASCE 41-17.

with $\text{fs2} = \text{fs} = 656.25$

with $\text{Es2} = \text{Es} = 200000.00$

yv = 0.0025
shv = 0.008
ftv = 787.50
fyv = 656.25

suv = 0.032

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00

lo/lou,min = lb/d = 1.00

suv = 0.4*esuv_nominal ((5.5), TBDY) = 0.032

From table 5A.1, TBDY: esuv_nominal = 0.08,

considering characteristic value fsyv = fsv/1.2, from table 5.1, TBDY

For calculation of esuv_nominal and yv, shv,ftv,fyv, it is considered
characteristic value fsyv = fsv/1.2, from table 5.1, TBDY.

y1, sh1,ft1,fy1, are also multiplied by $\text{Min}(1, 1.25 \cdot (lb/d)^{2/3})$, from 10.3.5, ASCE 41-17.

with fsv = fs = 656.25

with Esv = Es = 200000.00

1 = Asl,ten/(b*d)*(fs1/fc) = 0.15720797

2 = Asl,com/(b*d)*(fs2/fc) = 0.15399964

v = Asl,mid/(b*d)*(fsv/fc) = 0.07860398

and confined core properties:

b = 240.00

d = 327.00

d' = 12.00

fcc (5A.2, TBDY) = 26.16063

cc (5A.5, TBDY) = 0.00290026

c = confinement factor = 1.09003

1 = Asl,ten/(b*d)*(fs1/fc) = 0.21453839

2 = Asl,com/(b*d)*(fs2/fc) = 0.21016006

v = Asl,mid/(b*d)*(fsv/fc) = 0.1072692

Case/Assumption: Unconfined full section - Steel rupture

' satisfies Eq. (4.3)

v < vs,y2 - LHS eq.(4.5) is satisfied

su (4.9) = 0.16474284

Mu = MRc (4.14) = 1.8800E+008

u = su (4.1) = 0.00010732

Calculation of ratio lb/d

Adequate Lap Length: lb/d >= 1

Calculation of Shear Strength Vr = Min(Vr1,Vr2) = 261431.672

Calculation of Shear Strength at edge 1, Vr1 = 261431.672

Vr1 = Vn ((22.5.1.1), ACI 318-14)

NOTE: In expression (22.5.1.1) 'Vw' is replaced by 'Vw+ f*Vf'
where Vf is the contribution of FRPs (11.3), ACI 440).

From Table (22.5.5.1), ACI 318-14: Vc = 85502.483

= 1 (normal-weight concrete)

fc' = 24.00, but $fc^{0.5} \leq 8.3$ MPa (22.5.3.1, ACI 318-14)

pw = As/(bw*d) = 0.00628319

As (tension reinf.) = 603.1858

bw = 300.00

d = 320.00

Vu*d/Mu < 1 = 1.00

Mu = 30114.962

Vu = 2740.265

From (11.5.4.8), ACI 318-14: Vs = 175929.189

Av = 157079.633

fy = 525.00

s = 150.00

Vs has been multiplied by 1 (s < d/2, according to ASCE 41-17,10.3.4)

Vf ((11-3)-(11.4), ACI 440) = 0.00

From (11-11), ACI 440: $V_s + V_f \leq 312423.44$

Calculation of Shear Strength at edge 2, $V_{r2} = 261431.672$
 $V_{r2} = V_n$ ((22.5.1.1), ACI 318-14)

NOTE: In expression (22.5.1.1) 'Vw' is replaced by 'Vw + f*Vf'
where Vf is the contribution of FRPs (11.3), ACI 440).

From Table (22.5.5.1), ACI 318-14: $V_c = 85502.483$
= 1 (normal-weight concrete)
 $f_c' = 24.00$, but $f_c'^{0.5} \leq 8.3$ MPa (22.5.3.1, ACI 318-14)
 $\rho_w = A_s / (b_w * d) = 0.00628319$
 A_s (tension reinf.) = 603.1858
 $b_w = 300.00$
 $d = 320.00$
 $V_u * d / M_u < 1 = 1.00$
 $M_u = 30115.665$
 $V_u = 2740.264$

From (11.5.4.8), ACI 318-14: $V_s = 175929.189$
 $A_v = 157079.633$
 $f_y = 525.00$
 $s = 150.00$

V_s has been multiplied by 1 ($s < d/2$, according to ASCE 41-17,10.3.4)
 V_f ((11-3)-(11.4), ACI 440) = 0.00
From (11-11), ACI 440: $V_s + V_f \leq 312423.44$

End Of Calculation of Shear Capacity ratio for element: beam B1 of floor 1
At local axis: 3

Start Of Calculation of Shear Capacity ratio for element: beam B1 of floor 1
At Shear local axis: 2
(Bending local axis: 3)
Section Type: rcars

Constant Properties

Knowledge Factor, $\phi = 1.00$
Mean strength values are used for both shear and moment calculations.
Consequently:
Existing material of Primary Member: Concrete Strength, $f_c = f_{cm} = 24.00$
Existing material of Primary Member: Steel Strength, $f_s = f_{sm} = 525.00$
Concrete Elasticity, $E_c = 23025.204$
Steel Elasticity, $E_s = 200000.00$

Note: Especially for the calculation of moment strengths,
the above steel re-bar strengths are multiplied by 1.25 according to R18.6.5, ACI 318-14
Existing material: Steel Strength, $f_s = 1.25 * f_{sm} = 656.25$

Section Height, $H = 400.00$
Section Width, $W = 300.00$
Cover Thickness, $c = 25.00$
Mean Confinement Factor overall section = 1.09003
Element Length, $L = 1850.00$
Primary Member
Smooth Bars
Ductile Steel
With Detailing for Earthquake Resistance (including stirrups closed at 135°)
Longitudinal Bars With Ends Lapped Starting at the End Sections
Adequate Lap Length ($l_o / l_{ou, min} > 1$)
No FRP Wrapping

Stepwise Properties

At local axis: 2

EDGE -A-

Shear Force, $V_a = -3.6870970E-015$

EDGE -B-

Shear Force, $V_b = 3.6870970E-015$

BOTH EDGES

Axial Force, $F = -211.0849$

Longitudinal Reinforcement Area Distribution (in 2 divisions)

-Tension: $A_{sl,t} = 603.1858$

-Compression: $A_{sl,c} = 923.6282$

Longitudinal Reinforcement Area Distribution (in 3 divisions)

-Tension: $A_{sl,ten} = 508.938$

-Compression: $A_{sl,com} = 508.938$

-Middle: $A_{sl,mid} = 508.938$

Calculation of Shear Capacity ratio , $V_e/V_r = 0.79211753$

Member Controlled by Flexure ($V_e/V_r < 1$)

Calculation of Shear Demand from fig. R18.6.5, ACI 318-14 $V_e = (M_{pr1} + M_{pr2})/l_n \pm w_u \cdot l_n/2 = 137993.601$

with

$M_{pr1} = \text{Max}(M_{u1+}, M_{u1-}) = 1.2764E+008$

$M_{u1+} = 1.2764E+008$, is the ultimate moment strength at the edge 1 of the member in the actual moment direction which is defined for the static loading combination

$M_{u1-} = 1.2764E+008$, is the ultimate moment strength at the edge 1 of the member in the opposite moment direction which is defined for the static loading combination

$M_{pr2} = \text{Max}(M_{u2+}, M_{u2-}) = 1.2764E+008$

$M_{u2+} = 1.2764E+008$, is the ultimate moment strength at the edge 2 of the member in the actual moment direction which is defined for the the static loading combination

$M_{u2-} = 1.2764E+008$, is the ultimate moment strength at the edge 2 of the member in the opposite moment direction which is defined for the the static loading combination

and

$\pm w_u \cdot l_n = (|V_1| + |V_2|)/2$

with

$V_1 = -3.6870970E-015$, is the shear force acting at edge 1 for the the static loading combination

$V_2 = 3.6870970E-015$, is the shear force acting at edge 2 for the the static loading combination

Calculation of M_{u1+}

Calculation of ultimate curvature ϕ_u according to 4.1, Biskinis/Fardis 2013:

$\phi_u = 0.00015613$

$M_u = 1.2764E+008$

with full section properties:

$b = 400.00$

$d = 258.00$

$d' = 42.00$

$v = 8.5224858E-005$

$N = 211.0849$

$f_c = 24.00$

$\phi_{co} (5A.5, TBDY) = 0.002$

Final value of ϕ_{cu} : $\phi_{cu}^* = \text{shear_factor} \cdot \text{Max}(\phi_{cu}, \phi_{cc}) = 0.00773686$

The Shear_factor is considered equal to 1 (pure moment strength)

From (5.4b), TBDY: $\phi_{cu} = 0.00773686$

$w_e (5.4c) = 0.01121936$

$a_{se} ((5.4d), TBDY) = 0.15672608$

$b_o = 240.00$

$h_o = 340.00$

$b_{i2} = 346400.00$

$\phi_{sh,min} = \text{Min}(\phi_{sh,x}, \phi_{sh,y}) = 0.00261799$

$\phi_{sh,x} (5.4d) = 0.00349066$

$A_{sh} = A_{stir} \cdot n_s = 78.53982$

No stirrups, ns = 2.00
bk = 300.00

psh,y (5.4d) = 0.00261799
Ash = Astir*ns = 78.53982
No stirrups, ns = 2.00
bk = 400.00

s = 150.00
fywe = 656.25
fce = 24.00

From ((5.A5), TBDY), TBDY: cc = 0.00290026
c = confinement factor = 1.09003

y1 = 0.0025
sh1 = 0.008
ft1 = 787.50
fy1 = 656.25
su1 = 0.032

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00

lo/lou,min = lb/d = 1.00

su1 = 0.4*esu1_nominal ((5.5), TBDY) = 0.032

From table 5A.1, TBDY: esu1_nominal = 0.08,

For calculation of esu1_nominal and y1, sh1,ft1,fy1, it is considered
characteristic value fsy1 = fs1/1.2, from table 5.1, TBDY.

y1, sh1,ft1,fy1, are also multiplied by $\text{Min}(1, 1.25 \cdot (lb/d)^{2/3})$, from 10.3.5, ASCE 41-17.

with fs1 = fs = 656.25

with Es1 = Es = 200000.00

y2 = 0.0025
sh2 = 0.008
ft2 = 787.50
fy2 = 656.25
su2 = 0.032

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00

lo/lou,min = lb/lb,min = 1.00

su2 = 0.4*esu2_nominal ((5.5), TBDY) = 0.032

From table 5A.1, TBDY: esu2_nominal = 0.08,

For calculation of esu2_nominal and y2, sh2,ft2,fy2, it is considered
characteristic value fsy2 = fs2/1.2, from table 5.1, TBDY.

y1, sh1,ft1,fy1, are also multiplied by $\text{Min}(1, 1.25 \cdot (lb/d)^{2/3})$, from 10.3.5, ASCE 41-17.

with fs2 = fs = 656.25

with Es2 = Es = 200000.00

yv = 0.0025
shv = 0.008
ftv = 787.50
fyv = 656.25
suv = 0.032

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00

lo/lou,min = lb/d = 1.00

suv = 0.4*esuv_nominal ((5.5), TBDY) = 0.032

From table 5A.1, TBDY: esuv_nominal = 0.08,

considering characteristic value fsyv = fsv/1.2, from table 5.1, TBDY

For calculation of esuv_nominal and yv, shv,ftv,fyv, it is considered
characteristic value fsyv = fsv/1.2, from table 5.1, TBDY.

y1, sh1,ft1,fy1, are also multiplied by $\text{Min}(1, 1.25 \cdot (lb/d)^{2/3})$, from 10.3.5, ASCE 41-17.

with fsv = fs = 656.25

with Esv = Es = 200000.00

1 = Asl,ten/(b*d)*(fs1/fc) = 0.13484761

2 = Asl,com/(b*d)*(fs2/fc) = 0.13484761

v = Asl,mid/(b*d)*(fsv/fc) = 0.13484761

and confined core properties:

b = 340.00

$d = 228.00$
 $d' = 12.00$
 $f_{cc} (5A.2, TBDY) = 26.16063$
 $cc (5A.5, TBDY) = 0.00290026$
 $c = \text{confinement factor} = 1.09003$
 $1 = A_{sl,ten}/(b*d)*(f_{s1}/f_c) = 0.17951849$
 $2 = A_{sl,com}/(b*d)*(f_{s2}/f_c) = 0.17951849$
 $v = A_{sl,mid}/(b*d)*(f_{sv}/f_c) = 0.17951849$
 Case/Assumption: Unconfined full section - Steel rupture
 ' does not satisfy Eq. (4.3)

--->
 $v < v_{s,c}$ - RHS eq.(4.5) is satisfied
 --->
 $su (4.9) = 0.20560388$
 $Mu = MR_c (4.14) = 1.2764E+008$
 $u = su (4.1) = 0.00015613$

 Calculation of ratio l_b/d

 Adequate Lap Length: $l_b/d \geq 1$

 Calculation of Mu_1 -

 Calculation of ultimate curvature u according to 4.1, Biskinis/Fardis 2013:
 $u = 0.00015613$
 $Mu = 1.2764E+008$

 with full section properties:

$b = 400.00$
 $d = 258.00$
 $d' = 42.00$
 $v = 8.5224858E-005$
 $N = 211.0849$
 $f_c = 24.00$
 $co (5A.5, TBDY) = 0.002$
 Final value of cu : $cu^* = \text{shear_factor} * \text{Max}(cu, cc) = 0.00773686$
 The Shear_factor is considered equal to 1 (pure moment strength)
 From (5.4b), TBDY: $cu = 0.00773686$
 $w_e (5.4c) = 0.01121936$
 $ase ((5.4d), TBDY) = 0.15672608$
 $bo = 240.00$
 $ho = 340.00$
 $bi_2 = 346400.00$
 $psh,min = \text{Min}(psh,x, psh,y) = 0.00261799$

 $psh,x (5.4d) = 0.00349066$
 $A_{sh} = A_{stir}*n_s = 78.53982$
 No stirups, $n_s = 2.00$
 $bk = 300.00$

 $psh,y (5.4d) = 0.00261799$
 $A_{sh} = A_{stir}*n_s = 78.53982$
 No stirups, $n_s = 2.00$
 $bk = 400.00$

 $s = 150.00$
 $f_{ywe} = 656.25$
 $f_{ce} = 24.00$
 From ((5.A5), TBDY), TBDY: $cc = 0.00290026$
 $c = \text{confinement factor} = 1.09003$
 $y_1 = 0.0025$
 $sh_1 = 0.008$

$$ft1 = 787.50$$

$$fy1 = 656.25$$

$$su1 = 0.032$$

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00

$$lo/lou,min = lb/l_d = 1.00$$

$$su1 = 0.4 * esu1_nominal ((5.5), TBDY) = 0.032$$

From table 5A.1, TBDY: esu1_nominal = 0.08,

For calculation of esu1_nominal and y1, sh1,ft1,fy1, it is considered
characteristic value fsy1 = fs1/1.2, from table 5.1, TBDY.

y1, sh1,ft1,fy1, are also multiplied by $\text{Min}(1, 1.25 * (lb/l_d)^{2/3})$, from 10.3.5, ASCE 41-17.

$$\text{with } fs1 = fs = 656.25$$

$$\text{with } Es1 = Es = 200000.00$$

$$y2 = 0.0025$$

$$sh2 = 0.008$$

$$ft2 = 787.50$$

$$fy2 = 656.25$$

$$su2 = 0.032$$

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00

$$lo/lou,min = lb/l_b,min = 1.00$$

$$su2 = 0.4 * esu2_nominal ((5.5), TBDY) = 0.032$$

From table 5A.1, TBDY: esu2_nominal = 0.08,

For calculation of esu2_nominal and y2, sh2,ft2,fy2, it is considered
characteristic value fsy2 = fs2/1.2, from table 5.1, TBDY.

y1, sh1,ft1,fy1, are also multiplied by $\text{Min}(1, 1.25 * (lb/l_d)^{2/3})$, from 10.3.5, ASCE 41-17.

$$\text{with } fs2 = fs = 656.25$$

$$\text{with } Es2 = Es = 200000.00$$

$$yv = 0.0025$$

$$shv = 0.008$$

$$ftv = 787.50$$

$$fyv = 656.25$$

$$suv = 0.032$$

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00

$$lo/lou,min = lb/l_d = 1.00$$

$$suv = 0.4 * esuv_nominal ((5.5), TBDY) = 0.032$$

From table 5A.1, TBDY: esuv_nominal = 0.08,

considering characteristic value fsyv = fsv/1.2, from table 5.1, TBDY

For calculation of esuv_nominal and yv, shv,ftv,fyv, it is considered
characteristic value fsyv = fsv/1.2, from table 5.1, TBDY.

y1, sh1,ft1,fy1, are also multiplied by $\text{Min}(1, 1.25 * (lb/l_d)^{2/3})$, from 10.3.5, ASCE 41-17.

$$\text{with } fsv = fs = 656.25$$

$$\text{with } Esv = Es = 200000.00$$

$$1 = Asl,ten / (b * d) * (fs1 / fc) = 0.13484761$$

$$2 = Asl,com / (b * d) * (fs2 / fc) = 0.13484761$$

$$v = Asl,mid / (b * d) * (fsv / fc) = 0.13484761$$

and confined core properties:

$$b = 340.00$$

$$d = 228.00$$

$$d' = 12.00$$

$$fcc (5A.2, TBDY) = 26.16063$$

$$cc (5A.5, TBDY) = 0.00290026$$

$$c = \text{confinement factor} = 1.09003$$

$$1 = Asl,ten / (b * d) * (fs1 / fc) = 0.17951849$$

$$2 = Asl,com / (b * d) * (fs2 / fc) = 0.17951849$$

$$v = Asl,mid / (b * d) * (fsv / fc) = 0.17951849$$

Case/Assumption: Unconfined full section - Steel rupture

' does not satisfy Eq. (4.3)

--->

v < vs,c - RHS eq.(4.5) is satisfied

--->

$$su (4.9) = 0.20560388$$

$$Mu = MRc (4.14) = 1.2764E+008$$

$$u = s_u(4.1) = 0.00015613$$

Calculation of ratio l_b/d

Adequate Lap Length: $l_b/d \geq 1$

Calculation of μ_{2+}

Calculation of ultimate curvature μ according to 4.1, Biskinis/Fardis 2013:

$$u = 0.00015613$$

$$\mu = 1.2764E+008$$

with full section properties:

$$b = 400.00$$

$$d = 258.00$$

$$d' = 42.00$$

$$v = 8.5224858E-005$$

$$N = 211.0849$$

$$f_c = 24.00$$

$$c_o(5A.5, \text{TBDY}) = 0.002$$

$$\text{Final value of } \mu: \mu^* = \text{shear_factor} * \text{Max}(\mu_c, \mu_{cc}) = 0.00773686$$

The Shear_factor is considered equal to 1 (pure moment strength)

$$\text{From (5.4b), TBDY: } \mu_c = 0.00773686$$

$$\mu_{cc} \text{ (5.4c)} = 0.01121936$$

$$a_{se} \text{ ((5.4d), TBDY)} = 0.15672608$$

$$b_o = 240.00$$

$$h_o = 340.00$$

$$b_i^2 = 346400.00$$

$$\mu_{sh,min} = \text{Min}(\mu_{sh,x}, \mu_{sh,y}) = 0.00261799$$

$$\mu_{sh,x} \text{ (5.4d)} = 0.00349066$$

$$A_{sh} = A_{stir} * n_s = 78.53982$$

$$\text{No stirrups, } n_s = 2.00$$

$$b_k = 300.00$$

$$\mu_{sh,y} \text{ (5.4d)} = 0.00261799$$

$$A_{sh} = A_{stir} * n_s = 78.53982$$

$$\text{No stirrups, } n_s = 2.00$$

$$b_k = 400.00$$

$$s = 150.00$$

$$f_{ywe} = 656.25$$

$$f_{ce} = 24.00$$

$$\text{From ((5.A5), TBDY), TBDY: } \mu_{cc} = 0.00290026$$

$$c = \text{confinement factor} = 1.09003$$

$$y_1 = 0.0025$$

$$sh_1 = 0.008$$

$$ft_1 = 787.50$$

$$fy_1 = 656.25$$

$$s_{u1} = 0.032$$

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor and also multiplied by the shear_factor according to 15.7.1.4, with Shear_factor = 1.00

$$l_o/l_{o,min} = l_b/d = 1.00$$

$$s_{u1} = 0.4 * s_{u1_nominal} \text{ ((5.5), TBDY)} = 0.032$$

$$\text{From table 5A.1, TBDY: } s_{u1_nominal} = 0.08,$$

For calculation of $s_{u1_nominal}$ and y_1, sh_1, ft_1, fy_1 , it is considered characteristic value $f_{sy1} = f_{s1}/1.2$, from table 5.1, TBDY.

y_1, sh_1, ft_1, fy_1 , are also multiplied by $\text{Min}(1, 1.25 * (l_b/d)^{2/3})$, from 10.3.5, ASCE 41-17.

$$\text{with } f_{s1} = f_s = 656.25$$

$$\text{with } E_{s1} = E_s = 200000.00$$

$$y_2 = 0.0025$$

$$sh_2 = 0.008$$

$$ft_2 = 787.50$$

$$fy_2 = 656.25$$

$$su_2 = 0.032$$

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00

$$lo/lo_{min} = lb/lb_{min} = 1.00$$

$$su_2 = 0.4 * esu_{2_nominal} ((5.5), TBDY) = 0.032$$

From table 5A.1, TBDY: $esu_{2_nominal} = 0.08$,

For calculation of $esu_{2_nominal}$ and y_2 , sh_2, ft_2, fy_2 , it is considered
characteristic value $fsy_2 = fs_2/1.2$, from table 5.1, TBDY.

y_1 , sh_1, ft_1, fy_1 , are also multiplied by $\text{Min}(1, 1.25 * (lb/ld)^{2/3})$, from 10.3.5, ASCE 41-17.

$$\text{with } fs_2 = fs = 656.25$$

$$\text{with } Es_2 = Es = 200000.00$$

$$yv = 0.0025$$

$$shv = 0.008$$

$$ftv = 787.50$$

$$fyv = 656.25$$

$$suv = 0.032$$

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00

$$lo/lo_{min} = lb/ld = 1.00$$

$$suv = 0.4 * esuv_{nominal} ((5.5), TBDY) = 0.032$$

From table 5A.1, TBDY: $esuv_{nominal} = 0.08$,

considering characteristic value $fsyv = fsv/1.2$, from table 5.1, TBDY

For calculation of $esuv_{nominal}$ and yv , shv, ftv, fyv , it is considered
characteristic value $fsyv = fsv/1.2$, from table 5.1, TBDY.

y_1 , sh_1, ft_1, fy_1 , are also multiplied by $\text{Min}(1, 1.25 * (lb/ld)^{2/3})$, from 10.3.5, ASCE 41-17.

$$\text{with } fsv = fs = 656.25$$

$$\text{with } Esv = Es = 200000.00$$

$$1 = Asl_{ten}/(b*d) * (fs_1/fc) = 0.13484761$$

$$2 = Asl_{com}/(b*d) * (fs_2/fc) = 0.13484761$$

$$v = Asl_{mid}/(b*d) * (fsv/fc) = 0.13484761$$

and confined core properties:

$$b = 340.00$$

$$d = 228.00$$

$$d' = 12.00$$

$$fcc (5A.2, TBDY) = 26.16063$$

$$cc (5A.5, TBDY) = 0.00290026$$

$$c = \text{confinement factor} = 1.09003$$

$$1 = Asl_{ten}/(b*d) * (fs_1/fc) = 0.17951849$$

$$2 = Asl_{com}/(b*d) * (fs_2/fc) = 0.17951849$$

$$v = Asl_{mid}/(b*d) * (fsv/fc) = 0.17951849$$

Case/Assumption: Unconfined full section - Steel rupture

' does not satisfy Eq. (4.3)

--->

$v < v_{s,c}$ - RHS eq.(4.5) is satisfied

--->

$$su (4.9) = 0.20560388$$

$$\mu_u = MRc (4.14) = 1.2764E+008$$

$$u = su (4.1) = 0.00015613$$

Calculation of ratio lb/ld

Adequate Lap Length: $lb/ld \geq 1$

Calculation of μ_{u2} -

Calculation of ultimate curvature u according to 4.1, Biskinis/Fardis 2013:

$$u = 0.00015613$$

Mu = 1.2764E+008

with full section properties:

b = 400.00

d = 258.00

d' = 42.00

v = 8.5224858E-005

N = 211.0849

fc = 24.00

co (5A.5, TBDY) = 0.002

Final value of cu: $cu^* = \text{shear_factor} * \text{Max}(cu, cc) = 0.00773686$

The Shear_factor is considered equal to 1 (pure moment strength)

From (5.4b), TBDY: $cu = 0.00773686$

we (5.4c) = 0.01121936

ase ((5.4d), TBDY) = 0.15672608

bo = 240.00

ho = 340.00

bi2 = 346400.00

psh,min = $\text{Min}(psh,x, psh,y) = 0.00261799$

psh,x (5.4d) = 0.00349066

Ash = $\text{Astir} * ns = 78.53982$

No stirups, ns = 2.00

bk = 300.00

psh,y (5.4d) = 0.00261799

Ash = $\text{Astir} * ns = 78.53982$

No stirups, ns = 2.00

bk = 400.00

s = 150.00

fywe = 656.25

fce = 24.00

From ((5.A5), TBDY), TBDY: $cc = 0.00290026$

c = confinement factor = 1.09003

y1 = 0.0025

sh1 = 0.008

ft1 = 787.50

fy1 = 656.25

su1 = 0.032

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00

lo/lou,min = lb/d = 1.00

su1 = $0.4 * \text{esu1_nominal} ((5.5), \text{TBDY}) = 0.032$

From table 5A.1, TBDY: $\text{esu1_nominal} = 0.08$,

For calculation of esu1_nominal and y1, sh1,ft1,fy1, it is considered
characteristic value $\text{fsy1} = \text{fs1}/1.2$, from table 5.1, TBDY.

y1, sh1,ft1,fy1, are also multiplied by $\text{Min}(1, 1.25 * (lb/d)^{2/3})$, from 10.3.5, ASCE 41-17.

with $\text{fs1} = \text{fs} = 656.25$

with $\text{Es1} = \text{Es} = 200000.00$

y2 = 0.0025

sh2 = 0.008

ft2 = 787.50

fy2 = 656.25

su2 = 0.032

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00

lo/lou,min = lb/lb,min = 1.00

su2 = $0.4 * \text{esu2_nominal} ((5.5), \text{TBDY}) = 0.032$

From table 5A.1, TBDY: $\text{esu2_nominal} = 0.08$,

For calculation of esu2_nominal and y2, sh2,ft2,fy2, it is considered
characteristic value $\text{fsy2} = \text{fs2}/1.2$, from table 5.1, TBDY.

y1, sh1,ft1,fy1, are also multiplied by $\text{Min}(1, 1.25 * (lb/d)^{2/3})$, from 10.3.5, ASCE 41-17.

with $\text{fs2} = \text{fs} = 656.25$

with $\text{Es2} = \text{Es} = 200000.00$

yv = 0.0025
shv = 0.008
ftv = 787.50
fyv = 656.25
suv = 0.032

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00

lo/lou,min = lb/d = 1.00

suv = 0.4*esuv_nominal ((5.5), TBDY) = 0.032

From table 5A.1, TBDY: esuv_nominal = 0.08,

considering characteristic value fsyv = fsv/1.2, from table 5.1, TBDY

For calculation of esuv_nominal and yv, shv,ftv,fyv, it is considered
characteristic value fsyv = fsv/1.2, from table 5.1, TBDY.

y1, sh1,ft1,fy1, are also multiplied by Min(1,1.25*(lb/d)^2/3), from 10.3.5, ASCE 41-17.

with fsv = fs = 656.25

with Esv = Es = 200000.00

1 = Asl,ten/(b*d)*(fs1/fc) = 0.13484761

2 = Asl,com/(b*d)*(fs2/fc) = 0.13484761

v = Asl,mid/(b*d)*(fsv/fc) = 0.13484761

and confined core properties:

b = 340.00

d = 228.00

d' = 12.00

fcc (5A.2, TBDY) = 26.16063

cc (5A.5, TBDY) = 0.00290026

c = confinement factor = 1.09003

1 = Asl,ten/(b*d)*(fs1/fc) = 0.17951849

2 = Asl,com/(b*d)*(fs2/fc) = 0.17951849

v = Asl,mid/(b*d)*(fsv/fc) = 0.17951849

Case/Assumption: Unconfined full section - Steel rupture

' does not satisfy Eq. (4.3)

v < vs,c - RHS eq.(4.5) is satisfied

su (4.9) = 0.20560388

Mu = MRc (4.14) = 1.2764E+008

u = su (4.1) = 0.00015613

Calculation of ratio lb/d

Adequate Lap Length: lb/d >= 1

Calculation of Shear Strength Vr = Min(Vr1,Vr2) = 174208.493

Calculation of Shear Strength at edge 1, Vr1 = 174208.493

Vr1 = Vn ((22.5.1.1), ACI 318-14)

NOTE: In expression (22.5.1.1) 'Vw' is replaced by 'Vw+ f*Vf'
where Vf is the contribution of FRPs (11.3), ACI 440).

From Table (22.5.5.1), ACI 318-14: Vc = 75248.325

= 1 (normal-weight concrete)

fc' = 24.00, but fc'^0.5 <= 8.3 MPa (22.5.3.1, ACI 318-14)

pw = As/(bw*d) = 0.00628319

As (tension reinf.) = 603.1858

bw = 400.00

d = 240.00

Vu*d/Mu < 1 = 0.00

Mu = 7.6252677E-012

Vu = 3.6870970E-015

From (11.5.4.8), ACI 318-14: Vs = 98960.169

Av = 157079.633

$f_y = 525.00$

$s = 150.00$

V_s has been multiplied by $2(1-s/d)$ ($s > d/2$, according to ASCE 41-17,10.3.4)

$2(1-s/d) = 0.75$

V_f ((11-3)-(11.4), ACI 440) = 0.00

From (11-11), ACI 440: $V_s + V_f \leq 312423.44$

Calculation of Shear Strength at edge 2, $V_{r2} = 174208.493$

$V_{r2} = V_n$ ((22.5.1.1), ACI 318-14)

NOTE: In expression (22.5.1.1) ' V_w ' is replaced by ' $V_w + f^*V_f$ '

where V_f is the contribution of FRPs (11.3), ACI 440).

From Table (22.5.5.1), ACI 318-14: $V_c = 75248.325$

= 1 (normal-weight concrete)

$f_c' = 24.00$, but $f_c'^{0.5} \leq 8.3$ MPa (22.5.3.1, ACI 318-14)

$p_w = A_s/(b_w*d) = 0.00628319$

A_s (tension reinf.) = 603.1858

$b_w = 400.00$

$d = 240.00$

$V_u*d/M_u < 1 = 0.00$

$M_u = 8.0393416E-013$

$V_u = 3.6870970E-015$

From (11.5.4.8), ACI 318-14: $V_s = 98960.169$

$A_v = 157079.633$

$f_y = 525.00$

$s = 150.00$

V_s has been multiplied by $2(1-s/d)$ ($s > d/2$, according to ASCE 41-17,10.3.4)

$2(1-s/d) = 0.75$

V_f ((11-3)-(11.4), ACI 440) = 0.00

From (11-11), ACI 440: $V_s + V_f \leq 312423.44$

End Of Calculation of Shear Capacity ratio for element: beam B1 of floor 1

At local axis: 2

Start Of Calculation of Chord Rotation Capacity for element: beam B1 of floor 1

At local axis: 2

Integration Section: (b)

Section Type: rcars

Constant Properties

Knowledge Factor, = 1.00

Chord Rotation is generally considered as Deformation-Controlled Action according to Table C7-1, ASCE 41-17.

Mean strengths are used for Deformation-Controlled Actions according to 7.5.1.3, ASCE 41-17

Consequently:

Existing material of Primary Member: Concrete Strength, $f_c = f_{cm} = 24.00$

Existing material of Primary Member: Steel Strength, $f_s = f_{sm} = 525.00$

Concrete Elasticity, $E_c = 23025.204$

Steel Elasticity, $E_s = 200000.00$

Section Height, $H = 400.00$

Section Width, $W = 300.00$

Cover Thickness, $c = 25.00$

Element Length, $L = 1850.00$

Primary Member

Smooth Bars

Ductile Steel

With Detailing for Earthquake Resistance (including stirrups closed at 135°)

Longitudinal Bars With Ends Lapped Starting at the End Sections

Adequate Lap Length ($l_b/l_d > 1$)

No FRP Wrapping

Stepwise Properties

Bending Moment, $M = 4.4551E+006$
Shear Force, $V2 = -2.3583230E-014$
Shear Force, $V3 = 7492.435$
Axial Force, $F = -490.6724$
Longitudinal Reinforcement Area Distribution (in 2 divisions)
-Tension: $As_t = 615.7522$
-Compression: $As_c = 911.0619$
Longitudinal Reinforcement Area Distribution (in 3 divisions)
-Tension: $As_{,ten} = 615.7522$
-Compression: $As_{,com} = 603.1858$
-Middle: $As_{,mid} = 307.8761$
Mean Diameter of Tension Reinforcement, $Db_L = 14.00$

Existing component: From table 7-7, ASCE 41_17: Final chord rotation Capacity $u_{,R} = \gamma + p = 0.02216348$

- Calculation of γ -

$\gamma = (M \cdot L_s / 3) / E_{eff} = 0.00216348$ ((4.29), Biskinis Phd)
 $M_y = 1.2064E+008$
 $L_s = M/V$ (with $L_s > 0.1 \cdot L$ and $L_s < 2 \cdot L$) = 594.6128
From table 10.5, ASCE 41_17: $E_{eff} = 0.3 \cdot E_c \cdot I_g = 1.1052E+013$

Calculation of Yielding Moment M_y

Calculation of γ and M_y according to Annex 7 -

$\gamma = \text{Min}(\gamma_{,ten}, \gamma_{,com})$
 $\gamma_{,ten} = 1.0039820E-005$
with $f_y = 525.00$
 $d = 358.00$
 $\gamma = 0.26966795$
 $A = 0.01422485$
 $B = 0.00802201$
with $p_t = 0.00573326$
 $p_c = 0.00561626$
 $p_v = 0.00286663$
 $N = 490.6724$
 $b = 300.00$
 $\gamma = 0.12011173$
 $\gamma_{,comp} = 1.9439150E-005$
with $f_c = 24.00$
 $E_c = 23025.204$
 $\gamma = 0.26960005$
 $A = 0.01420397$
 $B = 0.00801331$
with $E_s = 200000.00$

Calculation of ratio l_b/d

Adequate Lap Length: $l_b/d \geq 1$

- Calculation of p -

From table 10-7: $p = 0.02$

with:

- Condition i occurred

Beam controlled by flexure: $V_p/V_o \leq 1$

shear control ratio $V_p/V_o = 0.78793176$

- Transverse Reinforcement: NC
- Stirrup Spacing $> d/3$
- Low ductility demand, $\lambda < 2$ (table 10-6, ASCE 41-17)
 $= 1.3800479E-005$
- Stirrup Spacing $\leq d/2$
 $d = 358.00$
 $s = 150.00$
- Strength provided by hoops $V_s < 3/4 \cdot \text{design Shear}$
 $V_s = 175929.189$, already given in calculation of shear control ratio
design Shear = 7492.435
- ($\lambda - 1$)/ $\lambda = -0.15609354$
 $= A_{st}/(b_w \cdot d) = 0.00573326$
Tension Reinf Area: $A_{st} = 615.7522$
 $\lambda = A_{sc}/(b_w \cdot d) = 0.00848289$
Compression Reinf Area: $A_{sc} = 911.0619$
- From (B-1), ACI 318-11: $\lambda = 0.01761524$
 $f_c = 24.00$
 $f_y = 525.00$
From 10.2.7.3, ACI 318-11: $\lambda = 0.85$
From fig R10.3.3, ACI 318-11 (Ence 454, too): $87000/(87000 + f_y) = c_b/d_t = 0.003/(0.003 + \lambda) = 0.53333333$
 $\lambda = 0.002625$
- $V/(b_w \cdot d \cdot f_c^{0.5}) = 0.17148902$, NOTE: units in lb & in
 $b_w = 300.00$

End Of Calculation of Chord Rotation Capacity for element: beam B1 of floor 1
At local axis: 2
Integration Section: (b)

Calculation No. 15

beam B1, Floor 1



Limit State: Life Safety (data interpolation between analysis steps 1 and 2)

Analysis: Uniform +X

Check: Shear capacity V_{Rd}

Edge: End

Local Axis: (3)



Start Of Calculation of Shear Capacity for element: beam B1 of floor 1

At local axis: 3

Integration Section: (b)

Section Type: rcars

Constant Properties

Knowledge Factor, $\gamma = 1.00$

Member Shear Force is generally considered as Force-Controlled Action according to Table C7-1, ASCE 41-17.

Lower-bound strengths are used for Force-Controlled Actions according to 7.5.1.3, ASCE 41-17

Consequently:

Existing material of Primary Member: Concrete Strength, $f_c = f_{c_lower_bound} = 16.00$

Existing material of Primary Member: Steel Strength, $f_s = f_{s_lower_bound} = 420.00$

Concrete Elasticity, $E_c = 23025.204$

Steel Elasticity, $E_s = 200000.00$

Section Height, $H = 400.00$

Section Width, $W = 300.00$

Cover Thickness, $c = 25.00$

Element Length, $L = 1850.00$

Primary Member

Smooth Bars

Ductile Steel

With Detailing for Earthquake Resistance (including stirrups closed at 135°)

Longitudinal Bars With Ends Lapped Starting at the End Sections

Adequate Lap Length ($l_o/l_{o,min} = l_b/l_d \geq 1$)

No FRP Wrapping

Stepwise Properties

EDGE -A-

Bending Moment, $M_a = 4.3364E+006$

Shear Force, $V_a = -2011.906$

EDGE -B-

Bending Moment, $M_b = 4.4551E+006$

Shear Force, $V_b = 7492.435$

BOTH EDGES

Axial Force, $F = -490.6724$

Longitudinal Reinforcement Area Distribution (in 2 divisions)

-Tension: $A_{sl,ten} = 615.7522$

-Compression: $A_{sl,com} = 911.0619$

Longitudinal Reinforcement Area Distribution (in 3 divisions)

-Tension: $A_{sl,ten} = 615.7522$

-Compression: $A_{sl,com} = 603.1858$

-Middle: $A_{sl,mid} = 307.8761$

Mean Diameter of Tension Reinforcement, $Db_{L,ten} = 14.00$

Existing component: From table 7-7, ASCE 41_17: Final Shear Capacity $VR = *V_n = 207816.751$

$V_n ((22.5.1.1), ACI 318-14) = 207816.751$

NOTE: In expression (22.5.1.1) 'Vw' is replaced by 'Vw+ f*Vf' where Vf is the contribution of FRPs (11.3), ACI 440).

From Table (22.5.5.1), ACI 318-14: $V_c = 67073.40$
= 1 (normal-weight concrete)
 $f'_c = 16.00$, but $f'_c^{0.5} \leq 8.3$ MPa (22.5.3.1, ACI 318-14)
 $\rho_w = A_s/(b_w*d) = 0.00641409$
 A_s (tension reinf.) = 615.7522
 $b_w = 300.00$
 $d = 320.00$
 $V_u*d/\mu_u < 1 = 0.53816531$
 $\mu_u = 4.4551E+006$
 $V_u = 7492.435$
From (11.5.4.8), ACI 318-14: $V_s = 140743.351$
 $A_v = 157079.633$
 $f_y = 420.00$
 $s = 150.00$
 V_s has been multiplied by 1 ($s < d/2$, according to ASCE 41-17,10.3.4)
 V_f ((11-3)-(11.4), ACI 440) = 0.00
From (11-11), ACI 440: $V_s + V_f \leq 255092.67$

End Of Calculation of Shear Capacity for element: beam B1 of floor 1
At local axis: 3
Integration Section: (b)

Calculation No. 16

beam B1, Floor 1



Limit State: Life Safety (data interpolation between analysis steps 1 and 2)

Analysis: Uniform +X

Check: Chord rotation capacity (θ_u)

Edge: End

Local Axis: (3)



Start Of Calculation of Shear Capacity ratio for element: beam B1 of floor 1
At Shear local axis: 3
(Bending local axis: 2)

Section Type: rcars

Constant Properties

Knowledge Factor, $\gamma = 1.00$

Mean strength values are used for both shear and moment calculations.

Consequently:

Existing material of Primary Member: Concrete Strength, $f_c = f_{cm} = 24.00$

Existing material of Primary Member: Steel Strength, $f_s = f_{sm} = 525.00$

Concrete Elasticity, $E_c = 23025.204$

Steel Elasticity, $E_s = 200000.00$

#####

Note: Especially for the calculation of moment strengths,

the above steel re-bar strengths are multiplied by 1.25 according to R18.6.5, ACI 318-14

Existing material: Steel Strength, $f_s = 1.25 \cdot f_{sm} = 656.25$

#####

Section Height, $H = 400.00$

Section Width, $W = 300.00$

Cover Thickness, $c = 25.00$

Mean Confinement Factor overall section = 1.09003

Element Length, $L = 1850.00$

Primary Member

Smooth Bars

Ductile Steel

With Detailing for Earthquake Resistance (including stirrups closed at 135°)

Longitudinal Bars With Ends Lapped Starting at the End Sections

Adequate Lap Length ($l_o/l_{ou, \min} >= 1$)

No FRP Wrapping

Stepwise Properties

At local axis: 3

EDGE -A-

Shear Force, $V_a = 2740.265$

EDGE -B-

Shear Force, $V_b = 2740.264$

BOTH EDGES

Axial Force, $F = -211.0849$

Longitudinal Reinforcement Area Distribution (in 2 divisions)

-Tension: $A_{sl, \text{ten}} = 603.1858$

-Compression: $A_{sl, \text{com}} = 923.6282$

Longitudinal Reinforcement Area Distribution (in 3 divisions)

-Tension: $A_{sl, \text{ten}} = 603.1858$

-Compression: $A_{sl, \text{com}} = 615.7522$

-Middle: $A_{sl, \text{mid}} = 307.8761$

Calculation of Shear Capacity ratio, $V_e/V_r = 0.78793176$

Member Controlled by Flexure ($V_e/V_r < 1$)

Calculation of Shear Demand from fig. R18.6.5, ACI 318-14 $V_e = (M_{pr1} + M_{pr2})/l_n \pm w_u \cdot l_n / 2 = 205990.317$

with

$M_{pr1} = \text{Max}(M_{u1+}, M_{u1-}) = 1.8802E+008$

$M_{u1+} = 1.8495E+008$, is the ultimate moment strength at the edge 1 of the member in the actual moment direction which is defined for the static loading combination

$M_{u1-} = 1.8802E+008$, is the ultimate moment strength at the edge 1 of the member in the opposite moment direction which is defined for the static loading combination

$M_{pr2} = \text{Max}(M_{u2+}, M_{u2-}) = 1.8800E+008$

$M_{u2+} = 1.8498E+008$, is the ultimate moment strength at the edge 2 of the member in the actual moment direction which is defined for the the static loading combination

$M_{u2-} = 1.8800E+008$, is the ultimate moment strength at the edge 2 of the member in the opposite moment direction which is defined for the the static loading combination

and

$\pm w_u \cdot l_n = (|V_1| + |V_2|)/2$

with

V1 = 2740.265, is the shear force acting at edge 1 for the the static loading combination
V2 = 2740.264, is the shear force acting at edge 2 for the the static loading combination

Calculation of Mu1+

Calculation of ultimate curvature ϕ_u according to 4.1, Biskinis/Fardis 2013:

$$u = 0.0001071$$

$$Mu = 1.8495E+008$$

with full section properties:

$$b = 300.00$$

$$d = 357.00$$

$$d' = 42.00$$

$$v = 8.2121432E-005$$

$$N = 211.0849$$

$$f_c = 24.00$$

$$c_o \text{ (5A.5, TBDY)} = 0.002$$

$$\text{Final value of } c_u: c_u^* = \text{shear_factor} * \text{Max}(c_u, c_c) = 0.00773686$$

The Shear_factor is considered equal to 1 (pure moment strength)

$$\text{From (5.4b), TBDY: } c_u = 0.00773686$$

$$w_e \text{ (5.4c)} = 0.01121936$$

$$a_{se} \text{ ((5.4d), TBDY)} = 0.15672608$$

$$b_o = 240.00$$

$$h_o = 340.00$$

$$b_{i2} = 346400.00$$

$$p_{sh,min} = \text{Min}(p_{sh,x}, p_{sh,y}) = 0.00261799$$

 $p_{sh,x} \text{ (5.4d)} = 0.00349066$

$$A_{sh} = A_{stir} * n_s = 78.53982$$

$$\text{No stirups, } n_s = 2.00$$

$$b_k = 300.00$$

 $p_{sh,y} \text{ (5.4d)} = 0.00261799$

$$A_{sh} = A_{stir} * n_s = 78.53982$$

$$\text{No stirups, } n_s = 2.00$$

$$b_k = 400.00$$

 $s = 150.00$

$$f_{ywe} = 656.25$$

$$f_{ce} = 24.00$$

$$\text{From ((5.A5), TBDY), TBDY: } c_c = 0.00290026$$

$$c = \text{confinement factor} = 1.09003$$

$$y_1 = 0.0025$$

$$sh_1 = 0.008$$

$$ft_1 = 787.50$$

$$fy_1 = 656.25$$

$$su_1 = 0.032$$

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00

$$l_o/l_{ou,min} = l_b/l_d = 1.00$$

$$su_1 = 0.4 * esu_1_{nominal} \text{ ((5.5), TBDY)} = 0.032$$

$$\text{From table 5A.1, TBDY: } esu_1_{nominal} = 0.08,$$

For calculation of $esu_1_{nominal}$ and y_1, sh_1, ft_1, fy_1 , it is considered
characteristic value $fsy_1 = fs_1/1.2$, from table 5.1, TBDY.

$$y_1, sh_1, ft_1, fy_1, \text{ are also multiplied by } \text{Min}(1, 1.25 * (l_b/l_d)^{2/3}), \text{ from 10.3.5, ASCE 41-17.}$$

$$\text{with } fs_1 = fs = 656.25$$

$$\text{with } E_{s1} = E_s = 200000.00$$

$$y_2 = 0.0025$$

$$sh_2 = 0.008$$

$$ft_2 = 787.50$$

$$fy_2 = 656.25$$

$$su_2 = 0.032$$

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor

and also multiplied by the shear_factor according to 15.7.1.4, with

Shear_factor = 1.00

lo/lou,min = lb/lb,min = 1.00

su2 = 0.4*esu2_nominal ((5.5), TBDY) = 0.032

From table 5A.1, TBDY: esu2_nominal = 0.08,

For calculation of esu2_nominal and y2, sh2,ft2,fy2, it is considered characteristic value fsy2 = fs2/1.2, from table 5.1, TBDY.

y1, sh1,ft1,fy1, are also multiplied by $\text{Min}(1, 1.25 \cdot (lb/ld)^{2/3})$, from 10.3.5, ASCE 41-17.

with fs2 = fs = 656.25

with Es2 = Es = 200000.00

yv = 0.0025

shv = 0.008

ftv = 787.50

fyv = 656.25

suv = 0.032

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor

and also multiplied by the shear_factor according to 15.7.1.4, with Shear_factor = 1.00

lo/lou,min = lb/ld = 1.00

suv = 0.4*esuv_nominal ((5.5), TBDY) = 0.032

From table 5A.1, TBDY: esuv_nominal = 0.08,

considering characteristic value fsyv = fsv/1.2, from table 5.1, TBDY

For calculation of esuv_nominal and yv, shv,ftv,fyv, it is considered characteristic value fsyv = fsv/1.2, from table 5.1, TBDY.

y1, sh1,ft1,fy1, are also multiplied by $\text{Min}(1, 1.25 \cdot (lb/ld)^{2/3})$, from 10.3.5, ASCE 41-17.

with fsv = fs = 656.25

with Esv = Es = 200000.00

1 = Asl,ten/(b*d)*(fs1/fc) = 0.15399964

2 = Asl,com/(b*d)*(fs2/fc) = 0.15720797

v = Asl,mid/(b*d)*(fsv/fc) = 0.07860398

and confined core properties:

b = 240.00

d = 327.00

d' = 12.00

fcc (5A.2, TBDY) = 26.16063

cc (5A.5, TBDY) = 0.00290026

c = confinement factor = 1.09003

1 = Asl,ten/(b*d)*(fs1/fc) = 0.21016006

2 = Asl,com/(b*d)*(fs2/fc) = 0.21453839

v = Asl,mid/(b*d)*(fsv/fc) = 0.1072692

Case/Assumption: Unconfined full section - Steel rupture

' satisfies Eq. (4.3)

--->

v < vs,y2 - LHS eq.(4.5) is satisfied

--->

su (4.9) = 0.1630814

Mu = MRc (4.14) = 1.8495E+008

u = su (4.1) = 0.0001071

Calculation of ratio lb/ld

Adequate Lap Length: lb/ld >= 1

Calculation of Mu1-

Calculation of ultimate curvature u according to 4.1, Biskinis/Fardis 2013:

u = 0.00010722

Mu = 1.8802E+008

with full section properties:

b = 300.00

d = 358.00

d' = 43.00
v = 8.1892042E-005
N = 211.0849
fc = 24.00
co (5A.5, TBDY) = 0.002
Final value of cu: cu* = shear_factor * Max(cu, cc) = 0.00773686
The Shear_factor is considered equal to 1 (pure moment strength)
From (5.4b), TBDY: cu = 0.00773686
we (5.4c) = 0.01121936
ase ((5.4d), TBDY) = 0.15672608
bo = 240.00
ho = 340.00
bi2 = 346400.00
psh,min = Min(psh,x , psh,y) = 0.00261799

psh,x (5.4d) = 0.00349066
Ash = Astir*ns = 78.53982
No stirups, ns = 2.00
bk = 300.00

psh,y (5.4d) = 0.00261799
Ash = Astir*ns = 78.53982
No stirups, ns = 2.00
bk = 400.00

s = 150.00
fywe = 656.25
fce = 24.00
From ((5.A5), TBDY), TBDY: cc = 0.00290026
c = confinement factor = 1.09003
y1 = 0.0025
sh1 = 0.008
ft1 = 787.50
fy1 = 656.25
su1 = 0.032

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00
lo/lou,min = lb/lb = 1.00
su1 = 0.4*esu1_nominal ((5.5), TBDY) = 0.032
From table 5A.1, TBDY: esu1_nominal = 0.08,
For calculation of esu1_nominal and y1, sh1,ft1,fy1, it is considered
characteristic value fsy1 = fs1/1.2, from table 5.1, TBDY.
y1, sh1,ft1,fy1, are also multiplied by Min(1,1.25*(lb/lb)^ 2/3), from 10.3.5, ASCE 41-17.
with fs1 = fs = 656.25
with Es1 = Es = 200000.00

y2 = 0.0025
sh2 = 0.008
ft2 = 787.50
fy2 = 656.25
su2 = 0.032
using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00
lo/lou,min = lb/lb,min = 1.00
su2 = 0.4*esu2_nominal ((5.5), TBDY) = 0.032
From table 5A.1, TBDY: esu2_nominal = 0.08,
For calculation of esu2_nominal and y2, sh2,ft2,fy2, it is considered
characteristic value fsy2 = fs2/1.2, from table 5.1, TBDY.
y1, sh1,ft1,fy1, are also multiplied by Min(1,1.25*(lb/lb)^ 2/3), from 10.3.5, ASCE 41-17.
with fs2 = fs = 656.25
with Es2 = Es = 200000.00

yv = 0.0025
shv = 0.008
ftv = 787.50
fyv = 656.25
suv = 0.032

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00

$l_0/l_{ou,min} = l_b/l_d = 1.00$

$s_{uv} = 0.4 * e_{suv,nominal} ((5.5), TBDY) = 0.032$

From table 5A.1, TBDY: $e_{suv,nominal} = 0.08$,

considering characteristic value $f_{sv} = f_{sv}/1.2$, from table 5.1, TBDY

For calculation of $e_{suv,nominal}$ and γ_v , η_v , f_{tv} , f_{yv} , it is considered
characteristic value $f_{sv} = f_{sv}/1.2$, from table 5.1, TBDY.

γ_1 , η_1 , f_{t1} , f_{y1} , are also multiplied by $\text{Min}(1, 1.25 * (l_b/l_d)^{2/3})$, from 10.3.5, ASCE 41-17.

with $f_{sv} = f_s = 656.25$

with $E_{sv} = E_s = 200000.00$

$1 = A_{sl,ten}/(b*d) * (f_{s1}/f_c) = 0.15676884$

$2 = A_{sl,com}/(b*d) * (f_{s2}/f_c) = 0.15356947$

$v = A_{sl,mid}/(b*d) * (f_{sv}/f_c) = 0.07838442$

and confined core properties:

$b = 240.00$

$d = 328.00$

$d' = 13.00$

$f_{cc} (5A.2, TBDY) = 26.16063$

$cc (5A.5, TBDY) = 0.00290026$

$c = \text{confinement factor} = 1.09003$

$1 = A_{sl,ten}/(b*d) * (f_{s1}/f_c) = 0.21388431$

$2 = A_{sl,com}/(b*d) * (f_{s2}/f_c) = 0.20951933$

$v = A_{sl,mid}/(b*d) * (f_{sv}/f_c) = 0.10694216$

Case/Assumption: Unconfined full section - Steel rupture

' satisfies Eq. (4.3)

$v < v_{s,y2}$ - LHS eq.(4.5) is satisfied

$s_u (4.9) = 0.16631328$

$M_u = M_{Rc} (4.14) = 1.8802E+008$

$u = s_u (4.1) = 0.00010722$

Calculation of ratio l_b/l_d

Adequate Lap Length: $l_b/l_d \geq 1$

Calculation of M_{u2+}

Calculation of ultimate curvature u according to 4.1, Biskinis/Fardis 2013:

$u = 0.00010701$

$M_u = 1.8498E+008$

with full section properties:

$b = 300.00$

$d = 358.00$

$d' = 43.00$

$v = 8.1892042E-005$

$N = 211.0849$

$f_c = 24.00$

$co (5A.5, TBDY) = 0.002$

Final value of cu : $cu^* = \text{shear_factor} * \text{Max}(cu, cc) = 0.00773686$

The Shear_factor is considered equal to 1 (pure moment strength)

From (5.4b), TBDY: $cu = 0.00773686$

$w_e (5.4c) = 0.01121936$

$ase ((5.4d), TBDY) = 0.15672608$

$bo = 240.00$

$ho = 340.00$

$bi_2 = 346400.00$

$p_{sh,min} = \text{Min}(p_{sh,x}, p_{sh,y}) = 0.00261799$

psh,x (5.4d) = 0.00349066
Ash = Astir*ns = 78.53982
No stirups, ns = 2.00
bk = 300.00

psh,y (5.4d) = 0.00261799
Ash = Astir*ns = 78.53982
No stirups, ns = 2.00
bk = 400.00

s = 150.00
fywe = 656.25
fce = 24.00

From ((5.A5), TBDY), TBDY: cc = 0.00290026
c = confinement factor = 1.09003

y1 = 0.0025
sh1 = 0.008
ft1 = 787.50
fy1 = 656.25
su1 = 0.032

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00

lo/lou,min = lb/lb,min = 1.00

su1 = 0.4*esu1_nominal ((5.5), TBDY) = 0.032

From table 5A.1, TBDY: esu1_nominal = 0.08,

For calculation of esu1_nominal and y1, sh1,ft1,fy1, it is considered
characteristic value fsy1 = fs1/1.2, from table 5.1, TBDY.

y1, sh1,ft1,fy1, are also multiplied by Min(1,1.25*(lb/lb)^ 2/3), from 10.3.5, ASCE 41-17.

with fs1 = fs = 656.25

with Es1 = Es = 200000.00

y2 = 0.0025
sh2 = 0.008
ft2 = 787.50
fy2 = 656.25
su2 = 0.032

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00

lo/lou,min = lb/lb,min = 1.00

su2 = 0.4*esu2_nominal ((5.5), TBDY) = 0.032

From table 5A.1, TBDY: esu2_nominal = 0.08,

For calculation of esu2_nominal and y2, sh2,ft2,fy2, it is considered
characteristic value fsy2 = fs2/1.2, from table 5.1, TBDY.

y1, sh1,ft1,fy1, are also multiplied by Min(1,1.25*(lb/lb)^ 2/3), from 10.3.5, ASCE 41-17.

with fs2 = fs = 656.25

with Es2 = Es = 200000.00

yv = 0.0025
shv = 0.008
ftv = 787.50
fyv = 656.25
suv = 0.032

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00

lo/lou,min = lb/lb,min = 1.00

suv = 0.4*esuv_nominal ((5.5), TBDY) = 0.032

From table 5A.1, TBDY: esuv_nominal = 0.08,

considering characteristic value fsyv = fsv/1.2, from table 5.1, TBDY

For calculation of esuv_nominal and yv, shv,ftv,fyv, it is considered
characteristic value fsyv = fsv/1.2, from table 5.1, TBDY.

y1, sh1,ft1,fy1, are also multiplied by Min(1,1.25*(lb/lb)^ 2/3), from 10.3.5, ASCE 41-17.

with fsv = fs = 656.25

with Esv = Es = 200000.00

1 = Asl,ten/(b*d)*(fs1/fc) = 0.15356947

2 = Asl,com/(b*d)*(fs2/fc) = 0.15676884

v = Asl,mid/(b*d)*(fsv/fc) = 0.07838442

and confined core properties:

$$b = 240.00$$

$$d = 328.00$$

$$d' = 13.00$$

$$fcc (5A.2, TBDY) = 26.16063$$

$$cc (5A.5, TBDY) = 0.00290026$$

$$c = \text{confinement factor} = 1.09003$$

$$1 = A_{sl,ten}/(b*d)*(f_{s1}/f_c) = 0.20951933$$

$$2 = A_{sl,com}/(b*d)*(f_{s2}/f_c) = 0.21388431$$

$$v = A_{sl,mid}/(b*d)*(f_{sv}/f_c) = 0.10694216$$

Case/Assumption: Unconfined full section - Steel rupture

' satisfies Eq. (4.3)

--->

$v < v_{s,y2}$ - LHS eq.(4.5) is satisfied

--->

$$s_u (4.9) = 0.16466458$$

$$\mu_u = M_{Rc} (4.14) = 1.8498E+008$$

$$u = s_u (4.1) = 0.00010701$$

Calculation of ratio l_b/d

Adequate Lap Length: $l_b/d \geq 1$

Calculation of μ_{u2} -

Calculation of ultimate curvature μ_u according to 4.1, Biskinis/Fardis 2013:

$$u = 0.00010732$$

$$\mu_u = 1.8800E+008$$

with full section properties:

$$b = 300.00$$

$$d = 357.00$$

$$d' = 42.00$$

$$v = 8.2121432E-005$$

$$N = 211.0849$$

$$f_c = 24.00$$

$$c_o (5A.5, TBDY) = 0.002$$

$$\text{Final value of } c_u: c_u^* = \text{shear_factor} * \text{Max}(c_u, c_c) = 0.00773686$$

The Shear_factor is considered equal to 1 (pure moment strength)

$$\text{From (5.4b), TBDY: } c_u = 0.00773686$$

$$w_e (5.4c) = 0.01121936$$

$$a_{se} ((5.4d), TBDY) = 0.15672608$$

$$b_o = 240.00$$

$$h_o = 340.00$$

$$b_{i2} = 346400.00$$

$$p_{sh,min} = \text{Min}(p_{sh,x}, p_{sh,y}) = 0.00261799$$

$$p_{sh,x} (5.4d) = 0.00349066$$

$$A_{sh} = A_{stir} * n_s = 78.53982$$

$$\text{No stirups, } n_s = 2.00$$

$$b_k = 300.00$$

$$p_{sh,y} (5.4d) = 0.00261799$$

$$A_{sh} = A_{stir} * n_s = 78.53982$$

$$\text{No stirups, } n_s = 2.00$$

$$b_k = 400.00$$

$$s = 150.00$$

$$f_{ywe} = 656.25$$

$$f_{ce} = 24.00$$

$$\text{From ((5.A5), TBDY), TBDY: } c_c = 0.00290026$$

$$c = \text{confinement factor} = 1.09003$$

y1 = 0.0025
sh1 = 0.008
ft1 = 787.50
fy1 = 656.25
su1 = 0.032

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00

lo/lou,min = lb/d = 1.00

su1 = 0.4*esu1_nominal ((5.5), TBDY) = 0.032

From table 5A.1, TBDY: esu1_nominal = 0.08,

For calculation of esu1_nominal and y1, sh1,ft1,fy1, it is considered
characteristic value fsy1 = fs1/1.2, from table 5.1, TBDY.

y1, sh1,ft1,fy1, are also multiplied by $\text{Min}(1, 1.25 \cdot (lb/d)^{2/3})$, from 10.3.5, ASCE 41-17.

with fs1 = fs = 656.25

with Es1 = Es = 200000.00

y2 = 0.0025
sh2 = 0.008
ft2 = 787.50
fy2 = 656.25
su2 = 0.032

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00

lo/lou,min = lb/lb,min = 1.00

su2 = 0.4*esu2_nominal ((5.5), TBDY) = 0.032

From table 5A.1, TBDY: esu2_nominal = 0.08,

For calculation of esu2_nominal and y2, sh2,ft2,fy2, it is considered
characteristic value fsy2 = fs2/1.2, from table 5.1, TBDY.

y1, sh1,ft1,fy1, are also multiplied by $\text{Min}(1, 1.25 \cdot (lb/d)^{2/3})$, from 10.3.5, ASCE 41-17.

with fs2 = fs = 656.25

with Es2 = Es = 200000.00

yv = 0.0025
shv = 0.008
ftv = 787.50
fyv = 656.25
suv = 0.032

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00

lo/lou,min = lb/d = 1.00

suv = 0.4*esuv_nominal ((5.5), TBDY) = 0.032

From table 5A.1, TBDY: esuv_nominal = 0.08,

considering characteristic value fsyv = fsv/1.2, from table 5.1, TBDY

For calculation of esuv_nominal and yv, shv,ftv,fyv, it is considered
characteristic value fsyv = fsv/1.2, from table 5.1, TBDY.

y1, sh1,ft1,fy1, are also multiplied by $\text{Min}(1, 1.25 \cdot (lb/d)^{2/3})$, from 10.3.5, ASCE 41-17.

with fsv = fs = 656.25

with Esv = Es = 200000.00

1 = Asl,ten/(b*d)*(fs1/fc) = 0.15720797

2 = Asl,com/(b*d)*(fs2/fc) = 0.15399964

v = Asl,mid/(b*d)*(fsv/fc) = 0.07860398

and confined core properties:

b = 240.00

d = 327.00

d' = 12.00

fcc (5A.2, TBDY) = 26.16063

cc (5A.5, TBDY) = 0.00290026

c = confinement factor = 1.09003

1 = Asl,ten/(b*d)*(fs1/fc) = 0.21453839

2 = Asl,com/(b*d)*(fs2/fc) = 0.21016006

v = Asl,mid/(b*d)*(fsv/fc) = 0.1072692

Case/Assumption: Unconfined full section - Steel rupture

' satisfies Eq. (4.3)

---->

v < vs,y2 - LHS eq.(4.5) is satisfied

---->

su (4.9) = 0.16474284
Mu = MRc (4.14) = 1.8800E+008
u = su (4.1) = 0.00010732

Calculation of ratio lb/l_d

Adequate Lap Length: lb/l_d >= 1

Calculation of Shear Strength Vr = Min(Vr1,Vr2) = 261431.672

Calculation of Shear Strength at edge 1, Vr1 = 261431.672
Vr1 = Vn ((22.5.1.1), ACI 318-14)

NOTE: In expression (22.5.1.1) 'Vw' is replaced by 'Vw+ f*Vf'
where Vf is the contribution of FRPs (11.3), ACI 440).

From Table (22.5.5.1), ACI 318-14: Vc = 85502.483
= 1 (normal-weight concrete)
fc' = 24.00, but fc'^0.5 <= 8.3 MPa (22.5.3.1, ACI 318-14)
pw = As/(bw*d) = 0.00628319
As (tension reinf.) = 603.1858
bw = 300.00
d = 320.00
Vu*d/Mu < 1 = 1.00
Mu = 30114.962
Vu = 2740.265

From (11.5.4.8), ACI 318-14: Vs = 175929.189
Av = 157079.633
fy = 525.00
s = 150.00

Vs has been multiplied by 1 (s<d/2, according to ASCE 41-17,10.3.4)
Vf ((11-3)-(11.4), ACI 440) = 0.00
From (11-11), ACI 440: Vs + Vf <= 312423.44

Calculation of Shear Strength at edge 2, Vr2 = 261431.672
Vr2 = Vn ((22.5.1.1), ACI 318-14)

NOTE: In expression (22.5.1.1) 'Vw' is replaced by 'Vw+ f*Vf'
where Vf is the contribution of FRPs (11.3), ACI 440).

From Table (22.5.5.1), ACI 318-14: Vc = 85502.483
= 1 (normal-weight concrete)
fc' = 24.00, but fc'^0.5 <= 8.3 MPa (22.5.3.1, ACI 318-14)
pw = As/(bw*d) = 0.00628319
As (tension reinf.) = 603.1858
bw = 300.00
d = 320.00
Vu*d/Mu < 1 = 1.00
Mu = 30115.665
Vu = 2740.264

From (11.5.4.8), ACI 318-14: Vs = 175929.189
Av = 157079.633
fy = 525.00
s = 150.00

Vs has been multiplied by 1 (s<d/2, according to ASCE 41-17,10.3.4)
Vf ((11-3)-(11.4), ACI 440) = 0.00
From (11-11), ACI 440: Vs + Vf <= 312423.44

End Of Calculation of Shear Capacity ratio for element: beam B1 of floor 1
At local axis: 3

Start Of Calculation of Shear Capacity ratio for element: beam B1 of floor 1

At Shear local axis: 2

(Bending local axis: 3)

Section Type: rcars

Constant Properties

Knowledge Factor, $\gamma = 1.00$

Mean strength values are used for both shear and moment calculations.

Consequently:

Existing material of Primary Member: Concrete Strength, $f_c = f_{cm} = 24.00$

Existing material of Primary Member: Steel Strength, $f_s = f_{sm} = 525.00$

Concrete Elasticity, $E_c = 23025.204$

Steel Elasticity, $E_s = 200000.00$

#####

Note: Especially for the calculation of moment strengths,

the above steel re-bar strengths are multiplied by 1.25 according to R18.6.5, ACI 318-14

Existing material: Steel Strength, $f_s = 1.25 \cdot f_{sm} = 656.25$

#####

Section Height, $H = 400.00$

Section Width, $W = 300.00$

Cover Thickness, $c = 25.00$

Mean Confinement Factor overall section = 1.09003

Element Length, $L = 1850.00$

Primary Member

Smooth Bars

Ductile Steel

With Detailing for Earthquake Resistance (including stirrups closed at 135°)

Longitudinal Bars With Ends Lapped Starting at the End Sections

Adequate Lap Length ($l_o/l_{ou}, \min >= 1$)

No FRP Wrapping

Stepwise Properties

At local axis: 2

EDGE -A-

Shear Force, $V_a = -3.6870970E-015$

EDGE -B-

Shear Force, $V_b = 3.6870970E-015$

BOTH EDGES

Axial Force, $F = -211.0849$

Longitudinal Reinforcement Area Distribution (in 2 divisions)

-Tension: $A_{st} = 603.1858$

-Compression: $A_{sc} = 923.6282$

Longitudinal Reinforcement Area Distribution (in 3 divisions)

-Tension: $A_{st,ten} = 508.938$

-Compression: $A_{sc,com} = 508.938$

-Middle: $A_{sl,mid} = 508.938$

Calculation of Shear Capacity ratio, $V_e/V_r = 0.79211753$

Member Controlled by Flexure ($V_e/V_r < 1$)

Calculation of Shear Demand from fig. R18.6.5, ACI 318-14 $V_e = (M_{pr1} + M_{pr2})/l_n \pm w_u \cdot l_n/2 = 137993.601$
with

$M_{pr1} = \text{Max}(M_{u1+}, M_{u1-}) = 1.2764E+008$

$M_{u1+} = 1.2764E+008$, is the ultimate moment strength at the edge 1 of the member in the actual moment direction which is defined for the static loading combination

$M_{u1-} = 1.2764E+008$, is the ultimate moment strength at the edge 1 of the member in the opposite moment direction which is defined for the static loading combination

$M_{pr2} = \text{Max}(M_{u2+}, M_{u2-}) = 1.2764E+008$

$M_{u2+} = 1.2764E+008$, is the ultimate moment strength at the edge 2 of the member in the actual moment direction which is defined for the static loading combination

$M_{u2-} = 1.2764E+008$, is the ultimate moment strength at the edge 2 of the member in the opposite moment

direction which is defined for the the static loading combination
and

$$\pm wu*ln = (|V1| + |V2|)/2$$

with

V1 = -3.6870970E-015, is the shear force acting at edge 1 for the the static loading combination

V2 = 3.6870970E-015, is the shear force acting at edge 2 for the the static loading combination

Calculation of Mu1+

Calculation of ultimate curvature ϕ_u according to 4.1, Biskinis/Fardis 2013:

$$u = 0.00015613$$

$$Mu = 1.2764E+008$$

with full section properties:

$$b = 400.00$$

$$d = 258.00$$

$$d' = 42.00$$

$$v = 8.5224858E-005$$

$$N = 211.0849$$

$$fc = 24.00$$

$$co \text{ (5A.5, TBDY)} = 0.002$$

$$\text{Final value of } \phi_u: \phi_u^* = \text{shear_factor} * \text{Max}(\phi_u, \phi_c) = 0.00773686$$

The Shear_factor is considered equal to 1 (pure moment strength)

$$\text{From (5.4b), TBDY: } \phi_u = 0.00773686$$

$$\phi_{ue} \text{ (5.4c)} = 0.01121936$$

$$\phi_{ase} \text{ ((5.4d), TBDY)} = 0.15672608$$

$$b_o = 240.00$$

$$h_o = 340.00$$

$$b_i^2 = 346400.00$$

$$\phi_{sh,min} = \text{Min}(\phi_{sh,x}, \phi_{sh,y}) = 0.00261799$$

 $\phi_{sh,x} \text{ (5.4d)} = 0.00349066$

$$A_{sh} = A_{stir} * n_s = 78.53982$$

$$\text{No stirups, } n_s = 2.00$$

$$b_k = 300.00$$

 $\phi_{sh,y} \text{ (5.4d)} = 0.00261799$

$$A_{sh} = A_{stir} * n_s = 78.53982$$

$$\text{No stirups, } n_s = 2.00$$

$$b_k = 400.00$$

 $s = 150.00$

$$f_{ywe} = 656.25$$

$$f_{ce} = 24.00$$

$$\text{From ((5.A5), TBDY), TBDY: } \phi_c = 0.00290026$$

$$c = \text{confinement factor} = 1.09003$$

$$y_1 = 0.0025$$

$$sh_1 = 0.008$$

$$ft_1 = 787.50$$

$$fy_1 = 656.25$$

$$su_1 = 0.032$$

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor

and also multiplied by the shear_factor according to 15.7.1.4, with

Shear_factor = 1.00

$$l_o/l_{ou,min} = l_b/l_d = 1.00$$

$$su_1 = 0.4 * esu_{1,nominal} \text{ ((5.5), TBDY)} = 0.032$$

$$\text{From table 5A.1, TBDY: } esu_{1,nominal} = 0.08,$$

For calculation of $esu_{1,nominal}$ and y_1, sh_1, ft_1, fy_1 , it is considered

characteristic value $fsy_1 = fs_1/1.2$, from table 5.1, TBDY.

y_1, sh_1, ft_1, fy_1 , are also multiplied by $\text{Min}(1, 1.25 * (l_b/l_d)^{2/3})$, from 10.3.5, ASCE 41-17.

$$\text{with } fs_1 = fs = 656.25$$

$$\text{with } Es_1 = Es = 200000.00$$

$$y_2 = 0.0025$$

$$sh_2 = 0.008$$

$$ft2 = 787.50$$

$$fy2 = 656.25$$

$$su2 = 0.032$$

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00

$$lo/lou,min = lb/lb,min = 1.00$$

$$su2 = 0.4 * esu2_nominal ((5.5), TBDY) = 0.032$$

From table 5A.1, TBDY: esu2_nominal = 0.08,

For calculation of esu2_nominal and y2, sh2,ft2,fy2, it is considered
characteristic value fsy2 = fs2/1.2, from table 5.1, TBDY.

y1, sh1,ft1,fy1, are also multiplied by $\text{Min}(1, 1.25 * (lb/ld)^{2/3})$, from 10.3.5, ASCE 41-17.

$$\text{with } fs2 = fs = 656.25$$

$$\text{with } Es2 = Es = 200000.00$$

$$yv = 0.0025$$

$$shv = 0.008$$

$$ftv = 787.50$$

$$fyv = 656.25$$

$$suv = 0.032$$

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00

$$lo/lou,min = lb/ld = 1.00$$

$$suv = 0.4 * esuv_nominal ((5.5), TBDY) = 0.032$$

From table 5A.1, TBDY: esuv_nominal = 0.08,

considering characteristic value fsyv = fsv/1.2, from table 5.1, TBDY

For calculation of esuv_nominal and yv, shv,ftv,fyv, it is considered
characteristic value fsyv = fsv/1.2, from table 5.1, TBDY.

y1, sh1,ft1,fy1, are also multiplied by $\text{Min}(1, 1.25 * (lb/ld)^{2/3})$, from 10.3.5, ASCE 41-17.

$$\text{with } fsv = fs = 656.25$$

$$\text{with } Esv = Es = 200000.00$$

$$1 = Asl,ten / (b * d) * (fs1 / fc) = 0.13484761$$

$$2 = Asl,com / (b * d) * (fs2 / fc) = 0.13484761$$

$$v = Asl,mid / (b * d) * (fsv / fc) = 0.13484761$$

and confined core properties:

$$b = 340.00$$

$$d = 228.00$$

$$d' = 12.00$$

$$fcc (5A.2, TBDY) = 26.16063$$

$$cc (5A.5, TBDY) = 0.00290026$$

$$c = \text{confinement factor} = 1.09003$$

$$1 = Asl,ten / (b * d) * (fs1 / fc) = 0.17951849$$

$$2 = Asl,com / (b * d) * (fs2 / fc) = 0.17951849$$

$$v = Asl,mid / (b * d) * (fsv / fc) = 0.17951849$$

Case/Assumption: Unconfined full section - Steel rupture

' does not satisfy Eq. (4.3)

---->

$v < vs,c$ - RHS eq.(4.5) is satisfied

---->

$$su (4.9) = 0.20560388$$

$$Mu = MRc (4.14) = 1.2764E+008$$

$$u = su (4.1) = 0.00015613$$

Calculation of ratio lb/ld

Adequate Lap Length: $lb/ld \geq 1$

Calculation of Mu1-

Calculation of ultimate curvature u according to 4.1, Biskinis/Fardis 2013:

$$u = 0.00015613$$

$$Mu = 1.2764E+008$$

with full section properties:

$$b = 400.00$$

$$d = 258.00$$

$$d' = 42.00$$

$$v = 8.5224858E-005$$

$$N = 211.0849$$

$$f_c = 24.00$$

$$c_o(5A.5, \text{TBDY}) = 0.002$$

$$\text{Final value of } c_u: c_u^* = \text{shear_factor} * \text{Max}(c_u, c_c) = 0.00773686$$

The Shear_factor is considered equal to 1 (pure moment strength)

$$\text{From (5.4b), TBDY: } c_u = 0.00773686$$

$$w_e(5.4c) = 0.01121936$$

$$a_{se}((5.4d), \text{TBDY}) = 0.15672608$$

$$b_o = 240.00$$

$$h_o = 340.00$$

$$b_{i2} = 346400.00$$

$$p_{sh,min} = \text{Min}(p_{sh,x}, p_{sh,y}) = 0.00261799$$

$$p_{sh,x}(5.4d) = 0.00349066$$

$$A_{sh} = A_{stir} * n_s = 78.53982$$

No stirrups, $n_s = 2.00$

$$b_k = 300.00$$

$$p_{sh,y}(5.4d) = 0.00261799$$

$$A_{sh} = A_{stir} * n_s = 78.53982$$

No stirrups, $n_s = 2.00$

$$b_k = 400.00$$

$$s = 150.00$$

$$f_{ywe} = 656.25$$

$$f_{ce} = 24.00$$

$$\text{From ((5.A5), TBDY), TBDY: } c_c = 0.00290026$$

$$c = \text{confinement factor} = 1.09003$$

$$y_1 = 0.0025$$

$$sh_1 = 0.008$$

$$ft_1 = 787.50$$

$$fy_1 = 656.25$$

$$su_1 = 0.032$$

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor and also multiplied by the shear_factor according to 15.7.1.4, with Shear_factor = 1.00

$$l_o/l_{o,min} = l_b/d = 1.00$$

$$su_1 = 0.4 * esu_{1,nominal}((5.5), \text{TBDY}) = 0.032$$

$$\text{From table 5A.1, TBDY: } esu_{1,nominal} = 0.08,$$

For calculation of $esu_{1,nominal}$ and y_1, sh_1, ft_1, fy_1 , it is considered characteristic value $fsy_1 = fs_1/1.2$, from table 5.1, TBDY.

y_1, sh_1, ft_1, fy_1 , are also multiplied by $\text{Min}(1, 1.25 * (l_b/d)^{2/3})$, from 10.3.5, ASCE 41-17.

$$\text{with } fs_1 = fs = 656.25$$

$$\text{with } Es_1 = Es = 200000.00$$

$$y_2 = 0.0025$$

$$sh_2 = 0.008$$

$$ft_2 = 787.50$$

$$fy_2 = 656.25$$

$$su_2 = 0.032$$

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor and also multiplied by the shear_factor according to 15.7.1.4, with Shear_factor = 1.00

$$l_o/l_{o,min} = l_b/l_{b,min} = 1.00$$

$$su_2 = 0.4 * esu_{2,nominal}((5.5), \text{TBDY}) = 0.032$$

$$\text{From table 5A.1, TBDY: } esu_{2,nominal} = 0.08,$$

For calculation of $esu_{2,nominal}$ and y_2, sh_2, ft_2, fy_2 , it is considered characteristic value $fsy_2 = fs_2/1.2$, from table 5.1, TBDY.

y_2, sh_2, ft_2, fy_2 , are also multiplied by $\text{Min}(1, 1.25 * (l_b/d)^{2/3})$, from 10.3.5, ASCE 41-17.

$$\text{with } fs_2 = fs = 656.25$$

$$\text{with } Es_2 = Es = 200000.00$$

$$y_v = 0.0025$$

$shv = 0.008$
 $ftv = 787.50$
 $fyv = 656.25$
 $suv = 0.032$
 using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
 and also multiplied by the shear_factor according to 15.7.1.4, with
 $Shear_factor = 1.00$
 $lo/lou,min = lb/ld = 1.00$
 $suv = 0.4 * esuv_nominal ((5.5), TBDY) = 0.032$
 From table 5A.1, TBDY: $esuv_nominal = 0.08$,
 considering characteristic value $fsyv = fsv/1.2$, from table 5.1, TBDY
 For calculation of $esuv_nominal$ and yv , shv,ftv,fyv , it is considered
 characteristic value $fsyv = fsv/1.2$, from table 5.1, TBDY.
 $y1, sh1,ft1,fy1$, are also multiplied by $Min(1,1.25*(lb/ld)^{2/3})$, from 10.3.5, ASCE 41-17.
 with $fsv = fs = 656.25$
 with $Esv = Es = 200000.00$
 $1 = Asl,ten/(b*d)*(fs1/fc) = 0.13484761$
 $2 = Asl,com/(b*d)*(fs2/fc) = 0.13484761$
 $v = Asl,mid/(b*d)*(fsv/fc) = 0.13484761$
 and confined core properties:
 $b = 340.00$
 $d = 228.00$
 $d' = 12.00$
 $fcc (5A.2, TBDY) = 26.16063$
 $cc (5A.5, TBDY) = 0.00290026$
 $c = confinement\ factor = 1.09003$
 $1 = Asl,ten/(b*d)*(fs1/fc) = 0.17951849$
 $2 = Asl,com/(b*d)*(fs2/fc) = 0.17951849$
 $v = Asl,mid/(b*d)*(fsv/fc) = 0.17951849$
 Case/Assumption: Unconfined full section - Steel rupture
 ' does not satisfy Eq. (4.3)
 --->
 $v < vs,c$ - RHS eq.(4.5) is satisfied
 --->
 $su (4.9) = 0.20560388$
 $Mu = MRc (4.14) = 1.2764E+008$
 $u = su (4.1) = 0.00015613$

 Calculation of ratio lb/ld

Adequate Lap Length: $lb/ld \geq 1$

 Calculation of $Mu2+$

 Calculation of ultimate curvature u according to 4.1, Biskinis/Fardis 2013:

$u = 0.00015613$
 $Mu = 1.2764E+008$

with full section properties:

$b = 400.00$
 $d = 258.00$
 $d' = 42.00$
 $v = 8.5224858E-005$
 $N = 211.0849$
 $fc = 24.00$
 $co (5A.5, TBDY) = 0.002$
 Final value of cu : $cu^* = shear_factor * Max(cu, cc) = 0.00773686$
 The Shear_factor is considered equal to 1 (pure moment strength)
 From (5.4b), TBDY: $cu = 0.00773686$
 $we (5.4c) = 0.01121936$
 $ase ((5.4d), TBDY) = 0.15672608$
 $bo = 240.00$

ho = 340.00
bi2 = 346400.00
psh,min = Min(psh,x , psh,y) = 0.00261799

psh,x (5.4d) = 0.00349066
Ash = Astir*ns = 78.53982
No stirups, ns = 2.00
bk = 300.00

psh,y (5.4d) = 0.00261799
Ash = Astir*ns = 78.53982
No stirups, ns = 2.00
bk = 400.00

s = 150.00
fywe = 656.25
fce = 24.00
From ((5.A5), TBDY), TBDY: cc = 0.00290026
c = confinement factor = 1.09003
y1 = 0.0025
sh1 = 0.008
ft1 = 787.50
fy1 = 656.25
su1 = 0.032

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00

lo/lou,min = lb/d = 1.00

su1 = 0.4*esu1_nominal ((5.5), TBDY) = 0.032

From table 5A.1, TBDY: esu1_nominal = 0.08,

For calculation of esu1_nominal and y1, sh1,ft1,fy1, it is considered
characteristic value fsy1 = fs/1.2, from table 5.1, TBDY.

y1, sh1,ft1,fy1, are also multiplied by Min(1,1.25*(lb/d)^ 2/3), from 10.3.5, ASCE 41-17.

with fs1 = fs = 656.25

with Es1 = Es = 200000.00

y2 = 0.0025
sh2 = 0.008
ft2 = 787.50
fy2 = 656.25
su2 = 0.032

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00

lo/lou,min = lb/lb,min = 1.00

su2 = 0.4*esu2_nominal ((5.5), TBDY) = 0.032

From table 5A.1, TBDY: esu2_nominal = 0.08,

For calculation of esu2_nominal and y2, sh2,ft2,fy2, it is considered
characteristic value fsy2 = fs/1.2, from table 5.1, TBDY.

y1, sh1,ft1,fy1, are also multiplied by Min(1,1.25*(lb/d)^ 2/3), from 10.3.5, ASCE 41-17.

with fs2 = fs = 656.25

with Es2 = Es = 200000.00

yv = 0.0025
shv = 0.008
ftv = 787.50
fyv = 656.25
suv = 0.032

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00

lo/lou,min = lb/d = 1.00

suv = 0.4*esuv_nominal ((5.5), TBDY) = 0.032

From table 5A.1, TBDY: esuv_nominal = 0.08,

considering characteristic value fsyv = fsv/1.2, from table 5.1, TBDY

For calculation of esuv_nominal and yv, shv,ftv,fyv, it is considered
characteristic value fsyv = fsv/1.2, from table 5.1, TBDY.

y1, sh1,ft1,fy1, are also multiplied by Min(1,1.25*(lb/d)^ 2/3), from 10.3.5, ASCE 41-17.

with fsv = fs = 656.25

with $E_{sv} = E_s = 200000.00$

$$1 = A_{sl,ten}/(b*d)*(f_{s1}/f_c) = 0.13484761$$

$$2 = A_{sl,com}/(b*d)*(f_{s2}/f_c) = 0.13484761$$

$$v = A_{sl,mid}/(b*d)*(f_{sv}/f_c) = 0.13484761$$

and confined core properties:

$$b = 340.00$$

$$d = 228.00$$

$$d' = 12.00$$

$$f_{cc} (5A.2, TBDY) = 26.16063$$

$$c_c (5A.5, TBDY) = 0.00290026$$

$$c = \text{confinement factor} = 1.09003$$

$$1 = A_{sl,ten}/(b*d)*(f_{s1}/f_c) = 0.17951849$$

$$2 = A_{sl,com}/(b*d)*(f_{s2}/f_c) = 0.17951849$$

$$v = A_{sl,mid}/(b*d)*(f_{sv}/f_c) = 0.17951849$$

Case/Assumption: Unconfined full section - Steel rupture

' does not satisfy Eq. (4.3)

--->

$v < v_{s,c}$ - RHS eq.(4.5) is satisfied

--->

$$s_u (4.9) = 0.20560388$$

$$\mu_u = M_{Rc} (4.14) = 1.2764E+008$$

$$u = s_u (4.1) = 0.00015613$$

Calculation of ratio l_b/d

Adequate Lap Length: $l_b/d \geq 1$

Calculation of μ_{u2} -

Calculation of ultimate curvature μ_u according to 4.1, Biskinis/Fardis 2013:

$$u = 0.00015613$$

$$\mu_u = 1.2764E+008$$

with full section properties:

$$b = 400.00$$

$$d = 258.00$$

$$d' = 42.00$$

$$v = 8.5224858E-005$$

$$N = 211.0849$$

$$f_c = 24.00$$

$$c_c (5A.5, TBDY) = 0.002$$

$$\text{Final value of } c_u: c_u^* = \text{shear_factor} * \text{Max}(c_u, c_c) = 0.00773686$$

The Shear_factor is considered equal to 1 (pure moment strength)

$$\text{From (5.4b), TBDY: } c_u = 0.00773686$$

$$w_e (5.4c) = 0.01121936$$

$$a_{se} ((5.4d), TBDY) = 0.15672608$$

$$b_o = 240.00$$

$$h_o = 340.00$$

$$b_{i2} = 346400.00$$

$$p_{sh,min} = \text{Min}(p_{sh,x}, p_{sh,y}) = 0.00261799$$

$$p_{sh,x} (5.4d) = 0.00349066$$

$$A_{sh} = A_{stir}*n_s = 78.53982$$

$$\text{No stirups, } n_s = 2.00$$

$$b_k = 300.00$$

$$p_{sh,y} (5.4d) = 0.00261799$$

$$A_{sh} = A_{stir}*n_s = 78.53982$$

$$\text{No stirups, } n_s = 2.00$$

$$b_k = 400.00$$

$$s = 150.00$$

$$fy_{we} = 656.25$$

$$f_{ce} = 24.00$$

From (5A.5), TBDY, TBDY: $cc = 0.00290026$

$$c = \text{confinement factor} = 1.09003$$

$$y_1 = 0.0025$$

$$sh_1 = 0.008$$

$$ft_1 = 787.50$$

$$fy_1 = 656.25$$

$$su_1 = 0.032$$

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00

$$lo/lou, \min = lb/ld = 1.00$$

$$su_1 = 0.4 * esu_{1_nominal} ((5.5), TBDY) = 0.032$$

From table 5A.1, TBDY: $esu_{1_nominal} = 0.08$,

For calculation of $esu_{1_nominal}$ and y_1, sh_1, ft_1, fy_1 , it is considered
characteristic value $fsy_1 = fs_1/1.2$, from table 5.1, TBDY.

y_1, sh_1, ft_1, fy_1 , are also multiplied by $\text{Min}(1, 1.25 * (lb/ld)^{2/3})$, from 10.3.5, ASCE 41-17.

$$\text{with } fs_1 = fs = 656.25$$

$$\text{with } Es_1 = Es = 200000.00$$

$$y_2 = 0.0025$$

$$sh_2 = 0.008$$

$$ft_2 = 787.50$$

$$fy_2 = 656.25$$

$$su_2 = 0.032$$

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00

$$lo/lou, \min = lb/lb, \min = 1.00$$

$$su_2 = 0.4 * esu_{2_nominal} ((5.5), TBDY) = 0.032$$

From table 5A.1, TBDY: $esu_{2_nominal} = 0.08$,

For calculation of $esu_{2_nominal}$ and y_2, sh_2, ft_2, fy_2 , it is considered
characteristic value $fsy_2 = fs_2/1.2$, from table 5.1, TBDY.

y_1, sh_1, ft_1, fy_1 , are also multiplied by $\text{Min}(1, 1.25 * (lb/ld)^{2/3})$, from 10.3.5, ASCE 41-17.

$$\text{with } fs_2 = fs = 656.25$$

$$\text{with } Es_2 = Es = 200000.00$$

$$y_v = 0.0025$$

$$sh_v = 0.008$$

$$ft_v = 787.50$$

$$fy_v = 656.25$$

$$su_v = 0.032$$

using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00

$$lo/lou, \min = lb/ld = 1.00$$

$$su_v = 0.4 * esu_{v_nominal} ((5.5), TBDY) = 0.032$$

From table 5A.1, TBDY: $esu_{v_nominal} = 0.08$,

considering characteristic value $fsy_v = fsv/1.2$, from table 5.1, TBDY
For calculation of $esu_{v_nominal}$ and y_v, sh_v, ft_v, fy_v , it is considered
characteristic value $fsy_v = fsv/1.2$, from table 5.1, TBDY.

y_1, sh_1, ft_1, fy_1 , are also multiplied by $\text{Min}(1, 1.25 * (lb/ld)^{2/3})$, from 10.3.5, ASCE 41-17.

$$\text{with } fsv = fs = 656.25$$

$$\text{with } Es_v = Es = 200000.00$$

$$1 = Asl, \text{ten} / (b * d) * (fs_1 / f_c) = 0.13484761$$

$$2 = Asl, \text{com} / (b * d) * (fs_2 / f_c) = 0.13484761$$

$$v = Asl, \text{mid} / (b * d) * (fsv / f_c) = 0.13484761$$

and confined core properties:

$$b = 340.00$$

$$d = 228.00$$

$$d' = 12.00$$

$$fcc (5A.2, TBDY) = 26.16063$$

$$cc (5A.5, TBDY) = 0.00290026$$

$$c = \text{confinement factor} = 1.09003$$

$$1 = Asl, \text{ten} / (b * d) * (fs_1 / f_c) = 0.17951849$$

$$2 = Asl, \text{com} / (b * d) * (fs_2 / f_c) = 0.17951849$$

$$v = Asl, \text{mid} / (b * d) * (fsv / f_c) = 0.17951849$$

Case/Assumption: Unconfinedsd full section - Steel rupture

' does not satisfy Eq. (4.3)

---->

$v < v_{s,c}$ - RHS eq.(4.5) is satisfied

---->

μ_u (4.9) = 0.20560388

$\mu_u = M/R_c$ (4.14) = 1.2764E+008

$u = \mu_u$ (4.1) = 0.00015613

Calculation of ratio l_b/d

Adequate Lap Length: $l_b/d \geq 1$

Calculation of Shear Strength $V_r = \text{Min}(V_{r1}, V_{r2}) = 174208.493$

Calculation of Shear Strength at edge 1, $V_{r1} = 174208.493$

$V_{r1} = V_n$ ((22.5.1.1), ACI 318-14)

NOTE: In expression (22.5.1.1) ' V_w ' is replaced by ' $V_w + f \cdot V_f$ '
where V_f is the contribution of FRPs (11.3), ACI 440).

From Table (22.5.5.1), ACI 318-14: $V_c = 75248.325$

= 1 (normal-weight concrete)

$f_c' = 24.00$, but $f_c'^{0.5} \leq 8.3$ MPa (22.5.3.1, ACI 318-14)

$\rho_w = A_s/(b_w \cdot d) = 0.00628319$

A_s (tension reinf.) = 603.1858

$b_w = 400.00$

$d = 240.00$

$V_u \cdot d / \mu_u < 1 = 0.00$

$\mu_u = 7.6252677E-012$

$V_u = 3.6870970E-015$

From (11.5.4.8), ACI 318-14: $V_s = 98960.169$

$A_v = 157079.633$

$f_y = 525.00$

$s = 150.00$

V_s has been multiplied by $2(1-s/d)$ ($s > d/2$, according to ASCE 41-17,10.3.4)

$2(1-s/d) = 0.75$

V_f ((11-3)-(11.4), ACI 440) = 0.00

From (11-11), ACI 440: $V_s + V_f \leq 312423.44$

Calculation of Shear Strength at edge 2, $V_{r2} = 174208.493$

$V_{r2} = V_n$ ((22.5.1.1), ACI 318-14)

NOTE: In expression (22.5.1.1) ' V_w ' is replaced by ' $V_w + f \cdot V_f$ '
where V_f is the contribution of FRPs (11.3), ACI 440).

From Table (22.5.5.1), ACI 318-14: $V_c = 75248.325$

= 1 (normal-weight concrete)

$f_c' = 24.00$, but $f_c'^{0.5} \leq 8.3$ MPa (22.5.3.1, ACI 318-14)

$\rho_w = A_s/(b_w \cdot d) = 0.00628319$

A_s (tension reinf.) = 603.1858

$b_w = 400.00$

$d = 240.00$

$V_u \cdot d / \mu_u < 1 = 0.00$

$\mu_u = 8.0393416E-013$

$V_u = 3.6870970E-015$

From (11.5.4.8), ACI 318-14: $V_s = 98960.169$

$A_v = 157079.633$

$f_y = 525.00$

$s = 150.00$

V_s has been multiplied by $2(1-s/d)$ ($s > d/2$, according to ASCE 41-17,10.3.4)

$2(1-s/d) = 0.75$

V_f ((11-3)-(11.4), ACI 440) = 0.00

From (11-11), ACI 440: $V_s + V_f \leq 312423.44$

End Of Calculation of Shear Capacity ratio for element: beam B1 of floor 1
At local axis: 2

Start Of Calculation of Chord Rotation Capacity for element: beam B1 of floor 1
At local axis: 3
Integration Section: (b)
Section Type: rcars

Constant Properties

Knowledge Factor, $\gamma = 1.00$
Chord Rotation is generally considered as Deformation-Controlled Action according to Table C7-1, ASCE 41-17.
Mean strengths are used for Deformation-Controlled Actions according to 7.5.1.3, ASCE 41-17
Consequently:
Existing material of Primary Member: Concrete Strength, $f_c = f_{cm} = 24.00$
Existing material of Primary Member: Steel Strength, $f_s = f_{sm} = 525.00$
Concrete Elasticity, $E_c = 23025.204$
Steel Elasticity, $E_s = 200000.00$
Section Height, $H = 400.00$
Section Width, $W = 300.00$
Cover Thickness, $c = 25.00$
Element Length, $L = 1850.00$
Primary Member
Smooth Bars
Ductile Steel
With Detailing for Earthquake Resistance (including stirrups closed at 135°)
Longitudinal Bars With Ends Lapped Starting at the End Sections
Adequate Lap Length ($l_b/d >= 1$)
No FRP Wrapping

Stepwise Properties

Bending Moment, $M = 5.4436895E-011$
Shear Force, $V_2 = -2.3583230E-014$
Shear Force, $V_3 = 7492.435$
Axial Force, $F = -490.6724$
Longitudinal Reinforcement Area Distribution (in 2 divisions)
-Tension: $A_{st} = 615.7522$
-Compression: $A_{sc} = 911.0619$
Longitudinal Reinforcement Area Distribution (in 3 divisions)
-Tension: $A_{st,ten} = 508.938$
-Compression: $A_{st,com} = 508.938$
-Middle: $A_{st,mid} = 508.938$
Mean Diameter of Tension Reinforcement, $D_bL = 14.66667$

Existing component: From table 7-7, ASCE 41_17: Final chord rotation Capacity $u_{,R} = \gamma \cdot u = 0.02404297$
 $u = \gamma \cdot u + p = 0.02404297$

- Calculation of γ -

$\gamma = (M_y \cdot L_s / 3) / E_{eff} = 0.00404297$ ((4.29), Biskinis Phd))
 $M_y = 8.1517E+007$
 $L_s = M/V$ (with $L_s > 0.1 \cdot L$ and $L_s < 2 \cdot L$) = 925.00
From table 10.5, ASCE 41_17: $E_{eff} = 0.3 \cdot E_c \cdot I_g = 6.2168E+012$

Calculation of Yielding Moment M_y

Calculation of ρ_y and M_y according to Annex 7 -

$y = \text{Min}(y_{\text{ten}}, y_{\text{com}})$
 $y_{\text{ten}} = 1.4111379\text{E-}005$
with $f_y = 525.00$
 $d = 258.00$
 $y = 0.27899188$
 $A = 0.01480377$
 $B = 0.00861063$
with $p_t = 0.00493157$
 $p_c = 0.00493157$
 $p_v = 0.00493157$
 $N = 490.6724$
 $b = 400.00$
 $\rho = 0.1627907$
 $y_{\text{comp}} = 2.6071644\text{E-}005$
with $f_c = 24.00$
 $E_c = 23025.204$
 $y = 0.27892802$
 $A = 0.01478204$
 $B = 0.00860158$
with $E_s = 200000.00$

Calculation of ratio l_b/d

Adequate Lap Length: $l_b/d \geq 1$

- Calculation of ρ_p -

From table 10-7: $\rho_p = 0.02$

with:

- Condition i occurred

Beam controlled by flexure: $V_p/V_o \leq 1$

shear control ratio $V_p/V_o = 0.79211753$

- Transverse Reinforcement: NC

- Stirrup Spacing $> d/3$

- Low ductility demand, $\rho_p / \rho_y < 2$ (table 10-6, ASCE 41-17)

$= 5.4314820\text{E-}022$

- Stirrup Spacing $> d/2$

$d = 258.00$

$s = 150.00$

- Strength provided by hoops $V_s < 3/4$ *design Shear

$V_s = 131946.891$, already given in calculation of shear control ratio

design Shear = $2.3583230\text{E-}014$

- ($\rho_c - \rho_p$)/ $\rho_{\text{bal}} = -0.16244618$

$= A_{s1}/(b_w*d) = 0.00596659$

Tension Reinf Area: $A_{s1} = 615.7522$

$\rho_c = A_{s2}/(b_w*d) = 0.00882812$

Compression Reinf Area: $A_{s2} = 911.0619$

From (B-1), ACI 318-11: $\rho_{\text{bal}} = 0.01761524$

$f_c = 24.00$

$f_y = 525.00$

From 10.2.7.3, ACI 318-11: $\rho_1 = 0.85$

From fig R10.3.3, ACI 318-11 (Ence 454, too): $87000/(87000 + f_y) = c_b/d_t = 0.003/(0.003 + \rho_y) = 0.53333333$

$\rho_y = 0.002625$

- $V/(b_w*d*f_c^{0.5}) = 5.6174758\text{E-}019$, NOTE: units in lb & in

$b_w = 400.00$

End Of Calculation of Chord Rotation Capacity for element: beam B1 of floor 1

At local axis: 3

Integration Section: (b)
