

Detailed Member Calculations

Units: N&mm

Regulation: ASCE 41-17

Calculation No. 1

column C1, Floor 1


Limit State: Immediate Occupancy (data interpolation between analysis steps 1 and 2)

Analysis: Uniform +X

Check: Shear capacity V_{Rd}

Edge: Start

Local Axis: (2)



Start Of Calculation of Shear Capacity for element: column JCC1 of floor 1

At local axis: 2

Integration Section: (a)

Section Type: rcjcs

Constant Properties

Knowledge Factor, $\gamma = 1.00$

Member Shear Force is generally considered as Force-Controlled Action according to Table C7-1, ASCE 41-17.

Lower-bound strengths are used for Force-Controlled Actions according to 7.5.1.3, ASCE 41-17

Consequently:

Jacket

New material of Primary Member: Concrete Strength, $f_c = f_{c_lower_bound} = 25.00$

New material of Primary Member: Steel Strength, $f_s = f_{s_lower_bound} = 500.00$

Concrete Elasticity, $E_c = 26999.444$

Steel Elasticity, $E_s = 200000.00$

Existing Column

New material of Primary Member: Concrete Strength, $f_c = f_{c_lower_bound} = 25.00$

New material of Primary Member: Steel Strength, $f_s = f_{s_lower_bound} = 500.00$

Concrete Elasticity, $E_c = 26999.444$

Steel Elasticity, $E_s = 200000.00$

#####

Note: Especially for the calculation of μ_y for displacement ductility demand, the expected (mean value) strengths are used (7.5.1.3, ASCE 41-17) because bending is considered as Deformation-Controlled Action (Table C7-1, ASCE 41-17).

Jacket

New material: Concrete Strength, $f_c = f_{cm} = 33.00$

New material: Steel Strength, $f_s = f_{sm} = 555.56$

Existing Column

New material: Concrete Strength, $f_c = f_{cm} = 33.00$

New material: Steel Strength, $f_s = f_{sm} = 555.56$

#####

External Diameter, $D = 500.00$

Internal Diameter, $D = 300.00$

Cover Thickness, $c = 25.00$

Element Length, $L = 3000.00$

Primary Member

Smooth Bars

Ductile Steel

With Detailing for Earthquake Resistance (including stirrups closed at 135°)

Longitudinal Bars With Ends Lapped Starting at the End Sections

Adequate Lap Length ($l_o/l_{ou, min} = l_b/l_d \geq 1$)

No FRP Wrapping

Stepwise Properties

EDGE -A-

Bending Moment, $M_a = -2.2535E+007$

Shear Force, $V_a = -7509.70$

EDGE -B-

Bending Moment, $M_b = 0.03802603$

Shear Force, $V_b = 7509.70$

BOTH EDGES

Axial Force, $F = -7386.21$

Longitudinal Reinforcement Area Distribution (in 2 divisions)

-Tension: $A_{sl} = 1272.345$

-Compression: $A_{slc} = 1781.283$

Longitudinal Reinforcement Area Distribution (in 3 divisions)

-Tension: $A_{sl, ten} = 1017.876$

-Compression: $A_{sl, com} = 1017.876$

-Middle: $A_{sl, mid} = 1017.876$

Mean Diameter of Tension Reinforcement, $D_{bL, ten} = 18.00$

New component: From table 7-7, ASCE 41_17: Final Shear Capacity $V_R = 1.0 \cdot V_n = 345302.777$

V_n ((10.3), ASCE 41-17) = $k_n l \cdot V_{CoI} = 345302.777$

$V_{CoI} = 345302.777$

$k_n = 1.00$

displacement_ductility_demand = 0.01717345

NOTE: In expression (10-3) ' $V_s = A_v \cdot f_y \cdot d / s$ ' is replaced by ' $V_s + f \cdot V_f$ ' where V_f is the contribution of FRPs (11.3), ACI 440).

= 1 (normal-weight concrete)

Mean concrete strength: $f_c' = (f_c'_{jacket} \cdot Area_{jacket} + f_c'_{core} \cdot Area_{core}) / Area_{section} = 25.00$, but $f_c'^{0.5} \leq 8.3$ MPa (22.5.3.1, ACI 318-14)

$M / V_d = 4.00$

$\mu_u = 2.2535E+007$

$V_u = 7509.70$
 $d = 0.8 \cdot D = 400.00$
 $N_u = 7386.21$
 $A_g = 196349.541$
 From (11.5.4.8), ACI 318-14: $V_s = V_{s1} + V_{s2} = 246740.11$
 $V_{s1} = 246740.11$ is calculated for jacket, with:
 $A_v = \sqrt{2} \cdot A_{stirrup} = 123370.055$
 $f_y = 500.00$
 $s = 100.00$
 V_{s1} is multiplied by $Col1 = 1.00$
 $s/d = 0.25$
 $V_{s2} = 0.00$ is calculated for core, with:
 $A_v = \sqrt{2} \cdot A_{stirrup} = 78956.835$
 $f_y = 500.00$
 $s = 250.00$
 V_{s2} is multiplied by $Col2 = 0.00$
 $s/d = 1.04167$
 V_f ((11-3)-(11.4), ACI 440) = 0.00
 From (11-11), ACI 440: $V_s + V_f \leq 417394.406$
 $b_w \cdot d = \frac{1}{4} \cdot d \cdot d = 125663.706$

displacement ductility demand is calculated as $\frac{1}{y}$

- Calculation of $\frac{1}{y}$ for END A -
for rotation axis 3 and integ. section (a)

From analysis, chord rotation = 0.00025064
 $y = (M_y \cdot L_s / 3) / E_{eff} = 0.01459454$ ((4.29), Biskinis Phd)
 $M_y = 3.6259E+008$
 $L_s = M/V$ (with $L_s > 0.1 \cdot L$ and $L_s < 2 \cdot L$) = 3000.736
 From table 10.5, ASCE 41_17: $E_{eff} = factor \cdot E_c \cdot I_g = 2.4850E+013$
 $factor = 0.30$
 $A_g = 196349.541$
 Mean concrete strength: $f_c' = (f_c'_{jacket} \cdot Area_{jacket} + f_c'_{core} \cdot Area_{core}) / Area_{section} = 33.00$
 $N = 7386.21$
 $E_c \cdot I_g = E_c \cdot I_{g,jacket} + E_c \cdot I_{g,core} = 8.2833E+013$

Calculation of Yielding Moment M_y

Calculation of $\frac{1}{y}$ and M_y according to (7) - (8) in Biskinis and Fardis

$M_y = \min(M_{y,ten}, M_{y,com}) = 3.6259E+008$
 y ((10a) or (10b)) = 1.0622306E-005
 $M_{y,ten}$ (8a) = 3.6259E+008
 $\frac{1}{y}$ (7a) = 65.43628
 error of function (7a) = 0.00293092
 $M_{y,com}$ (8b) = 7.5621E+008
 $\frac{1}{y}$ (7b) = 64.56803
 error of function (7b) = -0.00721907
 with $e_y = 0.0027778$
 $e_{co} = 0.002$
 $a_{pl} = 0.35$ ((9a) in Biskinis and Fardis for no FRP Wrap)
 $d_1 = 44.00$
 $R = 250.00$
 $v = 0.00113993$
 $N = 7386.21$
 $A_c = 196349.541$
 $= 0.26182028$
 with $f_c = 33.00$


Calculation of ratio I_b/I_d

Adequate Lap Length: $l_b/l_d \geq 1$

End Of Calculation of Shear Capacity for element: column JCC1 of floor 1
At local axis: 2
Integration Section: (a)

Calculation No. 2

column C1, Floor 1
Limit State: Immediate Occupancy (data interpolation between analysis steps 1 and 2)
Analysis: Uniform +X
Check: Chord rotation capacity (ϕ)
Edge: Start
Local Axis: (2)



Start Of Calculation of Shear Capacity ratio for element: column JCC1 of floor 1
At Shear local axis: 3
(Bending local axis: 2)
Section Type: rcjcs

Constant Properties

Knowledge Factor, $\gamma = 1.00$
Mean strength values are used for both shear and moment calculations.
Consequently:
Jacket
New material of Primary Member: Concrete Strength, $f_c = f_{cm} = 33.00$
New material of Primary Member: Steel Strength, $f_s = f_{sm} = 555.56$
Concrete Elasticity, $E_c = 26999.444$
Steel Elasticity, $E_s = 200000.00$
Existing Column
New material of Primary Member: Concrete Strength, $f_c = f_{cm} = 33.00$
New material of Primary Member: Steel Strength, $f_s = f_{sm} = 555.56$
Concrete Elasticity, $E_c = 26999.444$
Steel Elasticity, $E_s = 200000.00$

Note: Especially for the calculation of moment strengths,

the above steel re-bar strengths are multiplied by 1.25 according to R18.6.5, ACI 318-14

Jacket

New material: Steel Strength, $f_s = 1.25 \cdot f_{sm} = 694.45$

Existing Column

New material: Steel Strength, $f_s = 1.25 \cdot f_{sm} = 694.45$

#####

External Diameter, $D = 500.00$

Internal Diameter, $D = 300.00$

Cover Thickness, $c = 25.00$

Mean Confinement Factor overall section = 1.30349

Element Length, $L = 3000.00$

Primary Member

Smooth Bars

Ductile Steel

With Detailing for Earthquake Resistance (including stirrups closed at 135°)

Longitudinal Bars With Ends Lapped Starting at the End Sections

Adequate Lap Length ($l_o/l_{ou, \min} > 1$)

No FRP Wrapping

Stepwise Properties

At local axis: 3

EDGE -A-

Shear Force, $V_a = 4.4860917E-031$

EDGE -B-

Shear Force, $V_b = -4.4860917E-031$

BOTH EDGES

Axial Force, $F = -7389.214$

Longitudinal Reinforcement Area Distribution (in 2 divisions)

-Tension: $A_{st} = 0.00$

-Compression: $A_{sc} = 3053.628$

Longitudinal Reinforcement Area Distribution (in 3 divisions)

-Tension: $A_{st, \text{ten}} = 1017.876$

-Compression: $A_{sl, \text{com}} = 1017.876$

-Middle: $A_{sl, \text{mid}} = 1017.876$

Calculation of Shear Capacity ratio, $V_e/V_r = 0.54503121$

Member Controlled by Flexure ($V_e/V_r < 1$)

Calculation of Shear Demand from fig. R18.6.5, ACI 318-14 $V_e = (M_{pr1} + M_{pr2})/l_n = 272744.406$

with

$M_{pr1} = \text{Max}(Mu_{1+}, Mu_{1-}) = 4.0912E+008$

$Mu_{1+} = 4.0912E+008$, is the ultimate moment strength at the edge 1 of the member in the actual moment direction which is defined for the static loading combination

$Mu_{1-} = 4.0912E+008$, is the ultimate moment strength at the edge 1 of the member in the opposite moment direction which is defined for the static loading combination

$M_{pr2} = \text{Max}(Mu_{2+}, Mu_{2-}) = 4.0912E+008$

$Mu_{2+} = 4.0912E+008$, is the ultimate moment strength at the edge 2 of the member in the actual moment direction which is defined for the the static loading combination

$Mu_{2-} = 4.0912E+008$, is the ultimate moment strength at the edge 2 of the member in the opposite moment direction which is defined for the the static loading combination

Calculation of Mu_{1+}

Calculation of ultimate Moment Strength ((3.67), Biskinis Phd), Mu

$Mu = 4.0912E+008$

= 0.97738438

' = 0.86668818

error of function (3.68), Biskinis Phd = 94694.946

From 5A.2, TBDY: $f_{cc} = f_c^* \quad c = 43.01531$

conf. factor $c = 1.30349$

$f_c = 33.00$

From 10.3.5, ASCE 41-17, Final value of f_y : $f_y \cdot \text{Min}(1, 1.25 \cdot (l_b/d)^{2/3}) = 694.45$

$l_b/d = 1.00$

$d_1 = 44.00$

$R = 250.00$

$v = 0.0011401$

$N = 7389.214$

$A_c = 196349.541$

$= \cdot \text{Min}(1, 1.25 \cdot (l_b/d)^{2/3}) = 0.26182028$

Calculation of ratio l_b/d

Adequate Lap Length: $l_b/d \geq 1$

Calculation of μ_{1-}

Calculation of ultimate Moment Strength ((3.67), Biskinis Phd), μ

$\mu = 4.0912E+008$

$= 0.97738438$

$' = 0.86668818$

error of function (3.68), Biskinis Phd = 94694.946

From 5A.2, TBDY: $f_{cc} = f_c \cdot c = 43.01531$

conf. factor $c = 1.30349$

$f_c = 33.00$

From 10.3.5, ASCE 41-17, Final value of f_y : $f_y \cdot \text{Min}(1, 1.25 \cdot (l_b/d)^{2/3}) = 694.45$

$l_b/d = 1.00$

$d_1 = 44.00$

$R = 250.00$

$v = 0.0011401$

$N = 7389.214$

$A_c = 196349.541$

$= \cdot \text{Min}(1, 1.25 \cdot (l_b/d)^{2/3}) = 0.26182028$

Calculation of ratio l_b/d

Adequate Lap Length: $l_b/d \geq 1$

Calculation of μ_{2+}

Calculation of ultimate Moment Strength ((3.67), Biskinis Phd), μ

$\mu = 4.0912E+008$

$= 0.97738438$

$' = 0.86668818$

error of function (3.68), Biskinis Phd = 94694.946

From 5A.2, TBDY: $f_{cc} = f_c \cdot c = 43.01531$

conf. factor $c = 1.30349$

$f_c = 33.00$

From 10.3.5, ASCE 41-17, Final value of f_y : $f_y \cdot \text{Min}(1, 1.25 \cdot (l_b/d)^{2/3}) = 694.45$

$l_b/d = 1.00$

$d_1 = 44.00$

$R = 250.00$

$v = 0.0011401$

$N = 7389.214$

$A_c = 196349.541$

$$= \text{Min}(1, 1.25 \cdot (l_b/d)^{2/3}) = 0.26182028$$

Calculation of ratio l_b/d

Adequate Lap Length: $l_b/d \geq 1$

Calculation of μ_2

Calculation of ultimate Moment Strength ((3.67), Biskinis Phd), μ
 $\mu = 4.0912E+008$

$$= 0.97738438$$

$$' = 0.86668818$$

error of function (3.68), Biskinis Phd = 94694.946

From 5A.2, TBDY: $f_{cc} = f_c \cdot c = 43.01531$

conf. factor $c = 1.30349$

$f_c = 33.00$

From 10.3.5, ASCE 41-17, Final value of f_y : $f_y \cdot \text{Min}(1, 1.25 \cdot (l_b/d)^{2/3}) = 694.45$

$$l_b/d = 1.00$$

$$d_1 = 44.00$$

$$R = 250.00$$

$$v = 0.0011401$$

$$N = 7389.214$$

$$A_c = 196349.541$$

$$= \text{Min}(1, 1.25 \cdot (l_b/d)^{2/3}) = 0.26182028$$

Calculation of ratio l_b/d

Adequate Lap Length: $l_b/d \geq 1$

Calculation of Shear Strength $V_r = \text{Min}(V_{r1}, V_{r2}) = 500419.792$

Calculation of Shear Strength at edge 1, $V_{r1} = 500419.792$

$V_{r1} = V_{Col}$ ((10.3), ASCE 41-17) = $k_{nl} \cdot V_{Col0}$

$$V_{Col0} = 500419.792$$

$k_{nl} = 1$ (zero step-static loading)

NOTE: In expression (10-3) ' $V_s = A_v \cdot f_y \cdot d/s$ ' is replaced by ' $V_s + f \cdot V_f$ '
where V_f is the contribution of FRPs (11.3), ACI 440).

$= 1$ (normal-weight concrete)

Mean concrete strength: $f_c' = (f_c'_{\text{jacket}} \cdot \text{Area}_{\text{jacket}} + f_c'_{\text{core}} \cdot \text{Area}_{\text{core}}) / \text{Area}_{\text{section}} = 33.00$, but $f_c'^{0.5} \leq 8.3$
MPa (22.5.3.1, ACI 318-14)

$$M/d = 2.00$$

$$\mu = 2.5382294E-011$$

$$V_u = 4.4860917E-031$$

$$d = 0.8 \cdot D = 400.00$$

$$N_u = 7389.214$$

$$A_g = 196349.541$$

From (11.5.4.8), ACI 318-14: $V_s = V_{s1} + V_{s2} = 274157.871$

$V_{s1} = 274157.871$ is calculated for jacket, with:

$$A_v = \sqrt{2} \cdot A_{\text{stirrup}} = 123370.055$$

$$f_y = 555.56$$

$$s = 100.00$$

V_{s1} is multiplied by $\text{Col1} = 1.00$

$$s/d = 0.25$$

$V_{s2} = 0.00$ is calculated for core, with:

$$A_v = \sqrt{2} \cdot A_{\text{stirrup}} = 78956.835$$

$f_y = 555.56$

$s = 250.00$

Vs2 is multiplied by Col2 = 0.00

$s/d = 1.04167$

Vf ((11-3)-(11.4), ACI 440) = 0.00

From (11-11), ACI 440: $V_s + V_f \leq 479549.663$

$b_w*d = *d*d/4 = 125663.706$

Calculation of Shear Strength at edge 2, $V_{r2} = 500419.792$

$V_{r2} = V_{Col} ((10.3), ASCE 41-17) = knl*V_{Col0}$

$V_{Col0} = 500419.792$

$knl = 1$ (zero step-static loading)

NOTE: In expression (10-3) ' $V_s = A_v*f_y*d/s$ ' is replaced by ' $V_s + f*V_f$ ' where V_f is the contribution of FRPs (11.3), ACI 440).

= 1 (normal-weight concrete)

Mean concrete strength: $f_c' = (f_c'_{jacket}*Area_{jacket} + f_c'_{core}*Area_{core})/Area_{section} = 33.00$, but $f_c'^{0.5} \leq 8.3$ MPa (22.5.3.1, ACI 318-14)

$M/Vd = 2.00$

$\mu_u = 2.5382294E-011$

$\nu_u = 4.4860917E-031$

$d = 0.8*D = 400.00$

$N_u = 7389.214$

$A_g = 196349.541$

From (11.5.4.8), ACI 318-14: $V_s = V_{s1} + V_{s2} = 274157.871$

$V_{s1} = 274157.871$ is calculated for jacket, with:

$A_v = /2*A_{stirrup} = 123370.055$

$f_y = 555.56$

$s = 100.00$

V_{s1} is multiplied by Col1 = 1.00

$s/d = 0.25$

$V_{s2} = 0.00$ is calculated for core, with:

$A_v = /2*A_{stirrup} = 78956.835$

$f_y = 555.56$

$s = 250.00$

V_{s2} is multiplied by Col2 = 0.00

$s/d = 1.04167$

Vf ((11-3)-(11.4), ACI 440) = 0.00

From (11-11), ACI 440: $V_s + V_f \leq 479549.663$

$b_w*d = *d*d/4 = 125663.706$

End Of Calculation of Shear Capacity ratio for element: column JCC1 of floor 1

At local axis: 3

Start Of Calculation of Shear Capacity ratio for element: column JCC1 of floor 1

At Shear local axis: 2

(Bending local axis: 3)

Section Type: rcjcs

Constant Properties

Knowledge Factor, = 1.00

Mean strength values are used for both shear and moment calculations.

Consequently:

Jacket

New material of Primary Member: Concrete Strength, $f_c = f_{cm} = 33.00$

New material of Primary Member: Steel Strength, $f_s = f_{sm} = 555.56$

Concrete Elasticity, $E_c = 26999.444$

Steel Elasticity, $E_s = 200000.00$

Existing Column

New material of Primary Member: Concrete Strength, $f_c = f_{cm} = 33.00$

New material of Primary Member: Steel Strength, $f_s = f_{sm} = 555.56$
Concrete Elasticity, $E_c = 26999.444$
Steel Elasticity, $E_s = 200000.00$

Note: Especially for the calculation of moment strengths,
the above steel re-bar strengths are multiplied by 1.25 according to R18.6.5, ACI 318-14
Jacket
New material: Steel Strength, $f_s = 1.25 \cdot f_{sm} = 694.45$
Existing Column
New material: Steel Strength, $f_s = 1.25 \cdot f_{sm} = 694.45$

External Diameter, $D = 500.00$
Internal Diameter, $D = 300.00$
Cover Thickness, $c = 25.00$
Mean Confinement Factor overall section = 1.30349
Element Length, $L = 3000.00$
Primary Member
Smooth Bars
Ductile Steel
With Detailing for Earthquake Resistance (including stirrups closed at 135°)
Longitudinal Bars With Ends Lapped Starting at the End Sections
Adequate Lap Length ($l_o/l_{o,min} >= 1$)
No FRP Wrapping

Stepwise Properties

At local axis: 2
EDGE -A-
Shear Force, $V_a = -2.7468482E-047$
EDGE -B-
Shear Force, $V_b = 2.7468482E-047$
BOTH EDGES
Axial Force, $F = -7389.214$
Longitudinal Reinforcement Area Distribution (in 2 divisions)
-Tension: $As_t = 0.00$
-Compression: $As_c = 3053.628$
Longitudinal Reinforcement Area Distribution (in 3 divisions)
-Tension: $As_{t,ten} = 1017.876$
-Compression: $As_{c,com} = 1017.876$
-Middle: $As_{c,mid} = 1017.876$

Calculation of Shear Capacity ratio , $V_e/V_r = 0.54503121$
Member Controlled by Flexure ($V_e/V_r < 1$)
Calculation of Shear Demand from fig. R18.6.5, ACI 318-14 $V_e = (M_{pr1} + M_{pr2})/l_n = 272744.406$
with
 $M_{pr1} = \text{Max}(Mu_{1+} , Mu_{1-}) = 4.0912E+008$
 $Mu_{1+} = 4.0912E+008$, is the ultimate moment strength at the edge 1 of the member in the actual moment direction
which is defined for the static loading combination
 $Mu_{1-} = 4.0912E+008$, is the ultimate moment strength at the edge 1 of the member in the opposite moment
direction which is defined for the static loading combination
 $M_{pr2} = \text{Max}(Mu_{2+} , Mu_{2-}) = 4.0912E+008$
 $Mu_{2+} = 4.0912E+008$, is the ultimate moment strength at the edge 2 of the member in the actual moment direction
which is defined for the the static loading combination
 $Mu_{2-} = 4.0912E+008$, is the ultimate moment strength at the edge 2 of the member in the opposite moment
direction which is defined for the the static loading combination

Calculation of Mu_{1+}

Calculation of ultimate Moment Strength ((3.67), Biskinis Phd), Mu
 $Mu = 4.0912E+008$

= 0.97738438
' = 0.86668818
error of function (3.68), Biskinis Phd = 94694.946
From 5A.2, TBDY: $f_{cc} = f_c \cdot c = 43.01531$
conf. factor $c = 1.30349$
 $f_c = 33.00$
From 10.3.5, ASCE 41-17, Final value of f_y : $f_y \cdot \text{Min}(1, 1.25 \cdot (l_b/d)^{2/3}) = 694.45$
 $l_b/d = 1.00$
 $d_1 = 44.00$
 $R = 250.00$
 $v = 0.0011401$
 $N = 7389.214$
 $Ac = 196349.541$
 $= \cdot \text{Min}(1, 1.25 \cdot (l_b/d)^{2/3}) = 0.26182028$

Calculation of ratio l_b/d

Adequate Lap Length: $l_b/d \geq 1$

Calculation of μ_{1-}

Calculation of ultimate Moment Strength ((3.67), Biskinis Phd), μ
 $\mu = 4.0912E+008$

= 0.97738438
' = 0.86668818
error of function (3.68), Biskinis Phd = 94694.946
From 5A.2, TBDY: $f_{cc} = f_c \cdot c = 43.01531$
conf. factor $c = 1.30349$
 $f_c = 33.00$
From 10.3.5, ASCE 41-17, Final value of f_y : $f_y \cdot \text{Min}(1, 1.25 \cdot (l_b/d)^{2/3}) = 694.45$
 $l_b/d = 1.00$
 $d_1 = 44.00$
 $R = 250.00$
 $v = 0.0011401$
 $N = 7389.214$
 $Ac = 196349.541$
 $= \cdot \text{Min}(1, 1.25 \cdot (l_b/d)^{2/3}) = 0.26182028$

Calculation of ratio l_b/d

Adequate Lap Length: $l_b/d \geq 1$

Calculation of μ_{2+}

Calculation of ultimate Moment Strength ((3.67), Biskinis Phd), μ
 $\mu = 4.0912E+008$

= 0.97738438
' = 0.86668818
error of function (3.68), Biskinis Phd = 94694.946
From 5A.2, TBDY: $f_{cc} = f_c \cdot c = 43.01531$
conf. factor $c = 1.30349$
 $f_c = 33.00$
From 10.3.5, ASCE 41-17, Final value of f_y : $f_y \cdot \text{Min}(1, 1.25 \cdot (l_b/d)^{2/3}) = 694.45$
 $l_b/d = 1.00$

d1 = 44.00
R = 250.00
v = 0.0011401
N = 7389.214
Ac = 196349.541
= *Min(1,1.25*(lb/d)^ 2/3) = 0.26182028

Calculation of ratio lb/d

Adequate Lap Length: lb/d >= 1

Calculation of Mu2-

Calculation of ultimate Moment Strength ((3.67), Biskinis Phd), Mu

Mu = 4.0912E+008

= 0.97738438

' = 0.86668818

error of function (3.68), Biskinis Phd = 94694.946

From 5A.2, TBDY: fcc = fc* c = 43.01531

conf. factor c = 1.30349

fc = 33.00

From 10.3.5, ASCE 41-17, Final value of fy: fy*Min(1,1.25*(lb/d)^ 2/3) = 694.45

lb/d = 1.00

d1 = 44.00

R = 250.00

v = 0.0011401

N = 7389.214

Ac = 196349.541

= *Min(1,1.25*(lb/d)^ 2/3) = 0.26182028

Calculation of ratio lb/d

Adequate Lap Length: lb/d >= 1

Calculation of Shear Strength Vr = Min(Vr1,Vr2) = 500419.792

Calculation of Shear Strength at edge 1, Vr1 = 500419.792

Vr1 = VCol ((10.3), ASCE 41-17) = knl*VCol0

VCol0 = 500419.792

knl = 1 (zero step-static loading)

NOTE: In expression (10-3) 'Vs = Av*fy*d/s' is replaced by 'Vs+ f*Vf' where Vf is the contribution of FRPs (11.3), ACI 440).

= 1 (normal-weight concrete)

Mean concrete strength: fc' = (fc'_jacket*Area_jacket + fc'_core*Area_core)/Area_section = 33.00, but fc'^0.5 <= 8.3 MPa (22.5.3.1, ACI 318-14)

M/d = 2.00

Mu = 2.1979728E-011

Vu = 2.7468482E-047

d = 0.8*D = 400.00

Nu = 7389.214

Ag = 196349.541

From (11.5.4.8), ACI 318-14: Vs = Vs1 + Vs2 = 274157.871

Vs1 = 274157.871 is calculated for jacket, with:

Av = /2*A_stirrup = 123370.055

fy = 555.56

s = 100.00
Vs1 is multiplied by Col1 = 1.00
s/d = 0.25
Vs2 = 0.00 is calculated for core, with:
Av = $\sqrt{2} \cdot A_{\text{stirrup}} = 78956.835$
fy = 555.56
s = 250.00
Vs2 is multiplied by Col2 = 0.00
s/d = 1.04167
Vf ((11-3)-(11.4), ACI 440) = 0.00
From (11-11), ACI 440: Vs + Vf <= 479549.663
bw*d = $\frac{1}{4} \cdot d^2 = 125663.706$

Calculation of Shear Strength at edge 2, Vr2 = 500419.792
Vr2 = VCol ((10.3), ASCE 41-17) = knl*VCol0
VCol0 = 500419.792
knl = 1 (zero step-static loading)

NOTE: In expression (10-3) 'Vs = Av*fy*d/s' is replaced by 'Vs+ f*Vf'
where Vf is the contribution of FRPs (11.3), ACI 440).

= 1 (normal-weight concrete)
Mean concrete strength: fc' = (fc'_jacket*Area_jacket + fc'_core*Area_core)/Area_section = 33.00, but fc'^0.5 <= 8.3
MPa (22.5.3.1, ACI 318-14)
M/Vd = 2.00
Mu = 2.1979728E-011
Vu = 2.7468482E-047
d = 0.8*D = 400.00
Nu = 7389.214
Ag = 196349.541
From (11.5.4.8), ACI 318-14: Vs = Vs1 + Vs2 = 274157.871
Vs1 = 274157.871 is calculated for jacket, with:
Av = $\sqrt{2} \cdot A_{\text{stirrup}} = 123370.055$
fy = 555.56
s = 100.00
Vs1 is multiplied by Col1 = 1.00
s/d = 0.25
Vs2 = 0.00 is calculated for core, with:
Av = $\sqrt{2} \cdot A_{\text{stirrup}} = 78956.835$
fy = 555.56
s = 250.00
Vs2 is multiplied by Col2 = 0.00
s/d = 1.04167
Vf ((11-3)-(11.4), ACI 440) = 0.00
From (11-11), ACI 440: Vs + Vf <= 479549.663
bw*d = $\frac{1}{4} \cdot d^2 = 125663.706$

End Of Calculation of Shear Capacity ratio for element: column JCC1 of floor 1
At local axis: 2

Start Of Calculation of Chord Rotation Capacity for element: column JCC1 of floor 1
At local axis: 2
Integration Section: (a)
Section Type: rcjcs

Constant Properties

Knowledge Factor, = 1.00
Chord Rotation is generally considered as Deformation-Controlled Action according to Table C7-1, ASCE 41-17.
Mean strengths are used for Deformation-Controlled Actions according to 7.5.1.3, ASCE 41-17
Consequently:
Jacket

New material of Primary Member: Concrete Strength, $f_c = f_{cm} = 33.00$
 New material of Primary Member: Steel Strength, $f_s = f_{sm} = 555.56$
 Concrete Elasticity, $E_c = 26999.444$
 Steel Elasticity, $E_s = 200000.00$
 Existing Column
 New material of Primary Member: Concrete Strength, $f_c = f_{cm} = 33.00$
 New material of Primary Member: Steel Strength, $f_s = f_{sm} = 555.56$
 Concrete Elasticity, $E_c = 26999.444$
 Steel Elasticity, $E_s = 200000.00$
 External Diameter, $D = 500.00$
 Internal Diameter, $D = 300.00$
 Cover Thickness, $c = 25.00$
 Element Length, $L = 3000.00$
 Primary Member
 Smooth Bars
 Ductile Steel
 With Detailing for Earthquake Resistance (including stirrups closed at 135°)
 Longitudinal Bars With Ends Lapped Starting at the End Sections
 Adequate Lap Length ($l_b/l_d \geq 1$)
 No FRP Wrapping

 Stepwise Properties

Bending Moment, $M = 1.5387606E-009$
 Shear Force, $V_2 = -7509.70$
 Shear Force, $V_3 = -5.3669914E-013$
 Axial Force, $F = -7386.21$
 Longitudinal Reinforcement Area Distribution (in 2 divisions)
 -Tension: $A_{st} = 1272.345$
 -Compression: $A_{sc} = 1781.283$
 Longitudinal Reinforcement Area Distribution (in 3 divisions)
 -Tension: $A_{st,ten} = 1017.876$
 -Compression: $A_{sc,com} = 1017.876$
 -Middle: $A_{st,mid} = 1017.876$
 Mean Diameter of Tension Reinforcement, $DbL = 18.00$

 New component: From table 7-7, ASCE 41_17: Final chord rotation Capacity $u_{,R} = 1.0^*$ $u = 0.01229548$
 $u = y + p = 0.01229548$

 - Calculation of y -

$y = (M_y * L_s / 3) / E_{eff} = 0.00729548$ ((4.29), Biskinis Phd))
 $M_y = 3.6259E+008$
 $L_s = M/V$ (with $L_s > 0.1 * L$ and $L_s < 2 * L$) = 1500.00
 From table 10.5, ASCE 41_17: $E_{eff} = factor * E_c * I_g = 2.4850E+013$
 $factor = 0.30$
 $A_g = 196349.541$
 Mean concrete strength: $f_c' = (f_c'_{jacket} * Area_{jacket} + f_c'_{core} * Area_{core}) / Area_{section} = 33.00$
 $N = 7386.21$
 $E_c * I_g = E_c_{jacket} * I_{g,jacket} + E_c_{core} * I_{g,core} = 8.2833E+013$

 Calculation of Yielding Moment M_y

Calculation of y and M_y according to (7) - (8) in Biskinis and Fardis

$M_y = \text{Min}(M_{y,ten}, M_{y,com}) = 3.6259E+008$
 y ((10a) or (10b)) = $1.0622306E-005$
 $M_{y,ten}$ (8a) = $3.6259E+008$
 y_{ten} (7a) = 65.43628
 error of function (7a) = 0.00293092

$M_{y_com} (8b) = 7.5621E+008$
 $_{com} (7b) = 64.56803$
 error of function (7b) = -0.00721907
 with $e_y = 0.0027778$
 $e_{co} = 0.002$
 $a_{pl} = 0.35$ ((9a) in Biskinis and Fardis for no FRP Wrap)
 $d_1 = 44.00$
 $R = 250.00$
 $v = 0.00113993$
 $N = 7386.21$
 $A_c = 196349.541$
 $= 0.26182028$
 with $f_c = 33.00$

 Calculation of ratio l_b/d

Adequate Lap Length: $l_b/d \geq 1$

- Calculation of ρ -

From table 10-9: $\rho = 0.005$

with:

- Columns not controlled by inadequate development or splicing along the clear height because $l_b/d \geq 1$

shear control ratio $V_y E / V_{CoI} E = 0.54503121$

$d = d_{external} = 0.00$

$s = s_{external} = 0.00$

$t = s_1 + s_2 + 2 * t_f / b_w * (f_{fe} / f_s) = 0.00323428$

jacket: $s_1 = A_{v1} * (D_{c1} / 2) / (s_1 * A_g) = 0.0027646$

$A_{v1} = 78.53982$, is the area of stirrup

$D_{c1} = D_{ext} - 2 * cover - External\ Hoop\ Diameter = 440.00$, is the total Length of all stirrups parallel to loading

(shear) direction

$s_1 = 100.00$

core: $s_2 = A_{v2} * (D_{c2} / 2) / (s_2 * A_g) = 0.00046968$

$A_{v2} = 50.26548$, is the area of stirrup

$D_{c2} = D_{int} - Internal\ Hoop\ Diameter = 292.00$, is the total Length of all stirrups parallel to loading (shear)

direction

$s_2 = 250.00$

The term $2 * t_f / b_w * (f_{fe} / f_s)$ is implemented to account for FRP contribution

where $f = 2 * t_f / b_w$ is FRP ratio (EC8 - 3, A.4.4.3(6)) and f_{fe} / f_s normalises f to steel strength

All these variables have already been given in Shear control ratio calculation.

For the normalisation f_s of jacket is used.

$N_{UD} = 7386.21$

$A_g = 196349.541$

$f_{cE} = (f_{c_jacket} * Area_jacket + f_{c_core} * Area_core) / section_area = 33.00$

$f_{yE} = (f_{y_ext_Long_Reinf} * Area_ext_Long_Reinf + f_{y_int_Long_Reinf} * Area_int_Long_Reinf) / Area_Tot_Long_Rein = 2.1219958E-314$

$f_{yE} = (f_{y_ext_Trans_Reinf} * Area_ext_Trans_Reinf + f_{y_int_Trans_Reinf} * Area_int_Trans_Reinf) / Area_Tot_Trans_Rein = 555.56$

$\rho_l = Area_Tot_Long_Rein / (A_g) = 0.015552$

$f_{cE} = 33.00$

End Of Calculation of Chord Rotation Capacity for element: column JCC1 of floor 1

At local axis: 2

Integration Section: (a)

Calculation No. 3

column C1, Floor 1


Limit State: Immediate Occupancy (data interpolation between analysis steps 1 and 2)

Analysis: Uniform +X

Check: Shear capacity VRd

Edge: Start

Local Axis: (3)



Start Of Calculation of Shear Capacity for element: column JCC1 of floor 1

At local axis: 3

Integration Section: (a)

Section Type: rcjcs

Constant Properties

Knowledge Factor, $\gamma = 1.00$

Member Shear Force is generally considered as Force-Controlled Action according to Table C7-1, ASCE 41-17.

Lower-bound strengths are used for Force-Controlled Actions according to 7.5.1.3, ASCE 41-17

Consequently:

Jacket

New material of Primary Member: Concrete Strength, $f_c = f_{c_lower_bound} = 25.00$

New material of Primary Member: Steel Strength, $f_s = f_{s_lower_bound} = 500.00$

Concrete Elasticity, $E_c = 26999.444$

Steel Elasticity, $E_s = 200000.00$

Existing Column

New material of Primary Member: Concrete Strength, $f_c = f_{c_lower_bound} = 25.00$

New material of Primary Member: Steel Strength, $f_s = f_{s_lower_bound} = 500.00$

Concrete Elasticity, $E_c = 26999.444$

Steel Elasticity, $E_s = 200000.00$

#####

Note: Especially for the calculation of γ for displacement ductility demand, the expected (mean value) strengths are used (7.5.1.3, ASCE 41-17) because bending is considered as Deformation-Controlled Action (Table C7-1, ASCE 41-17).

Jacket

New material: Concrete Strength, $f_c = f_{cm} = 33.00$

New material: Steel Strength, $f_s = f_{sm} = 555.56$

Existing Column

New material: Concrete Strength, $f_c = f_{cm} = 33.00$

New material: Steel Strength, $f_s = f_{sm} = 555.56$

#####

External Diameter, D = 500.00
Internal Diameter, D = 300.00
Cover Thickness, c = 25.00
Element Length, L = 3000.00
Primary Member
Smooth Bars
Ductile Steel
With Detailing for Earthquake Resistance (including stirrups closed at 135°)
Longitudinal Bars With Ends Lapped Starting at the End Sections
Adequate Lap Length ($l_o/l_{o,u,min} = l_b/l_d >= 1$)
No FRP Wrapping

Stepwise Properties

EDGE -A-
Bending Moment, $M_a = 1.5387606E-009$
Shear Force, $V_a = -5.3669914E-013$
EDGE -B-
Bending Moment, $M_b = 7.1693020E-011$
Shear Force, $V_b = 5.3669914E-013$
BOTH EDGES
Axial Force, $F = -7386.21$
Longitudinal Reinforcement Area Distribution (in 2 divisions)
-Tension: $A_{s,t} = 1272.345$
-Compression: $A_{s,c} = 1781.283$
Longitudinal Reinforcement Area Distribution (in 3 divisions)
-Tension: $A_{s,ten} = 1017.876$
-Compression: $A_{s,com} = 1017.876$
-Middle: $A_{s,mid} = 1017.876$
Mean Diameter of Tension Reinforcement, $D_{bL,ten} = 18.00$

New component: From table 7-7, ASCE 41_17: Final Shear Capacity $V_R = 1.0 \cdot V_n = 443865.445$
 V_n ((10.3), ASCE 41-17) = $k_n \cdot V_{Co10} = 443865.445$
 $V_{Co10} = 443865.445$
 $k_n = 1.00$
 $displacement_ductility_demand = 0.00$

NOTE: In expression (10-3) ' $V_s = A_v \cdot f_y \cdot d / s$ ' is replaced by ' $V_s + f \cdot V_f$ '
where V_f is the contribution of FRPs (11.3), ACI 440).

= 1 (normal-weight concrete)
Mean concrete strength: $f_c' = (f_c'_{jacket} \cdot Area_{jacket} + f_c'_{core} \cdot Area_{core}) / Area_{section} = 25.00$, but $f_c'^{0.5} <= 8.3$
MPa (22.5.3.1, ACI 318-14)
 $M / V_d = 2.00$
 $M_u = 1.5387606E-009$
 $V_u = 5.3669914E-013$
 $d = 0.8 \cdot D = 400.00$
 $N_u = 7386.21$
 $A_g = 196349.541$
From (11.5.4.8), ACI 318-14: $V_s = V_{s1} + V_{s2} = 246740.11$
 $V_{s1} = 246740.11$ is calculated for jacket, with:
 $A_v = \sqrt{2} \cdot A_{stirrup} = 123370.055$
 $f_y = 500.00$
 $s = 100.00$
 V_{s1} is multiplied by $Col1 = 1.00$
 $s/d = 0.25$
 $V_{s2} = 0.00$ is calculated for core, with:
 $A_v = \sqrt{2} \cdot A_{stirrup} = 78956.835$
 $f_y = 500.00$
 $s = 250.00$
 V_{s2} is multiplied by $Col2 = 0.00$
 $s/d = 1.04167$
 V_f ((11-3)-(11.4), ACI 440) = 0.00

From (11-11), ACI 440: $V_s + V_f \leq 417394.406$
 $bw*d = *d*d/4 = 125663.706$

displacement_ductility_demand is calculated as ϕ / y

- Calculation of ϕ / y for END A -
for rotation axis 2 and integ. section (a)

From analysis, chord rotation $\theta = 1.6170996E-020$
 $y = (M_y * L_s / 3) / E_{eff} = 0.00729548$ ((4.29), Biskinis Phd))
 $M_y = 3.6259E+008$
 $L_s = M/V$ (with $L_s > 0.1*L$ and $L_s < 2*L$) = 1500.00
From table 10.5, ASCE 41_17: $E_{eff} = factor * E_c * I_g = 2.4850E+013$
factor = 0.30
 $A_g = 196349.541$
Mean concrete strength: $f_c' = (f_c'_{jacket} * Area_{jacket} + f_c'_{core} * Area_{core}) / Area_{section} = 33.00$
 $N = 7386.21$
 $E_c * I_g = E_{c,jacket} * I_{g,jacket} + E_{c,core} * I_{g,core} = 8.2833E+013$

Calculation of Yielding Moment M_y

Calculation of ϕ and M_y according to (7) - (8) in Biskinis and Fardis

$M_y = \min(M_{y,ten}, M_{y,com}) = 3.6259E+008$
 ϕ ((10a) or (10b)) = $1.0622306E-005$
 $M_{y,ten}$ (8a) = $3.6259E+008$
 ϕ_{ten} (7a) = 65.43628
error of function (7a) = 0.00293092
 $M_{y,com}$ (8b) = $7.5621E+008$
 ϕ_{com} (7b) = 64.56803
error of function (7b) = -0.00721907
with $e_y = 0.0027778$
 $e_{co} = 0.002$
 $a_{pl} = 0.35$ ((9a) in Biskinis and Fardis for no FRP Wrap)
 $d_1 = 44.00$
 $R = 250.00$
 $v = 0.00113993$
 $N = 7386.21$
 $A_c = 196349.541$
= 0.26182028
with $f_c = 33.00$

Calculation of ratio I_b / I_d

Adequate Lap Length: $I_b / I_d \geq 1$

End Of Calculation of Shear Capacity for element: column JCC1 of floor 1

At local axis: 3

Integration Section: (a)

Calculation No. 4

column C1, Floor 1


Limit State: Immediate Occupancy (data interpolation between analysis steps 1 and 2)

Analysis: Uniform +X

Check: Chord rotation capacity (θ_r)

Edge: Start

Local Axis: (3)



Start Of Calculation of Shear Capacity ratio for element: column JCC1 of floor 1

At Shear local axis: 3

(Bending local axis: 2)

Section Type: rcjcs

Constant Properties

Knowledge Factor, $\gamma = 1.00$

Mean strength values are used for both shear and moment calculations.

Consequently:

Jacket

New material of Primary Member: Concrete Strength, $f_c = f_{cm} = 33.00$

New material of Primary Member: Steel Strength, $f_s = f_{sm} = 555.56$

Concrete Elasticity, $E_c = 26999.444$

Steel Elasticity, $E_s = 200000.00$

Existing Column

New material of Primary Member: Concrete Strength, $f_c = f_{cm} = 33.00$

New material of Primary Member: Steel Strength, $f_s = f_{sm} = 555.56$

Concrete Elasticity, $E_c = 26999.444$

Steel Elasticity, $E_s = 200000.00$

#####

Note: Especially for the calculation of moment strengths,

the above steel re-bar strengths are multiplied by 1.25 according to R18.6.5, ACI 318-14

Jacket

New material: Steel Strength, $f_s = 1.25 \cdot f_{sm} = 694.45$

Existing Column

New material: Steel Strength, $f_s = 1.25 \cdot f_{sm} = 694.45$

#####

External Diameter, $D = 500.00$

Internal Diameter, $D = 300.00$

Cover Thickness, $c = 25.00$

Mean Confinement Factor overall section = 1.30349

Element Length, $L = 3000.00$

Primary Member

Smooth Bars

Ductile Steel

With Detailing for Earthquake Resistance (including stirrups closed at 135°)

Longitudinal Bars With Ends Lapped Starting at the End Sections

Adequate Lap Length ($l_o/l_{ou, \min} > 1$)

No FRP Wrapping

Stepwise Properties

At local axis: 3

EDGE -A-

Shear Force, $V_a = 4.4860917E-031$

EDGE -B-

Shear Force, $V_b = -4.4860917E-031$

BOTH EDGES

Axial Force, $F = -7389.214$

Longitudinal Reinforcement Area Distribution (in 2 divisions)

-Tension: $As_t = 0.00$

-Compression: $As_c = 3053.628$

Longitudinal Reinforcement Area Distribution (in 3 divisions)

-Tension: $As_{t,ten} = 1017.876$

-Compression: $As_{c,com} = 1017.876$

-Middle: $As_{mid} = 1017.876$

Calculation of Shear Capacity ratio, $V_e/V_r = 0.54503121$

Member Controlled by Flexure ($V_e/V_r < 1$)

Calculation of Shear Demand from fig. R18.6.5, ACI 318-14 $V_e = (M_{pr1} + M_{pr2})/l_n = 272744.406$

with

$M_{pr1} = \text{Max}(M_{u1+}, M_{u1-}) = 4.0912E+008$

$M_{u1+} = 4.0912E+008$, is the ultimate moment strength at the edge 1 of the member in the actual moment direction which is defined for the static loading combination

$M_{u1-} = 4.0912E+008$, is the ultimate moment strength at the edge 1 of the member in the opposite moment direction which is defined for the static loading combination

$M_{pr2} = \text{Max}(M_{u2+}, M_{u2-}) = 4.0912E+008$

$M_{u2+} = 4.0912E+008$, is the ultimate moment strength at the edge 2 of the member in the actual moment direction which is defined for the the static loading combination

$M_{u2-} = 4.0912E+008$, is the ultimate moment strength at the edge 2 of the member in the opposite moment direction which is defined for the the static loading combination

Calculation of M_{u1+}

Calculation of ultimate Moment Strength ((3.67), Biskinis Phd), M_u

$M_u = 4.0912E+008$

$\phi = 0.97738438$

$\phi' = 0.86668818$

error of function (3.68), Biskinis Phd = 94694.946

From 5A.2, TBDY: $f_{cc} = f_c \cdot c = 43.01531$

conf. factor $c = 1.30349$

$f_c = 33.00$

From 10.3.5, ASCE 41-17, Final value of f_y : $f_y \cdot \text{Min}(1, 1.25 \cdot (l_b/d)^{2/3}) = 694.45$

$l_b/d = 1.00$

$d_1 = 44.00$

$R = 250.00$

$v = 0.0011401$

$N = 7389.214$

$A_c = 196349.541$

$\phi \cdot \text{Min}(1, 1.25 \cdot (l_b/d)^{2/3}) = 0.26182028$

Calculation of ratio l_b/d

Adequate Lap Length: $l_b/d \geq 1$

Calculation of Mu1-

Calculation of ultimate Moment Strength ((3.67), Biskinis Phd), Mu
Mu = 4.0912E+008

= 0.97738438
' = 0.86668818
error of function (3.68), Biskinis Phd = 94694.946
From 5A.2, TBDY: $f_{cc} = f_c \cdot c = 43.01531$
conf. factor $c = 1.30349$
 $f_c = 33.00$
From 10.3.5, ASCE 41-17, Final value of f_y : $f_y \cdot \text{Min}(1, 1.25 \cdot (l_b/d)^{2/3}) = 694.45$
 $l_b/d = 1.00$
 $d_1 = 44.00$
 $R = 250.00$
 $v = 0.0011401$
 $N = 7389.214$
 $A_c = 196349.541$
= $\cdot \text{Min}(1, 1.25 \cdot (l_b/d)^{2/3}) = 0.26182028$

Calculation of ratio l_b/d

Adequate Lap Length: $l_b/d \geq 1$

Calculation of Mu2+

Calculation of ultimate Moment Strength ((3.67), Biskinis Phd), Mu
Mu = 4.0912E+008

= 0.97738438
' = 0.86668818
error of function (3.68), Biskinis Phd = 94694.946
From 5A.2, TBDY: $f_{cc} = f_c \cdot c = 43.01531$
conf. factor $c = 1.30349$
 $f_c = 33.00$
From 10.3.5, ASCE 41-17, Final value of f_y : $f_y \cdot \text{Min}(1, 1.25 \cdot (l_b/d)^{2/3}) = 694.45$
 $l_b/d = 1.00$
 $d_1 = 44.00$
 $R = 250.00$
 $v = 0.0011401$
 $N = 7389.214$
 $A_c = 196349.541$
= $\cdot \text{Min}(1, 1.25 \cdot (l_b/d)^{2/3}) = 0.26182028$

Calculation of ratio l_b/d

Adequate Lap Length: $l_b/d \geq 1$

Calculation of Mu2-

Calculation of ultimate Moment Strength ((3.67), Biskinis Phd), Mu
Mu = 4.0912E+008

= 0.97738438

$\rho = 0.86668818$
 error of function (3.68), Biskinis Phd = 94694.946
 From 5A.2, TBDY: $f_{cc} = f_c \cdot c = 43.01531$
 conf. factor $c = 1.30349$
 $f_c = 33.00$
 From 10.3.5, ASCE 41-17, Final value of f_y : $f_y \cdot \text{Min}(1, 1.25 \cdot (l_b/d)^{2/3}) = 694.45$
 $l_b/d = 1.00$
 $d_1 = 44.00$
 $R = 250.00$
 $v = 0.0011401$
 $N = 7389.214$
 $A_c = 196349.541$
 $= \cdot \text{Min}(1, 1.25 \cdot (l_b/d)^{2/3}) = 0.26182028$

 Calculation of ratio l_b/d

Adequate Lap Length: $l_b/d \geq 1$

 Calculation of Shear Strength $V_r = \text{Min}(V_{r1}, V_{r2}) = 500419.792$

Calculation of Shear Strength at edge 1, $V_{r1} = 500419.792$

$V_{r1} = V_{Co1}$ ((10.3), ASCE 41-17) = $k_{nl} \cdot V_{Co10}$
 $V_{Co10} = 500419.792$
 $k_{nl} = 1$ (zero step-static loading)

 NOTE: In expression (10-3) ' $V_s = A_v \cdot f_y \cdot d/s$ ' is replaced by ' $V_s + f \cdot V_f$ '
 where V_f is the contribution of FRPs (11.3), ACI 440).

$= 1$ (normal-weight concrete)
 Mean concrete strength: $f'_c = (f'_c \cdot \text{Area}_{\text{jacket}} + f'_c \cdot \text{Area}_{\text{core}}) / \text{Area}_{\text{section}} = 33.00$, but $f_c^{0.5} \leq 8.3$
 MPa (22.5.3.1, ACI 318-14)

$M/Vd = 2.00$
 $\mu_u = 2.5382294E-011$
 $\nu_u = 4.4860917E-031$
 $d = 0.8 \cdot D = 400.00$
 $N_u = 7389.214$
 $A_g = 196349.541$
 From (11.5.4.8), ACI 318-14: $V_s = V_{s1} + V_{s2} = 274157.871$
 $V_{s1} = 274157.871$ is calculated for jacket, with:
 $A_v = \sqrt{2} \cdot A_{\text{stirup}} = 123370.055$
 $f_y = 555.56$
 $s = 100.00$
 V_{s1} is multiplied by $Col1 = 1.00$
 $s/d = 0.25$
 $V_{s2} = 0.00$ is calculated for core, with:
 $A_v = \sqrt{2} \cdot A_{\text{stirup}} = 78956.835$
 $f_y = 555.56$
 $s = 250.00$
 V_{s2} is multiplied by $Col2 = 0.00$
 $s/d = 1.04167$
 V_f ((11-3)-(11.4), ACI 440) = 0.00
 From (11-11), ACI 440: $V_s + V_f \leq 479549.663$
 $b_w \cdot d = \cdot d \cdot d/4 = 125663.706$

 Calculation of Shear Strength at edge 2, $V_{r2} = 500419.792$

$V_{r2} = V_{Co2}$ ((10.3), ASCE 41-17) = $k_{nl} \cdot V_{Co20}$
 $V_{Co20} = 500419.792$
 $k_{nl} = 1$ (zero step-static loading)

 NOTE: In expression (10-3) ' $V_s = A_v \cdot f_y \cdot d/s$ ' is replaced by ' $V_s + f \cdot V_f$ '
 where V_f is the contribution of FRPs (11.3), ACI 440).

= 1 (normal-weight concrete)

Mean concrete strength: $f_c' = (f_c'_{jacket} \cdot Area_{jacket} + f_c'_{core} \cdot Area_{core}) / Area_{section} = 33.00$, but $f_c'^{0.5} \leq 8.3$ MPa (22.5.3.1, ACI 318-14)

$M/Vd = 2.00$

$\mu_u = 2.5382294E-011$

$\nu_u = 4.4860917E-031$

$d = 0.8 \cdot D = 400.00$

$N_u = 7389.214$

$A_g = 196349.541$

From (11.5.4.8), ACI 318-14: $V_s = V_{s1} + V_{s2} = 274157.871$

$V_{s1} = 274157.871$ is calculated for jacket, with:

$A_v = \sqrt{2} \cdot A_{stirrup} = 123370.055$

$f_y = 555.56$

$s = 100.00$

V_{s1} is multiplied by $Col1 = 1.00$

$s/d = 0.25$

$V_{s2} = 0.00$ is calculated for core, with:

$A_v = \sqrt{2} \cdot A_{stirrup} = 78956.835$

$f_y = 555.56$

$s = 250.00$

V_{s2} is multiplied by $Col2 = 0.00$

$s/d = 1.04167$

V_f ((11-3)-(11.4), ACI 440) = 0.00

From (11-11), ACI 440: $V_s + V_f \leq 479549.663$

$b_w \cdot d = \frac{A_v \cdot s}{f_y} = 125663.706$

End Of Calculation of Shear Capacity ratio for element: column JCC1 of floor 1
At local axis: 3

Start Of Calculation of Shear Capacity ratio for element: column JCC1 of floor 1
At Shear local axis: 2
(Bending local axis: 3)
Section Type: rcjcs

Constant Properties

Knowledge Factor, $\phi = 1.00$

Mean strength values are used for both shear and moment calculations.

Consequently:

Jacket

New material of Primary Member: Concrete Strength, $f_c = f_{cm} = 33.00$

New material of Primary Member: Steel Strength, $f_s = f_{sm} = 555.56$

Concrete Elasticity, $E_c = 26999.444$

Steel Elasticity, $E_s = 200000.00$

Existing Column

New material of Primary Member: Concrete Strength, $f_c = f_{cm} = 33.00$

New material of Primary Member: Steel Strength, $f_s = f_{sm} = 555.56$

Concrete Elasticity, $E_c = 26999.444$

Steel Elasticity, $E_s = 200000.00$

#####

Note: Especially for the calculation of moment strengths,

the above steel re-bar strengths are multiplied by 1.25 according to R18.6.5, ACI 318-14

Jacket

New material: Steel Strength, $f_s = 1.25 \cdot f_{sm} = 694.45$

Existing Column

New material: Steel Strength, $f_s = 1.25 \cdot f_{sm} = 694.45$

#####

External Diameter, $D = 500.00$

Internal Diameter, $D = 300.00$

Cover Thickness, $c = 25.00$

Mean Confinement Factor overall section = 1.30349

Element Length, $L = 3000.00$

Primary Member

Smooth Bars
Ductile Steel
With Detailing for Earthquake Resistance (including stirrups closed at 135°)
Longitudinal Bars With Ends Lapped Starting at the End Sections
Adequate Lap Length ($l_o/l_{ou, \min} >= 1$)
No FRP Wrapping

Stepwise Properties

At local axis: 2
EDGE -A-
Shear Force, $V_a = -2.7468482E-047$
EDGE -B-
Shear Force, $V_b = 2.7468482E-047$
BOTH EDGES
Axial Force, $F = -7389.214$
Longitudinal Reinforcement Area Distribution (in 2 divisions)
-Tension: $A_{st} = 0.00$
-Compression: $A_{sc} = 3053.628$
Longitudinal Reinforcement Area Distribution (in 3 divisions)
-Tension: $A_{st, \text{ten}} = 1017.876$
-Compression: $A_{sc, \text{com}} = 1017.876$
-Middle: $A_{sc, \text{mid}} = 1017.876$

Calculation of Shear Capacity ratio, $V_e/V_r = 0.54503121$
Member Controlled by Flexure ($V_e/V_r < 1$)
Calculation of Shear Demand from fig. R18.6.5, ACI 318-14 $V_e = (M_{pr1} + M_{pr2})/l_n = 272744.406$
with
 $M_{pr1} = \text{Max}(M_{u1+}, M_{u1-}) = 4.0912E+008$
 $M_{u1+} = 4.0912E+008$, is the ultimate moment strength at the edge 1 of the member in the actual moment direction which is defined for the static loading combination
 $M_{u1-} = 4.0912E+008$, is the ultimate moment strength at the edge 1 of the member in the opposite moment direction which is defined for the static loading combination
 $M_{pr2} = \text{Max}(M_{u2+}, M_{u2-}) = 4.0912E+008$
 $M_{u2+} = 4.0912E+008$, is the ultimate moment strength at the edge 2 of the member in the actual moment direction which is defined for the the static loading combination
 $M_{u2-} = 4.0912E+008$, is the ultimate moment strength at the edge 2 of the member in the opposite moment direction which is defined for the the static loading combination

Calculation of M_{u1+}

Calculation of ultimate Moment Strength ((3.67), Biskinis Phd), M_u
 $M_u = 4.0912E+008$

 $\phi = 0.97738438$
 $\lambda = 0.86668818$
error of function (3.68), Biskinis Phd = 94694.946
From 5A.2, TBDY: $f_{cc} = f_c^* c = 43.01531$
conf. factor $c = 1.30349$
 $f_c = 33.00$
From 10.3.5, ASCE 41-17, Final value of f_y : $f_y * \text{Min}(1, 1.25 * (l_b/l_d)^{2/3}) = 694.45$
 $l_b/l_d = 1.00$
 $d_1 = 44.00$
 $R = 250.00$
 $v = 0.0011401$
 $N = 7389.214$
 $A_c = 196349.541$
 $= * \text{Min}(1, 1.25 * (l_b/l_d)^{2/3}) = 0.26182028$

Calculation of ratio lb/d

Adequate Lap Length: $lb/d \geq 1$

Calculation of Mu1-

Calculation of ultimate Moment Strength ((3.67), Biskinis Phd), Mu
Mu = 4.0912E+008

$$= 0.97738438$$

$$' = 0.86668818$$

error of function (3.68), Biskinis Phd = 94694.946

From 5A.2, TBDY: $f_{cc} = f_c \cdot c = 43.01531$

conf. factor $c = 1.30349$

$f_c = 33.00$

From 10.3.5, ASCE 41-17, Final value of f_y : $f_y \cdot \text{Min}(1, 1.25 \cdot (lb/d)^{2/3}) = 694.45$

$$lb/d = 1.00$$

$$d1 = 44.00$$

$$R = 250.00$$

$$v = 0.0011401$$

$$N = 7389.214$$

$$Ac = 196349.541$$

$$= \cdot \text{Min}(1, 1.25 \cdot (lb/d)^{2/3}) = 0.26182028$$

Calculation of ratio lb/d

Adequate Lap Length: $lb/d \geq 1$

Calculation of Mu2+

Calculation of ultimate Moment Strength ((3.67), Biskinis Phd), Mu
Mu = 4.0912E+008

$$= 0.97738438$$

$$' = 0.86668818$$

error of function (3.68), Biskinis Phd = 94694.946

From 5A.2, TBDY: $f_{cc} = f_c \cdot c = 43.01531$

conf. factor $c = 1.30349$

$f_c = 33.00$

From 10.3.5, ASCE 41-17, Final value of f_y : $f_y \cdot \text{Min}(1, 1.25 \cdot (lb/d)^{2/3}) = 694.45$

$$lb/d = 1.00$$

$$d1 = 44.00$$

$$R = 250.00$$

$$v = 0.0011401$$

$$N = 7389.214$$

$$Ac = 196349.541$$

$$= \cdot \text{Min}(1, 1.25 \cdot (lb/d)^{2/3}) = 0.26182028$$

Calculation of ratio lb/d

Adequate Lap Length: $lb/d \geq 1$

Calculation of Mu2-

Calculation of ultimate Moment Strength ((3.67), Biskinis Phd), Mu

$$\text{Mu} = 4.0912\text{E}+008$$

$$= 0.97738438$$

$$' = 0.86668818$$

error of function (3.68), Biskinis Phd = 94694.946

From 5A.2, TBDY: $f_{cc} = f_c' \cdot c = 43.01531$

$$\text{conf. factor } c = 1.30349$$

$$f_c = 33.00$$

From 10.3.5, ASCE 41-17, Final value of fy: $f_y \cdot \text{Min}(1, 1.25 \cdot (l_b/d)^{2/3}) = 694.45$

$$l_b/d = 1.00$$

$$d_1 = 44.00$$

$$R = 250.00$$

$$v = 0.0011401$$

$$N = 7389.214$$

$$A_c = 196349.541$$

$$= \cdot \text{Min}(1, 1.25 \cdot (l_b/d)^{2/3}) = 0.26182028$$

Calculation of ratio l_b/d

Adequate Lap Length: $l_b/d \geq 1$

Calculation of Shear Strength $V_r = \text{Min}(V_{r1}, V_{r2}) = 500419.792$

Calculation of Shear Strength at edge 1, $V_{r1} = 500419.792$

$V_{r1} = V_{Col}$ ((10.3), ASCE 41-17) = $k_{nl} \cdot V_{Col0}$

$$V_{Col0} = 500419.792$$

$$k_{nl} = 1 \text{ (zero step-static loading)}$$

NOTE: In expression (10-3) ' $V_s = A_v \cdot f_y \cdot d/s$ ' is replaced by ' $V_s + f \cdot V_f$ ' where V_f is the contribution of FRPs (11.3), ACI 440).

$$= 1 \text{ (normal-weight concrete)}$$

Mean concrete strength: $f_c' = (f_c'_{\text{jacket}} \cdot \text{Area}_{\text{jacket}} + f_c'_{\text{core}} \cdot \text{Area}_{\text{core}}) / \text{Area}_{\text{section}} = 33.00$, but $f_c^{0.5} \leq 8.3$ MPa (22.5.3.1, ACI 318-14)

$$M/d = 2.00$$

$$\text{Mu} = 2.1979728\text{E}-011$$

$$V_u = 2.7468482\text{E}-047$$

$$d = 0.8 \cdot D = 400.00$$

$$N_u = 7389.214$$

$$A_g = 196349.541$$

From (11.5.4.8), ACI 318-14: $V_s = V_{s1} + V_{s2} = 274157.871$

$V_{s1} = 274157.871$ is calculated for jacket, with:

$$A_v = \sqrt{2} \cdot A_{\text{stirrup}} = 123370.055$$

$$f_y = 555.56$$

$$s = 100.00$$

V_{s1} is multiplied by $Col1 = 1.00$

$$s/d = 0.25$$

$V_{s2} = 0.00$ is calculated for core, with:

$$A_v = \sqrt{2} \cdot A_{\text{stirrup}} = 78956.835$$

$$f_y = 555.56$$

$$s = 250.00$$

V_{s2} is multiplied by $Col2 = 0.00$

$$s/d = 1.04167$$

V_f ((11-3)-(11.4), ACI 440) = 0.00

From (11-11), ACI 440: $V_s + V_f \leq 479549.663$

$$b_w \cdot d = \cdot d \cdot d/4 = 125663.706$$

Calculation of Shear Strength at edge 2, $V_{r2} = 500419.792$

$V_{r2} = V_{Col}$ ((10.3), ASCE 41-17) = $k_{nl} \cdot V_{Col0}$

$$V_{Col0} = 500419.792$$

knl = 1 (zero step-static loading)

NOTE: In expression (10-3) ' $V_s = A_v \cdot f_y \cdot d / s$ ' is replaced by ' $V_s + f \cdot V_f$ '
where V_f is the contribution of FRPs (11.3), ACI 440).

= 1 (normal-weight concrete)

Mean concrete strength: $f_c' = (f_c'_{\text{jacket}} \cdot \text{Area}_{\text{jacket}} + f_c'_{\text{core}} \cdot \text{Area}_{\text{core}}) / \text{Area}_{\text{section}} = 33.00$, but $f_c'^{0.5} \leq 8.3$
MPa (22.5.3.1, ACI 318-14)

$M/Vd = 2.00$

$\mu_u = 2.1979728E-011$

$\nu_u = 2.7468482E-047$

$d = 0.8 \cdot D = 400.00$

$N_u = 7389.214$

$A_g = 196349.541$

From (11.5.4.8), ACI 318-14: $V_s = V_{s1} + V_{s2} = 274157.871$

$V_{s1} = 274157.871$ is calculated for jacket, with:

$A_v = \sqrt{2} \cdot A_{\text{stirrup}} = 123370.055$

$f_y = 555.56$

$s = 100.00$

V_{s1} is multiplied by $\text{Col1} = 1.00$

$s/d = 0.25$

$V_{s2} = 0.00$ is calculated for core, with:

$A_v = \sqrt{2} \cdot A_{\text{stirrup}} = 78956.835$

$f_y = 555.56$

$s = 250.00$

V_{s2} is multiplied by $\text{Col2} = 0.00$

$s/d = 1.04167$

V_f ((11-3)-(11.4), ACI 440) = 0.00

From (11-11), ACI 440: $V_s + V_f \leq 479549.663$

$b_w \cdot d = \sqrt{4} \cdot d \cdot d / 4 = 125663.706$

End Of Calculation of Shear Capacity ratio for element: column JCC1 of floor 1

At local axis: 2

Start Of Calculation of Chord Rotation Capacity for element: column JCC1 of floor 1

At local axis: 3

Integration Section: (a)

Section Type: rcjcs

Constant Properties

Knowledge Factor, $\phi = 1.00$

Chord Rotation is generally considered as Deformation-Controlled Action according to Table C7-1, ASCE 41-17.

Mean strengths are used for Deformation-Controlled Actions according to 7.5.1.3, ASCE 41-17

Consequently:

Jacket

New material of Primary Member: Concrete Strength, $f_c = f_{cm} = 33.00$

New material of Primary Member: Steel Strength, $f_s = f_{sm} = 555.56$

Concrete Elasticity, $E_c = 26999.444$

Steel Elasticity, $E_s = 200000.00$

Existing Column

New material of Primary Member: Concrete Strength, $f_c = f_{cm} = 33.00$

New material of Primary Member: Steel Strength, $f_s = f_{sm} = 555.56$

Concrete Elasticity, $E_c = 26999.444$

Steel Elasticity, $E_s = 200000.00$

External Diameter, $D = 500.00$

Internal Diameter, $D = 300.00$

Cover Thickness, $c = 25.00$

Element Length, $L = 3000.00$

Primary Member

Smooth Bars

Ductile Steel

With Detailing for Earthquake Resistance (including stirrups closed at 135°)

Longitudinal Bars With Ends Lapped Starting at the End Sections
Adequate Lap Length ($l_b/l_d \geq 1$)
No FRP Wrapping

Stepwise Properties

Bending Moment, $M = -2.2535E+007$
Shear Force, $V2 = -7509.70$
Shear Force, $V3 = -5.3669914E-013$
Axial Force, $F = -7386.21$
Longitudinal Reinforcement Area Distribution (in 2 divisions)
-Tension: $As_t = 1272.345$
-Compression: $As_c = 1781.283$
Longitudinal Reinforcement Area Distribution (in 3 divisions)
-Tension: $As_{t,ten} = 1017.876$
-Compression: $As_{c,com} = 1017.876$
-Middle: $As_{mid} = 1017.876$
Mean Diameter of Tension Reinforcement, $Db_L = 18.00$

New component: From table 7-7, ASCE 41_17: Final chord rotation Capacity $u_{,R} = 1.0^*$ $u = 0.01959454$
 $u = y + p = 0.01959454$

- Calculation of y -

 $y = (M_y * L_s / 3) / E_{eff} = 0.01459454$ ((4.29), Biskinis Phd))
 $M_y = 3.6259E+008$
 $L_s = M/V$ (with $L_s > 0.1 * L$ and $L_s < 2 * L$) = 3000.736
From table 10.5, ASCE 41_17: $E_{eff} = factor * E_c * I_g = 2.4850E+013$
 $factor = 0.30$
 $A_g = 196349.541$
Mean concrete strength: $fc' = (fc'_{jacket} * Area_{jacket} + fc'_{core} * Area_{core}) / Area_{section} = 33.00$
 $N = 7386.21$
 $E_c * I_g = E_{c,jacket} * I_{g,jacket} + E_{c,core} * I_{g,core} = 8.2833E+013$

Calculation of Yielding Moment M_y

Calculation of y and M_y according to (7) - (8) in Biskinis and Fardis

 $M_y = \text{Min}(M_{y,ten}, M_{y,com}) = 3.6259E+008$
 y ((10a) or (10b)) = $1.0622306E-005$
 $M_{y,ten}$ (8a) = $3.6259E+008$
 y_{ten} (7a) = 65.43628
error of function (7a) = 0.00293092
 $M_{y,com}$ (8b) = $7.5621E+008$
 y_{com} (7b) = 64.56803
error of function (7b) = -0.00721907
with $e_y = 0.0027778$
 $e_{co} = 0.002$
 $apl = 0.35$ ((9a) in Biskinis and Fardis for no FRP Wrap)
 $d1 = 44.00$
 $R = 250.00$
 $v = 0.00113993$
 $N = 7386.21$
 $A_c = 196349.541$
 $= 0.26182028$
with $fc = 33.00$

Calculation of ratio l_b/l_d

Adequate Lap Length: $l_b/l_d \geq 1$

- Calculation of p -

From table 10-9: $p = 0.005$

with:

- Columns not controlled by inadequate development or splicing along the clear height because $l_b/l_d \geq 1$

shear control ratio $V_{yE}/V_{CoI0E} = 0.54503121$

$d = d_{\text{external}} = 0.00$

$s = s_{\text{external}} = 0.00$

$t = s_1 + s_2 + 2 \cdot t_f/bw \cdot (f_{fe}/f_s) = 0.00323428$

jacket: $s_1 = A_{v1} \cdot (D_{c1}/2) / (s_1 \cdot A_g) = 0.0027646$

$A_{v1} = 78.53982$, is the area of stirrup

$D_{c1} = D_{\text{ext}} - 2 \cdot \text{cover} - \text{External Hoop Diameter} = 440.00$, is the total Length of all stirrups parallel to loading

(shear) direction

$s_1 = 100.00$

core: $s_2 = A_{v2} \cdot (D_{c2}/2) / (s_2 \cdot A_g) = 0.00046968$

$A_{v2} = 50.26548$, is the area of stirrup

$D_{c2} = D_{\text{int}} - \text{Internal Hoop Diameter} = 292.00$, is the total Length of all stirrups parallel to loading (shear)

direction

$s_2 = 250.00$

The term $2 \cdot t_f/bw \cdot (f_{fe}/f_s)$ is implemented to account for FRP contribution

where $f = 2 \cdot t_f/bw$ is FRP ratio (EC8 - 3, A.4.4.3(6)) and f_{fe}/f_s normalises f to steel strength

All these variables have already been given in Shear control ratio calculation.

For the normalisation f_s of jacket is used.

$N_{UD} = 7386.21$

$A_g = 196349.541$

$f_{cE} = (f_{c,jacket} \cdot \text{Area}_{jacket} + f_{c,core} \cdot \text{Area}_{core}) / \text{section_area} = 33.00$

$f_{yIE} = (f_{y,ext_Long_Reinf} \cdot \text{Area}_{ext_Long_Reinf} + f_{y,int_Long_Reinf} \cdot \text{Area}_{int_Long_Reinf}) / \text{Area}_{Tot_Long_Rein} = 2.1219958E-314$

$f_{yIE} = (f_{y,ext_Trans_Reinf} \cdot \text{Area}_{ext_Trans_Reinf} + f_{y,int_Trans_Reinf} \cdot \text{Area}_{int_Trans_Reinf}) / \text{Area}_{Tot_Trans_Rein} = 555.56$

$p_l = \text{Area}_{Tot_Long_Rein} / (A_g) = 0.015552$

$f_{cE} = 33.00$

End Of Calculation of Chord Rotation Capacity for element: column JCC1 of floor 1

At local axis: 3

Integration Section: (a)

Calculation No. 5

column C1, Floor 1



Limit State: Immediate Occupancy (data interpolation between analysis steps 1 and 2)

Analysis: Uniform +X

Check: Shear capacity V_{Rd}

Edge: End

Local Axis: (2)



Start Of Calculation of Shear Capacity for element: column JCC1 of floor 1

At local axis: 2

Integration Section: (b)

Section Type: rcjcs

Constant Properties

Knowledge Factor, $\gamma = 1.00$

Member Shear Force is generally considered as Force-Controlled Action according to Table C7-1, ASCE 41-17.

Lower-bound strengths are used for Force-Controlled Actions according to 7.5.1.3, ASCE 41-17

Consequently:

Jacket

New material of Primary Member: Concrete Strength, $f_c = f_{c_lower_bound} = 25.00$

New material of Primary Member: Steel Strength, $f_s = f_{s_lower_bound} = 500.00$

Concrete Elasticity, $E_c = 26999.444$

Steel Elasticity, $E_s = 200000.00$

Existing Column

New material of Primary Member: Concrete Strength, $f_c = f_{c_lower_bound} = 25.00$

New material of Primary Member: Steel Strength, $f_s = f_{s_lower_bound} = 500.00$

Concrete Elasticity, $E_c = 26999.444$

Steel Elasticity, $E_s = 200000.00$

#####

Note: Especially for the calculation of γ for displacement ductility demand, the expected (mean value) strengths are used (7.5.1.3, ASCE 41-17) because bending is considered as Deformation-Controlled Action (Table C7-1, ASCE 41-17).

Jacket

New material: Concrete Strength, $f_c = f_{cm} = 33.00$

New material: Steel Strength, $f_s = f_{sm} = 555.56$

Existing Column

New material: Concrete Strength, $f_c = f_{cm} = 33.00$

New material: Steel Strength, $f_s = f_{sm} = 555.56$

#####

External Diameter, $D = 500.00$

Internal Diameter, $D = 300.00$

Cover Thickness, $c = 25.00$

Element Length, $L = 3000.00$

Primary Member

Smooth Bars

Ductile Steel

With Detailing for Earthquake Resistance (including stirrups closed at 135°)

Longitudinal Bars With Ends Lapped Starting at the End Sections

Adequate Lap Length ($l_o/l_{o,u,min} = l_b/l_d \geq 1$)

No FRP Wrapping

Stepwise Properties

EDGE -A-

Bending Moment, $M_a = -2.2535E+007$

Shear Force, $V_a = -7509.70$

EDGE -B-

Bending Moment, $M_b = 0.03802603$

Shear Force, $V_b = 7509.70$
 BOTH EDGES
 Axial Force, $F = -7386.21$
 Longitudinal Reinforcement Area Distribution (in 2 divisions)
 -Tension: $As_t = 0.00$
 -Compression: $As_c = 3053.628$
 Longitudinal Reinforcement Area Distribution (in 3 divisions)
 -Tension: $As_{t,ten} = 1017.876$
 -Compression: $As_{c,com} = 1017.876$
 -Middle: $As_{c,mid} = 1017.876$
 Mean Diameter of Tension Reinforcement, $Db_{L,ten} = 18.00$

New component: From table 7-7, ASCE 41_17: Final Shear Capacity $V_R = 1.0 \cdot V_n = 443865.445$
 V_n ((10.3), ASCE 41-17) = $k_n \cdot V_{CoI0} = 443865.445$
 $V_{CoI} = 443865.445$
 $k_n = 1.00$
 $displacement_ductility_demand = 0.09321537$

NOTE: In expression (10-3) ' $V_s = A_v \cdot f_y \cdot d / s$ ' is replaced by ' $V_s + f \cdot V_f$ '
 where V_f is the contribution of FRPs (11.3), ACI 440).

= 1 (normal-weight concrete)
 Mean concrete strength: $f'_c = (f'_{c,jacket} \cdot Area_{jacket} + f'_{c,core} \cdot Area_{core}) / Area_{section} = 25.00$, but $f'_c^{0.5} \leq 8.3$
 MPa (22.5.3.1, ACI 318-14)
 $M/Vd = 2.00$
 $\mu_u = 0.03802603$
 $V_u = 7509.70$
 $d = 0.8 \cdot D = 400.00$
 $N_u = 7386.21$
 $A_g = 196349.541$
 From (11.5.4.8), ACI 318-14: $V_s = V_{s1} + V_{s2} = 246740.11$
 $V_{s1} = 246740.11$ is calculated for jacket, with:
 $A_v = \sqrt{2} \cdot A_{stirrup} = 123370.055$
 $f_y = 500.00$
 $s = 100.00$
 V_{s1} is multiplied by $Col1 = 1.00$
 $s/d = 0.25$
 $V_{s2} = 0.00$ is calculated for core, with:
 $A_v = \sqrt{2} \cdot A_{stirrup} = 78956.835$
 $f_y = 500.00$
 $s = 250.00$
 V_{s2} is multiplied by $Col2 = 0.00$
 $s/d = 1.04167$
 V_f ((11-3)-(11.4), ACI 440) = 0.00
 From (11-11), ACI 440: $V_s + V_f \leq 417394.406$
 $b_w \cdot d = \sqrt{N_u} \cdot d / 4 = 125663.706$

$displacement_ductility_demand$ is calculated as μ / y

- Calculation of μ / y for END B -
 for rotation axis 3 and integ. section (b)

From analysis, chord rotation $\theta = 0.00013601$
 $y = (M_y \cdot L_s / 3) / E_{eff} = 0.0014591$ ((4.29), Biskinis Phd))
 $M_y = 3.6259E+008$
 $L_s = M/V$ (with $L_s > 0.1 \cdot L$ and $L_s < 2 \cdot L$) = 300.00
 From table 10.5, ASCE 41_17: $E_{eff} = factor \cdot E_c \cdot I_g = 2.4850E+013$
 $factor = 0.30$
 $A_g = 196349.541$
 Mean concrete strength: $f'_c = (f'_{c,jacket} \cdot Area_{jacket} + f'_{c,core} \cdot Area_{core}) / Area_{section} = 33.00$
 $N = 7386.21$
 $E_c \cdot I_g = E_{c,jacket} \cdot I_{g,jacket} + E_{c,core} \cdot I_{g,core} = 8.2833E+013$

Calculation of Yielding Moment M_y

Calculation of ρ_y and M_y according to (7) - (8) in Biskinis and Fardis

$M_y = \text{Min}(M_{y_ten}, M_{y_com}) = 3.6259E+008$

$\rho_y \text{ ((10a) or (10b))} = 1.0622306E-005$

$M_{y_ten} \text{ (8a)} = 3.6259E+008$

$\rho_{y_ten} \text{ (7a)} = 65.43628$

error of function (7a) = 0.00293092

$M_{y_com} \text{ (8b)} = 7.5621E+008$

$\rho_{y_com} \text{ (7b)} = 64.56803$

error of function (7b) = -0.00721907

with $e_y = 0.0027778$

$e_{co} = 0.002$

$a_{pl} = 0.35 \text{ ((9a) in Biskinis and Fardis for no FRP Wrap)}$

$d_1 = 44.00$

$R = 250.00$

$v = 0.00113993$

$N = 7386.21$

$A_c = 196349.541$

$= 0.26182028$

with $f_c = 33.00$

Calculation of ratio l_b/d

Adequate Lap Length: $l_b/d \geq 1$

End Of Calculation of Shear Capacity for element: column JCC1 of floor 1

At local axis: 2

Integration Section: (b)

Calculation No. 6

column C1, Floor 1



Limit State: Immediate Occupancy (data interpolation between analysis steps 1 and 2)

Analysis: Uniform +X

Check: Chord rotation capacity (ρ_u)

Edge: End

Local Axis: (2)



Start Of Calculation of Shear Capacity ratio for element: column JCC1 of floor 1

At Shear local axis: 3
 (Bending local axis: 2)
 Section Type: rcjcs

Constant Properties

Knowledge Factor, $\gamma = 1.00$
 Mean strength values are used for both shear and moment calculations.
 Consequently:

Jacket

New material of Primary Member: Concrete Strength, $f_c = f_{cm} = 33.00$
 New material of Primary Member: Steel Strength, $f_s = f_{sm} = 555.56$
 Concrete Elasticity, $E_c = 26999.444$
 Steel Elasticity, $E_s = 200000.00$

Existing Column

New material of Primary Member: Concrete Strength, $f_c = f_{cm} = 33.00$
 New material of Primary Member: Steel Strength, $f_s = f_{sm} = 555.56$
 Concrete Elasticity, $E_c = 26999.444$
 Steel Elasticity, $E_s = 200000.00$

#####

Note: Especially for the calculation of moment strengths,
 the above steel re-bar strengths are multiplied by 1.25 according to R18.6.5, ACI 318-14

Jacket

New material: Steel Strength, $f_s = 1.25 \cdot f_{sm} = 694.45$

Existing Column

New material: Steel Strength, $f_s = 1.25 \cdot f_{sm} = 694.45$

#####

External Diameter, $D = 500.00$

Internal Diameter, $D = 300.00$

Cover Thickness, $c = 25.00$

Mean Confinement Factor overall section = 1.30349

Element Length, $L = 3000.00$

Primary Member

Smooth Bars

Ductile Steel

With Detailing for Earthquake Resistance (including stirrups closed at 135°)

Longitudinal Bars With Ends Lapped Starting at the End Sections

Adequate Lap Length ($l_o/l_{ou, \min} >= 1$)

No FRP Wrapping

Stepwise Properties

At local axis: 3

EDGE -A-

Shear Force, $V_a = 4.4860917E-031$

EDGE -B-

Shear Force, $V_b = -4.4860917E-031$

BOTH EDGES

Axial Force, $F = -7389.214$

Longitudinal Reinforcement Area Distribution (in 2 divisions)

-Tension: Aslt = 0.00

-Compression: Aslc = 3053.628

Longitudinal Reinforcement Area Distribution (in 3 divisions)

-Tension: Asl,ten = 1017.876

-Compression: Asl,com = 1017.876

-Middle: Asl,mid = 1017.876

Calculation of Shear Capacity ratio , $V_e/V_r = 0.54503121$

Member Controlled by Flexure ($V_e/V_r < 1$)

Calculation of Shear Demand from fig. R18.6.5, ACI 318-14 $V_e = (M_{pr1} + M_{pr2})/l_n = 272744.406$

with

$M_{pr1} = \text{Max}(M_{u1+} , M_{u1-}) = 4.0912E+008$

$M_{u1+} = 4.0912E+008$, is the ultimate moment strength at the edge 1 of the member in the actual moment direction which is defined for the static loading combination

$M_{u1-} = 4.0912E+008$, is the ultimate moment strength at the edge 1 of the member in the opposite moment direction which is defined for the static loading combination

$M_{pr2} = \text{Max}(M_{u2+} , M_{u2-}) = 4.0912E+008$

$M_{u2+} = 4.0912E+008$, is the ultimate moment strength at the edge 2 of the member in the actual moment direction which is defined for the the static loading combination

$M_{u2-} = 4.0912E+008$, is the ultimate moment strength at the edge 2 of the member in the opposite moment direction which is defined for the the static loading combination

Calculation of M_{u1+}

Calculation of ultimate Moment Strength ((3.67), Biskinis Phd), M_u

$M_u = 4.0912E+008$

$\phi = 0.97738438$

$\lambda = 0.86668818$

error of function (3.68), Biskinis Phd = 94694.946

From 5A.2, TBDY: $f_{cc} = f_c \cdot c = 43.01531$

conf. factor $c = 1.30349$

$f_c = 33.00$

From 10.3.5, ASCE 41-17, Final value of f_y : $f_y \cdot \text{Min}(1, 1.25 \cdot (l_b/d)^{2/3}) = 694.45$

$l_b/d = 1.00$

$d_1 = 44.00$

$R = 250.00$

$v = 0.0011401$

$N = 7389.214$

$A_c = 196349.541$

$\phi \cdot \text{Min}(1, 1.25 \cdot (l_b/d)^{2/3}) = 0.26182028$

Calculation of ratio l_b/d

Adequate Lap Length: $l_b/d \geq 1$

Calculation of M_{u1-}

Calculation of ultimate Moment Strength ((3.67), Biskinis Phd), M_u

$M_u = 4.0912E+008$

$\phi = 0.97738438$

$\lambda = 0.86668818$

error of function (3.68), Biskinis Phd = 94694.946

From 5A.2, TBDY: $f_{cc} = f_c \cdot c = 43.01531$

conf. factor $c = 1.30349$

fc = 33.00

From 10.3.5, ASCE 41-17, Final value of fy: $f_y \cdot \text{Min}(1, 1.25 \cdot (l_b/d)^{2/3}) = 694.45$

lb/d = 1.00

d1 = 44.00

R = 250.00

v = 0.0011401

N = 7389.214

Ac = 196349.541

= $\text{Min}(1, 1.25 \cdot (l_b/d)^{2/3}) = 0.26182028$

Calculation of ratio lb/d

Adequate Lap Length: $l_b/d \geq 1$

Calculation of Mu2+

Calculation of ultimate Moment Strength ((3.67), Biskinis Phd), Mu

Mu = 4.0912E+008

= 0.97738438

' = 0.86668818

error of function (3.68), Biskinis Phd = 94694.946

From 5A.2, TBDY: $f_{cc} = f_c \cdot c = 43.01531$

conf. factor c = 1.30349

fc = 33.00

From 10.3.5, ASCE 41-17, Final value of fy: $f_y \cdot \text{Min}(1, 1.25 \cdot (l_b/d)^{2/3}) = 694.45$

lb/d = 1.00

d1 = 44.00

R = 250.00

v = 0.0011401

N = 7389.214

Ac = 196349.541

= $\text{Min}(1, 1.25 \cdot (l_b/d)^{2/3}) = 0.26182028$

Calculation of ratio lb/d

Adequate Lap Length: $l_b/d \geq 1$

Calculation of Mu2-

Calculation of ultimate Moment Strength ((3.67), Biskinis Phd), Mu

Mu = 4.0912E+008

= 0.97738438

' = 0.86668818

error of function (3.68), Biskinis Phd = 94694.946

From 5A.2, TBDY: $f_{cc} = f_c \cdot c = 43.01531$

conf. factor c = 1.30349

fc = 33.00

From 10.3.5, ASCE 41-17, Final value of fy: $f_y \cdot \text{Min}(1, 1.25 \cdot (l_b/d)^{2/3}) = 694.45$

lb/d = 1.00

d1 = 44.00

R = 250.00

v = 0.0011401

N = 7389.214

Ac = 196349.541

= $\text{Min}(1, 1.25 \cdot (l_b/d)^{2/3}) = 0.26182028$

Calculation of ratio l_b/d

Adequate Lap Length: $l_b/d \geq 1$

Calculation of Shear Strength $V_r = \text{Min}(V_{r1}, V_{r2}) = 500419.792$

Calculation of Shear Strength at edge 1, $V_{r1} = 500419.792$

$V_{r1} = V_{Col} \text{ ((10.3), ASCE 41-17)} = k_n l V_{Col0}$

$V_{Col0} = 500419.792$

$k_n l = 1$ (zero step-static loading)

NOTE: In expression (10-3) ' $V_s = A_v f_y d/s$ ' is replaced by ' $V_s + f^* V_f$ ' where V_f is the contribution of FRPs (11.3), ACI 440).

$= 1$ (normal-weight concrete)

Mean concrete strength: $f_c' = (f_c'_{jacket} \text{Area}_{jacket} + f_c'_{core} \text{Area}_{core}) / \text{Area}_{section} = 33.00$, but $f_c'^{0.5} \leq 8.3$ MPa (22.5.3.1, ACI 318-14)

$M/Vd = 2.00$

$\mu_u = 2.5382294E-011$

$\nu_u = 4.4860917E-031$

$d = 0.8 \cdot D = 400.00$

$N_u = 7389.214$

$A_g = 196349.541$

From (11.5.4.8), ACI 318-14: $V_s = V_{s1} + V_{s2} = 274157.871$

$V_{s1} = 274157.871$ is calculated for jacket, with:

$A_v = \sqrt{2} \cdot A_{stirrup} = 123370.055$

$f_y = 555.56$

$s = 100.00$

V_{s1} is multiplied by $Col1 = 1.00$

$s/d = 0.25$

$V_{s2} = 0.00$ is calculated for core, with:

$A_v = \sqrt{2} \cdot A_{stirrup} = 78956.835$

$f_y = 555.56$

$s = 250.00$

V_{s2} is multiplied by $Col2 = 0.00$

$s/d = 1.04167$

$V_f \text{ ((11-3)-(11.4), ACI 440)} = 0.00$

From (11-11), ACI 440: $V_s + V_f \leq 479549.663$

$b_w \cdot d = \frac{1}{4} \cdot d \cdot d = 125663.706$

Calculation of Shear Strength at edge 2, $V_{r2} = 500419.792$

$V_{r2} = V_{Col} \text{ ((10.3), ASCE 41-17)} = k_n l V_{Col0}$

$V_{Col0} = 500419.792$

$k_n l = 1$ (zero step-static loading)

NOTE: In expression (10-3) ' $V_s = A_v f_y d/s$ ' is replaced by ' $V_s + f^* V_f$ ' where V_f is the contribution of FRPs (11.3), ACI 440).

$= 1$ (normal-weight concrete)

Mean concrete strength: $f_c' = (f_c'_{jacket} \text{Area}_{jacket} + f_c'_{core} \text{Area}_{core}) / \text{Area}_{section} = 33.00$, but $f_c'^{0.5} \leq 8.3$ MPa (22.5.3.1, ACI 318-14)

$M/Vd = 2.00$

$\mu_u = 2.5382294E-011$

$\nu_u = 4.4860917E-031$

$d = 0.8 \cdot D = 400.00$

$N_u = 7389.214$

$A_g = 196349.541$

From (11.5.4.8), ACI 318-14: $V_s = V_{s1} + V_{s2} = 274157.871$

$V_{s1} = 274157.871$ is calculated for jacket, with:

$A_v = \sqrt{2} \cdot A_{stirrup} = 123370.055$

$f_y = 555.56$

s = 100.00
Vs1 is multiplied by Col1 = 1.00
s/d = 0.25
Vs2 = 0.00 is calculated for core, with:
Av = $\sqrt{2} \cdot A_{stirrup} = 78956.835$
fy = 555.56
s = 250.00
Vs2 is multiplied by Col2 = 0.00
s/d = 1.04167
Vf ((11-3)-(11.4), ACI 440) = 0.00
From (11-11), ACI 440: Vs + Vf <= 479549.663
bw*d = $\sqrt{d} \cdot d / 4 = 125663.706$

End Of Calculation of Shear Capacity ratio for element: column JCC1 of floor 1
At local axis: 3

Start Of Calculation of Shear Capacity ratio for element: column JCC1 of floor 1
At Shear local axis: 2
(Bending local axis: 3)
Section Type: rcjcs

Constant Properties

Knowledge Factor, $\gamma = 1.00$
Mean strength values are used for both shear and moment calculations.
Consequently:
Jacket
New material of Primary Member: Concrete Strength, $f_c = f_{cm} = 33.00$
New material of Primary Member: Steel Strength, $f_s = f_{sm} = 555.56$
Concrete Elasticity, $E_c = 26999.444$
Steel Elasticity, $E_s = 200000.00$
Existing Column
New material of Primary Member: Concrete Strength, $f_c = f_{cm} = 33.00$
New material of Primary Member: Steel Strength, $f_s = f_{sm} = 555.56$
Concrete Elasticity, $E_c = 26999.444$
Steel Elasticity, $E_s = 200000.00$

Note: Especially for the calculation of moment strengths,
the above steel re-bar strengths are multiplied by 1.25 according to R18.6.5, ACI 318-14
Jacket
New material: Steel Strength, $f_s = 1.25 \cdot f_{sm} = 694.45$
Existing Column
New material: Steel Strength, $f_s = 1.25 \cdot f_{sm} = 694.45$

External Diameter, D = 500.00
Internal Diameter, D = 300.00
Cover Thickness, c = 25.00
Mean Confinement Factor overall section = 1.30349
Element Length, L = 3000.00
Primary Member
Smooth Bars
Ductile Steel
With Detailing for Earthquake Resistance (including stirrups closed at 135°)
Longitudinal Bars With Ends Lapped Starting at the End Sections
Adequate Lap Length ($l_o/l_{ou}, \min >= 1$)
No FRP Wrapping

Stepwise Properties

At local axis: 2
EDGE -A-
Shear Force, Va = -2.7468482E-047

EDGE -B-

Shear Force, $V_b = 2.7468482E-047$

BOTH EDGES

Axial Force, $F = -7389.214$

Longitudinal Reinforcement Area Distribution (in 2 divisions)

-Tension: $A_{st} = 0.00$

-Compression: $A_{sc} = 3053.628$

Longitudinal Reinforcement Area Distribution (in 3 divisions)

-Tension: $A_{st,ten} = 1017.876$

-Compression: $A_{sc,com} = 1017.876$

-Middle: $A_{st,mid} = 1017.876$

Calculation of Shear Capacity ratio, $V_e/V_r = 0.54503121$

Member Controlled by Flexure ($V_e/V_r < 1$)

Calculation of Shear Demand from fig. R18.6.5, ACI 318-14 $V_e = (M_{pr1} + M_{pr2})/l_n = 272744.406$

with

$M_{pr1} = \text{Max}(M_{u1+}, M_{u1-}) = 4.0912E+008$

$M_{u1+} = 4.0912E+008$, is the ultimate moment strength at the edge 1 of the member in the actual moment direction which is defined for the static loading combination

$M_{u1-} = 4.0912E+008$, is the ultimate moment strength at the edge 1 of the member in the opposite moment direction which is defined for the static loading combination

$M_{pr2} = \text{Max}(M_{u2+}, M_{u2-}) = 4.0912E+008$

$M_{u2+} = 4.0912E+008$, is the ultimate moment strength at the edge 2 of the member in the actual moment direction which is defined for the the static loading combination

$M_{u2-} = 4.0912E+008$, is the ultimate moment strength at the edge 2 of the member in the opposite moment direction which is defined for the the static loading combination

Calculation of M_{u1+}

Calculation of ultimate Moment Strength ((3.67), Biskinis Phd), M_u

$M_u = 4.0912E+008$

$\phi = 0.97738438$

$\phi' = 0.86668818$

error of function (3.68), Biskinis Phd = 94694.946

From 5A.2, TBDY: $f_{cc} = f_c \cdot c = 43.01531$

conf. factor $c = 1.30349$

$f_c = 33.00$

From 10.3.5, ASCE 41-17, Final value of f_y : $f_y \cdot \text{Min}(1, 1.25 \cdot (l_b/d)^{2/3}) = 694.45$

$l_b/d = 1.00$

$d_1 = 44.00$

$R = 250.00$

$v = 0.0011401$

$N = 7389.214$

$A_c = 196349.541$

$\phi \cdot \text{Min}(1, 1.25 \cdot (l_b/d)^{2/3}) = 0.26182028$

Calculation of ratio l_b/d

Adequate Lap Length: $l_b/d \geq 1$

Calculation of M_{u1-}

Calculation of ultimate Moment Strength ((3.67), Biskinis Phd), M_u

$M_u = 4.0912E+008$

= 0.97738438
' = 0.86668818
error of function (3.68), Biskinis Phd = 94694.946
From 5A.2, TBDY: $f_{cc} = f_c \cdot c = 43.01531$
conf. factor $c = 1.30349$
 $f_c = 33.00$
From 10.3.5, ASCE 41-17, Final value of f_y : $f_y \cdot \text{Min}(1, 1.25 \cdot (l_b/d)^{2/3}) = 694.45$
 $l_b/d = 1.00$
 $d_1 = 44.00$
 $R = 250.00$
 $v = 0.0011401$
 $N = 7389.214$
 $A_c = 196349.541$
 $= \cdot \text{Min}(1, 1.25 \cdot (l_b/d)^{2/3}) = 0.26182028$

Calculation of ratio l_b/d

Adequate Lap Length: $l_b/d \geq 1$

Calculation of μ_{2+}

Calculation of ultimate Moment Strength ((3.67), Biskinis Phd), μ
 $\mu = 4.0912E+008$

= 0.97738438
' = 0.86668818
error of function (3.68), Biskinis Phd = 94694.946
From 5A.2, TBDY: $f_{cc} = f_c \cdot c = 43.01531$
conf. factor $c = 1.30349$
 $f_c = 33.00$
From 10.3.5, ASCE 41-17, Final value of f_y : $f_y \cdot \text{Min}(1, 1.25 \cdot (l_b/d)^{2/3}) = 694.45$
 $l_b/d = 1.00$
 $d_1 = 44.00$
 $R = 250.00$
 $v = 0.0011401$
 $N = 7389.214$
 $A_c = 196349.541$
 $= \cdot \text{Min}(1, 1.25 \cdot (l_b/d)^{2/3}) = 0.26182028$

Calculation of ratio l_b/d

Adequate Lap Length: $l_b/d \geq 1$

Calculation of μ_{2-}

Calculation of ultimate Moment Strength ((3.67), Biskinis Phd), μ
 $\mu = 4.0912E+008$

= 0.97738438
' = 0.86668818
error of function (3.68), Biskinis Phd = 94694.946
From 5A.2, TBDY: $f_{cc} = f_c \cdot c = 43.01531$
conf. factor $c = 1.30349$
 $f_c = 33.00$
From 10.3.5, ASCE 41-17, Final value of f_y : $f_y \cdot \text{Min}(1, 1.25 \cdot (l_b/d)^{2/3}) = 694.45$
 $l_b/d = 1.00$
 $d_1 = 44.00$

R = 250.00
v = 0.0011401
N = 7389.214
Ac = 196349.541
= *Min(1,1.25*(lb/d)^ 2/3) = 0.26182028

Calculation of ratio lb/d

Adequate Lap Length: lb/d >= 1

Calculation of Shear Strength Vr = Min(Vr1,Vr2) = 500419.792

Calculation of Shear Strength at edge 1, Vr1 = 500419.792

Vr1 = VCol ((10.3), ASCE 41-17) = knl*VCol0

VCol0 = 500419.792

knl = 1 (zero step-static loading)

NOTE: In expression (10-3) 'Vs = Av*fy*d/s' is replaced by 'Vs+ f*Vf'
where Vf is the contribution of FRPs (11.3), ACI 440).

= 1 (normal-weight concrete)

Mean concrete strength: fc' = (fc'_jacket*Area_jacket + fc'_core*Area_core)/Area_section = 33.00, but fc'^0.5 <= 8.3
MPa (22.5.3.1, ACI 318-14)

M/Vd = 2.00

Mu = 2.1979728E-011

Vu = 2.7468482E-047

d = 0.8*D = 400.00

Nu = 7389.214

Ag = 196349.541

From (11.5.4.8), ACI 318-14: Vs = Vs1 + Vs2 = 274157.871

Vs1 = 274157.871 is calculated for jacket, with:

Av = /2*A_stirrup = 123370.055

fy = 555.56

s = 100.00

Vs1 is multiplied by Col1 = 1.00

s/d = 0.25

Vs2 = 0.00 is calculated for core, with:

Av = /2*A_stirrup = 78956.835

fy = 555.56

s = 250.00

Vs2 is multiplied by Col2 = 0.00

s/d = 1.04167

Vf ((11-3)-(11.4), ACI 440) = 0.00

From (11-11), ACI 440: Vs + Vf <= 479549.663

bw*d = *d*d/4 = 125663.706

Calculation of Shear Strength at edge 2, Vr2 = 500419.792

Vr2 = VCol ((10.3), ASCE 41-17) = knl*VCol0

VCol0 = 500419.792

knl = 1 (zero step-static loading)

NOTE: In expression (10-3) 'Vs = Av*fy*d/s' is replaced by 'Vs+ f*Vf'
where Vf is the contribution of FRPs (11.3), ACI 440).

= 1 (normal-weight concrete)

Mean concrete strength: fc' = (fc'_jacket*Area_jacket + fc'_core*Area_core)/Area_section = 33.00, but fc'^0.5 <= 8.3
MPa (22.5.3.1, ACI 318-14)

M/Vd = 2.00

Mu = 2.1979728E-011

Vu = 2.7468482E-047

d = 0.8*D = 400.00

Nu = 7389.214

Ag = 196349.541

From (11.5.4.8), ACI 318-14: Vs = Vs1 + Vs2 = 274157.871

Vs1 = 274157.871 is calculated for jacket, with:

$A_v = \frac{1}{2} A_{stirrup} = 123370.055$

fy = 555.56

s = 100.00

Vs1 is multiplied by Col1 = 1.00

s/d = 0.25

Vs2 = 0.00 is calculated for core, with:

$A_v = \frac{1}{2} A_{stirrup} = 78956.835$

fy = 555.56

s = 250.00

Vs2 is multiplied by Col2 = 0.00

s/d = 1.04167

Vf ((11-3)-(11.4), ACI 440) = 0.00

From (11-11), ACI 440: Vs + Vf <= 479549.663

$b_w * d = \frac{1}{4} * d * d = 125663.706$

End Of Calculation of Shear Capacity ratio for element: column JCC1 of floor 1
At local axis: 2

Start Of Calculation of Chord Rotation Capacity for element: column JCC1 of floor 1
At local axis: 2
Integration Section: (b)
Section Type: rcjcs

Constant Properties

Knowledge Factor, = 1.00

Chord Rotation is generally considered as Deformation-Controlled Action according to Table C7-1, ASCE 41-17.

Mean strengths are used for Deformation-Controlled Actions according to 7.5.1.3, ASCE 41-17

Consequently:

Jacket

New material of Primary Member: Concrete Strength, fc = fcm = 33.00

New material of Primary Member: Steel Strength, fs = fsm = 555.56

Concrete Elasticity, Ec = 26999.444

Steel Elasticity, Es = 200000.00

Existing Column

New material of Primary Member: Concrete Strength, fc = fcm = 33.00

New material of Primary Member: Steel Strength, fs = fsm = 555.56

Concrete Elasticity, Ec = 26999.444

Steel Elasticity, Es = 200000.00

External Diameter, D = 500.00

Internal Diameter, D = 300.00

Cover Thickness, c = 25.00

Element Length, L = 3000.00

Primary Member

Smooth Bars

Ductile Steel

With Detailing for Earthquake Resistance (including stirrups closed at 135°)

Longitudinal Bars With Ends Lapped Starting at the End Sections

Adequate Lap Length (lb/d >= 1)

No FRP Wrapping

Stepwise Properties

Bending Moment, M = 7.1693020E-011

Shear Force, V2 = 7509.70

Shear Force, V3 = 5.3669914E-013

Axial Force, F = -7386.21

Longitudinal Reinforcement Area Distribution (in 2 divisions)

-Tension: Aslt = 0.00

-Compression: $As_c = 3053.628$

Longitudinal Reinforcement Area Distribution (in 3 divisions)

-Tension: $As_{t,ten} = 1017.876$

-Compression: $As_{c,com} = 1017.876$

-Middle: $As_{c,mid} = 1017.876$

Mean Diameter of Tension Reinforcement, $Db_L = 18.00$

New component: From table 7-7, ASCE 41_17: Final chord rotation Capacity $u_{,R} = 1.0^*$ $u = 0.01229548$

$u = y + p = 0.01229548$

- Calculation of y -

$y = (My * L_s / 3) / E_{eff} = 0.00729548$ ((4.29), Biskinis Phd)

$My = 3.6259E+008$

$L_s = M/V$ (with $L_s > 0.1 * L$ and $L_s < 2 * L$) = 1500.00

From table 10.5, ASCE 41_17: $E_{eff} = factor * E_c * I_g = 2.4850E+013$

factor = 0.30

$A_g = 196349.541$

Mean concrete strength: $fc' = (fc'_{jacket} * Area_{jacket} + fc'_{core} * Area_{core}) / Area_{section} = 33.00$

$N = 7386.21$

$E_c * I_g = E_{c,jacket} * I_{g,jacket} + E_{c,core} * I_{g,core} = 8.2833E+013$

Calculation of Yielding Moment My

Calculation of y and My according to (7) - (8) in Biskinis and Fardis

$My = \min(My_{ten}, My_{com}) = 3.6259E+008$

y ((10a) or (10b)) = $1.0622306E-005$

My_{ten} (8a) = $3.6259E+008$

y_{ten} (7a) = 65.43628

error of function (7a) = 0.00293092

My_{com} (8b) = $7.5621E+008$

y_{com} (7b) = 64.56803

error of function (7b) = -0.00721907

with $e_y = 0.0027778$

$e_{co} = 0.002$

$apl = 0.35$ ((9a) in Biskinis and Fardis for no FRP Wrap)

$d_1 = 44.00$

$R = 250.00$

$v = 0.00113993$

$N = 7386.21$

$A_c = 196349.541$

= 0.26182028

with $fc = 33.00$

Calculation of ratio l_b/d

Adequate Lap Length: $l_b/d \geq 1$

- Calculation of p -

From table 10-9: $p = 0.005$

with:

- Columns not controlled by inadequate development or splicing along the clear height because $l_b/d \geq 1$

shear control ratio $V_y E / C_o I_{OE} = 0.54503121$

$d = d_{external} = 0.00$

$s = s_{external} = 0.00$

$t = s_1 + s_2 + 2 * t_f / bw * (f_f / f_s) = 0.00323428$


jacket: $s_1 = A_{v1} * (D_c / 2) / (s_1 * A_g) = 0.0027646$

$Av1 = 78.53982$, is the area of stirrup
 $Dc1 = D_{ext} - 2 \cdot cover - \text{External Hoop Diameter} = 440.00$, is the total Length of all stirrups parallel to loading (shear) direction
 $s1 = 100.00$
 core: $s2 = Av2 \cdot (Dc2/2) / (s2 \cdot Ag) = 0.00046968$
 $Av2 = 50.26548$, is the area of stirrup
 $Dc2 = D_{int} - \text{Internal Hoop Diameter} = 292.00$, is the total Length of all stirrups parallel to loading (shear) direction
 $s2 = 250.00$
 The term $2 \cdot t_f / b_w \cdot (f_{fe} / f_s)$ is implemented to account for FRP contribution where $f = 2 \cdot t_f / b_w$ is FRP ratio (EC8 - 3, A.4.4.3(6)) and f_{fe} / f_s normalises f to steel strength. All these variables have already been given in Shear control ratio calculation. For the normalisation f_s of jacket is used.
 $NUD = 7386.21$
 $Ag = 196349.541$
 $f_{cE} = (f_{c,jacket} \cdot Area_{jacket} + f_{c,core} \cdot Area_{core}) / section_area = 33.00$
 $f_{yE} = (f_{y,ext_Long_Reinf} \cdot Area_{ext_Long_Reinf} + f_{y,int_Long_Reinf} \cdot Area_{int_Long_Reinf}) / Area_{Tot_Long_Rein} = 2.1219958E-314$
 $f_{yE} = (f_{y,ext_Trans_Reinf} \cdot Area_{ext_Trans_Reinf} + f_{y,int_Trans_Reinf} \cdot Area_{int_Trans_Reinf}) / Area_{Tot_Trans_Rein} = 555.56$
 $pl = Area_{Tot_Long_Rein} / (Ag) = 0.015552$
 $f_{cE} = 33.00$

 End Of Calculation of Chord Rotation Capacity for element: column JCC1 of floor 1
 At local axis: 2
 Integration Section: (b)

Calculation No. 7

column C1, Floor 1
 Limit State: Immediate Occupancy (data interpolation between analysis steps 1 and 2)
 Analysis: Uniform +X
 Check: Shear capacity V_{Rd}
 Edge: End
 Local Axis: (3)



Start Of Calculation of Shear Capacity for element: column JCC1 of floor 1

At local axis: 3
Integration Section: (b)
Section Type: rcjcs

Constant Properties

Knowledge Factor, $\gamma = 1.00$
Member Shear Force is generally considered as Force-Controlled Action according to Table C7-1, ASCE 41-17.
Lower-bound strengths are used for Force-Controlled Actions according to 7.5.1.3, ASCE 41-17

Consequently:

Jacket

New material of Primary Member: Concrete Strength, $f_c = f_{c_lower_bound} = 25.00$

New material of Primary Member: Steel Strength, $f_s = f_{s_lower_bound} = 500.00$

Concrete Elasticity, $E_c = 26999.444$

Steel Elasticity, $E_s = 200000.00$

Existing Column

New material of Primary Member: Concrete Strength, $f_c = f_{c_lower_bound} = 25.00$

New material of Primary Member: Steel Strength, $f_s = f_{s_lower_bound} = 500.00$

Concrete Elasticity, $E_c = 26999.444$

Steel Elasticity, $E_s = 200000.00$

#####

Note: Especially for the calculation of γ for displacement ductility demand,
the expected (mean value) strengths are used (7.5.1.3, ASCE 41-17) because bending is considered as
Deformation-Controlled Action (Table C7-1, ASCE 41-17).

Jacket

New material: Concrete Strength, $f_c = f_{cm} = 33.00$

New material: Steel Strength, $f_s = f_{sm} = 555.56$

Existing Column

New material: Concrete Strength, $f_c = f_{cm} = 33.00$

New material: Steel Strength, $f_s = f_{sm} = 555.56$

#####

External Diameter, $D = 500.00$

Internal Diameter, $D = 300.00$

Cover Thickness, $c = 25.00$

Element Length, $L = 3000.00$

Primary Member

Smooth Bars

Ductile Steel

With Detailing for Earthquake Resistance (including stirrups closed at 135°)

Longitudinal Bars With Ends Lapped Starting at the End Sections

Adequate Lap Length ($l_o/l_{ou,min} = l_b/l_d >= 1$)

No FRP Wrapping

Stepwise Properties

EDGE -A-

Bending Moment, $M_a = 1.5387606E-009$

Shear Force, $V_a = -5.3669914E-013$

EDGE -B-

Bending Moment, $M_b = 7.1693020E-011$

Shear Force, $V_b = 5.3669914E-013$

BOTH EDGES

Axial Force, $F = -7386.21$

Longitudinal Reinforcement Area Distribution (in 2 divisions)

-Tension: $A_{st} = 0.00$

-Compression: $A_{sc} = 3053.628$

Longitudinal Reinforcement Area Distribution (in 3 divisions)

-Tension: $A_{st,ten} = 1017.876$

-Compression: $A_{st,com} = 1017.876$

-Middle: $A_{st,mid} = 1017.876$

Mean Diameter of Tension Reinforcement, $Db_{L,ten} = 18.00$

New component: From table 7-7, ASCE 41_17: Final Shear Capacity $V_R = 1.0 * V_n = 443865.445$

Vn ((10.3), ASCE 41-17) = knl*VCol0 = 443865.445

VCol = 443865.445

knl = 1.00

displacement_ductility_demand = 0.00

NOTE: In expression (10-3) 'Vs = Av*fy*d/s' is replaced by 'Vs+ f*Vf'
where Vf is the contribution of FRPs (11.3), ACI 440).

= 1 (normal-weight concrete)

Mean concrete strength: fc' = (fc'_jacket*Area_jacket + fc'_core*Area_core)/Area_section = 25.00, but fc'^0.5 <= 8.3 MPa (22.5.3.1, ACI 318-14)

M/Vd = 2.00

Mu = 7.1693020E-011

Vu = 5.3669914E-013

d = 0.8*D = 400.00

Nu = 7386.21

Ag = 196349.541

From (11.5.4.8), ACI 318-14: Vs = Vs1 + Vs2 = 246740.11

Vs1 = 246740.11 is calculated for jacket, with:

Av = /2*A_stirrup = 123370.055

fy = 500.00

s = 100.00

Vs1 is multiplied by Col1 = 1.00

s/d = 0.25

Vs2 = 0.00 is calculated for core, with:

Av = /2*A_stirrup = 78956.835

fy = 500.00

s = 250.00

Vs2 is multiplied by Col2 = 0.00

s/d = 1.04167

Vf ((11-3)-(11.4), ACI 440) = 0.00

From (11-11), ACI 440: Vs + Vf <= 417394.406

bw*d = *d*d/4 = 125663.706

displacement_ductility_demand is calculated as / y

- Calculation of / y for END B -

for rotation axis 2 and integ. section (b)

From analysis, chord rotation = 8.1228335E-021

y = (My*Ls/3)/Eleff = 0.00729548 ((4.29),Biskinis Phd))

My = 3.6259E+008

Ls = M/V (with Ls >0.1*L and Ls < 2*L) = 1500.00

From table 10.5, ASCE 41_17: Eleff = factor*Ec*Ig = 2.4850E+013

factor = 0.30

Ag = 196349.541

Mean concrete strength: fc' = (fc'_jacket*Area_jacket + fc'_core*Area_core)/Area_section = 33.00

N = 7386.21

Ec*Ig = Ec_jacket*Ig_jacket + Ec_core*Ig_core = 8.2833E+013

Calculation of Yielding Moment My

Calculation of y and My according to (7) - (8) in Biskinis and Fardis

My = Min(My_ten,My_com) = 3.6259E+008

y ((10a) or (10b)) = 1.0622306E-005

My_ten (8a) = 3.6259E+008

_ten (7a) = 65.43628

error of function (7a) = 0.00293092

My_com (8b) = 7.5621E+008

_com (7b) = 64.56803

error of function (7b) = -0.00721907

with ey = 0.0027778

$e_{co} = 0.002$
 $a_{pl} = 0.35$ ((9a) in Biskinis and Fardis for no FRP Wrap)
 $d_1 = 44.00$
 $R = 250.00$
 $v = 0.00113993$
 $N = 7386.21$
 $A_c = 196349.541$
 $= 0.26182028$
with $f_c = 33.00$

Calculation of ratio l_b/d

Adequate Lap Length: $l_b/d \geq 1$

End Of Calculation of Shear Capacity for element: column JCC1 of floor 1
At local axis: 3
Integration Section: (b)

Calculation No. 8

column C1, Floor 1


Limit State: Immediate Occupancy (data interpolation between analysis steps 1 and 2)

Analysis: Uniform +X

Check: Chord rotation capacity (θ)

Edge: End

Local Axis: (3)



Start Of Calculation of Shear Capacity ratio for element: column JCC1 of floor 1

At Shear local axis: 3
(Bending local axis: 2)
Section Type: rcjcs

Constant Properties

Knowledge Factor, $\gamma = 1.00$
Mean strength values are used for both shear and moment calculations.

Consequently:

Jacket

New material of Primary Member: Concrete Strength, $f_c = f_{cm} = 33.00$

New material of Primary Member: Steel Strength, $f_s = f_{sm} = 555.56$

Concrete Elasticity, $E_c = 26999.444$

Steel Elasticity, $E_s = 200000.00$

Existing Column

New material of Primary Member: Concrete Strength, $f_c = f_{cm} = 33.00$

New material of Primary Member: Steel Strength, $f_s = f_{sm} = 555.56$

Concrete Elasticity, $E_c = 26999.444$

Steel Elasticity, $E_s = 200000.00$

#####

Note: Especially for the calculation of moment strengths,

the above steel re-bar strengths are multiplied by 1.25 according to R18.6.5, ACI 318-14

Jacket

New material: Steel Strength, $f_s = 1.25 \cdot f_{sm} = 694.45$

Existing Column

New material: Steel Strength, $f_s = 1.25 \cdot f_{sm} = 694.45$

#####

External Diameter, $D = 500.00$

Internal Diameter, $D = 300.00$

Cover Thickness, $c = 25.00$

Mean Confinement Factor overall section = 1.30349

Element Length, $L = 3000.00$

Primary Member

Smooth Bars

Ductile Steel

With Detailing for Earthquake Resistance (including stirrups closed at 135°)

Longitudinal Bars With Ends Lapped Starting at the End Sections

Adequate Lap Length ($l_o/l_{ou}, \min > 1$)

No FRP Wrapping

Stepwise Properties

At local axis: 3

EDGE -A-

Shear Force, $V_a = 4.4860917E-031$

EDGE -B-

Shear Force, $V_b = -4.4860917E-031$

BOTH EDGES

Axial Force, $F = -7389.214$

Longitudinal Reinforcement Area Distribution (in 2 divisions)

-Tension: $A_{sl,t} = 0.00$

-Compression: $A_{sl,c} = 3053.628$

Longitudinal Reinforcement Area Distribution (in 3 divisions)

-Tension: $A_{sl,ten} = 1017.876$

-Compression: $A_{sl,com} = 1017.876$

-Middle: $A_{sl,mid} = 1017.876$

Calculation of Shear Capacity ratio, $V_e/V_r = 0.54503121$

Member Controlled by Flexure ($V_e/V_r < 1$)

Calculation of Shear Demand from fig. R18.6.5, ACI 318-14 $V_e = (M_{pr1} + M_{pr2})/l_n = 272744.406$

with

$M_{pr1} = \text{Max}(M_{u1+}, M_{u1-}) = 4.0912E+008$

$M_{u1+} = 4.0912E+008$, is the ultimate moment strength at the edge 1 of the member in the actual moment direction which is defined for the static loading combination

$M_{u1-} = 4.0912E+008$, is the ultimate moment strength at the edge 1 of the member in the opposite moment direction which is defined for the static loading combination

$M_{pr2} = \text{Max}(M_{u2+}, M_{u2-}) = 4.0912E+008$

$M_{u2+} = 4.0912E+008$, is the ultimate moment strength at the edge 2 of the member in the actual moment direction which is defined for the static loading combination

$M_{u2-} = 4.0912E+008$, is the ultimate moment strength at the edge 2 of the member in the opposite moment direction which is defined for the static loading combination

Calculation of Mu1+

Calculation of ultimate Moment Strength ((3.67), Biskinis Phd), Mu
Mu = 4.0912E+008

= 0.97738438
' = 0.86668818
error of function (3.68), Biskinis Phd = 94694.946
From 5A.2, TBDY: fcc = fc* c = 43.01531
conf. factor c = 1.30349
fc = 33.00
From 10.3.5, ASCE 41-17, Final value of fy: fy*Min(1,1.25*(lb/d)^ 2/3) = 694.45
lb/d = 1.00
d1 = 44.00
R = 250.00
v = 0.0011401
N = 7389.214
Ac = 196349.541
= *Min(1,1.25*(lb/d)^ 2/3) = 0.26182028

Calculation of ratio lb/d

Adequate Lap Length: lb/d >= 1

Calculation of Mu1-

Calculation of ultimate Moment Strength ((3.67), Biskinis Phd), Mu
Mu = 4.0912E+008

= 0.97738438
' = 0.86668818
error of function (3.68), Biskinis Phd = 94694.946
From 5A.2, TBDY: fcc = fc* c = 43.01531
conf. factor c = 1.30349
fc = 33.00
From 10.3.5, ASCE 41-17, Final value of fy: fy*Min(1,1.25*(lb/d)^ 2/3) = 694.45
lb/d = 1.00
d1 = 44.00
R = 250.00
v = 0.0011401
N = 7389.214
Ac = 196349.541
= *Min(1,1.25*(lb/d)^ 2/3) = 0.26182028

Calculation of ratio lb/d

Adequate Lap Length: lb/d >= 1

Calculation of Mu2+

Calculation of ultimate Moment Strength ((3.67), Biskinis Phd), Mu
Mu = 4.0912E+008

= 0.97738438
 ' = 0.86668818
 error of function (3.68), Biskinis Phd = 94694.946
 From 5A.2, TBDY: $f_{cc} = f_c \cdot c = 43.01531$
 conf. factor $c = 1.30349$
 $f_c = 33.00$
 From 10.3.5, ASCE 41-17, Final value of f_y : $f_y \cdot \text{Min}(1, 1.25 \cdot (l_b/d)^{2/3}) = 694.45$
 $l_b/d = 1.00$
 $d_1 = 44.00$
 $R = 250.00$
 $v = 0.0011401$
 $N = 7389.214$
 $A_c = 196349.541$
 $= \cdot \text{Min}(1, 1.25 \cdot (l_b/d)^{2/3}) = 0.26182028$

 Calculation of ratio l_b/d

 Adequate Lap Length: $l_b/d \geq 1$

 Calculation of μ_2 -

 Calculation of ultimate Moment Strength ((3.67), Biskinis Phd), μ
 $\mu = 4.0912E+008$

 = 0.97738438
 ' = 0.86668818
 error of function (3.68), Biskinis Phd = 94694.946
 From 5A.2, TBDY: $f_{cc} = f_c \cdot c = 43.01531$
 conf. factor $c = 1.30349$
 $f_c = 33.00$
 From 10.3.5, ASCE 41-17, Final value of f_y : $f_y \cdot \text{Min}(1, 1.25 \cdot (l_b/d)^{2/3}) = 694.45$
 $l_b/d = 1.00$
 $d_1 = 44.00$
 $R = 250.00$
 $v = 0.0011401$
 $N = 7389.214$
 $A_c = 196349.541$
 $= \cdot \text{Min}(1, 1.25 \cdot (l_b/d)^{2/3}) = 0.26182028$

 Calculation of ratio l_b/d

 Adequate Lap Length: $l_b/d \geq 1$

 Calculation of Shear Strength $V_r = \text{Min}(V_{r1}, V_{r2}) = 500419.792$

 Calculation of Shear Strength at edge 1, $V_{r1} = 500419.792$
 $V_{r1} = V_{CoI} ((10.3), ASCE 41-17) = k_{nl} \cdot V_{CoI0}$
 $V_{CoI0} = 500419.792$
 $k_{nl} = 1$ (zero step-static loading)

 NOTE: In expression (10-3) ' $V_s = A_v \cdot f_y \cdot d/s$ ' is replaced by ' $V_{s+} = f \cdot V_f$ '
 where V_f is the contribution of FRPs (11.3), ACI 440).

 = 1 (normal-weight concrete)
 Mean concrete strength: $f_c' = (f_c'_{jacket} \cdot \text{Area}_{jacket} + f_c'_{core} \cdot \text{Area}_{core}) / \text{Area}_{section} = 33.00$, but $f_c'^{0.5} \leq 8.3$
 MPa (22.5.3.1, ACI 318-14)
 $M/d = 2.00$
 $\mu = 2.5382294E-011$

$V_u = 4.4860917E-031$
 $d = 0.8 \cdot D = 400.00$
 $N_u = 7389.214$
 $A_g = 196349.541$
 From (11.5.4.8), ACI 318-14: $V_s = V_{s1} + V_{s2} = 274157.871$
 $V_{s1} = 274157.871$ is calculated for jacket, with:
 $A_v = \sqrt{2} \cdot A_{stirrup} = 123370.055$
 $f_y = 555.56$
 $s = 100.00$
 V_{s1} is multiplied by $Col1 = 1.00$
 $s/d = 0.25$
 $V_{s2} = 0.00$ is calculated for core, with:
 $A_v = \sqrt{2} \cdot A_{stirrup} = 78956.835$
 $f_y = 555.56$
 $s = 250.00$
 V_{s2} is multiplied by $Col2 = 0.00$
 $s/d = 1.04167$
 V_f ((11-3)-(11.4), ACI 440) = 0.00
 From (11-11), ACI 440: $V_s + V_f \leq 479549.663$
 $b_w \cdot d = \sqrt{2} \cdot d^2 / 4 = 125663.706$

Calculation of Shear Strength at edge 2, $V_{r2} = 500419.792$
 $V_{r2} = V_{Col}$ ((10.3), ASCE 41-17) = $k_n l \cdot V_{Col0}$
 $V_{Col0} = 500419.792$
 $k_n l = 1$ (zero step-static loading)

NOTE: In expression (10-3) ' $V_s = A_v \cdot f_y \cdot d / s$ ' is replaced by ' $V_s + f \cdot V_f$ '
 where V_f is the contribution of FRPs (11.3), ACI 440).

$\lambda = 1$ (normal-weight concrete)
 Mean concrete strength: $f_c' = (f_c'_{jacket} \cdot Area_{jacket} + f_c'_{core} \cdot Area_{core}) / Area_{section} = 33.00$, but $f_c'^{0.5} \leq 8.3$
 MPa (22.5.3.1, ACI 318-14)

$M/Vd = 2.00$
 $M_u = 2.5382294E-011$
 $V_u = 4.4860917E-031$
 $d = 0.8 \cdot D = 400.00$
 $N_u = 7389.214$
 $A_g = 196349.541$
 From (11.5.4.8), ACI 318-14: $V_s = V_{s1} + V_{s2} = 274157.871$
 $V_{s1} = 274157.871$ is calculated for jacket, with:
 $A_v = \sqrt{2} \cdot A_{stirrup} = 123370.055$
 $f_y = 555.56$
 $s = 100.00$
 V_{s1} is multiplied by $Col1 = 1.00$
 $s/d = 0.25$
 $V_{s2} = 0.00$ is calculated for core, with:
 $A_v = \sqrt{2} \cdot A_{stirrup} = 78956.835$
 $f_y = 555.56$
 $s = 250.00$
 V_{s2} is multiplied by $Col2 = 0.00$
 $s/d = 1.04167$
 V_f ((11-3)-(11.4), ACI 440) = 0.00
 From (11-11), ACI 440: $V_s + V_f \leq 479549.663$
 $b_w \cdot d = \sqrt{2} \cdot d^2 / 4 = 125663.706$

End Of Calculation of Shear Capacity ratio for element: column JCC1 of floor 1
 At local axis: 3

Start Of Calculation of Shear Capacity ratio for element: column JCC1 of floor 1
 At Shear local axis: 2
 (Bending local axis: 3)
 Section Type: rcjcs

Constant Properties

Knowledge Factor, $\gamma = 1.00$

Mean strength values are used for both shear and moment calculations.

Consequently:

Jacket

New material of Primary Member: Concrete Strength, $f_c = f_{cm} = 33.00$

New material of Primary Member: Steel Strength, $f_s = f_{sm} = 555.56$

Concrete Elasticity, $E_c = 26999.444$

Steel Elasticity, $E_s = 200000.00$

Existing Column

New material of Primary Member: Concrete Strength, $f_c = f_{cm} = 33.00$

New material of Primary Member: Steel Strength, $f_s = f_{sm} = 555.56$

Concrete Elasticity, $E_c = 26999.444$

Steel Elasticity, $E_s = 200000.00$

#####

Note: Especially for the calculation of moment strengths,

the above steel re-bar strengths are multiplied by 1.25 according to R18.6.5, ACI 318-14

Jacket

New material: Steel Strength, $f_s = 1.25 \cdot f_{sm} = 694.45$

Existing Column

New material: Steel Strength, $f_s = 1.25 \cdot f_{sm} = 694.45$

#####

External Diameter, $D = 500.00$

Internal Diameter, $D = 300.00$

Cover Thickness, $c = 25.00$

Mean Confinement Factor overall section = 1.30349

Element Length, $L = 3000.00$

Primary Member

Smooth Bars

Ductile Steel

With Detailing for Earthquake Resistance (including stirrups closed at 135°)

Longitudinal Bars With Ends Lapped Starting at the End Sections

Adequate Lap Length ($l_o/l_{ou, \min} > 1$)

No FRP Wrapping

Stepwise Properties

At local axis: 2

EDGE -A-

Shear Force, $V_a = -2.7468482E-047$

EDGE -B-

Shear Force, $V_b = 2.7468482E-047$

BOTH EDGES

Axial Force, $F = -7389.214$

Longitudinal Reinforcement Area Distribution (in 2 divisions)

-Tension: $A_{st} = 0.00$

-Compression: $A_{sc} = 3053.628$

Longitudinal Reinforcement Area Distribution (in 3 divisions)

-Tension: $A_{st, \text{ten}} = 1017.876$

-Compression: $A_{sc, \text{com}} = 1017.876$

-Middle: $A_{sc, \text{mid}} = 1017.876$

Calculation of Shear Capacity ratio, $V_e/V_r = 0.54503121$

Member Controlled by Flexure ($V_e/V_r < 1$)

Calculation of Shear Demand from fig. R18.6.5, ACI 318-14 $V_e = (M_{pr1} + M_{pr2})/l_n = 272744.406$

with

$M_{pr1} = \text{Max}(M_{u1+}, M_{u1-}) = 4.0912E+008$

$M_{u1+} = 4.0912E+008$, is the ultimate moment strength at the edge 1 of the member in the actual moment direction which is defined for the static loading combination

$M_{u1-} = 4.0912E+008$, is the ultimate moment strength at the edge 1 of the member in the opposite moment direction which is defined for the static loading combination

$$M_{pr2} = \text{Max}(M_{u2+}, M_{u2-}) = 4.0912E+008$$

$M_{u2+} = 4.0912E+008$, is the ultimate moment strength at the edge 2 of the member in the actual moment direction which is defined for the the static loading combination

$M_{u2-} = 4.0912E+008$, is the ultimate moment strength at the edge 2 of the member in the opposite moment direction which is defined for the the static loading combination

Calculation of M_{u1+}

Calculation of ultimate Moment Strength ((3.67), Biskinis Phd), M_u
 $M_u = 4.0912E+008$

$$= 0.97738438$$

$$' = 0.86668818$$

error of function (3.68), Biskinis Phd = 94694.946

From 5A.2, TBDY: $f_{cc} = f_c \cdot c = 43.01531$

conf. factor $c = 1.30349$

$f_c = 33.00$

From 10.3.5, ASCE 41-17, Final value of f_y : $f_y \cdot \text{Min}(1, 1.25 \cdot (l_b/d)^{2/3}) = 694.45$

$$l_b/d = 1.00$$

$$d_1 = 44.00$$

$$R = 250.00$$

$$v = 0.0011401$$

$$N = 7389.214$$

$$A_c = 196349.541$$

$$= \cdot \text{Min}(1, 1.25 \cdot (l_b/d)^{2/3}) = 0.26182028$$

Calculation of ratio l_b/d

Adequate Lap Length: $l_b/d \geq 1$

Calculation of M_{u1-}

Calculation of ultimate Moment Strength ((3.67), Biskinis Phd), M_u
 $M_u = 4.0912E+008$

$$= 0.97738438$$

$$' = 0.86668818$$

error of function (3.68), Biskinis Phd = 94694.946

From 5A.2, TBDY: $f_{cc} = f_c \cdot c = 43.01531$

conf. factor $c = 1.30349$

$f_c = 33.00$

From 10.3.5, ASCE 41-17, Final value of f_y : $f_y \cdot \text{Min}(1, 1.25 \cdot (l_b/d)^{2/3}) = 694.45$

$$l_b/d = 1.00$$

$$d_1 = 44.00$$

$$R = 250.00$$

$$v = 0.0011401$$

$$N = 7389.214$$

$$A_c = 196349.541$$

$$= \cdot \text{Min}(1, 1.25 \cdot (l_b/d)^{2/3}) = 0.26182028$$

Calculation of ratio l_b/d

Adequate Lap Length: $l_b/d \geq 1$

Calculation of M_{u2+}

Calculation of ultimate Moment Strength ((3.67), Biskinis Phd), Mu

Mu = 4.0912E+008

= 0.97738438

' = 0.86668818

error of function (3.68), Biskinis Phd = 94694.946

From 5A.2, TBDY: fcc = fc* c = 43.01531

conf. factor c = 1.30349

fc = 33.00

From 10.3.5, ASCE 41-17, Final value of fy: fy*Min(1,1.25*(lb/d)^ 2/3) = 694.45

lb/d = 1.00

d1 = 44.00

R = 250.00

v = 0.0011401

N = 7389.214

Ac = 196349.541

= *Min(1,1.25*(lb/d)^ 2/3) = 0.26182028

Calculation of ratio lb/d

Adequate Lap Length: lb/d >= 1

Calculation of Mu2-

Calculation of ultimate Moment Strength ((3.67), Biskinis Phd), Mu

Mu = 4.0912E+008

= 0.97738438

' = 0.86668818

error of function (3.68), Biskinis Phd = 94694.946

From 5A.2, TBDY: fcc = fc* c = 43.01531

conf. factor c = 1.30349

fc = 33.00

From 10.3.5, ASCE 41-17, Final value of fy: fy*Min(1,1.25*(lb/d)^ 2/3) = 694.45

lb/d = 1.00

d1 = 44.00

R = 250.00

v = 0.0011401

N = 7389.214

Ac = 196349.541

= *Min(1,1.25*(lb/d)^ 2/3) = 0.26182028

Calculation of ratio lb/d

Adequate Lap Length: lb/d >= 1

Calculation of Shear Strength Vr = Min(Vr1,Vr2) = 500419.792

Calculation of Shear Strength at edge 1, Vr1 = 500419.792

Vr1 = VCol ((10.3), ASCE 41-17) = knl*VCol0

VCol0 = 500419.792

knl = 1 (zero step-static loading)

NOTE: In expression (10-3) 'Vs = Av*fy*d/s' is replaced by 'Vs+ f*Vf'
where Vf is the contribution of FRPs (11.3), ACI 440).

= 1 (normal-weight concrete)
Mean concrete strength: $f_c' = (f_c'_{\text{jacket}} \cdot \text{Area}_{\text{jacket}} + f_c'_{\text{core}} \cdot \text{Area}_{\text{core}}) / \text{Area}_{\text{section}} = 33.00$, but $f_c'^{0.5} \leq 8.3$ MPa (22.5.3.1, ACI 318-14)
 $M/Vd = 2.00$
 $\mu_u = 2.1979728E-011$
 $V_u = 2.7468482E-047$
 $d = 0.8 \cdot D = 400.00$
 $N_u = 7389.214$
 $A_g = 196349.541$
From (11.5.4.8), ACI 318-14: $V_s = V_{s1} + V_{s2} = 274157.871$
 $V_{s1} = 274157.871$ is calculated for jacket, with:
 $A_v = \sqrt{2} \cdot A_{\text{stirrup}} = 123370.055$
 $f_y = 555.56$
 $s = 100.00$
 V_{s1} is multiplied by $\text{Col1} = 1.00$
 $s/d = 0.25$
 $V_{s2} = 0.00$ is calculated for core, with:
 $A_v = \sqrt{2} \cdot A_{\text{stirrup}} = 78956.835$
 $f_y = 555.56$
 $s = 250.00$
 V_{s2} is multiplied by $\text{Col2} = 0.00$
 $s/d = 1.04167$
 $V_f ((11-3)-(11.4), \text{ACI } 440) = 0.00$
From (11-11), ACI 440: $V_s + V_f \leq 479549.663$
 $b_w \cdot d = \sqrt{2} \cdot d^2 / 4 = 125663.706$

Calculation of Shear Strength at edge 2, $V_{r2} = 500419.792$
 $V_{r2} = V_{\text{Col}} ((10.3), \text{ASCE } 41-17) = k_{nl} \cdot V_{\text{ColO}}$
 $V_{\text{ColO}} = 500419.792$
 $k_{nl} = 1$ (zero step-static loading)

NOTE: In expression (10-3) ' $V_s = A_v \cdot f_y \cdot d / s$ ' is replaced by ' $V_s + f \cdot V_f$ ' where V_f is the contribution of FRPs (11.3), ACI 440).

= 1 (normal-weight concrete)
Mean concrete strength: $f_c' = (f_c'_{\text{jacket}} \cdot \text{Area}_{\text{jacket}} + f_c'_{\text{core}} \cdot \text{Area}_{\text{core}}) / \text{Area}_{\text{section}} = 33.00$, but $f_c'^{0.5} \leq 8.3$ MPa (22.5.3.1, ACI 318-14)
 $M/Vd = 2.00$
 $\mu_u = 2.1979728E-011$
 $V_u = 2.7468482E-047$
 $d = 0.8 \cdot D = 400.00$
 $N_u = 7389.214$
 $A_g = 196349.541$
From (11.5.4.8), ACI 318-14: $V_s = V_{s1} + V_{s2} = 274157.871$
 $V_{s1} = 274157.871$ is calculated for jacket, with:
 $A_v = \sqrt{2} \cdot A_{\text{stirrup}} = 123370.055$
 $f_y = 555.56$
 $s = 100.00$
 V_{s1} is multiplied by $\text{Col1} = 1.00$
 $s/d = 0.25$
 $V_{s2} = 0.00$ is calculated for core, with:
 $A_v = \sqrt{2} \cdot A_{\text{stirrup}} = 78956.835$
 $f_y = 555.56$
 $s = 250.00$
 V_{s2} is multiplied by $\text{Col2} = 0.00$
 $s/d = 1.04167$
 $V_f ((11-3)-(11.4), \text{ACI } 440) = 0.00$
From (11-11), ACI 440: $V_s + V_f \leq 479549.663$
 $b_w \cdot d = \sqrt{2} \cdot d^2 / 4 = 125663.706$

End Of Calculation of Shear Capacity ratio for element: column JCC1 of floor 1
At local axis: 2

Start Of Calculation of Chord Rotation Capacity for element: column JCC1 of floor 1

At local axis: 3

Integration Section: (b)

Section Type: rcjcs

Constant Properties

Knowledge Factor, $k = 1.00$

Chord Rotation is generally considered as Deformation-Controlled Action according to Table C7-1, ASCE 41-17.

Mean strengths are used for Deformation-Controlled Actions according to 7.5.1.3, ASCE 41-17

Consequently:

Jacket

New material of Primary Member: Concrete Strength, $f_c = f_{cm} = 33.00$

New material of Primary Member: Steel Strength, $f_s = f_{sm} = 555.56$

Concrete Elasticity, $E_c = 26999.444$

Steel Elasticity, $E_s = 200000.00$

Existing Column

New material of Primary Member: Concrete Strength, $f_c = f_{cm} = 33.00$

New material of Primary Member: Steel Strength, $f_s = f_{sm} = 555.56$

Concrete Elasticity, $E_c = 26999.444$

Steel Elasticity, $E_s = 200000.00$

External Diameter, $D = 500.00$

Internal Diameter, $D = 300.00$

Cover Thickness, $c = 25.00$

Element Length, $L = 3000.00$

Primary Member

Smooth Bars

Ductile Steel

With Detailing for Earthquake Resistance (including stirrups closed at 135°)

Longitudinal Bars With Ends Lapped Starting at the End Sections

Adequate Lap Length ($l_b/d >= 1$)

No FRP Wrapping

Stepwise Properties

Bending Moment, $M = 0.03802603$

Shear Force, $V_2 = 7509.70$

Shear Force, $V_3 = 5.3669914E-013$

Axial Force, $F = -7386.21$

Longitudinal Reinforcement Area Distribution (in 2 divisions)

-Tension: $A_{st} = 0.00$

-Compression: $A_{sc} = 3053.628$

Longitudinal Reinforcement Area Distribution (in 3 divisions)

-Tension: $A_{st,ten} = 1017.876$

-Compression: $A_{st,com} = 1017.876$

-Middle: $A_{st,mid} = 1017.876$

Mean Diameter of Tension Reinforcement, $D_bL = 18.00$

New component: From table 7-7, ASCE 41_17: Final chord rotation Capacity $u_{,R} = 1.0^* u = 0.0064591$

$u = y + p = 0.0064591$

- Calculation of y -

$y = (M_y * L_s / 3) / E_{eff} = 0.0014591$ ((4.29), Biskinis Phd))

$M_y = 3.6259E+008$

$L_s = M/V$ (with $L_s > 0.1 * L$ and $L_s < 2 * L$) = 300.00

From table 10.5, ASCE 41_17: $E_{eff} = factor * E_c * I_g = 2.4850E+013$

factor = 0.30

$A_g = 196349.541$

Mean concrete strength: $f_c' = (f_c'_{jacket} * Area_{jacket} + f_c'_{core} * Area_{core}) / Area_{section} = 33.00$

$N = 7386.21$

$$E_c I_g = E_c \text{ jacket} I_g \text{ jacket} + E_c \text{ core} I_g \text{ core} = 8.2833E+013$$

Calculation of Yielding Moment M_y

Calculation of ρ_y and M_y according to (7) - (8) in Biskinis and Fardis

$$M_y = \text{Min}(M_{y_ten}, M_{y_com}) = 3.6259E+008$$

$$\rho_y \text{ ((10a) or (10b))} = 1.0622306E-005$$

$$M_{y_ten} \text{ (8a)} = 3.6259E+008$$

$$\rho_{y_ten} \text{ (7a)} = 65.43628$$

$$\text{error of function (7a)} = 0.00293092$$

$$M_{y_com} \text{ (8b)} = 7.5621E+008$$

$$\rho_{y_com} \text{ (7b)} = 64.56803$$

$$\text{error of function (7b)} = -0.00721907$$

with $e_y = 0.0027778$
 $e_{co} = 0.002$
 $a_{pl} = 0.35$ ((9a) in Biskinis and Fardis for no FRP Wrap)
 $d_1 = 44.00$
 $R = 250.00$
 $v = 0.00113993$
 $N = 7386.21$
 $A_c = 196349.541$
 $\rho = 0.26182028$
with $f_c = 33.00$

Calculation of ratio l_b/d

Adequate Lap Length: $l_b/d \geq 1$

- Calculation of ρ_p -

From table 10-9: $\rho_p = 0.005$

with:

- Columns not controlled by inadequate development or splicing along the clear height because $l_b/d \geq 1$

$$\text{shear control ratio } V_y E / V C o l O E = 0.54503121$$

$$d = d_{\text{external}} = 0.00$$

$$s = s_{\text{external}} = 0.00$$

$$t = s_1 + s_2 + 2 * t_f / b_w * (f_{fe} / f_s) = 0.00323428$$

jacket: $s_1 = A_{v1} * (D_{c1} / 2) / (s_1 * A_g) = 0.0027646$
 $A_{v1} = 78.53982$, is the area of stirrup
 $D_{c1} = D_{\text{ext}} - 2 * \text{cover} - \text{External Hoop Diameter} = 440.00$, is the total Length of all stirrups parallel to loading (shear) direction
 $s_1 = 100.00$

core: $s_2 = A_{v2} * (D_{c2} / 2) / (s_2 * A_g) = 0.00046968$
 $A_{v2} = 50.26548$, is the area of stirrup
 $D_{c2} = D_{\text{int}} - \text{Internal Hoop Diameter} = 292.00$, is the total Length of all stirrups parallel to loading (shear) direction
 $s_2 = 250.00$

The term $2 * t_f / b_w * (f_{fe} / f_s)$ is implemented to account for FRP contribution where $f = 2 * t_f / b_w$ is FRP ratio (EC8 - 3, A.4.4.3(6)) and f_{fe} / f_s normalises f to steel strength. All these variables have already been given in Shear control ratio calculation.

For the normalisation f_s of jacket is used.

$$N_{UD} = 7386.21$$

$$A_g = 196349.541$$

$$f_{cE} = (f_c \text{ jacket} * \text{Area}_{\text{jacket}} + f_c \text{ core} * \text{Area}_{\text{core}}) / \text{section_area} = 33.00$$

$$f_{yLE} = (f_{y_ext_Long_Reinf} * \text{Area}_{\text{ext_Long_Reinf}} + f_{y_int_Long_Reinf} * \text{Area}_{\text{int_Long_Reinf}}) / \text{Area}_{\text{Tot_Long_Rein}} = 2.1219958E-314$$

$$f_{yTE} = (f_{y_ext_Trans_Reinf} * \text{Area}_{\text{ext_Trans_Reinf}} + f_{y_int_Trans_Reinf} * \text{Area}_{\text{int_Trans_Reinf}}) / \text{Area}_{\text{Tot_Trans_Rein}} = 555.56$$

$$\rho_l = \text{Area}_{\text{Tot_Long_Rein}} / (A_g) = 0.015552$$


$$f_{cE} = 33.00$$

End Of Calculation of Chord Rotation Capacity for element: column JCC1 of floor 1

At local axis: 3
Integration Section: (b)

Calculation No. 9

column C1, Floor 1
Limit State: Collapse Prevention (data interpolation between analysis steps 1 and 2)
Analysis: Uniform +X
Check: Shear capacity V_{Rd}
Edge: Start
Local Axis: (2)



Start Of Calculation of Shear Capacity for element: column JCC1 of floor 1
At local axis: 2
Integration Section: (a)
Section Type: rcjcs

Constant Properties

Knowledge Factor, $\gamma = 1.00$
Member Shear Force is generally considered as Force-Controlled Action according to Table C7-1, ASCE 41-17.
Lower-bound strengths are used for Force-Controlled Actions according to 7.5.1.3, ASCE 41-17
Consequently:

Jacket

New material of Primary Member: Concrete Strength, $f_c = f_{c_lower_bound} = 25.00$
New material of Primary Member: Steel Strength, $f_s = f_{s_lower_bound} = 500.00$
Concrete Elasticity, $E_c = 26999.444$
Steel Elasticity, $E_s = 200000.00$

Existing Column

New material of Primary Member: Concrete Strength, $f_c = f_{c_lower_bound} = 25.00$
New material of Primary Member: Steel Strength, $f_s = f_{s_lower_bound} = 500.00$
Concrete Elasticity, $E_c = 26999.444$
Steel Elasticity, $E_s = 200000.00$

#####

Note: Especially for the calculation of γ for displacement ductility demand,
the expected (mean value) strengths are used (7.5.1.3, ASCE 41-17) because bending is considered as

Deformation-Controlled Action (Table C7-1, ASCE 41-17).

Jacket

New material: Concrete Strength, $f_c = f_{cm} = 33.00$

New material: Steel Strength, $f_s = f_{sm} = 555.56$

Existing Column

New material: Concrete Strength, $f_c = f_{cm} = 33.00$

New material: Steel Strength, $f_s = f_{sm} = 555.56$

#####

External Diameter, $D = 500.00$

Internal Diameter, $D = 300.00$

Cover Thickness, $c = 25.00$

Element Length, $L = 3000.00$

Primary Member

Smooth Bars

Ductile Steel

With Detailing for Earthquake Resistance (including stirrups closed at 135°)

Longitudinal Bars With Ends Lapped Starting at the End Sections

Adequate Lap Length ($l_o/l_{ou,min} = l_b/l_d \geq 1$)

No FRP Wrapping

Stepwise Properties

EDGE -A-

Bending Moment, $M_a = -1.4267E+007$

Shear Force, $V_a = -4754.456$

EDGE -B-

Bending Moment, $M_b = 0.02407461$

Shear Force, $V_b = 4754.456$

BOTH EDGES

Axial Force, $F = -7387.312$

Longitudinal Reinforcement Area Distribution (in 2 divisions)

-Tension: $As_t = 0.00$

-Compression: $As_c = 3053.628$

Longitudinal Reinforcement Area Distribution (in 3 divisions)

-Tension: $As_{t,ten} = 1017.876$

-Compression: $As_{c,com} = 1017.876$

-Middle: $As_{mid} = 1017.876$

Mean Diameter of Tension Reinforcement, $Db_{L,ten} = 18.00$

New component: From table 7-7, ASCE 41_17: Final Shear Capacity $V_R = 1.0 \cdot V_n = 345302.887$

V_n ((10.3), ASCE 41-17) = $k_n \cdot V_{CoI} = 345302.887$

$V_{CoI} = 345302.887$

$k_n = 1.00$

displacement_ductility_demand = 0.01087266

NOTE: In expression (10-3) ' $V_s = A_v \cdot f_y \cdot d / s$ ' is replaced by ' $V_s + f \cdot V_f$ '

where V_f is the contribution of FRPs (11.3), ACI 440).

= 1 (normal-weight concrete)

Mean concrete strength: $f_c' = (f_c'_{jacket} \cdot Area_{jacket} + f_c'_{core} \cdot Area_{core}) / Area_{section} = 25.00$, but $f_c'^{0.5} \leq 8.3$ MPa (22.5.3.1, ACI 318-14)

$M/Vd = 4.00$

$M_u = 1.4267E+007$

$V_u = 4754.456$

$d = 0.8 \cdot D = 400.00$

$N_u = 7387.312$

$A_g = 196349.541$

From (11.5.4.8), ACI 318-14: $V_s = V_{s1} + V_{s2} = 246740.11$

$V_{s1} = 246740.11$ is calculated for jacket, with:

$A_v = \sqrt{2} \cdot A_{stirrup} = 123370.055$

$f_y = 500.00$

$s = 100.00$

V_{s1} is multiplied by $Col1 = 1.00$

$$s/d = 0.25$$

Vs2 = 0.00 is calculated for core, with:

$$A_v = \sqrt{2} \cdot A_{stirrup} = 78956.835$$

$$f_y = 500.00$$

$$s = 250.00$$

Vs2 is multiplied by Col2 = 0.00

$$s/d = 1.04167$$

Vf ((11-3)-(11.4), ACI 440) = 0.00

From (11-11), ACI 440: Vs + Vf <= 417394.406

$$b_w \cdot d = \sqrt{d} \cdot d / 4 = 125663.706$$

displacement_ductility_demand is calculated as δ / y

- Calculation of δ / y for END A -
for rotation axis 3 and integ. section (a)

From analysis, chord rotation = 0.00015868

$$y = (M_y \cdot L_s / 3) / E_{eff} = 0.01459455 \text{ ((4.29), Biskinis Phd)}$$

$$M_y = 3.6259E+008$$

$$L_s = M/V \text{ (with } L_s > 0.1 \cdot L \text{ and } L_s < 2 \cdot L) = 3000.736$$

From table 10.5, ASCE 41_17: $E_{eff} = \text{factor} \cdot E_c \cdot I_g = 2.4850E+013$

$$\text{factor} = 0.30$$

$$A_g = 196349.541$$

$$\text{Mean concrete strength: } f_c' = (f_c'_{jacket} \cdot A_{jacket} + f_c'_{core} \cdot A_{core}) / A_{section} = 33.00$$

$$N = 7387.312$$

$$E_c \cdot I_g = E_{c_{jacket}} \cdot I_{g_{jacket}} + E_{c_{core}} \cdot I_{g_{core}} = 8.2833E+013$$

Calculation of Yielding Moment M_y

Calculation of δ / y and M_y according to (7) - (8) in Biskinis and Fardis

$$M_y = \text{Min}(M_{y_{ten}}, M_{y_{com}}) = 3.6259E+008$$

$$y \text{ ((10a) or (10b))} = 1.0622309E-005$$

$$M_{y_{ten}} \text{ (8a)} = 3.6259E+008$$

$$\delta_{ten} \text{ (7a)} = 65.4363$$

$$\text{error of function (7a)} = 0.0029309$$

$$M_{y_{com}} \text{ (8b)} = 7.5621E+008$$

$$\delta_{com} \text{ (7b)} = 64.56804$$

$$\text{error of function (7b)} = -0.00721905$$

$$\text{with } e_y = 0.0027778$$

$$e_{co} = 0.002$$

$$a_{pl} = 0.35 \text{ ((9a) in Biskinis and Fardis for no FRP Wrap)}$$

$$d_1 = 44.00$$

$$R = 250.00$$

$$v = 0.0011401$$

$$N = 7387.312$$

$$A_c = 196349.541$$

$$= 0.26182028$$

$$\text{with } f_c = 33.00$$

Calculation of ratio l_b/d

Adequate Lap Length: $l_b/d \geq 1$

End Of Calculation of Shear Capacity for element: column JCC1 of floor 1

At local axis: 2

Integration Section: (a)

Calculation No. 10

column C1, Floor 1


Limit State: Collapse Prevention (data interpolation between analysis steps 1 and 2)

Analysis: Uniform +X

Check: Chord rotation capacity (θ_r)

Edge: Start

Local Axis: (2)



Start Of Calculation of Shear Capacity ratio for element: column JCC1 of floor 1

At Shear local axis: 3

(Bending local axis: 2)

Section Type: rcjcs

Constant Properties

Knowledge Factor, $\gamma = 1.00$

Mean strength values are used for both shear and moment calculations.

Consequently:

Jacket

New material of Primary Member: Concrete Strength, $f_c = f_{cm} = 33.00$

New material of Primary Member: Steel Strength, $f_s = f_{sm} = 555.56$

Concrete Elasticity, $E_c = 26999.444$

Steel Elasticity, $E_s = 200000.00$

Existing Column

New material of Primary Member: Concrete Strength, $f_c = f_{cm} = 33.00$

New material of Primary Member: Steel Strength, $f_s = f_{sm} = 555.56$

Concrete Elasticity, $E_c = 26999.444$

Steel Elasticity, $E_s = 200000.00$

#####

Note: Especially for the calculation of moment strengths,

the above steel re-bar strengths are multiplied by 1.25 according to R18.6.5, ACI 318-14

Jacket

New material: Steel Strength, $f_s = 1.25 \cdot f_{sm} = 694.45$

Existing Column

New material: Steel Strength, $f_s = 1.25 \cdot f_{sm} = 694.45$

#####

External Diameter, $D = 500.00$

Internal Diameter, $D = 300.00$

Cover Thickness, $c = 25.00$

Mean Confinement Factor overall section = 1.30349

Element Length, L = 3000.00
Primary Member
Smooth Bars
Ductile Steel
With Detailing for Earthquake Resistance (including stirrups closed at 135°)
Longitudinal Bars With Ends Lapped Starting at the End Sections
Adequate Lap Length ($l_o/l_{ou}, \min >= 1$)
No FRP Wrapping

Stepwise Properties

At local axis: 3
EDGE -A-
Shear Force, $V_a = 4.4860917E-031$
EDGE -B-
Shear Force, $V_b = -4.4860917E-031$
BOTH EDGES
Axial Force, $F = -7389.214$
Longitudinal Reinforcement Area Distribution (in 2 divisions)
-Tension: $A_{st} = 0.00$
-Compression: $A_{sc} = 3053.628$
Longitudinal Reinforcement Area Distribution (in 3 divisions)
-Tension: $A_{st,ten} = 1017.876$
-Compression: $A_{st,com} = 1017.876$
-Middle: $A_{st,mid} = 1017.876$

Calculation of Shear Capacity ratio, $V_e/V_r = 0.54503121$
Member Controlled by Flexure ($V_e/V_r < 1$)
Calculation of Shear Demand from fig. R18.6.5, ACI 318-14 $V_e = (M_{pr1} + M_{pr2})/l_n = 272744.406$
with
 $M_{pr1} = \text{Max}(Mu_{1+}, Mu_{1-}) = 4.0912E+008$
 $Mu_{1+} = 4.0912E+008$, is the ultimate moment strength at the edge 1 of the member in the actual moment direction which is defined for the static loading combination
 $Mu_{1-} = 4.0912E+008$, is the ultimate moment strength at the edge 1 of the member in the opposite moment direction which is defined for the static loading combination
 $M_{pr2} = \text{Max}(Mu_{2+}, Mu_{2-}) = 4.0912E+008$
 $Mu_{2+} = 4.0912E+008$, is the ultimate moment strength at the edge 2 of the member in the actual moment direction which is defined for the the static loading combination
 $Mu_{2-} = 4.0912E+008$, is the ultimate moment strength at the edge 2 of the member in the opposite moment direction which is defined for the the static loading combination

Calculation of Mu_{1+}

Calculation of ultimate Moment Strength ((3.67), Biskinis Phd), Mu
 $Mu = 4.0912E+008$

 $\phi = 0.97738438$
 $\phi' = 0.86668818$
error of function (3.68), Biskinis Phd = 94694.946
From 5A.2, TBDY: $f_{cc} = f_c^* \quad c = 43.01531$
conf. factor $c = 1.30349$
 $f_c = 33.00$
From 10.3.5, ASCE 41-17, Final value of f_y : $f_y * \text{Min}(1, 1.25 * (l_b/d)^{2/3}) = 694.45$
 $l_b/d = 1.00$
 $d_1 = 44.00$
 $R = 250.00$
 $v = 0.0011401$
 $N = 7389.214$
 $A_c = 196349.541$
 $\phi' = \phi * \text{Min}(1, 1.25 * (l_b/d)^{2/3}) = 0.26182028$

Calculation of ratio lb/d

Adequate Lap Length: $lb/d \geq 1$

Calculation of Mu1-

Calculation of ultimate Moment Strength ((3.67), Biskinis Phd), Mu
Mu = 4.0912E+008

= 0.97738438
' = 0.86668818
error of function (3.68), Biskinis Phd = 94694.946
From 5A.2, TBDY: $f_{cc} = f_c \cdot c = 43.01531$
conf. factor $c = 1.30349$
 $f_c = 33.00$
From 10.3.5, ASCE 41-17, Final value of f_y : $f_y \cdot \text{Min}(1, 1.25 \cdot (lb/d)^{2/3}) = 694.45$
 $lb/d = 1.00$
 $d1 = 44.00$
 $R = 250.00$
 $v = 0.0011401$
 $N = 7389.214$
 $Ac = 196349.541$
= $\cdot \text{Min}(1, 1.25 \cdot (lb/d)^{2/3}) = 0.26182028$

Calculation of ratio lb/d

Adequate Lap Length: $lb/d \geq 1$

Calculation of Mu2+

Calculation of ultimate Moment Strength ((3.67), Biskinis Phd), Mu
Mu = 4.0912E+008

= 0.97738438
' = 0.86668818
error of function (3.68), Biskinis Phd = 94694.946
From 5A.2, TBDY: $f_{cc} = f_c \cdot c = 43.01531$
conf. factor $c = 1.30349$
 $f_c = 33.00$
From 10.3.5, ASCE 41-17, Final value of f_y : $f_y \cdot \text{Min}(1, 1.25 \cdot (lb/d)^{2/3}) = 694.45$
 $lb/d = 1.00$
 $d1 = 44.00$
 $R = 250.00$
 $v = 0.0011401$
 $N = 7389.214$
 $Ac = 196349.541$
= $\cdot \text{Min}(1, 1.25 \cdot (lb/d)^{2/3}) = 0.26182028$

Calculation of ratio lb/d

Adequate Lap Length: $lb/d \geq 1$

Calculation of Mu2-

Calculation of ultimate Moment Strength ((3.67), Biskinis Phd), Mu
Mu = 4.0912E+008

= 0.97738438
' = 0.86668818
error of function (3.68), Biskinis Phd = 94694.946
From 5A.2, TBDY: $f_{cc} = f_c \cdot c = 43.01531$
conf. factor $c = 1.30349$
 $f_c = 33.00$
From 10.3.5, ASCE 41-17, Final value of f_y : $f_y \cdot \text{Min}(1, 1.25 \cdot (l_b/d)^{2/3}) = 694.45$
 $l_b/d = 1.00$
 $d_1 = 44.00$
 $R = 250.00$
 $v = 0.0011401$
 $N = 7389.214$
 $A_c = 196349.541$
= $\cdot \text{Min}(1, 1.25 \cdot (l_b/d)^{2/3}) = 0.26182028$

Calculation of ratio l_b/d

Adequate Lap Length: $l_b/d \geq 1$

Calculation of Shear Strength $V_r = \text{Min}(V_{r1}, V_{r2}) = 500419.792$

Calculation of Shear Strength at edge 1, $V_{r1} = 500419.792$

$V_{r1} = V_{Col}$ ((10.3), ASCE 41-17) = $k_{nl} \cdot V_{Col0}$

$V_{Col0} = 500419.792$

$k_{nl} = 1$ (zero step-static loading)

NOTE: In expression (10-3) ' $V_s = A_v \cdot f_y \cdot d/s$ ' is replaced by ' $V_s + f \cdot V_f$ '
where V_f is the contribution of FRPs (11.3), ACI 440).

= 1 (normal-weight concrete)
Mean concrete strength: $f_c' = (f_c'_{jacket} \cdot \text{Area}_{jacket} + f_c'_{core} \cdot \text{Area}_{core}) / \text{Area}_{section} = 33.00$, but $f_c'^{0.5} \leq 8.3$
MPa (22.5.3.1, ACI 318-14)
 $M/d = 2.00$
 $M_u = 2.5382294E-011$
 $V_u = 4.4860917E-031$
 $d = 0.8 \cdot D = 400.00$
 $N_u = 7389.214$
 $A_g = 196349.541$
From (11.5.4.8), ACI 318-14: $V_s = V_{s1} + V_{s2} = 274157.871$
 $V_{s1} = 274157.871$ is calculated for jacket, with:
 $A_v = \sqrt{2} \cdot A_{stirrup} = 123370.055$
 $f_y = 555.56$
 $s = 100.00$
 V_{s1} is multiplied by $Col1 = 1.00$
 $s/d = 0.25$
 $V_{s2} = 0.00$ is calculated for core, with:
 $A_v = \sqrt{2} \cdot A_{stirrup} = 78956.835$
 $f_y = 555.56$
 $s = 250.00$
 V_{s2} is multiplied by $Col2 = 0.00$
 $s/d = 1.04167$
 V_f ((11-3)-(11.4), ACI 440) = 0.00
From (11-11), ACI 440: $V_s + V_f \leq 479549.663$
 $b_w \cdot d = \sqrt{d} \cdot d/4 = 125663.706$

Calculation of Shear Strength at edge 2, $V_{r2} = 500419.792$

Vr2 = VCol ((10.3), ASCE 41-17) = knl*VCol0

VCol0 = 500419.792

kn1 = 1 (zero step-static loading)

NOTE: In expression (10-3) 'Vs = Av*fy*d/s' is replaced by 'Vs+ f*Vf'
where Vf is the contribution of FRPs (11.3), ACI 440).

= 1 (normal-weight concrete)

Mean concrete strength: fc' = (fc'_jacket*Area_jacket + fc'_core*Area_core)/Area_section = 33.00, but fc'^0.5 <= 8.3 MPa (22.5.3.1, ACI 318-14)

M/Vd = 2.00

Mu = 2.5382294E-011

Vu = 4.4860917E-031

d = 0.8*D = 400.00

Nu = 7389.214

Ag = 196349.541

From (11.5.4.8), ACI 318-14: Vs = Vs1 + Vs2 = 274157.871

Vs1 = 274157.871 is calculated for jacket, with:

Av = /2*A_stirrup = 123370.055

fy = 555.56

s = 100.00

Vs1 is multiplied by Col1 = 1.00

s/d = 0.25

Vs2 = 0.00 is calculated for core, with:

Av = /2*A_stirrup = 78956.835

fy = 555.56

s = 250.00

Vs2 is multiplied by Col2 = 0.00

s/d = 1.04167

Vf ((11-3)-(11.4), ACI 440) = 0.00

From (11-11), ACI 440: Vs + Vf <= 479549.663

bw*d = *d*d/4 = 125663.706

End Of Calculation of Shear Capacity ratio for element: column JCC1 of floor 1
At local axis: 3

Start Of Calculation of Shear Capacity ratio for element: column JCC1 of floor 1
At Shear local axis: 2
(Bending local axis: 3)
Section Type: rcjcs

Constant Properties

Knowledge Factor, = 1.00

Mean strength values are used for both shear and moment calculations.

Consequently:

Jacket

New material of Primary Member: Concrete Strength, fc = fcm = 33.00

New material of Primary Member: Steel Strength, fs = fsm = 555.56

Concrete Elasticity, Ec = 26999.444

Steel Elasticity, Es = 200000.00

Existing Column

New material of Primary Member: Concrete Strength, fc = fcm = 33.00

New material of Primary Member: Steel Strength, fs = fsm = 555.56

Concrete Elasticity, Ec = 26999.444

Steel Elasticity, Es = 200000.00

#####

Note: Especially for the calculation of moment strengths,

the above steel re-bar strengths are multiplied by 1.25 according to R18.6.5, ACI 318-14

Jacket

New material: Steel Strength, fs = 1.25*fsm = 694.45

Existing Column

New material: Steel Strength, fs = 1.25*fsm = 694.45

#####

External Diameter, D = 500.00
Internal Diameter, D = 300.00
Cover Thickness, c = 25.00
Mean Confinement Factor overall section = 1.30349
Element Length, L = 3000.00
Primary Member
Smooth Bars
Ductile Steel
With Detailing for Earthquake Resistance (including stirrups closed at 135°)
Longitudinal Bars With Ends Lapped Starting at the End Sections
Adequate Lap Length ($l_o/l_{ou}, \min \geq 1$)
No FRP Wrapping

Stepwise Properties

At local axis: 2
EDGE -A-
Shear Force, $V_a = -2.7468482E-047$
EDGE -B-
Shear Force, $V_b = 2.7468482E-047$
BOTH EDGES
Axial Force, $F = -7389.214$
Longitudinal Reinforcement Area Distribution (in 2 divisions)
-Tension: $As_t = 0.00$
-Compression: $As_c = 3053.628$
Longitudinal Reinforcement Area Distribution (in 3 divisions)
-Tension: $As_{t,ten} = 1017.876$
-Compression: $As_{c,com} = 1017.876$
-Middle: $As_{c,mid} = 1017.876$

Calculation of Shear Capacity ratio, $V_e/V_r = 0.54503121$
Member Controlled by Flexure ($V_e/V_r < 1$)
Calculation of Shear Demand from fig. R18.6.5, ACI 318-14 $V_e = (M_{pr1} + M_{pr2})/l_n = 272744.406$
with
 $M_{pr1} = \text{Max}(Mu_{1+}, Mu_{1-}) = 4.0912E+008$
 $Mu_{1+} = 4.0912E+008$, is the ultimate moment strength at the edge 1 of the member in the actual moment direction
which is defined for the static loading combination
 $Mu_{1-} = 4.0912E+008$, is the ultimate moment strength at the edge 1 of the member in the opposite moment
direction which is defined for the static loading combination
 $M_{pr2} = \text{Max}(Mu_{2+}, Mu_{2-}) = 4.0912E+008$
 $Mu_{2+} = 4.0912E+008$, is the ultimate moment strength at the edge 2 of the member in the actual moment direction
which is defined for the the static loading combination
 $Mu_{2-} = 4.0912E+008$, is the ultimate moment strength at the edge 2 of the member in the opposite moment
direction which is defined for the the static loading combination

Calculation of Mu_{1+}

Calculation of ultimate Moment Strength ((3.67), Biskinis Phd), Mu
 $Mu = 4.0912E+008$

= 0.97738438
' = 0.86668818
error of function (3.68), Biskinis Phd = 94694.946
From 5A.2, TBDY: $f_{cc} = f_c * c = 43.01531$
conf. factor $c = 1.30349$
 $f_c = 33.00$
From 10.3.5, ASCE 41-17, Final value of $f_y: f_y * \text{Min}(1, 1.25 * (l_b/l_d)^{2/3}) = 694.45$
 $l_b/l_d = 1.00$
 $d_1 = 44.00$

R = 250.00
v = 0.0011401
N = 7389.214
Ac = 196349.541
= *Min(1,1.25*(lb/d)^ 2/3) = 0.26182028

Calculation of ratio lb/d

Adequate Lap Length: lb/d >= 1

Calculation of Mu1-

Calculation of ultimate Moment Strength ((3.67), Biskinis Phd), Mu
Mu = 4.0912E+008

= 0.97738438
' = 0.86668818
error of function (3.68), Biskinis Phd = 94694.946
From 5A.2, TBDY: fcc = fc* c = 43.01531
conf. factor c = 1.30349
fc = 33.00
From 10.3.5, ASCE 41-17, Final value of fy: fy*Min(1,1.25*(lb/d)^ 2/3) = 694.45
lb/d = 1.00
d1 = 44.00
R = 250.00
v = 0.0011401
N = 7389.214
Ac = 196349.541
= *Min(1,1.25*(lb/d)^ 2/3) = 0.26182028

Calculation of ratio lb/d

Adequate Lap Length: lb/d >= 1

Calculation of Mu2+

Calculation of ultimate Moment Strength ((3.67), Biskinis Phd), Mu
Mu = 4.0912E+008

= 0.97738438
' = 0.86668818
error of function (3.68), Biskinis Phd = 94694.946
From 5A.2, TBDY: fcc = fc* c = 43.01531
conf. factor c = 1.30349
fc = 33.00
From 10.3.5, ASCE 41-17, Final value of fy: fy*Min(1,1.25*(lb/d)^ 2/3) = 694.45
lb/d = 1.00
d1 = 44.00
R = 250.00
v = 0.0011401
N = 7389.214
Ac = 196349.541
= *Min(1,1.25*(lb/d)^ 2/3) = 0.26182028

Calculation of ratio lb/d

Adequate Lap Length: $l_b/d \geq 1$

Calculation of μ_2

Calculation of ultimate Moment Strength ((3.67), Biskinis Phd), μ
 $\mu = 4.0912E+008$

$$= 0.97738438$$

$$' = 0.86668818$$

error of function (3.68), Biskinis Phd = 94694.946

From 5A.2, TBDY: $f_{cc} = f_c \cdot c = 43.01531$

conf. factor $c = 1.30349$

$$f_c = 33.00$$

From 10.3.5, ASCE 41-17, Final value of f_y : $f_y \cdot \text{Min}(1, 1.25 \cdot (l_b/d)^{2/3}) = 694.45$

$$l_b/d = 1.00$$

$$d_1 = 44.00$$

$$R = 250.00$$

$$v = 0.0011401$$

$$N = 7389.214$$

$$A_c = 196349.541$$

$$= \cdot \text{Min}(1, 1.25 \cdot (l_b/d)^{2/3}) = 0.26182028$$

Calculation of ratio l_b/d

Adequate Lap Length: $l_b/d \geq 1$

Calculation of Shear Strength $V_r = \text{Min}(V_{r1}, V_{r2}) = 500419.792$

Calculation of Shear Strength at edge 1, $V_{r1} = 500419.792$

$V_{r1} = V_{Col}$ ((10.3), ASCE 41-17) = $k_{nl} \cdot V_{Col0}$

$$V_{Col0} = 500419.792$$

$k_{nl} = 1$ (zero step-static loading)

NOTE: In expression (10-3) ' $V_s = A_v \cdot f_y \cdot d/s$ ' is replaced by ' $V_{s+} = f \cdot V_f$ ' where V_f is the contribution of FRPs (11.3), ACI 440).

= 1 (normal-weight concrete)

Mean concrete strength: $f_c' = (f_c'_{jacket} \cdot \text{Area}_{jacket} + f_c'_{core} \cdot \text{Area}_{core}) / \text{Area}_{section} = 33.00$, but $f_c'^{0.5} \leq 8.3$ MPa (22.5.3.1, ACI 318-14)

$$M/Vd = 2.00$$

$$\mu = 2.1979728E-011$$

$$V_u = 2.7468482E-047$$

$$d = 0.8 \cdot D = 400.00$$

$$N_u = 7389.214$$

$$A_g = 196349.541$$

From (11.5.4.8), ACI 318-14: $V_s = V_{s1} + V_{s2} = 274157.871$

$V_{s1} = 274157.871$ is calculated for jacket, with:

$$A_v = \sqrt{2} \cdot A_{stirrup} = 123370.055$$

$$f_y = 555.56$$

$$s = 100.00$$

V_{s1} is multiplied by $Col1 = 1.00$

$$s/d = 0.25$$

$V_{s2} = 0.00$ is calculated for core, with:

$$A_v = \sqrt{2} \cdot A_{stirrup} = 78956.835$$

$$f_y = 555.56$$

$$s = 250.00$$

V_{s2} is multiplied by $Col2 = 0.00$

$$s/d = 1.04167$$

V_f ((11-3)-(11.4), ACI 440) = 0.00

From (11-11), ACI 440: $V_s + V_f \leq 479549.663$
 $bw*d = *d*d/4 = 125663.706$

Calculation of Shear Strength at edge 2, $V_{r2} = 500419.792$
 $V_{r2} = V_{Col} ((10.3), ASCE 41-17) = knl * V_{Col0}$
 $V_{Col0} = 500419.792$
 $knl = 1$ (zero step-static loading)

NOTE: In expression (10-3) ' $V_s = A_v * f_y * d / s$ ' is replaced by ' $V_s + f * V_f$ '
where V_f is the contribution of FRPs (11.3), ACI 440).

$= 1$ (normal-weight concrete)
Mean concrete strength: $f_c' = (f_c'_{jacket} * Area_{jacket} + f_c'_{core} * Area_{core}) / Area_{section} = 33.00$, but $f_c'^{0.5} \leq 8.3$
MPa (22.5.3.1, ACI 318-14)
 $M/Vd = 2.00$
 $\mu_u = 2.1979728E-011$
 $V_u = 2.7468482E-047$
 $d = 0.8 * D = 400.00$
 $N_u = 7389.214$
 $A_g = 196349.541$
From (11.5.4.8), ACI 318-14: $V_s = V_{s1} + V_{s2} = 274157.871$
 $V_{s1} = 274157.871$ is calculated for jacket, with:
 $A_v = /2 * A_{stirrup} = 123370.055$
 $f_y = 555.56$
 $s = 100.00$
 V_{s1} is multiplied by $Col1 = 1.00$
 $s/d = 0.25$
 $V_{s2} = 0.00$ is calculated for core, with:
 $A_v = /2 * A_{stirrup} = 78956.835$
 $f_y = 555.56$
 $s = 250.00$
 V_{s2} is multiplied by $Col2 = 0.00$
 $s/d = 1.04167$
 $V_f ((11-3)-(11.4), ACI 440) = 0.00$
From (11-11), ACI 440: $V_s + V_f \leq 479549.663$
 $bw*d = *d*d/4 = 125663.706$

End Of Calculation of Shear Capacity ratio for element: column JCC1 of floor 1
At local axis: 2

Start Of Calculation of Chord Rotation Capacity for element: column JCC1 of floor 1

At local axis: 2
Integration Section: (a)
Section Type: rcjcs

Constant Properties

Knowledge Factor, $= 1.00$
Chord Rotation is generally considered as Deformation-Controlled Action according to Table C7-1, ASCE 41-17.
Mean strengths are used for Deformation-Controlled Actions according to 7.5.1.3, ASCE 41-17
Consequently:
Jacket
New material of Primary Member: Concrete Strength, $f_c = f_{cm} = 33.00$
New material of Primary Member: Steel Strength, $f_s = f_{sm} = 555.56$
Concrete Elasticity, $E_c = 26999.444$
Steel Elasticity, $E_s = 200000.00$
Existing Column
New material of Primary Member: Concrete Strength, $f_c = f_{cm} = 33.00$
New material of Primary Member: Steel Strength, $f_s = f_{sm} = 555.56$
Concrete Elasticity, $E_c = 26999.444$
Steel Elasticity, $E_s = 200000.00$
External Diameter, $D = 500.00$

Internal Diameter, D = 300.00
Cover Thickness, c = 25.00
Element Length, L = 3000.00
Primary Member
Smooth Bars
Ductile Steel
With Detailing for Earthquake Resistance (including stirrups closed at 135°)
Longitudinal Bars With Ends Lapped Starting at the End Sections
Adequate Lap Length ($l_b/l_d >= 1$)
No FRP Wrapping

Stepwise Properties

Bending Moment, M = 9.8351515E-010
Shear Force, V2 = -4754.456
Shear Force, V3 = -3.3978885E-013
Axial Force, F = -7387.312
Longitudinal Reinforcement Area Distribution (in 2 divisions)
-Tension: A_{st} = 0.00
-Compression: A_{sc} = 3053.628
Longitudinal Reinforcement Area Distribution (in 3 divisions)
-Tension: A_{sl,ten} = 1017.876
-Compression: A_{sl,com} = 1017.876
-Middle: A_{sl,mid} = 1017.876
Mean Diameter of Tension Reinforcement, D_{bL} = 18.00

New component: From table 7-7, ASCE 41_17: Final chord rotation Capacity $u_{,R} = 1.0^* u = 0.06266099$
 $u = y + p = 0.06266099$

- Calculation of y -

$y = (M_y * L_s / 3) / E_{eff} = 0.00729549$ ((4.29), Biskinis Phd)
M_y = 3.6259E+008
L_s = M/V (with L_s > 0.1*L and L_s < 2*L) = 1500.00
From table 10.5, ASCE 41_17: E_{eff} = factor * E_c * I_g = 2.4850E+013
factor = 0.30
A_g = 196349.541
Mean concrete strength: f_c' = (f_c'_{jacket} * Area_{jacket} + f_c'_{core} * Area_{core}) / Area_{section} = 33.00
N = 7387.312
E_c * I_g = E_c_{jacket} * I_g_{jacket} + E_c_{core} * I_g_{core} = 8.2833E+013

Calculation of Yielding Moment M_y

Calculation of y and M_y according to (7) - (8) in Biskinis and Fardis

M_y = Min(M_y_{ten}, M_y_{com}) = 3.6259E+008
y ((10a) or (10b)) = 1.0622309E-005
M_y_{ten} (8a) = 3.6259E+008
_ten (7a) = 65.4363
error of function (7a) = 0.0029309
M_y_{com} (8b) = 7.5621E+008
_com (7b) = 64.56804
error of function (7b) = -0.00721905
with e_y = 0.0027778
e_{co} = 0.002
a_{pl} = 0.35 ((9a) in Biskinis and Fardis for no FRP Wrap)
d₁ = 44.00
R = 250.00
v = 0.0011401
N = 7387.312

$$A_c = 196349.541$$
$$= 0.26182028$$

with $f_c = 33.00$

Calculation of ratio l_b/l_d

Adequate Lap Length: $l_b/l_d \geq 1$

- Calculation of ρ -

From table 10-9: $\rho = 0.05536551$

with:

- Columns not controlled by inadequate development or splicing along the clear height because $l_b/l_d \geq 1$
shear control ratio $V_y E / V_{CoI} E = 0.54503121$

$$d = d_{\text{external}} = 0.00$$

$$s = s_{\text{external}} = 0.00$$

$$t = s_1 + s_2 + 2 \cdot t_f / b_w \cdot (f_{fe} / f_s) = 0.00323428$$

$$\text{jacket: } s_1 = A_{v1} \cdot (D_{c1} / 2) / (s_1 \cdot A_g) = 0.0027646$$

$A_{v1} = 78.53982$, is the area of stirrup

$D_{c1} = D_{\text{ext}} - 2 \cdot \text{cover} - \text{External Hoop Diameter} = 440.00$, is the total Length of all stirrups parallel to loading

(shear) direction

$$s_1 = 100.00$$

$$\text{core: } s_2 = A_{v2} \cdot (D_{c2} / 2) / (s_2 \cdot A_g) = 0.00046968$$

$A_{v2} = 50.26548$, is the area of stirrup

$D_{c2} = D_{\text{int}} - \text{Internal Hoop Diameter} = 292.00$, is the total Length of all stirrups parallel to loading (shear)

direction

$$s_2 = 250.00$$

The term $2 \cdot t_f / b_w \cdot (f_{fe} / f_s)$ is implemented to account for FRP contribution

where $f = 2 \cdot t_f / b_w$ is FRP ratio (EC8 - 3, A.4.4.3(6)) and f_{fe} / f_s normalises f to steel strength

All these variables have already been given in Shear control ratio calculation.

For the normalisation f_s of jacket is used.

$$N_{UD} = 7387.312$$

$$A_g = 196349.541$$

$$f_{cE} = (f_{c_{\text{jacket}}} \cdot \text{Area}_{\text{jacket}} + f_{c_{\text{core}}} \cdot \text{Area}_{\text{core}}) / \text{section_area} = 33.00$$

$$f_{yE} = (f_{y_{\text{ext_Long_Reinf}}} \cdot \text{Area}_{\text{ext_Long_Reinf}} + f_{y_{\text{int_Long_Reinf}}} \cdot \text{Area}_{\text{int_Long_Reinf}}) / \text{Area}_{\text{Tot_Long_Rein}} = 2.1219958E-314$$

$$f_{yE} = (f_{y_{\text{ext_Trans_Reinf}}} \cdot \text{Area}_{\text{ext_Trans_Reinf}} + f_{y_{\text{int_Trans_Reinf}}} \cdot \text{Area}_{\text{int_Trans_Reinf}}) / \text{Area}_{\text{Tot_Trans_Rein}} = 555.56$$

$$\rho_l = \text{Area}_{\text{Tot_Long_Rein}} / (A_g) = 0.015552$$

$$f_{cE} = 33.00$$

End Of Calculation of Chord Rotation Capacity for element: column JCC1 of floor 1

At local axis: 2

Integration Section: (a)

Calculation No. 11

column C1, Floor 1


Limit State: Collapse Prevention (data interpolation between analysis steps 1 and 2)

Analysis: Uniform +X

Check: Shear capacity VRd

Edge: Start

Local Axis: (3)



Start Of Calculation of Shear Capacity for element: column JCC1 of floor 1

At local axis: 3

Integration Section: (a)

Section Type: rcjcs

Constant Properties

Knowledge Factor, $\gamma = 1.00$

Member Shear Force is generally considered as Force-Controlled Action according to Table C7-1, ASCE 41-17.

Lower-bound strengths are used for Force-Controlled Actions according to 7.5.1.3, ASCE 41-17

Consequently:

Jacket

New material of Primary Member: Concrete Strength, $f_c = f_{c_lower_bound} = 25.00$

New material of Primary Member: Steel Strength, $f_s = f_{s_lower_bound} = 500.00$

Concrete Elasticity, $E_c = 26999.444$

Steel Elasticity, $E_s = 200000.00$

Existing Column

New material of Primary Member: Concrete Strength, $f_c = f_{c_lower_bound} = 25.00$

New material of Primary Member: Steel Strength, $f_s = f_{s_lower_bound} = 500.00$

Concrete Elasticity, $E_c = 26999.444$

Steel Elasticity, $E_s = 200000.00$

#####

Note: Especially for the calculation of γ for displacement ductility demand, the expected (mean value) strengths are used (7.5.1.3, ASCE 41-17) because bending is considered as Deformation-Controlled Action (Table C7-1, ASCE 41-17).

Jacket

New material: Concrete Strength, $f_c = f_{cm} = 33.00$

New material: Steel Strength, $f_s = f_{sm} = 555.56$

Existing Column

New material: Concrete Strength, $f_c = f_{cm} = 33.00$

New material: Steel Strength, $f_s = f_{sm} = 555.56$

#####

External Diameter, $D = 500.00$

Internal Diameter, $D = 300.00$

Cover Thickness, $c = 25.00$

Element Length, $L = 3000.00$

Primary Member

Smooth Bars

Ductile Steel

With Detailing for Earthquake Resistance (including stirrups closed at 135°)
Longitudinal Bars With Ends Lapped Starting at the End Sections
Adequate Lap Length ($l_o/l_{ou,min} = l_b/l_d \geq 1$)
No FRP Wrapping

Stepwise Properties

EDGE -A-
Bending Moment, $M_a = 9.8351515E-010$
Shear Force, $V_a = -3.3978885E-013$
EDGE -B-
Bending Moment, $M_b = 3.6076925E-011$
Shear Force, $V_b = 3.3978885E-013$
BOTH EDGES
Axial Force, $F = -7387.312$
Longitudinal Reinforcement Area Distribution (in 2 divisions)
-Tension: $A_{st} = 0.00$
-Compression: $A_{sc} = 3053.628$
Longitudinal Reinforcement Area Distribution (in 3 divisions)
-Tension: $A_{st,ten} = 1017.876$
-Compression: $A_{sc,com} = 1017.876$
-Middle: $A_{st,mid} = 1017.876$
Mean Diameter of Tension Reinforcement, $D_{bL,ten} = 18.00$

New component: From table 7-7, ASCE 41_17: Final Shear Capacity $V_R = 1.0 \cdot V_n = 443865.663$
 V_n ((10.3), ASCE 41-17) = $k_n \cdot V_{CoI0} = 443865.663$
 $V_{CoI} = 443865.663$
 $k_n = 1.00$
displacement_ductility_demand = 0.00

NOTE: In expression (10-3) ' $V_s = A_v \cdot f_y \cdot d / s$ ' is replaced by ' $V_s + f \cdot V_f$ '
where V_f is the contribution of FRPs (11.3), ACI 440).

= 1 (normal-weight concrete)
Mean concrete strength: $f'_c = (f'_{c,jacket} \cdot Area_{jacket} + f'_{c,core} \cdot Area_{core}) / Area_{section} = 25.00$, but $f'_c^{0.5} \leq 8.3$
MPa (22.5.3.1, ACI 318-14)
 $M/d = 2.00$
 $M_u = 9.8351515E-010$
 $V_u = 3.3978885E-013$
 $d = 0.8 \cdot D = 400.00$
 $N_u = 7387.312$
 $A_g = 196349.541$
From (11.5.4.8), ACI 318-14: $V_s = V_{s1} + V_{s2} = 246740.11$
 $V_{s1} = 246740.11$ is calculated for jacket, with:
 $A_v = \sqrt{2} \cdot A_{stirrup} = 123370.055$
 $f_y = 500.00$
 $s = 100.00$
 V_{s1} is multiplied by $Col1 = 1.00$
 $s/d = 0.25$
 $V_{s2} = 0.00$ is calculated for core, with:
 $A_v = \sqrt{2} \cdot A_{stirrup} = 78956.835$
 $f_y = 500.00$
 $s = 250.00$
 V_{s2} is multiplied by $Col2 = 0.00$
 $s/d = 1.04167$
 V_f ((11-3)-(11.4), ACI 440) = 0.00
From (11-11), ACI 440: $V_s + V_f \leq 417394.406$
 $b_w \cdot d = \sqrt{2} \cdot d^2 / 4 = 125663.706$

displacement_ductility_demand is calculated as $\frac{V_u}{V_R} \cdot \frac{d}{y}$

- Calculation of ϕ_y for END A -
for rotation axis 2 and integ. section (a)

From analysis, chord rotation $\theta = 1.0237997E-020$

$$y = (M_y * L_s / 3) / E_{eff} = 0.00729549 \text{ ((4.29), Biskinis Phd)}$$

$$M_y = 3.6259E+008$$

$$L_s = M/V \text{ (with } L_s > 0.1 * L \text{ and } L_s < 2 * L) = 1500.00$$

$$\text{From table 10.5, ASCE 41_17: } E_{eff} = \text{factor} * E_c * I_g = 2.4850E+013$$

$$\text{factor} = 0.30$$

$$A_g = 196349.541$$

$$\text{Mean concrete strength: } f'_c = (f'_{c_jacket} * A_{jacket} + f'_{c_core} * A_{core}) / A_{section} = 33.00$$

$$N = 7387.312$$

$$E_c * I_g = E_{c_jacket} * I_{g_jacket} + E_{c_core} * I_{g_core} = 8.2833E+013$$

Calculation of Yielding Moment M_y

Calculation of ϕ_y and M_y according to (7) - (8) in Biskinis and Fardis

$$M_y = \text{Min}(M_{y_ten}, M_{y_com}) = 3.6259E+008$$

$$y \text{ ((10a) or (10b))} = 1.0622309E-005$$

$$M_{y_ten} \text{ (8a)} = 3.6259E+008$$

$$y_{ten} \text{ (7a)} = 65.4363$$

$$\text{error of function (7a)} = 0.0029309$$

$$M_{y_com} \text{ (8b)} = 7.5621E+008$$

$$y_{com} \text{ (7b)} = 64.56804$$

$$\text{error of function (7b)} = -0.00721905$$

$$\text{with } e_y = 0.0027778$$

$$e_{co} = 0.002$$

$$a_{pl} = 0.35 \text{ ((9a) in Biskinis and Fardis for no FRP Wrap)}$$

$$d_1 = 44.00$$

$$R = 250.00$$

$$v = 0.0011401$$

$$N = 7387.312$$

$$A_c = 196349.541$$

$$= 0.26182028$$

$$\text{with } f_c = 33.00$$

Calculation of ratio I_b/I_d

Adequate Lap Length: $I_b/I_d \geq 1$

End Of Calculation of Shear Capacity for element: column JCC1 of floor 1

At local axis: 3

Integration Section: (a)

Calculation No. 12

column C1, Floor 1


Limit State: Collapse Prevention (data interpolation between analysis steps 1 and 2)

Analysis: Uniform +X

Check: Chord rotation capacity (θ_r)

Edge: Start

Local Axis: (3)



Start Of Calculation of Shear Capacity ratio for element: column JCC1 of floor 1

At Shear local axis: 3

(Bending local axis: 2)

Section Type: rcjcs

Constant Properties

Knowledge Factor, $\gamma = 1.00$

Mean strength values are used for both shear and moment calculations.

Consequently:

Jacket

New material of Primary Member: Concrete Strength, $f_c = f_{cm} = 33.00$

New material of Primary Member: Steel Strength, $f_s = f_{sm} = 555.56$

Concrete Elasticity, $E_c = 26999.444$

Steel Elasticity, $E_s = 200000.00$

Existing Column

New material of Primary Member: Concrete Strength, $f_c = f_{cm} = 33.00$

New material of Primary Member: Steel Strength, $f_s = f_{sm} = 555.56$

Concrete Elasticity, $E_c = 26999.444$

Steel Elasticity, $E_s = 200000.00$

#####

Note: Especially for the calculation of moment strengths,

the above steel re-bar strengths are multiplied by 1.25 according to R18.6.5, ACI 318-14

Jacket

New material: Steel Strength, $f_s = 1.25 \cdot f_{sm} = 694.45$

Existing Column

New material: Steel Strength, $f_s = 1.25 \cdot f_{sm} = 694.45$

#####

External Diameter, $D = 500.00$

Internal Diameter, $D = 300.00$

Cover Thickness, $c = 25.00$

Mean Confinement Factor overall section = 1.30349

Element Length, $L = 3000.00$

Primary Member

Smooth Bars

Ductile Steel

With Detailing for Earthquake Resistance (including stirrups closed at 135°)

Longitudinal Bars With Ends Lapped Starting at the End Sections

Adequate Lap Length ($l_o/l_{ou, \min} > 1$)

No FRP Wrapping

Stepwise Properties

At local axis: 3

EDGE -A-

Shear Force, $V_a = 4.4860917E-031$

EDGE -B-

Shear Force, $V_b = -4.4860917E-031$

BOTH EDGES

Axial Force, $F = -7389.214$

Longitudinal Reinforcement Area Distribution (in 2 divisions)

-Tension: $As_t = 0.00$

-Compression: $As_c = 3053.628$

Longitudinal Reinforcement Area Distribution (in 3 divisions)

-Tension: $As_{t,ten} = 1017.876$

-Compression: $As_{c,com} = 1017.876$

-Middle: $As_{mid} = 1017.876$

Calculation of Shear Capacity ratio, $V_e/V_r = 0.54503121$

Member Controlled by Flexure ($V_e/V_r < 1$)

Calculation of Shear Demand from fig. R18.6.5, ACI 318-14 $V_e = (M_{pr1} + M_{pr2})/l_n = 272744.406$

with

$M_{pr1} = \text{Max}(M_{u1+}, M_{u1-}) = 4.0912E+008$

$M_{u1+} = 4.0912E+008$, is the ultimate moment strength at the edge 1 of the member in the actual moment direction which is defined for the static loading combination

$M_{u1-} = 4.0912E+008$, is the ultimate moment strength at the edge 1 of the member in the opposite moment direction which is defined for the static loading combination

$M_{pr2} = \text{Max}(M_{u2+}, M_{u2-}) = 4.0912E+008$

$M_{u2+} = 4.0912E+008$, is the ultimate moment strength at the edge 2 of the member in the actual moment direction which is defined for the the static loading combination

$M_{u2-} = 4.0912E+008$, is the ultimate moment strength at the edge 2 of the member in the opposite moment direction which is defined for the the static loading combination

Calculation of M_{u1+}

Calculation of ultimate Moment Strength ((3.67), Biskinis Phd), M_u

$M_u = 4.0912E+008$

$\phi = 0.97738438$

$\phi' = 0.86668818$

error of function (3.68), Biskinis Phd = 94694.946

From 5A.2, TBDY: $f_{cc} = f_c \cdot c = 43.01531$

conf. factor $c = 1.30349$

$f_c = 33.00$

From 10.3.5, ASCE 41-17, Final value of f_y : $f_y \cdot \text{Min}(1, 1.25 \cdot (l_b/d)^{2/3}) = 694.45$

$l_b/d = 1.00$

$d_1 = 44.00$

$R = 250.00$

$v = 0.0011401$

$N = 7389.214$

$A_c = 196349.541$

$\phi' \cdot \text{Min}(1, 1.25 \cdot (l_b/d)^{2/3}) = 0.26182028$

Calculation of ratio l_b/d

Adequate Lap Length: $l_b/d \geq 1$

Calculation of Mu1-

Calculation of ultimate Moment Strength ((3.67), Biskinis Phd), Mu
Mu = 4.0912E+008

= 0.97738438
' = 0.86668818
error of function (3.68), Biskinis Phd = 94694.946
From 5A.2, TBDY: fcc = fc* c = 43.01531
conf. factor c = 1.30349
fc = 33.00
From 10.3.5, ASCE 41-17, Final value of fy: fy*Min(1,1.25*(lb/d)^ 2/3) = 694.45
lb/d = 1.00
d1 = 44.00
R = 250.00
v = 0.0011401
N = 7389.214
Ac = 196349.541
= *Min(1,1.25*(lb/d)^ 2/3) = 0.26182028

Calculation of ratio lb/d

Adequate Lap Length: lb/d >= 1

Calculation of Mu2+

Calculation of ultimate Moment Strength ((3.67), Biskinis Phd), Mu
Mu = 4.0912E+008

= 0.97738438
' = 0.86668818
error of function (3.68), Biskinis Phd = 94694.946
From 5A.2, TBDY: fcc = fc* c = 43.01531
conf. factor c = 1.30349
fc = 33.00
From 10.3.5, ASCE 41-17, Final value of fy: fy*Min(1,1.25*(lb/d)^ 2/3) = 694.45
lb/d = 1.00
d1 = 44.00
R = 250.00
v = 0.0011401
N = 7389.214
Ac = 196349.541
= *Min(1,1.25*(lb/d)^ 2/3) = 0.26182028

Calculation of ratio lb/d

Adequate Lap Length: lb/d >= 1

Calculation of Mu2-

Calculation of ultimate Moment Strength ((3.67), Biskinis Phd), Mu
Mu = 4.0912E+008

= 0.97738438

$\lambda = 0.86668818$
 error of function (3.68), Biskinis Phd = 94694.946
 From 5A.2, TBDY: $f_{cc} = f_c \cdot c = 43.01531$
 conf. factor $c = 1.30349$
 $f_c = 33.00$
 From 10.3.5, ASCE 41-17, Final value of f_y : $f_y \cdot \text{Min}(1, 1.25 \cdot (l_b/d)^{2/3}) = 694.45$
 $l_b/d = 1.00$
 $d_1 = 44.00$
 $R = 250.00$
 $v = 0.0011401$
 $N = 7389.214$
 $A_c = 196349.541$
 $= \cdot \text{Min}(1, 1.25 \cdot (l_b/d)^{2/3}) = 0.26182028$

 Calculation of ratio l_b/d

Adequate Lap Length: $l_b/d \geq 1$

 Calculation of Shear Strength $V_r = \text{Min}(V_{r1}, V_{r2}) = 500419.792$

Calculation of Shear Strength at edge 1, $V_{r1} = 500419.792$

$V_{r1} = V_{Co1}$ ((10.3), ASCE 41-17) = $k_{nl} \cdot V_{Co10}$
 $V_{Co10} = 500419.792$
 $k_{nl} = 1$ (zero step-static loading)

 NOTE: In expression (10-3) ' $V_s = A_v \cdot f_y \cdot d/s$ ' is replaced by ' $V_s + f \cdot V_f$ '
 where V_f is the contribution of FRPs (11.3), ACI 440).

$= 1$ (normal-weight concrete)
 Mean concrete strength: $f'_c = (f'_{c_jacket} \cdot \text{Area}_{jacket} + f'_{c_core} \cdot \text{Area}_{core}) / \text{Area}_{section} = 33.00$, but $f_c^{0.5} \leq 8.3$
 MPa (22.5.3.1, ACI 318-14)

$M/Vd = 2.00$
 $\mu_u = 2.5382294E-011$
 $\nu_u = 4.4860917E-031$
 $d = 0.8 \cdot D = 400.00$
 $N_u = 7389.214$
 $A_g = 196349.541$
 From (11.5.4.8), ACI 318-14: $V_s = V_{s1} + V_{s2} = 274157.871$
 $V_{s1} = 274157.871$ is calculated for jacket, with:
 $A_v = \sqrt{2} \cdot A_{stirrup} = 123370.055$
 $f_y = 555.56$
 $s = 100.00$
 V_{s1} is multiplied by $Col1 = 1.00$
 $s/d = 0.25$
 $V_{s2} = 0.00$ is calculated for core, with:
 $A_v = \sqrt{2} \cdot A_{stirrup} = 78956.835$
 $f_y = 555.56$
 $s = 250.00$
 V_{s2} is multiplied by $Col2 = 0.00$
 $s/d = 1.04167$
 V_f ((11-3)-(11.4), ACI 440) = 0.00
 From (11-11), ACI 440: $V_s + V_f \leq 479549.663$
 $b_w \cdot d = \cdot d \cdot d/4 = 125663.706$

 Calculation of Shear Strength at edge 2, $V_{r2} = 500419.792$

$V_{r2} = V_{Co2}$ ((10.3), ASCE 41-17) = $k_{nl} \cdot V_{Co20}$
 $V_{Co20} = 500419.792$
 $k_{nl} = 1$ (zero step-static loading)

 NOTE: In expression (10-3) ' $V_s = A_v \cdot f_y \cdot d/s$ ' is replaced by ' $V_s + f \cdot V_f$ '
 where V_f is the contribution of FRPs (11.3), ACI 440).

= 1 (normal-weight concrete)

Mean concrete strength: $f_c' = (f_c'_{jacket} \cdot Area_{jacket} + f_c'_{core} \cdot Area_{core}) / Area_{section} = 33.00$, but $f_c'^{0.5} \leq 8.3$ MPa (22.5.3.1, ACI 318-14)

$M/Vd = 2.00$

$\mu_u = 2.5382294E-011$

$\nu_u = 4.4860917E-031$

$d = 0.8 \cdot D = 400.00$

$N_u = 7389.214$

$A_g = 196349.541$

From (11.5.4.8), ACI 318-14: $V_s = V_{s1} + V_{s2} = 274157.871$

$V_{s1} = 274157.871$ is calculated for jacket, with:

$A_v = \sqrt{2} \cdot A_{stirrup} = 123370.055$

$f_y = 555.56$

$s = 100.00$

V_{s1} is multiplied by $Col1 = 1.00$

$s/d = 0.25$

$V_{s2} = 0.00$ is calculated for core, with:

$A_v = \sqrt{2} \cdot A_{stirrup} = 78956.835$

$f_y = 555.56$

$s = 250.00$

V_{s2} is multiplied by $Col2 = 0.00$

$s/d = 1.04167$

V_f ((11-3)-(11.4), ACI 440) = 0.00

From (11-11), ACI 440: $V_s + V_f \leq 479549.663$

$b_w \cdot d = \sqrt{3} \cdot d^2 / 4 = 125663.706$

End Of Calculation of Shear Capacity ratio for element: column JCC1 of floor 1
At local axis: 3

Start Of Calculation of Shear Capacity ratio for element: column JCC1 of floor 1
At Shear local axis: 2
(Bending local axis: 3)
Section Type: rcjcs

Constant Properties

Knowledge Factor, $\phi = 1.00$

Mean strength values are used for both shear and moment calculations.

Consequently:

Jacket

New material of Primary Member: Concrete Strength, $f_c = f_{cm} = 33.00$

New material of Primary Member: Steel Strength, $f_s = f_{sm} = 555.56$

Concrete Elasticity, $E_c = 26999.444$

Steel Elasticity, $E_s = 200000.00$

Existing Column

New material of Primary Member: Concrete Strength, $f_c = f_{cm} = 33.00$

New material of Primary Member: Steel Strength, $f_s = f_{sm} = 555.56$

Concrete Elasticity, $E_c = 26999.444$

Steel Elasticity, $E_s = 200000.00$

#####

Note: Especially for the calculation of moment strengths,

the above steel re-bar strengths are multiplied by 1.25 according to R18.6.5, ACI 318-14

Jacket

New material: Steel Strength, $f_s = 1.25 \cdot f_{sm} = 694.45$

Existing Column

New material: Steel Strength, $f_s = 1.25 \cdot f_{sm} = 694.45$

#####

External Diameter, $D = 500.00$

Internal Diameter, $D = 300.00$

Cover Thickness, $c = 25.00$

Mean Confinement Factor overall section = 1.30349

Element Length, $L = 3000.00$

Primary Member

Smooth Bars
Ductile Steel
With Detailing for Earthquake Resistance (including stirrups closed at 135°)
Longitudinal Bars With Ends Lapped Starting at the End Sections
Adequate Lap Length ($l_o/l_{ou}, \min >= 1$)
No FRP Wrapping

Stepwise Properties

At local axis: 2
EDGE -A-
Shear Force, $V_a = -2.7468482E-047$
EDGE -B-
Shear Force, $V_b = 2.7468482E-047$
BOTH EDGES
Axial Force, $F = -7389.214$
Longitudinal Reinforcement Area Distribution (in 2 divisions)
-Tension: $A_{st} = 0.00$
-Compression: $A_{sc} = 3053.628$
Longitudinal Reinforcement Area Distribution (in 3 divisions)
-Tension: $A_{st,ten} = 1017.876$
-Compression: $A_{sc,com} = 1017.876$
-Middle: $A_{sc,mid} = 1017.876$

Calculation of Shear Capacity ratio, $V_e/V_r = 0.54503121$
Member Controlled by Flexure ($V_e/V_r < 1$)
Calculation of Shear Demand from fig. R18.6.5, ACI 318-14 $V_e = (M_{pr1} + M_{pr2})/l_n = 272744.406$
with
 $M_{pr1} = \text{Max}(M_{u1+}, M_{u1-}) = 4.0912E+008$
 $M_{u1+} = 4.0912E+008$, is the ultimate moment strength at the edge 1 of the member in the actual moment direction which is defined for the static loading combination
 $M_{u1-} = 4.0912E+008$, is the ultimate moment strength at the edge 1 of the member in the opposite moment direction which is defined for the static loading combination
 $M_{pr2} = \text{Max}(M_{u2+}, M_{u2-}) = 4.0912E+008$
 $M_{u2+} = 4.0912E+008$, is the ultimate moment strength at the edge 2 of the member in the actual moment direction which is defined for the the static loading combination
 $M_{u2-} = 4.0912E+008$, is the ultimate moment strength at the edge 2 of the member in the opposite moment direction which is defined for the the static loading combination

Calculation of M_{u1+}

Calculation of ultimate Moment Strength ((3.67), Biskinis Phd), M_u
 $M_u = 4.0912E+008$

 $\phi = 0.97738438$
 $\lambda = 0.86668818$
error of function (3.68), Biskinis Phd = 94694.946
From 5A.2, TBDY: $f_{cc} = f_c^* c = 43.01531$
conf. factor $\gamma_c = 1.30349$
 $f_c = 33.00$
From 10.3.5, ASCE 41-17, Final value of f_y : $f_y * \text{Min}(1, 1.25 * (l_b/l_d)^{2/3}) = 694.45$
 $l_b/l_d = 1.00$
 $d_1 = 44.00$
 $R = 250.00$
 $v = 0.0011401$
 $N = 7389.214$
 $A_c = 196349.541$
 $\phi * \text{Min}(1, 1.25 * (l_b/l_d)^{2/3}) = 0.26182028$

Calculation of ratio lb/d

Adequate Lap Length: $lb/d \geq 1$

Calculation of Mu1-

Calculation of ultimate Moment Strength ((3.67), Biskinis Phd), Mu
Mu = 4.0912E+008

$$= 0.97738438$$

$$' = 0.86668818$$

error of function (3.68), Biskinis Phd = 94694.946

From 5A.2, TBDY: $f_{cc} = f_c \cdot c = 43.01531$

conf. factor $c = 1.30349$

$f_c = 33.00$

From 10.3.5, ASCE 41-17, Final value of f_y : $f_y \cdot \text{Min}(1, 1.25 \cdot (lb/d)^{2/3}) = 694.45$

$$lb/d = 1.00$$

$$d1 = 44.00$$

$$R = 250.00$$

$$v = 0.0011401$$

$$N = 7389.214$$

$$Ac = 196349.541$$

$$= \cdot \text{Min}(1, 1.25 \cdot (lb/d)^{2/3}) = 0.26182028$$

Calculation of ratio lb/d

Adequate Lap Length: $lb/d \geq 1$

Calculation of Mu2+

Calculation of ultimate Moment Strength ((3.67), Biskinis Phd), Mu
Mu = 4.0912E+008

$$= 0.97738438$$

$$' = 0.86668818$$

error of function (3.68), Biskinis Phd = 94694.946

From 5A.2, TBDY: $f_{cc} = f_c \cdot c = 43.01531$

conf. factor $c = 1.30349$

$f_c = 33.00$

From 10.3.5, ASCE 41-17, Final value of f_y : $f_y \cdot \text{Min}(1, 1.25 \cdot (lb/d)^{2/3}) = 694.45$

$$lb/d = 1.00$$

$$d1 = 44.00$$

$$R = 250.00$$

$$v = 0.0011401$$

$$N = 7389.214$$

$$Ac = 196349.541$$

$$= \cdot \text{Min}(1, 1.25 \cdot (lb/d)^{2/3}) = 0.26182028$$

Calculation of ratio lb/d

Adequate Lap Length: $lb/d \geq 1$

Calculation of Mu2-

Calculation of ultimate Moment Strength ((3.67), Biskinis Phd), Mu
Mu = 4.0912E+008

= 0.97738438
' = 0.86668818
error of function (3.68), Biskinis Phd = 94694.946
From 5A.2, TBDY: fcc = fc* c = 43.01531
conf. factor c = 1.30349
fc = 33.00
From 10.3.5, ASCE 41-17, Final value of fy: fy*Min(1,1.25*(lb/d)^ 2/3) = 694.45
lb/d = 1.00
d1 = 44.00
R = 250.00
v = 0.0011401
N = 7389.214
Ac = 196349.541
= *Min(1,1.25*(lb/d)^ 2/3) = 0.26182028

Calculation of ratio lb/d

Adequate Lap Length: lb/d >= 1

Calculation of Shear Strength Vr = Min(Vr1,Vr2) = 500419.792

Calculation of Shear Strength at edge 1, Vr1 = 500419.792
Vr1 = VCol ((10.3), ASCE 41-17) = knl*VCol0
VCol0 = 500419.792
knl = 1 (zero step-static loading)

NOTE: In expression (10-3) 'Vs = Av*fy*d/s' is replaced by 'Vs+ f*Vf'
where Vf is the contribution of FRPs (11.3), ACI 440).

= 1 (normal-weight concrete)
Mean concrete strength: fc' = (fc'_jacket*Area_jacket + fc'_core*Area_core)/Area_section = 33.00, but fc'^0.5 <= 8.3
MPa (22.5.3.1, ACI 318-14)
M/d = 2.00
Mu = 2.1979728E-011
Vu = 2.7468482E-047
d = 0.8*D = 400.00
Nu = 7389.214
Ag = 196349.541
From (11.5.4.8), ACI 318-14: Vs = Vs1 + Vs2 = 274157.871
Vs1 = 274157.871 is calculated for jacket, with:
Av = /2*A_stirrup = 123370.055
fy = 555.56
s = 100.00
Vs1 is multiplied by Col1 = 1.00
s/d = 0.25
Vs2 = 0.00 is calculated for core, with:
Av = /2*A_stirrup = 78956.835
fy = 555.56
s = 250.00
Vs2 is multiplied by Col2 = 0.00
s/d = 1.04167
Vf ((11-3)-(11.4), ACI 440) = 0.00
From (11-11), ACI 440: Vs + Vf <= 479549.663
bw*d = *d*d/4 = 125663.706

Calculation of Shear Strength at edge 2, Vr2 = 500419.792
Vr2 = VCol ((10.3), ASCE 41-17) = knl*VCol0
VCol0 = 500419.792

kn1 = 1 (zero step-static loading)

NOTE: In expression (10-3) ' $V_s = A_v \cdot f_y \cdot d / s$ ' is replaced by ' $V_s + f \cdot V_f$ '
where V_f is the contribution of FRPs (11.3), ACI 440).

= 1 (normal-weight concrete)

Mean concrete strength: $f_c' = (f_c'_{\text{jacket}} \cdot \text{Area}_{\text{jacket}} + f_c'_{\text{core}} \cdot \text{Area}_{\text{core}}) / \text{Area}_{\text{section}} = 33.00$, but $f_c'^{0.5} \leq 8.3$
MPa (22.5.3.1, ACI 318-14)

$M/Vd = 2.00$

$\mu_u = 2.1979728E-011$

$\nu_u = 2.7468482E-047$

$d = 0.8 \cdot D = 400.00$

$N_u = 7389.214$

$A_g = 196349.541$

From (11.5.4.8), ACI 318-14: $V_s = V_{s1} + V_{s2} = 274157.871$

$V_{s1} = 274157.871$ is calculated for jacket, with:

$A_v = \sqrt{2} \cdot A_{\text{stirrup}} = 123370.055$

$f_y = 555.56$

$s = 100.00$

V_{s1} is multiplied by $\text{Col1} = 1.00$

$s/d = 0.25$

$V_{s2} = 0.00$ is calculated for core, with:

$A_v = \sqrt{2} \cdot A_{\text{stirrup}} = 78956.835$

$f_y = 555.56$

$s = 250.00$

V_{s2} is multiplied by $\text{Col2} = 0.00$

$s/d = 1.04167$

V_f ((11-3)-(11.4), ACI 440) = 0.00

From (11-11), ACI 440: $V_s + V_f \leq 479549.663$

$b_w \cdot d = \sqrt{4} \cdot d \cdot d / 4 = 125663.706$

End Of Calculation of Shear Capacity ratio for element: column JCC1 of floor 1
At local axis: 2

Start Of Calculation of Chord Rotation Capacity for element: column JCC1 of floor 1

At local axis: 3

Integration Section: (a)

Section Type: rcjcs

Constant Properties

Knowledge Factor, $\phi = 1.00$

Chord Rotation is generally considered as Deformation-Controlled Action according to Table C7-1, ASCE 41-17.

Mean strengths are used for Deformation-Controlled Actions according to 7.5.1.3, ASCE 41-17

Consequently:

Jacket

New material of Primary Member: Concrete Strength, $f_c = f_{cm} = 33.00$

New material of Primary Member: Steel Strength, $f_s = f_{sm} = 555.56$

Concrete Elasticity, $E_c = 26999.444$

Steel Elasticity, $E_s = 200000.00$

Existing Column

New material of Primary Member: Concrete Strength, $f_c = f_{cm} = 33.00$

New material of Primary Member: Steel Strength, $f_s = f_{sm} = 555.56$

Concrete Elasticity, $E_c = 26999.444$

Steel Elasticity, $E_s = 200000.00$

External Diameter, $D = 500.00$

Internal Diameter, $D = 300.00$

Cover Thickness, $c = 25.00$

Element Length, $L = 3000.00$

Primary Member

Smooth Bars

Ductile Steel

With Detailing for Earthquake Resistance (including stirrups closed at 135°)

Longitudinal Bars With Ends Lapped Starting at the End Sections
Adequate Lap Length ($l_b/l_d \geq 1$)
No FRP Wrapping

Stepwise Properties

Bending Moment, $M = -1.4267E+007$
Shear Force, $V2 = -4754.456$
Shear Force, $V3 = -3.3978885E-013$
Axial Force, $F = -7387.312$
Longitudinal Reinforcement Area Distribution (in 2 divisions)
-Tension: $A_{st} = 0.00$
-Compression: $A_{sc} = 3053.628$
Longitudinal Reinforcement Area Distribution (in 3 divisions)
-Tension: $A_{st,ten} = 1017.876$
-Compression: $A_{sc,com} = 1017.876$
-Middle: $A_{st,mid} = 1017.876$
Mean Diameter of Tension Reinforcement, $DbL = 18.00$

New component: From table 7-7, ASCE 41_17: Final chord rotation Capacity $u_{,R} = 1.0^*$ $u = 0.06996006$
 $u = y + p = 0.06996006$

- Calculation of y -

 $y = (M_y * L_s / 3) / E_{eff} = 0.01459455$ ((4.29), Biskinis Phd))
 $M_y = 3.6259E+008$
 $L_s = M/V$ (with $L_s > 0.1 * L$ and $L_s < 2 * L$) = 3000.736
From table 10.5, ASCE 41_17: $E_{eff} = factor * E_c * I_g = 2.4850E+013$
 $factor = 0.30$
 $A_g = 196349.541$
Mean concrete strength: $fc' = (fc'_{jacket} * Area_{jacket} + fc'_{core} * Area_{core}) / Area_{section} = 33.00$
 $N = 7387.312$
 $E_c * I_g = E_{c,jacket} * I_{g,jacket} + E_{c,core} * I_{g,core} = 8.2833E+013$

Calculation of Yielding Moment M_y

Calculation of y and M_y according to (7) - (8) in Biskinis and Fardis

 $M_y = \text{Min}(M_{y,ten}, M_{y,com}) = 3.6259E+008$
 y ((10a) or (10b)) = $1.0622309E-005$
 $M_{y,ten}$ (8a) = $3.6259E+008$
 y_{ten} (7a) = 65.4363
error of function (7a) = 0.0029309
 $M_{y,com}$ (8b) = $7.5621E+008$
 y_{com} (7b) = 64.56804
error of function (7b) = -0.00721905
with $e_y = 0.0027778$
 $e_{co} = 0.002$
 $apl = 0.35$ ((9a) in Biskinis and Fardis for no FRP Wrap)
 $d1 = 44.00$
 $R = 250.00$
 $v = 0.0011401$
 $N = 7387.312$
 $A_c = 196349.541$
 $= 0.26182028$
with $fc = 33.00$

Calculation of ratio l_b/l_d

Adequate Lap Length: $l_b/l_d \geq 1$

- Calculation of p -

From table 10-9: $p = 0.05536551$

with:

- Columns not controlled by inadequate development or splicing along the clear height because $l_b/l_d \geq 1$

shear control ratio $V_{yE}/V_{CoI0E} = 0.54503121$

$d = d_{\text{external}} = 0.00$

$s = s_{\text{external}} = 0.00$

$t = s_1 + s_2 + 2 \cdot t_f/bw \cdot (f_{fe}/f_s) = 0.00323428$

jacket: $s_1 = A_{v1} \cdot (D_{c1}/2)/(s_1 \cdot A_g) = 0.0027646$

$A_{v1} = 78.53982$, is the area of stirrup

$D_{c1} = D_{\text{ext}} - 2 \cdot \text{cover} - \text{External Hoop Diameter} = 440.00$, is the total Length of all stirrups parallel to loading

(shear) direction

$s_1 = 100.00$

core: $s_2 = A_{v2} \cdot (D_{c2}/2)/(s_2 \cdot A_g) = 0.00046968$

$A_{v2} = 50.26548$, is the area of stirrup

$D_{c2} = D_{\text{int}} - \text{Internal Hoop Diameter} = 292.00$, is the total Length of all stirrups parallel to loading (shear)

direction

$s_2 = 250.00$

The term $2 \cdot t_f/bw \cdot (f_{fe}/f_s)$ is implemented to account for FRP contribution

where $f = 2 \cdot t_f/bw$ is FRP ratio (EC8 - 3, A.4.4.3(6)) and f_{fe}/f_s normalises f to steel strength

All these variables have already been given in Shear control ratio calculation.

For the normalisation f_s of jacket is used.

$N_{UD} = 7387.312$

$A_g = 196349.541$

$f_{cE} = (f_{c,\text{jacket}} \cdot \text{Area}_{\text{jacket}} + f_{c,\text{core}} \cdot \text{Area}_{\text{core}})/\text{section_area} = 33.00$

$f_{yIE} = (f_{y,\text{ext_Long_Reinf}} \cdot \text{Area}_{\text{ext_Long_Reinf}} + f_{y,\text{int_Long_Reinf}} \cdot \text{Area}_{\text{int_Long_Reinf}})/\text{Area}_{\text{Tot_Long_Rein}} = 2.1219958E-314$

$f_{yIE} = (f_{y,\text{ext_Trans_Reinf}} \cdot \text{Area}_{\text{ext_Trans_Reinf}} + f_{y,\text{int_Trans_Reinf}} \cdot \text{Area}_{\text{int_Trans_Reinf}})/\text{Area}_{\text{Tot_Trans_Rein}} = 555.56$

$p_l = \text{Area}_{\text{Tot_Long_Rein}}/(A_g) = 0.015552$

$f_{cE} = 33.00$

End Of Calculation of Chord Rotation Capacity for element: column JCC1 of floor 1

At local axis: 3

Integration Section: (a)

Calculation No. 13

column C1, Floor 1



Limit State: Collapse Prevention (data interpolation between analysis steps 1 and 2)

Analysis: Uniform +X

Check: Shear capacity V_{Rd}

Edge: End

Local Axis: (2)



Start Of Calculation of Shear Capacity for element: column JCC1 of floor 1

At local axis: 2

Integration Section: (b)

Section Type: rcjcs

Constant Properties

Knowledge Factor, $\gamma = 1.00$

Member Shear Force is generally considered as Force-Controlled Action according to Table C7-1, ASCE 41-17.

Lower-bound strengths are used for Force-Controlled Actions according to 7.5.1.3, ASCE 41-17

Consequently:

Jacket

New material of Primary Member: Concrete Strength, $f_c = f_{c_lower_bound} = 25.00$

New material of Primary Member: Steel Strength, $f_s = f_{s_lower_bound} = 500.00$

Concrete Elasticity, $E_c = 26999.444$

Steel Elasticity, $E_s = 200000.00$

Existing Column

New material of Primary Member: Concrete Strength, $f_c = f_{c_lower_bound} = 25.00$

New material of Primary Member: Steel Strength, $f_s = f_{s_lower_bound} = 500.00$

Concrete Elasticity, $E_c = 26999.444$

Steel Elasticity, $E_s = 200000.00$

#####

Note: Especially for the calculation of γ for displacement ductility demand, the expected (mean value) strengths are used (7.5.1.3, ASCE 41-17) because bending is considered as Deformation-Controlled Action (Table C7-1, ASCE 41-17).

Jacket

New material: Concrete Strength, $f_c = f_{cm} = 33.00$

New material: Steel Strength, $f_s = f_{sm} = 555.56$

Existing Column

New material: Concrete Strength, $f_c = f_{cm} = 33.00$

New material: Steel Strength, $f_s = f_{sm} = 555.56$

#####

External Diameter, $D = 500.00$

Internal Diameter, $D = 300.00$

Cover Thickness, $c = 25.00$

Element Length, $L = 3000.00$

Primary Member

Smooth Bars

Ductile Steel

With Detailing for Earthquake Resistance (including stirrups closed at 135°)

Longitudinal Bars With Ends Lapped Starting at the End Sections

Adequate Lap Length ($l_o/l_{ou,min} = l_b/l_d \geq 1$)

No FRP Wrapping

Stepwise Properties

EDGE -A-

Bending Moment, $M_a = -1.4267E+007$

Shear Force, $V_a = -4754.456$

EDGE -B-

Bending Moment, $M_b = 0.02407461$

Shear Force, $V_b = 4754.456$
 BOTH EDGES
 Axial Force, $F = -7387.312$
 Longitudinal Reinforcement Area Distribution (in 2 divisions)
 -Tension: $As_t = 0.00$
 -Compression: $As_c = 3053.628$
 Longitudinal Reinforcement Area Distribution (in 3 divisions)
 -Tension: $As_{t,ten} = 1017.876$
 -Compression: $As_{c,com} = 1017.876$
 -Middle: $As_{c,mid} = 1017.876$
 Mean Diameter of Tension Reinforcement, $Db_{L,ten} = 18.00$

New component: From table 7-7, ASCE 41_17: Final Shear Capacity $VR = 1.0 \cdot V_n = 443865.663$
 $V_n ((10.3), ASCE 41-17) = knl \cdot V_{Col0} = 443865.663$
 $V_{Col} = 443865.663$
 $knl = 1.00$
 $displacement_ductility_demand = 0.05901542$

NOTE: In expression (10-3) ' $V_s = A_v \cdot f_y \cdot d / s$ ' is replaced by ' $V_s + f \cdot V_f$ '
 where V_f is the contribution of FRPs (11.3), ACI 440).

$= 1$ (normal-weight concrete)
 Mean concrete strength: $fc' = (fc'_{jacket} \cdot Area_{jacket} + fc'_{core} \cdot Area_{core}) / Area_{section} = 25.00$, but $fc'^{0.5} \leq 8.3$
 MPa (22.5.3.1, ACI 318-14)
 $M/Vd = 2.00$
 $\mu_u = 0.02407461$
 $V_u = 4754.456$
 $d = 0.8 \cdot D = 400.00$
 $N_u = 7387.312$
 $A_g = 196349.541$
 From (11.5.4.8), ACI 318-14: $V_s = V_{s1} + V_{s2} = 246740.11$
 $V_{s1} = 246740.11$ is calculated for jacket, with:
 $A_v = \sqrt{2} \cdot A_{stirrup} = 123370.055$
 $f_y = 500.00$
 $s = 100.00$
 V_{s1} is multiplied by $Col1 = 1.00$
 $s/d = 0.25$
 $V_{s2} = 0.00$ is calculated for core, with:
 $A_v = \sqrt{2} \cdot A_{stirrup} = 78956.835$
 $f_y = 500.00$
 $s = 250.00$
 V_{s2} is multiplied by $Col2 = 0.00$
 $s/d = 1.04167$
 $V_f ((11-3)-(11.4), ACI 440) = 0.00$
 From (11-11), ACI 440: $V_s + V_f \leq 417394.406$
 $b_w \cdot d = \sqrt{N_u} \cdot d / 4 = 125663.706$

$displacement_ductility_demand$ is calculated as μ / y

- Calculation of μ / y for END B -
 for rotation axis 3 and integ. section (b)

From analysis, chord rotation $\theta = 8.6109245E-005$
 $y = (M_y \cdot L_s / 3) / E_{eff} = 0.0014591$ ((4.29), Biskinis Phd)
 $M_y = 3.6259E+008$
 $L_s = M/V$ (with $L_s > 0.1 \cdot L$ and $L_s < 2 \cdot L$) = 300.00
 From table 10.5, ASCE 41_17: $E_{eff} = factor \cdot E_c \cdot I_g = 2.4850E+013$
 $factor = 0.30$
 $A_g = 196349.541$
 Mean concrete strength: $fc' = (fc'_{jacket} \cdot Area_{jacket} + fc'_{core} \cdot Area_{core}) / Area_{section} = 33.00$
 $N = 7387.312$
 $E_c \cdot I_g = E_{c,jacket} \cdot I_{g,jacket} + E_{c,core} \cdot I_{g,core} = 8.2833E+013$

Calculation of Yielding Moment M_y

Calculation of ρ_y and M_y according to (7) - (8) in Biskinis and Fardis

$M_y = \text{Min}(M_{y_ten}, M_{y_com}) = 3.6259E+008$

$\rho_y ((10a) \text{ or } (10b)) = 1.0622309E-005$

$M_{y_ten} (8a) = 3.6259E+008$

$\rho_{y_ten} (7a) = 65.4363$

error of function (7a) = 0.0029309

$M_{y_com} (8b) = 7.5621E+008$

$\rho_{y_com} (7b) = 64.56804$

error of function (7b) = -0.00721905

with $e_y = 0.0027778$

$e_{co} = 0.002$

$a_{pl} = 0.35 ((9a) \text{ in Biskinis and Fardis for no FRP Wrap})$

$d_1 = 44.00$

$R = 250.00$

$v = 0.0011401$

$N = 7387.312$

$A_c = 196349.541$

$= 0.26182028$

with $f_c = 33.00$

Calculation of ratio l_b/d

Adequate Lap Length: $l_b/d \geq 1$

End Of Calculation of Shear Capacity for element: column JCC1 of floor 1

At local axis: 2

Integration Section: (b)

Calculation No. 14

column C1, Floor 1



Limit State: Collapse Prevention (data interpolation between analysis steps 1 and 2)

Analysis: Uniform +X

Check: Chord rotation capacity (ρ_u)

Edge: End

Local Axis: (2)



Start Of Calculation of Shear Capacity ratio for element: column JCC1 of floor 1

At Shear local axis: 3
 (Bending local axis: 2)
 Section Type: rcjcs

Constant Properties

Knowledge Factor, $\gamma = 1.00$
 Mean strength values are used for both shear and moment calculations.
 Consequently:

Jacket

New material of Primary Member: Concrete Strength, $f_c = f_{cm} = 33.00$
 New material of Primary Member: Steel Strength, $f_s = f_{sm} = 555.56$
 Concrete Elasticity, $E_c = 26999.444$
 Steel Elasticity, $E_s = 200000.00$

Existing Column

New material of Primary Member: Concrete Strength, $f_c = f_{cm} = 33.00$
 New material of Primary Member: Steel Strength, $f_s = f_{sm} = 555.56$
 Concrete Elasticity, $E_c = 26999.444$
 Steel Elasticity, $E_s = 200000.00$

#####

Note: Especially for the calculation of moment strengths,
 the above steel re-bar strengths are multiplied by 1.25 according to R18.6.5, ACI 318-14

Jacket

New material: Steel Strength, $f_s = 1.25 \cdot f_{sm} = 694.45$

Existing Column

New material: Steel Strength, $f_s = 1.25 \cdot f_{sm} = 694.45$

#####

External Diameter, $D = 500.00$

Internal Diameter, $D = 300.00$

Cover Thickness, $c = 25.00$

Mean Confinement Factor overall section = 1.30349

Element Length, $L = 3000.00$

Primary Member

Smooth Bars

Ductile Steel

With Detailing for Earthquake Resistance (including stirrups closed at 135°)

Longitudinal Bars With Ends Lapped Starting at the End Sections

Adequate Lap Length ($l_o/l_{ou, min} >= 1$)

No FRP Wrapping

Stepwise Properties

At local axis: 3

EDGE -A-

Shear Force, $V_a = 4.4860917E-031$

EDGE -B-

Shear Force, $V_b = -4.4860917E-031$

BOTH EDGES

Axial Force, $F = -7389.214$

Longitudinal Reinforcement Area Distribution (in 2 divisions)

-Tension: Aslt = 0.00

-Compression: Aslc = 3053.628

Longitudinal Reinforcement Area Distribution (in 3 divisions)

-Tension: Asl,ten = 1017.876

-Compression: Asl,com = 1017.876

-Middle: Asl,mid = 1017.876

Calculation of Shear Capacity ratio , $V_e/V_r = 0.54503121$

Member Controlled by Flexure ($V_e/V_r < 1$)

Calculation of Shear Demand from fig. R18.6.5, ACI 318-14 $V_e = (M_{pr1} + M_{pr2})/l_n = 272744.406$

with

$M_{pr1} = \text{Max}(M_{u1+} , M_{u1-}) = 4.0912E+008$

$M_{u1+} = 4.0912E+008$, is the ultimate moment strength at the edge 1 of the member in the actual moment direction which is defined for the static loading combination

$M_{u1-} = 4.0912E+008$, is the ultimate moment strength at the edge 1 of the member in the opposite moment direction which is defined for the static loading combination

$M_{pr2} = \text{Max}(M_{u2+} , M_{u2-}) = 4.0912E+008$

$M_{u2+} = 4.0912E+008$, is the ultimate moment strength at the edge 2 of the member in the actual moment direction which is defined for the the static loading combination

$M_{u2-} = 4.0912E+008$, is the ultimate moment strength at the edge 2 of the member in the opposite moment direction which is defined for the the static loading combination

Calculation of M_{u1+}

Calculation of ultimate Moment Strength ((3.67), Biskinis Phd), M_u

$M_u = 4.0912E+008$

$\phi = 0.97738438$

$\lambda = 0.86668818$

error of function (3.68), Biskinis Phd = 94694.946

From 5A.2, TBDY: $f_{cc} = f_c \cdot c = 43.01531$

conf. factor $c = 1.30349$

$f_c = 33.00$

From 10.3.5, ASCE 41-17, Final value of f_y : $f_y \cdot \text{Min}(1, 1.25 \cdot (l_b/d)^{2/3}) = 694.45$

$l_b/d = 1.00$

$d_1 = 44.00$

$R = 250.00$

$v = 0.0011401$

$N = 7389.214$

$A_c = 196349.541$

$\phi \cdot \text{Min}(1, 1.25 \cdot (l_b/d)^{2/3}) = 0.26182028$

Calculation of ratio l_b/d

Adequate Lap Length: $l_b/d \geq 1$

Calculation of M_{u1-}

Calculation of ultimate Moment Strength ((3.67), Biskinis Phd), M_u

$M_u = 4.0912E+008$

$\phi = 0.97738438$

$\lambda = 0.86668818$

error of function (3.68), Biskinis Phd = 94694.946

From 5A.2, TBDY: $f_{cc} = f_c \cdot c = 43.01531$

conf. factor $c = 1.30349$

$f_c = 33.00$

From 10.3.5, ASCE 41-17, Final value of f_y : $f_y \cdot \text{Min}(1, 1.25 \cdot (l_b/d)^{2/3}) = 694.45$

$l_b/d = 1.00$

$d_1 = 44.00$

$R = 250.00$

$v = 0.0011401$

$N = 7389.214$

$A_c = 196349.541$

$= \text{Min}(1, 1.25 \cdot (l_b/d)^{2/3}) = 0.26182028$

Calculation of ratio l_b/d

Adequate Lap Length: $l_b/d \geq 1$

Calculation of μ_{2+}

Calculation of ultimate Moment Strength ((3.67), Biskinis Phd), μ

$\mu = 4.0912E+008$

$\phi = 0.97738438$

$\lambda = 0.86668818$

error of function (3.68), Biskinis Phd = 94694.946

From 5A.2, TBDY: $f_{cc} = f_c \cdot c = 43.01531$

conf. factor $c = 1.30349$

$f_c = 33.00$

From 10.3.5, ASCE 41-17, Final value of f_y : $f_y \cdot \text{Min}(1, 1.25 \cdot (l_b/d)^{2/3}) = 694.45$

$l_b/d = 1.00$

$d_1 = 44.00$

$R = 250.00$

$v = 0.0011401$

$N = 7389.214$

$A_c = 196349.541$

$= \text{Min}(1, 1.25 \cdot (l_b/d)^{2/3}) = 0.26182028$

Calculation of ratio l_b/d

Adequate Lap Length: $l_b/d \geq 1$

Calculation of μ_{2-}

Calculation of ultimate Moment Strength ((3.67), Biskinis Phd), μ

$\mu = 4.0912E+008$

$\phi = 0.97738438$

$\lambda = 0.86668818$

error of function (3.68), Biskinis Phd = 94694.946

From 5A.2, TBDY: $f_{cc} = f_c \cdot c = 43.01531$

conf. factor $c = 1.30349$

$f_c = 33.00$

From 10.3.5, ASCE 41-17, Final value of f_y : $f_y \cdot \text{Min}(1, 1.25 \cdot (l_b/d)^{2/3}) = 694.45$

$l_b/d = 1.00$

$d_1 = 44.00$

$R = 250.00$

$v = 0.0011401$

$N = 7389.214$

$A_c = 196349.541$

$= \text{Min}(1, 1.25 \cdot (l_b/d)^{2/3}) = 0.26182028$

Calculation of ratio l_b/d

Adequate Lap Length: $l_b/d \geq 1$

Calculation of Shear Strength $V_r = \text{Min}(V_{r1}, V_{r2}) = 500419.792$

Calculation of Shear Strength at edge 1, $V_{r1} = 500419.792$

$V_{r1} = V_{Col} \text{ ((10.3), ASCE 41-17)} = k_n l V_{Col0}$

$V_{Col0} = 500419.792$

$k_n l = 1$ (zero step-static loading)

NOTE: In expression (10-3) ' $V_s = A_v f_y d/s$ ' is replaced by ' $V_s + f V_f$ '
where V_f is the contribution of FRPs (11.3), ACI 440).

$= 1$ (normal-weight concrete)

Mean concrete strength: $f_c' = (f_c'_{jacket} \text{Area}_{jacket} + f_c'_{core} \text{Area}_{core}) / \text{Area}_{section} = 33.00$, but $f_c'^{0.5} \leq 8.3$
MPa (22.5.3.1, ACI 318-14)

$M/Vd = 2.00$

$\mu_u = 2.5382294E-011$

$\nu_u = 4.4860917E-031$

$d = 0.8D = 400.00$

$N_u = 7389.214$

$A_g = 196349.541$

From (11.5.4.8), ACI 318-14: $V_s = V_{s1} + V_{s2} = 274157.871$

$V_{s1} = 274157.871$ is calculated for jacket, with:

$A_v = \sqrt{2} A_{stirrup} = 123370.055$

$f_y = 555.56$

$s = 100.00$

V_{s1} is multiplied by $Col1 = 1.00$

$s/d = 0.25$

$V_{s2} = 0.00$ is calculated for core, with:

$A_v = \sqrt{2} A_{stirrup} = 78956.835$

$f_y = 555.56$

$s = 250.00$

V_{s2} is multiplied by $Col2 = 0.00$

$s/d = 1.04167$

$V_f \text{ ((11-3)-(11.4), ACI 440)} = 0.00$

From (11-11), ACI 440: $V_s + V_f \leq 479549.663$

$b_w d = \sqrt{2} d^2 / 4 = 125663.706$

Calculation of Shear Strength at edge 2, $V_{r2} = 500419.792$

$V_{r2} = V_{Col} \text{ ((10.3), ASCE 41-17)} = k_n l V_{Col0}$

$V_{Col0} = 500419.792$

$k_n l = 1$ (zero step-static loading)

NOTE: In expression (10-3) ' $V_s = A_v f_y d/s$ ' is replaced by ' $V_s + f V_f$ '
where V_f is the contribution of FRPs (11.3), ACI 440).

$= 1$ (normal-weight concrete)

Mean concrete strength: $f_c' = (f_c'_{jacket} \text{Area}_{jacket} + f_c'_{core} \text{Area}_{core}) / \text{Area}_{section} = 33.00$, but $f_c'^{0.5} \leq 8.3$
MPa (22.5.3.1, ACI 318-14)

$M/Vd = 2.00$

$\mu_u = 2.5382294E-011$

$\nu_u = 4.4860917E-031$

$d = 0.8D = 400.00$

$N_u = 7389.214$

$A_g = 196349.541$

From (11.5.4.8), ACI 318-14: $V_s = V_{s1} + V_{s2} = 274157.871$

$V_{s1} = 274157.871$ is calculated for jacket, with:

$A_v = \sqrt{2} A_{stirrup} = 123370.055$

$f_y = 555.56$

s = 100.00
Vs1 is multiplied by Col1 = 1.00
s/d = 0.25
Vs2 = 0.00 is calculated for core, with:
Av = $\sqrt{2} \cdot A_{stirrup} = 78956.835$
fy = 555.56
s = 250.00
Vs2 is multiplied by Col2 = 0.00
s/d = 1.04167
Vf ((11-3)-(11.4), ACI 440) = 0.00
From (11-11), ACI 440: Vs + Vf <= 479549.663
bw*d = $\sqrt{d} \cdot d / 4 = 125663.706$

End Of Calculation of Shear Capacity ratio for element: column JCC1 of floor 1
At local axis: 3

Start Of Calculation of Shear Capacity ratio for element: column JCC1 of floor 1
At Shear local axis: 2
(Bending local axis: 3)
Section Type: rcjcs

Constant Properties

Knowledge Factor, $\gamma = 1.00$
Mean strength values are used for both shear and moment calculations.
Consequently:
Jacket
New material of Primary Member: Concrete Strength, $f_c = f_{cm} = 33.00$
New material of Primary Member: Steel Strength, $f_s = f_{sm} = 555.56$
Concrete Elasticity, $E_c = 26999.444$
Steel Elasticity, $E_s = 200000.00$
Existing Column
New material of Primary Member: Concrete Strength, $f_c = f_{cm} = 33.00$
New material of Primary Member: Steel Strength, $f_s = f_{sm} = 555.56$
Concrete Elasticity, $E_c = 26999.444$
Steel Elasticity, $E_s = 200000.00$

Note: Especially for the calculation of moment strengths,
the above steel re-bar strengths are multiplied by 1.25 according to R18.6.5, ACI 318-14
Jacket
New material: Steel Strength, $f_s = 1.25 \cdot f_{sm} = 694.45$
Existing Column
New material: Steel Strength, $f_s = 1.25 \cdot f_{sm} = 694.45$

External Diameter, D = 500.00
Internal Diameter, D = 300.00
Cover Thickness, c = 25.00
Mean Confinement Factor overall section = 1.30349
Element Length, L = 3000.00
Primary Member
Smooth Bars
Ductile Steel
With Detailing for Earthquake Resistance (including stirrups closed at 135°)
Longitudinal Bars With Ends Lapped Starting at the End Sections
Adequate Lap Length ($l_o/l_{ou}, \min >= 1$)
No FRP Wrapping

Stepwise Properties

At local axis: 2
EDGE -A-
Shear Force, Va = -2.7468482E-047

EDGE -B-

Shear Force, $V_b = 2.7468482E-047$

BOTH EDGES

Axial Force, $F = -7389.214$

Longitudinal Reinforcement Area Distribution (in 2 divisions)

-Tension: $A_{st} = 0.00$

-Compression: $A_{sc} = 3053.628$

Longitudinal Reinforcement Area Distribution (in 3 divisions)

-Tension: $A_{st,ten} = 1017.876$

-Compression: $A_{sc,com} = 1017.876$

-Middle: $A_{st,mid} = 1017.876$

Calculation of Shear Capacity ratio, $V_e/V_r = 0.54503121$

Member Controlled by Flexure ($V_e/V_r < 1$)

Calculation of Shear Demand from fig. R18.6.5, ACI 318-14 $V_e = (M_{pr1} + M_{pr2})/l_n = 272744.406$

with

$M_{pr1} = \text{Max}(M_{u1+}, M_{u1-}) = 4.0912E+008$

$M_{u1+} = 4.0912E+008$, is the ultimate moment strength at the edge 1 of the member in the actual moment direction which is defined for the static loading combination

$M_{u1-} = 4.0912E+008$, is the ultimate moment strength at the edge 1 of the member in the opposite moment direction which is defined for the static loading combination

$M_{pr2} = \text{Max}(M_{u2+}, M_{u2-}) = 4.0912E+008$

$M_{u2+} = 4.0912E+008$, is the ultimate moment strength at the edge 2 of the member in the actual moment direction which is defined for the the static loading combination

$M_{u2-} = 4.0912E+008$, is the ultimate moment strength at the edge 2 of the member in the opposite moment direction which is defined for the the static loading combination

Calculation of M_{u1+}

Calculation of ultimate Moment Strength ((3.67), Biskinis Phd), M_u

$M_u = 4.0912E+008$

$\phi = 0.97738438$

$\phi' = 0.86668818$

error of function (3.68), Biskinis Phd = 94694.946

From 5A.2, TBDY: $f_{cc} = f_c \cdot c = 43.01531$

conf. factor $c = 1.30349$

$f_c = 33.00$

From 10.3.5, ASCE 41-17, Final value of f_y : $f_y \cdot \text{Min}(1, 1.25 \cdot (l_b/d)^{2/3}) = 694.45$

$l_b/d = 1.00$

$d_1 = 44.00$

$R = 250.00$

$v = 0.0011401$

$N = 7389.214$

$A_c = 196349.541$

$\phi \cdot \text{Min}(1, 1.25 \cdot (l_b/d)^{2/3}) = 0.26182028$

Calculation of ratio l_b/d

Adequate Lap Length: $l_b/d \geq 1$

Calculation of M_{u1-}

Calculation of ultimate Moment Strength ((3.67), Biskinis Phd), M_u

$M_u = 4.0912E+008$

= 0.97738438
' = 0.86668818
error of function (3.68), Biskinis Phd = 94694.946
From 5A.2, TBDY: $f_{cc} = f_c \cdot c = 43.01531$
conf. factor $c = 1.30349$
 $f_c = 33.00$
From 10.3.5, ASCE 41-17, Final value of f_y : $f_y \cdot \text{Min}(1, 1.25 \cdot (l_b/d)^{2/3}) = 694.45$
 $l_b/d = 1.00$
 $d_1 = 44.00$
 $R = 250.00$
 $v = 0.0011401$
 $N = 7389.214$
 $A_c = 196349.541$
 $= \cdot \text{Min}(1, 1.25 \cdot (l_b/d)^{2/3}) = 0.26182028$

Calculation of ratio l_b/d

Adequate Lap Length: $l_b/d \geq 1$

Calculation of μ_{2+}

Calculation of ultimate Moment Strength ((3.67), Biskinis Phd), μ
 $\mu = 4.0912E+008$

= 0.97738438
' = 0.86668818
error of function (3.68), Biskinis Phd = 94694.946
From 5A.2, TBDY: $f_{cc} = f_c \cdot c = 43.01531$
conf. factor $c = 1.30349$
 $f_c = 33.00$
From 10.3.5, ASCE 41-17, Final value of f_y : $f_y \cdot \text{Min}(1, 1.25 \cdot (l_b/d)^{2/3}) = 694.45$
 $l_b/d = 1.00$
 $d_1 = 44.00$
 $R = 250.00$
 $v = 0.0011401$
 $N = 7389.214$
 $A_c = 196349.541$
 $= \cdot \text{Min}(1, 1.25 \cdot (l_b/d)^{2/3}) = 0.26182028$

Calculation of ratio l_b/d

Adequate Lap Length: $l_b/d \geq 1$

Calculation of μ_{2-}

Calculation of ultimate Moment Strength ((3.67), Biskinis Phd), μ
 $\mu = 4.0912E+008$

= 0.97738438
' = 0.86668818
error of function (3.68), Biskinis Phd = 94694.946
From 5A.2, TBDY: $f_{cc} = f_c \cdot c = 43.01531$
conf. factor $c = 1.30349$
 $f_c = 33.00$
From 10.3.5, ASCE 41-17, Final value of f_y : $f_y \cdot \text{Min}(1, 1.25 \cdot (l_b/d)^{2/3}) = 694.45$
 $l_b/d = 1.00$
 $d_1 = 44.00$

R = 250.00
v = 0.0011401
N = 7389.214
Ac = 196349.541
= *Min(1,1.25*(lb/d)^ 2/3) = 0.26182028

Calculation of ratio lb/d

Adequate Lap Length: lb/d >= 1

Calculation of Shear Strength Vr = Min(Vr1,Vr2) = 500419.792

Calculation of Shear Strength at edge 1, Vr1 = 500419.792

Vr1 = VCol ((10.3), ASCE 41-17) = knl*VCol0

VCol0 = 500419.792

knl = 1 (zero step-static loading)

NOTE: In expression (10-3) 'Vs = Av*fy*d/s' is replaced by 'Vs+ f*Vf'
where Vf is the contribution of FRPs (11.3), ACI 440).

= 1 (normal-weight concrete)

Mean concrete strength: fc' = (fc'_jacket*Area_jacket + fc'_core*Area_core)/Area_section = 33.00, but fc'^0.5 <= 8.3
MPa (22.5.3.1, ACI 318-14)

M/Vd = 2.00

Mu = 2.1979728E-011

Vu = 2.7468482E-047

d = 0.8*D = 400.00

Nu = 7389.214

Ag = 196349.541

From (11.5.4.8), ACI 318-14: Vs = Vs1 + Vs2 = 274157.871

Vs1 = 274157.871 is calculated for jacket, with:

Av = /2*A_stirrup = 123370.055

fy = 555.56

s = 100.00

Vs1 is multiplied by Col1 = 1.00

s/d = 0.25

Vs2 = 0.00 is calculated for core, with:

Av = /2*A_stirrup = 78956.835

fy = 555.56

s = 250.00

Vs2 is multiplied by Col2 = 0.00

s/d = 1.04167

Vf ((11-3)-(11.4), ACI 440) = 0.00

From (11-11), ACI 440: Vs + Vf <= 479549.663

bw*d = *d*d/4 = 125663.706

Calculation of Shear Strength at edge 2, Vr2 = 500419.792

Vr2 = VCol ((10.3), ASCE 41-17) = knl*VCol0

VCol0 = 500419.792

knl = 1 (zero step-static loading)

NOTE: In expression (10-3) 'Vs = Av*fy*d/s' is replaced by 'Vs+ f*Vf'
where Vf is the contribution of FRPs (11.3), ACI 440).

= 1 (normal-weight concrete)

Mean concrete strength: fc' = (fc'_jacket*Area_jacket + fc'_core*Area_core)/Area_section = 33.00, but fc'^0.5 <= 8.3
MPa (22.5.3.1, ACI 318-14)

M/Vd = 2.00

Mu = 2.1979728E-011

Vu = 2.7468482E-047

d = 0.8*D = 400.00

Nu = 7389.214

Ag = 196349.541
From (11.5.4.8), ACI 318-14: Vs = Vs1 + Vs2 = 274157.871
Vs1 = 274157.871 is calculated for jacket, with:
Av = $\frac{1}{2}A_{stirrup}$ = 123370.055
fy = 555.56
s = 100.00
Vs1 is multiplied by Col1 = 1.00
s/d = 0.25
Vs2 = 0.00 is calculated for core, with:
Av = $\frac{1}{2}A_{stirrup}$ = 78956.835
fy = 555.56
s = 250.00
Vs2 is multiplied by Col2 = 0.00
s/d = 1.04167
Vf ((11-3)-(11.4), ACI 440) = 0.00
From (11-11), ACI 440: Vs + Vf <= 479549.663
bw*d = $\frac{1}{4}d^2$ = 125663.706

End Of Calculation of Shear Capacity ratio for element: column JCC1 of floor 1
At local axis: 2

Start Of Calculation of Chord Rotation Capacity for element: column JCC1 of floor 1
At local axis: 2
Integration Section: (b)
Section Type: rcjcs

Constant Properties

Knowledge Factor, = 1.00
Chord Rotation is generally considered as Deformation-Controlled Action according to Table C7-1, ASCE 41-17.
Mean strengths are used for Deformation-Controlled Actions according to 7.5.1.3, ASCE 41-17
Consequently:
Jacket
New material of Primary Member: Concrete Strength, fc = fcm = 33.00
New material of Primary Member: Steel Strength, fs = fsm = 555.56
Concrete Elasticity, Ec = 26999.444
Steel Elasticity, Es = 200000.00
Existing Column
New material of Primary Member: Concrete Strength, fc = fcm = 33.00
New material of Primary Member: Steel Strength, fs = fsm = 555.56
Concrete Elasticity, Ec = 26999.444
Steel Elasticity, Es = 200000.00
External Diameter, D = 500.00
Internal Diameter, D = 300.00
Cover Thickness, c = 25.00
Element Length, L = 3000.00
Primary Member
Smooth Bars
Ductile Steel
With Detailing for Earthquake Resistance (including stirrups closed at 135°)
Longitudinal Bars With Ends Lapped Starting at the End Sections
Adequate Lap Length ($l_b/d >= 1$)
No FRP Wrapping

Stepwise Properties

Bending Moment, M = 3.6076925E-011
Shear Force, V2 = 4754.456
Shear Force, V3 = 3.3978885E-013
Axial Force, F = -7387.312
Longitudinal Reinforcement Area Distribution (in 2 divisions)
-Tension: Aslt = 0.00

-Compression: $As_c = 3053.628$

Longitudinal Reinforcement Area Distribution (in 3 divisions)

-Tension: $As_{ten} = 1017.876$

-Compression: $As_{com} = 1017.876$

-Middle: $As_{mid} = 1017.876$

Mean Diameter of Tension Reinforcement, $Db_L = 18.00$

New component: From table 7-7, ASCE 41_17: Final chord rotation Capacity $u_R = 1.0^*$ $u = 0.06266099$

$u = y + p = 0.06266099$

- Calculation of y -

$y = (My * L_s / 3) / E_{eff} = 0.00729549$ ((4.29), Biskinis Phd)

$My = 3.6259E+008$

$L_s = M/V$ (with $L_s > 0.1 * L$ and $L_s < 2 * L$) = 1500.00

From table 10.5, ASCE 41_17: $E_{eff} = factor * E_c * I_g = 2.4850E+013$

factor = 0.30

$A_g = 196349.541$

Mean concrete strength: $fc' = (fc'_{jacket} * Area_{jacket} + fc'_{core} * Area_{core}) / Area_{section} = 33.00$

$N = 7387.312$

$E_c * I_g = E_{c_{jacket}} * I_{g_{jacket}} + E_{c_{core}} * I_{g_{core}} = 8.2833E+013$

Calculation of Yielding Moment My

Calculation of y and My according to (7) - (8) in Biskinis and Fardis

$My = \text{Min}(My_{ten}, My_{com}) = 3.6259E+008$

y ((10a) or (10b)) = $1.0622309E-005$

My_{ten} (8a) = $3.6259E+008$

y_{ten} (7a) = 65.4363

error of function (7a) = 0.0029309

My_{com} (8b) = $7.5621E+008$

y_{com} (7b) = 64.56804

error of function (7b) = -0.00721905

with $e_y = 0.0027778$

$e_{co} = 0.002$

$apl = 0.35$ ((9a) in Biskinis and Fardis for no FRP Wrap)

$d_1 = 44.00$

$R = 250.00$

$v = 0.0011401$

$N = 7387.312$

$A_c = 196349.541$

= 0.26182028

with $fc = 33.00$

Calculation of ratio l_b/d

Adequate Lap Length: $l_b/d \geq 1$

- Calculation of p -

From table 10-9: $p = 0.05536551$

with:

- Columns not controlled by inadequate development or splicing along the clear height because $l_b/d \geq 1$

shear control ratio $V_y E / C_o I_{OE} = 0.54503121$

$d = d_{external} = 0.00$

$s = s_{external} = 0.00$

$t = s_1 + s_2 + 2 * t_f / bw * (f_f / f_s) = 0.00323428$

jacket: $s_1 = A_{v1} * (D_c / 2) / (s_1 * A_g) = 0.0027646$

$A_{v1} = 78.53982$, is the area of stirrup
 $D_{c1} = D_{ext} - 2 \cdot cover - \text{External Hoop Diameter} = 440.00$, is the total Length of all stirrups parallel to loading (shear) direction
 $s_1 = 100.00$
 core: $s_2 = A_{v2} \cdot (D_{c2}/2) / (s_2 \cdot A_g) = 0.00046968$
 $A_{v2} = 50.26548$, is the area of stirrup
 $D_{c2} = D_{int} - \text{Internal Hoop Diameter} = 292.00$, is the total Length of all stirrups parallel to loading (shear) direction
 $s_2 = 250.00$
 The term $2 \cdot t_f / b_w \cdot (f_{fe} / f_s)$ is implemented to account for FRP contribution where $f = 2 \cdot t_f / b_w$ is FRP ratio (EC8 - 3, A.4.4.3(6)) and f_{fe} / f_s normalises f to steel strength. All these variables have already been given in Shear control ratio calculation. For the normalisation f_s of jacket is used.
 $N_{UD} = 7387.312$
 $A_g = 196349.541$
 $f_{cE} = (f_{c,jacket} \cdot Area_{jacket} + f_{c,core} \cdot Area_{core}) / section_area = 33.00$
 $f_{yE} = (f_{y,ext_Long_Reinf} \cdot Area_{ext_Long_Reinf} + f_{y,int_Long_Reinf} \cdot Area_{int_Long_Reinf}) / Area_{Tot_Long_Rein} = 2.1219958E-314$
 $f_{yE} = (f_{y,ext_Trans_Reinf} \cdot Area_{ext_Trans_Reinf} + f_{y,int_Trans_Reinf} \cdot Area_{int_Trans_Reinf}) / Area_{Tot_Trans_Rein} = 555.56$
 $\rho_l = Area_{Tot_Long_Rein} / (A_g) = 0.015552$
 $f_{cE} = 33.00$

 End Of Calculation of Chord Rotation Capacity for element: column JCC1 of floor 1
 At local axis: 2
 Integration Section: (b)

Calculation No. 15

column C1, Floor 1


Limit State: Collapse Prevention (data interpolation between analysis steps 1 and 2)

Analysis: Uniform +X

Check: Shear capacity V_{Rd}

Edge: End

Local Axis: (3)



Start Of Calculation of Shear Capacity for element: column JCC1 of floor 1

At local axis: 3
Integration Section: (b)
Section Type: rcjcs

Constant Properties

Knowledge Factor, $\gamma = 1.00$
Member Shear Force is generally considered as Force-Controlled Action according to Table C7-1, ASCE 41-17.
Lower-bound strengths are used for Force-Controlled Actions according to 7.5.1.3, ASCE 41-17

Consequently:

Jacket

New material of Primary Member: Concrete Strength, $f_c = f_{c_lower_bound} = 25.00$

New material of Primary Member: Steel Strength, $f_s = f_{s_lower_bound} = 500.00$

Concrete Elasticity, $E_c = 26999.444$

Steel Elasticity, $E_s = 200000.00$

Existing Column

New material of Primary Member: Concrete Strength, $f_c = f_{c_lower_bound} = 25.00$

New material of Primary Member: Steel Strength, $f_s = f_{s_lower_bound} = 500.00$

Concrete Elasticity, $E_c = 26999.444$

Steel Elasticity, $E_s = 200000.00$

#####

Note: Especially for the calculation of γ for displacement ductility demand,
the expected (mean value) strengths are used (7.5.1.3, ASCE 41-17) because bending is considered as
Deformation-Controlled Action (Table C7-1, ASCE 41-17).

Jacket

New material: Concrete Strength, $f_c = f_{cm} = 33.00$

New material: Steel Strength, $f_s = f_{sm} = 555.56$

Existing Column

New material: Concrete Strength, $f_c = f_{cm} = 33.00$

New material: Steel Strength, $f_s = f_{sm} = 555.56$

#####

External Diameter, $D = 500.00$

Internal Diameter, $D = 300.00$

Cover Thickness, $c = 25.00$

Element Length, $L = 3000.00$

Primary Member

Smooth Bars

Ductile Steel

With Detailing for Earthquake Resistance (including stirrups closed at 135°)

Longitudinal Bars With Ends Lapped Starting at the End Sections

Adequate Lap Length ($l_o/l_{ou,min} = l_b/l_d >= 1$)

No FRP Wrapping

Stepwise Properties

EDGE -A-

Bending Moment, $M_a = 9.8351515E-010$

Shear Force, $V_a = -3.3978885E-013$

EDGE -B-

Bending Moment, $M_b = 3.6076925E-011$

Shear Force, $V_b = 3.3978885E-013$

BOTH EDGES

Axial Force, $F = -7387.312$

Longitudinal Reinforcement Area Distribution (in 2 divisions)

-Tension: $A_{st} = 0.00$

-Compression: $A_{sc} = 3053.628$

Longitudinal Reinforcement Area Distribution (in 3 divisions)

-Tension: $A_{st,ten} = 1017.876$

-Compression: $A_{st,com} = 1017.876$

-Middle: $A_{st,mid} = 1017.876$

Mean Diameter of Tension Reinforcement, $Db_{L,ten} = 18.00$

New component: From table 7-7, ASCE 41_17: Final Shear Capacity $V_R = 1.0 * V_n = 443865.663$

Vn ((10.3), ASCE 41-17) = knl*VCol0 = 443865.663

VCol = 443865.663

knl = 1.00

displacement_ductility_demand = 0.00

NOTE: In expression (10-3) 'Vs = Av*fy*d/s' is replaced by 'Vs+ f*Vf'
where Vf is the contribution of FRPs (11.3), ACI 440).

= 1 (normal-weight concrete)

Mean concrete strength: fc' = (fc'_jacket*Area_jacket + fc'_core*Area_core)/Area_section = 25.00, but fc'^0.5 <= 8.3 MPa (22.5.3.1, ACI 318-14)

M/Vd = 2.00

Mu = 3.6076925E-011

Vu = 3.3978885E-013

d = 0.8*D = 400.00

Nu = 7387.312

Ag = 196349.541

From (11.5.4.8), ACI 318-14: Vs = Vs1 + Vs2 = 246740.11

Vs1 = 246740.11 is calculated for jacket, with:

Av = /2*A_stirrup = 123370.055

fy = 500.00

s = 100.00

Vs1 is multiplied by Col1 = 1.00

s/d = 0.25

Vs2 = 0.00 is calculated for core, with:

Av = /2*A_stirrup = 78956.835

fy = 500.00

s = 250.00

Vs2 is multiplied by Col2 = 0.00

s/d = 1.04167

Vf ((11-3)-(11.4), ACI 440) = 0.00

From (11-11), ACI 440: Vs + Vf <= 417394.406

bw*d = *d*d/4 = 125663.706

displacement_ductility_demand is calculated as / y

- Calculation of / y for END B -

for rotation axis 2 and integ. section (b)

From analysis, chord rotation = 5.1426359E-021

y = (My*Ls/3)/Eleff = 0.00729549 ((4.29),Biskinis Phd))

My = 3.6259E+008

Ls = M/V (with Ls >0.1*L and Ls < 2*L) = 1500.00

From table 10.5, ASCE 41_17: Eleff = factor*Ec*Ig = 2.4850E+013

factor = 0.30

Ag = 196349.541

Mean concrete strength: fc' = (fc'_jacket*Area_jacket + fc'_core*Area_core)/Area_section = 33.00

N = 7387.312

Ec*Ig = Ec_jacket*Ig_jacket + Ec_core*Ig_core = 8.2833E+013

Calculation of Yielding Moment My

Calculation of y and My according to (7) - (8) in Biskinis and Fardis

My = Min(My_ten,My_com) = 3.6259E+008

y ((10a) or (10b)) = 1.0622309E-005

My_ten (8a) = 3.6259E+008

_ten (7a) = 65.4363

error of function (7a) = 0.0029309

My_com (8b) = 7.5621E+008

_com (7b) = 64.56804

error of function (7b) = -0.00721905

with ey = 0.0027778

$e_{co} = 0.002$
 $a_{pl} = 0.35$ ((9a) in Biskinis and Fardis for no FRP Wrap)
 $d_1 = 44.00$
 $R = 250.00$
 $v = 0.0011401$
 $N = 7387.312$
 $A_c = 196349.541$
 $= 0.26182028$
with $f_c = 33.00$

Calculation of ratio l_b/d

Adequate Lap Length: $l_b/d \geq 1$

End Of Calculation of Shear Capacity for element: column JCC1 of floor 1
At local axis: 3
Integration Section: (b)

Calculation No. 16

column C1, Floor 1


Limit State: Collapse Prevention (data interpolation between analysis steps 1 and 2)

Analysis: Uniform +X

Check: Chord rotation capacity (θ)

Edge: End

Local Axis: (3)



Start Of Calculation of Shear Capacity ratio for element: column JCC1 of floor 1

At Shear local axis: 3
(Bending local axis: 2)
Section Type: rcjcs

Constant Properties

Knowledge Factor, $\gamma = 1.00$
Mean strength values are used for both shear and moment calculations.

Consequently:

Jacket

New material of Primary Member: Concrete Strength, $f_c = f_{cm} = 33.00$

New material of Primary Member: Steel Strength, $f_s = f_{sm} = 555.56$

Concrete Elasticity, $E_c = 26999.444$

Steel Elasticity, $E_s = 200000.00$

Existing Column

New material of Primary Member: Concrete Strength, $f_c = f_{cm} = 33.00$

New material of Primary Member: Steel Strength, $f_s = f_{sm} = 555.56$

Concrete Elasticity, $E_c = 26999.444$

Steel Elasticity, $E_s = 200000.00$

#####

Note: Especially for the calculation of moment strengths,

the above steel re-bar strengths are multiplied by 1.25 according to R18.6.5, ACI 318-14

Jacket

New material: Steel Strength, $f_s = 1.25 \cdot f_{sm} = 694.45$

Existing Column

New material: Steel Strength, $f_s = 1.25 \cdot f_{sm} = 694.45$

#####

External Diameter, $D = 500.00$

Internal Diameter, $D = 300.00$

Cover Thickness, $c = 25.00$

Mean Confinement Factor overall section = 1.30349

Element Length, $L = 3000.00$

Primary Member

Smooth Bars

Ductile Steel

With Detailing for Earthquake Resistance (including stirrups closed at 135°)

Longitudinal Bars With Ends Lapped Starting at the End Sections

Adequate Lap Length ($l_o/l_{ou}, \min >= 1$)

No FRP Wrapping

Stepwise Properties

At local axis: 3

EDGE -A-

Shear Force, $V_a = 4.4860917E-031$

EDGE -B-

Shear Force, $V_b = -4.4860917E-031$

BOTH EDGES

Axial Force, $F = -7389.214$

Longitudinal Reinforcement Area Distribution (in 2 divisions)

-Tension: $A_{sl,t} = 0.00$

-Compression: $A_{sl,c} = 3053.628$

Longitudinal Reinforcement Area Distribution (in 3 divisions)

-Tension: $A_{sl,ten} = 1017.876$

-Compression: $A_{sl,com} = 1017.876$

-Middle: $A_{sl,mid} = 1017.876$

Calculation of Shear Capacity ratio, $V_e/V_r = 0.54503121$

Member Controlled by Flexure ($V_e/V_r < 1$)

Calculation of Shear Demand from fig. R18.6.5, ACI 318-14 $V_e = (M_{pr1} + M_{pr2})/l_n = 272744.406$

with

$M_{pr1} = \max(\mu_{u1+}, \mu_{u1-}) = 4.0912E+008$

$\mu_{u1+} = 4.0912E+008$, is the ultimate moment strength at the edge 1 of the member in the actual moment direction which is defined for the static loading combination

$\mu_{u1-} = 4.0912E+008$, is the ultimate moment strength at the edge 1 of the member in the opposite moment direction which is defined for the static loading combination

$M_{pr2} = \max(\mu_{u2+}, \mu_{u2-}) = 4.0912E+008$

$\mu_{u2+} = 4.0912E+008$, is the ultimate moment strength at the edge 2 of the member in the actual moment direction which is defined for the static loading combination

$\mu_{u2-} = 4.0912E+008$, is the ultimate moment strength at the edge 2 of the member in the opposite moment direction which is defined for the static loading combination

Calculation of Mu1+

Calculation of ultimate Moment Strength ((3.67), Biskinis Phd), Mu
Mu = 4.0912E+008

= 0.97738438
' = 0.86668818
error of function (3.68), Biskinis Phd = 94694.946
From 5A.2, TBDY: fcc = fc* c = 43.01531
conf. factor c = 1.30349
fc = 33.00
From 10.3.5, ASCE 41-17, Final value of fy: fy*Min(1,1.25*(lb/d)^ 2/3) = 694.45
lb/d = 1.00
d1 = 44.00
R = 250.00
v = 0.0011401
N = 7389.214
Ac = 196349.541
= *Min(1,1.25*(lb/d)^ 2/3) = 0.26182028

Calculation of ratio lb/d

Adequate Lap Length: lb/d >= 1

Calculation of Mu1-

Calculation of ultimate Moment Strength ((3.67), Biskinis Phd), Mu
Mu = 4.0912E+008

= 0.97738438
' = 0.86668818
error of function (3.68), Biskinis Phd = 94694.946
From 5A.2, TBDY: fcc = fc* c = 43.01531
conf. factor c = 1.30349
fc = 33.00
From 10.3.5, ASCE 41-17, Final value of fy: fy*Min(1,1.25*(lb/d)^ 2/3) = 694.45
lb/d = 1.00
d1 = 44.00
R = 250.00
v = 0.0011401
N = 7389.214
Ac = 196349.541
= *Min(1,1.25*(lb/d)^ 2/3) = 0.26182028

Calculation of ratio lb/d

Adequate Lap Length: lb/d >= 1

Calculation of Mu2+

Calculation of ultimate Moment Strength ((3.67), Biskinis Phd), Mu
Mu = 4.0912E+008

= 0.97738438
 ' = 0.86668818
 error of function (3.68), Biskinis Phd = 94694.946
 From 5A.2, TBDY: $f_{cc} = f_c \cdot c = 43.01531$
 conf. factor $c = 1.30349$
 $f_c = 33.00$
 From 10.3.5, ASCE 41-17, Final value of f_y : $f_y \cdot \text{Min}(1, 1.25 \cdot (l_b/d)^{2/3}) = 694.45$
 $l_b/d = 1.00$
 $d_1 = 44.00$
 $R = 250.00$
 $v = 0.0011401$
 $N = 7389.214$
 $A_c = 196349.541$
 $= \cdot \text{Min}(1, 1.25 \cdot (l_b/d)^{2/3}) = 0.26182028$

 Calculation of ratio l_b/d

 Adequate Lap Length: $l_b/d \geq 1$

 Calculation of μ_2 -

 Calculation of ultimate Moment Strength ((3.67), Biskinis Phd), μ
 $\mu = 4.0912E+008$

 = 0.97738438
 ' = 0.86668818
 error of function (3.68), Biskinis Phd = 94694.946
 From 5A.2, TBDY: $f_{cc} = f_c \cdot c = 43.01531$
 conf. factor $c = 1.30349$
 $f_c = 33.00$
 From 10.3.5, ASCE 41-17, Final value of f_y : $f_y \cdot \text{Min}(1, 1.25 \cdot (l_b/d)^{2/3}) = 694.45$
 $l_b/d = 1.00$
 $d_1 = 44.00$
 $R = 250.00$
 $v = 0.0011401$
 $N = 7389.214$
 $A_c = 196349.541$
 $= \cdot \text{Min}(1, 1.25 \cdot (l_b/d)^{2/3}) = 0.26182028$

 Calculation of ratio l_b/d

 Adequate Lap Length: $l_b/d \geq 1$

 Calculation of Shear Strength $V_r = \text{Min}(V_{r1}, V_{r2}) = 500419.792$

 Calculation of Shear Strength at edge 1, $V_{r1} = 500419.792$

$V_{r1} = V_{Col}$ ((10.3), ASCE 41-17) = $k_{nl} \cdot V_{ColO}$
 $V_{ColO} = 500419.792$
 $k_{nl} = 1$ (zero step-static loading)

 NOTE: In expression (10-3) ' $V_s = A_v \cdot f_y \cdot d/s$ ' is replaced by ' $V_{s+} = f \cdot V_f$ '
 where V_f is the contribution of FRPs (11.3), ACI 440).

 = 1 (normal-weight concrete)
 Mean concrete strength: $f_c' = (f_c'_{jacket} \cdot \text{Area}_{jacket} + f_c'_{core} \cdot \text{Area}_{core}) / \text{Area}_{section} = 33.00$, but $f_c'^{0.5} \leq 8.3$
 MPa (22.5.3.1, ACI 318-14)
 $M/d = 2.00$
 $\mu = 2.5382294E-011$

$V_u = 4.4860917E-031$
 $d = 0.8 \cdot D = 400.00$
 $N_u = 7389.214$
 $A_g = 196349.541$
 From (11.5.4.8), ACI 318-14: $V_s = V_{s1} + V_{s2} = 274157.871$
 $V_{s1} = 274157.871$ is calculated for jacket, with:
 $A_v = \sqrt{2} \cdot A_{stirrup} = 123370.055$
 $f_y = 555.56$
 $s = 100.00$
 V_{s1} is multiplied by $Col1 = 1.00$
 $s/d = 0.25$
 $V_{s2} = 0.00$ is calculated for core, with:
 $A_v = \sqrt{2} \cdot A_{stirrup} = 78956.835$
 $f_y = 555.56$
 $s = 250.00$
 V_{s2} is multiplied by $Col2 = 0.00$
 $s/d = 1.04167$
 V_f ((11-3)-(11.4), ACI 440) = 0.00
 From (11-11), ACI 440: $V_s + V_f \leq 479549.663$
 $b_w \cdot d = \frac{1}{4} \cdot d \cdot d = 125663.706$

Calculation of Shear Strength at edge 2, $V_{r2} = 500419.792$
 $V_{r2} = V_{Col}$ ((10.3), ASCE 41-17) = $k_n l \cdot V_{Col0}$
 $V_{Col0} = 500419.792$
 $k_n l = 1$ (zero step-static loading)

NOTE: In expression (10-3) ' $V_s = A_v \cdot f_y \cdot d / s$ ' is replaced by ' $V_s + f \cdot V_f$ '
 where V_f is the contribution of FRPs (11.3), ACI 440).

$\lambda = 1$ (normal-weight concrete)
 Mean concrete strength: $f_c' = (f_c'_{jacket} \cdot Area_{jacket} + f_c'_{core} \cdot Area_{core}) / Area_{section} = 33.00$, but $f_c'^{0.5} \leq 8.3$
 MPa (22.5.3.1, ACI 318-14)

$M/Vd = 2.00$
 $M_u = 2.5382294E-011$
 $V_u = 4.4860917E-031$
 $d = 0.8 \cdot D = 400.00$
 $N_u = 7389.214$
 $A_g = 196349.541$
 From (11.5.4.8), ACI 318-14: $V_s = V_{s1} + V_{s2} = 274157.871$
 $V_{s1} = 274157.871$ is calculated for jacket, with:
 $A_v = \sqrt{2} \cdot A_{stirrup} = 123370.055$
 $f_y = 555.56$
 $s = 100.00$
 V_{s1} is multiplied by $Col1 = 1.00$
 $s/d = 0.25$
 $V_{s2} = 0.00$ is calculated for core, with:
 $A_v = \sqrt{2} \cdot A_{stirrup} = 78956.835$
 $f_y = 555.56$
 $s = 250.00$
 V_{s2} is multiplied by $Col2 = 0.00$
 $s/d = 1.04167$
 V_f ((11-3)-(11.4), ACI 440) = 0.00
 From (11-11), ACI 440: $V_s + V_f \leq 479549.663$
 $b_w \cdot d = \frac{1}{4} \cdot d \cdot d = 125663.706$

End Of Calculation of Shear Capacity ratio for element: column JCC1 of floor 1
 At local axis: 3

Start Of Calculation of Shear Capacity ratio for element: column JCC1 of floor 1
 At Shear local axis: 2
 (Bending local axis: 3)
 Section Type: rcjcs

Constant Properties

Knowledge Factor, $\gamma = 1.00$

Mean strength values are used for both shear and moment calculations.

Consequently:

Jacket

New material of Primary Member: Concrete Strength, $f_c = f_{cm} = 33.00$

New material of Primary Member: Steel Strength, $f_s = f_{sm} = 555.56$

Concrete Elasticity, $E_c = 26999.444$

Steel Elasticity, $E_s = 200000.00$

Existing Column

New material of Primary Member: Concrete Strength, $f_c = f_{cm} = 33.00$

New material of Primary Member: Steel Strength, $f_s = f_{sm} = 555.56$

Concrete Elasticity, $E_c = 26999.444$

Steel Elasticity, $E_s = 200000.00$

#####

Note: Especially for the calculation of moment strengths,

the above steel re-bar strengths are multiplied by 1.25 according to R18.6.5, ACI 318-14

Jacket

New material: Steel Strength, $f_s = 1.25 \cdot f_{sm} = 694.45$

Existing Column

New material: Steel Strength, $f_s = 1.25 \cdot f_{sm} = 694.45$

#####

External Diameter, $D = 500.00$

Internal Diameter, $D = 300.00$

Cover Thickness, $c = 25.00$

Mean Confinement Factor overall section = 1.30349

Element Length, $L = 3000.00$

Primary Member

Smooth Bars

Ductile Steel

With Detailing for Earthquake Resistance (including stirrups closed at 135°)

Longitudinal Bars With Ends Lapped Starting at the End Sections

Adequate Lap Length ($l_o/l_{ou, \min} > 1$)

No FRP Wrapping

Stepwise Properties

At local axis: 2

EDGE -A-

Shear Force, $V_a = -2.7468482E-047$

EDGE -B-

Shear Force, $V_b = 2.7468482E-047$

BOTH EDGES

Axial Force, $F = -7389.214$

Longitudinal Reinforcement Area Distribution (in 2 divisions)

-Tension: $A_{st} = 0.00$

-Compression: $A_{sc} = 3053.628$

Longitudinal Reinforcement Area Distribution (in 3 divisions)

-Tension: $A_{st, \text{ten}} = 1017.876$

-Compression: $A_{sc, \text{com}} = 1017.876$

-Middle: $A_{sc, \text{mid}} = 1017.876$

Calculation of Shear Capacity ratio, $V_e/V_r = 0.54503121$

Member Controlled by Flexure ($V_e/V_r < 1$)

Calculation of Shear Demand from fig. R18.6.5, ACI 318-14 $V_e = (M_{pr1} + M_{pr2})/l_n = 272744.406$

with

$M_{pr1} = \text{Max}(M_{u1+}, M_{u1-}) = 4.0912E+008$

$M_{u1+} = 4.0912E+008$, is the ultimate moment strength at the edge 1 of the member in the actual moment direction which is defined for the static loading combination

$M_{u1-} = 4.0912E+008$, is the ultimate moment strength at the edge 1 of the member in the opposite moment direction which is defined for the static loading combination

$M_{pr2} = \text{Max}(M_{u2+}, M_{u2-}) = 4.0912E+008$

$M_{u2+} = 4.0912E+008$, is the ultimate moment strength at the edge 2 of the member in the actual moment direction which is defined for the the static loading combination

$M_{u2-} = 4.0912E+008$, is the ultimate moment strength at the edge 2 of the member in the opposite moment direction which is defined for the the static loading combination

Calculation of M_{u1+}

Calculation of ultimate Moment Strength ((3.67), Biskinis Phd), M_u
 $M_u = 4.0912E+008$

$\phi = 0.97738438$

$\lambda = 0.86668818$

error of function (3.68), Biskinis Phd = 94694.946

From 5A.2, TBDY: $f_{cc} = f_c \cdot c = 43.01531$

conf. factor $c = 1.30349$

$f_c = 33.00$

From 10.3.5, ASCE 41-17, Final value of f_y : $f_y \cdot \text{Min}(1, 1.25 \cdot (l_b/d)^{2/3}) = 694.45$

$l_b/d = 1.00$

$d_1 = 44.00$

$R = 250.00$

$v = 0.0011401$

$N = 7389.214$

$A_c = 196349.541$

$= \cdot \text{Min}(1, 1.25 \cdot (l_b/d)^{2/3}) = 0.26182028$

Calculation of ratio l_b/d

Adequate Lap Length: $l_b/d \geq 1$

Calculation of M_{u1-}

Calculation of ultimate Moment Strength ((3.67), Biskinis Phd), M_u
 $M_u = 4.0912E+008$

$\phi = 0.97738438$

$\lambda = 0.86668818$

error of function (3.68), Biskinis Phd = 94694.946

From 5A.2, TBDY: $f_{cc} = f_c \cdot c = 43.01531$

conf. factor $c = 1.30349$

$f_c = 33.00$

From 10.3.5, ASCE 41-17, Final value of f_y : $f_y \cdot \text{Min}(1, 1.25 \cdot (l_b/d)^{2/3}) = 694.45$

$l_b/d = 1.00$

$d_1 = 44.00$

$R = 250.00$

$v = 0.0011401$

$N = 7389.214$

$A_c = 196349.541$

$= \cdot \text{Min}(1, 1.25 \cdot (l_b/d)^{2/3}) = 0.26182028$

Calculation of ratio l_b/d

Adequate Lap Length: $l_b/d \geq 1$

Calculation of M_{u2+}

Calculation of ultimate Moment Strength ((3.67), Biskinis Phd), Mu

Mu = 4.0912E+008

= 0.97738438

' = 0.86668818

error of function (3.68), Biskinis Phd = 94694.946

From 5A.2, TBDY: fcc = fc* c = 43.01531

conf. factor c = 1.30349

fc = 33.00

From 10.3.5, ASCE 41-17, Final value of fy: fy*Min(1,1.25*(lb/d)^ 2/3) = 694.45

lb/d = 1.00

d1 = 44.00

R = 250.00

v = 0.0011401

N = 7389.214

Ac = 196349.541

= *Min(1,1.25*(lb/d)^ 2/3) = 0.26182028

Calculation of ratio lb/d

Adequate Lap Length: lb/d >= 1

Calculation of Mu2-

Calculation of ultimate Moment Strength ((3.67), Biskinis Phd), Mu

Mu = 4.0912E+008

= 0.97738438

' = 0.86668818

error of function (3.68), Biskinis Phd = 94694.946

From 5A.2, TBDY: fcc = fc* c = 43.01531

conf. factor c = 1.30349

fc = 33.00

From 10.3.5, ASCE 41-17, Final value of fy: fy*Min(1,1.25*(lb/d)^ 2/3) = 694.45

lb/d = 1.00

d1 = 44.00

R = 250.00

v = 0.0011401

N = 7389.214

Ac = 196349.541

= *Min(1,1.25*(lb/d)^ 2/3) = 0.26182028

Calculation of ratio lb/d

Adequate Lap Length: lb/d >= 1

Calculation of Shear Strength Vr = Min(Vr1,Vr2) = 500419.792

Calculation of Shear Strength at edge 1, Vr1 = 500419.792

Vr1 = VCol ((10.3), ASCE 41-17) = knl*VCol0

VCol0 = 500419.792

knl = 1 (zero step-static loading)

NOTE: In expression (10-3) 'Vs = Av*fy*d/s' is replaced by 'Vs+ f*Vf'
where Vf is the contribution of FRPs (11.3), ACI 440).

= 1 (normal-weight concrete)
 Mean concrete strength: $f_c' = (f_c'_{\text{jacket}} \cdot \text{Area}_{\text{jacket}} + f_c'_{\text{core}} \cdot \text{Area}_{\text{core}}) / \text{Area}_{\text{section}} = 33.00$, but $f_c'^{0.5} \leq 8.3$
 MPa (22.5.3.1, ACI 318-14)
 $M/Vd = 2.00$
 $\mu_u = 2.1979728E-011$
 $V_u = 2.7468482E-047$
 $d = 0.8 \cdot D = 400.00$
 $N_u = 7389.214$
 $A_g = 196349.541$
 From (11.5.4.8), ACI 318-14: $V_s = V_{s1} + V_{s2} = 274157.871$
 $V_{s1} = 274157.871$ is calculated for jacket, with:
 $A_v = \sqrt{2} \cdot A_{\text{stirrup}} = 123370.055$
 $f_y = 555.56$
 $s = 100.00$
 V_{s1} is multiplied by $\text{Col1} = 1.00$
 $s/d = 0.25$
 $V_{s2} = 0.00$ is calculated for core, with:
 $A_v = \sqrt{2} \cdot A_{\text{stirrup}} = 78956.835$
 $f_y = 555.56$
 $s = 250.00$
 V_{s2} is multiplied by $\text{Col2} = 0.00$
 $s/d = 1.04167$
 $V_f ((11-3)-(11.4), \text{ACI } 440) = 0.00$
 From (11-11), ACI 440: $V_s + V_f \leq 479549.663$
 $b_w \cdot d = \sqrt{3} \cdot d^2 / 4 = 125663.706$

 Calculation of Shear Strength at edge 2, $V_{r2} = 500419.792$
 $V_{r2} = V_{\text{Col}} ((10.3), \text{ASCE } 41-17) = k_{nl} \cdot V_{\text{ColO}}$
 $V_{\text{ColO}} = 500419.792$
 $k_{nl} = 1$ (zero step-static loading)

 NOTE: In expression (10-3) ' $V_s = A_v \cdot f_y \cdot d / s$ ' is replaced by ' $V_s + f \cdot V_f$ '
 where V_f is the contribution of FRPs (11.3), ACI 440).

 = 1 (normal-weight concrete)
 Mean concrete strength: $f_c' = (f_c'_{\text{jacket}} \cdot \text{Area}_{\text{jacket}} + f_c'_{\text{core}} \cdot \text{Area}_{\text{core}}) / \text{Area}_{\text{section}} = 33.00$, but $f_c'^{0.5} \leq 8.3$
 MPa (22.5.3.1, ACI 318-14)
 $M/Vd = 2.00$
 $\mu_u = 2.1979728E-011$
 $V_u = 2.7468482E-047$
 $d = 0.8 \cdot D = 400.00$
 $N_u = 7389.214$
 $A_g = 196349.541$
 From (11.5.4.8), ACI 318-14: $V_s = V_{s1} + V_{s2} = 274157.871$
 $V_{s1} = 274157.871$ is calculated for jacket, with:
 $A_v = \sqrt{2} \cdot A_{\text{stirrup}} = 123370.055$
 $f_y = 555.56$
 $s = 100.00$
 V_{s1} is multiplied by $\text{Col1} = 1.00$
 $s/d = 0.25$
 $V_{s2} = 0.00$ is calculated for core, with:
 $A_v = \sqrt{2} \cdot A_{\text{stirrup}} = 78956.835$
 $f_y = 555.56$
 $s = 250.00$
 V_{s2} is multiplied by $\text{Col2} = 0.00$
 $s/d = 1.04167$
 $V_f ((11-3)-(11.4), \text{ACI } 440) = 0.00$
 From (11-11), ACI 440: $V_s + V_f \leq 479549.663$
 $b_w \cdot d = \sqrt{3} \cdot d^2 / 4 = 125663.706$

 End Of Calculation of Shear Capacity ratio for element: column JCC1 of floor 1
 At local axis: 2

Start Of Calculation of Chord Rotation Capacity for element: column JCC1 of floor 1

At local axis: 3

Integration Section: (b)

Section Type: rcjcs

Constant Properties

Knowledge Factor, $k = 1.00$

Chord Rotation is generally considered as Deformation-Controlled Action according to Table C7-1, ASCE 41-17.

Mean strengths are used for Deformation-Controlled Actions according to 7.5.1.3, ASCE 41-17

Consequently:

Jacket

New material of Primary Member: Concrete Strength, $f_c = f_{cm} = 33.00$

New material of Primary Member: Steel Strength, $f_s = f_{sm} = 555.56$

Concrete Elasticity, $E_c = 26999.444$

Steel Elasticity, $E_s = 200000.00$

Existing Column

New material of Primary Member: Concrete Strength, $f_c = f_{cm} = 33.00$

New material of Primary Member: Steel Strength, $f_s = f_{sm} = 555.56$

Concrete Elasticity, $E_c = 26999.444$

Steel Elasticity, $E_s = 200000.00$

External Diameter, $D = 500.00$

Internal Diameter, $D = 300.00$

Cover Thickness, $c = 25.00$

Element Length, $L = 3000.00$

Primary Member

Smooth Bars

Ductile Steel

With Detailing for Earthquake Resistance (including stirrups closed at 135°)

Longitudinal Bars With Ends Lapped Starting at the End Sections

Adequate Lap Length ($l_b/d >= 1$)

No FRP Wrapping

Stepwise Properties

Bending Moment, $M = 0.02407461$

Shear Force, $V_2 = 4754.456$

Shear Force, $V_3 = 3.3978885E-013$

Axial Force, $F = -7387.312$

Longitudinal Reinforcement Area Distribution (in 2 divisions)

-Tension: $A_{st} = 0.00$

-Compression: $A_{sc} = 3053.628$

Longitudinal Reinforcement Area Distribution (in 3 divisions)

-Tension: $A_{st,ten} = 1017.876$

-Compression: $A_{st,com} = 1017.876$

-Middle: $A_{st,mid} = 1017.876$

Mean Diameter of Tension Reinforcement, $Db_L = 18.00$

New component: From table 7-7, ASCE 41_17: Final chord rotation Capacity $u_{,R} = 1.0^* u = 0.0568246$

$u = y + p = 0.0568246$

- Calculation of y -

$y = (M_y * L_s / 3) / E_{eff} = 0.0014591$ ((4.29), Biskinis Phd))

$M_y = 3.6259E+008$

$L_s = M/V$ (with $L_s > 0.1 * L$ and $L_s < 2 * L$) = 300.00

From table 10.5, ASCE 41_17: $E_{eff} = factor * E_c * I_g = 2.4850E+013$

factor = 0.30

$A_g = 196349.541$

Mean concrete strength: $f_c' = (f_c'_{jacket} * Area_{jacket} + f_c'_{core} * Area_{core}) / Area_{section} = 33.00$

$N = 7387.312$

$$E_c I_g = E_c \text{ jacket} I_g \text{ jacket} + E_c \text{ core} I_g \text{ core} = 8.2833E+013$$

Calculation of Yielding Moment M_y

Calculation of ρ_y and M_y according to (7) - (8) in Biskinis and Fardis

$$M_y = \text{Min}(M_{y_ten}, M_{y_com}) = 3.6259E+008$$

$$\rho_y \text{ ((10a) or (10b))} = 1.0622309E-005$$

$$M_{y_ten} \text{ (8a)} = 3.6259E+008$$

$$\rho_{y_ten} \text{ (7a)} = 65.4363$$

$$\text{error of function (7a)} = 0.0029309$$

$$M_{y_com} \text{ (8b)} = 7.5621E+008$$

$$\rho_{y_com} \text{ (7b)} = 64.56804$$

$$\text{error of function (7b)} = -0.00721905$$

with $e_y = 0.0027778$
 $e_{co} = 0.002$
 $a_{pl} = 0.35$ ((9a) in Biskinis and Fardis for no FRP Wrap)
 $d_1 = 44.00$
 $R = 250.00$
 $v = 0.0011401$
 $N = 7387.312$
 $A_c = 196349.541$
 $\rho_y = 0.26182028$
with $f_c = 33.00$

Calculation of ratio l_b/d

Adequate Lap Length: $l_b/d \geq 1$

- Calculation of ρ_p -

From table 10-9: $\rho_p = 0.05536551$

with:

- Columns not controlled by inadequate development or splicing along the clear height because $l_b/d \geq 1$

$$\text{shear control ratio } V_y E / V_c O_{IE} = 0.54503121$$

$$d = d_{\text{external}} = 0.00$$

$$s = s_{\text{external}} = 0.00$$

$$t = s_1 + s_2 + 2 * t_f / b_w * (f_{fe} / f_s) = 0.00323428$$

jacket: $s_1 = A_{v1} * (D_{c1} / 2) / (s_1 * A_g) = 0.0027646$
 $A_{v1} = 78.53982$, is the area of stirrup
 $D_{c1} = D_{\text{ext}} - 2 * \text{cover} - \text{External Hoop Diameter} = 440.00$, is the total Length of all stirrups parallel to loading (shear) direction
 $s_1 = 100.00$

core: $s_2 = A_{v2} * (D_{c2} / 2) / (s_2 * A_g) = 0.00046968$
 $A_{v2} = 50.26548$, is the area of stirrup
 $D_{c2} = D_{\text{int}} - \text{Internal Hoop Diameter} = 292.00$, is the total Length of all stirrups parallel to loading (shear) direction
 $s_2 = 250.00$

The term $2 * t_f / b_w * (f_{fe} / f_s)$ is implemented to account for FRP contribution where $f = 2 * t_f / b_w$ is FRP ratio (EC8 - 3, A.4.4.3(6)) and f_{fe} / f_s normalises f to steel strength. All these variables have already been given in Shear control ratio calculation.

For the normalisation f_s of jacket is used.

$$N_{UD} = 7387.312$$

$$A_g = 196349.541$$

$$f_{cE} = (f_c \text{ jacket} * \text{Area}_{\text{jacket}} + f_c \text{ core} * \text{Area}_{\text{core}}) / \text{section_area} = 33.00$$

$$f_{yIE} = (f_{y_ext_Long_Reinf} * \text{Area}_{\text{ext_Long_Reinf}} + f_{y_int_Long_Reinf} * \text{Area}_{\text{int_Long_Reinf}}) / \text{Area}_{\text{Tot_Long_Rein}} = 2.1219958E-314$$

$$f_{yTE} = (f_{y_ext_Trans_Reinf} * \text{Area}_{\text{ext_Trans_Reinf}} + f_{y_int_Trans_Reinf} * \text{Area}_{\text{int_Trans_Reinf}}) / \text{Area}_{\text{Tot_Trans_Rein}} = 555.56$$

$$\rho_l = \text{Area}_{\text{Tot_Long_Rein}} / (A_g) = 0.015552$$

$$f_{cE} = 33.00$$

End Of Calculation of Chord Rotation Capacity for element: column JCC1 of floor 1

At local axis: 3
Integration Section: (b)
