

# Detailed Member Calculations

**Units: N&mm**

**Regulation: ASCE 41-17**

## Calculation No. 1

column C1, Floor 1


Limit State: Operational Level (data interpolation between analysis steps 1 and 2)

Analysis: Uniform +X

Check: Shear capacity  $V_{Rd}$

Edge: Start

Local Axis: (2)



Start Of Calculation of Shear Capacity for element: column JLC1 of floor 1

At local axis: 2

Integration Section: (a)

Section Type: rcjcs

Constant Properties

Knowledge Factor,  $\gamma = 1.00$

Member Shear Force is generally considered as Force-Controlled Action according to Table C7-1, ASCE 41-17.

Lower-bound strengths are used for Force-Controlled Actions according to 7.5.1.3, ASCE 41-17

Consequently:

Jacket

New material of Primary Member: Concrete Strength,  $f_c = f_{c\_lower\_bound} = 20.00$

New material of Primary Member: Steel Strength,  $f_s = f_{s\_lower\_bound} = 500.00$

Concrete Elasticity,  $E_c = 25742.96$   
Steel Elasticity,  $E_s = 200000.00$   
Existing Column  
New material of Primary Member: Concrete Strength,  $f_c = f_{c\_lower\_bound} = 20.00$   
New material of Primary Member: Steel Strength,  $f_s = f_{s\_lower\_bound} = 500.00$   
Concrete Elasticity,  $E_c = 25742.96$   
Steel Elasticity,  $E_s = 200000.00$   
#####  
Note: Especially for the calculation of  $\mu_y$  for displacement ductility demand,  
the expected (mean value) strengths are used (7.5.1.3, ASCE 41-17) because bending is considered as  
Deformation-Controlled Action (Table C7-1, ASCE 41-17).  
Jacket  
New material: Concrete Strength,  $f_c = f_{cm} = 30.00$   
New material: Steel Strength,  $f_s = f_{sm} = 625.00$   
Existing Column  
New material: Concrete Strength,  $f_c = f_{cm} = 30.00$   
New material: Steel Strength,  $f_s = f_{sm} = 625.00$   
#####  
Max Height,  $H_{max} = 750.00$   
Min Height,  $H_{min} = 400.00$   
Max Width,  $W_{max} = 750.00$   
Min Width,  $W_{min} = 400.00$   
Jacket Thickness,  $t_j = 100.00$   
Cover Thickness,  $c = 25.00$   
Element Length,  $L = 3000.00$   
Primary Member  
Smooth Bars  
Ductile Steel  
With Detailing for Earthquake Resistance (including stirrups closed at  $135^\circ$ )  
Longitudinal Bars With Ends Lapped Starting at the End Sections  
Lap Length  $l_o = l_b = 300.00$   
No FRP Wrapping

#### Stepwise Properties

EDGE -A-  
Bending Moment,  $M_a = -1.4730E+007$   
Shear Force,  $V_a = -4846.489$   
EDGE -B-  
Bending Moment,  $M_b = 186273.79$   
Shear Force,  $V_b = 4846.489$   
BOTH EDGES  
Axial Force,  $F = -17232.621$   
Longitudinal Reinforcement Area Distribution (in 2 divisions)  
-Tension:  $A_{sl,t} = 0.00$   
-Compression:  $A_{sl,c} = 5353.274$   
Longitudinal Reinforcement Area Distribution (in 3 divisions)  
-Tension:  $A_{sl,ten} = 1137.257$   
-Compression:  $A_{sl,com} = 2208.54$   
-Middle:  $A_{sl,mid} = 2007.478$   
Mean Diameter of Tension Reinforcement,  $Db_{L,ten} = 16.80$

New component: From table 7-7, ASCE 41\_17: Final Shear Capacity  $V_R = 1.0 \cdot V_n = 848882.103$   
 $V_n$  ((10.3), ASCE 41-17) =  $k_n \cdot V_{CoI} = 848882.103$   
 $V_{CoI} = 848882.103$   
 $k_n = 1.00$   
displacement\_ductility\_demand = 0.02762218

NOTE: In expression (10-3) ' $V_s = A_v \cdot f_y \cdot d/s$ ' is replaced by ' $V_s + f' \cdot V_f$ '  
where  $V_f$  is the contribution of FRPs (11.3), ACI 440).

= 1 (normal-weight concrete)  
Mean concrete strength:  $f'_c = (f'_c\_jacket \cdot Area\_jacket + f'_c\_core \cdot Area\_core) / Area\_section = 20.00$ , but  $f'_c^{0.5} \leq 8.3$

MPa (22.5.3.1, ACI 318-14)

$$M/Vd = 4.00$$

$$\mu_u = 1.4730E+007$$

$$V_u = 4846.489$$

$$d = 0.8 \cdot h = 600.00$$

$$N_u = 17232.621$$

$$A_g = 300000.00$$

$$\text{From (11.5.4.8), ACI 318-14: } V_s = V_{sjacket} + V_{s,core} = 811033.559$$

where:

$$V_{sjacket} = V_{sj1} + V_{sj2} = 722566.31$$

$V_{sj1} = 251327.412$  is calculated for section web jacket, with:

$$d = 320.00$$

$$A_v = 157079.633$$

$$f_y = 500.00$$

$$s = 100.00$$

$V_{sj1}$  is multiplied by  $Col,j1 = 1.00$

$$s/d = 0.3125$$

$V_{sj2} = 471238.898$  is calculated for section flange jacket, with:

$$d = 600.00$$

$$A_v = 157079.633$$

$$f_y = 500.00$$

$$s = 100.00$$

$V_{sj2}$  is multiplied by  $Col,j2 = 1.00$

$$s/d = 0.16666667$$

$$V_{s,core} = V_{s,c1} + V_{s,c2} = 88467.249$$

$V_{s,c1} = 0.00$  is calculated for section web core, with:

$$d = 160.00$$

$$A_v = 100530.965$$

$$f_y = 500.00$$

$$s = 250.00$$

$V_{s,c1}$  is multiplied by  $Col,c1 = 0.00$

$$s/d = 1.5625$$

$V_{s,c2} = 88467.249$  is calculated for section flange core, with:

$$d = 440.00$$

$$A_v = 100530.965$$

$$f_y = 500.00$$

$$s = 250.00$$

$V_{s,c2}$  is multiplied by  $Col,c2 = 1.00$

$$s/d = 0.56818182$$

$$V_f ((11-3)-(11.4), \text{ACI 440}) = 0.00$$

$$\text{From (11-11), ACI 440: } V_s + V_f \leq 713005.69$$

$$bw = 400.00$$

displacement\_ductility\_demand is calculated as  $\delta / y$

- Calculation of  $\delta / y$  for END A -  
for rotation axis 3 and integ. section (a)

From analysis, chord rotation  $\theta = 5.5147643E-005$

$$y = (M_y \cdot L_s / 3) / E_{eff} = 0.0019965 ((4.29), \text{Biskinis Phd})$$

$$M_y = 2.8693E+008$$

$$L_s = M/V \text{ (with } L_s > 0.1 \cdot L \text{ and } L_s < 2 \cdot L) = 3039.252$$

$$\text{From table 10.5, ASCE 41_17: } E_{eff} = \text{factor} \cdot E_c \cdot I_g = 1.4560E+014$$

$$\text{factor} = 0.30$$

$$A_g = 440000.00$$

$$\text{Mean concrete strength: } f'_c = (f'_{c,jacket} \cdot \text{Area}_{jacket} + f'_{c,core} \cdot \text{Area}_{core}) / \text{Area}_{section} = 30.00$$

$$N = 17232.621$$

$$E_c \cdot I_g = E_{c,jacket} \cdot I_{g,jacket} + E_{c,core} \cdot I_{g,core} = 4.8532E+014$$

Calculation of Yielding Moment  $M_y$

Calculation of  $\delta$  and  $M_y$  according to Annex 7 -

Assuming neutral axis within flange (  $y < t/d$ , compression zone rectangular) with:

flange width,  $b = 750.00$

web width,  $b_w = 400.00$

flange thickness,  $t = 400.00$

$y = \text{Min}(y_{\text{ten}}, y_{\text{com}})$

$y_{\text{ten}} = 2.1452649\text{E-}006$

with ((10.1), ASCE 41-17)  $f_y = \text{Min}(f_y, 1.25*f_y*(l_b/d)^{2/3}) = 243.3535$

$d = 707.00$

$y = 0.1977546$

$A = 0.0102293$

$B = 0.00453971$

with  $p_t = 0.00214476$

$p_c = 0.00416509$

$p_v = 0.00378591$

$N = 17232.621$

$b = 750.00$

" = 0.06082037

$y_{\text{comp}} = 1.5203329\text{E-}005$

with  $f_c = 30.00$

$E_c = 25742.96$

$y = 0.19515388$

$A = 0.01001829$

$B = 0.00440616$

with  $E_s = 200000.00$

CONFIRMATION:  $y = 0.19591085 < t/d$

Calculation of ratio  $l_b/d$

Lap Length:  $l_d/d, \text{min} = 0.17384865$

$l_b = 300.00$

$l_d = 1725.639$

Calculation of  $l$  according to (25.4.3.2), ACI 318-14, using mean values for all the section re-bars.

$l_d, \text{min}$  from (25.4.3.2) is multiplied 2 times to account for smooth re-bars (10.3.5, ASCE 41-17)

= 1

$d_b = 16.66667$

Mean strength value of all re-bars:  $f_y = 625.00$

Mean concrete strength:  $f_c' = (f_c'_{\text{jacket}} * \text{Area}_{\text{jacket}} + f_c'_{\text{core}} * \text{Area}_{\text{core}}) / \text{Area}_{\text{section}} = 30.00$ , but  $f_c'^{0.5} \leq 8.3$  MPa (22.5.3.1, ACI 318-14)

$t = 1.00$

$s = 0.80$

$e = 1.00$

$cb = 25.00$

$K_{tr} = 1.7174$

$A_{tr} = \text{Min}(A_{tr_x}, A_{tr_y}) = 257.6106$

where  $A_{tr_x}$ ,  $A_{tr_y}$  are the sum of the area of all stirrup legs along X and Y loxal axis

$s = \text{Max}(s_{\text{external}}, s_{\text{internal}}) = 250.00$

$n = 24.00$

End Of Calculation of Shear Capacity for element: column JLC1 of floor 1

At local axis: 2

Integration Section: (a)

## Calculation No. 2

column C1, Floor 1


Limit State: Operational Level (data interpolation between analysis steps 1 and 2)

Analysis: Uniform +X

Check: Chord rotation capacity ( $\phi$ )

Edge: Start

Local Axis: (2)



Start Of Calculation of Shear Capacity ratio for element: column JLC1 of floor 1

At Shear local axis: 3

(Bending local axis: 2)

Section Type: rcjlcs

Constant Properties

Knowledge Factor,  $\gamma = 1.00$

Mean strength values are used for both shear and moment calculations.

Consequently:

Jacket

New material of Primary Member: Concrete Strength,  $f_c = f_{cm} = 30.00$

New material of Primary Member: Steel Strength,  $f_s = f_{sm} = 625.00$

Concrete Elasticity,  $E_c = 25742.96$

Steel Elasticity,  $E_s = 200000.00$

Existing Column

New material of Primary Member: Concrete Strength,  $f_c = f_{cm} = 30.00$

New material of Primary Member: Steel Strength,  $f_s = f_{sm} = 625.00$

Concrete Elasticity,  $E_c = 25742.96$

Steel Elasticity,  $E_s = 200000.00$

#####

Note: Especially for the calculation of moment strengths,

the above steel re-bar strengths are multiplied by 1.25 according to R18.6.5, ACI 318-14

Jacket

New material: Steel Strength,  $f_s = 1.25 \cdot f_{sm} = 781.25$

Existing Column

New material: Steel Strength,  $f_s = 1.25 \cdot f_{sm} = 781.25$

#####

Max Height,  $H_{max} = 750.00$

Min Height,  $H_{min} = 400.00$

Max Width,  $W_{max} = 750.00$

Min Width,  $W_{min} = 400.00$

Jacket Thickness,  $t_j = 100.00$

Cover Thickness,  $c = 25.00$

Mean Confinement Factor overall section = 1.27105

Element Length,  $L = 3000.00$

Primary Member

Smooth Bars

Ductile Steel

With Detailing for Earthquake Resistance (including stirrups closed at 135°)  
Longitudinal Bars With Ends Lapped Starting at the End Sections  
Lap Length  $l_o = 300.00$   
No FRP Wrapping

#### Stepwise Properties

At local axis: 3  
EDGE -A-  
Shear Force,  $V_a = -0.00017144$   
EDGE -B-  
Shear Force,  $V_b = 0.00017144$   
BOTH EDGES  
Axial Force,  $F = -16273.608$   
Longitudinal Reinforcement Area Distribution (in 2 divisions)  
-Tension:  $A_{sl,t} = 0.00$   
-Compression:  $A_{sl,c} = 5353.274$   
Longitudinal Reinforcement Area Distribution (in 3 divisions)  
-Tension:  $A_{sl,ten} = 1137.257$   
-Compression:  $A_{sl,com} = 2208.54$   
-Middle:  $A_{sl,mid} = 2007.478$

Calculation of Shear Capacity ratio ,  $V_e/V_r = 0.32266369$   
Member Controlled by Flexure ( $V_e/V_r < 1$ )  
Calculation of Shear Demand from fig. R18.6.5, ACI 318-14  $V_e = (M_{pr1} + M_{pr2})/l_n = 335307.657$   
with  
 $M_{pr1} = \text{Max}(\mu_{u1+}, \mu_{u1-}) = 5.0296E+008$   
 $\mu_{u1+} = 2.3387E+008$ , is the ultimate moment strength at the edge 1 of the member in the actual moment direction which is defined for the static loading combination  
 $\mu_{u1-} = 5.0296E+008$ , is the ultimate moment strength at the edge 1 of the member in the opposite moment direction which is defined for the static loading combination  
 $M_{pr2} = \text{Max}(\mu_{u2+}, \mu_{u2-}) = 5.0296E+008$   
 $\mu_{u2+} = 2.3387E+008$ , is the ultimate moment strength at the edge 2 of the member in the actual moment direction which is defined for the the static loading combination  
 $\mu_{u2-} = 5.0296E+008$ , is the ultimate moment strength at the edge 2 of the member in the opposite moment direction which is defined for the the static loading combination

#### Calculation of $\mu_{u1+}$

Calculation of ultimate curvature  $\mu_u$  according to 4.1, Biskinis/Fardis 2013:

$$\mu_u = 4.8099118E-006$$

$$\mu_u = 2.3387E+008$$

with full section properties:

$$b = 750.00$$

$$d = 707.00$$

$$d' = 43.00$$

$$v = 0.00102301$$

$$N = 16273.608$$

$$f_c = 30.00$$

$$c_o (5A.5, \text{TBDY}) = 0.002$$

$$\text{Final value of } \mu_u: \mu_u^* = \text{shear\_factor} * \text{Max}(\mu_u, c_o) = 0.01260361$$

The Shear\_factor is considered equal to 1 (pure moment strength)

$$\text{From (5.4b), TBDY: } \mu_u = 0.01260361$$

$$\mu_u (5.4c) = 0.05179731$$

$$a_{se} ((5.4d), \text{TBDY}) = (a_{se1} * A_{ext} + a_{se2} * A_{int}) / A_{sec} = 0.45746528$$

$$a_{se1} = \text{Max}(((A_{conf,max1} - A_{noConf1}) / A_{conf,max1}) * (A_{conf,min1} / A_{conf,max1}), 0) = 0.45746528$$

The definitions of  $A_{noConf}$ ,  $A_{conf,min}$  and  $A_{conf,max}$  are derived from generalization of the rectangular sections confinement, which is expressed by (5.4d).

The generalization is done according to Mander, J., Priestley, M., and Park, R. (1988)

"Theoretical Stress-Strain Model for Confined Concrete."

J. Struct. Eng., 10.1061/(ASCE)0733-9445(1988)114:8(1804), 1804-1826.

$A_{conf,max1} = 353600.00$  is the confined core area at levels of member with hoops and is calculated as the area of core enclosed by the center lines of the external perimeter hoops.  
 $A_{conf,min1} = 293525.00$  is the confined core area at midway between the levels of hoops and is calculated by reducing all the dimensions of the area  $A_{conf,max1}$  by a length equal to half the clear spacing between external hoops.

$A_{noconf1} = 158733.333$  is the unconfined external core area which is equal to  $b_i^2/6$  as defined at (A.2).  
 $a_{se2} (>= a_{se1}) = \text{Max}(((A_{conf,max2} - A_{noconf2})/A_{conf,max2}) * (A_{conf,min2}/A_{conf,max2}), 0) = 0.45746528$

The definitions of  $A_{noconf}$ ,  $A_{conf,min}$  and  $A_{conf,max}$  are derived from generalization of the rectangular sections confinement, which is expressed by (5.4d).

The generalization is done according to Mander, J., Priestley, M., and Park, R. (1988)

"Theoretical Stress-Strain Model for Confined Concrete."

J. Struct. Eng., 10.1061/(ASCE)0733-9445(1988)114:8(1804), 1804-1826.

$A_{conf,max2} = 171264.00$  is the confined core area at levels of member with hoops and is calculated as the area of core enclosed by the center lines of the internal perimeter hoops.

$A_{conf,min2} = 54741.00$  is the confined core area at midway between the levels of hoops and is calculated by reducing all the dimensions of the area  $A_{conf,max2}$  by a length equal to half the clear spacing between internal hoops.

$A_{noconf2} = 106242.667$  is the unconfined internal core area which is equal to  $b_i^2/6$  as defined at (A.2).  
 $p_{sh,min} * F_{ywe} = \text{Min}(p_{sh,x} * F_{ywe}, p_{sh,y} * F_{ywe}) = 3.3968$

-----  
 $p_{sh,x} * F_{ywe} = p_{sh1} * F_{ywe1} + p_{s2} * F_{ywe2} = 3.3968$   
 $p_{sh1} ((5.4d), \text{TBDY}) = L_{stir1} * A_{stir1} / (A_{sec} * s_1) = 0.00367709$   
 $L_{stir1}$  (Length of stirrups along Y) = 2060.00  
 $A_{stir1}$  (stirrups area) = 78.53982  
 $p_{sh2} (5.4d) = L_{stir2} * A_{stir2} / (A_{sec} * s_2) = 0.00067082$   
 $L_{stir2}$  (Length of stirrups along Y) = 1468.00  
 $A_{stir2}$  (stirrups area) = 50.26548

-----  
 $p_{sh,y} * F_{ywe} = p_{sh1} * F_{ywe1} + p_{s2} * F_{ywe2} = 3.3968$   
 $p_{sh1} ((5.4d), \text{TBDY}) = L_{stir1} * A_{stir1} / (A_{sec} * s_1) = 0.00367709$   
 $L_{stir1}$  (Length of stirrups along X) = 2060.00  
 $A_{stir1}$  (stirrups area) = 78.53982  
 $p_{sh2} ((5.4d), \text{TBDY}) = L_{stir2} * A_{stir2} / (A_{sec} * s_2) = 0.00067082$   
 $L_{stir2}$  (Length of stirrups along X) = 1468.00  
 $A_{stir2}$  (stirrups area) = 50.26548

-----  
 $A_{sec} = 440000.00$

$s_1 = 100.00$

$s_2 = 250.00$

$f_{ywe1} = 781.25$

$f_{ywe2} = 781.25$

$f_{ce} = 30.00$

From ((5.A5), TBDY), TBDY:  $c_c = 0.00471045$

$c = \text{confinement factor} = 1.27105$

$y_1 = 0.00083886$

$sh_1 = 0.00268436$

$ft_1 = 314.5735$

$fy_1 = 262.1446$

$su_1 = 0.00268436$

using (30) in Biskinis/Fardis (2013) multiplied with shear\_factor and also multiplied by the shear\_factor according to 15.7.1.4, with Shear\_factor = 1.00

$l_o/l_{ou,min} = l_b/l_d = 0.13907892$

$su_1 = 0.4 * esu_{1,nominal} ((5.5), \text{TBDY}) = 0.032$

From table 5A.1, TBDY:  $esu_{1,nominal} = 0.08$ ,

For calculation of  $esu_{1,nominal}$  and  $y_1, sh_1, ft_1, fy_1$ , it is considered characteristic value  $fsy_1 = fs_1/1.2$ , from table 5.1, TBDY.

$y_1, sh_1, ft_1, fy_1$ , are also multiplied by  $\text{Min}(1, 1.25 * (l_b/l_d)^{2/3})$ , from 10.3.5, ASCE 41-17.

with  $fs_1 = (f_{s,jacket} * A_{s,ten,jacket} + f_{s,core} * A_{s,ten,core}) / A_{s,ten} = 262.1446$

with  $Es_1 = (E_{s,jacket} * A_{s,ten,jacket} + E_{s,core} * A_{s,ten,core}) / A_{s,ten} = 200000.00$

$y_2 = 0.00083886$

$sh_2 = 0.00268436$

$ft_2 = 314.5735$

$fy_2 = 262.1446$

$su_2 = 0.00268436$

using (30) in Biskinis/Fardis (2013) multiplied with shear\_factor  
 and also multiplied by the shear\_factor according to 15.7.1.4, with  
 Shear\_factor = 1.00  
 $l_o/l_{ou,min} = l_b/l_{b,min} = 0.13907892$   
 $su_2 = 0.4 \cdot esu_{2,nominal} ((5.5), TBDY) = 0.032$   
 From table 5A.1, TBDY:  $esu_{2,nominal} = 0.08$ ,  
 For calculation of  $esu_{2,nominal}$  and  $y_2, sh_2, ft_2, fy_2$ , it is considered  
 characteristic value  $fsy_2 = fs_2/1.2$ , from table 5.1, TBDY.  
 $y_1, sh_1, ft_1, fy_1$ , are also multiplied by  $\text{Min}(1, 1.25 \cdot (l_b/l_d)^{2/3})$ , from 10.3.5, ASCE 41-17.  
 with  $fs_2 = (fs_{jacket} \cdot A_{sl,com,jacket} + fs_{core} \cdot A_{sl,com,core}) / A_{sl,com} = 262.1446$   
 with  $Es_2 = (Es_{jacket} \cdot A_{sl,com,jacket} + Es_{core} \cdot A_{sl,com,core}) / A_{sl,com} = 200000.00$   
 $y_v = 0.00083886$   
 $sh_v = 0.00268436$   
 $ft_v = 314.5735$   
 $fy_v = 262.1446$   
 $su_v = 0.00268436$   
 using (30) in Biskinis/Fardis (2013) multiplied with shear\_factor  
 and also multiplied by the shear\_factor according to 15.7.1.4, with  
 Shear\_factor = 1.00  
 $l_o/l_{ou,min} = l_b/l_d = 0.13907892$   
 $suv = 0.4 \cdot esuv_{nominal} ((5.5), TBDY) = 0.032$   
 From table 5A.1, TBDY:  $esuv_{nominal} = 0.08$ ,  
 considering characteristic value  $fsyv = fsv/1.2$ , from table 5.1, TBDY  
 For calculation of  $esuv_{nominal}$  and  $y_v, sh_v, ft_v, fy_v$ , it is considered  
 characteristic value  $fsyv = fsv/1.2$ , from table 5.1, TBDY.  
 $y_1, sh_1, ft_1, fy_1$ , are also multiplied by  $\text{Min}(1, 1.25 \cdot (l_b/l_d)^{2/3})$ , from 10.3.5, ASCE 41-17.  
 with  $fsv = (fs_{jacket} \cdot A_{sl,mid,jacket} + fs_{mid} \cdot A_{sl,mid,core}) / A_{sl,mid} = 262.1446$   
 with  $Es_v = (Es_{jacket} \cdot A_{sl,mid,jacket} + Es_{mid} \cdot A_{sl,mid,core}) / A_{sl,mid} = 200000.00$   
 $1 = A_{sl,ten} / (b \cdot d) \cdot (fs_1 / fc) = 0.0187412$   
 $2 = A_{sl,com} / (b \cdot d) \cdot (fs_2 / fc) = 0.03639521$   
 $v = A_{sl,mid} / (b \cdot d) \cdot (fsv / fc) = 0.03308184$   
 and confined core properties:  
 $b = 690.00$   
 $d = 677.00$   
 $d' = 13.00$   
 $fcc (5A.2, TBDY) = 38.13135$   
 $cc (5A.5, TBDY) = 0.00471045$   
 $c = \text{confinement factor} = 1.27105$   
 $1 = A_{sl,ten} / (b \cdot d) \cdot (fs_1 / fc) = 0.02127357$   
 $2 = A_{sl,com} / (b \cdot d) \cdot (fs_2 / fc) = 0.04131304$   
 $v = A_{sl,mid} / (b \cdot d) \cdot (fsv / fc) = 0.03755196$   
 Case/Assumption: Unconfined full section - Steel rupture  
 ' satisfies Eq. (4.3)  
 --->  
 $v < v_{s,y_2}$  - LHS eq.(4.5) is satisfied  
 --->  
 $su (4.9) = 0.21062322$   
 $Mu = MRc (4.14) = 2.3387E+008$   
 $u = su (4.1) = 4.8099118E-006$

---

Calculation of ratio  $l_b/l_d$   
 -----  
 Lap Length:  $l_b/l_d = 0.13907892$   
 $l_b = 300.00$   
 $l_d = 2157.049$   
 Calculation of  $l_{b,min}$  according to (25.4.3.2), ACI 318-14, using mean values for all the section re-bars.  
 $l_{d,min}$  from (25.4.3.2) is multiplied 2 times to account for smooth re-bars (9.1.2, TS500 - No provision in ACI 318)  
 $= 1$   
 $db = 16.66667$   
 Mean strength value of all re-bars:  $fy = 781.25$   
 Mean concrete strength:  $fc' = (fc'_{jacket} \cdot Area_{jacket} + fc'_{core} \cdot Area_{core}) / Area_{section} = 30.00$ , but  $fc'^{0.5} \leq 8.3$   
 MPa (22.5.3.1, ACI 318-14)  
 $t = 1.00$   
 $s = 0.80$   
 $e = 1.00$   
 $cb = 25.00$



$$K_{tr} = 1.7174$$

$$A_{tr} = \text{Min}(A_{tr\_x}, A_{tr\_y}) = 257.6106$$

where  $A_{tr\_x}$ ,  $A_{tr\_y}$  are the sum of the area of all stirrup legs along X and Y local axis

$$s = \text{Max}(s_{\text{external}}, s_{\text{internal}}) = 250.00$$

$$n = 24.00$$

Calculation of  $\mu_1$ -

Calculation of ultimate curvature  $\mu_u$  according to 4.1, Biskinis/Fardis 2013:

$$\mu_u = 5.1201636E-006$$

$$\mu_u = 5.0296E+008$$

with full section properties:

$$b = 400.00$$

$$d = 707.00$$

$$d' = 43.00$$

$$v = 0.00191815$$

$$N = 16273.608$$

$$f_c = 30.00$$

$$\alpha (5A.5, \text{TDY}) = 0.002$$

$$\text{Final value of } \mu_u: \mu_u^* = \text{shear\_factor} * \text{Max}(\mu_u, \mu_c) = 0.01260361$$

The Shear\_factor is considered equal to 1 (pure moment strength)

$$\text{From (5.4b), TDY: } \mu_u = 0.01260361$$

$$\mu_c (5.4c) = 0.05179731$$

$$\alpha_{se} ((5.4d), \text{TDY}) = (\alpha_{se1} * A_{ext} + \alpha_{se2} * A_{int}) / A_{sec} = 0.45746528$$

$$\alpha_{se1} = \text{Max}(((A_{conf,max1} - A_{noConf1}) / A_{conf,max1}) * (A_{conf,min1} / A_{conf,max1}), 0) = 0.45746528$$

The definitions of  $A_{noConf}$ ,  $A_{conf,min}$  and  $A_{conf,max}$  are derived from generalization of the rectangular sections confinement, which is expressed by (5.4d).

The generalization is done according to Mander, J., Priestley, M., and Park, R. (1988)

"Theoretical Stress-Strain Model for Confined Concrete."

J. Struct. Eng., 10.1061/(ASCE)0733-9445(1988)114:8(1804), 1804-1826.

$A_{conf,max1} = 353600.00$  is the confined core area at levels of member with hoops and is calculated as the area of core enclosed by the center lines of the external perimeter hoops.

$A_{conf,min1} = 293525.00$  is the confined core area at midway between the levels of hoops and is calculated by reducing all the dimensions of the area  $A_{conf,max1}$  by a length equal to half the clear spacing between external hoops.

$A_{noConf1} = 158733.333$  is the unconfined external core area which is equal to  $b_i^2/6$  as defined at (A.2).

$$\alpha_{se2} (>= \alpha_{se1}) = \text{Max}(((A_{conf,max2} - A_{noConf2}) / A_{conf,max2}) * (A_{conf,min2} / A_{conf,max2}), 0) = 0.45746528$$

The definitions of  $A_{noConf}$ ,  $A_{conf,min}$  and  $A_{conf,max}$  are derived from generalization of the rectangular sections confinement, which is expressed by (5.4d).

The generalization is done according to Mander, J., Priestley, M., and Park, R. (1988)

"Theoretical Stress-Strain Model for Confined Concrete."

J. Struct. Eng., 10.1061/(ASCE)0733-9445(1988)114:8(1804), 1804-1826.

$A_{conf,max2} = 171264.00$  is the confined core area at levels of member with hoops and is calculated as the area of core enclosed by the center lines of the internal perimeter hoops.

$A_{conf,min2} = 54741.00$  is the confined core area at midway between the levels of hoops and is calculated by reducing all the dimensions of the area  $A_{conf,max2}$  by a length equal to half the clear spacing between internal hoops.

$A_{noConf2} = 106242.667$  is the unconfined internal core area which is equal to  $b_i^2/6$  as defined at (A.2).

$$p_{sh,min} * F_{ywe} = \text{Min}(p_{sh,x} * F_{ywe}, p_{sh,y} * F_{ywe}) = 3.3968$$

$$p_{sh,x} * F_{ywe} = p_{sh1} * F_{ywe1} + p_{sh2} * F_{ywe2} = 3.3968$$

$$p_{sh1} ((5.4d), \text{TDY}) = L_{stir1} * A_{stir1} / (A_{sec} * s_1) = 0.00367709$$

$$L_{stir1} (\text{Length of stirrups along Y}) = 2060.00$$

$$A_{stir1} (\text{stirrups area}) = 78.53982$$

$$p_{sh2} (5.4d) = L_{stir2} * A_{stir2} / (A_{sec} * s_2) = 0.00067082$$

$$L_{stir2} (\text{Length of stirrups along Y}) = 1468.00$$

$$A_{stir2} (\text{stirrups area}) = 50.26548$$

$$p_{sh,y} * F_{ywe} = p_{sh1} * F_{ywe1} + p_{sh2} * F_{ywe2} = 3.3968$$

$$p_{sh1} ((5.4d), \text{TDY}) = L_{stir1} * A_{stir1} / (A_{sec} * s_1) = 0.00367709$$

$$L_{stir1} (\text{Length of stirrups along X}) = 2060.00$$

$$A_{stir1} (\text{stirrups area}) = 78.53982$$

$psh2 ((5.4d), TBDY) = Lstir2 * Astir2 / (Asec * s2) = 0.00067082$   
 $Lstir2$  (Length of stirrups along X) = 1468.00  
 $Astir2$  (stirrups area) = 50.26548

Asec = 440000.00

s1 = 100.00

s2 = 250.00

fywe1 = 781.25

fywe2 = 781.25

fce = 30.00

From ((5.A5), TBDY), TBDY: cc = 0.00471045

c = confinement factor = 1.27105

y1 = 0.00083886

sh1 = 0.00268436

ft1 = 314.5735

fy1 = 262.1446

su1 = 0.00268436

using (30) in Biskinis/Fardis (2013) multiplied with shear\_factor  
and also multiplied by the shear\_factor according to 15.7.1.4, with  
Shear\_factor = 1.00

lo/lou,min = lb/ld = 0.13907892

su1 = 0.4\*esu1\_nominal ((5.5), TBDY) = 0.032

From table 5A.1, TBDY: esu1\_nominal = 0.08,

For calculation of esu1\_nominal and y1, sh1,ft1,fy1, it is considered  
characteristic value fsy1 = fs1/1.2, from table 5.1, TBDY.

y1, sh1,ft1,fy1, are also multiplied by  $\text{Min}(1, 1.25 * (lb/ld)^{2/3})$ , from 10.3.5, ASCE 41-17.

with fs1 = (fs,jacket\*Asl,ten,jacket + fs,core\*Asl,ten,core)/Asl,ten = 262.1446

with Es1 = (Es,jacket\*Asl,ten,jacket + Es,core\*Asl,ten,core)/Asl,ten = 200000.00

y2 = 0.00083886

sh2 = 0.00268436

ft2 = 314.5735

fy2 = 262.1446

su2 = 0.00268436

using (30) in Biskinis/Fardis (2013) multiplied with shear\_factor  
and also multiplied by the shear\_factor according to 15.7.1.4, with  
Shear\_factor = 1.00

lo/lou,min = lb/lb,min = 0.13907892

su2 = 0.4\*esu2\_nominal ((5.5), TBDY) = 0.032

From table 5A.1, TBDY: esu2\_nominal = 0.08,

For calculation of esu2\_nominal and y2, sh2,ft2,fy2, it is considered  
characteristic value fsy2 = fs2/1.2, from table 5.1, TBDY.

y1, sh1,ft1,fy1, are also multiplied by  $\text{Min}(1, 1.25 * (lb/ld)^{2/3})$ , from 10.3.5, ASCE 41-17.

with fs2 = (fs,jacket\*Asl,com,jacket + fs,core\*Asl,com,core)/Asl,com = 262.1446

with Es2 = (Es,jacket\*Asl,com,jacket + Es,core\*Asl,com,core)/Asl,com = 200000.00

yv = 0.00083886

shv = 0.00268436

ftv = 314.5735

fyv = 262.1446

suv = 0.00268436

using (30) in Biskinis/Fardis (2013) multiplied with shear\_factor  
and also multiplied by the shear\_factor according to 15.7.1.4, with  
Shear\_factor = 1.00

lo/lou,min = lb/ld = 0.13907892

suv = 0.4\*esuv\_nominal ((5.5), TBDY) = 0.032

From table 5A.1, TBDY: esuv\_nominal = 0.08,

considering characteristic value fsyv = fsv/1.2, from table 5.1, TBDY  
For calculation of esuv\_nominal and yv, shv,ftv,fyv, it is considered  
characteristic value fsyv = fsv/1.2, from table 5.1, TBDY.

y1, sh1,ft1,fy1, are also multiplied by  $\text{Min}(1, 1.25 * (lb/ld)^{2/3})$ , from 10.3.5, ASCE 41-17.

with fsv = (fs,jacket\*Asl,mid,jacket + fs,mid\*Asl,mid,core)/Asl,mid = 262.1446

with Esv = (Es,jacket\*Asl,mid,jacket + Es,mid\*Asl,mid,core)/Asl,mid = 200000.00

1 = Asl,ten/(b\*d)\*(fs1/fc) = 0.06824101

2 = Asl,com/(b\*d)\*(fs2/fc) = 0.03513975

v = Asl,mid/(b\*d)\*(fsv/fc) = 0.06202846

and confined core properties:

b = 340.00

d = 677.00

```

d' = 13.00
fcc (5A.2, TBDY) = 38.13135
cc (5A.5, TBDY) = 0.00471045
c = confinement factor = 1.27105
1 = Asl,ten/(b*d)*(fs1/fc) = 0.08384116
2 = Asl,com/(b*d)*(fs2/fc) = 0.04317283
v = Asl,mid/(b*d)*(fsv/fc) = 0.07620839
Case/Assumption: Unconfined full section - Steel rupture
'satisfies Eq. (4.3)
---->
v < vs,y2 - LHS eq.(4.5) is satisfied
---->
su (4.9) = 0.2584548
Mu = MRc (4.14) = 5.0296E+008
u = su (4.1) = 5.1201636E-006
-----

Calculation of ratio lb/ld
-----

Lap Length: lb/ld = 0.13907892
lb = 300.00
ld = 2157.049
Calculation of lb,min according to (25.4.3.2), ACI 318-14, using mean values for all the section re-bars.
ld,min from (25.4.3.2) is multiplied 2 times to account for smooth re-bars (9.1.2, TS500 - No provision in ACI 318)
= 1
db = 16.66667
Mean strength value of all re-bars: fy = 781.25
Mean concrete strength: fc' = (fc'_jacket*Area_jacket + fc'_core*Area_core)/Area_section = 30.00, but fc'^0.5 <= 8.3
MPa (22.5.3.1, ACI 318-14)
t = 1.00
s = 0.80
e = 1.00
cb = 25.00
Ktr = 1.7174
Atr = Min(Atr_x,Atr_y) = 257.6106
where Atr_x, Atr_y are the sum of the area of all stirrup legs along X and Y loxal axis
s = Max(s_external,s_internal) = 250.00
n = 24.00
-----

Calculation of Mu2+
-----

Calculation of ultimate curvature u according to 4.1, Biskinis/Fardis 2013:
u = 4.8099118E-006
Mu = 2.3387E+008
-----

with full section properties:
b = 750.00
d = 707.00
d' = 43.00
v = 0.00102301
N = 16273.608
fc = 30.00
co (5A.5, TBDY) = 0.002
Final value of cu: cu* = shear_factor * Max( cu, cc) = 0.01260361
The Shear_factor is considered equal to 1 (pure moment strength)
From (5.4b), TBDY: cu = 0.01260361
we (5.4c) = 0.05179731
ase ((5.4d), TBDY) = (ase1*Aext+ase2*Aint)/Asec = 0.45746528
ase1 = Max(((Aconf,max1-AnoConf1)/Aconf,max1)*(Aconf,min1/Aconf,max1),0) = 0.45746528
The definitions of AnoConf, Aconf,min and Aconf,max are derived from generalization
of the rectangular sections confinement, which is expressed by (5.4d).
The generalization is done according to Mander, J., Priestley, M., and Park, R. (1988)
"Theoretical Stress-Strain Model for Confined Concrete."

```

J. Struct. Eng., 10.1061/(ASCE)0733-9445(1988)114:8(1804), 1804-1826.

Aconf,max1 = 353600.00 is the confined core area at levels of member with hoops and is calculated as the area of core enclosed by the center lines of the external perimeter hoops.  
Aconf,min1 = 293525.00 is the confined core area at midway between the levels of hoops and is calculated by reducing all the dimensions of the area Aconf,max1 by a length equal to half the clear spacing between external hoops.

AnoConf1 = 158733.333 is the unconfined external core area which is equal to  $b_i^2/6$  as defined at (A.2).  
ase2 ( $\geq$  ase1) =  $\text{Max}(((A_{\text{conf,max2}} - A_{\text{noConf2}})/A_{\text{conf,max2}}) * (A_{\text{conf,min2}}/A_{\text{conf,max2}}), 0) = 0.45746528$

The definitions of AnoConf, Aconf,min and Aconf,max are derived from generalization of the rectangular sections confinement, which is expressed by (5.4d).

The generalization is done according to Mander, J., Priestley, M., and Park, R. (1988)

"Theoretical Stress-Strain Model for Confined Concrete."

J. Struct. Eng., 10.1061/(ASCE)0733-9445(1988)114:8(1804), 1804-1826.

Aconf,max2 = 171264.00 is the confined core area at levels of member with hoops and is calculated as the area of core enclosed by the center lines of the internal perimeter hoops.

Aconf,min2 = 54741.00 is the confined core area at midway between the levels of hoops and is calculated by reducing all the dimensions of the area Aconf,max2 by a length equal to half the clear spacing between internal hoops.

AnoConf2 = 106242.667 is the unconfined internal core area which is equal to  $b_i^2/6$  as defined at (A.2).  
psh,min\*Fywe =  $\text{Min}(psh_x * Fywe, psh_y * Fywe) = 3.3968$

psh\_x\*Fywe = psh1\*Fywe1 + ps2\*Fywe2 = 3.3968  
psh1 ((5.4d), TBDY) =  $L_{\text{stir1}} * A_{\text{stir1}} / (A_{\text{sec}} * s_1) = 0.00367709$   
Lstir1 (Length of stirrups along Y) = 2060.00  
Astir1 (stirrups area) = 78.53982  
psh2 (5.4d) =  $L_{\text{stir2}} * A_{\text{stir2}} / (A_{\text{sec}} * s_2) = 0.00067082$   
Lstir2 (Length of stirrups along Y) = 1468.00  
Astir2 (stirrups area) = 50.26548

psh\_y\*Fywe = psh1\*Fywe1 + ps2\*Fywe2 = 3.3968  
psh1 ((5.4d), TBDY) =  $L_{\text{stir1}} * A_{\text{stir1}} / (A_{\text{sec}} * s_1) = 0.00367709$   
Lstir1 (Length of stirrups along X) = 2060.00  
Astir1 (stirrups area) = 78.53982  
psh2 ((5.4d), TBDY) =  $L_{\text{stir2}} * A_{\text{stir2}} / (A_{\text{sec}} * s_2) = 0.00067082$   
Lstir2 (Length of stirrups along X) = 1468.00  
Astir2 (stirrups area) = 50.26548

Asec = 440000.00

s1 = 100.00

s2 = 250.00

fywe1 = 781.25

fywe2 = 781.25

fce = 30.00

From ((5.A5), TBDY), TBDY: cc = 0.00471045

c = confinement factor = 1.27105

y1 = 0.00083886

sh1 = 0.00268436

ft1 = 314.5735

fy1 = 262.1446

su1 = 0.00268436

using (30) in Biskinis/Fardis (2013) multiplied with shear\_factor and also multiplied by the shear\_factor according to 15.7.1.4, with Shear\_factor = 1.00

lo/lo,min = lb/ld = 0.13907892

su1 =  $0.4 * esu1_{\text{nominal}} ((5.5), \text{TBDY}) = 0.032$

From table 5A.1, TBDY: esu1\_nominal = 0.08,

For calculation of esu1\_nominal and y1, sh1, ft1, fy1, it is considered characteristic value fsy1 = fs1/1.2, from table 5.1, TBDY.

y1, sh1, ft1, fy1, are also multiplied by  $\text{Min}(1, 1.25 * (lb/ld)^{2/3})$ , from 10.3.5, ASCE 41-17.

with fs1 =  $(f_{s,jacket} * A_{s,ten,jacket} + f_{s,core} * A_{s,ten,core}) / A_{s,ten} = 262.1446$

with Es1 =  $(E_{s,jacket} * A_{s,ten,jacket} + E_{s,core} * A_{s,ten,core}) / A_{s,ten} = 200000.00$

y2 = 0.00083886

sh2 = 0.00268436

ft2 = 314.5735

fy2 = 262.1446

su2 = 0.00268436

using (30) in Biskinis/Fardis (2013) multiplied with shear\_factor

and also multiplied by the shear\_factor according to 15.7.1.4, with  
 Shear\_factor = 1.00  
 $l_o/l_{o,min} = l_b/l_{b,min} = 0.13907892$   
 $su_2 = 0.4 * esu_{2,nominal} ((5.5), TBDY) = 0.032$   
 From table 5A.1, TBDY:  $esu_{2,nominal} = 0.08$ ,  
 For calculation of  $esu_{2,nominal}$  and  $y_2, sh_2, ft_2, fy_2$ , it is considered  
 characteristic value  $fsy_2 = fs_2/1.2$ , from table 5.1, TBDY.  
 $y_1, sh_1, ft_1, fy_1$ , are also multiplied by  $Min(1, 1.25 * (l_b/l_d)^{2/3})$ , from 10.3.5, ASCE 41-17.  
 with  $fs_2 = (fs_{jacket} * Asl_{com,jacket} + fs_{core} * Asl_{com,core}) / Asl_{com} = 262.1446$   
 with  $Es_2 = (Es_{jacket} * Asl_{com,jacket} + Es_{core} * Asl_{com,core}) / Asl_{com} = 200000.00$   
 $y_v = 0.00083886$   
 $sh_v = 0.00268436$   
 $ft_v = 314.5735$   
 $fy_v = 262.1446$   
 $suv = 0.00268436$   
 using (30) in Biskinis/Fardis (2013) multiplied with shear\_factor  
 and also multiplied by the shear\_factor according to 15.7.1.4, with  
 Shear\_factor = 1.00  
 $l_o/l_{o,min} = l_b/l_d = 0.13907892$   
 $suv = 0.4 * esuv_{nominal} ((5.5), TBDY) = 0.032$   
 From table 5A.1, TBDY:  $esuv_{nominal} = 0.08$ ,  
 considering characteristic value  $fsv = fs_v/1.2$ , from table 5.1, TBDY  
 For calculation of  $esuv_{nominal}$  and  $y_v, sh_v, ft_v, fy_v$ , it is considered  
 characteristic value  $fsv = fs_v/1.2$ , from table 5.1, TBDY.  
 $y_1, sh_1, ft_1, fy_1$ , are also multiplied by  $Min(1, 1.25 * (l_b/l_d)^{2/3})$ , from 10.3.5, ASCE 41-17.  
 with  $fs_v = (fs_{jacket} * Asl_{mid,jacket} + fs_{mid} * Asl_{mid,core}) / Asl_{mid} = 262.1446$   
 with  $Es_v = (Es_{jacket} * Asl_{mid,jacket} + Es_{mid} * Asl_{mid,core}) / Asl_{mid} = 200000.00$   
 $1 = Asl_{ten} / (b * d) * (fs_1 / fc) = 0.0187412$   
 $2 = Asl_{com} / (b * d) * (fs_2 / fc) = 0.03639521$   
 $v = Asl_{mid} / (b * d) * (fs_v / fc) = 0.03308184$

and confined core properties:

$b = 690.00$   
 $d = 677.00$   
 $d' = 13.00$   
 $fcc (5A.2, TBDY) = 38.13135$   
 $cc (5A.5, TBDY) = 0.00471045$   
 $c = \text{confinement factor} = 1.27105$   
 $1 = Asl_{ten} / (b * d) * (fs_1 / fc) = 0.02127357$   
 $2 = Asl_{com} / (b * d) * (fs_2 / fc) = 0.04131304$   
 $v = Asl_{mid} / (b * d) * (fs_v / fc) = 0.03755196$

Case/Assumption: Unconfined full section - Steel rupture

' satisfies Eq. (4.3)

----

$v < v_{s,y_2}$  - LHS eq.(4.5) is satisfied

----

$su (4.9) = 0.21062322$

$Mu = MRc (4.14) = 2.3387E+008$

$u = su (4.1) = 4.8099118E-006$

-----  
 Calculation of ratio  $l_b/l_d$

-----  
 Lap Length:  $l_b/l_d = 0.13907892$

$l_b = 300.00$

$l_d = 2157.049$

Calculation of  $l_{b,min}$  according to (25.4.3.2), ACI 318-14, using mean values for all the section re-bars.

$l_{d,min}$  from (25.4.3.2) is multiplied 2 times to account for smooth re-bars (9.1.2, TS500 - No provision in ACI 318)

= 1

$db = 16.66667$

Mean strength value of all re-bars:  $fy = 781.25$

Mean concrete strength:  $fc' = (fc'_{jacket} * Area_{jacket} + fc'_{core} * Area_{core}) / Area_{section} = 30.00$ , but  $fc'^{0.5} \leq 8.3$   
 MPa (22.5.3.1, ACI 318-14)

$t = 1.00$

$s = 0.80$

$e = 1.00$

$cb = 25.00$

$K_{tr} = 1.7174$

$$A_{tr} = \text{Min}(A_{tr\_x}, A_{tr\_y}) = 257.6106$$

where  $A_{tr\_x}$ ,  $A_{tr\_y}$  are the sum of the area of all stirrup legs along X and Y local axis

$$s = \text{Max}(s_{\text{external}}, s_{\text{internal}}) = 250.00$$

$$n = 24.00$$

Calculation of  $\mu_2$ -

Calculation of ultimate curvature  $\mu$  according to 4.1, Biskinis/Fardis 2013:

$$\mu = 5.1201636E-006$$

$$\mu_2 = 5.0296E+008$$

with full section properties:

$$b = 400.00$$

$$d = 707.00$$

$$d' = 43.00$$

$$v = 0.00191815$$

$$N = 16273.608$$

$$f_c = 30.00$$

$$\alpha (5A.5, \text{TDY}) = 0.002$$

$$\text{Final value of } \mu: \mu^* = \text{shear\_factor} * \text{Max}(\mu, \alpha) = 0.01260361$$

The Shear\_factor is considered equal to 1 (pure moment strength)

$$\text{From (5.4b), TDY: } \mu = 0.01260361$$

$$\text{we (5.4c) } = 0.05179731$$

$$\text{ase ((5.4d), TDY) } = (\text{ase1} * A_{\text{ext}} + \text{ase2} * A_{\text{int}}) / A_{\text{sec}} = 0.45746528$$

$$\text{ase1} = \text{Max}(((A_{\text{conf,max1}} - A_{\text{noConf1}}) / A_{\text{conf,max1}}) * (A_{\text{conf,min1}} / A_{\text{conf,max1}}), 0) = 0.45746528$$

The definitions of  $A_{\text{noConf}}$ ,  $A_{\text{conf,min}}$  and  $A_{\text{conf,max}}$  are derived from generalization of the rectangular sections confinement, which is expressed by (5.4d).

The generalization is done according to Mander, J., Priestley, M., and Park, R. (1988)

"Theoretical Stress-Strain Model for Confined Concrete."

J. Struct. Eng., 10.1061/(ASCE)0733-9445(1988)114:8(1804), 1804-1826.

$A_{\text{conf,max1}} = 353600.00$  is the confined core area at levels of member with hoops and

is calculated as the area of core enclosed by the center lines of the external perimeter hoops.

$A_{\text{conf,min1}} = 293525.00$  is the confined core area at midway between the levels of hoops and

is calculated by reducing all the dimensions of the area  $A_{\text{conf,max1}}$  by a length equal to half the clear spacing between external hoops.

$A_{\text{noConf1}} = 158733.333$  is the unconfined external core area which is equal to  $b_i^2/6$  as defined at (A.2).

$$\text{ase2} (>= \text{ase1}) = \text{Max}(((A_{\text{conf,max2}} - A_{\text{noConf2}}) / A_{\text{conf,max2}}) * (A_{\text{conf,min2}} / A_{\text{conf,max2}}), 0) = 0.45746528$$

The definitions of  $A_{\text{noConf}}$ ,  $A_{\text{conf,min}}$  and  $A_{\text{conf,max}}$  are derived from generalization of the rectangular sections confinement, which is expressed by (5.4d).

The generalization is done according to Mander, J., Priestley, M., and Park, R. (1988)

"Theoretical Stress-Strain Model for Confined Concrete."

J. Struct. Eng., 10.1061/(ASCE)0733-9445(1988)114:8(1804), 1804-1826.

$A_{\text{conf,max2}} = 171264.00$  is the confined core area at levels of member with hoops and

is calculated as the area of core enclosed by the center lines of the internal perimeter hoops.

$A_{\text{conf,min2}} = 54741.00$  is the confined core area at midway between the levels of hoops and

is calculated by reducing all the dimensions of the area  $A_{\text{conf,max2}}$  by a length equal to half the clear spacing between internal hoops.

$A_{\text{noConf2}} = 106242.667$  is the unconfined internal core area which is equal to  $b_i^2/6$  as defined at (A.2).

$$p_{sh,min} * F_{ywe} = \text{Min}(p_{sh,x} * F_{ywe}, p_{sh,y} * F_{ywe}) = 3.3968$$

$$p_{sh,x} * F_{ywe} = p_{sh1} * F_{ywe1} + p_{sh2} * F_{ywe2} = 3.3968$$

$$p_{sh1} ((5.4d), \text{TDY}) = L_{stir1} * A_{stir1} / (A_{sec} * s_1) = 0.00367709$$

$$L_{stir1} (\text{Length of stirrups along Y}) = 2060.00$$

$$A_{stir1} (\text{stirrups area}) = 78.53982$$

$$p_{sh2} (5.4d) = L_{stir2} * A_{stir2} / (A_{sec} * s_2) = 0.00067082$$

$$L_{stir2} (\text{Length of stirrups along Y}) = 1468.00$$

$$A_{stir2} (\text{stirrups area}) = 50.26548$$

$$p_{sh,y} * F_{ywe} = p_{sh1} * F_{ywe1} + p_{sh2} * F_{ywe2} = 3.3968$$

$$p_{sh1} ((5.4d), \text{TDY}) = L_{stir1} * A_{stir1} / (A_{sec} * s_1) = 0.00367709$$

$$L_{stir1} (\text{Length of stirrups along X}) = 2060.00$$

$$A_{stir1} (\text{stirrups area}) = 78.53982$$

$$p_{sh2} ((5.4d), \text{TDY}) = L_{stir2} * A_{stir2} / (A_{sec} * s_2) = 0.00067082$$

Lstir2 (Length of stirrups along X) = 1468.00  
Astir2 (stirrups area) = 50.26548

Asec = 440000.00

s1 = 100.00

s2 = 250.00

fywe1 = 781.25

fywe2 = 781.25

fce = 30.00

From ((5.A5), TBDY), TBDY: cc = 0.00471045

c = confinement factor = 1.27105

y1 = 0.00083886

sh1 = 0.00268436

ft1 = 314.5735

fy1 = 262.1446

su1 = 0.00268436

using (30) in Biskinis/Fardis (2013) multiplied with shear\_factor  
and also multiplied by the shear\_factor according to 15.7.1.4, with  
Shear\_factor = 1.00

lo/lou,min = lb/lb = 0.13907892

su1 = 0.4\*esu1\_nominal ((5.5), TBDY) = 0.032

From table 5A.1, TBDY: esu1\_nominal = 0.08,

For calculation of esu1\_nominal and y1, sh1,ft1,fy1, it is considered  
characteristic value fsy1 = fs1/1.2, from table 5.1, TBDY.

y1, sh1,ft1,fy1, are also multiplied by  $\text{Min}(1, 1.25 \cdot (lb/lb)^{2/3})$ , from 10.3.5, ASCE 41-17.

with fs1 = (fs,jacket\*Asl,ten,jacket + fs,core\*Asl,ten,core)/Asl,ten = 262.1446

with Es1 = (Es,jacket\*Asl,ten,jacket + Es,core\*Asl,ten,core)/Asl,ten = 200000.00

y2 = 0.00083886

sh2 = 0.00268436

ft2 = 314.5735

fy2 = 262.1446

su2 = 0.00268436

using (30) in Biskinis/Fardis (2013) multiplied with shear\_factor  
and also multiplied by the shear\_factor according to 15.7.1.4, with  
Shear\_factor = 1.00

lo/lou,min = lb/lb,min = 0.13907892

su2 = 0.4\*esu2\_nominal ((5.5), TBDY) = 0.032

From table 5A.1, TBDY: esu2\_nominal = 0.08,

For calculation of esu2\_nominal and y2, sh2,ft2,fy2, it is considered  
characteristic value fsy2 = fs2/1.2, from table 5.1, TBDY.

y1, sh1,ft1,fy1, are also multiplied by  $\text{Min}(1, 1.25 \cdot (lb/lb)^{2/3})$ , from 10.3.5, ASCE 41-17.

with fs2 = (fs,jacket\*Asl,com,jacket + fs,core\*Asl,com,core)/Asl,com = 262.1446

with Es2 = (Es,jacket\*Asl,com,jacket + Es,core\*Asl,com,core)/Asl,com = 200000.00

yv = 0.00083886

shv = 0.00268436

ftv = 314.5735

fyv = 262.1446

suv = 0.00268436

using (30) in Biskinis/Fardis (2013) multiplied with shear\_factor  
and also multiplied by the shear\_factor according to 15.7.1.4, with  
Shear\_factor = 1.00

lo/lou,min = lb/lb = 0.13907892

suv = 0.4\*esuv\_nominal ((5.5), TBDY) = 0.032

From table 5A.1, TBDY: esuv\_nominal = 0.08,

considering characteristic value fsyv = fsv/1.2, from table 5.1, TBDY

For calculation of esuv\_nominal and yv, shv,ftv,fyv, it is considered  
characteristic value fsyv = fsv/1.2, from table 5.1, TBDY.

y1, sh1,ft1,fy1, are also multiplied by  $\text{Min}(1, 1.25 \cdot (lb/lb)^{2/3})$ , from 10.3.5, ASCE 41-17.

with fsv = (fs,jacket\*Asl,mid,jacket + fs,mid\*Asl,mid,core)/Asl,mid = 262.1446

with Esv = (Es,jacket\*Asl,mid,jacket + Es,mid\*Asl,mid,core)/Asl,mid = 200000.00

1 = Asl,ten/(b\*d)\*(fs1/fc) = 0.06824101

2 = Asl,com/(b\*d)\*(fs2/fc) = 0.03513975

v = Asl,mid/(b\*d)\*(fsv/fc) = 0.06202846

and confined core properties:

b = 340.00

d = 677.00

d' = 13.00

```

fcc (5A.2, TBDY) = 38.13135
cc (5A.5, TBDY) = 0.00471045
c = confinement factor = 1.27105
1 = Asl,ten/(b*d)*(fs1/fc) = 0.08384116
2 = Asl,com/(b*d)*(fs2/fc) = 0.04317283
v = Asl,mid/(b*d)*(fsv/fc) = 0.07620839
Case/Assumption: Unconfined full section - Steel rupture
'satisfies Eq. (4.3)
--->
v < vs,y2 - LHS eq.(4.5) is satisfied
--->
su (4.9) = 0.2584548
Mu = MRc (4.14) = 5.0296E+008
u = su (4.1) = 5.1201636E-006

```

#### Calculation of ratio lb/ld

```

Lap Length: lb/ld = 0.13907892
lb = 300.00
ld = 2157.049
Calculation of lb,min according to (25.4.3.2), ACI 318-14, using mean values for all the section re-bars.
ld,min from (25.4.3.2) is multiplied 2 times to account for smooth re-bars (9.1.2, TS500 - No provision in ACI 318)
= 1
db = 16.66667
Mean strength value of all re-bars: fy = 781.25
Mean concrete strength: fc' = (fc'_jacket*Area_jacket + fc'_core*Area_core)/Area_section = 30.00, but fc'^0.5 <= 8.3
MPa (22.5.3.1, ACI 318-14)
t = 1.00
s = 0.80
e = 1.00
cb = 25.00
Ktr = 1.7174
Atr = Min(Atr_x,Atr_y) = 257.6106
where Atr_x, Atr_y are the sum of the area of all stirrup legs along X and Y loxal axis
s = Max(s_external,s_internal) = 250.00
n = 24.00

```

Calculation of Shear Strength  $V_r = \text{Min}(V_{r1}, V_{r2}) = 1.0392\text{E}+006$

Calculation of Shear Strength at edge 1,  $V_{r1} = 1.0392\text{E}+006$   
 $V_{r1} = V_{Col} \text{ ((10.3), ASCE 41-17)} = knl * V_{Col0}$   
 $V_{Col0} = 1.0392\text{E}+006$   
 $knl = 1$  (zero step-static loading)

NOTE: In expression (10-3) ' $V_s = A_v * f_y * d / s$ ' is replaced by ' $V_s + f * V_f$ '  
 where  $V_f$  is the contribution of FRPs (11.3), ACI 440).

```

= 1 (normal-weight concrete)
Mean concrete strength: fc' = (fc'_jacket*Area_jacket + fc'_core*Area_core)/Area_section = 30.00, but fc'^0.5 <= 8.3
MPa (22.5.3.1, ACI 318-14)
M/Vd = 4.00
Mu = 1308.016
Vu = 0.00017144
d = 0.8*h = 600.00
Nu = 16273.608
Ag = 300000.00
From (11.5.4.8), ACI 318-14: Vs = Vs,jacket + Vs,core = 1.0138E+006
where:
Vs,jacket = Vs,j1 + Vs,j2 = 903207.888
Vs,j1 = 589048.623 is calculated for section web jacket, with:
d = 600.00
Av = 157079.633
fy = 625.00

```



$s = 100.00$   
 $V_{sj1}$  is multiplied by  $Col,j1 = 1.00$   
 $s/d = 0.16666667$   
 $V_{sj2} = 314159.265$  is calculated for section flange jacket, with:  
 $d = 320.00$   
 $A_v = 157079.633$   
 $f_y = 625.00$   
 $s = 100.00$   
 $V_{sj2}$  is multiplied by  $Col,j2 = 1.00$   
 $s/d = 0.3125$   
 $V_{s,core} = V_{s,c1} + V_{s,c2} = 110584.061$   
 $V_{s,c1} = 110584.061$  is calculated for section web core, with:  
 $d = 440.00$   
 $A_v = 100530.965$   
 $f_y = 625.00$   
 $s = 250.00$   
 $V_{s,c1}$  is multiplied by  $Col,c1 = 1.00$   
 $s/d = 0.56818182$   
 $V_{s,c2} = 0.00$  is calculated for section flange core, with:  
 $d = 160.00$   
 $A_v = 100530.965$   
 $f_y = 625.00$   
 $s = 250.00$   
 $V_{s,c2}$  is multiplied by  $Col,c2 = 0.00$   
 $s/d = 1.5625$   
 $V_f ((11-3)-(11.4), ACI 440) = 0.00$   
 From (11-11), ACI 440:  $V_s + V_f \leq 873250.061$   
 $bw = 400.00$

Calculation of Shear Strength at edge 2,  $V_{r2} = 1.0392E+006$   
 $V_{r2} = V_{Col} ((10.3), ASCE 41-17) = knl * V_{Col0}$   
 $V_{Col0} = 1.0392E+006$   
 $knl = 1$  (zero step-static loading)

NOTE: In expression (10-3) ' $V_s = A_v * f_y * d / s$ ' is replaced by ' $V_s + f * V_f$ '  
 where  $V_f$  is the contribution of FRPs (11.3), ACI 440).

$= 1$  (normal-weight concrete)  
 Mean concrete strength:  $f'_c = (f'_{c,jacket} * Area_{jacket} + f'_{c,core} * Area_{core}) / Area_{section} = 30.00$ , but  $f'_c^{0.5} \leq 8.3$   
 MPa (22.5.3.1, ACI 318-14)  
 $M/Vd = 4.00$   
 $M_u = 1308.016$   
 $V_u = 0.00017144$   
 $d = 0.8 * h = 600.00$   
 $N_u = 16273.608$   
 $A_g = 300000.00$   
 From (11.5.4.8), ACI 318-14:  $V_s = V_{sj,jacket} + V_{sj,core} = 1.0138E+006$   
 where:  
 $V_{sj,jacket} = V_{sj1} + V_{sj2} = 903207.888$   
 $V_{sj1} = 589048.623$  is calculated for section web jacket, with:  
 $d = 600.00$   
 $A_v = 157079.633$   
 $f_y = 625.00$   
 $s = 100.00$   
 $V_{sj1}$  is multiplied by  $Col,j1 = 1.00$   
 $s/d = 0.16666667$   
 $V_{sj2} = 314159.265$  is calculated for section flange jacket, with:  
 $d = 320.00$   
 $A_v = 157079.633$   
 $f_y = 625.00$   
 $s = 100.00$   
 $V_{sj2}$  is multiplied by  $Col,j2 = 1.00$   
 $s/d = 0.3125$   
 $V_{s,core} = V_{s,c1} + V_{s,c2} = 110584.061$   
 $V_{s,c1} = 110584.061$  is calculated for section web core, with:  
 $d = 440.00$

```

Av = 100530.965
fy = 625.00
s = 250.00
Vs,c1 is multiplied by Col,c1 = 1.00
s/d = 0.56818182
Vs,c2 = 0.00 is calculated for section flange core, with:
d = 160.00
Av = 100530.965
fy = 625.00
s = 250.00
Vs,c2 is multiplied by Col,c2 = 0.00
s/d = 1.5625
Vf ((11-3)-(11.4), ACI 440) = 0.00
From (11-11), ACI 440: Vs + Vf <= 873250.061
bw = 400.00
-----

End Of Calculation of Shear Capacity ratio for element: column JLC1 of floor 1
At local axis: 3
-----

Start Of Calculation of Shear Capacity ratio for element: column JLC1 of floor 1
At Shear local axis: 2
(Bending local axis: 3)
Section Type: rcjlc

Constant Properties
-----
Knowledge Factor,   = 1.00
Mean strength values are used for both shear and moment calculations.
Consequently:
Jacket
New material of Primary Member: Concrete Strength, fc = fcm = 30.00
New material of Primary Member: Steel Strength, fs = fsm = 625.00
Concrete Elasticity, Ec = 25742.96
Steel Elasticity, Es = 200000.00
Existing Column
New material of Primary Member: Concrete Strength, fc = fcm = 30.00
New material of Primary Member: Steel Strength, fs = fsm = 625.00
Concrete Elasticity, Ec = 25742.96
Steel Elasticity, Es = 200000.00
#####
Note: Especially for the calculation of moment strengths,
the above steel re-bar strengths are multiplied by 1.25 according to R18.6.5, ACI 318-14
Jacket
New material: Steel Strength, fs = 1.25*fsm = 781.25
Existing Column
New material: Steel Strength, fs = 1.25*fsm = 781.25
#####
Max Height, Hmax = 750.00
Min Height, Hmin = 400.00
Max Width, Wmax = 750.00
Min Width, Wmin = 400.00
Jacket Thickness, tj = 100.00
Cover Thickness, c = 25.00
Mean Confinement Factor overall section = 1.27105
Element Length, L = 3000.00
Primary Member
Smooth Bars
Ductile Steel
With Detailing for Earthquake Resistance (including stirrups closed at 135°)
Longitudinal Bars With Ends Lapped Starting at the End Sections
Lap Length lo = 300.00
No FRP Wrapping
-----

```

## Stepwise Properties

At local axis: 2

EDGE -A-

Shear Force,  $V_a = -0.0001715$

EDGE -B-

Shear Force,  $V_b = 0.0001715$

BOTH EDGES

Axial Force,  $F = -16273.608$

Longitudinal Reinforcement Area Distribution (in 2 divisions)

-Tension:  $As_t = 0.00$

-Compression:  $As_c = 5353.274$

Longitudinal Reinforcement Area Distribution (in 3 divisions)

-Tension:  $As_{t,ten} = 1137.257$

-Compression:  $As_{c,com} = 2208.54$

-Middle:  $As_{l,mid} = 2007.478$

Calculation of Shear Capacity ratio,  $V_e/V_r = 0.32266369$

Member Controlled by Flexure ( $V_e/V_r < 1$ )

Calculation of Shear Demand from fig. R18.6.5, ACI 318-14  $V_e = (M_{pr1} + M_{pr2})/l_n = 335307.657$   
with

$M_{pr1} = \text{Max}(\mu_{1+}, \mu_{1-}) = 5.0296\text{E}+008$

$\mu_{1+} = 2.3387\text{E}+008$ , is the ultimate moment strength at the edge 1 of the member in the actual moment direction which is defined for the static loading combination

$\mu_{1-} = 5.0296\text{E}+008$ , is the ultimate moment strength at the edge 1 of the member in the opposite moment direction which is defined for the static loading combination

$M_{pr2} = \text{Max}(\mu_{2+}, \mu_{2-}) = 5.0296\text{E}+008$

$\mu_{2+} = 2.3387\text{E}+008$ , is the ultimate moment strength at the edge 2 of the member in the actual moment direction which is defined for the static loading combination

$\mu_{2-} = 5.0296\text{E}+008$ , is the ultimate moment strength at the edge 2 of the member in the opposite moment direction which is defined for the static loading combination

Calculation of  $\mu_{1+}$

Calculation of ultimate curvature  $\phi_u$  according to 4.1, Biskinis/Fardis 2013:

$\phi_u = 4.8099118\text{E}-006$

$M_u = 2.3387\text{E}+008$

with full section properties:

$b = 750.00$

$d = 707.00$

$d' = 43.00$

$v = 0.00102301$

$N = 16273.608$

$f_c = 30.00$

$\phi_c$  (5A.5, TBDY) = 0.002

Final value of  $\phi_u$ :  $\phi_u^* = \text{shear\_factor} * \text{Max}(\phi_{cu}, \phi_{cc}) = 0.01260361$

The Shear\_factor is considered equal to 1 (pure moment strength)

From (5.4b), TBDY:  $\phi_{cu} = 0.01260361$

we (5.4c) = 0.05179731

$\phi_{ase}$  ((5.4d), TBDY) =  $(\phi_{ase1} * A_{ext} + \phi_{ase2} * A_{int}) / A_{sec} = 0.45746528$

$\phi_{ase1} = \text{Max}(((A_{conf,max1} - A_{noConf1}) / A_{conf,max1}) * (A_{conf,min1} / A_{conf,max1}), 0) = 0.45746528$

The definitions of  $A_{noConf}$ ,  $A_{conf,min}$  and  $A_{conf,max}$  are derived from generalization of the rectangular sections confinement, which is expressed by (5.4d).

The generalization is done according to Mander, J., Priestley, M., and Park, R. (1988)

"Theoretical Stress-Strain Model for Confined Concrete."

J. Struct. Eng., 10.1061/(ASCE)0733-9445(1988)114:8(1804), 1804-1826.

$A_{conf,max1} = 353600.00$  is the confined core area at levels of member with hoops and

is calculated as the area of core enclosed by the center lines of the external perimeter hoops.

$A_{conf,min1} = 293525.00$  is the confined core area at midway between the levels of hoops and

is calculated by reducing all the dimensions of the area  $A_{conf,max1}$  by a length equal to half the clear spacing between external hoops.

$A_{noConf1} = 158733.333$  is the unconfined external core area which is equal to  $b_i^2/6$  as defined at (A.2).  
 $ase2 (>=ase1) = \text{Max}(((A_{conf,max2}-A_{noConf2})/A_{conf,max2})*(A_{conf,min2}/A_{conf,max2}),0) = 0.45746528$

The definitions of  $A_{noConf}$ ,  $A_{conf,min}$  and  $A_{conf,max}$  are derived from generalization of the rectangular sections confinement, which is expressed by (5.4d).

The generalization is done according to Mander, J., Priestley, M., and Park, R. (1988) "Theoretical Stress-Strain Model for Confined Concrete."

J. Struct. Eng., 10.1061/(ASCE)0733-9445(1988)114:8(1804), 1804-1826.

$A_{conf,max2} = 171264.00$  is the confined core area at levels of member with hoops and is calculated as the area of core enclosed by the center lines of the internal perimeter hoops.

$A_{conf,min2} = 54741.00$  is the confined core area at midway between the levels of hoops and is calculated by reducing all the dimensions of the area  $A_{conf,max2}$  by a length equal to half the clear spacing between internal hoops.

$A_{noConf2} = 106242.667$  is the unconfined internal core area which is equal to  $b_i^2/6$  as defined at (A.2).  
 $psh,min*Fywe = \text{Min}(psh,x*Fywe, psh,y*Fywe) = 3.3968$

-----  
 $psh_x*Fywe = psh1*Fywe1 + ps2*Fywe2 = 3.3968$   
 $psh1 ((5.4d), TBDY) = Lstir1*Astir1/(Asec*s1) = 0.00367709$   
 $Lstir1$  (Length of stirrups along Y) = 2060.00  
 $Astir1$  (stirrups area) = 78.53982  
 $psh2 ((5.4d)) = Lstir2*Astir2/(Asec*s2) = 0.00067082$   
 $Lstir2$  (Length of stirrups along Y) = 1468.00  
 $Astir2$  (stirrups area) = 50.26548

-----  
 $psh_y*Fywe = psh1*Fywe1 + ps2*Fywe2 = 3.3968$   
 $psh1 ((5.4d), TBDY) = Lstir1*Astir1/(Asec*s1) = 0.00367709$   
 $Lstir1$  (Length of stirrups along X) = 2060.00  
 $Astir1$  (stirrups area) = 78.53982  
 $psh2 ((5.4d), TBDY) = Lstir2*Astir2/(Asec*s2) = 0.00067082$   
 $Lstir2$  (Length of stirrups along X) = 1468.00  
 $Astir2$  (stirrups area) = 50.26548

-----  
 $Asec = 440000.00$

$s1 = 100.00$

$s2 = 250.00$

$fywe1 = 781.25$

$fywe2 = 781.25$

$fce = 30.00$

From ((5.A5), TBDY), TBDY:  $cc = 0.00471045$

$c$  = confinement factor = 1.27105

$y1 = 0.00083886$

$sh1 = 0.00268436$

$ft1 = 314.5735$

$fy1 = 262.1446$

$su1 = 0.00268436$

using (30) in Biskinis/Fardis (2013) multiplied with shear\_factor and also multiplied by the shear\_factor according to 15.7.1.4, with

Shear\_factor = 1.00

$lo/lou,min = lb/ld = 0.13907892$

$su1 = 0.4*esu1\_nominal ((5.5), TBDY) = 0.032$

From table 5A.1, TBDY:  $esu1\_nominal = 0.08$ ,

For calculation of  $esu1\_nominal$  and  $y1, sh1, ft1, fy1$ , it is considered characteristic value  $fsy1 = fs1/1.2$ , from table 5.1, TBDY.

$y1, sh1, ft1, fy1$ , are also multiplied by  $\text{Min}(1, 1.25*(lb/ld)^{2/3})$ , from 10.3.5, ASCE 41-17.

with  $fs1 = (fs,jacket*Asl,ten,jacket + fs,core*Asl,ten,core)/Asl,ten = 262.1446$

with  $Es1 = (Es,jacket*Asl,ten,jacket + Es,core*Asl,ten,core)/Asl,ten = 200000.00$

$y2 = 0.00083886$

$sh2 = 0.00268436$

$ft2 = 314.5735$

$fy2 = 262.1446$

$su2 = 0.00268436$

using (30) in Biskinis/Fardis (2013) multiplied with shear\_factor and also multiplied by the shear\_factor according to 15.7.1.4, with

Shear\_factor = 1.00

$lo/lou,min = lb/lb,min = 0.13907892$

$su2 = 0.4*esu2\_nominal ((5.5), TBDY) = 0.032$

From table 5A.1, TBDY:  $es_{2\_nominal} = 0.08$ ,  
For calculation of  $es_{2\_nominal}$  and  $y_2$ ,  $sh_2, ft_2, fy_2$ , it is considered  
characteristic value  $fs_{y2} = fs_2/1.2$ , from table 5.1, TBDY.  
 $y_1$ ,  $sh_1, ft_1, fy_1$ , are also multiplied by  $\text{Min}(1, 1.25 \cdot (lb/ld)^{2/3})$ , from 10.3.5, ASCE 41-17.  
with  $fs_2 = (fs_{jacket} \cdot Asl_{com,jacket} + fs_{core} \cdot Asl_{com,core}) / Asl_{com} = 262.1446$   
with  $Es_2 = (Es_{jacket} \cdot Asl_{com,jacket} + Es_{core} \cdot Asl_{com,core}) / Asl_{com} = 200000.00$   
 $y_v = 0.00083886$   
 $sh_v = 0.00268436$   
 $ft_v = 314.5735$   
 $fy_v = 262.1446$   
 $suv = 0.00268436$   
using (30) in Biskinis/Fardis (2013) multiplied with shear\_factor  
and also multiplied by the shear\_factor according to 15.7.1.4, with  
Shear\_factor = 1.00  
 $lo/lo_{u,min} = lb/ld = 0.13907892$   
 $suv = 0.4 \cdot es_{uv\_nominal} ((5.5), TBDY) = 0.032$   
From table 5A.1, TBDY:  $es_{uv\_nominal} = 0.08$ ,  
considering characteristic value  $fs_{yv} = fs_v/1.2$ , from table 5.1, TBDY  
For calculation of  $es_{uv\_nominal}$  and  $y_v$ ,  $sh_v, ft_v, fy_v$ , it is considered  
characteristic value  $fs_{yv} = fs_v/1.2$ , from table 5.1, TBDY.  
 $y_1$ ,  $sh_1, ft_1, fy_1$ , are also multiplied by  $\text{Min}(1, 1.25 \cdot (lb/ld)^{2/3})$ , from 10.3.5, ASCE 41-17.  
with  $fs_v = (fs_{jacket} \cdot Asl_{mid,jacket} + fs_{mid} \cdot Asl_{mid,core}) / Asl_{mid} = 262.1446$   
with  $Es_v = (Es_{jacket} \cdot Asl_{mid,jacket} + Es_{mid} \cdot Asl_{mid,core}) / Asl_{mid} = 200000.00$   
 $1 = Asl_{ten} / (b \cdot d) \cdot (fs_1 / fc) = 0.0187412$   
 $2 = Asl_{com} / (b \cdot d) \cdot (fs_2 / fc) = 0.03639521$   
 $v = Asl_{mid} / (b \cdot d) \cdot (fs_v / fc) = 0.03308184$   
and confined core properties:  
 $b = 690.00$   
 $d = 677.00$   
 $d' = 13.00$   
 $fcc (5A.2, TBDY) = 38.13135$   
 $cc (5A.5, TBDY) = 0.00471045$   
 $c = \text{confinement factor} = 1.27105$   
 $1 = Asl_{ten} / (b \cdot d) \cdot (fs_1 / fc) = 0.02127357$   
 $2 = Asl_{com} / (b \cdot d) \cdot (fs_2 / fc) = 0.04131304$   
 $v = Asl_{mid} / (b \cdot d) \cdot (fs_v / fc) = 0.03755196$   
Case/Assumption: Unconfined full section - Steel rupture  
' satisfies Eq. (4.3)  
--->  
 $v < v_{s,y2}$  - LHS eq.(4.5) is satisfied  
--->  
 $su (4.9) = 0.21062322$   
 $Mu = MRc (4.14) = 2.3387E+008$   
 $u = su (4.1) = 4.8099118E-006$   
-----  
Calculation of ratio  $lb/ld$   
-----  
Lap Length:  $lb/ld = 0.13907892$   
 $lb = 300.00$   
 $ld = 2157.049$   
Calculation of  $lb_{min}$  according to (25.4.3.2), ACI 318-14, using mean values for all the section re-bars.  
 $ld_{min}$  from (25.4.3.2) is multiplied 2 times to account for smooth re-bars (9.1.2, TS500 - No provision in ACI 318)  
 $= 1$   
 $db = 16.66667$   
Mean strength value of all re-bars:  $fy = 781.25$   
Mean concrete strength:  $fc' = (fc'_{jacket} \cdot Area_{jacket} + fc'_{core} \cdot Area_{core}) / Area_{section} = 30.00$ , but  $fc'^{0.5} \leq 8.3$   
MPa (22.5.3.1, ACI 318-14)  
 $t = 1.00$   
 $s = 0.80$   
 $e = 1.00$   
 $cb = 25.00$   
 $K_{tr} = 1.7174$   
 $A_{tr} = \text{Min}(A_{tr\_x}, A_{tr\_y}) = 257.6106$   
where  $A_{tr\_x}, A_{tr\_y}$  are the sum of the area of all stirrup legs along X and Y loxal axis  
 $s = \text{Max}(s_{external}, s_{internal}) = 250.00$   
 $n = 24.00$

## Calculation of Mu1-

Calculation of ultimate curvature  $\mu$  according to 4.1, Biskinis/Fardis 2013:

$$\mu = 5.1201636E-006$$

$$\mu_u = 5.0296E+008$$

with full section properties:

$$b = 400.00$$

$$d = 707.00$$

$$d' = 43.00$$

$$\nu = 0.00191815$$

$$N = 16273.608$$

$$f_c = 30.00$$

$$\alpha (5A.5, \text{TB DY}) = 0.002$$

$$\text{Final value of } \mu_u: \mu_u = \text{shear\_factor} * \text{Max}(\mu_u, \alpha) = 0.01260361$$

The Shear\_factor is considered equal to 1 (pure moment strength)

$$\text{From (5.4b), TB DY: } \mu_u = 0.01260361$$

$$\mu_{ue} (5.4c) = 0.05179731$$

$$\alpha_{se} ((5.4d), \text{TB DY}) = (\alpha_{se1} * A_{ext} + \alpha_{se2} * A_{int}) / A_{sec} = 0.45746528$$

$$\alpha_{se1} = \text{Max}(((A_{conf,max1} - A_{noConf1}) / A_{conf,max1}) * (A_{conf,min1} / A_{conf,max1}), 0) = 0.45746528$$

The definitions of  $A_{noConf}$ ,  $A_{conf,min}$  and  $A_{conf,max}$  are derived from generalization of the rectangular sections confinement, which is expressed by (5.4d).

The generalization is done according to Mander, J., Priestley, M., and Park, R. (1988)

"Theoretical Stress-Strain Model for Confined Concrete."

J. Struct. Eng., 10.1061/(ASCE)0733-9445(1988)114:8(1804), 1804-1826.

$A_{conf,max1} = 353600.00$  is the confined core area at levels of member with hoops and is calculated as the area of core enclosed by the center lines of the external perimeter hoops.

$A_{conf,min1} = 293525.00$  is the confined core area at midway between the levels of hoops and is calculated by reducing all the dimensions of the area  $A_{conf,max1}$  by a length equal to half the clear spacing between external hoops.

$$A_{noConf1} = 158733.333 \text{ is the unconfined external core area which is equal to } b^2/6 \text{ as defined at (A.2).}$$
$$\alpha_{se2} (\geq \alpha_{se1}) = \text{Max}(((A_{conf,max2} - A_{noConf2}) / A_{conf,max2}) * (A_{conf,min2} / A_{conf,max2}), 0) = 0.45746528$$

The definitions of  $A_{noConf}$ ,  $A_{conf,min}$  and  $A_{conf,max}$  are derived from generalization of the rectangular sections confinement, which is expressed by (5.4d).

The generalization is done according to Mander, J., Priestley, M., and Park, R. (1988)

"Theoretical Stress-Strain Model for Confined Concrete."

J. Struct. Eng., 10.1061/(ASCE)0733-9445(1988)114:8(1804), 1804-1826.

$A_{conf,max2} = 171264.00$  is the confined core area at levels of member with hoops and is calculated as the area of core enclosed by the center lines of the internal perimeter hoops.

$A_{conf,min2} = 54741.00$  is the confined core area at midway between the levels of hoops and is calculated by reducing all the dimensions of the area  $A_{conf,max2}$  by a length equal to half the clear spacing between internal hoops.

$$A_{noConf2} = 106242.667 \text{ is the unconfined internal core area which is equal to } b^2/6 \text{ as defined at (A.2).}$$
$$p_{sh,min} * F_{ywe} = \text{Min}(p_{sh,x} * F_{ywe}, p_{sh,y} * F_{ywe}) = 3.3968$$

$$p_{sh,x} * F_{ywe} = p_{sh1} * F_{ywe1} + p_{sh2} * F_{ywe2} = 3.3968$$

$$p_{sh1} ((5.4d), \text{TB DY}) = L_{stir1} * A_{stir1} / (A_{sec} * s_1) = 0.00367709$$

$$L_{stir1} \text{ (Length of stirrups along Y)} = 2060.00$$

$$A_{stir1} \text{ (stirrups area)} = 78.53982$$

$$p_{sh2} (5.4d) = L_{stir2} * A_{stir2} / (A_{sec} * s_2) = 0.00067082$$

$$L_{stir2} \text{ (Length of stirrups along Y)} = 1468.00$$

$$A_{stir2} \text{ (stirrups area)} = 50.26548$$

$$p_{sh,y} * F_{ywe} = p_{sh1} * F_{ywe1} + p_{sh2} * F_{ywe2} = 3.3968$$

$$p_{sh1} ((5.4d), \text{TB DY}) = L_{stir1} * A_{stir1} / (A_{sec} * s_1) = 0.00367709$$

$$L_{stir1} \text{ (Length of stirrups along X)} = 2060.00$$

$$A_{stir1} \text{ (stirrups area)} = 78.53982$$

$$p_{sh2} ((5.4d), \text{TB DY}) = L_{stir2} * A_{stir2} / (A_{sec} * s_2) = 0.00067082$$

$$L_{stir2} \text{ (Length of stirrups along X)} = 1468.00$$

$$A_{stir2} \text{ (stirrups area)} = 50.26548$$

$$A_{sec} = 440000.00$$

$s1 = 100.00$   
 $s2 = 250.00$   
 $fyw1 = 781.25$   
 $fyw2 = 781.25$   
 $fce = 30.00$   
 From ((5.A.5), TBDY), TBDY:  $cc = 0.00471045$   
 $c = \text{confinement factor} = 1.27105$   
 $y1 = 0.00083886$   
 $sh1 = 0.00268436$   
 $ft1 = 314.5735$   
 $fy1 = 262.1446$   
 $su1 = 0.00268436$   
 using (30) in Biskinis/Fardis (2013) multiplied with shear\_factor  
 and also multiplied by the shear\_factor according to 15.7.1.4, with  
 $\text{Shear\_factor} = 1.00$   
 $lo/lou, \min = lb/ld = 0.13907892$   
 $su1 = 0.4 * esu1\_nominal ((5.5), TBDY) = 0.032$   
 From table 5A.1, TBDY:  $esu1\_nominal = 0.08$ ,  
 For calculation of  $esu1\_nominal$  and  $y1, sh1, ft1, fy1$ , it is considered  
 characteristic value  $fsy1 = fs1/1.2$ , from table 5.1, TBDY.  
 $y1, sh1, ft1, fy1$ , are also multiplied by  $\text{Min}(1, 1.25 * (lb/ld)^{2/3})$ , from 10.3.5, ASCE 41-17.  
 with  $fs1 = (fs\_jacket * Asl, \text{ten}, \text{jacket} + fs\_core * Asl, \text{ten}, \text{core}) / Asl, \text{ten} = 262.1446$   
 with  $Es1 = (Es\_jacket * Asl, \text{ten}, \text{jacket} + Es\_core * Asl, \text{ten}, \text{core}) / Asl, \text{ten} = 200000.00$   
 $y2 = 0.00083886$   
 $sh2 = 0.00268436$   
 $ft2 = 314.5735$   
 $fy2 = 262.1446$   
 $su2 = 0.00268436$   
 using (30) in Biskinis/Fardis (2013) multiplied with shear\_factor  
 and also multiplied by the shear\_factor according to 15.7.1.4, with  
 $\text{Shear\_factor} = 1.00$   
 $lo/lou, \min = lb/lb, \min = 0.13907892$   
 $su2 = 0.4 * esu2\_nominal ((5.5), TBDY) = 0.032$   
 From table 5A.1, TBDY:  $esu2\_nominal = 0.08$ ,  
 For calculation of  $esu2\_nominal$  and  $y2, sh2, ft2, fy2$ , it is considered  
 characteristic value  $fsy2 = fs2/1.2$ , from table 5.1, TBDY.  
 $y1, sh1, ft1, fy1$ , are also multiplied by  $\text{Min}(1, 1.25 * (lb/ld)^{2/3})$ , from 10.3.5, ASCE 41-17.  
 with  $fs2 = (fs\_jacket * Asl, \text{com}, \text{jacket} + fs\_core * Asl, \text{com}, \text{core}) / Asl, \text{com} = 262.1446$   
 with  $Es2 = (Es\_jacket * Asl, \text{com}, \text{jacket} + Es\_core * Asl, \text{com}, \text{core}) / Asl, \text{com} = 200000.00$   
 $yv = 0.00083886$   
 $shv = 0.00268436$   
 $ftv = 314.5735$   
 $fyv = 262.1446$   
 $suv = 0.00268436$   
 using (30) in Biskinis/Fardis (2013) multiplied with shear\_factor  
 and also multiplied by the shear\_factor according to 15.7.1.4, with  
 $\text{Shear\_factor} = 1.00$   
 $lo/lou, \min = lb/ld = 0.13907892$   
 $suv = 0.4 * esuv\_nominal ((5.5), TBDY) = 0.032$   
 From table 5A.1, TBDY:  $esuv\_nominal = 0.08$ ,  
 considering characteristic value  $fsyv = fsv/1.2$ , from table 5.1, TBDY  
 For calculation of  $esuv\_nominal$  and  $yv, shv, ftv, fyv$ , it is considered  
 characteristic value  $fsyv = fsv/1.2$ , from table 5.1, TBDY.  
 $y1, sh1, ft1, fy1$ , are also multiplied by  $\text{Min}(1, 1.25 * (lb/ld)^{2/3})$ , from 10.3.5, ASCE 41-17.  
 with  $fsv = (fs\_jacket * Asl, \text{mid}, \text{jacket} + fs\_mid * Asl, \text{mid}, \text{core}) / Asl, \text{mid} = 262.1446$   
 with  $Es_v = (Es\_jacket * Asl, \text{mid}, \text{jacket} + Es\_mid * Asl, \text{mid}, \text{core}) / Asl, \text{mid} = 200000.00$   
 $1 = Asl, \text{ten} / (b * d) * (fs1 / fc) = 0.06824101$   
 $2 = Asl, \text{com} / (b * d) * (fs2 / fc) = 0.03513975$   
 $v = Asl, \text{mid} / (b * d) * (fsv / fc) = 0.06202846$   
 and confined core properties:  
 $b = 340.00$   
 $d = 677.00$   
 $d' = 13.00$   
 $fcc (5A.2, TBDY) = 38.13135$   
 $cc (5A.5, TBDY) = 0.00471045$   
 $c = \text{confinement factor} = 1.27105$   
 $1 = Asl, \text{ten} / (b * d) * (fs1 / fc) = 0.08384116$

$$2 = A_{sl,com}/(b*d)*(f_s2/f_c) = 0.04317283$$

$$v = A_{sl,mid}/(b*d)*(f_{sv}/f_c) = 0.07620839$$

Case/Assumption: Unconfined full section - Steel rupture

' satisfies Eq. (4.3)

---->

$v < v_{s,y2}$  - LHS eq.(4.5) is satisfied

---->

$$s_u(4.9) = 0.2584548$$

$$M_u = M_{Rc}(4.14) = 5.0296E+008$$

$$u = s_u(4.1) = 5.1201636E-006$$

Calculation of ratio  $l_b/l_d$

Lap Length:  $l_b/l_d = 0.13907892$

$$l_b = 300.00$$

$$l_d = 2157.049$$

Calculation of  $l_b, \min$  according to (25.4.3.2), ACI 318-14, using mean values for all the section re-bars.

$l_d, \min$  from (25.4.3.2) is multiplied 2 times to account for smooth re-bars (9.1.2, TS500 - No provision in ACI 318)

$$= 1$$

$$d_b = 16.66667$$

Mean strength value of all re-bars:  $f_y = 781.25$

Mean concrete strength:  $f'_c = (f'_{c,jacket} \cdot Area_{jacket} + f'_{c,core} \cdot Area_{core}) / Area_{section} = 30.00$ , but  $f_c^{0.5} \leq 8.3$  MPa (22.5.3.1, ACI 318-14)

$$t = 1.00$$

$$s = 0.80$$

$$e = 1.00$$

$$c_b = 25.00$$

$$K_{tr} = 1.7174$$

$$A_{tr} = \min(A_{tr,x}, A_{tr,y}) = 257.6106$$

where  $A_{tr,x}$ ,  $A_{tr,y}$  are the sum of the area of all stirrup legs along X and Y loxal axis

$$s = \max(s_{external}, s_{internal}) = 250.00$$

$$n = 24.00$$

Calculation of  $M_{u2+}$

Calculation of ultimate curvature  $u$  according to 4.1, Biskinis/Fardis 2013:

$$u = 4.8099118E-006$$

$$M_u = 2.3387E+008$$

with full section properties:

$$b = 750.00$$

$$d = 707.00$$

$$d' = 43.00$$

$$v = 0.00102301$$

$$N = 16273.608$$

$$f_c = 30.00$$

$$c_o(5A.5, TBDY) = 0.002$$

$$\text{Final value of } c_u: c_u^* = \text{shear\_factor} \cdot \max(c_u, c_c) = 0.01260361$$

The Shear\_factor is considered equal to 1 (pure moment strength)

$$\text{From (5.4b), TBDY: } c_u = 0.01260361$$

$$w_e(5.4c) = 0.05179731$$

$$a_{se}((5.4d), TBDY) = (a_{se1} \cdot A_{ext} + a_{se2} \cdot A_{int}) / A_{sec} = 0.45746528$$

$$a_{se1} = \max(((A_{conf,max1} - A_{noConf1}) / A_{conf,max1}) \cdot (A_{conf,min1} / A_{conf,max1}), 0) = 0.45746528$$

The definitions of  $A_{noConf}$ ,  $A_{conf,min}$  and  $A_{conf,max}$  are derived from generalization of the rectangular sections confinement, which is expressed by (5.4d).

The generalization is done according to Mander, J., Priestley, M., and Park, R. (1988)

"Theoretical Stress-Strain Model for Confined Concrete."

J. Struct. Eng., 10.1061/(ASCE)0733-9445(1988)114:8(1804), 1804-1826.

$A_{conf,max1} = 353600.00$  is the confined core area at levels of member with hoops and

is calculated as the area of core enclosed by the center lines of the external perimeter hoops.

$A_{conf,min1} = 293525.00$  is the confined core area at midway between the levels of hoops and

is calculated by reducing all the dimensions of the area  $A_{conf,max1}$  by a length



equal to half the clear spacing between external hoops.

AnoConf1 = 158733.333 is the unconfined external core area which is equal to  $b_i^2/6$  as defined at (A.2).  
 $ase2 (>= ase1) = \text{Max}(((A_{conf,max2} - \text{AnoConf2})/A_{conf,max2}) * (A_{conf,min2}/A_{conf,max2}), 0) = 0.45746528$

The definitions of AnoConf, Aconf,min and Aconf,max are derived from generalization of the rectangular sections confinement, which is expressed by (5.4d).

The generalization is done according to Mander, J., Priestley, M., and Park, R. (1988)

"Theoretical Stress-Strain Model for Confined Concrete."

J. Struct. Eng., 10.1061/(ASCE)0733-9445(1988)114:8(1804), 1804-1826.

Aconf,max2 = 171264.00 is the confined core area at levels of member with hoops and

is calculated as the area of core enclosed by the center lines of the internal perimeter hoops.

Aconf,min2 = 54741.00 is the confined core area at midway between the levels of hoops and

is calculated by reducing all the dimensions of the area Aconf,max2 by a length

equal to half the clear spacing between internal hoops.

AnoConf2 = 106242.667 is the unconfined internal core area which is equal to  $b_i^2/6$  as defined at (A.2).

$psh,min * F_{ywe} = \text{Min}(psh,x * F_{ywe}, psh,y * F_{ywe}) = 3.3968$

$psh,x * F_{ywe} = psh1 * F_{ywe1} + ps2 * F_{ywe2} = 3.3968$

$psh1 ((5.4d), \text{TB DY}) = L_{stir1} * A_{stir1} / (A_{sec} * s1) = 0.00367709$

$L_{stir1}$  (Length of stirrups along Y) = 2060.00

$A_{stir1}$  (stirrups area) = 78.53982

$psh2 ((5.4d)) = L_{stir2} * A_{stir2} / (A_{sec} * s2) = 0.00067082$

$L_{stir2}$  (Length of stirrups along Y) = 1468.00

$A_{stir2}$  (stirrups area) = 50.26548

$psh,y * F_{ywe} = psh1 * F_{ywe1} + ps2 * F_{ywe2} = 3.3968$

$psh1 ((5.4d), \text{TB DY}) = L_{stir1} * A_{stir1} / (A_{sec} * s1) = 0.00367709$

$L_{stir1}$  (Length of stirrups along X) = 2060.00

$A_{stir1}$  (stirrups area) = 78.53982

$psh2 ((5.4d), \text{TB DY}) = L_{stir2} * A_{stir2} / (A_{sec} * s2) = 0.00067082$

$L_{stir2}$  (Length of stirrups along X) = 1468.00

$A_{stir2}$  (stirrups area) = 50.26548

$A_{sec} = 440000.00$

$s1 = 100.00$

$s2 = 250.00$

$f_{ywe1} = 781.25$

$f_{ywe2} = 781.25$

$f_{ce} = 30.00$

From ((5.A5), TB DY), TB DY:  $cc = 0.00471045$

$c$  = confinement factor = 1.27105

$y1 = 0.00083886$

$sh1 = 0.00268436$

$ft1 = 314.5735$

$fy1 = 262.1446$

$su1 = 0.00268436$

using (30) in Biskinis/Fardis (2013) multiplied with shear\_factor

and also multiplied by the shear\_factor according to 15.7.1.4, with

Shear\_factor = 1.00

$lo/lo_{min} = lb/ld = 0.13907892$

$su1 = 0.4 * esu1_{nominal} ((5.5), \text{TB DY}) = 0.032$

From table 5A.1, TB DY:  $esu1_{nominal} = 0.08$ ,

For calculation of  $esu1_{nominal}$  and  $y1, sh1, ft1, fy1$ , it is considered characteristic value  $fsy1 = fs1/1.2$ , from table 5.1, TB DY.

$y1, sh1, ft1, fy1$ , are also multiplied by  $\text{Min}(1, 1.25 * (lb/ld)^{2/3})$ , from 10.3.5, ASCE 41-17.

with  $fs1 = (fs_{jacket} * A_{sl,ten,jacket} + fs_{core} * A_{sl,ten,core}) / A_{sl,ten} = 262.1446$

with  $Es1 = (Es_{jacket} * A_{sl,ten,jacket} + Es_{core} * A_{sl,ten,core}) / A_{sl,ten} = 200000.00$

$y2 = 0.00083886$

$sh2 = 0.00268436$

$ft2 = 314.5735$

$fy2 = 262.1446$

$su2 = 0.00268436$

using (30) in Biskinis/Fardis (2013) multiplied with shear\_factor

and also multiplied by the shear\_factor according to 15.7.1.4, with

Shear\_factor = 1.00

$lo/lo_{min} = lb/lb_{min} = 0.13907892$

$su2 = 0.4 * esu2_{nominal} ((5.5), \text{TB DY}) = 0.032$

From table 5A.1, TB DY:  $esu2_{nominal} = 0.08$ ,

For calculation of  $es_{u2\_nominal}$  and  $y_2$ ,  $sh_{2,ft2,fy2}$ , it is considered characteristic value  $fs_{y2} = fs_2/1.2$ , from table 5.1, TBDY.

$y_1$ ,  $sh_{1,ft1,fy1}$ , are also multiplied by  $\text{Min}(1, 1.25 \cdot (l_b/l_d)^{2/3})$ , from 10.3.5, ASCE 41-17.

with  $fs_2 = (fs_{jacket} \cdot A_{sl,com,jacket} + fs_{core} \cdot A_{sl,com,core}) / A_{sl,com} = 262.1446$

with  $Es_2 = (Es_{jacket} \cdot A_{sl,com,jacket} + Es_{core} \cdot A_{sl,com,core}) / A_{sl,com} = 200000.00$

$y_v = 0.00083886$

$sh_v = 0.00268436$

$ft_v = 314.5735$

$fy_v = 262.1446$

$suv = 0.00268436$

using (30) in Biskinis/Fardis (2013) multiplied with shear\_factor and also multiplied by the shear\_factor according to 15.7.1.4, with Shear\_factor = 1.00

$l_o/l_{ou,min} = l_b/l_d = 0.13907892$

$suv = 0.4 \cdot es_{u\_nominal} ((5.5), TBDY) = 0.032$

From table 5A.1, TBDY:  $es_{u\_nominal} = 0.08$ ,

considering characteristic value  $fs_{yv} = fs_v/1.2$ , from table 5.1, TBDY

For calculation of  $es_{u\_nominal}$  and  $y_v$ ,  $sh_v$ ,  $ft_v$ ,  $fy_v$ , it is considered characteristic value  $fs_{yv} = fs_v/1.2$ , from table 5.1, TBDY.

$y_1$ ,  $sh_{1,ft1,fy1}$ , are also multiplied by  $\text{Min}(1, 1.25 \cdot (l_b/l_d)^{2/3})$ , from 10.3.5, ASCE 41-17.

with  $fs_v = (fs_{jacket} \cdot A_{sl,mid,jacket} + fs_{mid} \cdot A_{sl,mid,core}) / A_{sl,mid} = 262.1446$

with  $Es_v = (Es_{jacket} \cdot A_{sl,mid,jacket} + Es_{mid} \cdot A_{sl,mid,core}) / A_{sl,mid} = 200000.00$

$1 = A_{sl,ten}/(b \cdot d) \cdot (fs_1/f_c) = 0.0187412$

$2 = A_{sl,com}/(b \cdot d) \cdot (fs_2/f_c) = 0.03639521$

$v = A_{sl,mid}/(b \cdot d) \cdot (fs_v/f_c) = 0.03308184$

and confined core properties:

$b = 690.00$

$d = 677.00$

$d' = 13.00$

$f_{cc} (5A.2, TBDY) = 38.13135$

$cc (5A.5, TBDY) = 0.00471045$

$c = \text{confinement factor} = 1.27105$

$1 = A_{sl,ten}/(b \cdot d) \cdot (fs_1/f_c) = 0.02127357$

$2 = A_{sl,com}/(b \cdot d) \cdot (fs_2/f_c) = 0.04131304$

$v = A_{sl,mid}/(b \cdot d) \cdot (fs_v/f_c) = 0.03755196$

Case/Assumption: Unconfined full section - Steel rupture

' satisfies Eq. (4.3)

--->

$v < v_{s,y2}$  - LHS eq.(4.5) is satisfied

--->

$su (4.9) = 0.21062322$

$Mu = MR_c (4.14) = 2.3387E+008$

$u = su (4.1) = 4.8099118E-006$

-----

Calculation of ratio  $l_b/l_d$

-----

Lap Length:  $l_b/l_d = 0.13907892$

$l_b = 300.00$

$l_d = 2157.049$

Calculation of  $l_{b,min}$  according to (25.4.3.2), ACI 318-14, using mean values for all the section re-bars.

$l_{d,min}$  from (25.4.3.2) is multiplied 2 times to account for smooth re-bars (9.1.2, TS500 - No provision in ACI 318)

= 1

$db = 16.66667$

Mean strength value of all re-bars:  $fy = 781.25$

Mean concrete strength:  $fc' = (fc'_{jacket} \cdot Area_{jacket} + fc'_{core} \cdot Area_{core}) / Area_{section} = 30.00$ , but  $fc'^{0.5} \leq 8.3$  MPa (22.5.3.1, ACI 318-14)

$t = 1.00$

$s = 0.80$

$e = 1.00$

$cb = 25.00$

$K_{tr} = 1.7174$

$A_{tr} = \text{Min}(A_{tr\_x}, A_{tr\_y}) = 257.6106$

where  $A_{tr\_x}$ ,  $A_{tr\_y}$  are the sum of the area of all stirrup legs along X and Y loxal axis

$s = \text{Max}(s_{external}, s_{internal}) = 250.00$

$n = 24.00$

-----

## Calculation of Mu2-

Calculation of ultimate curvature  $\mu$  according to 4.1, Biskinis/Fardis 2013:

$$\mu = 5.1201636E-006$$

$$Mu = 5.0296E+008$$

with full section properties:

$$b = 400.00$$

$$d = 707.00$$

$$d' = 43.00$$

$$v = 0.00191815$$

$$N = 16273.608$$

$$f_c = 30.00$$

$$c_o \text{ (5A.5, TBDY)} = 0.002$$

$$\text{Final value of } \mu: \mu = \text{shear\_factor} * \text{Max}(\mu_c, \mu_o) = 0.01260361$$

The Shear\_factor is considered equal to 1 (pure moment strength)

$$\text{From (5.4b), TBDY: } \mu_c = 0.01260361$$

$$\mu_o \text{ (5.4c)} = 0.05179731$$

$$a_{se} \text{ ((5.4d), TBDY)} = (a_{se1} * A_{ext} + a_{se2} * A_{int}) / A_{sec} = 0.45746528$$

$$a_{se1} = \text{Max}(((A_{conf,max1} - A_{noConf1}) / A_{conf,max1}) * (A_{conf,min1} / A_{conf,max1}), 0) = 0.45746528$$

The definitions of  $A_{noConf}$ ,  $A_{conf,min}$  and  $A_{conf,max}$  are derived from generalization

of the rectangular sections confinement, which is expressed by (5.4d).

The generalization is done according to Mander, J., Priestley, M., and Park, R. (1988)

"Theoretical Stress-Strain Model for Confined Concrete."

J. Struct. Eng., 10.1061/(ASCE)0733-9445(1988)114:8(1804), 1804-1826.

$A_{conf,max1} = 353600.00$  is the confined core area at levels of member with hoops and

is calculated as the area of core enclosed by the center lines of the external perimeter hoops.

$A_{conf,min1} = 293525.00$  is the confined core area at midway between the levels of hoops and

is calculated by reducing all the dimensions of the area  $A_{conf,max1}$  by a length

equal to half the clear spacing between external hoops.

$A_{noConf1} = 158733.333$  is the unconfined external core area which is equal to  $b_i^2/6$  as defined at (A.2).

$$a_{se2} (>= a_{se1}) = \text{Max}(((A_{conf,max2} - A_{noConf2}) / A_{conf,max2}) * (A_{conf,min2} / A_{conf,max2}), 0) = 0.45746528$$

The definitions of  $A_{noConf}$ ,  $A_{conf,min}$  and  $A_{conf,max}$  are derived from generalization

of the rectangular sections confinement, which is expressed by (5.4d).

The generalization is done according to Mander, J., Priestley, M., and Park, R. (1988)

"Theoretical Stress-Strain Model for Confined Concrete."

J. Struct. Eng., 10.1061/(ASCE)0733-9445(1988)114:8(1804), 1804-1826.

$A_{conf,max2} = 171264.00$  is the confined core area at levels of member with hoops and

is calculated as the area of core enclosed by the center lines of the internal perimeter hoops.

$A_{conf,min2} = 54741.00$  is the confined core area at midway between the levels of hoops and

is calculated by reducing all the dimensions of the area  $A_{conf,max2}$  by a length

equal to half the clear spacing between internal hoops.

$A_{noConf2} = 106242.667$  is the unconfined internal core area which is equal to  $b_i^2/6$  as defined at (A.2).

$$p_{sh,min} * F_{ywe} = \text{Min}(p_{sh,x} * F_{ywe}, p_{sh,y} * F_{ywe}) = 3.3968$$

$$p_{sh,x} * F_{ywe} = p_{sh1} * F_{ywe1} + p_{sh2} * F_{ywe2} = 3.3968$$

$$p_{sh1} \text{ ((5.4d), TBDY)} = L_{stir1} * A_{stir1} / (A_{sec} * s_1) = 0.00367709$$

$$L_{stir1} \text{ (Length of stirrups along Y)} = 2060.00$$

$$A_{stir1} \text{ (stirrups area)} = 78.53982$$

$$p_{sh2} \text{ (5.4d)} = L_{stir2} * A_{stir2} / (A_{sec} * s_2) = 0.00067082$$

$$L_{stir2} \text{ (Length of stirrups along Y)} = 1468.00$$

$$A_{stir2} \text{ (stirrups area)} = 50.26548$$

$$p_{sh,y} * F_{ywe} = p_{sh1} * F_{ywe1} + p_{sh2} * F_{ywe2} = 3.3968$$

$$p_{sh1} \text{ ((5.4d), TBDY)} = L_{stir1} * A_{stir1} / (A_{sec} * s_1) = 0.00367709$$

$$L_{stir1} \text{ (Length of stirrups along X)} = 2060.00$$

$$A_{stir1} \text{ (stirrups area)} = 78.53982$$

$$p_{sh2} \text{ ((5.4d), TBDY)} = L_{stir2} * A_{stir2} / (A_{sec} * s_2) = 0.00067082$$

$$L_{stir2} \text{ (Length of stirrups along X)} = 1468.00$$

$$A_{stir2} \text{ (stirrups area)} = 50.26548$$

$$A_{sec} = 440000.00$$

$$s_1 = 100.00$$

$s_2 = 250.00$   
 $fy_{we1} = 781.25$   
 $fy_{we2} = 781.25$   
 $f_{ce} = 30.00$   
 From ((5A.5), TBDY), TBDY:  $cc = 0.00471045$   
 $c = \text{confinement factor} = 1.27105$   
 $y_1 = 0.00083886$   
 $sh_1 = 0.00268436$   
 $ft_1 = 314.5735$   
 $fy_1 = 262.1446$   
 $su_1 = 0.00268436$   
 using (30) in Biskinis/Fardis (2013) multiplied with shear\_factor  
 and also multiplied by the shear\_factor according to 15.7.1.4, with  
 $\text{Shear\_factor} = 1.00$   
 $lo/lou, \min = lb/ld = 0.13907892$   
 $su_1 = 0.4 * esu_1, \text{nominal} ((5.5), \text{TBDY}) = 0.032$   
 From table 5A.1, TBDY:  $esu_1, \text{nominal} = 0.08$ ,  
 For calculation of  $esu_1, \text{nominal}$  and  $y_1, sh_1, ft_1, fy_1$ , it is considered  
 characteristic value  $fs_1 = fs_1/1.2$ , from table 5.1, TBDY.  
 $y_1, sh_1, ft_1, fy_1$ , are also multiplied by  $\text{Min}(1, 1.25 * (lb/ld)^{2/3})$ , from 10.3.5, ASCE 41-17.  
 with  $fs_1 = (fs_{\text{jacket}} * Asl, \text{ten, jacket} + fs_{\text{core}} * Asl, \text{ten, core}) / Asl, \text{ten} = 262.1446$   
 with  $Es_1 = (Es_{\text{jacket}} * Asl, \text{ten, jacket} + Es_{\text{core}} * Asl, \text{ten, core}) / Asl, \text{ten} = 200000.00$   
 $y_2 = 0.00083886$   
 $sh_2 = 0.00268436$   
 $ft_2 = 314.5735$   
 $fy_2 = 262.1446$   
 $su_2 = 0.00268436$   
 using (30) in Biskinis/Fardis (2013) multiplied with shear\_factor  
 and also multiplied by the shear\_factor according to 15.7.1.4, with  
 $\text{Shear\_factor} = 1.00$   
 $lo/lou, \min = lb/lb, \min = 0.13907892$   
 $su_2 = 0.4 * esu_2, \text{nominal} ((5.5), \text{TBDY}) = 0.032$   
 From table 5A.1, TBDY:  $esu_2, \text{nominal} = 0.08$ ,  
 For calculation of  $esu_2, \text{nominal}$  and  $y_2, sh_2, ft_2, fy_2$ , it is considered  
 characteristic value  $fs_2 = fs_2/1.2$ , from table 5.1, TBDY.  
 $y_1, sh_1, ft_1, fy_1$ , are also multiplied by  $\text{Min}(1, 1.25 * (lb/ld)^{2/3})$ , from 10.3.5, ASCE 41-17.  
 with  $fs_2 = (fs_{\text{jacket}} * Asl, \text{com, jacket} + fs_{\text{core}} * Asl, \text{com, core}) / Asl, \text{com} = 262.1446$   
 with  $Es_2 = (Es_{\text{jacket}} * Asl, \text{com, jacket} + Es_{\text{core}} * Asl, \text{com, core}) / Asl, \text{com} = 200000.00$   
 $y_v = 0.00083886$   
 $sh_v = 0.00268436$   
 $ft_v = 314.5735$   
 $fy_v = 262.1446$   
 $suv = 0.00268436$   
 using (30) in Biskinis/Fardis (2013) multiplied with shear\_factor  
 and also multiplied by the shear\_factor according to 15.7.1.4, with  
 $\text{Shear\_factor} = 1.00$   
 $lo/lou, \min = lb/ld = 0.13907892$   
 $suv = 0.4 * esuv, \text{nominal} ((5.5), \text{TBDY}) = 0.032$   
 From table 5A.1, TBDY:  $esuv, \text{nominal} = 0.08$ ,  
 considering characteristic value  $fs_v = fs_v/1.2$ , from table 5.1, TBDY  
 For calculation of  $esuv, \text{nominal}$  and  $y_v, sh_v, ft_v, fy_v$ , it is considered  
 characteristic value  $fs_v = fs_v/1.2$ , from table 5.1, TBDY.  
 $y_1, sh_1, ft_1, fy_1$ , are also multiplied by  $\text{Min}(1, 1.25 * (lb/ld)^{2/3})$ , from 10.3.5, ASCE 41-17.  
 with  $fs_v = (fs_{\text{jacket}} * Asl, \text{mid, jacket} + fs_{\text{mid}} * Asl, \text{mid, core}) / Asl, \text{mid} = 262.1446$   
 with  $Es_v = (Es_{\text{jacket}} * Asl, \text{mid, jacket} + Es_{\text{mid}} * Asl, \text{mid, core}) / Asl, \text{mid} = 200000.00$   
 $1 = Asl, \text{ten} / (b * d) * (fs_1 / f_c) = 0.06824101$   
 $2 = Asl, \text{com} / (b * d) * (fs_2 / f_c) = 0.03513975$   
 $v = Asl, \text{mid} / (b * d) * (fs_v / f_c) = 0.06202846$   
 and confined core properties:  
 $b = 340.00$   
 $d = 677.00$   
 $d' = 13.00$   
 $f_{cc} (5A.2, \text{TBDY}) = 38.13135$   
 $cc (5A.5, \text{TBDY}) = 0.00471045$   
 $c = \text{confinement factor} = 1.27105$   
 $1 = Asl, \text{ten} / (b * d) * (fs_1 / f_c) = 0.08384116$   
 $2 = Asl, \text{com} / (b * d) * (fs_2 / f_c) = 0.04317283$

$$v = A_{sl, mid} / (b \cdot d) \cdot (f_{sv} / f_c) = 0.07620839$$

Case/Assumption: Unconfined full section - Steel rupture

' satisfies Eq. (4.3)

--->

$v < v_{s,y2}$  - LHS eq.(4.5) is satisfied

--->

$$s_u(4.9) = 0.2584548$$

$$M_u = M_{Rc}(4.14) = 5.0296E+008$$

$$u = s_u(4.1) = 5.1201636E-006$$

Calculation of ratio  $l_b/l_d$

Lap Length:  $l_b/l_d = 0.13907892$

$$l_b = 300.00$$

$$l_d = 2157.049$$

Calculation of  $l_b, min$  according to (25.4.3.2), ACI 318-14, using mean values for all the section re-bars.

$l_d, min$  from (25.4.3.2) is multiplied 2 times to account for smooth re-bars (9.1.2, TS500 - No provision in ACI 318)

$$= 1$$

$$d_b = 16.66667$$

Mean strength value of all re-bars:  $f_y = 781.25$

Mean concrete strength:  $f'_c = (f'_c_{jacket} \cdot Area_{jacket} + f'_c_{core} \cdot Area_{core}) / Area_{section} = 30.00$ , but  $f_c^{0.5} \leq 8.3$

MPa (22.5.3.1, ACI 318-14)

$$t = 1.00$$

$$s = 0.80$$

$$e = 1.00$$

$$c_b = 25.00$$

$$K_{tr} = 1.7174$$

$$A_{tr} = \min(A_{tr_x}, A_{tr_y}) = 257.6106$$

where  $A_{tr_x}$ ,  $A_{tr_y}$  are the sum of the area of all stirrup legs along X and Y local axis

$$s = \max(s_{external}, s_{internal}) = 250.00$$

$$n = 24.00$$

Calculation of Shear Strength  $V_r = \min(V_{r1}, V_{r2}) = 1.0392E+006$

Calculation of Shear Strength at edge 1,  $V_{r1} = 1.0392E+006$

$$V_{r1} = V_{Col}((10.3), ASCE 41-17) = k_{nl} \cdot V_{Col0}$$

$$V_{Col0} = 1.0392E+006$$

$k_{nl} = 1$  (zero step-static loading)

NOTE: In expression (10-3) ' $V_s = A_v \cdot f_y \cdot d / s$ ' is replaced by ' $V_s + f \cdot V_f$ '

where  $V_f$  is the contribution of FRPs (11.3), ACI 440).

$$= 1 \text{ (normal-weight concrete)}$$

Mean concrete strength:  $f'_c = (f'_c_{jacket} \cdot Area_{jacket} + f'_c_{core} \cdot Area_{core}) / Area_{section} = 30.00$ , but  $f_c^{0.5} \leq 8.3$

MPa (22.5.3.1, ACI 318-14)

$$M/Vd = 4.00$$

$$M_u = 1308.675$$

$$V_u = 0.0001715$$

$$d = 0.8 \cdot h = 600.00$$

$$N_u = 16273.608$$

$$A_g = 300000.00$$

From (11.5.4.8), ACI 318-14:  $V_s = V_{sjacket} + V_{s,core} = 1.0138E+006$

where:

$$V_{sjacket} = V_{sj1} + V_{sj2} = 903207.888$$

$V_{sj1} = 314159.265$  is calculated for section web jacket, with:

$$d = 320.00$$

$$A_v = 157079.633$$

$$f_y = 625.00$$

$$s = 100.00$$

$V_{sj1}$  is multiplied by  $Col_{j1} = 1.00$

$$s/d = 0.3125$$

$V_{sj2} = 589048.623$  is calculated for section flange jacket, with:

$$d = 600.00$$

$A_v = 157079.633$   
 $f_y = 625.00$   
 $s = 100.00$   
 $V_{s,j2}$  is multiplied by  $Col,j2 = 1.00$   
 $s/d = 0.16666667$   
 $V_{s,core} = V_{s,c1} + V_{s,c2} = 110584.061$   
 $V_{s,c1} = 0.00$  is calculated for section web core, with:  
 $d = 160.00$   
 $A_v = 100530.965$   
 $f_y = 625.00$   
 $s = 250.00$   
 $V_{s,c1}$  is multiplied by  $Col,c1 = 0.00$   
 $s/d = 1.5625$   
 $V_{s,c2} = 110584.061$  is calculated for section flange core, with:  
 $d = 440.00$   
 $A_v = 100530.965$   
 $f_y = 625.00$   
 $s = 250.00$   
 $V_{s,c2}$  is multiplied by  $Col,c2 = 1.00$   
 $s/d = 0.56818182$   
 $V_f ((11-3)-(11.4), ACI 440) = 0.00$   
 From (11-11), ACI 440:  $V_s + V_f \leq 873250.061$   
 $bw = 400.00$

-----  
 Calculation of Shear Strength at edge 2,  $V_{r2} = 1.0392E+006$   
 $V_{r2} = V_{Col} ((10.3), ASCE 41-17) = knl * V_{Col0}$   
 $V_{Col0} = 1.0392E+006$   
 $knl = 1$  (zero step-static loading)

-----  
 NOTE: In expression (10-3) ' $V_s = A_v * f_y * d / s$ ' is replaced by ' $V_s + f * V_f$ '  
 where  $V_f$  is the contribution of FRPs (11.3), ACI 440).

-----  
 $= 1$  (normal-weight concrete)  
 Mean concrete strength:  $f_c' = (f_c'_{jacket} * Area_{jacket} + f_c'_{core} * Area_{core}) / Area_{section} = 30.00$ , but  $f_c'^{0.5} \leq 8.3$   
 MPa (22.5.3.1, ACI 318-14)  
 $M/Vd = 4.00$   
 $\mu_u = 1308.675$   
 $V_u = 0.0001715$   
 $d = 0.8 * h = 600.00$   
 $N_u = 16273.608$   
 $A_g = 300000.00$   
 From (11.5.4.8), ACI 318-14:  $V_s = V_{s,jacket} + V_{s,core} = 1.0138E+006$   
 where:  
 $V_{s,jacket} = V_{s,j1} + V_{s,j2} = 903207.888$   
 $V_{s,j1} = 314159.265$  is calculated for section web jacket, with:  
 $d = 320.00$   
 $A_v = 157079.633$   
 $f_y = 625.00$   
 $s = 100.00$   
 $V_{s,j1}$  is multiplied by  $Col,j1 = 1.00$   
 $s/d = 0.3125$   
 $V_{s,j2} = 589048.623$  is calculated for section flange jacket, with:  
 $d = 600.00$   
 $A_v = 157079.633$   
 $f_y = 625.00$   
 $s = 100.00$   
 $V_{s,j2}$  is multiplied by  $Col,j2 = 1.00$   
 $s/d = 0.16666667$   
 $V_{s,core} = V_{s,c1} + V_{s,c2} = 110584.061$   
 $V_{s,c1} = 0.00$  is calculated for section web core, with:  
 $d = 160.00$   
 $A_v = 100530.965$   
 $f_y = 625.00$   
 $s = 250.00$   
 $V_{s,c1}$  is multiplied by  $Col,c1 = 0.00$   
 $s/d = 1.5625$

$V_{s,c2} = 110584.061$  is calculated for section flange core, with:

$d = 440.00$

$A_v = 100530.965$

$f_y = 625.00$

$s = 250.00$

$V_{s,c2}$  is multiplied by  $Col,c2 = 1.00$

$s/d = 0.56818182$

$V_f ((11-3)-(11.4), ACI 440) = 0.00$

From (11-11), ACI 440:  $V_s + V_f \leq 873250.061$

$bw = 400.00$

End Of Calculation of Shear Capacity ratio for element: column JLC1 of floor 1

At local axis: 2

Start Of Calculation of Chord Rotation Capacity for element: column JLC1 of floor 1

At local axis: 2

Integration Section: (a)

Section Type: rcjlc

Constant Properties

Knowledge Factor,  $= 1.00$

Chord Rotation is generally considered as Deformation-Controlled Action according to Table C7-1, ASCE 41-17.

Mean strengths are used for Deformation-Controlled Actions according to 7.5.1.3, ASCE 41-17

Consequently:

Jacket

New material of Primary Member: Concrete Strength,  $f_c = f_{cm} = 30.00$

New material of Primary Member: Steel Strength,  $f_s = f_{sm} = 625.00$

Concrete Elasticity,  $E_c = 25742.96$

Steel Elasticity,  $E_s = 200000.00$

Existing Column

New material of Primary Member: Concrete Strength,  $f_c = f_{cm} = 30.00$

New material of Primary Member: Steel Strength,  $f_s = f_{sm} = 625.00$

Concrete Elasticity,  $E_c = 25742.96$

Steel Elasticity,  $E_s = 200000.00$

Max Height,  $H_{max} = 750.00$

Min Height,  $H_{min} = 400.00$

Max Width,  $W_{max} = 750.00$

Min Width,  $W_{min} = 400.00$

Jacket Thickness,  $t_j = 100.00$

Cover Thickness,  $c = 25.00$

Element Length,  $L = 3000.00$

Primary Member

Smooth Bars

Ductile Steel

With Detailing for Earthquake Resistance (including stirrups closed at  $135^\circ$ )

Longitudinal Bars With Ends Lapped Starting at the End Sections

Lap Length  $l_b = 300.00$

No FRP Wrapping

Stepwise Properties

Bending Moment,  $M = -293351.828$

Shear Force,  $V_2 = -4846.489$

Shear Force,  $V_3 = 135.9404$

Axial Force,  $F = -17232.621$

Longitudinal Reinforcement Area Distribution (in 2 divisions)

-Tension:  $As_t = 0.00$

-Compression:  $As_c = 5353.274$

Longitudinal Reinforcement Area Distribution (in 3 divisions)

-Tension:  $As_{l,ten} = 1137.257$

-Compression:  $As_{l,com} = 2208.54$

-Middle:  $Asl_{mid} = 2007.478$   
 Longitudinal External Reinforcement Area Distribution (in 3 divisions)  
 -Tension:  $Asl_{ten,jacket} = 829.3805$   
 -Compression:  $Asl_{com,jacket} = 1746.726$   
 -Middle:  $Asl_{mid,jacket} = 1545.664$   
 Longitudinal Internal Reinforcement Area Distribution (in 3 divisions)  
 -Tension:  $Asl_{ten,core} = 307.8761$   
 -Compression:  $Asl_{com,core} = 461.8141$   
 -Middle:  $Asl_{mid,core} = 461.8141$   
 Mean Diameter of Tension Reinforcement,  $DbL = 16.80$

New component: From table 7-7, ASCE 41\_17: Final chord rotation Capacity  $u_R = 1.0$   $u = 0.00141756$   
 $u = y + p = 0.00141756$

- Calculation of  $y$  -

$y = (M_y * L_s / 3) / E_{eff} = 0.00141756$  ((4.29), Biskinis Phd))  
 $M_y = 2.8693E+008$   
 $L_s = M/V$  (with  $L_s > 0.1 * L$  and  $L_s < 2 * L$ ) = 2157.945  
 From table 10.5, ASCE 41\_17:  $E_{eff} = factor * E_c * I_g = 1.4560E+014$   
 $factor = 0.30$   
 $A_g = 440000.00$   
 Mean concrete strength:  $fc' = (fc'_{jacket} * Area_{jacket} + fc'_{core} * Area_{core}) / Area_{section} = 30.00$   
 $N = 17232.621$   
 $E_c * I_g = E_{c,jacket} * I_{g,jacket} + E_{c,core} * I_{g,core} = 4.8532E+014$

Calculation of Yielding Moment  $M_y$

Calculation of  $y$  and  $M_y$  according to Annex 7 -

Assuming neutral axis within flange ( $y < t/d$ , compression zone rectangular) with:  
 flange width,  $b = 750.00$   
 web width,  $b_w = 400.00$   
 flange thickness,  $t = 400.00$

$y = \min(y_{ten}, y_{com})$   
 $y_{ten} = 2.1452649E-006$   
 with ((10.1), ASCE 41-17)  $f_y = \min(f_y, 1.25 * f_y * (l_b / l_d)^{2/3}) = 243.3535$   
 $d = 707.00$   
 $y = 0.1977546$   
 $A = 0.0102293$   
 $B = 0.00453971$   
 with  $p_t = 0.00434791$   
 $p_c = 0.00416509$   
 $p_v = 0.00378591$   
 $N = 17232.621$   
 $b = 750.00$   
 $" = 0.06082037$   
 $y_{comp} = 1.5203329E-005$   
 with  $fc = 30.00$   
 $E_c = 25742.96$   
 $y = 0.19515388$   
 $A = 0.01001829$   
 $B = 0.00440616$   
 with  $E_s = 200000.00$   
 CONFIRMATION:  $y = 0.19591085 < t/d$

Calculation of ratio  $l_b / l_d$



Lap Length:  $l_d/l_{d,min} = 0.17384865$   
 $l_b = 300.00$   
 $l_d = 1725.639$   
 Calculation of  $l$  according to (25.4.3.2), ACI 318-14, using mean values for all the section re-bars.  
 $l_{d,min}$  from (25.4.3.2) is multiplied 2 times to account for smooth re-bars (10.3.5, ASCE 41-17)  
 $= 1$   
 $db = 16.66667$   
 Mean strength value of all re-bars:  $f_y = 625.00$   
 Mean concrete strength:  $f'_c = (f'_{c,jacket} \cdot Area_{jacket} + f'_{c,core} \cdot Area_{core}) / Area_{section} = 30.00$ , but  $f'_c^{0.5} \leq 8.3$   
 MPa (22.5.3.1, ACI 318-14)  
 $t = 1.00$   
 $s = 0.80$   
 $e = 1.00$   
 $cb = 25.00$   
 $K_{tr} = 1.7174$   
 $A_{tr} = \text{Min}(A_{tr,x}, A_{tr,y}) = 257.6106$   
 where  $A_{tr,x}$ ,  $A_{tr,y}$  are the sum of the area of all stirrup legs along X and Y local axis  
 $s = \text{Max}(s_{external}, s_{internal}) = 250.00$   
 $n = 24.00$

#### - Calculation of $p$ -

From table 10-8:  $p = 0.00$

with:

- Columns controlled by inadequate development or splicing along the clear height because  $l_b/l_d < 1$

shear control ratio  $V_y E / V_{col} E = 0.32266369$

$d = d_{external} = 707.00$

$s = s_{external} = 0.00$

-  $t = s_1 + s_2 + 2 \cdot t_f / b_w \cdot (f_{fe} / f_s) = 0.00434791$

jacket:  $s_1 = A_{v1} \cdot L_{stir1} / (s_1 \cdot A_g) = 0.00367709$

$A_{v1} = 78.53982$ , is the area of every stirrup parallel to loading (shear) direction

$L_{stir1} = 2060.00$ , is the total Length of all stirrups parallel to loading (shear) direction

$s_1 = 100.00$

core:  $s_2 = A_{v2} \cdot L_{stir2} / (s_2 \cdot A_g) = 0.00067082$

$A_{v2} = 50.26548$ , is the area of every stirrup parallel to loading (shear) direction

$L_{stir2} = 1468.00$ , is the total Length of all stirrups parallel to loading (shear) direction

$s_2 = 250.00$

The term  $2 \cdot t_f / b_w \cdot (f_{fe} / f_s)$  is implemented to account for FRP contribution

where  $f = 2 \cdot t_f / b_w$  is FRP ratio (EC8 - 3, A.4.4.3(6)) and  $f_{fe} / f_s$  normalises  $f$  to steel strength

All these variables have already been given in Shear control ratio calculation.

For the normalisation  $f_s$  of jacket is used.

$NUD = 17232.621$

$A_g = 440000.00$

$f_{cE} = (f_{c,jacket} \cdot Area_{jacket} + f_{c,core} \cdot Area_{core}) / section\_area = 30.00$

$f_{yE} = (f_{y,ext\_Long\_Reinf} \cdot Area_{ext\_Long\_Reinf} + f_{y,int\_Long\_Reinf} \cdot Area_{int\_Long\_Reinf}) / Area_{Tot\_Long\_Rein} = 625.00$

$f_{yE} = (f_{y,ext\_Trans\_Reinf} \cdot s_1 + f_{y,int\_Trans\_Reinf} \cdot s_2) / (s_1 + s_2) = 625.00$

$p_l = Area_{Tot\_Long\_Rein} / (b \cdot d) = 0.01009575$

$b = 750.00$

$d = 707.00$

$f_{cE} = 30.00$

End Of Calculation of Chord Rotation Capacity for element: column JLC1 of floor 1

At local axis: 2

Integration Section: (a)

### Calculation No. 3

column C1, Floor 1



Limit State: Operational Level (data interpolation between analysis steps 1 and 2)

Analysis: Uniform +X

Check: Shear capacity VRd

Edge: Start

Local Axis: (3)



Start Of Calculation of Shear Capacity for element: column JLC1 of floor 1

At local axis: 3

Integration Section: (a)

Section Type: rcjls

Constant Properties

Knowledge Factor,  $\gamma = 1.00$

Member Shear Force is generally considered as Force-Controlled Action according to Table C7-1, ASCE 41-17.

Lower-bound strengths are used for Force-Controlled Actions according to 7.5.1.3, ASCE 41-17

Consequently:

Jacket

New material of Primary Member: Concrete Strength,  $f_c = f_{c\_lower\_bound} = 20.00$

New material of Primary Member: Steel Strength,  $f_s = f_{s\_lower\_bound} = 500.00$

Concrete Elasticity,  $E_c = 25742.96$

Steel Elasticity,  $E_s = 200000.00$

Existing Column

New material of Primary Member: Concrete Strength,  $f_c = f_{c\_lower\_bound} = 20.00$

New material of Primary Member: Steel Strength,  $f_s = f_{s\_lower\_bound} = 500.00$

Concrete Elasticity,  $E_c = 25742.96$

Steel Elasticity,  $E_s = 200000.00$

#####

Note: Especially for the calculation of  $\gamma$  for displacement ductility demand, the expected (mean value) strengths are used (7.5.1.3, ASCE 41-17) because bending is considered as Deformation-Controlled Action (Table C7-1, ASCE 41-17).

Jacket

New material: Concrete Strength,  $f_c = f_{cm} = 30.00$

New material: Steel Strength,  $f_s = f_{sm} = 625.00$

Existing Column

New material: Concrete Strength,  $f_c = f_{cm} = 30.00$

New material: Steel Strength,  $f_s = f_{sm} = 625.00$

#####

Max Height, Hmax = 750.00  
 Min Height, Hmin = 400.00  
 Max Width, Wmax = 750.00  
 Min Width, Wmin = 400.00  
 Jacket Thickness, tj = 100.00  
 Cover Thickness, c = 25.00  
 Element Length, L = 3000.00  
 Primary Member  
 Smooth Bars  
 Ductile Steel  
 With Detailing for Earthquake Resistance (including stirrups closed at 135°)  
 Longitudinal Bars With Ends Lapped Starting at the End Sections  
 Lap Length lo = lb = 300.00  
 No FRP Wrapping

#### Stepwise Properties

EDGE -A-  
 Bending Moment, Ma = -293351.828  
 Shear Force, Va = 135.9404  
 EDGE -B-  
 Bending Moment, Mb = -112991.609  
 Shear Force, Vb = -135.9404  
 BOTH EDGES  
 Axial Force, F = -17232.621  
 Longitudinal Reinforcement Area Distribution (in 2 divisions)  
   -Tension: Aslt = 0.00  
   -Compression: Aslc = 5353.274  
 Longitudinal Reinforcement Area Distribution (in 3 divisions)  
   -Tension: Asl,ten = 1137.257  
   -Compression: Asl,com = 2208.54  
   -Middle: Asl,mid = 2007.478  
 Mean Diameter of Tension Reinforcement, DbL,ten = 16.80

New component: From table 7-7, ASCE 41\_17: Final Shear Capacity VR = 1.0\*Vn = 864123.256  
 Vn ((10.3), ASCE 41-17) = knl\*VColO = 864123.256  
 VCol = 864123.256  
 knl = 1.00  
 displacement\_ductility\_demand = 0.01498415

NOTE: In expression (10-3) 'Vs = Av\*fy\*d/s' is replaced by 'Vs+ f\*Vf'  
 where Vf is the contribution of FRPs (11.3), ACI 440).

= 1 (normal-weight concrete)  
 Mean concrete strength: fc' = (fc'\_jacket\*Area\_jacket + fc'\_core\*Area\_core)/Area\_section = 20.00, but  $fc'^{0.5} \leq 8.3$   
 MPa (22.5.3.1, ACI 318-14)  
 M/Vd = 3.59657  
 Mu = 293351.828  
 Vu = 135.9404  
 d = 0.8\*h = 600.00  
 Nu = 17232.621  
 Ag = 300000.00  
 From (11.5.4.8), ACI 318-14: Vs = Vs,jacket + Vs,core = 811033.559  
 where:  
 Vs,jacket = Vs,j1 + Vs,j2 = 722566.31  
 Vs,j1 = 471238.898 is calculated for section web jacket, with:  
   d = 600.00  
   Av = 157079.633  
   fy = 500.00  
   s = 100.00  
 Vs,j1 is multiplied by Col,j1 = 1.00  
   s/d = 0.16666667  
 Vs,j2 = 251327.412 is calculated for section flange jacket, with:

$d = 320.00$   
 $A_v = 157079.633$   
 $f_y = 500.00$   
 $s = 100.00$   
 $V_{s,j2}$  is multiplied by  $Col,j2 = 1.00$   
 $s/d = 0.3125$   
 $V_{s,core} = V_{s,c1} + V_{s,c2} = 88467.249$   
 $V_{s,c1} = 88467.249$  is calculated for section web core, with:  
 $d = 440.00$   
 $A_v = 100530.965$   
 $f_y = 500.00$   
 $s = 250.00$   
 $V_{s,c1}$  is multiplied by  $Col,c1 = 1.00$   
 $s/d = 0.56818182$   
 $V_{s,c2} = 0.00$  is calculated for section flange core, with:  
 $d = 160.00$   
 $A_v = 100530.965$   
 $f_y = 500.00$   
 $s = 250.00$   
 $V_{s,c2}$  is multiplied by  $Col,c2 = 0.00$   
 $s/d = 1.5625$   
 $V_f ((11-3)-(11.4), ACI 440) = 0.00$   
 From (11-11), ACI 440:  $V_s + V_f \leq 713005.69$   
 $bw = 400.00$

displacement ductility demand is calculated as  $\delta / y$

- Calculation of  $\delta / y$  for END A -  
for rotation axis 2 and integ. section (a)

From analysis, chord rotation  $\theta = 2.1240994E-005$   
 $y = (M_y * L_s / 3) / E_{eff} = 0.00141756 ((4.29), Biskinis Phd)$   
 $M_y = 2.8693E+008$   
 $L_s = M/V$  (with  $L_s > 0.1 * L$  and  $L_s < 2 * L$ ) = 2157.945  
 From table 10.5, ASCE 41\_17:  $E_{eff} = factor * E_c * I_g = 1.4560E+014$   
 $factor = 0.30$   
 $A_g = 440000.00$   
 Mean concrete strength:  $f'_c = (f'_{c,jacket} * Area_{jacket} + f'_{c,core} * Area_{core}) / Area_{section} = 30.00$   
 $N = 17232.621$   
 $E_c * I_g = E_{c,jacket} * I_{g,jacket} + E_{c,core} * I_{g,core} = 4.8532E+014$

Calculation of Yielding Moment  $M_y$

Calculation of  $\delta$  and  $M_y$  according to Annex 7 -

Assuming neutral axis within flange ( $y < t/d$ , compression zone rectangular) with:  
 flange width,  $b = 750.00$   
 web width,  $bw = 400.00$   
 flange thickness,  $t = 400.00$

$y = \text{Min}(y_{ten}, y_{com})$   
 $y_{ten} = 2.1452649E-006$   
 with ((10.1), ASCE 41-17)  $f_y = \text{Min}(f_y, 1.25 * f_y * (I_b/d)^{2/3}) = 243.3535$   
 $d = 707.00$   
 $y = 0.1977546$   
 $A = 0.0102293$   
 $B = 0.00453971$   
 with  $pt = 0.00214476$   
 $pc = 0.00416509$   
 $pv = 0.00378591$   
 $N = 17232.621$   
 $b = 750.00$   
 $\rho = 0.06082037$

y\_comp = 1.5203329E-005

with fc = 30.00

Ec = 25742.96

y = 0.19515388

A = 0.01001829

B = 0.00440616

with Es = 200000.00

CONFIRMATION: y = 0.19591085 < t/d

Calculation of ratio lb/l<sub>d</sub>

Lap Length: l<sub>d</sub>/l<sub>d,min</sub> = 0.17384865

lb = 300.00

l<sub>d</sub> = 1725.639

Calculation of l according to (25.4.3.2), ACI 318-14, using mean values for all the section re-bars.

l<sub>d,min</sub> from (25.4.3.2) is multiplied 2 times to account for smooth re-bars (10.3.5, ASCE 41-17)

= 1

db = 16.66667

Mean strength value of all re-bars: f<sub>y</sub> = 625.00

Mean concrete strength: f<sub>c'</sub> = (f<sub>c'</sub><sub>jacket</sub>\*Area<sub>jacket</sub> + f<sub>c'</sub><sub>core</sub>\*Area<sub>core</sub>)/Area<sub>section</sub> = 30.00, but f<sub>c'</sub><sup>0.5</sup> ≤ 8.3 MPa (22.5.3.1, ACI 318-14)

t = 1.00

s = 0.80

e = 1.00

cb = 25.00

K<sub>tr</sub> = 1.7174

A<sub>tr</sub> = Min(A<sub>tr,x</sub>, A<sub>tr,y</sub>) = 257.6106

where A<sub>tr,x</sub>, A<sub>tr,y</sub> are the sum of the area of all stirrup legs along X and Y local axis

s = Max(s<sub>external</sub>, s<sub>internal</sub>) = 250.00

n = 24.00

End Of Calculation of Shear Capacity for element: column JLC1 of floor 1

At local axis: 3

Integration Section: (a)

## Calculation No. 4

column C1, Floor 1



Limit State: Operational Level (data interpolation between analysis steps 1 and 2)

Analysis: Uniform +X

Check: Chord rotation capacity ( u )

Edge: Start

Local Axis: (3)



Start Of Calculation of Shear Capacity ratio for element: column JLC1 of floor 1

At Shear local axis: 3

(Bending local axis: 2)

Section Type: rcjlcs

Constant Properties

Knowledge Factor,  $\gamma = 1.00$

Mean strength values are used for both shear and moment calculations.

Consequently:

Jacket

New material of Primary Member: Concrete Strength,  $f_c = f_{cm} = 30.00$

New material of Primary Member: Steel Strength,  $f_s = f_{sm} = 625.00$

Concrete Elasticity,  $E_c = 25742.96$

Steel Elasticity,  $E_s = 200000.00$

Existing Column

New material of Primary Member: Concrete Strength,  $f_c = f_{cm} = 30.00$

New material of Primary Member: Steel Strength,  $f_s = f_{sm} = 625.00$

Concrete Elasticity,  $E_c = 25742.96$

Steel Elasticity,  $E_s = 200000.00$

#####

Note: Especially for the calculation of moment strengths,

the above steel re-bar strengths are multiplied by 1.25 according to R18.6.5, ACI 318-14

Jacket

New material: Steel Strength,  $f_s = 1.25 \cdot f_{sm} = 781.25$

Existing Column

New material: Steel Strength,  $f_s = 1.25 \cdot f_{sm} = 781.25$

#####

Max Height,  $H_{max} = 750.00$

Min Height,  $H_{min} = 400.00$

Max Width,  $W_{max} = 750.00$

Min Width,  $W_{min} = 400.00$

Jacket Thickness,  $t_j = 100.00$

Cover Thickness,  $c = 25.00$

Mean Confinement Factor overall section = 1.27105

Element Length,  $L = 3000.00$

Primary Member

Smooth Bars

Ductile Steel

With Detailing for Earthquake Resistance (including stirrups closed at  $135^\circ$ )

Longitudinal Bars With Ends Lapped Starting at the End Sections

Lap Length  $l_o = 300.00$

No FRP Wrapping

Stepwise Properties

At local axis: 3

EDGE -A-

Shear Force,  $V_a = -0.00017144$

EDGE -B-

Shear Force,  $V_b = 0.00017144$

## BOTH EDGES

Axial Force,  $F = -16273.608$

Longitudinal Reinforcement Area Distribution (in 2 divisions)

-Tension:  $As_t = 0.00$

-Compression:  $As_c = 5353.274$

Longitudinal Reinforcement Area Distribution (in 3 divisions)

-Tension:  $As_{t,ten} = 1137.257$

-Compression:  $As_{c,com} = 2208.54$

-Middle:  $As_{c,mid} = 2007.478$

Calculation of Shear Capacity ratio,  $V_e/V_r = 0.32266369$

Member Controlled by Flexure ( $V_e/V_r < 1$ )

Calculation of Shear Demand from fig. R18.6.5, ACI 318-14  $V_e = (M_{pr1} + M_{pr2})/l_n = 335307.657$

with

$M_{pr1} = \text{Max}(Mu_{1+}, Mu_{1-}) = 5.0296E+008$

$Mu_{1+} = 2.3387E+008$ , is the ultimate moment strength at the edge 1 of the member in the actual moment direction which is defined for the static loading combination

$Mu_{1-} = 5.0296E+008$ , is the ultimate moment strength at the edge 1 of the member in the opposite moment direction which is defined for the static loading combination

$M_{pr2} = \text{Max}(Mu_{2+}, Mu_{2-}) = 5.0296E+008$

$Mu_{2+} = 2.3387E+008$ , is the ultimate moment strength at the edge 2 of the member in the actual moment direction which is defined for the static loading combination

$Mu_{2-} = 5.0296E+008$ , is the ultimate moment strength at the edge 2 of the member in the opposite moment direction which is defined for the static loading combination

Calculation of  $Mu_{1+}$

Calculation of ultimate curvature  $\phi_u$  according to 4.1, Biskinis/Fardis 2013:

$\phi_u = 4.8099118E-006$

$M_u = 2.3387E+008$

with full section properties:

$b = 750.00$

$d = 707.00$

$d' = 43.00$

$v = 0.00102301$

$N = 16273.608$

$f_c = 30.00$

$\phi_c$  (5A.5, TBDY) = 0.002

Final value of  $\phi_u$ :  $\phi_u^* = \text{shear\_factor} * \text{Max}(\phi_u, \phi_c) = 0.01260361$

The Shear\_factor is considered equal to 1 (pure moment strength)

From (5.4b), TBDY:  $\phi_u = 0.01260361$

we (5.4c) = 0.05179731

$ase$  ((5.4d), TBDY) =  $(ase1 * A_{ext} + ase2 * A_{int}) / A_{sec} = 0.45746528$

$ase1 = \text{Max}(((A_{conf,max1} - A_{noConf1}) / A_{conf,max1}) * (A_{conf,min1} / A_{conf,max1}), 0) = 0.45746528$

The definitions of  $A_{noConf}$ ,  $A_{conf,min}$  and  $A_{conf,max}$  are derived from generalization of the rectangular sections confinement, which is expressed by (5.4d).

The generalization is done according to Mander, J., Priestley, M., and Park, R. (1988)

"Theoretical Stress-Strain Model for Confined Concrete."

J. Struct. Eng., 10.1061/(ASCE)0733-9445(1988)114:8(1804), 1804-1826.

$A_{conf,max1} = 353600.00$  is the confined core area at levels of member with hoops and is calculated as the area of core enclosed by the center lines of the external perimeter hoops.

$A_{conf,min1} = 293525.00$  is the confined core area at midway between the levels of hoops and is calculated by reducing all the dimensions of the area  $A_{conf,max1}$  by a length equal to half the clear spacing between external hoops.

$A_{noConf1} = 158733.333$  is the unconfined external core area which is equal to  $b_i^2/6$  as defined at (A.2).

$ase2$  ( $\geq ase1$ ) =  $\text{Max}(((A_{conf,max2} - A_{noConf2}) / A_{conf,max2}) * (A_{conf,min2} / A_{conf,max2}), 0) = 0.45746528$

The definitions of  $A_{noConf}$ ,  $A_{conf,min}$  and  $A_{conf,max}$  are derived from generalization of the rectangular sections confinement, which is expressed by (5.4d).

The generalization is done according to Mander, J., Priestley, M., and Park, R. (1988)

"Theoretical Stress-Strain Model for Confined Concrete."

J. Struct. Eng., 10.1061/(ASCE)0733-9445(1988)114:8(1804), 1804-1826.

Aconf,max2 = 171264.00 is the confined core area at levels of member with hoops and is calculated as the area of core enclosed by the center lines of the internal perimeter hoops.

Aconf,min2 = 54741.00 is the confined core area at midway between the levels of hoops and is calculated by reducing all the dimensions of the area Aconf,max2 by a length equal to half the clear spacing between internal hoops.

AnoConf2 = 106242.667 is the unconfined internal core area which is equal to  $b_i^2/6$  as defined at (A.2).  
 $psh,min*Fywe = \text{Min}(psh,x*Fywe, psh,y*Fywe) = 3.3968$

$psh_x*Fywe = psh1*Fywe1 + ps2*Fywe2 = 3.3968$   
 $psh1 ((5.4d), TBDY) = Lstir1*Astir1/(Asec*s1) = 0.00367709$   
Lstir1 (Length of stirrups along Y) = 2060.00  
Astir1 (stirrups area) = 78.53982  
 $psh2 ((5.4d) = Lstir2*Astir2/(Asec*s2) = 0.00067082$   
Lstir2 (Length of stirrups along Y) = 1468.00  
Astir2 (stirrups area) = 50.26548

$psh_y*Fywe = psh1*Fywe1 + ps2*Fywe2 = 3.3968$   
 $psh1 ((5.4d), TBDY) = Lstir1*Astir1/(Asec*s1) = 0.00367709$   
Lstir1 (Length of stirrups along X) = 2060.00  
Astir1 (stirrups area) = 78.53982  
 $psh2 ((5.4d), TBDY) = Lstir2*Astir2/(Asec*s2) = 0.00067082$   
Lstir2 (Length of stirrups along X) = 1468.00  
Astir2 (stirrups area) = 50.26548

Asec = 440000.00

s1 = 100.00

s2 = 250.00

fywe1 = 781.25

fywe2 = 781.25

fce = 30.00

From ((5.A5), TBDY), TBDY: cc = 0.00471045

c = confinement factor = 1.27105

y1 = 0.00083886

sh1 = 0.00268436

ft1 = 314.5735

fy1 = 262.1446

su1 = 0.00268436

using (30) in Biskinis/Fardis (2013) multiplied with shear\_factor and also multiplied by the shear\_factor according to 15.7.1.4, with Shear\_factor = 1.00

lo/lou,min = lb/lb = 0.13907892

su1 = 0.4\*esu1\_nominal ((5.5), TBDY) = 0.032

From table 5A.1, TBDY: esu1\_nominal = 0.08,

For calculation of esu1\_nominal and y1, sh1,ft1,fy1, it is considered characteristic value fsy1 = fs1/1.2, from table 5.1, TBDY.

y1, sh1,ft1,fy1, are also multiplied by  $\text{Min}(1, 1.25*(lb/lb)^{2/3})$ , from 10.3.5, ASCE 41-17.

with fs1 = (fs,jacket\*Asl,ten,jacket + fs,core\*Asl,ten,core)/Asl,ten = 262.1446

with Es1 = (Es,jacket\*Asl,ten,jacket + Es,core\*Asl,ten,core)/Asl,ten = 200000.00

y2 = 0.00083886

sh2 = 0.00268436

ft2 = 314.5735

fy2 = 262.1446

su2 = 0.00268436

using (30) in Biskinis/Fardis (2013) multiplied with shear\_factor and also multiplied by the shear\_factor according to 15.7.1.4, with Shear\_factor = 1.00

lo/lou,min = lb/lb,min = 0.13907892

su2 = 0.4\*esu2\_nominal ((5.5), TBDY) = 0.032

From table 5A.1, TBDY: esu2\_nominal = 0.08,

For calculation of esu2\_nominal and y2, sh2,ft2,fy2, it is considered characteristic value fsy2 = fs2/1.2, from table 5.1, TBDY.

y1, sh1,ft1,fy1, are also multiplied by  $\text{Min}(1, 1.25*(lb/lb)^{2/3})$ , from 10.3.5, ASCE 41-17.

with fs2 = (fs,jacket\*Asl,com,jacket + fs,core\*Asl,com,core)/Asl,com = 262.1446

with Es2 = (Es,jacket\*Asl,com,jacket + Es,core\*Asl,com,core)/Asl,com = 200000.00

yv = 0.00083886

shv = 0.00268436



```

ftv = 314.5735
fyv = 262.1446
suv = 0.00268436
    using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
    and also multiplied by the shear_factor according to 15.7.1.4, with
    Shear_factor = 1.00
    lo/lo,min = lb/ld = 0.13907892
    suv = 0.4*esuv_nominal ((5.5), TBDY) = 0.032
    From table 5A.1, TBDY: esuv_nominal = 0.08,
    considering characteristic value fsyv = fsv/1.2, from table 5.1, TBDY
    For calculation of esuv_nominal and yv, shv,ftv,fyv, it is considered
    characteristic value fsyv = fsv/1.2, from table 5.1, TBDY.
    y1, sh1,ft1,fy1, are also multiplied by Min(1,1.25*(lb/ld)^2/3), from 10.3.5, ASCE 41-17.
    with fsv = (fsjacket*Asl,mid,jacket + fs,mid*Asl,mid,core)/Asl,mid = 262.1446
    with Esv = (Es,jacket*Asl,mid,jacket + Es,mid*Asl,mid,core)/Asl,mid = 200000.00
    1 = Asl,ten/(b*d)*(fs1/fc) = 0.0187412
    2 = Asl,com/(b*d)*(fs2/fc) = 0.03639521
    v = Asl,mid/(b*d)*(fsv/fc) = 0.03308184
and confined core properties:
b = 690.00
d = 677.00
d' = 13.00
fcc (5A.2, TBDY) = 38.13135
cc (5A.5, TBDY) = 0.00471045
    c = confinement factor = 1.27105
    1 = Asl,ten/(b*d)*(fs1/fc) = 0.02127357
    2 = Asl,com/(b*d)*(fs2/fc) = 0.04131304
    v = Asl,mid/(b*d)*(fsv/fc) = 0.03755196
Case/Assumption: Unconfined full section - Steel rupture
' satisfies Eq. (4.3)
--->
v < vs,y2 - LHS eq.(4.5) is satisfied
--->
su (4.9) = 0.21062322
Mu = MRc (4.14) = 2.3387E+008
u = su (4.1) = 4.8099118E-006
-----

Calculation of ratio lb/ld
-----
Lap Length: lb/ld = 0.13907892
lb = 300.00
ld = 2157.049
Calculation of lb,min according to (25.4.3.2), ACI 318-14, using mean values for all the section re-bars.
ld,min from (25.4.3.2) is multiplied 2 times to account for smooth re-bars (9.1.2, TS500 - No provision in ACI 318)
= 1
db = 16.66667
Mean strength value of all re-bars: fy = 781.25
Mean concrete strength: fc' = (fc'_jacket*Area_jacket + fc'_core*Area_core)/Area_section = 30.00, but fc'^0.5 <= 8.3
MPa (22.5.3.1, ACI 318-14)
t = 1.00
s = 0.80
e = 1.00
cb = 25.00
Ktr = 1.7174
Atr = Min(Atr_x,Atr_y) = 257.6106
where Atr_x, Atr_y are the sum of the area of all stirrup legs along X and Y loxal axis
s = Max(s_external,s_internal) = 250.00
n = 24.00
-----
-----
-----
Calculation of Mu1-
-----
-----
-----
Calculation of ultimate curvature u according to 4.1, Biskinis/Fardis 2013:

```

u = 5.1201636E-006  
Mu = 5.0296E+008

with full section properties:

b = 400.00  
d = 707.00  
d' = 43.00  
v = 0.00191815  
N = 16273.608  
fc = 30.00  
co (5A.5, TBDY) = 0.002

Final value of cu:  $cu^* = \text{shear\_factor} * \text{Max}(cu, cc) = 0.01260361$

The Shear\_factor is considered equal to 1 (pure moment strength)

From (5.4b), TBDY:  $cu = 0.01260361$

we (5.4c) = 0.05179731

ase ((5.4d), TBDY) =  $(ase1 * A_{ext} + ase2 * A_{int}) / A_{sec} = 0.45746528$

$ase1 = \text{Max}(((A_{conf,max1} - A_{noConf1}) / A_{conf,max1}) * (A_{conf,min1} / A_{conf,max1}), 0) = 0.45746528$

The definitions of  $A_{noConf}$ ,  $A_{conf,min}$  and  $A_{conf,max}$  are derived from generalization of the rectangular sections confinement, which is expressed by (5.4d).

The generalization is done according to Mander, J., Priestley, M., and Park, R. (1988)

"Theoretical Stress-Strain Model for Confined Concrete."

J. Struct. Eng., 10.1061/(ASCE)0733-9445(1988)114:8(1804), 1804-1826.

$A_{conf,max1} = 353600.00$  is the confined core area at levels of member with hoops and

is calculated as the area of core enclosed by the center lines of the external perimeter hoops.

$A_{conf,min1} = 293525.00$  is the confined core area at midway between the levels of hoops and

is calculated by reducing all the dimensions of the area  $A_{conf,max1}$  by a length equal to half the clear spacing between external hoops.

$A_{noConf1} = 158733.333$  is the unconfined external core area which is equal to  $b_i d_i / 6$  as defined at (A.2).

$ase2 (>= ase1) = \text{Max}(((A_{conf,max2} - A_{noConf2}) / A_{conf,max2}) * (A_{conf,min2} / A_{conf,max2}), 0) = 0.45746528$

The definitions of  $A_{noConf}$ ,  $A_{conf,min}$  and  $A_{conf,max}$  are derived from generalization of the rectangular sections confinement, which is expressed by (5.4d).

The generalization is done according to Mander, J., Priestley, M., and Park, R. (1988)

"Theoretical Stress-Strain Model for Confined Concrete."

J. Struct. Eng., 10.1061/(ASCE)0733-9445(1988)114:8(1804), 1804-1826.

$A_{conf,max2} = 171264.00$  is the confined core area at levels of member with hoops and

is calculated as the area of core enclosed by the center lines of the internal perimeter hoops.

$A_{conf,min2} = 54741.00$  is the confined core area at midway between the levels of hoops and

is calculated by reducing all the dimensions of the area  $A_{conf,max2}$  by a length equal to half the clear spacing between internal hoops.

$A_{noConf2} = 106242.667$  is the unconfined internal core area which is equal to  $b_i d_i / 6$  as defined at (A.2).

$psh_{min} * F_{ywe} = \text{Min}(psh_x * F_{ywe}, psh_y * F_{ywe}) = 3.3968$

$psh_x * F_{ywe} = psh1 * F_{ywe1} + ps2 * F_{ywe2} = 3.3968$

$psh1 ((5.4d), TBDY) = L_{stir1} * A_{stir1} / (A_{sec} * s1) = 0.00367709$

$L_{stir1}$  (Length of stirrups along Y) = 2060.00

$A_{stir1}$  (stirrups area) = 78.53982

$psh2 (5.4d) = L_{stir2} * A_{stir2} / (A_{sec} * s2) = 0.00067082$

$L_{stir2}$  (Length of stirrups along Y) = 1468.00

$A_{stir2}$  (stirrups area) = 50.26548

$psh_y * F_{ywe} = psh1 * F_{ywe1} + ps2 * F_{ywe2} = 3.3968$

$psh1 ((5.4d), TBDY) = L_{stir1} * A_{stir1} / (A_{sec} * s1) = 0.00367709$

$L_{stir1}$  (Length of stirrups along X) = 2060.00

$A_{stir1}$  (stirrups area) = 78.53982

$psh2 ((5.4d), TBDY) = L_{stir2} * A_{stir2} / (A_{sec} * s2) = 0.00067082$

$L_{stir2}$  (Length of stirrups along X) = 1468.00

$A_{stir2}$  (stirrups area) = 50.26548

$A_{sec} = 440000.00$

$s1 = 100.00$

$s2 = 250.00$

$f_{ywe1} = 781.25$

$f_{ywe2} = 781.25$

$f_{ce} = 30.00$

From ((5.A5), TBDY):  $cc = 0.00471045$

c = confinement factor = 1.27105

$y1 = 0.00083886$

```

sh1 = 0.00268436
ft1 = 314.5735
fy1 = 262.1446
su1 = 0.00268436
    using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
    and also multiplied by the shear_factor according to 15.7.1.4, with
    Shear_factor = 1.00
    lo/lou,min = lb/ld = 0.13907892
    su1 = 0.4*esu1_nominal ((5.5), TBDY) = 0.032
    From table 5A.1, TBDY: esu1_nominal = 0.08,
    For calculation of esu1_nominal and y1, sh1,ft1,fy1, it is considered
    characteristic value fsy1 = fs1/1.2, from table 5.1, TBDY.
    y1, sh1,ft1,fy1, are also multiplied by Min(1,1.25*(lb/ld)^ 2/3), from 10.3.5, ASCE 41-17.
    with fs1 = (fs,jacket*Asl,ten,jacket + fs,core*Asl,ten,core)/Asl,ten = 262.1446
    with Es1 = (Es,jacket*Asl,ten,jacket + Es,core*Asl,ten,core)/Asl,ten = 200000.00
y2 = 0.00083886
sh2 = 0.00268436
ft2 = 314.5735
fy2 = 262.1446
su2 = 0.00268436
    using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
    and also multiplied by the shear_factor according to 15.7.1.4, with
    Shear_factor = 1.00
    lo/lou,min = lb/lb,min = 0.13907892
    su2 = 0.4*esu2_nominal ((5.5), TBDY) = 0.032
    From table 5A.1, TBDY: esu2_nominal = 0.08,
    For calculation of esu2_nominal and y2, sh2,ft2,fy2, it is considered
    characteristic value fsy2 = fs2/1.2, from table 5.1, TBDY.
    y1, sh1,ft1,fy1, are also multiplied by Min(1,1.25*(lb/ld)^ 2/3), from 10.3.5, ASCE 41-17.
    with fs2 = (fs,jacket*Asl,com,jacket + fs,core*Asl,com,core)/Asl,com = 262.1446
    with Es2 = (Es,jacket*Asl,com,jacket + Es,core*Asl,com,core)/Asl,com = 200000.00
yv = 0.00083886
shv = 0.00268436
ftv = 314.5735
fyv = 262.1446
suv = 0.00268436
    using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
    and also multiplied by the shear_factor according to 15.7.1.4, with
    Shear_factor = 1.00
    lo/lou,min = lb/ld = 0.13907892
    suv = 0.4*esuv_nominal ((5.5), TBDY) = 0.032
    From table 5A.1, TBDY: esuv_nominal = 0.08,
    considering characteristic value fsyv = fsv/1.2, from table 5.1, TBDY
    For calculation of esuv_nominal and yv, shv,ftv,fyv, it is considered
    characteristic value fsyv = fsv/1.2, from table 5.1, TBDY.
    y1, sh1,ft1,fy1, are also multiplied by Min(1,1.25*(lb/ld)^ 2/3), from 10.3.5, ASCE 41-17.
    with fsv = (fs,jacket*Asl,mid,jacket + fs,mid*Asl,mid,core)/Asl,mid = 262.1446
    with Esv = (Es,jacket*Asl,mid,jacket + Es,mid*Asl,mid,core)/Asl,mid = 200000.00
1 = Asl,ten/(b*d)*(fs1/fc) = 0.06824101
2 = Asl,com/(b*d)*(fs2/fc) = 0.03513975
v = Asl,mid/(b*d)*(fsv/fc) = 0.06202846
and confined core properties:
b = 340.00
d = 677.00
d' = 13.00
fcc (5A.2, TBDY) = 38.13135
cc (5A.5, TBDY) = 0.00471045
    c = confinement factor = 1.27105
    1 = Asl,ten/(b*d)*(fs1/fc) = 0.08384116
    2 = Asl,com/(b*d)*(fs2/fc) = 0.04317283
    v = Asl,mid/(b*d)*(fsv/fc) = 0.07620839
Case/Assumption: Unconfined full section - Steel rupture
' satisfies Eq. (4.3)
--->
v < vs,y2 - LHS eq.(4.5) is satisfied
--->
su (4.9) = 0.2584548

```

$$\begin{aligned} \mu &= MRC(4.14) = 5.0296E+008 \\ u &= su(4.1) = 5.1201636E-006 \end{aligned}$$

#### Calculation of ratio $l_b/l_d$

$$\text{Lap Length: } l_b/l_d = 0.13907892$$

$$l_b = 300.00$$

$$l_d = 2157.049$$

Calculation of  $l_b$ ,min according to (25.4.3.2), ACI 318-14, using mean values for all the section re-bars.

$l_d$ ,min from (25.4.3.2) is multiplied 2 times to account for smooth re-bars (9.1.2, TS500 - No provision in ACI 318)

$$= 1$$

$$d_b = 16.66667$$

$$\text{Mean strength value of all re-bars: } f_y = 781.25$$

$$\text{Mean concrete strength: } f_c' = (f_c'_{\text{jacket}} \cdot \text{Area}_{\text{jacket}} + f_c'_{\text{core}} \cdot \text{Area}_{\text{core}}) / \text{Area}_{\text{section}} = 30.00, \text{ but } f_c'^{0.5} \leq 8.3 \text{ MPa (22.5.3.1, ACI 318-14)}$$

$$t = 1.00$$

$$s = 0.80$$

$$e = 1.00$$

$$c_b = 25.00$$

$$K_{tr} = 1.7174$$

$$A_{tr} = \text{Min}(A_{tr_x}, A_{tr_y}) = 257.6106$$

where  $A_{tr_x}$ ,  $A_{tr_y}$  are the sum of the area of all stirrup legs along X and Y loxal axis

$$s = \text{Max}(s_{\text{external}}, s_{\text{internal}}) = 250.00$$

$$n = 24.00$$

#### Calculation of $\mu_{u2+}$

Calculation of ultimate curvature  $\mu_u$  according to 4.1, Biskinis/Fardis 2013:

$$u = 4.8099118E-006$$

$$\mu_u = 2.3387E+008$$

with full section properties:

$$b = 750.00$$

$$d = 707.00$$

$$d' = 43.00$$

$$v = 0.00102301$$

$$N = 16273.608$$

$$f_c = 30.00$$

$$co(5A.5, TBDY) = 0.002$$

$$\text{Final value of } cu: cu^* = \text{shear\_factor} * \text{Max}(cu, cc) = 0.01260361$$

The Shear\_factor is considered equal to 1 (pure moment strength)

$$\text{From (5.4b), TBDY: } cu = 0.01260361$$

$$we(5.4c) = 0.05179731$$

$$ase((5.4d), TBDY) = (ase1 * A_{ext} + ase2 * A_{int}) / A_{sec} = 0.45746528$$

$$ase1 = \text{Max}(((A_{conf,max1} - A_{noConf1}) / A_{conf,max1}) * (A_{conf,min1} / A_{conf,max1}), 0) = 0.45746528$$

The definitions of  $A_{noConf}$ ,  $A_{conf,min}$  and  $A_{conf,max}$  are derived from generalization of the rectangular sections confinement, which is expressed by (5.4d).

The generalization is done according to Mander, J., Priestley, M., and Park, R. (1988)

"Theoretical Stress-Strain Model for Confined Concrete."

J. Struct. Eng., 10.1061/(ASCE)0733-9445(1988)114:8(1804), 1804-1826.

$A_{conf,max1} = 353600.00$  is the confined core area at levels of member with hoops and is calculated as the area of core enclosed by the center lines of the external perimeter hoops.

$A_{conf,min1} = 293525.00$  is the confined core area at midway between the levels of hoops and is calculated by reducing all the dimensions of the area  $A_{conf,max1}$  by a length

equal to half the clear spacing between external hoops.

$A_{noConf1} = 158733.333$  is the unconfined external core area which is equal to  $b_i^2/6$  as defined at (A.2).

$$ase2 (>= ase1) = \text{Max}(((A_{conf,max2} - A_{noConf2}) / A_{conf,max2}) * (A_{conf,min2} / A_{conf,max2}), 0) = 0.45746528$$

The definitions of  $A_{noConf}$ ,  $A_{conf,min}$  and  $A_{conf,max}$  are derived from generalization of the rectangular sections confinement, which is expressed by (5.4d).

The generalization is done according to Mander, J., Priestley, M., and Park, R. (1988)

"Theoretical Stress-Strain Model for Confined Concrete."

J. Struct. Eng., 10.1061/(ASCE)0733-9445(1988)114:8(1804), 1804-1826.

Aconf,max2 = 171264.00 is the confined core area at levels of member with hoops and is calculated as the area of core enclosed by the center lines of the internal perimeter hoops.

Aconf,min2 = 54741.00 is the confined core area at midway between the levels of hoops and is calculated by reducing all the dimensions of the area Aconf,max2 by a length equal to half the clear spacing between internal hoops.

AnoConf2 = 106242.667 is the unconfined internal core area which is equal to  $b_i^2/6$  as defined at (A.2).  
 $psh,min*Fywe = \text{Min}(psh,x*Fywe, psh,y*Fywe) = 3.3968$

---

$psh_x*Fywe = psh1*Fywe1 + ps2*Fywe2 = 3.3968$   
 $psh1 \text{ ((5.4d), TBDY)} = Lstir1*Astir1/(Asec*s1) = 0.00367709$   
 $Lstir1 \text{ (Length of stirrups along Y)} = 2060.00$   
 $Astir1 \text{ (stirrups area)} = 78.53982$   
 $psh2 \text{ (5.4d)} = Lstir2*Astir2/(Asec*s2) = 0.00067082$   
 $Lstir2 \text{ (Length of stirrups along Y)} = 1468.00$   
 $Astir2 \text{ (stirrups area)} = 50.26548$

---

$psh_y*Fywe = psh1*Fywe1 + ps2*Fywe2 = 3.3968$   
 $psh1 \text{ ((5.4d), TBDY)} = Lstir1*Astir1/(Asec*s1) = 0.00367709$   
 $Lstir1 \text{ (Length of stirrups along X)} = 2060.00$   
 $Astir1 \text{ (stirrups area)} = 78.53982$   
 $psh2 \text{ ((5.4d), TBDY)} = Lstir2*Astir2/(Asec*s2) = 0.00067082$   
 $Lstir2 \text{ (Length of stirrups along X)} = 1468.00$   
 $Astir2 \text{ (stirrups area)} = 50.26548$

---

Asec = 440000.00

s1 = 100.00

s2 = 250.00

fywe1 = 781.25

fywe2 = 781.25

fce = 30.00

From ((5.A5), TBDY), TBDY: cc = 0.00471045

c = confinement factor = 1.27105

y1 = 0.00083886

sh1 = 0.00268436

ft1 = 314.5735

fy1 = 262.1446

su1 = 0.00268436

using (30) in Biskinis/Fardis (2013) multiplied with shear\_factor and also multiplied by the shear\_factor according to 15.7.1.4, with Shear\_factor = 1.00

lo/lou,min = lb/lb,min = 0.13907892

su1 = 0.4\*esu1\_nominal ((5.5), TBDY) = 0.032

From table 5A.1, TBDY: esu1\_nominal = 0.08,

For calculation of esu1\_nominal and y1, sh1,ft1,fy1, it is considered characteristic value fsy1 = fs1/1.2, from table 5.1, TBDY.

y1, sh1,ft1,fy1, are also multiplied by  $\text{Min}(1, 1.25*(lb/lb)^{2/3})$ , from 10.3.5, ASCE 41-17.

with fs1 = (fs,jacket\*Asl,ten,jacket + fs,core\*Asl,ten,core)/Asl,ten = 262.1446

with Es1 = (Es,jacket\*Asl,ten,jacket + Es,core\*Asl,ten,core)/Asl,ten = 200000.00

y2 = 0.00083886

sh2 = 0.00268436

ft2 = 314.5735

fy2 = 262.1446

su2 = 0.00268436

using (30) in Biskinis/Fardis (2013) multiplied with shear\_factor and also multiplied by the shear\_factor according to 15.7.1.4, with Shear\_factor = 1.00

lo/lou,min = lb/lb,min = 0.13907892

su2 = 0.4\*esu2\_nominal ((5.5), TBDY) = 0.032

From table 5A.1, TBDY: esu2\_nominal = 0.08,

For calculation of esu2\_nominal and y2, sh2,ft2,fy2, it is considered characteristic value fsy2 = fs2/1.2, from table 5.1, TBDY.

y1, sh1,ft1,fy1, are also multiplied by  $\text{Min}(1, 1.25*(lb/lb)^{2/3})$ , from 10.3.5, ASCE 41-17.

with fs2 = (fs,jacket\*Asl,com,jacket + fs,core\*Asl,com,core)/Asl,com = 262.1446

with Es2 = (Es,jacket\*Asl,com,jacket + Es,core\*Asl,com,core)/Asl,com = 200000.00

yv = 0.00083886

shv = 0.00268436

ftv = 314.5735

```

fyv = 262.1446
suv = 0.00268436
    using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
    and also multiplied by the shear_factor according to 15.7.1.4, with
    Shear_factor = 1.00
    lo/lo,min = lb/ld = 0.13907892
    suv = 0.4*esuv_nominal ((5.5), TBDY) = 0.032
    From table 5A.1, TBDY: esuv_nominal = 0.08,
    considering characteristic value fsyv = fsv/1.2, from table 5.1, TBDY
    For calculation of esuv_nominal and yv, shv,ftv,fyv, it is considered
    characteristic value fsyv = fsv/1.2, from table 5.1, TBDY.
    y1, sh1,ft1,fy1, are also multiplied by Min(1,1.25*(lb/ld)^ 2/3), from 10.3.5, ASCE 41-17.
    with fsv = (fsjacket*Asl,mid,jacket + fs,mid*Asl,mid,core)/Asl,mid = 262.1446
    with Esv = (Es,jacket*Asl,mid,jacket + Es,mid*Asl,mid,core)/Asl,mid = 200000.00
    1 = Asl,ten/(b*d)*(fs1/fc) = 0.0187412
    2 = Asl,com/(b*d)*(fs2/fc) = 0.03639521
    v = Asl,mid/(b*d)*(fsv/fc) = 0.03308184
and confined core properties:
b = 690.00
d = 677.00
d' = 13.00
fcc (5A.2, TBDY) = 38.13135
cc (5A.5, TBDY) = 0.00471045
    c = confinement factor = 1.27105
    1 = Asl,ten/(b*d)*(fs1/fc) = 0.02127357
    2 = Asl,com/(b*d)*(fs2/fc) = 0.04131304
    v = Asl,mid/(b*d)*(fsv/fc) = 0.03755196
Case/Assumption: Unconfined full section - Steel rupture
' satisfies Eq. (4.3)
--->
v < vs,y2 - LHS eq.(4.5) is satisfied
--->
su (4.9) = 0.21062322
Mu = MRc (4.14) = 2.3387E+008
u = su (4.1) = 4.8099118E-006
-----

Calculation of ratio lb/ld
-----
Lap Length: lb/ld = 0.13907892
lb = 300.00
ld = 2157.049
Calculation of lb,min according to (25.4.3.2), ACI 318-14, using mean values for all the section re-bars.
ld,min from (25.4.3.2) is multiplied 2 times to account for smooth re-bars (9.1.2, TS500 - No provision in ACI 318)
= 1
db = 16.66667
Mean strength value of all re-bars: fy = 781.25
Mean concrete strength: fc' = (fc'_jacket*Area_jacket + fc'_core*Area_core)/Area_section = 30.00, but fc'^0.5 <= 8.3
MPa (22.5.3.1, ACI 318-14)
t = 1.00
s = 0.80
e = 1.00
cb = 25.00
Ktr = 1.7174
Atr = Min(Atr_x,Atr_y) = 257.6106
where Atr_x, Atr_y are the sum of the area of all stirrup legs along X and Y loxal axis
s = Max(s_external,s_internal) = 250.00
n = 24.00
-----

Calculation of Mu2-
-----

Calculation of ultimate curvature u according to 4.1, Biskinis/Fardis 2013:
u = 5.1201636E-006

```

$$\mu = 5.0296E+008$$

with full section properties:

$$b = 400.00$$

$$d = 707.00$$

$$d' = 43.00$$

$$v = 0.00191815$$

$$N = 16273.608$$

$$f_c = 30.00$$

$$\alpha (5A.5, \text{TB DY}) = 0.002$$

$$\text{Final value of } \mu: \mu^* = \text{shear\_factor} * \text{Max}(\mu, \alpha) = 0.01260361$$

The Shear\_factor is considered equal to 1 (pure moment strength)

$$\text{From (5.4b), TB DY: } \mu = 0.01260361$$

$$\mu_e (5.4c) = 0.05179731$$

$$\alpha_e ((5.4d), \text{TB DY}) = (\alpha_1 * A_{ext} + \alpha_2 * A_{int}) / A_{sec} = 0.45746528$$

$$\alpha_1 = \text{Max}(((A_{conf,max1} - A_{noConf1}) / A_{conf,max1}) * (A_{conf,min1} / A_{conf,max1}), 0) = 0.45746528$$

The definitions of  $A_{noConf}$ ,  $A_{conf,min}$  and  $A_{conf,max}$  are derived from generalization of the rectangular sections confinement, which is expressed by (5.4d).

The generalization is done according to Mander, J., Priestley, M., and Park, R. (1988)

"Theoretical Stress-Strain Model for Confined Concrete."

J. Struct. Eng., 10.1061/(ASCE)0733-9445(1988)114:8(1804), 1804-1826.

$A_{conf,max1} = 353600.00$  is the confined core area at levels of member with hoops and

is calculated as the area of core enclosed by the center lines of the external perimeter hoops.

$A_{conf,min1} = 293525.00$  is the confined core area at midway between the levels of hoops and

is calculated by reducing all the dimensions of the area  $A_{conf,max1}$  by a length

equal to half the clear spacing between external hoops.

$A_{noConf1} = 158733.333$  is the unconfined external core area which is equal to  $b_i^2/6$  as defined at (A.2).

$$\alpha_2 (> \alpha_1) = \text{Max}(((A_{conf,max2} - A_{noConf2}) / A_{conf,max2}) * (A_{conf,min2} / A_{conf,max2}), 0) = 0.45746528$$

The definitions of  $A_{noConf}$ ,  $A_{conf,min}$  and  $A_{conf,max}$  are derived from generalization of the rectangular sections confinement, which is expressed by (5.4d).

The generalization is done according to Mander, J., Priestley, M., and Park, R. (1988)

"Theoretical Stress-Strain Model for Confined Concrete."

J. Struct. Eng., 10.1061/(ASCE)0733-9445(1988)114:8(1804), 1804-1826.

$A_{conf,max2} = 171264.00$  is the confined core area at levels of member with hoops and

is calculated as the area of core enclosed by the center lines of the internal perimeter hoops.

$A_{conf,min2} = 54741.00$  is the confined core area at midway between the levels of hoops and

is calculated by reducing all the dimensions of the area  $A_{conf,max2}$  by a length

equal to half the clear spacing between internal hoops.

$A_{noConf2} = 106242.667$  is the unconfined internal core area which is equal to  $b_i^2/6$  as defined at (A.2).

$$p_{sh,min} * F_{ywe} = \text{Min}(p_{sh,x} * F_{ywe}, p_{sh,y} * F_{ywe}) = 3.3968$$

$$p_{sh,x} * F_{ywe} = p_{sh1} * F_{ywe1} + p_{sh2} * F_{ywe2} = 3.3968$$

$$p_{sh1} ((5.4d), \text{TB DY}) = L_{stir1} * A_{stir1} / (A_{sec} * s_1) = 0.00367709$$

$$L_{stir1} (\text{Length of stirrups along Y}) = 2060.00$$

$$A_{stir1} (\text{stirrups area}) = 78.53982$$

$$p_{sh2} (5.4d) = L_{stir2} * A_{stir2} / (A_{sec} * s_2) = 0.00067082$$

$$L_{stir2} (\text{Length of stirrups along Y}) = 1468.00$$

$$A_{stir2} (\text{stirrups area}) = 50.26548$$

$$p_{sh,y} * F_{ywe} = p_{sh1} * F_{ywe1} + p_{sh2} * F_{ywe2} = 3.3968$$

$$p_{sh1} ((5.4d), \text{TB DY}) = L_{stir1} * A_{stir1} / (A_{sec} * s_1) = 0.00367709$$

$$L_{stir1} (\text{Length of stirrups along X}) = 2060.00$$

$$A_{stir1} (\text{stirrups area}) = 78.53982$$

$$p_{sh2} ((5.4d), \text{TB DY}) = L_{stir2} * A_{stir2} / (A_{sec} * s_2) = 0.00067082$$

$$L_{stir2} (\text{Length of stirrups along X}) = 1468.00$$

$$A_{stir2} (\text{stirrups area}) = 50.26548$$

$$A_{sec} = 440000.00$$

$$s_1 = 100.00$$

$$s_2 = 250.00$$

$$f_{ywe1} = 781.25$$

$$f_{ywe2} = 781.25$$

$$f_{ce} = 30.00$$

$$\text{From ((5.A5), TB DY), TB DY: } \alpha_c = 0.00471045$$

$$c = \text{confinement factor} = 1.27105$$

$$y_1 = 0.00083886$$

$$sh_1 = 0.00268436$$

```

ft1 = 314.5735
fy1 = 262.1446
su1 = 0.00268436
    using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
    and also multiplied by the shear_factor according to 15.7.1.4, with
    Shear_factor = 1.00
    lo/lou,min = lb/lb = 0.13907892
    su1 = 0.4*esu1_nominal ((5.5), TBDY) = 0.032
    From table 5A.1, TBDY: esu1_nominal = 0.08,
    For calculation of esu1_nominal and y1, sh1,ft1,fy1, it is considered
    characteristic value fsy1 = fs1/1.2, from table 5.1, TBDY.
    y1, sh1,ft1,fy1, are also multiplied by Min(1,1.25*(lb/lb)^2/3), from 10.3.5, ASCE 41-17.
    with fs1 = (fs,jacket*Asl,ten,jacket + fs,core*Asl,ten,core)/Asl,ten = 262.1446
    with Es1 = (Es,jacket*Asl,ten,jacket + Es,core*Asl,ten,core)/Asl,ten = 200000.00
y2 = 0.00083886
sh2 = 0.00268436
ft2 = 314.5735
fy2 = 262.1446
su2 = 0.00268436
    using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
    and also multiplied by the shear_factor according to 15.7.1.4, with
    Shear_factor = 1.00
    lo/lou,min = lb/lb,min = 0.13907892
    su2 = 0.4*esu2_nominal ((5.5), TBDY) = 0.032
    From table 5A.1, TBDY: esu2_nominal = 0.08,
    For calculation of esu2_nominal and y2, sh2,ft2,fy2, it is considered
    characteristic value fsy2 = fs2/1.2, from table 5.1, TBDY.
    y1, sh1,ft1,fy1, are also multiplied by Min(1,1.25*(lb/lb)^2/3), from 10.3.5, ASCE 41-17.
    with fs2 = (fs,jacket*Asl,com,jacket + fs,core*Asl,com,core)/Asl,com = 262.1446
    with Es2 = (Es,jacket*Asl,com,jacket + Es,core*Asl,com,core)/Asl,com = 200000.00
yv = 0.00083886
shv = 0.00268436
ftv = 314.5735
fyv = 262.1446
suv = 0.00268436
    using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
    and also multiplied by the shear_factor according to 15.7.1.4, with
    Shear_factor = 1.00
    lo/lou,min = lb/lb = 0.13907892
    suv = 0.4*esuv_nominal ((5.5), TBDY) = 0.032
    From table 5A.1, TBDY: esuv_nominal = 0.08,
    considering characteristic value fsyv = fsv/1.2, from table 5.1, TBDY
    For calculation of esuv_nominal and yv, shv,ftv,fyv, it is considered
    characteristic value fsyv = fsv/1.2, from table 5.1, TBDY.
    y1, sh1,ft1,fy1, are also multiplied by Min(1,1.25*(lb/lb)^2/3), from 10.3.5, ASCE 41-17.
    with fsv = (fs,jacket*Asl,mid,jacket + fs,mid*Asl,mid,core)/Asl,mid = 262.1446
    with Esv = (Es,jacket*Asl,mid,jacket + Es,mid*Asl,mid,core)/Asl,mid = 200000.00
1 = Asl,ten/(b*d)*(fs1/fc) = 0.06824101
2 = Asl,com/(b*d)*(fs2/fc) = 0.03513975
v = Asl,mid/(b*d)*(fsv/fc) = 0.06202846
and confined core properties:
b = 340.00
d = 677.00
d' = 13.00
fcc (5A.2, TBDY) = 38.13135
cc (5A.5, TBDY) = 0.00471045
    c = confinement factor = 1.27105
    1 = Asl,ten/(b*d)*(fs1/fc) = 0.08384116
    2 = Asl,com/(b*d)*(fs2/fc) = 0.04317283
    v = Asl,mid/(b*d)*(fsv/fc) = 0.07620839
Case/Assumption: Unconfined full section - Steel rupture
' satisfies Eq. (4.3)
--->
v < vs,y2 - LHS eq.(4.5) is satisfied
--->
su (4.9) = 0.2584548
Mu = MRc (4.14) = 5.0296E+008

```



$$u = s_u(4.1) = 5.1201636E-006$$

Calculation of ratio  $l_b/d$

Lap Length:  $l_b/d = 0.13907892$

$l_b = 300.00$

$d = 2157.049$

Calculation of  $l_b$ ,min according to (25.4.3.2), ACI 318-14, using mean values for all the section re-bars.

$l_b$ ,min from (25.4.3.2) is multiplied 2 times to account for smooth re-bars (9.1.2, TS500 - No provision in ACI 318)

$= 1$

$db = 16.66667$

Mean strength value of all re-bars:  $f_y = 781.25$

Mean concrete strength:  $f'_c = (f'_{c,jacket} \cdot Area_{jacket} + f'_{c,core} \cdot Area_{core}) / Area_{section} = 30.00$ , but  $f_c^{0.5} \leq 8.3$  MPa (22.5.3.1, ACI 318-14)

$t = 1.00$

$s = 0.80$

$e = 1.00$

$cb = 25.00$

$K_{tr} = 1.7174$

$A_{tr} = \text{Min}(A_{tr,x}, A_{tr,y}) = 257.6106$

where  $A_{tr,x}$ ,  $A_{tr,y}$  are the sum of the area of all stirrup legs along X and Y loxal axis

$s = \text{Max}(s_{external}, s_{internal}) = 250.00$

$n = 24.00$

Calculation of Shear Strength  $V_r = \text{Min}(V_{r1}, V_{r2}) = 1.0392E+006$

Calculation of Shear Strength at edge 1,  $V_{r1} = 1.0392E+006$

$V_{r1} = V_{Col}((10.3), ASCE 41-17) = k_{nl} \cdot V_{Col0}$

$V_{Col0} = 1.0392E+006$

$k_{nl} = 1$  (zero step-static loading)

NOTE: In expression (10-3) ' $V_s = A_v \cdot f_y \cdot d / s$ ' is replaced by ' $V_s + f \cdot V_f$ ' where  $V_f$  is the contribution of FRPs (11.3), ACI 440).

$= 1$  (normal-weight concrete)

Mean concrete strength:  $f'_c = (f'_{c,jacket} \cdot Area_{jacket} + f'_{c,core} \cdot Area_{core}) / Area_{section} = 30.00$ , but  $f_c^{0.5} \leq 8.3$  MPa (22.5.3.1, ACI 318-14)

$M/Vd = 4.00$

$\mu_u = 1308.016$

$V_u = 0.00017144$

$d = 0.8 \cdot h = 600.00$

$N_u = 16273.608$

$A_g = 300000.00$

From (11.5.4.8), ACI 318-14:  $V_s = V_{s,jacket} + V_{s,core} = 1.0138E+006$

where:

$V_{s,jacket} = V_{sj1} + V_{sj2} = 903207.888$

$V_{sj1} = 589048.623$  is calculated for section web jacket, with:

$d = 600.00$

$A_v = 157079.633$

$f_y = 625.00$

$s = 100.00$

$V_{sj1}$  is multiplied by  $Col,j1 = 1.00$

$s/d = 0.16666667$

$V_{sj2} = 314159.265$  is calculated for section flange jacket, with:

$d = 320.00$

$A_v = 157079.633$

$f_y = 625.00$

$s = 100.00$

$V_{sj2}$  is multiplied by  $Col,j2 = 1.00$

$s/d = 0.3125$

$V_{s,core} = V_{sc1} + V_{sc2} = 110584.061$

$V_{sc1} = 110584.061$  is calculated for section web core, with:

$d = 440.00$

$A_v = 100530.965$   
 $f_y = 625.00$   
 $s = 250.00$   
 $V_{s,c1}$  is multiplied by  $Col,c1 = 1.00$   
 $s/d = 0.56818182$   
 $V_{s,c2} = 0.00$  is calculated for section flange core, with:  
 $d = 160.00$   
 $A_v = 100530.965$   
 $f_y = 625.00$   
 $s = 250.00$   
 $V_{s,c2}$  is multiplied by  $Col,c2 = 0.00$   
 $s/d = 1.5625$   
 $V_f ((11-3)-(11.4), ACI 440) = 0.00$   
 From (11-11), ACI 440:  $V_s + V_f \leq 873250.061$   
 $bw = 400.00$

Calculation of Shear Strength at edge 2,  $V_{r2} = 1.0392E+006$   
 $V_{r2} = V_{Col} ((10.3), ASCE 41-17) = knl * V_{Col0}$   
 $V_{Col0} = 1.0392E+006$   
 $knl = 1$  (zero step-static loading)

NOTE: In expression (10-3) ' $V_s = A_v * f_y * d / s$ ' is replaced by ' $V_s + f * V_f$ ' where  $V_f$  is the contribution of FRPs (11.3), ACI 440).

$= 1$  (normal-weight concrete)  
 Mean concrete strength:  $f'_c = (f'_c\_jacket * Area\_jacket + f'_c\_core * Area\_core) / Area\_section = 30.00$ , but  $f'_c^{0.5} \leq 8.3$  MPa (22.5.3.1, ACI 318-14)

$M/Vd = 4.00$   
 $\mu_u = 1308.016$   
 $V_u = 0.00017144$   
 $d = 0.8 * h = 600.00$   
 $N_u = 16273.608$   
 $A_g = 300000.00$   
 From (11.5.4.8), ACI 318-14:  $V_s = V_{s,jacket} + V_{s,core} = 1.0138E+006$   
 where:

$V_{s,jacket} = V_{s,j1} + V_{s,j2} = 903207.888$   
 $V_{s,j1} = 589048.623$  is calculated for section web jacket, with:  
 $d = 600.00$   
 $A_v = 157079.633$   
 $f_y = 625.00$   
 $s = 100.00$   
 $V_{s,j1}$  is multiplied by  $Col,j1 = 1.00$   
 $s/d = 0.16666667$   
 $V_{s,j2} = 314159.265$  is calculated for section flange jacket, with:  
 $d = 320.00$   
 $A_v = 157079.633$   
 $f_y = 625.00$   
 $s = 100.00$   
 $V_{s,j2}$  is multiplied by  $Col,j2 = 1.00$   
 $s/d = 0.3125$   
 $V_{s,core} = V_{s,c1} + V_{s,c2} = 110584.061$   
 $V_{s,c1} = 110584.061$  is calculated for section web core, with:  
 $d = 440.00$   
 $A_v = 100530.965$   
 $f_y = 625.00$   
 $s = 250.00$   
 $V_{s,c1}$  is multiplied by  $Col,c1 = 1.00$   
 $s/d = 0.56818182$   
 $V_{s,c2} = 0.00$  is calculated for section flange core, with:  
 $d = 160.00$   
 $A_v = 100530.965$   
 $f_y = 625.00$   
 $s = 250.00$   
 $V_{s,c2}$  is multiplied by  $Col,c2 = 0.00$   
 $s/d = 1.5625$   
 $V_f ((11-3)-(11.4), ACI 440) = 0.00$

From (11-11), ACI 440:  $V_s + V_f \leq 873250.061$   
 $b_w = 400.00$

End Of Calculation of Shear Capacity ratio for element: column JLC1 of floor 1  
At local axis: 3

Start Of Calculation of Shear Capacity ratio for element: column JLC1 of floor 1  
At Shear local axis: 2  
(Bending local axis: 3)  
Section Type: rcjcs

#### Constant Properties

Knowledge Factor,  $= 1.00$   
Mean strength values are used for both shear and moment calculations.  
Consequently:  
Jacket  
New material of Primary Member: Concrete Strength,  $f_c = f_{cm} = 30.00$   
New material of Primary Member: Steel Strength,  $f_s = f_{sm} = 625.00$   
Concrete Elasticity,  $E_c = 25742.96$   
Steel Elasticity,  $E_s = 200000.00$   
Existing Column  
New material of Primary Member: Concrete Strength,  $f_c = f_{cm} = 30.00$   
New material of Primary Member: Steel Strength,  $f_s = f_{sm} = 625.00$   
Concrete Elasticity,  $E_c = 25742.96$   
Steel Elasticity,  $E_s = 200000.00$   
#####  
Note: Especially for the calculation of moment strengths,  
the above steel re-bar strengths are multiplied by 1.25 according to R18.6.5, ACI 318-14  
Jacket  
New material: Steel Strength,  $f_s = 1.25 \cdot f_{sm} = 781.25$   
Existing Column  
New material: Steel Strength,  $f_s = 1.25 \cdot f_{sm} = 781.25$   
#####  
Max Height,  $H_{max} = 750.00$   
Min Height,  $H_{min} = 400.00$   
Max Width,  $W_{max} = 750.00$   
Min Width,  $W_{min} = 400.00$   
Jacket Thickness,  $t_j = 100.00$   
Cover Thickness,  $c = 25.00$   
Mean Confinement Factor overall section = 1.27105  
Element Length,  $L = 3000.00$   
Primary Member  
Smooth Bars  
Ductile Steel  
With Detailing for Earthquake Resistance (including stirrups closed at 135°)  
Longitudinal Bars With Ends Lapped Starting at the End Sections  
Lap Length  $l_o = 300.00$   
No FRP Wrapping

#### Stepwise Properties

At local axis: 2  
EDGE -A-  
Shear Force,  $V_a = -0.0001715$   
EDGE -B-  
Shear Force,  $V_b = 0.0001715$   
BOTH EDGES  
Axial Force,  $F = -16273.608$   
Longitudinal Reinforcement Area Distribution (in 2 divisions)  
-Tension:  $A_{st} = 0.00$   
-Compression:  $A_{sc} = 5353.274$

Longitudinal Reinforcement Area Distribution (in 3 divisions)

-Tension:  $Asl_{ten} = 1137.257$

-Compression:  $Asl_{com} = 2208.54$

-Middle:  $Asl_{mid} = 2007.478$

Calculation of Shear Capacity ratio ,  $Ve/Vr = 0.32266369$

Member Controlled by Flexure ( $Ve/Vr < 1$ )

Calculation of Shear Demand from fig. R18.6.5, ACI 318-14  $Ve = (Mpr1 + Mpr2)/ln = 335307.657$

with

$Mpr1 = \text{Max}(Mu1+, Mu1-) = 5.0296E+008$

$Mu1+ = 2.3387E+008$ , is the ultimate moment strength at the edge 1 of the member in the actual moment direction which is defined for the static loading combination

$Mu1- = 5.0296E+008$ , is the ultimate moment strength at the edge 1 of the member in the opposite moment direction which is defined for the static loading combination

$Mpr2 = \text{Max}(Mu2+, Mu2-) = 5.0296E+008$

$Mu2+ = 2.3387E+008$ , is the ultimate moment strength at the edge 2 of the member in the actual moment direction which is defined for the static loading combination

$Mu2- = 5.0296E+008$ , is the ultimate moment strength at the edge 2 of the member in the opposite moment direction which is defined for the static loading combination

Calculation of  $Mu1+$

Calculation of ultimate curvature  $u$  according to 4.1, Biskinis/Fardis 2013:

$u = 4.8099118E-006$

$Mu = 2.3387E+008$

with full section properties:

$b = 750.00$

$d = 707.00$

$d' = 43.00$

$v = 0.00102301$

$N = 16273.608$

$fc = 30.00$

$co (5A.5, TBDY) = 0.002$

Final value of  $cu$ :  $cu^* = \text{shear\_factor} * \text{Max}(cu, cc) = 0.01260361$

The Shear\_factor is considered equal to 1 (pure moment strength)

From (5.4b), TBDY:  $cu = 0.01260361$

$we (5.4c) = 0.05179731$

$ase ((5.4d), TBDY) = (ase1 * Aext + ase2 * Aint) / Asec = 0.45746528$

$ase1 = \text{Max}(((Aconf, max1 - AnoConf1) / Aconf, max1) * (Aconf, min1 / Aconf, max1), 0) = 0.45746528$

The definitions of  $AnoConf$ ,  $Aconf, min$  and  $Aconf, max$  are derived from generalization of the rectangular sections confinement, which is expressed by (5.4d).

The generalization is done according to Mander, J., Priestley, M., and Park, R. (1988)

"Theoretical Stress-Strain Model for Confined Concrete."

J. Struct. Eng., 10.1061/(ASCE)0733-9445(1988)114:8(1804), 1804-1826.

$Aconf, max1 = 353600.00$  is the confined core area at levels of member with hoops and is calculated as the area of core enclosed by the center lines of the external perimeter hoops.

$Aconf, min1 = 293525.00$  is the confined core area at midway between the levels of hoops and is calculated by reducing all the dimensions of the area  $Aconf, max1$  by a length equal to half the clear spacing between external hoops.

$AnoConf1 = 158733.333$  is the unconfined external core area which is equal to  $bi^2/6$  as defined at (A.2).

$ase2 (>= ase1) = \text{Max}(((Aconf, max2 - AnoConf2) / Aconf, max2) * (Aconf, min2 / Aconf, max2), 0) = 0.45746528$

The definitions of  $AnoConf$ ,  $Aconf, min$  and  $Aconf, max$  are derived from generalization of the rectangular sections confinement, which is expressed by (5.4d).

The generalization is done according to Mander, J., Priestley, M., and Park, R. (1988)

"Theoretical Stress-Strain Model for Confined Concrete."

J. Struct. Eng., 10.1061/(ASCE)0733-9445(1988)114:8(1804), 1804-1826.

$Aconf, max2 = 171264.00$  is the confined core area at levels of member with hoops and is calculated as the area of core enclosed by the center lines of the internal perimeter hoops.

$Aconf, min2 = 54741.00$  is the confined core area at midway between the levels of hoops and is calculated by reducing all the dimensions of the area  $Aconf, max2$  by a length

equal to half the clear spacing between internal hoops.

AnoConf2 = 106242.667 is the unconfined internal core area which is equal to  $b_i^2/6$  as defined at (A.2).  
 $psh_{min} \cdot Fywe = \text{Min}(psh_x \cdot Fywe, psh_y \cdot Fywe) = 3.3968$

$psh_x \cdot Fywe = psh1 \cdot Fywe1 + ps2 \cdot Fywe2 = 3.3968$   
 $psh1 \text{ ((5.4d), TBDY)} = Lstir1 \cdot Astir1 / (Asec \cdot s1) = 0.00367709$   
Lstir1 (Length of stirrups along Y) = 2060.00  
Astir1 (stirrups area) = 78.53982  
 $psh2 \text{ (5.4d)} = Lstir2 \cdot Astir2 / (Asec \cdot s2) = 0.00067082$   
Lstir2 (Length of stirrups along Y) = 1468.00  
Astir2 (stirrups area) = 50.26548

$psh_y \cdot Fywe = psh1 \cdot Fywe1 + ps2 \cdot Fywe2 = 3.3968$   
 $psh1 \text{ ((5.4d), TBDY)} = Lstir1 \cdot Astir1 / (Asec \cdot s1) = 0.00367709$   
Lstir1 (Length of stirrups along X) = 2060.00  
Astir1 (stirrups area) = 78.53982  
 $psh2 \text{ ((5.4d), TBDY)} = Lstir2 \cdot Astir2 / (Asec \cdot s2) = 0.00067082$   
Lstir2 (Length of stirrups along X) = 1468.00  
Astir2 (stirrups area) = 50.26548

Asec = 440000.00

s1 = 100.00

s2 = 250.00

fywe1 = 781.25

fywe2 = 781.25

fce = 30.00

From ((5.A5), TBDY), TBDY: cc = 0.00471045

c = confinement factor = 1.27105

y1 = 0.00083886

sh1 = 0.00268436

ft1 = 314.5735

fy1 = 262.1446

su1 = 0.00268436

using (30) in Biskinis/Fardis (2013) multiplied with shear\_factor  
and also multiplied by the shear\_factor according to 15.7.1.4, with  
Shear\_factor = 1.00

lo/lou,min = lb/lb = 0.13907892

su1 = 0.4\*esu1\_nominal ((5.5), TBDY) = 0.032

From table 5A.1, TBDY: esu1\_nominal = 0.08,

For calculation of esu1\_nominal and y1, sh1, ft1, fy1, it is considered  
characteristic value fsy1 = fs1/1.2, from table 5.1, TBDY.

y1, sh1, ft1, fy1, are also multiplied by  $\text{Min}(1, 1.25 \cdot (lb/lb)^{2/3})$ , from 10.3.5, ASCE 41-17.

with fs1 = (fs,jacket\*Asl,ten,jacket + fs,core\*Asl,ten,core)/Asl,ten = 262.1446

with Es1 = (Es,jacket\*Asl,ten,jacket + Es,core\*Asl,ten,core)/Asl,ten = 200000.00

y2 = 0.00083886

sh2 = 0.00268436

ft2 = 314.5735

fy2 = 262.1446

su2 = 0.00268436

using (30) in Biskinis/Fardis (2013) multiplied with shear\_factor  
and also multiplied by the shear\_factor according to 15.7.1.4, with  
Shear\_factor = 1.00

lo/lou,min = lb/lb,min = 0.13907892

su2 = 0.4\*esu2\_nominal ((5.5), TBDY) = 0.032

From table 5A.1, TBDY: esu2\_nominal = 0.08,

For calculation of esu2\_nominal and y2, sh2, ft2, fy2, it is considered  
characteristic value fsy2 = fs2/1.2, from table 5.1, TBDY.

y1, sh1, ft1, fy1, are also multiplied by  $\text{Min}(1, 1.25 \cdot (lb/lb)^{2/3})$ , from 10.3.5, ASCE 41-17.

with fs2 = (fs,jacket\*Asl,com,jacket + fs,core\*Asl,com,core)/Asl,com = 262.1446

with Es2 = (Es,jacket\*Asl,com,jacket + Es,core\*Asl,com,core)/Asl,com = 200000.00

yv = 0.00083886

shv = 0.00268436

ftv = 314.5735

fyv = 262.1446

suv = 0.00268436

using (30) in Biskinis/Fardis (2013) multiplied with shear\_factor  
and also multiplied by the shear\_factor according to 15.7.1.4, with

```

Shear_factor = 1.00
lo/lou,min = lb/ld = 0.13907892
suv = 0.4*esuv_nominal ((5.5), TBDY) = 0.032
From table 5A.1, TBDY: esuv_nominal = 0.08,
considering characteristic value fsyv = fsv/1.2, from table 5.1, TBDY
For calculation of esuv_nominal and yv, shv,ftv,fyv, it is considered
characteristic value fsyv = fsv/1.2, from table 5.1, TBDY.
y1, sh1,ft1,fy1, are also multiplied by Min(1,1.25*(lb/ld)^ 2/3), from 10.3.5, ASCE 41-17.
with fsv = (fsjacket*Asl,mid,jacket + fs,mid*Asl,mid,core)/Asl,mid = 262.1446
with Esv = (Es,jacket*Asl,mid,jacket + Es,mid*Asl,mid,core)/Asl,mid = 200000.00
1 = Asl,ten/(b*d)*(fs1/fc) = 0.0187412
2 = Asl,com/(b*d)*(fs2/fc) = 0.03639521
v = Asl,mid/(b*d)*(fsv/fc) = 0.03308184
and confined core properties:
b = 690.00
d = 677.00
d' = 13.00
fcc (5A.2, TBDY) = 38.13135
cc (5A.5, TBDY) = 0.00471045
c = confinement factor = 1.27105
1 = Asl,ten/(b*d)*(fs1/fc) = 0.02127357
2 = Asl,com/(b*d)*(fs2/fc) = 0.04131304
v = Asl,mid/(b*d)*(fsv/fc) = 0.03755196
Case/Assumption: Unconfined full section - Steel rupture
' satisfies Eq. (4.3)
---->
v < vs,y2 - LHS eq.(4.5) is satisfied
---->
su (4.9) = 0.21062322
Mu = MRc (4.14) = 2.3387E+008
u = su (4.1) = 4.8099118E-006
-----

Calculation of ratio lb/ld
-----
Lap Length: lb/ld = 0.13907892
lb = 300.00
ld = 2157.049
Calculation of lb,min according to (25.4.3.2), ACI 318-14, using mean values for all the section re-bars.
ld,min from (25.4.3.2) is multiplied 2 times to account for smooth re-bars (9.1.2, TS500 - No provision in ACI 318)
= 1
db = 16.66667
Mean strength value of all re-bars: fy = 781.25
Mean concrete strength: fc' = (fc'_jacket*Area_jacket + fc'_core*Area_core)/Area_section = 30.00, but fc'^0.5 <= 8.3
MPa (22.5.3.1, ACI 318-14)
t = 1.00
s = 0.80
e = 1.00
cb = 25.00
Ktr = 1.7174
Atr = Min(Atr_x,Atr_y) = 257.6106
where Atr_x, Atr_y are the sum of the area of all stirrup legs along X and Y loxal axis
s = Max(s_external,s_internal) = 250.00
n = 24.00
-----

Calculation of Mu1-
-----

Calculation of ultimate curvature u according to 4.1, Biskinis/Fardis 2013:
u = 5.1201636E-006
Mu = 5.0296E+008
-----

with full section properties:
b = 400.00

```

$d = 707.00$   
 $d' = 43.00$   
 $v = 0.00191815$   
 $N = 16273.608$   
 $f_c = 30.00$   
 $co (5A.5, TBDY) = 0.002$   
 Final value of  $cu$ :  $cu^* = shear\_factor * Max(cu, cc) = 0.01260361$   
 The Shear\_factor is considered equal to 1 (pure moment strength)  
 From (5.4b), TBDY:  $cu = 0.01260361$   
 $we (5.4c) = 0.05179731$   
 $ase ((5.4d), TBDY) = (ase1 * A_{ext} + ase2 * A_{int}) / A_{sec} = 0.45746528$   
 $ase1 = Max(((A_{conf,max1} - A_{noConf1}) / A_{conf,max1}) * (A_{conf,min1} / A_{conf,max1}), 0) = 0.45746528$   
 The definitions of  $A_{noConf}$ ,  $A_{conf,min}$  and  $A_{conf,max}$  are derived from generalization of the rectangular sections confinement, which is expressed by (5.4d).  
 The generalization is done according to Mander, J., Priestley, M., and Park, R. (1988) "Theoretical Stress-Strain Model for Confined Concrete."  
 J. Struct. Eng., 10.1061/(ASCE)0733-9445(1988)114:8(1804), 1804-1826.  
 $A_{conf,max1} = 353600.00$  is the confined core area at levels of member with hoops and is calculated as the area of core enclosed by the center lines of the external perimeter hoops.  
 $A_{conf,min1} = 293525.00$  is the confined core area at midway between the levels of hoops and is calculated by reducing all the dimensions of the area  $A_{conf,max1}$  by a length equal to half the clear spacing between external hoops.  
 $A_{noConf1} = 158733.333$  is the unconfined external core area which is equal to  $b_i^2/6$  as defined at (A.2).  
 $ase2 (>= ase1) = Max(((A_{conf,max2} - A_{noConf2}) / A_{conf,max2}) * (A_{conf,min2} / A_{conf,max2}), 0) = 0.45746528$   
 The definitions of  $A_{noConf}$ ,  $A_{conf,min}$  and  $A_{conf,max}$  are derived from generalization of the rectangular sections confinement, which is expressed by (5.4d).  
 The generalization is done according to Mander, J., Priestley, M., and Park, R. (1988) "Theoretical Stress-Strain Model for Confined Concrete."  
 J. Struct. Eng., 10.1061/(ASCE)0733-9445(1988)114:8(1804), 1804-1826.  
 $A_{conf,max2} = 171264.00$  is the confined core area at levels of member with hoops and is calculated as the area of core enclosed by the center lines of the internal perimeter hoops.  
 $A_{conf,min2} = 54741.00$  is the confined core area at midway between the levels of hoops and is calculated by reducing all the dimensions of the area  $A_{conf,max2}$  by a length equal to half the clear spacing between internal hoops.  
 $A_{noConf2} = 106242.667$  is the unconfined internal core area which is equal to  $b_i^2/6$  as defined at (A.2).  
 $psh_{min} * F_{ywe} = Min(psh_x * F_{ywe}, psh_y * F_{ywe}) = 3.3968$

---

$psh_x * F_{ywe} = psh1 * F_{ywe1} + ps2 * F_{ywe2} = 3.3968$   
 $psh1 ((5.4d), TBDY) = L_{stir1} * A_{stir1} / (A_{sec} * s1) = 0.00367709$   
 $L_{stir1}$  (Length of stirrups along Y) = 2060.00  
 $A_{stir1}$  (stirrups area) = 78.53982  
 $psh2 (5.4d) = L_{stir2} * A_{stir2} / (A_{sec} * s2) = 0.00067082$   
 $L_{stir2}$  (Length of stirrups along Y) = 1468.00  
 $A_{stir2}$  (stirrups area) = 50.26548

---

$psh_y * F_{ywe} = psh1 * F_{ywe1} + ps2 * F_{ywe2} = 3.3968$   
 $psh1 ((5.4d), TBDY) = L_{stir1} * A_{stir1} / (A_{sec} * s1) = 0.00367709$   
 $L_{stir1}$  (Length of stirrups along X) = 2060.00  
 $A_{stir1}$  (stirrups area) = 78.53982  
 $psh2 ((5.4d), TBDY) = L_{stir2} * A_{stir2} / (A_{sec} * s2) = 0.00067082$   
 $L_{stir2}$  (Length of stirrups along X) = 1468.00  
 $A_{stir2}$  (stirrups area) = 50.26548

---

$A_{sec} = 440000.00$   
 $s1 = 100.00$   
 $s2 = 250.00$   
 $f_{ywe1} = 781.25$   
 $f_{ywe2} = 781.25$   
 $f_{ce} = 30.00$   
 From ((5.A5), TBDY), TBDY:  $cc = 0.00471045$   
 $c =$  confinement factor = 1.27105  
 $y1 = 0.00083886$   
 $sh1 = 0.00268436$   
 $ft1 = 314.5735$   
 $fy1 = 262.1446$   
 $su1 = 0.00268436$   
 using (30) in Biskinis/Fardis (2013) multiplied with shear\_factor

and also multiplied by the shear\_factor according to 15.7.1.4, with  
Shear\_factor = 1.00  
 $l_o/l_{ou,min} = l_b/l_d = 0.13907892$   
 $su_1 = 0.4 * esu_{1,nominal} ((5.5), TBDY) = 0.032$   
From table 5A.1, TBDY:  $esu_{1,nominal} = 0.08$ ,  
For calculation of  $esu_{1,nominal}$  and  $y_1, sh_1, ft_1, fy_1$ , it is considered  
characteristic value  $fsy_1 = fs_1/1.2$ , from table 5.1, TBDY.  
 $y_1, sh_1, ft_1, fy_1$ , are also multiplied by  $Min(1, 1.25 * (l_b/l_d)^{2/3})$ , from 10.3.5, ASCE 41-17.  
with  $fs_1 = (fs_{jacket} * Asl_{ten,jacket} + fs_{core} * Asl_{ten,core}) / Asl_{ten} = 262.1446$   
with  $Es_1 = (Es_{jacket} * Asl_{ten,jacket} + Es_{core} * Asl_{ten,core}) / Asl_{ten} = 200000.00$   
 $y_2 = 0.00083886$   
 $sh_2 = 0.00268436$   
 $ft_2 = 314.5735$   
 $fy_2 = 262.1446$   
 $su_2 = 0.00268436$   
using (30) in Biskinis/Fardis (2013) multiplied with shear\_factor  
and also multiplied by the shear\_factor according to 15.7.1.4, with  
Shear\_factor = 1.00  
 $l_o/l_{ou,min} = l_b/l_{b,min} = 0.13907892$   
 $su_2 = 0.4 * esu_{2,nominal} ((5.5), TBDY) = 0.032$   
From table 5A.1, TBDY:  $esu_{2,nominal} = 0.08$ ,  
For calculation of  $esu_{2,nominal}$  and  $y_2, sh_2, ft_2, fy_2$ , it is considered  
characteristic value  $fsy_2 = fs_2/1.2$ , from table 5.1, TBDY.  
 $y_2, sh_2, ft_2, fy_2$ , are also multiplied by  $Min(1, 1.25 * (l_b/l_d)^{2/3})$ , from 10.3.5, ASCE 41-17.  
with  $fs_2 = (fs_{jacket} * Asl_{com,jacket} + fs_{core} * Asl_{com,core}) / Asl_{com} = 262.1446$   
with  $Es_2 = (Es_{jacket} * Asl_{com,jacket} + Es_{core} * Asl_{com,core}) / Asl_{com} = 200000.00$   
 $y_v = 0.00083886$   
 $sh_v = 0.00268436$   
 $ft_v = 314.5735$   
 $fy_v = 262.1446$   
 $suv = 0.00268436$   
using (30) in Biskinis/Fardis (2013) multiplied with shear\_factor  
and also multiplied by the shear\_factor according to 15.7.1.4, with  
Shear\_factor = 1.00  
 $l_o/l_{ou,min} = l_b/l_d = 0.13907892$   
 $suv = 0.4 * esuv_{nominal} ((5.5), TBDY) = 0.032$   
From table 5A.1, TBDY:  $esuv_{nominal} = 0.08$ ,  
considering characteristic value  $fsyv = fsv/1.2$ , from table 5.1, TBDY  
For calculation of  $esuv_{nominal}$  and  $y_v, sh_v, ft_v, fy_v$ , it is considered  
characteristic value  $fsyv = fsv/1.2$ , from table 5.1, TBDY.  
 $y_1, sh_1, ft_1, fy_1$ , are also multiplied by  $Min(1, 1.25 * (l_b/l_d)^{2/3})$ , from 10.3.5, ASCE 41-17.  
with  $fsv = (fs_{jacket} * Asl_{mid,jacket} + fs_{mid} * Asl_{mid,core}) / Asl_{mid} = 262.1446$   
with  $Esv = (Es_{jacket} * Asl_{mid,jacket} + Es_{mid} * Asl_{mid,core}) / Asl_{mid} = 200000.00$   
 $1 = Asl_{ten} / (b * d) * (fs_1 / fc) = 0.06824101$   
 $2 = Asl_{com} / (b * d) * (fs_2 / fc) = 0.03513975$   
 $v = Asl_{mid} / (b * d) * (fsv / fc) = 0.06202846$   
and confined core properties:  
 $b = 340.00$   
 $d = 677.00$   
 $d' = 13.00$   
 $f_{cc} (5A.2, TBDY) = 38.13135$   
 $cc (5A.5, TBDY) = 0.00471045$   
 $c = \text{confinement factor} = 1.27105$   
 $1 = Asl_{ten} / (b * d) * (fs_1 / fc) = 0.08384116$   
 $2 = Asl_{com} / (b * d) * (fs_2 / fc) = 0.04317283$   
 $v = Asl_{mid} / (b * d) * (fsv / fc) = 0.07620839$   
Case/Assumption: Unconfined full section - Steel rupture  
'satisfies Eq. (4.3)  
--->  
 $v < v_{s,y2}$  - LHS eq.(4.5) is satisfied  
--->  
 $su (4.9) = 0.2584548$   
 $Mu = MRc (4.14) = 5.0296E+008$   
 $u = su (4.1) = 5.1201636E-006$

-----  
Calculation of ratio  $l_b/l_d$



Lap Length:  $l_b/l_d = 0.13907892$   
 $l_b = 300.00$   
 $l_d = 2157.049$   
 Calculation of  $l_b$ ,min according to (25.4.3.2), ACI 318-14, using mean values for all the section re-bars.  
 $l_d$ ,min from (25.4.3.2) is multiplied 2 times to account for smooth re-bars (9.1.2, TS500 - No provision in ACI 318)  
 $= 1$   
 $db = 16.66667$   
 Mean strength value of all re-bars:  $f_y = 781.25$   
 Mean concrete strength:  $f'_c = (f'_{c\_jacket} \cdot Area_{jacket} + f'_{c\_core} \cdot Area_{core}) / Area_{section} = 30.00$ , but  $f_c^{0.5} \leq 8.3$   
 MPa (22.5.3.1, ACI 318-14)  
 $t = 1.00$   
 $s = 0.80$   
 $e = 1.00$   
 $cb = 25.00$   
 $K_{tr} = 1.7174$   
 $A_{tr} = \text{Min}(A_{tr\_x}, A_{tr\_y}) = 257.6106$   
 where  $A_{tr\_x}$ ,  $A_{tr\_y}$  are the sum of the area of all stirrup legs along X and Y loxal axis  
 $s = \text{Max}(s_{external}, s_{internal}) = 250.00$   
 $n = 24.00$

Calculation of  $\mu_{2+}$

Calculation of ultimate curvature  $\mu$  according to 4.1, Biskinis/Fardis 2013:

$\mu = 4.8099118E-006$

$\mu_u = 2.3387E+008$

with full section properties:

$b = 750.00$

$d = 707.00$

$d' = 43.00$

$v = 0.00102301$

$N = 16273.608$

$f_c = 30.00$

$co$  (5A.5, TBDY) = 0.002

Final value of  $\mu_u$ :  $\mu_u = \text{shear\_factor} \cdot \text{Max}(\mu_u, \mu_c) = 0.01260361$

The Shear\_factor is considered equal to 1 (pure moment strength)

From (5.4b), TBDY:  $\mu_u = 0.01260361$

we (5.4c) = 0.05179731

$ase$  ((5.4d), TBDY) =  $(ase1 \cdot A_{ext} + ase2 \cdot A_{int}) / A_{sec} = 0.45746528$

$ase1 = \text{Max}(((A_{conf,max1} - A_{noConf1}) / A_{conf,max1}) \cdot (A_{conf,min1} / A_{conf,max1}), 0) = 0.45746528$

The definitions of  $A_{noConf}$ ,  $A_{conf,min}$  and  $A_{conf,max}$  are derived from generalization of the rectangular sections confinement, which is expressed by (5.4d).

The generalization is done according to Mander, J., Priestley, M., and Park, R. (1988)

"Theoretical Stress-Strain Model for Confined Concrete."

J. Struct. Eng., 10.1061/(ASCE)0733-9445(1988)114:8(1804), 1804-1826.

$A_{conf,max1} = 353600.00$  is the confined core area at levels of member with hoops and

is calculated as the area of core enclosed by the center lines of the external perimeter hoops.

$A_{conf,min1} = 293525.00$  is the confined core area at midway between the levels of hoops and

is calculated by reducing all the dimensions of the area  $A_{conf,max1}$  by a length equal to half the clear spacing between external hoops.

$A_{noConf1} = 158733.333$  is the unconfined external core area which is equal to  $b_i^2/6$  as defined at (A.2).

$ase2$  ( $\geq ase1$ ) =  $\text{Max}(((A_{conf,max2} - A_{noConf2}) / A_{conf,max2}) \cdot (A_{conf,min2} / A_{conf,max2}), 0) = 0.45746528$

The definitions of  $A_{noConf}$ ,  $A_{conf,min}$  and  $A_{conf,max}$  are derived from generalization

of the rectangular sections confinement, which is expressed by (5.4d).

The generalization is done according to Mander, J., Priestley, M., and Park, R. (1988)

"Theoretical Stress-Strain Model for Confined Concrete."

J. Struct. Eng., 10.1061/(ASCE)0733-9445(1988)114:8(1804), 1804-1826.

$A_{conf,max2} = 171264.00$  is the confined core area at levels of member with hoops and

is calculated as the area of core enclosed by the center lines of the internal perimeter hoops.

$A_{conf,min2} = 54741.00$  is the confined core area at midway between the levels of hoops and

is calculated by reducing all the dimensions of the area  $A_{conf,max2}$  by a length equal to half the clear spacing between internal hoops.

AnoConf2 = 106242.667 is the unconfined internal core area which is equal to  $b_i^2/6$  as defined at (A.2).  
 $psh_{min} \cdot F_{ywe} = \min(psh_x \cdot F_{ywe}, psh_y \cdot F_{ywe}) = 3.3968$

$psh_x \cdot F_{ywe} = psh1 \cdot F_{ywe1} + ps2 \cdot F_{ywe2} = 3.3968$   
 $psh1$  ((5.4d), TBDY) =  $Lstir1 \cdot Astir1 / (Asec \cdot s1) = 0.00367709$   
Lstir1 (Length of stirrups along Y) = 2060.00  
Astir1 (stirrups area) = 78.53982  
 $psh2$  (5.4d) =  $Lstir2 \cdot Astir2 / (Asec \cdot s2) = 0.00067082$   
Lstir2 (Length of stirrups along Y) = 1468.00  
Astir2 (stirrups area) = 50.26548

$psh_y \cdot F_{ywe} = psh1 \cdot F_{ywe1} + ps2 \cdot F_{ywe2} = 3.3968$   
 $psh1$  ((5.4d), TBDY) =  $Lstir1 \cdot Astir1 / (Asec \cdot s1) = 0.00367709$   
Lstir1 (Length of stirrups along X) = 2060.00  
Astir1 (stirrups area) = 78.53982  
 $psh2$  ((5.4d), TBDY) =  $Lstir2 \cdot Astir2 / (Asec \cdot s2) = 0.00067082$   
Lstir2 (Length of stirrups along X) = 1468.00  
Astir2 (stirrups area) = 50.26548

Asec = 440000.00  
s1 = 100.00  
s2 = 250.00  
fywe1 = 781.25  
fywe2 = 781.25  
fce = 30.00

From ((5.A5), TBDY), TBDY: cc = 0.00471045  
c = confinement factor = 1.27105

y1 = 0.00083886  
sh1 = 0.00268436  
ft1 = 314.5735  
fy1 = 262.1446  
su1 = 0.00268436

using (30) in Biskinis/Fardis (2013) multiplied with shear\_factor  
and also multiplied by the shear\_factor according to 15.7.1.4, with  
Shear\_factor = 1.00

lo/lou,min = lb/lb = 0.13907892  
su1 =  $0.4 \cdot esu1_{nominal}$  ((5.5), TBDY) = 0.032

From table 5A.1, TBDY: esu1\_nominal = 0.08,

For calculation of esu1\_nominal and y1, sh1, ft1, fy1, it is considered  
characteristic value fsy1 = fs1/1.2, from table 5.1, TBDY.

y1, sh1, ft1, fy1, are also multiplied by  $\min(1, 1.25 \cdot (lb/lb)^{2/3})$ , from 10.3.5, ASCE 41-17.

with fs1 =  $(fs_{jacket} \cdot Asl_{ten,jacket} + fs_{core} \cdot Asl_{ten,core}) / Asl_{ten} = 262.1446$

with Es1 =  $(Es_{jacket} \cdot Asl_{ten,jacket} + Es_{core} \cdot Asl_{ten,core}) / Asl_{ten} = 200000.00$

y2 = 0.00083886  
sh2 = 0.00268436  
ft2 = 314.5735  
fy2 = 262.1446  
su2 = 0.00268436

using (30) in Biskinis/Fardis (2013) multiplied with shear\_factor  
and also multiplied by the shear\_factor according to 15.7.1.4, with  
Shear\_factor = 1.00

lo/lou,min = lb/lb,min = 0.13907892  
su2 =  $0.4 \cdot esu2_{nominal}$  ((5.5), TBDY) = 0.032

From table 5A.1, TBDY: esu2\_nominal = 0.08,

For calculation of esu2\_nominal and y2, sh2, ft2, fy2, it is considered  
characteristic value fsy2 = fs2/1.2, from table 5.1, TBDY.

y1, sh1, ft1, fy1, are also multiplied by  $\min(1, 1.25 \cdot (lb/lb)^{2/3})$ , from 10.3.5, ASCE 41-17.

with fs2 =  $(fs_{jacket} \cdot Asl_{com,jacket} + fs_{core} \cdot Asl_{com,core}) / Asl_{com} = 262.1446$

with Es2 =  $(Es_{jacket} \cdot Asl_{com,jacket} + Es_{core} \cdot Asl_{com,core}) / Asl_{com} = 200000.00$

yv = 0.00083886  
shv = 0.00268436  
ftv = 314.5735  
fyv = 262.1446  
suv = 0.00268436

using (30) in Biskinis/Fardis (2013) multiplied with shear\_factor  
and also multiplied by the shear\_factor according to 15.7.1.4, with  
Shear\_factor = 1.00

$l_o/l_{ou,min} = l_b/l_d = 0.13907892$   
 $s_{uv} = 0.4 * e_{suv\_nominal} ((5.5), TBDY) = 0.032$   
 From table 5A.1, TBDY:  $e_{suv\_nominal} = 0.08$ ,  
 considering characteristic value  $f_{syv} = f_{sv}/1.2$ , from table 5.1, TBDY  
 For calculation of  $e_{suv\_nominal}$  and  $y_v$ ,  $sh_v$ ,  $ft_v$ ,  $f_{yv}$ , it is considered  
 characteristic value  $f_{syv} = f_{sv}/1.2$ , from table 5.1, TBDY.  
 $y_1$ ,  $sh_1$ ,  $ft_1$ ,  $f_{y1}$ , are also multiplied by  $\text{Min}(1, 1.25 * (l_b/l_d)^{2/3})$ , from 10.3.5, ASCE 41-17.  
 with  $f_{sv} = (f_{sj\_jacket} * A_{sl,mid,jacket} + f_{s,mid} * A_{sl,mid,core}) / A_{sl,mid} = 262.1446$   
 with  $E_{sv} = (E_{sj\_jacket} * A_{sl,mid,jacket} + E_{s,mid} * A_{sl,mid,core}) / A_{sl,mid} = 200000.00$   
 $1 = A_{sl,ten} / (b * d) * (f_{s1} / f_c) = 0.0187412$   
 $2 = A_{sl,com} / (b * d) * (f_{s2} / f_c) = 0.03639521$   
 $v = A_{sl,mid} / (b * d) * (f_{sv} / f_c) = 0.03308184$

and confined core properties:

$b = 690.00$   
 $d = 677.00$   
 $d' = 13.00$   
 $f_{cc} (5A.2, TBDY) = 38.13135$   
 $cc (5A.5, TBDY) = 0.00471045$   
 $c = \text{confinement factor} = 1.27105$   
 $1 = A_{sl,ten} / (b * d) * (f_{s1} / f_c) = 0.02127357$   
 $2 = A_{sl,com} / (b * d) * (f_{s2} / f_c) = 0.04131304$   
 $v = A_{sl,mid} / (b * d) * (f_{sv} / f_c) = 0.03755196$

Case/Assumption: Unconfined full section - Steel rupture

' satisfies Eq. (4.3)

--->

$v < v_{s,y2}$  - LHS eq.(4.5) is satisfied

--->

$su (4.9) = 0.21062322$   
 $M_u = M_{Rc} (4.14) = 2.3387E+008$   
 $u = su (4.1) = 4.8099118E-006$

Calculation of ratio  $l_b/l_d$

Lap Length:  $l_b/l_d = 0.13907892$

$l_b = 300.00$

$l_d = 2157.049$

Calculation of  $l_b,min$  according to (25.4.3.2), ACI 318-14, using mean values for all the section re-bars.

$l_d,min$  from (25.4.3.2) is multiplied 2 times to account for smooth re-bars (9.1.2, TS500 - No provision in ACI 318)

= 1

$db = 16.66667$

Mean strength value of all re-bars:  $f_y = 781.25$

Mean concrete strength:  $f'_c = (f'_{c\_jacket} * Area\_jacket + f'_{c\_core} * Area\_core) / Area\_section = 30.00$ , but  $f'_c^{0.5} \leq 8.3$  MPa (22.5.3.1, ACI 318-14)

$t = 1.00$

$s = 0.80$

$e = 1.00$

$cb = 25.00$

$K_{tr} = 1.7174$

$A_{tr} = \text{Min}(A_{tr\_x}, A_{tr\_y}) = 257.6106$

where  $A_{tr\_x}$ ,  $A_{tr\_y}$  are the sum of the area of all stirrup legs along X and Y local axis

$s = \text{Max}(s_{external}, s_{internal}) = 250.00$

$n = 24.00$

Calculation of  $M_{u2}$ -

Calculation of ultimate curvature  $\phi_u$  according to 4.1, Biskinis/Fardis 2013:

$u = 5.1201636E-006$

$M_u = 5.0296E+008$

with full section properties:

$b = 400.00$

$d = 707.00$

$d' = 43.00$   
 $v = 0.00191815$   
 $N = 16273.608$   
 $f_c = 30.00$   
 $co (5A.5, TBDY) = 0.002$   
 Final value of  $cu$ :  $cu^* = shear\_factor * Max(cu, cc) = 0.01260361$   
 The Shear\_factor is considered equal to 1 (pure moment strength)  
 From (5.4b), TBDY:  $cu = 0.01260361$   
 $we (5.4c) = 0.05179731$   
 $ase ((5.4d), TBDY) = (ase1 * A_{ext} + ase2 * A_{int}) / A_{sec} = 0.45746528$   
 $ase1 = Max(((A_{conf,max1} - A_{noConf1}) / A_{conf,max1}) * (A_{conf,min1} / A_{conf,max1}), 0) = 0.45746528$   
 The definitions of  $A_{noConf}$ ,  $A_{conf,min}$  and  $A_{conf,max}$  are derived from generalization of the rectangular sections confinement, which is expressed by (5.4d).  
 The generalization is done according to Mander, J., Priestley, M., and Park, R. (1988) "Theoretical Stress-Strain Model for Confined Concrete."  
 J. Struct. Eng., 10.1061/(ASCE)0733-9445(1988)114:8(1804), 1804-1826.  
 $A_{conf,max1} = 353600.00$  is the confined core area at levels of member with hoops and is calculated as the area of core enclosed by the center lines of the external perimeter hoops.  
 $A_{conf,min1} = 293525.00$  is the confined core area at midway between the levels of hoops and is calculated by reducing all the dimensions of the area  $A_{conf,max1}$  by a length equal to half the clear spacing between external hoops.  
 $A_{noConf1} = 158733.333$  is the unconfined external core area which is equal to  $b_i^2/6$  as defined at (A.2).  
 $ase2 (>= ase1) = Max(((A_{conf,max2} - A_{noConf2}) / A_{conf,max2}) * (A_{conf,min2} / A_{conf,max2}), 0) = 0.45746528$   
 The definitions of  $A_{noConf}$ ,  $A_{conf,min}$  and  $A_{conf,max}$  are derived from generalization of the rectangular sections confinement, which is expressed by (5.4d).  
 The generalization is done according to Mander, J., Priestley, M., and Park, R. (1988) "Theoretical Stress-Strain Model for Confined Concrete."  
 J. Struct. Eng., 10.1061/(ASCE)0733-9445(1988)114:8(1804), 1804-1826.  
 $A_{conf,max2} = 171264.00$  is the confined core area at levels of member with hoops and is calculated as the area of core enclosed by the center lines of the internal perimeter hoops.  
 $A_{conf,min2} = 54741.00$  is the confined core area at midway between the levels of hoops and is calculated by reducing all the dimensions of the area  $A_{conf,max2}$  by a length equal to half the clear spacing between internal hoops.  
 $A_{noConf2} = 106242.667$  is the unconfined internal core area which is equal to  $b_i^2/6$  as defined at (A.2).  
 $psh,min * F_{ywe} = Min(psh,x * F_{ywe}, psh,y * F_{ywe}) = 3.3968$

---

$psh_x * F_{ywe} = psh1 * F_{ywe1} + ps2 * F_{ywe2} = 3.3968$   
 $psh1 ((5.4d), TBDY) = L_{stir1} * A_{stir1} / (A_{sec} * s1) = 0.00367709$   
 $L_{stir1}$  (Length of stirrups along Y) = 2060.00  
 $A_{stir1}$  (stirrups area) = 78.53982  
 $psh2 (5.4d) = L_{stir2} * A_{stir2} / (A_{sec} * s2) = 0.00067082$   
 $L_{stir2}$  (Length of stirrups along Y) = 1468.00  
 $A_{stir2}$  (stirrups area) = 50.26548

---

$psh_y * F_{ywe} = psh1 * F_{ywe1} + ps2 * F_{ywe2} = 3.3968$   
 $psh1 ((5.4d), TBDY) = L_{stir1} * A_{stir1} / (A_{sec} * s1) = 0.00367709$   
 $L_{stir1}$  (Length of stirrups along X) = 2060.00  
 $A_{stir1}$  (stirrups area) = 78.53982  
 $psh2 ((5.4d), TBDY) = L_{stir2} * A_{stir2} / (A_{sec} * s2) = 0.00067082$   
 $L_{stir2}$  (Length of stirrups along X) = 1468.00  
 $A_{stir2}$  (stirrups area) = 50.26548

---

$A_{sec} = 440000.00$   
 $s1 = 100.00$   
 $s2 = 250.00$   
 $f_{ywe1} = 781.25$   
 $f_{ywe2} = 781.25$   
 $f_{ce} = 30.00$   
 From ((5.A5), TBDY), TBDY:  $cc = 0.00471045$   
 $c =$  confinement factor = 1.27105  
 $y1 = 0.00083886$   
 $sh1 = 0.00268436$   
 $ft1 = 314.5735$   
 $fy1 = 262.1446$   
 $su1 = 0.00268436$   
 using (30) in Biskinis/Fardis (2013) multiplied with shear\_factor and also multiplied by the shear\_factor according to 15.7.1.4, with

```

Shear_factor = 1.00
lo/lou,min = lb/ld = 0.13907892
su1 = 0.4*esu1_nominal ((5.5), TBDY) = 0.032
From table 5A.1, TBDY: esu1_nominal = 0.08,
For calculation of esu1_nominal and y1, sh1,ft1,fy1, it is considered
characteristic value fsy1 = fs1/1.2, from table 5.1, TBDY.
y1, sh1,ft1,fy1, are also multiplied by Min(1,1.25*(lb/ld)^ 2/3), from 10.3.5, ASCE 41-17.
with fs1 = (fs,jacket*Asl,ten,jacket + fs,core*Asl,ten,core)/Asl,ten = 262.1446
with Es1 = (Es,jacket*Asl,ten,jacket + Es,core*Asl,ten,core)/Asl,ten = 200000.00
y2 = 0.00083886
sh2 = 0.00268436
ft2 = 314.5735
fy2 = 262.1446
su2 = 0.00268436
using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00
lo/lou,min = lb/lb,min = 0.13907892
su2 = 0.4*esu2_nominal ((5.5), TBDY) = 0.032
From table 5A.1, TBDY: esu2_nominal = 0.08,
For calculation of esu2_nominal and y2, sh2,ft2,fy2, it is considered
characteristic value fsy2 = fs2/1.2, from table 5.1, TBDY.
y1, sh1,ft1,fy1, are also multiplied by Min(1,1.25*(lb/ld)^ 2/3), from 10.3.5, ASCE 41-17.
with fs2 = (fs,jacket*Asl,com,jacket + fs,core*Asl,com,core)/Asl,com = 262.1446
with Es2 = (Es,jacket*Asl,com,jacket + Es,core*Asl,com,core)/Asl,com = 200000.00
yv = 0.00083886
shv = 0.00268436
ftv = 314.5735
fyv = 262.1446
suv = 0.00268436
using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00
lo/lou,min = lb/ld = 0.13907892
suv = 0.4*esuv_nominal ((5.5), TBDY) = 0.032
From table 5A.1, TBDY: esuv_nominal = 0.08,
considering characteristic value fsyv = fsv/1.2, from table 5.1, TBDY
For calculation of esuv_nominal and yv, shv,ftv,fyv, it is considered
characteristic value fsyv = fsv/1.2, from table 5.1, TBDY.
y1, sh1,ft1,fy1, are also multiplied by Min(1,1.25*(lb/ld)^ 2/3), from 10.3.5, ASCE 41-17.
with fsv = (fs,jacket*Asl,mid,jacket + fs,mid*Asl,mid,core)/Asl,mid = 262.1446
with Esv = (Es,jacket*Asl,mid,jacket + Es,mid*Asl,mid,core)/Asl,mid = 200000.00
1 = Asl,ten/(b*d)*(fs1/fc) = 0.06824101
2 = Asl,com/(b*d)*(fs2/fc) = 0.03513975
v = Asl,mid/(b*d)*(fsv/fc) = 0.06202846
and confined core properties:
b = 340.00
d = 677.00
d' = 13.00
fcc (5A.2, TBDY) = 38.13135
cc (5A.5, TBDY) = 0.00471045
c = confinement factor = 1.27105
1 = Asl,ten/(b*d)*(fs1/fc) = 0.08384116
2 = Asl,com/(b*d)*(fs2/fc) = 0.04317283
v = Asl,mid/(b*d)*(fsv/fc) = 0.07620839
Case/Assumption: Unconfined full section - Steel rupture
' satisfies Eq. (4.3)
--->
v < vsy2 - LHS eq.(4.5) is satisfied
--->
su (4.9) = 0.2584548
Mu = MRc (4.14) = 5.0296E+008
u = su (4.1) = 5.1201636E-006

```

Calculation of ratio lb/ld

Lap Length:  $l_b/l_d = 0.13907892$   
 $l_b = 300.00$   
 $l_d = 2157.049$   
 Calculation of  $l_b$ , min according to (25.4.3.2), ACI 318-14, using mean values for all the section re-bars.  
 $l_d$ , min from (25.4.3.2) is multiplied 2 times to account for smooth re-bars (9.1.2, TS500 - No provision in ACI 318)  
 $= 1$   
 $db = 16.66667$   
 Mean strength value of all re-bars:  $f_y = 781.25$   
 Mean concrete strength:  $f'_c = (f'_{c\_jacket} \cdot Area_{jacket} + f'_{c\_core} \cdot Area_{core}) / Area_{section} = 30.00$ , but  $f_c^{0.5} \leq 8.3$   
 MPa (22.5.3.1, ACI 318-14)  
 $t = 1.00$   
 $s = 0.80$   
 $e = 1.00$   
 $cb = 25.00$   
 $K_{tr} = 1.7174$   
 $A_{tr} = \text{Min}(A_{tr\_x}, A_{tr\_y}) = 257.6106$   
 where  $A_{tr\_x}$ ,  $A_{tr\_y}$  are the sum of the area of all stirrup legs along X and Y loxal axis  
 $s = \text{Max}(s_{external}, s_{internal}) = 250.00$   
 $n = 24.00$

Calculation of Shear Strength  $V_r = \text{Min}(V_{r1}, V_{r2}) = 1.0392E+006$

Calculation of Shear Strength at edge 1,  $V_{r1} = 1.0392E+006$

$V_{r1} = V_{Col} \text{ ((10.3), ASCE 41-17)} = k_{nl} \cdot V_{Col0}$

$V_{Col0} = 1.0392E+006$

$k_{nl} = 1$  (zero step-static loading)

NOTE: In expression (10-3) ' $V_s = A_v \cdot f_y \cdot d / s$ ' is replaced by ' $V_s + f \cdot V_f$ '  
 where  $V_f$  is the contribution of FRPs (11.3), ACI 440).

$= 1$  (normal-weight concrete)

Mean concrete strength:  $f'_c = (f'_{c\_jacket} \cdot Area_{jacket} + f'_{c\_core} \cdot Area_{core}) / Area_{section} = 30.00$ , but  $f_c^{0.5} \leq 8.3$   
 MPa (22.5.3.1, ACI 318-14)

$M/Vd = 4.00$

$\mu_u = 1308.675$

$V_u = 0.0001715$

$d = 0.8 \cdot h = 600.00$

$N_u = 16273.608$

$A_g = 300000.00$

From (11.5.4.8), ACI 318-14:  $V_s = V_{s,jacket} + V_{s,core} = 1.0138E+006$

where:

$V_{s,jacket} = V_{s,j1} + V_{s,j2} = 903207.888$

$V_{s,j1} = 314159.265$  is calculated for section web jacket, with:

$d = 320.00$

$A_v = 157079.633$

$f_y = 625.00$

$s = 100.00$

$V_{s,j1}$  is multiplied by  $Col,j1 = 1.00$

$s/d = 0.3125$

$V_{s,j2} = 589048.623$  is calculated for section flange jacket, with:

$d = 600.00$

$A_v = 157079.633$

$f_y = 625.00$

$s = 100.00$

$V_{s,j2}$  is multiplied by  $Col,j2 = 1.00$

$s/d = 0.16666667$

$V_{s,core} = V_{s,c1} + V_{s,c2} = 110584.061$

$V_{s,c1} = 0.00$  is calculated for section web core, with:

$d = 160.00$

$A_v = 100530.965$

$f_y = 625.00$

$s = 250.00$

$V_{s,c1}$  is multiplied by  $Col,c1 = 0.00$

$s/d = 1.5625$

$V_{s,c2} = 110584.061$  is calculated for section flange core, with:

$$d = 440.00$$

$$A_v = 100530.965$$

$$f_y = 625.00$$

$$s = 250.00$$

$V_{s,c2}$  is multiplied by  $Col,c2 = 1.00$

$$s/d = 0.56818182$$

$V_f ((11-3)-(11.4), ACI 440) = 0.00$

From (11-11), ACI 440:  $V_s + V_f \leq 873250.061$

$$bw = 400.00$$

Calculation of Shear Strength at edge 2,  $V_{r2} = 1.0392E+006$

$V_{r2} = V_{Col} ((10.3), ASCE 41-17) = knl * V_{Col0}$

$$V_{Col0} = 1.0392E+006$$

$kn1 = 1$  (zero step-static loading)

NOTE: In expression (10-3) ' $V_s = A_v * f_y * d / s$ ' is replaced by ' $V_s + f * V_f$ ' where  $V_f$  is the contribution of FRPs (11.3), ACI 440).

$= 1$  (normal-weight concrete)

Mean concrete strength:  $f_c' = (f_c'_{jacket} * Area_{jacket} + f_c'_{core} * Area_{core}) / Area_{section} = 30.00$ , but  $f_c'^{0.5} \leq 8.3$  MPa (22.5.3.1, ACI 318-14)

$$M/Vd = 4.00$$

$$\mu_u = 1308.675$$

$$\nu_u = 0.0001715$$

$$d = 0.8 * h = 600.00$$

$$\mu_u = 16273.608$$

$$A_g = 300000.00$$

From (11.5.4.8), ACI 318-14:  $V_s = V_{sjacket} + V_{s,core} = 1.0138E+006$

where:

$$V_{sjacket} = V_{sj1} + V_{sj2} = 903207.888$$

$V_{sj1} = 314159.265$  is calculated for section web jacket, with:

$$d = 320.00$$

$$A_v = 157079.633$$

$$f_y = 625.00$$

$$s = 100.00$$

$V_{sj1}$  is multiplied by  $Col,j1 = 1.00$

$$s/d = 0.3125$$

$V_{sj2} = 589048.623$  is calculated for section flange jacket, with:

$$d = 600.00$$

$$A_v = 157079.633$$

$$f_y = 625.00$$

$$s = 100.00$$

$V_{sj2}$  is multiplied by  $Col,j2 = 1.00$

$$s/d = 0.16666667$$

$$V_{s,core} = V_{s,c1} + V_{s,c2} = 110584.061$$

$V_{s,c1} = 0.00$  is calculated for section web core, with:

$$d = 160.00$$

$$A_v = 100530.965$$

$$f_y = 625.00$$

$$s = 250.00$$

$V_{s,c1}$  is multiplied by  $Col,c1 = 0.00$

$$s/d = 1.5625$$

$V_{s,c2} = 110584.061$  is calculated for section flange core, with:

$$d = 440.00$$

$$A_v = 100530.965$$

$$f_y = 625.00$$

$$s = 250.00$$

$V_{s,c2}$  is multiplied by  $Col,c2 = 1.00$

$$s/d = 0.56818182$$

$V_f ((11-3)-(11.4), ACI 440) = 0.00$

From (11-11), ACI 440:  $V_s + V_f \leq 873250.061$

$$bw = 400.00$$

End Of Calculation of Shear Capacity ratio for element: column JLC1 of floor 1

At local axis: 2

Start Of Calculation of Chord Rotation Capacity for element: column JLC1 of floor 1

At local axis: 3

Integration Section: (a)

Section Type: rcjlc3

#### Constant Properties

Knowledge Factor,  $\gamma = 1.00$

Chord Rotation is generally considered as Deformation-Controlled Action according to Table C7-1, ASCE 41-17.

Mean strengths are used for Deformation-Controlled Actions according to 7.5.1.3, ASCE 41-17

Consequently:

Jacket

New material of Primary Member: Concrete Strength,  $f_c = f_{cm} = 30.00$

New material of Primary Member: Steel Strength,  $f_s = f_{sm} = 625.00$

Concrete Elasticity,  $E_c = 25742.96$

Steel Elasticity,  $E_s = 200000.00$

Existing Column

New material of Primary Member: Concrete Strength,  $f_c = f_{cm} = 30.00$

New material of Primary Member: Steel Strength,  $f_s = f_{sm} = 625.00$

Concrete Elasticity,  $E_c = 25742.96$

Steel Elasticity,  $E_s = 200000.00$

Max Height,  $H_{max} = 750.00$

Min Height,  $H_{min} = 400.00$

Max Width,  $W_{max} = 750.00$

Min Width,  $W_{min} = 400.00$

Jacket Thickness,  $t_j = 100.00$

Cover Thickness,  $c = 25.00$

Element Length,  $L = 3000.00$

Primary Member

Smooth Bars

Ductile Steel

With Detailing for Earthquake Resistance (including stirrups closed at  $135^\circ$ )

Longitudinal Bars With Ends Lapped Starting at the End Sections

Lap Length  $l_b = 300.00$

No FRP Wrapping

#### Stepwise Properties

Bending Moment,  $M = -1.4730E+007$

Shear Force,  $V_2 = -4846.489$

Shear Force,  $V_3 = 135.9404$

Axial Force,  $F = -17232.621$

Longitudinal Reinforcement Area Distribution (in 2 divisions)

-Tension:  $A_{sl,t} = 0.00$

-Compression:  $A_{sl,c} = 5353.274$

Longitudinal Reinforcement Area Distribution (in 3 divisions)

-Tension:  $A_{sl,ten} = 1137.257$

-Compression:  $A_{sl,com} = 2208.54$

-Middle:  $A_{sl,mid} = 2007.478$

Longitudinal External Reinforcement Area Distribution (in 3 divisions)

-Tension:  $A_{sl,ten,jacket} = 829.3805$

-Compression:  $A_{sl,com,jacket} = 1746.726$

-Middle:  $A_{sl,mid,jacket} = 1545.664$

Longitudinal Internal Reinforcement Area Distribution (in 3 divisions)

-Tension:  $A_{sl,ten,core} = 307.8761$

-Compression:  $A_{sl,com,core} = 461.8141$

-Middle:  $A_{sl,mid,core} = 461.8141$

Mean Diameter of Tension Reinforcement,  $Db_L = 16.80$



New component: From table 7-7, ASCE 41\_17: Final chord rotation Capacity  $u_R = 1.0$   $u = 0.0019965$   
 $u = y + p = 0.0019965$

- Calculation of  $y$  -

$y = (M_y * L_s / 3) / E_{eff} = 0.0019965 ((4.29), \text{Biskinis Phd})$   
 $M_y = 2.8693E+008$   
 $L_s = M/V$  (with  $L_s > 0.1 * L$  and  $L_s < 2 * L$ ) = 3039.252  
From table 10.5, ASCE 41\_17:  $E_{eff} = \text{factor} * E_c * I_g = 1.4560E+014$   
 $\text{factor} = 0.30$   
 $A_g = 440000.00$   
Mean concrete strength:  $f'_c = (f'_{c\_jacket} * \text{Area}_{jacket} + f'_{c\_core} * \text{Area}_{core}) / \text{Area}_{section} = 30.00$   
 $N = 17232.621$   
 $E_c * I_g = E_{c\_jacket} * I_{g\_jacket} + E_{c\_core} * I_{g\_core} = 4.8532E+014$

Calculation of Yielding Moment  $M_y$

Calculation of  $y$  and  $M_y$  according to Annex 7 -

Assuming neutral axis within flange ( $y < t/d$ , compression zone rectangular) with:

flange width,  $b = 750.00$   
web width,  $b_w = 400.00$   
flange thickness,  $t = 400.00$

$y = \text{Min}(y_{ten}, y_{com})$   
 $y_{ten} = 2.1452649E-006$   
with ((10.1), ASCE 41-17)  $f_y = \text{Min}(f_y, 1.25 * f_y * (I_b / I_d)^{2/3}) = 243.3535$   
 $d = 707.00$   
 $y = 0.1977546$   
 $A = 0.0102293$   
 $B = 0.00453971$   
with  $p_t = 0.00434791$   
 $p_c = 0.00416509$   
 $p_v = 0.00378591$   
 $N = 17232.621$   
 $b = 750.00$   
 $" = 0.06082037$   
 $y_{comp} = 1.5203329E-005$   
with  $f_c = 30.00$   
 $E_c = 25742.96$   
 $y = 0.19515388$   
 $A = 0.01001829$   
 $B = 0.00440616$   
with  $E_s = 200000.00$   
CONFIRMATION:  $y = 0.19591085 < t/d$

Calculation of ratio  $I_b / I_d$

Lap Length:  $I_d / I_{d,min} = 0.17384865$   
 $I_b = 300.00$   
 $I_d = 1725.639$   
Calculation of  $I$  according to (25.4.3.2), ACI 318-14, using mean values for all the section re-bars.  
 $I_{d,min}$  from (25.4.3.2) is multiplied 2 times to account for smooth re-bars (10.3.5, ASCE 41-17)  
 $= 1$   
 $db = 16.66667$   
Mean strength value of all re-bars:  $f_y = 625.00$   
Mean concrete strength:  $f'_c = (f'_{c\_jacket} * \text{Area}_{jacket} + f'_{c\_core} * \text{Area}_{core}) / \text{Area}_{section} = 30.00$ , but  $f_c^{0.5} \leq 8.3$  MPa (22.5.3.1, ACI 318-14)  
 $t = 1.00$   
 $s = 0.80$   
 $e = 1.00$

$$c_b = 25.00$$

$$K_{tr} = 1.7174$$

$$A_{tr} = \min(A_{tr_x}, A_{tr_y}) = 257.6106$$

where  $A_{tr_x}$ ,  $A_{tr_y}$  are the sum of the area of all stirrup legs along X and Y local axis

$$s = \max(s_{external}, s_{internal}) = 250.00$$

$$n = 24.00$$

- Calculation of  $p$  -

From table 10-8:  $p = 0.00$

with:

- Columns controlled by inadequate development or splicing along the clear height because  $l_b/l_d < 1$

$$\text{shear control ratio } V_y E / V_{Col} E = 0.32266369$$

$$d = d_{external} = 707.00$$

$$s = s_{external} = 0.00$$

$$- t = s_1 + s_2 + 2 \cdot t_f / b_w \cdot (f_{fe} / f_s) = 0.00434791$$

$$\text{jacket: } s_1 = A_{v1} \cdot L_{stir1} / (s_1 \cdot A_g) = 0.00367709$$

$A_{v1} = 78.53982$ , is the area of every stirrup parallel to loading (shear) direction

$L_{stir1} = 2060.00$ , is the total Length of all stirrups parallel to loading (shear) direction

$$s_1 = 100.00$$

$$\text{core: } s_2 = A_{v2} \cdot L_{stir2} / (s_2 \cdot A_g) = 0.00067082$$

$A_{v2} = 50.26548$ , is the area of every stirrup parallel to loading (shear) direction

$L_{stir2} = 1468.00$ , is the total Length of all stirrups parallel to loading (shear) direction

$$s_2 = 250.00$$

The term  $2 \cdot t_f / b_w \cdot (f_{fe} / f_s)$  is implemented to account for FRP contribution

where  $f = 2 \cdot t_f / b_w$  is FRP ratio (EC8 - 3, A.4.4.3(6)) and  $f_{fe} / f_s$  normalises  $f$  to steel strength

All these variables have already been given in Shear control ratio calculation.

For the normalisation  $f_s$  of jacket is used.

$$N_{UD} = 17232.621$$

$$A_g = 440000.00$$

$$f_{cE} = (f_{c\_jacket} \cdot \text{Area\_jacket} + f_{c\_core} \cdot \text{Area\_core}) / \text{section\_area} = 30.00$$

$$f_{yE} = (f_{y\_ext\_Long\_Reinf} \cdot \text{Area\_ext\_Long\_Reinf} + f_{y\_int\_Long\_Reinf} \cdot \text{Area\_int\_Long\_Reinf}) / \text{Area\_Tot\_Long\_Rein} = 625.00$$

$$f_{ytE} = (f_{y\_ext\_Trans\_Reinf} \cdot s_1 + f_{y\_int\_Trans\_Reinf} \cdot s_2) / (s_1 + s_2) = 625.00$$

$$\rho_l = \text{Area\_Tot\_Long\_Rein} / (b \cdot d) = 0.01009575$$

$$b = 750.00$$

$$d = 707.00$$

$$f_{cE} = 30.00$$

End Of Calculation of Chord Rotation Capacity for element: column JLC1 of floor 1

At local axis: 3

Integration Section: (a)

## Calculation No. 5

column C1, Floor 1


Limit State: Operational Level (data interpolation between analysis steps 1 and 2)

Analysis: Uniform +X

Check: Shear capacity VRd

Edge: End

Local Axis: (2)



Start Of Calculation of Shear Capacity for element: column JLC1 of floor 1

At local axis: 2

Integration Section: (b)

Section Type: rcjls

Constant Properties

Knowledge Factor,  $\gamma = 1.00$

Member Shear Force is generally considered as Force-Controlled Action according to Table C7-1, ASCE 41-17.

Lower-bound strengths are used for Force-Controlled Actions according to 7.5.1.3, ASCE 41-17

Consequently:

Jacket

New material of Primary Member: Concrete Strength,  $f_c = f_{c\_lower\_bound} = 20.00$

New material of Primary Member: Steel Strength,  $f_s = f_{s\_lower\_bound} = 500.00$

Concrete Elasticity,  $E_c = 25742.96$

Steel Elasticity,  $E_s = 200000.00$

Existing Column

New material of Primary Member: Concrete Strength,  $f_c = f_{c\_lower\_bound} = 20.00$

New material of Primary Member: Steel Strength,  $f_s = f_{s\_lower\_bound} = 500.00$

Concrete Elasticity,  $E_c = 25742.96$

Steel Elasticity,  $E_s = 200000.00$

#####

Note: Especially for the calculation of  $\gamma$  for displacement ductility demand, the expected (mean value) strengths are used (7.5.1.3, ASCE 41-17) because bending is considered as Deformation-Controlled Action (Table C7-1, ASCE 41-17).

Jacket

New material: Concrete Strength,  $f_c = f_{cm} = 30.00$

New material: Steel Strength,  $f_s = f_{sm} = 625.00$

Existing Column

New material: Concrete Strength,  $f_c = f_{cm} = 30.00$

New material: Steel Strength,  $f_s = f_{sm} = 625.00$

#####

Max Height,  $H_{max} = 750.00$

Min Height,  $H_{min} = 400.00$

Max Width,  $W_{max} = 750.00$

Min Width,  $W_{min} = 400.00$

Jacket Thickness,  $t_j = 100.00$

Cover Thickness,  $c = 25.00$

Element Length,  $L = 3000.00$

Primary Member  
Smooth Bars  
Ductile Steel  
With Detailing for Earthquake Resistance (including stirrups closed at 135°)  
Longitudinal Bars With Ends Lapped Starting at the End Sections  
Lap Length  $l_o = l_b = 300.00$   
No FRP Wrapping

#### Stepwise Properties

EDGE -A-  
Bending Moment,  $M_a = -1.4730E+007$   
Shear Force,  $V_a = -4846.489$   
EDGE -B-  
Bending Moment,  $M_b = 186273.79$   
Shear Force,  $V_b = 4846.489$   
BOTH EDGES  
Axial Force,  $F = -17232.621$   
Longitudinal Reinforcement Area Distribution (in 2 divisions)  
-Tension:  $A_{sl,t} = 0.00$   
-Compression:  $A_{sl,c} = 5353.274$   
Longitudinal Reinforcement Area Distribution (in 3 divisions)  
-Tension:  $A_{sl,ten} = 1137.257$   
-Compression:  $A_{sl,com} = 2208.54$   
-Middle:  $A_{sl,mid} = 2007.478$   
Mean Diameter of Tension Reinforcement,  $Db_{L,ten} = 16.80$

New component: From table 7-7, ASCE 41\_17: Final Shear Capacity  $V_R = 1.0 \cdot V_n = 984758.516$   
 $V_n$  ((10.3), ASCE 41-17) =  $k_n \cdot V_{CoI} = 984758.516$   
 $V_{CoI} = 984758.516$   
 $k_n = 1.00$   
 $displacement\_ductility\_demand = 0.07913193$

NOTE: In expression (10-3) ' $V_s = A_v \cdot f_y \cdot d/s$ ' is replaced by ' $V_{s+} = f \cdot V_f$ '  
where  $V_f$  is the contribution of FRPs ((11.3), ACI 440).

= 1 (normal-weight concrete)  
Mean concrete strength:  $f'_c = (f'_{c\_jacket} \cdot Area\_jacket + f'_{c\_core} \cdot Area\_core) / Area\_section = 20.00$ , but  $f'_c^{0.5} \leq 8.3$   
MPa ((22.5.3.1, ACI 318-14))  
 $M/V_d = 2.00$   
 $\mu_u = 186273.79$   
 $V_u = 4846.489$   
 $d = 0.8 \cdot h = 600.00$   
 $N_u = 17232.621$   
 $A_g = 300000.00$   
From ((11.5.4.8), ACI 318-14:  $V_s = V_{sjacket} + V_{s,core} = 811033.559$   
where:  
 $V_{sjacket} = V_{sj1} + V_{sj2} = 722566.31$   
 $V_{sj1} = 251327.412$  is calculated for section web jacket, with:  
 $d = 320.00$   
 $A_v = 157079.633$   
 $f_y = 500.00$   
 $s = 100.00$   
 $V_{sj1}$  is multiplied by  $Col_{j1} = 1.00$   
 $s/d = 0.3125$   
 $V_{sj2} = 471238.898$  is calculated for section flange jacket, with:  
 $d = 600.00$   
 $A_v = 157079.633$   
 $f_y = 500.00$   
 $s = 100.00$   
 $V_{sj2}$  is multiplied by  $Col_{j2} = 1.00$   
 $s/d = 0.16666667$   
 $V_{s,core} = V_{s,c1} + V_{s,c2} = 88467.249$

$V_{s,c1} = 0.00$  is calculated for section web core, with:

$$d = 160.00$$

$$A_v = 100530.965$$

$$f_y = 500.00$$

$$s = 250.00$$

$V_{s,c1}$  is multiplied by  $Col,c1 = 0.00$

$$s/d = 1.5625$$

$V_{s,c2} = 88467.249$  is calculated for section flange core, with:

$$d = 440.00$$

$$A_v = 100530.965$$

$$f_y = 500.00$$

$$s = 250.00$$

$V_{s,c2}$  is multiplied by  $Col,c2 = 1.00$

$$s/d = 0.56818182$$

$V_f ((11-3)-(11.4), ACI 440) = 0.00$

From (11-11), ACI 440:  $V_s + V_f \leq 713005.69$

$$bw = 400.00$$

displacement\_ductility\_demand is calculated as  $\phi / y$

- Calculation of  $\phi / y$  for END B -

for rotation axis 3 and integ. section (b)

From analysis, chord rotation  $\theta = 1.5594637E-005$

$$y = (M_y * L_s / 3) / E_{eff} = 0.00019707 ((4.29), Biskinis Phd)$$

$$M_y = 2.8693E+008$$

$$L_s = M/V \text{ (with } L_s > 0.1 * L \text{ and } L_s < 2 * L) = 300.00$$

From table 10.5, ASCE 41\_17:  $E_{eff} = factor * E_c * I_g = 1.4560E+014$

$$factor = 0.30$$

$$A_g = 440000.00$$

$$\text{Mean concrete strength: } f'_c = (f'_{c\_jacket} * Area\_jacket + f'_{c\_core} * Area\_core) / Area\_section = 30.00$$

$$N = 17232.621$$

$$E_c * I_g = E_{c\_jacket} * I_{g\_jacket} + E_{c\_core} * I_{g\_core} = 4.8532E+014$$

Calculation of Yielding Moment  $M_y$

Calculation of  $\phi / y$  and  $M_y$  according to Annex 7 -

Assuming neutral axis within flange ( $y < t/d$ , compression zone rectangular) with:

flange width,  $b = 750.00$

web width,  $bw = 400.00$

flange thickness,  $t = 400.00$

$$y = \text{Min}(y_{ten}, y_{com})$$

$$y_{ten} = 2.1452649E-006$$

$$\text{with } ((10.1), ASCE 41-17) f_y = \text{Min}(f_y, 1.25 * f_y * (I_b / I_d)^{2/3}) = 243.3535$$

$$d = 707.00$$

$$y = 0.1977546$$

$$A = 0.0102293$$

$$B = 0.00453971$$

$$\text{with } p_t = 0.00214476$$

$$p_c = 0.00416509$$

$$p_v = 0.00378591$$

$$N = 17232.621$$

$$b = 750.00$$

$$\rho = 0.06082037$$

$$y_{comp} = 1.5203329E-005$$

with  $f'_c = 30.00$

$$E_c = 25742.96$$

$$y = 0.19515388$$

$$A = 0.01001829$$

$$B = 0.00440616$$

$$\text{with } E_s = 200000.00$$

CONFIRMATION:  $y = 0.19591085 < t/d$

Calculation of ratio  $l_b/l_d$

Lap Length:  $l_d/l_{d,min} = 0.17384865$

$l_b = 300.00$

$l_d = 1725.639$

Calculation of  $l$  according to (25.4.3.2), ACI 318-14, using mean values for all the section re-bars.

$l_{d,min}$  from (25.4.3.2) is multiplied 2 times to account for smooth re-bars (10.3.5, ASCE 41-17)

$= 1$

$db = 16.66667$

Mean strength value of all re-bars:  $f_y = 625.00$

Mean concrete strength:  $f'_c = (f'_{c,jacket} \cdot Area_{jacket} + f'_{c,core} \cdot Area_{core}) / Area_{section} = 30.00$ , but  $f_c^{0.5} \leq 8.3$  MPa (22.5.3.1, ACI 318-14)

$t = 1.00$

$s = 0.80$

$e = 1.00$

$cb = 25.00$

$K_{tr} = 1.7174$

$A_{tr} = \min(A_{tr,x}, A_{tr,y}) = 257.6106$

where  $A_{tr,x}$ ,  $A_{tr,y}$  are the sum of the area of all stirrup legs along X and Y local axis

$s = \max(s_{external}, s_{internal}) = 250.00$

$n = 24.00$

End Of Calculation of Shear Capacity for element: column JLC1 of floor 1

At local axis: 2

Integration Section: (b)

## Calculation No. 6

column C1, Floor 1



Limit State: Operational Level (data interpolation between analysis steps 1 and 2)

Analysis: Uniform +X

Check: Chord rotation capacity ( $\phi$ )

Edge: End

Local Axis: (2)



Start Of Calculation of Shear Capacity ratio for element: column JLC1 of floor 1

At Shear local axis: 3

(Bending local axis: 2)

Section Type: rcjlc

#### Constant Properties

Knowledge Factor,  $\gamma = 1.00$

Mean strength values are used for both shear and moment calculations.

Consequently:

Jacket

New material of Primary Member: Concrete Strength,  $f_c = f_{cm} = 30.00$

New material of Primary Member: Steel Strength,  $f_s = f_{sm} = 625.00$

Concrete Elasticity,  $E_c = 25742.96$

Steel Elasticity,  $E_s = 200000.00$

Existing Column

New material of Primary Member: Concrete Strength,  $f_c = f_{cm} = 30.00$

New material of Primary Member: Steel Strength,  $f_s = f_{sm} = 625.00$

Concrete Elasticity,  $E_c = 25742.96$

Steel Elasticity,  $E_s = 200000.00$

#####

Note: Especially for the calculation of moment strengths,

the above steel re-bar strengths are multiplied by 1.25 according to R18.6.5, ACI 318-14

Jacket

New material: Steel Strength,  $f_s = 1.25 \cdot f_{sm} = 781.25$

Existing Column

New material: Steel Strength,  $f_s = 1.25 \cdot f_{sm} = 781.25$

#####

Max Height,  $H_{max} = 750.00$

Min Height,  $H_{min} = 400.00$

Max Width,  $W_{max} = 750.00$

Min Width,  $W_{min} = 400.00$

Jacket Thickness,  $t_j = 100.00$

Cover Thickness,  $c = 25.00$

Mean Confinement Factor overall section = 1.27105

Element Length,  $L = 3000.00$

Primary Member

Smooth Bars

Ductile Steel

With Detailing for Earthquake Resistance (including stirrups closed at 135°)

Longitudinal Bars With Ends Lapped Starting at the End Sections

Lap Length  $l_o = 300.00$

No FRP Wrapping

#### Stepwise Properties

At local axis: 3

EDGE -A-

Shear Force,  $V_a = -0.00017144$

EDGE -B-

Shear Force,  $V_b = 0.00017144$

BOTH EDGES

Axial Force,  $F = -16273.608$

Longitudinal Reinforcement Area Distribution (in 2 divisions)

-Tension:  $A_{sl} = 0.00$

-Compression:  $A_{sc} = 5353.274$

Longitudinal Reinforcement Area Distribution (in 3 divisions)

-Tension:  $A_{sl,ten} = 1137.257$

-Compression:  $A_{sl,com} = 2208.54$

-Middle:  $A_{sl,mid} = 2007.478$

Calculation of Shear Capacity ratio ,  $V_e/V_r = 0.32266369$

Member Controlled by Flexure ( $V_e/V_r < 1$ )

Calculation of Shear Demand from fig. R18.6.5, ACI 318-14  $V_e = (M_{pr1} + M_{pr2})/l_n = 335307.657$

with

$M_{pr1} = \text{Max}(M_{u1+}, M_{u1-}) = 5.0296\text{E}+008$

$M_{u1+} = 2.3387\text{E}+008$ , is the ultimate moment strength at the edge 1 of the member in the actual moment direction which is defined for the static loading combination

$M_{u1-} = 5.0296\text{E}+008$ , is the ultimate moment strength at the edge 1 of the member in the opposite moment direction which is defined for the static loading combination

$M_{pr2} = \text{Max}(M_{u2+}, M_{u2-}) = 5.0296\text{E}+008$

$M_{u2+} = 2.3387\text{E}+008$ , is the ultimate moment strength at the edge 2 of the member in the actual moment direction which is defined for the static loading combination

$M_{u2-} = 5.0296\text{E}+008$ , is the ultimate moment strength at the edge 2 of the member in the opposite moment direction which is defined for the static loading combination

-----  
Calculation of  $M_{u1+}$   
-----

-----  
Calculation of ultimate curvature  $\phi_u$  according to 4.1, Biskinis/Fardis 2013:

$\phi_u = 4.8099118\text{E}-006$

$M_u = 2.3387\text{E}+008$   
-----

with full section properties:

$b = 750.00$

$d = 707.00$

$d' = 43.00$

$v = 0.00102301$

$N = 16273.608$

$f_c = 30.00$

$\phi_c$  (5A.5, TBDY) = 0.002

Final value of  $\phi_u$ :  $\phi_u^* = \text{shear\_factor} * \text{Max}(\phi_u, \phi_c) = 0.01260361$

The Shear\_factor is considered equal to 1 (pure moment strength)

From (5.4b), TBDY:  $\phi_u = 0.01260361$

$\phi_{ue}$  (5.4c) = 0.05179731

$\phi_{ase}$  ((5.4d), TBDY) =  $(\phi_{ase1} * A_{ext} + \phi_{ase2} * A_{int}) / A_{sec} = 0.45746528$

$\phi_{ase1} = \text{Max}(((A_{conf,max1} - A_{noConf1}) / A_{conf,max1}) * (A_{conf,min1} / A_{conf,max1}), 0) = 0.45746528$

The definitions of  $A_{noConf}$ ,  $A_{conf,min}$  and  $A_{conf,max}$  are derived from generalization of the rectangular sections confinement, which is expressed by (5.4d).

The generalization is done according to Mander, J., Priestley, M., and Park, R. (1988)

"Theoretical Stress-Strain Model for Confined Concrete."

J. Struct. Eng., 10.1061/(ASCE)0733-9445(1988)114:8(1804), 1804-1826.

$A_{conf,max1} = 353600.00$  is the confined core area at levels of member with hoops and

is calculated as the area of core enclosed by the center lines of the external perimeter hoops.

$A_{conf,min1} = 293525.00$  is the confined core area at midway between the levels of hoops and

is calculated by reducing all the dimensions of the area  $A_{conf,max1}$  by a length

equal to half the clear spacing between external hoops.

$A_{noConf1} = 158733.333$  is the unconfined external core area which is equal to  $b_i^2/6$  as defined at (A.2).

$\phi_{ase2} (> \phi_{ase1}) = \text{Max}(((A_{conf,max2} - A_{noConf2}) / A_{conf,max2}) * (A_{conf,min2} / A_{conf,max2}), 0) = 0.45746528$

The definitions of  $A_{noConf}$ ,  $A_{conf,min}$  and  $A_{conf,max}$  are derived from generalization of the rectangular sections confinement, which is expressed by (5.4d).

The generalization is done according to Mander, J., Priestley, M., and Park, R. (1988)

"Theoretical Stress-Strain Model for Confined Concrete."

J. Struct. Eng., 10.1061/(ASCE)0733-9445(1988)114:8(1804), 1804-1826.

$A_{conf,max2} = 171264.00$  is the confined core area at levels of member with hoops and

is calculated as the area of core enclosed by the center lines of the internal perimeter hoops.

$A_{conf,min2} = 54741.00$  is the confined core area at midway between the levels of hoops and

is calculated by reducing all the dimensions of the area  $A_{conf,max2}$  by a length

equal to half the clear spacing between internal hoops.

$A_{noConf2} = 106242.667$  is the unconfined internal core area which is equal to  $b_i^2/6$  as defined at (A.2).

$p_{sh,min} * F_{ywe} = \text{Min}(p_{sh,x} * F_{ywe}, p_{sh,y} * F_{ywe}) = 3.3968$   
-----

$p_{sh,x} * F_{ywe} = p_{sh1} * F_{ywe1} + p_{sh2} * F_{ywe2} = 3.3968$

$p_{sh1}$  ((5.4d), TBDY) =  $L_{stir1} * A_{stir1} / (A_{sec} * s_1) = 0.00367709$

$L_{stir1}$  (Length of stirrups along Y) = 2060.00

$A_{stir1}$  (stirrups area) = 78.53982



$psh2 \text{ (5.4d)} = Lstir2 * Astir2 / (Asec * s2) = 0.00067082$   
 $Lstir2 \text{ (Length of stirrups along Y)} = 1468.00$   
 $Astir2 \text{ (stirrups area)} = 50.26548$

$psh\_y * Fywe = psh1 * Fywe1 + ps2 * Fywe2 = 3.3968$   
 $psh1 \text{ ((5.4d), TBDY)} = Lstir1 * Astir1 / (Asec * s1) = 0.00367709$   
 $Lstir1 \text{ (Length of stirrups along X)} = 2060.00$   
 $Astir1 \text{ (stirrups area)} = 78.53982$   
 $psh2 \text{ ((5.4d), TBDY)} = Lstir2 * Astir2 / (Asec * s2) = 0.00067082$   
 $Lstir2 \text{ (Length of stirrups along X)} = 1468.00$   
 $Astir2 \text{ (stirrups area)} = 50.26548$

$Asec = 440000.00$

$s1 = 100.00$

$s2 = 250.00$

$fywe1 = 781.25$

$fywe2 = 781.25$

$fce = 30.00$

From ((5.A5), TBDY), TBDY:  $cc = 0.00471045$

$c = \text{confinement factor} = 1.27105$

$y1 = 0.00083886$

$sh1 = 0.00268436$

$ft1 = 314.5735$

$fy1 = 262.1446$

$su1 = 0.00268436$

using (30) in Biskinis/Fardis (2013) multiplied with shear\_factor  
and also multiplied by the shear\_factor according to 15.7.1.4, with  
Shear\_factor = 1.00

$lo/lou,min = lb/ld = 0.13907892$

$su1 = 0.4 * esu1\_nominal \text{ ((5.5), TBDY)} = 0.032$

From table 5A.1, TBDY:  $esu1\_nominal = 0.08$ ,

For calculation of  $esu1\_nominal$  and  $y1$ ,  $sh1$ ,  $ft1$ ,  $fy1$ , it is considered  
characteristic value  $fsy1 = fs1/1.2$ , from table 5.1, TBDY.

$y1$ ,  $sh1$ ,  $ft1$ ,  $fy1$ , are also multiplied by  $\text{Min}(1, 1.25 * (lb/ld)^{2/3})$ , from 10.3.5, ASCE 41-17.

with  $fs1 = (fs,jacket * Asl,ten,jacket + fs,core * Asl,ten,core) / Asl,ten = 262.1446$

with  $Es1 = (Es,jacket * Asl,ten,jacket + Es,core * Asl,ten,core) / Asl,ten = 200000.00$

$y2 = 0.00083886$

$sh2 = 0.00268436$

$ft2 = 314.5735$

$fy2 = 262.1446$

$su2 = 0.00268436$

using (30) in Biskinis/Fardis (2013) multiplied with shear\_factor  
and also multiplied by the shear\_factor according to 15.7.1.4, with  
Shear\_factor = 1.00

$lo/lou,min = lb/lb,min = 0.13907892$

$su2 = 0.4 * esu2\_nominal \text{ ((5.5), TBDY)} = 0.032$

From table 5A.1, TBDY:  $esu2\_nominal = 0.08$ ,

For calculation of  $esu2\_nominal$  and  $y2$ ,  $sh2$ ,  $ft2$ ,  $fy2$ , it is considered  
characteristic value  $fsy2 = fs2/1.2$ , from table 5.1, TBDY.

$y1$ ,  $sh1$ ,  $ft1$ ,  $fy1$ , are also multiplied by  $\text{Min}(1, 1.25 * (lb/ld)^{2/3})$ , from 10.3.5, ASCE 41-17.

with  $fs2 = (fs,jacket * Asl,com,jacket + fs,core * Asl,com,core) / Asl,com = 262.1446$

with  $Es2 = (Es,jacket * Asl,com,jacket + Es,core * Asl,com,core) / Asl,com = 200000.00$

$yv = 0.00083886$

$shv = 0.00268436$

$ftv = 314.5735$

$fyv = 262.1446$

$suv = 0.00268436$

using (30) in Biskinis/Fardis (2013) multiplied with shear\_factor  
and also multiplied by the shear\_factor according to 15.7.1.4, with  
Shear\_factor = 1.00

$lo/lou,min = lb/ld = 0.13907892$

$suv = 0.4 * esuv\_nominal \text{ ((5.5), TBDY)} = 0.032$

From table 5A.1, TBDY:  $esuv\_nominal = 0.08$ ,

considering characteristic value  $fsyv = fsv/1.2$ , from table 5.1, TBDY  
For calculation of  $esuv\_nominal$  and  $yv$ ,  $shv$ ,  $ftv$ ,  $fyv$ , it is considered

characteristic value  $fsyv = fsv/1.2$ , from table 5.1, TBDY.

$y1$ ,  $sh1$ ,  $ft1$ ,  $fy1$ , are also multiplied by  $\text{Min}(1, 1.25 * (lb/ld)^{2/3})$ , from 10.3.5, ASCE 41-17.

```

with fsv = (fs,jacket*Asl,mid,jacket + fs,mid*Asl,mid,core)/Asl,mid = 262.1446
with Esv = (Es,jacket*Asl,mid,jacket + Es,mid*Asl,mid,core)/Asl,mid = 200000.00
1 = Asl,ten/(b*d)*(fs1/fc) = 0.0187412
2 = Asl,com/(b*d)*(fs2/fc) = 0.03639521
v = Asl,mid/(b*d)*(fsv/fc) = 0.03308184

```

and confined core properties:

```

b = 690.00
d = 677.00
d' = 13.00
fcc (5A.2, TBDY) = 38.13135
cc (5A.5, TBDY) = 0.00471045
c = confinement factor = 1.27105
1 = Asl,ten/(b*d)*(fs1/fc) = 0.02127357
2 = Asl,com/(b*d)*(fs2/fc) = 0.04131304
v = Asl,mid/(b*d)*(fsv/fc) = 0.03755196

```

Case/Assumption: Unconfined full section - Steel rupture

' satisfies Eq. (4.3)

--->

v < vs,y2 - LHS eq.(4.5) is satisfied

--->

```

su (4.9) = 0.21062322
Mu = MRc (4.14) = 2.3387E+008
u = su (4.1) = 4.8099118E-006

```

Calculation of ratio lb/d

Lap Length: lb/d = 0.13907892

lb = 300.00

ld = 2157.049

Calculation of lb,min according to (25.4.3.2), ACI 318-14, using mean values for all the section re-bars.

ld,min from (25.4.3.2) is multiplied 2 times to account for smooth re-bars (9.1.2, TS500 - No provision in ACI 318)

= 1

db = 16.66667

Mean strength value of all re-bars: fy = 781.25

Mean concrete strength: fc' = (fc'\_jacket\*Area\_jacket + fc'\_core\*Area\_core)/Area\_section = 30.00, but  $fc'^{0.5} \leq 8.3$  MPa (22.5.3.1, ACI 318-14)

t = 1.00

s = 0.80

e = 1.00

cb = 25.00

Ktr = 1.7174

Atr = Min(Atr\_x,Atr\_y) = 257.6106

where Atr\_x, Atr\_y are the sum of the area of all stirrup legs along X and Y loxal axis

s = Max(s\_external,s\_internal) = 250.00

n = 24.00

Calculation of Mu1-

Calculation of ultimate curvature u according to 4.1, Biskinis/Fardis 2013:

u = 5.1201636E-006

Mu = 5.0296E+008

with full section properties:

b = 400.00

d = 707.00

d' = 43.00

v = 0.00191815

N = 16273.608

fc = 30.00

co (5A.5, TBDY) = 0.002

Final value of cu: cu\* = shear\_factor \* Max( cu, cc) = 0.01260361

The Shear\_factor is considered equal to 1 (pure moment strength)

From (5.4b), TBDY:  $c_u = 0.01260361$

$w_e$  (5.4c) = 0.05179731

$a_{se}$  ((5.4d), TBDY) =  $(a_{se1} \cdot A_{ext} + a_{se2} \cdot A_{int}) / A_{sec} = 0.45746528$

$a_{se1} = \text{Max}(((A_{conf,max1} - A_{noConf1}) / A_{conf,max1}) \cdot (A_{conf,min1} / A_{conf,max1}), 0) = 0.45746528$

The definitions of  $A_{noConf}$ ,  $A_{conf,min}$  and  $A_{conf,max}$  are derived from generalization of the rectangular sections confinement, which is expressed by (5.4d).

The generalization is done according to Mander, J., Priestley, M., and Park, R. (1988)

"Theoretical Stress-Strain Model for Confined Concrete."

J. Struct. Eng., 10.1061/(ASCE)0733-9445(1988)114:8(1804), 1804-1826.

$A_{conf,max1} = 353600.00$  is the confined core area at levels of member with hoops and

is calculated as the area of core enclosed by the center lines of the external perimeter hoops.

$A_{conf,min1} = 293525.00$  is the confined core area at midway between the levels of hoops and

is calculated by reducing all the dimensions of the area  $A_{conf,max1}$  by a length

equal to half the clear spacing between external hoops.

$A_{noConf1} = 158733.333$  is the unconfined external core area which is equal to  $b_i^2/6$  as defined at (A.2).

$a_{se2} (>= a_{se1}) = \text{Max}(((A_{conf,max2} - A_{noConf2}) / A_{conf,max2}) \cdot (A_{conf,min2} / A_{conf,max2}), 0) = 0.45746528$

The definitions of  $A_{noConf}$ ,  $A_{conf,min}$  and  $A_{conf,max}$  are derived from generalization of the rectangular sections confinement, which is expressed by (5.4d).

The generalization is done according to Mander, J., Priestley, M., and Park, R. (1988)

"Theoretical Stress-Strain Model for Confined Concrete."

J. Struct. Eng., 10.1061/(ASCE)0733-9445(1988)114:8(1804), 1804-1826.

$A_{conf,max2} = 171264.00$  is the confined core area at levels of member with hoops and

is calculated as the area of core enclosed by the center lines of the internal perimeter hoops.

$A_{conf,min2} = 54741.00$  is the confined core area at midway between the levels of hoops and

is calculated by reducing all the dimensions of the area  $A_{conf,max2}$  by a length

equal to half the clear spacing between internal hoops.

$A_{noConf2} = 106242.667$  is the unconfined internal core area which is equal to  $b_i^2/6$  as defined at (A.2).

$p_{sh,min} \cdot F_{ywe} = \text{Min}(p_{sh,x} \cdot F_{ywe}, p_{sh,y} \cdot F_{ywe}) = 3.3968$

-----  
 $p_{sh,x} \cdot F_{ywe} = p_{sh1} \cdot F_{ywe1} + p_{s2} \cdot F_{ywe2} = 3.3968$

$p_{sh1}$  ((5.4d), TBDY) =  $L_{stir1} \cdot A_{stir1} / (A_{sec} \cdot s_1) = 0.00367709$

$L_{stir1}$  (Length of stirrups along Y) = 2060.00

$A_{stir1}$  (stirrups area) = 78.53982

$p_{sh2}$  (5.4d) =  $L_{stir2} \cdot A_{stir2} / (A_{sec} \cdot s_2) = 0.00067082$

$L_{stir2}$  (Length of stirrups along Y) = 1468.00

$A_{stir2}$  (stirrups area) = 50.26548

-----  
 $p_{sh,y} \cdot F_{ywe} = p_{sh1} \cdot F_{ywe1} + p_{s2} \cdot F_{ywe2} = 3.3968$

$p_{sh1}$  ((5.4d), TBDY) =  $L_{stir1} \cdot A_{stir1} / (A_{sec} \cdot s_1) = 0.00367709$

$L_{stir1}$  (Length of stirrups along X) = 2060.00

$A_{stir1}$  (stirrups area) = 78.53982

$p_{sh2}$  ((5.4d), TBDY) =  $L_{stir2} \cdot A_{stir2} / (A_{sec} \cdot s_2) = 0.00067082$

$L_{stir2}$  (Length of stirrups along X) = 1468.00

$A_{stir2}$  (stirrups area) = 50.26548

-----  
 $A_{sec} = 440000.00$

$s_1 = 100.00$

$s_2 = 250.00$

$f_{ywe1} = 781.25$

$f_{ywe2} = 781.25$

$f_{ce} = 30.00$

From ((5.A5), TBDY), TBDY:  $c_c = 0.00471045$

$c$  = confinement factor = 1.27105

$y_1 = 0.00083886$

$sh_1 = 0.00268436$

$ft_1 = 314.5735$

$fy_1 = 262.1446$

$su_1 = 0.00268436$

using (30) in Biskinis/Fardis (2013) multiplied with shear\_factor

and also multiplied by the shear\_factor according to 15.7.1.4, with

Shear\_factor = 1.00

$l_o/l_{ou,min} = l_b/l_d = 0.13907892$

$su_1 = 0.4 \cdot esu_1_{nominal}$  ((5.5), TBDY) = 0.032

From table 5A.1, TBDY:  $esu_1_{nominal} = 0.08$ ,

For calculation of  $esu_1_{nominal}$  and  $y_1$ ,  $sh_1$ ,  $ft_1$ ,  $fy_1$ , it is considered

characteristic value  $fsy_1 = f_{s1}/1.2$ , from table 5.1, TBDY.

$y_1$ ,  $sh_1$ ,  $ft_1$ ,  $fy_1$ , are also multiplied by  $\text{Min}(1, 1.25 \cdot (l_b/l_d)^{2/3})$ , from 10.3.5, ASCE 41-17.

```

with fs1 = (fs,jacket*Asl,ten,jacket + fs,core*Asl,ten,core)/Asl,ten = 262.1446
with Es1 = (Es,jacket*Asl,ten,jacket + Es,core*Asl,ten,core)/Asl,ten = 200000.00
y2 = 0.00083886
sh2 = 0.00268436
ft2 = 314.5735
fy2 = 262.1446
su2 = 0.00268436
using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00
lo/lou,min = lb/lb,min = 0.13907892
su2 = 0.4*esu2_nominal ((5.5), TBDY) = 0.032
From table 5A.1, TBDY: esu2_nominal = 0.08,
For calculation of esu2_nominal and y2, sh2,ft2,fy2, it is considered
characteristic value fsy2 = fs2/1.2, from table 5.1, TBDY.
y1, sh1,ft1,fy1, are also multiplied by Min(1,1.25*(lb/lb,min)^2/3), from 10.3.5, ASCE 41-17.
with fs2 = (fs,jacket*Asl,com,jacket + fs,core*Asl,com,core)/Asl,com = 262.1446
with Es2 = (Es,jacket*Asl,com,jacket + Es,core*Asl,com,core)/Asl,com = 200000.00
yv = 0.00083886
shv = 0.00268436
ftv = 314.5735
fyv = 262.1446
suv = 0.00268436
using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00
lo/lou,min = lb/lb,min = 0.13907892
suv = 0.4*esuv_nominal ((5.5), TBDY) = 0.032
From table 5A.1, TBDY: esuv_nominal = 0.08,
considering characteristic value fsyv = fsv/1.2, from table 5.1, TBDY
For calculation of esuv_nominal and yv, shv,ftv,fyv, it is considered
characteristic value fsyv = fsv/1.2, from table 5.1, TBDY.
y1, sh1,ft1,fy1, are also multiplied by Min(1,1.25*(lb/lb,min)^2/3), from 10.3.5, ASCE 41-17.
with fsv = (fs,jacket*Asl,mid,jacket + fs,mid*Asl,mid,core)/Asl,mid = 262.1446
with Esv = (Es,jacket*Asl,mid,jacket + Es,mid*Asl,mid,core)/Asl,mid = 200000.00
1 = Asl,ten/(b*d)*(fs1/fc) = 0.06824101
2 = Asl,com/(b*d)*(fs2/fc) = 0.03513975
v = Asl,mid/(b*d)*(fsv/fc) = 0.06202846
and confined core properties:
b = 340.00
d = 677.00
d' = 13.00
fcc (5A.2, TBDY) = 38.13135
cc (5A.5, TBDY) = 0.00471045
c = confinement factor = 1.27105
1 = Asl,ten/(b*d)*(fs1/fc) = 0.08384116
2 = Asl,com/(b*d)*(fs2/fc) = 0.04317283
v = Asl,mid/(b*d)*(fsv/fc) = 0.07620839
Case/Assumption: Unconfined full section - Steel rupture
'satisfies Eq. (4.3)
--->
v < vs,y2 - LHS eq.(4.5) is satisfied
--->
su (4.9) = 0.2584548
Mu = MRc (4.14) = 5.0296E+008
u = su (4.1) = 5.1201636E-006

```

Calculation of ratio lb/lb

```

Lap Length: lb/lb = 0.13907892
lb = 300.00
ld = 2157.049
Calculation of lb,min according to (25.4.3.2), ACI 318-14, using mean values for all the section re-bars.
ld,min from (25.4.3.2) is multiplied 2 times to account for smooth re-bars (9.1.2, TS500 - No provision in ACI 318)
= 1
db = 16.66667

```

Mean strength value of all re-bars:  $f_y = 781.25$   
Mean concrete strength:  $f_c' = (f_c'_{\text{jacket}} \cdot \text{Area}_{\text{jacket}} + f_c'_{\text{core}} \cdot \text{Area}_{\text{core}}) / \text{Area}_{\text{section}} = 30.00$ , but  $f_c'^{0.5} \leq 8.3$  MPa (22.5.3.1, ACI 318-14)  
 $t = 1.00$   
 $s = 0.80$   
 $e = 1.00$   
 $cb = 25.00$   
 $K_{tr} = 1.7174$   
 $A_{tr} = \text{Min}(A_{tr\_x}, A_{tr\_y}) = 257.6106$   
where  $A_{tr\_x}$ ,  $A_{tr\_y}$  are the sum of the area of all stirrup legs along X and Y loxal axis  
 $s = \text{Max}(s_{\text{external}}, s_{\text{internal}}) = 250.00$   
 $n = 24.00$

#### Calculation of $\mu_{2+}$

Calculation of ultimate curvature  $\mu$  according to 4.1, Biskinis/Fardis 2013:  
 $\mu = 4.8099118E-006$   
 $\mu_u = 2.3387E+008$

with full section properties:

$b = 750.00$   
 $d = 707.00$   
 $d' = 43.00$   
 $v = 0.00102301$   
 $N = 16273.608$   
 $f_c = 30.00$   
 $\alpha_1$  (5A.5, TBDY) = 0.002  
Final value of  $\mu_u$ :  $\mu_u^* = \text{shear\_factor} \cdot \text{Max}(\mu_u, \mu_c) = 0.01260361$   
The Shear\_factor is considered equal to 1 (pure moment strength)  
From (5.4b), TBDY:  $\mu_u = 0.01260361$   
 $\mu_{ue}$  (5.4c) = 0.05179731  
 $\alpha_{se}$  ((5.4d), TBDY) =  $(\alpha_{se1} \cdot A_{ext} + \alpha_{se2} \cdot A_{int}) / A_{sec} = 0.45746528$   
 $\alpha_{se1} = \text{Max}(((A_{conf,max1} - A_{noConf1}) / A_{conf,max1}) \cdot (A_{conf,min1} / A_{conf,max1}), 0) = 0.45746528$   
The definitions of  $A_{noConf}$ ,  $A_{conf,min}$  and  $A_{conf,max}$  are derived from generalization of the rectangular sections confinement, which is expressed by (5.4d).  
The generalization is done according to Mander, J., Priestley, M., and Park, R. (1988) "Theoretical Stress-Strain Model for Confined Concrete."  
J. Struct. Eng., 10.1061/(ASCE)0733-9445(1988)114:8(1804), 1804-1826.  
 $A_{conf,max1} = 353600.00$  is the confined core area at levels of member with hoops and is calculated as the area of core enclosed by the center lines of the external perimeter hoops.  
 $A_{conf,min1} = 293525.00$  is the confined core area at midway between the levels of hoops and is calculated by reducing all the dimensions of the area  $A_{conf,max1}$  by a length equal to half the clear spacing between external hoops.  
 $A_{noConf1} = 158733.333$  is the unconfined external core area which is equal to  $b_i^2/6$  as defined at (A.2).  
 $\alpha_{se2} (\geq \alpha_{se1}) = \text{Max}(((A_{conf,max2} - A_{noConf2}) / A_{conf,max2}) \cdot (A_{conf,min2} / A_{conf,max2}), 0) = 0.45746528$   
The definitions of  $A_{noConf}$ ,  $A_{conf,min}$  and  $A_{conf,max}$  are derived from generalization of the rectangular sections confinement, which is expressed by (5.4d).  
The generalization is done according to Mander, J., Priestley, M., and Park, R. (1988) "Theoretical Stress-Strain Model for Confined Concrete."  
J. Struct. Eng., 10.1061/(ASCE)0733-9445(1988)114:8(1804), 1804-1826.  
 $A_{conf,max2} = 171264.00$  is the confined core area at levels of member with hoops and is calculated as the area of core enclosed by the center lines of the internal perimeter hoops.  
 $A_{conf,min2} = 54741.00$  is the confined core area at midway between the levels of hoops and is calculated by reducing all the dimensions of the area  $A_{conf,max2}$  by a length equal to half the clear spacing between internal hoops.  
 $A_{noConf2} = 106242.667$  is the unconfined internal core area which is equal to  $b_i^2/6$  as defined at (A.2).  
 $p_{sh,min} \cdot F_{ywe} = \text{Min}(p_{sh,x} \cdot F_{ywe}, p_{sh,y} \cdot F_{ywe}) = 3.3968$

$p_{sh,x} \cdot F_{ywe} = p_{sh1} \cdot F_{ywe1} + p_{sh2} \cdot F_{ywe2} = 3.3968$   
 $p_{sh1}$  ((5.4d), TBDY) =  $L_{stir1} \cdot A_{stir1} / (A_{sec} \cdot s_1) = 0.00367709$   
 $L_{stir1}$  (Length of stirrups along Y) = 2060.00  
 $A_{stir1}$  (stirrups area) = 78.53982  
 $p_{sh2}$  (5.4d) =  $L_{stir2} \cdot A_{stir2} / (A_{sec} \cdot s_2) = 0.00067082$

Lstir2 (Length of stirrups along Y) = 1468.00  
Astir2 (stirrups area) = 50.26548

psh\_y\*Fywe = psh1\*Fywe1+ps2\*Fywe2 = 3.3968  
psh1 ((5.4d), TBDY) = Lstir1\*Astir1/(Asec\*s1) = 0.00367709  
Lstir1 (Length of stirrups along X) = 2060.00  
Astir1 (stirrups area) = 78.53982  
psh2 ((5.4d), TBDY) = Lstir2\*Astir2/(Asec\*s2) = 0.00067082  
Lstir2 (Length of stirrups along X) = 1468.00  
Astir2 (stirrups area) = 50.26548

Asec = 440000.00  
s1 = 100.00  
s2 = 250.00

fywe1 = 781.25  
fywe2 = 781.25  
fce = 30.00

From ((5.A5), TBDY), TBDY: cc = 0.00471045  
c = confinement factor = 1.27105

y1 = 0.00083886  
sh1 = 0.00268436  
ft1 = 314.5735  
fy1 = 262.1446  
su1 = 0.00268436

using (30) in Biskinis/Fardis (2013) multiplied with shear\_factor  
and also multiplied by the shear\_factor according to 15.7.1.4, with  
Shear\_factor = 1.00

lo/lou,min = lb/lb = 0.13907892

su1 = 0.4\*esu1\_nominal ((5.5), TBDY) = 0.032

From table 5A.1, TBDY: esu1\_nominal = 0.08,

For calculation of esu1\_nominal and y1, sh1,ft1,fy1, it is considered  
characteristic value fsy1 = fs1/1.2, from table 5.1, TBDY.

y1, sh1,ft1,fy1, are also multiplied by  $\text{Min}(1, 1.25 \cdot (lb/lb)^{2/3})$ , from 10.3.5, ASCE 41-17.

with fs1 = (fs,jacket\*Asl,ten,jacket + fs,core\*Asl,ten,core)/Asl,ten = 262.1446

with Es1 = (Es,jacket\*Asl,ten,jacket + Es,core\*Asl,ten,core)/Asl,ten = 200000.00

y2 = 0.00083886  
sh2 = 0.00268436  
ft2 = 314.5735  
fy2 = 262.1446  
su2 = 0.00268436

using (30) in Biskinis/Fardis (2013) multiplied with shear\_factor  
and also multiplied by the shear\_factor according to 15.7.1.4, with  
Shear\_factor = 1.00

lo/lou,min = lb/lb,min = 0.13907892

su2 = 0.4\*esu2\_nominal ((5.5), TBDY) = 0.032

From table 5A.1, TBDY: esu2\_nominal = 0.08,

For calculation of esu2\_nominal and y2, sh2,ft2,fy2, it is considered  
characteristic value fsy2 = fs2/1.2, from table 5.1, TBDY.

y1, sh1,ft1,fy1, are also multiplied by  $\text{Min}(1, 1.25 \cdot (lb/lb)^{2/3})$ , from 10.3.5, ASCE 41-17.

with fs2 = (fs,jacket\*Asl,com,jacket + fs,core\*Asl,com,core)/Asl,com = 262.1446

with Es2 = (Es,jacket\*Asl,com,jacket + Es,core\*Asl,com,core)/Asl,com = 200000.00

yv = 0.00083886  
shv = 0.00268436  
ftv = 314.5735  
fyv = 262.1446  
suv = 0.00268436

using (30) in Biskinis/Fardis (2013) multiplied with shear\_factor  
and also multiplied by the shear\_factor according to 15.7.1.4, with  
Shear\_factor = 1.00

lo/lou,min = lb/lb = 0.13907892

suv = 0.4\*esuv\_nominal ((5.5), TBDY) = 0.032

From table 5A.1, TBDY: esuv\_nominal = 0.08,

considering characteristic value fsyv = fsv/1.2, from table 5.1, TBDY

For calculation of esuv\_nominal and yv, shv,ftv,fyv, it is considered  
characteristic value fsyv = fsv/1.2, from table 5.1, TBDY.

y1, sh1,ft1,fy1, are also multiplied by  $\text{Min}(1, 1.25 \cdot (lb/lb)^{2/3})$ , from 10.3.5, ASCE 41-17.

with fsv = (fs,jacket\*Asl,mid,jacket + fs,mid\*Asl,mid,core)/Asl,mid = 262.1446

```

with Esv = (Esjacket*Asl,mid,jacket + Esmid*Asl,mid,core)/Asl,mid = 200000.00
1 = Asl,ten/(b*d)*(fs1/fc) = 0.0187412
2 = Asl,com/(b*d)*(fs2/fc) = 0.03639521
v = Asl,mid/(b*d)*(fsv/fc) = 0.03308184
and confined core properties:
b = 690.00
d = 677.00
d' = 13.00
fcc (5A.2, TBDY) = 38.13135
cc (5A.5, TBDY) = 0.00471045
c = confinement factor = 1.27105
1 = Asl,ten/(b*d)*(fs1/fc) = 0.02127357
2 = Asl,com/(b*d)*(fs2/fc) = 0.04131304
v = Asl,mid/(b*d)*(fsv/fc) = 0.03755196
Case/Assumption: Unconfined full section - Steel rupture
'satisfies Eq. (4.3)
--->
v < vs,y2 - LHS eq.(4.5) is satisfied
--->
su (4.9) = 0.21062322
Mu = MRc (4.14) = 2.3387E+008
u = su (4.1) = 4.8099118E-006
-----

Calculation of ratio lb/d
-----
Lap Length: lb/d = 0.13907892
lb = 300.00
ld = 2157.049
Calculation of lb,min according to (25.4.3.2), ACI 318-14, using mean values for all the section re-bars.
ld,min from (25.4.3.2) is multiplied 2 times to account for smooth re-bars (9.1.2, TS500 - No provision in ACI 318)
= 1
db = 16.66667
Mean strength value of all re-bars: fy = 781.25
Mean concrete strength: fc' = (fc'_jacket*Area_jacket + fc'_core*Area_core)/Area_section = 30.00, but fc'^0.5 <= 8.3
MPa (22.5.3.1, ACI 318-14)
t = 1.00
s = 0.80
e = 1.00
cb = 25.00
Ktr = 1.7174
Atr = Min(Atr,x,Atr,y) = 257.6106
where Atr,x, Atr,y are the sum of the area of all stirrup legs along X and Y loxal axis
s = Max(sexternal,sinternal) = 250.00
n = 24.00
-----
-----
-----

Calculation of Mu2-
-----
-----

Calculation of ultimate curvature u according to 4.1, Biskinis/Fardis 2013:
u = 5.1201636E-006
Mu = 5.0296E+008
-----

with full section properties:
b = 400.00
d = 707.00
d' = 43.00
v = 0.00191815
N = 16273.608
fc = 30.00
co (5A.5, TBDY) = 0.002
Final value of cu: cu* = shear_factor * Max( cu, cc) = 0.01260361
The Shear_factor is considered equal to 1 (pure moment strength)
From (5.4b), TBDY: cu = 0.01260361

```

$$w_e (5.4c) = 0.05179731$$

$$ase ((5.4d), TBDY) = (ase1 * A_{ext} + ase2 * A_{int}) / A_{sec} = 0.45746528$$

$$ase1 = \text{Max}(((A_{conf,max1} - A_{noConf1}) / A_{conf,max1}) * (A_{conf,min1} / A_{conf,max1}), 0) = 0.45746528$$

The definitions of  $A_{noConf}$ ,  $A_{conf,min}$  and  $A_{conf,max}$  are derived from generalization of the rectangular sections confinement, which is expressed by (5.4d).

The generalization is done according to Mander, J., Priestley, M., and Park, R. (1988)

"Theoretical Stress-Strain Model for Confined Concrete."

J. Struct. Eng., 10.1061/(ASCE)0733-9445(1988)114:8(1804), 1804-1826.

$A_{conf,max1} = 353600.00$  is the confined core area at levels of member with hoops and is calculated as the area of core enclosed by the center lines of the external perimeter hoops.

$A_{conf,min1} = 293525.00$  is the confined core area at midway between the levels of hoops and is calculated by reducing all the dimensions of the area  $A_{conf,max1}$  by a length equal to half the clear spacing between external hoops.

$A_{noConf1} = 158733.333$  is the unconfined external core area which is equal to  $b_i^2/6$  as defined at (A.2).

$$ase2 (>= ase1) = \text{Max}(((A_{conf,max2} - A_{noConf2}) / A_{conf,max2}) * (A_{conf,min2} / A_{conf,max2}), 0) = 0.45746528$$

The definitions of  $A_{noConf}$ ,  $A_{conf,min}$  and  $A_{conf,max}$  are derived from generalization of the rectangular sections confinement, which is expressed by (5.4d).

The generalization is done according to Mander, J., Priestley, M., and Park, R. (1988)

"Theoretical Stress-Strain Model for Confined Concrete."

J. Struct. Eng., 10.1061/(ASCE)0733-9445(1988)114:8(1804), 1804-1826.

$A_{conf,max2} = 171264.00$  is the confined core area at levels of member with hoops and is calculated as the area of core enclosed by the center lines of the internal perimeter hoops.

$A_{conf,min2} = 54741.00$  is the confined core area at midway between the levels of hoops and is calculated by reducing all the dimensions of the area  $A_{conf,max2}$  by a length equal to half the clear spacing between internal hoops.

$A_{noConf2} = 106242.667$  is the unconfined internal core area which is equal to  $b_i^2/6$  as defined at (A.2).

$$psh_{min} * F_{ywe} = \text{Min}(psh_x * F_{ywe}, psh_y * F_{ywe}) = 3.3968$$

$$psh_x * F_{ywe} = psh1 * F_{ywe1} + ps2 * F_{ywe2} = 3.3968$$

$$psh1 ((5.4d), TBDY) = L_{stir1} * A_{stir1} / (A_{sec} * s1) = 0.00367709$$

$L_{stir1}$  (Length of stirrups along Y) = 2060.00

$A_{stir1}$  (stirrups area) = 78.53982

$$psh2 (5.4d) = L_{stir2} * A_{stir2} / (A_{sec} * s2) = 0.00067082$$

$L_{stir2}$  (Length of stirrups along Y) = 1468.00

$A_{stir2}$  (stirrups area) = 50.26548

$$psh_y * F_{ywe} = psh1 * F_{ywe1} + ps2 * F_{ywe2} = 3.3968$$

$$psh1 ((5.4d), TBDY) = L_{stir1} * A_{stir1} / (A_{sec} * s1) = 0.00367709$$

$L_{stir1}$  (Length of stirrups along X) = 2060.00

$A_{stir1}$  (stirrups area) = 78.53982

$$psh2 ((5.4d), TBDY) = L_{stir2} * A_{stir2} / (A_{sec} * s2) = 0.00067082$$

$L_{stir2}$  (Length of stirrups along X) = 1468.00

$A_{stir2}$  (stirrups area) = 50.26548

$$A_{sec} = 440000.00$$

$$s1 = 100.00$$

$$s2 = 250.00$$

$$f_{ywe1} = 781.25$$

$$f_{ywe2} = 781.25$$

$$f_{ce} = 30.00$$

$$\text{From } ((5.A5), TBDY), TBDY: cc = 0.00471045$$

$$c = \text{confinement factor} = 1.27105$$

$$y1 = 0.00083886$$

$$sh1 = 0.00268436$$

$$ft1 = 314.5735$$

$$fy1 = 262.1446$$

$$su1 = 0.00268436$$

using (30) in Biskinis/Fardis (2013) multiplied with shear\_factor and also multiplied by the shear\_factor according to 15.7.1.4, with Shear\_factor = 1.00

$$l_o/l_{ou,min} = l_b/l_d = 0.13907892$$

$$su1 = 0.4 * esu1_{nominal} ((5.5), TBDY) = 0.032$$

From table 5A.1, TBDY:  $esu1_{nominal} = 0.08$ ,

For calculation of  $esu1_{nominal}$  and  $y1$ ,  $sh1$ ,  $ft1$ ,  $fy1$ , it is considered characteristic value  $fsy1 = fs1/1.2$ , from table 5.1, TBDY.

$y1$ ,  $sh1$ ,  $ft1$ ,  $fy1$ , are also multiplied by  $\text{Min}(1, 1.25 * (l_b/l_d)^{2/3})$ , from 10.3.5, ASCE 41-17.

$$\text{with } fs1 = (f_{s,jacket} * A_{sl,ten,jacket} + f_{s,core} * A_{sl,ten,core}) / A_{sl,ten} = 262.1446$$



with  $E_{s1} = (E_{s,jacket} \cdot A_{s,ten,jacket} + E_{s,core} \cdot A_{s,ten,core}) / A_{s,ten} = 200000.00$   
 $y_2 = 0.00083886$   
 $sh_2 = 0.00268436$   
 $ft_2 = 314.5735$   
 $fy_2 = 262.1446$   
 $su_2 = 0.00268436$   
 using (30) in Biskinis/Fardis (2013) multiplied with shear\_factor  
 and also multiplied by the shear\_factor according to 15.7.1.4, with  
 Shear\_factor = 1.00  
 $l_o/l_{ou,min} = l_b/l_{b,min} = 0.13907892$   
 $su_2 = 0.4 \cdot esu_{2,nominal} ((5.5), TBDY) = 0.032$   
 From table 5A.1, TBDY:  $esu_{2,nominal} = 0.08$ ,  
 For calculation of  $esu_{2,nominal}$  and  $y_2, sh_2, ft_2, fy_2$ , it is considered  
 characteristic value  $fs_2 = fs_2/1.2$ , from table 5.1, TBDY.  
 $y_1, sh_1, ft_1, fy_1$ , are also multiplied by  $\text{Min}(1, 1.25 \cdot (l_b/l_d)^{2/3})$ , from 10.3.5, ASCE 41-17.  
 with  $fs_2 = (f_{s,jacket} \cdot A_{s,com,jacket} + f_{s,core} \cdot A_{s,com,core}) / A_{s,com} = 262.1446$   
 with  $E_{s2} = (E_{s,jacket} \cdot A_{s,com,jacket} + E_{s,core} \cdot A_{s,com,core}) / A_{s,com} = 200000.00$   
 $y_v = 0.00083886$   
 $sh_v = 0.00268436$   
 $ft_v = 314.5735$   
 $fy_v = 262.1446$   
 $suv = 0.00268436$   
 using (30) in Biskinis/Fardis (2013) multiplied with shear\_factor  
 and also multiplied by the shear\_factor according to 15.7.1.4, with  
 Shear\_factor = 1.00  
 $l_o/l_{ou,min} = l_b/l_d = 0.13907892$   
 $suv = 0.4 \cdot esuv_{nominal} ((5.5), TBDY) = 0.032$   
 From table 5A.1, TBDY:  $esuv_{nominal} = 0.08$ ,  
 considering characteristic value  $fs_v = fs_v/1.2$ , from table 5.1, TBDY  
 For calculation of  $esuv_{nominal}$  and  $y_v, sh_v, ft_v, fy_v$ , it is considered  
 characteristic value  $fs_v = fs_v/1.2$ , from table 5.1, TBDY.  
 $y_1, sh_1, ft_1, fy_1$ , are also multiplied by  $\text{Min}(1, 1.25 \cdot (l_b/l_d)^{2/3})$ , from 10.3.5, ASCE 41-17.  
 with  $fs_v = (f_{s,jacket} \cdot A_{s,mid,jacket} + f_{s,mid} \cdot A_{s,mid,core}) / A_{s,mid} = 262.1446$   
 with  $E_{sv} = (E_{s,jacket} \cdot A_{s,mid,jacket} + E_{s,mid} \cdot A_{s,mid,core}) / A_{s,mid} = 200000.00$   
 $1 = A_{s,ten} / (b \cdot d) \cdot (f_{s1} / f_c) = 0.06824101$   
 $2 = A_{s,com} / (b \cdot d) \cdot (f_{s2} / f_c) = 0.03513975$   
 $v = A_{s,mid} / (b \cdot d) \cdot (f_{sv} / f_c) = 0.06202846$   
 and confined core properties:  
 $b = 340.00$   
 $d = 677.00$   
 $d' = 13.00$   
 $f_{cc} (5A.2, TBDY) = 38.13135$   
 $cc (5A.5, TBDY) = 0.00471045$   
 $c = \text{confinement factor} = 1.27105$   
 $1 = A_{s,ten} / (b \cdot d) \cdot (f_{s1} / f_c) = 0.08384116$   
 $2 = A_{s,com} / (b \cdot d) \cdot (f_{s2} / f_c) = 0.04317283$   
 $v = A_{s,mid} / (b \cdot d) \cdot (f_{sv} / f_c) = 0.07620839$   
 Case/Assumption: Unconfined full section - Steel rupture  
 ' satisfies Eq. (4.3)  
 --->  
 $v < v_{s,y2}$  - LHS eq.(4.5) is satisfied  
 --->  
 $su (4.9) = 0.2584548$   
 $\mu_u = M_{Rc} (4.14) = 5.0296E+008$   
 $u = su (4.1) = 5.1201636E-006$

#### Calculation of ratio $l_b/l_d$

Lap Length:  $l_b/l_d = 0.13907892$   
 $l_b = 300.00$   
 $l_d = 2157.049$   
 Calculation of  $l_{b,min}$  according to (25.4.3.2), ACI 318-14, using mean values for all the section re-bars.  
 $l_{d,min}$  from (25.4.3.2) is multiplied 2 times to account for smooth re-bars (9.1.2, TS500 - No provision in ACI 318)  
 $= 1$   
 $db = 16.66667$   
 Mean strength value of all re-bars:  $f_y = 781.25$

Mean concrete strength:  $fc' = (fc'_{jacket} \cdot Area_{jacket} + fc'_{core} \cdot Area_{core}) / Area_{section} = 30.00$ , but  $fc'^{0.5} \leq 8.3$  MPa (22.5.3.1, ACI 318-14)

$$t = 1.00$$

$$s = 0.80$$

$$e = 1.00$$

$$cb = 25.00$$

$$K_{tr} = 1.7174$$

$$A_{tr} = \text{Min}(A_{tr_x}, A_{tr_y}) = 257.6106$$

where  $A_{tr_x}$ ,  $A_{tr_y}$  are the sum of the area of all stirrup legs along X and Y loxal axis

$$s = \text{Max}(s_{external}, s_{internal}) = 250.00$$

$$n = 24.00$$

Calculation of Shear Strength  $V_r = \text{Min}(V_{r1}, V_{r2}) = 1.0392E+006$

Calculation of Shear Strength at edge 1,  $V_{r1} = 1.0392E+006$

$$V_{r1} = V_{Col} \text{ ((10.3), ASCE 41-17)} = knl \cdot V_{Col0}$$

$$V_{Col0} = 1.0392E+006$$

$$knl = 1 \text{ (zero step-static loading)}$$

NOTE: In expression (10-3) ' $V_s = A_v \cdot f_y \cdot d / s$ ' is replaced by ' $V_s + f \cdot V_f$ ' where  $V_f$  is the contribution of FRPs (11.3), ACI 440).

$$= 1 \text{ (normal-weight concrete)}$$

Mean concrete strength:  $fc' = (fc'_{jacket} \cdot Area_{jacket} + fc'_{core} \cdot Area_{core}) / Area_{section} = 30.00$ , but  $fc'^{0.5} \leq 8.3$  MPa (22.5.3.1, ACI 318-14)

$$M/Vd = 4.00$$

$$\mu_u = 1308.016$$

$$V_u = 0.00017144$$

$$d = 0.8 \cdot h = 600.00$$

$$N_u = 16273.608$$

$$A_g = 300000.00$$

$$\text{From (11.5.4.8), ACI 318-14: } V_s = V_{s,jacket} + V_{s,core} = 1.0138E+006$$

where:

$$V_{s,jacket} = V_{s,j1} + V_{s,j2} = 903207.888$$

$V_{s,j1} = 589048.623$  is calculated for section web jacket, with:

$$d = 600.00$$

$$A_v = 157079.633$$

$$f_y = 625.00$$

$$s = 100.00$$

$V_{s,j1}$  is multiplied by  $Col,j1 = 1.00$

$$s/d = 0.16666667$$

$V_{s,j2} = 314159.265$  is calculated for section flange jacket, with:

$$d = 320.00$$

$$A_v = 157079.633$$

$$f_y = 625.00$$

$$s = 100.00$$

$V_{s,j2}$  is multiplied by  $Col,j2 = 1.00$

$$s/d = 0.3125$$

$$V_{s,core} = V_{s,c1} + V_{s,c2} = 110584.061$$

$V_{s,c1} = 110584.061$  is calculated for section web core, with:

$$d = 440.00$$

$$A_v = 100530.965$$

$$f_y = 625.00$$

$$s = 250.00$$

$V_{s,c1}$  is multiplied by  $Col,c1 = 1.00$

$$s/d = 0.56818182$$

$V_{s,c2} = 0.00$  is calculated for section flange core, with:

$$d = 160.00$$

$$A_v = 100530.965$$

$$f_y = 625.00$$

$$s = 250.00$$

$V_{s,c2}$  is multiplied by  $Col,c2 = 0.00$

$$s/d = 1.5625$$

$$V_f \text{ ((11-3)-(11.4), ACI 440)} = 0.00$$

From (11-11), ACI 440:  $V_s + V_f \leq 873250.061$   
 $bw = 400.00$

Calculation of Shear Strength at edge 2,  $V_{r2} = 1.0392E+006$   
 $V_{r2} = V_{CoI} ((10.3), ASCE 41-17) = knl * V_{CoI0}$   
 $V_{CoI0} = 1.0392E+006$   
 $knl = 1$  (zero step-static loading)

NOTE: In expression (10-3) ' $V_s = A_v * f_y * d / s$ ' is replaced by ' $V_s + f * V_f$ '  
where  $V_f$  is the contribution of FRPs (11.3), ACI 440).

$= 1$  (normal-weight concrete)  
Mean concrete strength:  $f_c' = (f_c'_{jacket} * Area_{jacket} + f_c'_{core} * Area_{core}) / Area_{section} = 30.00$ , but  $f_c'^{0.5} \leq 8.3$  MPa (22.5.3.1, ACI 318-14)  
 $M/Vd = 4.00$   
 $\mu_u = 1308.016$   
 $V_u = 0.00017144$   
 $d = 0.8 * h = 600.00$   
 $N_u = 16273.608$   
 $A_g = 300000.00$   
From (11.5.4.8), ACI 318-14:  $V_s = V_{sjacket} + V_{s,core} = 1.0138E+006$   
where:  
 $V_{sjacket} = V_{sj1} + V_{sj2} = 903207.888$   
 $V_{sj1} = 589048.623$  is calculated for section web jacket, with:  
 $d = 600.00$   
 $A_v = 157079.633$   
 $f_y = 625.00$   
 $s = 100.00$   
 $V_{sj1}$  is multiplied by  $Col,j1 = 1.00$   
 $s/d = 0.16666667$   
 $V_{sj2} = 314159.265$  is calculated for section flange jacket, with:  
 $d = 320.00$   
 $A_v = 157079.633$   
 $f_y = 625.00$   
 $s = 100.00$   
 $V_{sj2}$  is multiplied by  $Col,j2 = 1.00$   
 $s/d = 0.3125$   
 $V_{s,core} = V_{s,c1} + V_{s,c2} = 110584.061$   
 $V_{s,c1} = 110584.061$  is calculated for section web core, with:  
 $d = 440.00$   
 $A_v = 100530.965$   
 $f_y = 625.00$   
 $s = 250.00$   
 $V_{s,c1}$  is multiplied by  $Col,c1 = 1.00$   
 $s/d = 0.56818182$   
 $V_{s,c2} = 0.00$  is calculated for section flange core, with:  
 $d = 160.00$   
 $A_v = 100530.965$   
 $f_y = 625.00$   
 $s = 250.00$   
 $V_{s,c2}$  is multiplied by  $Col,c2 = 0.00$   
 $s/d = 1.5625$   
 $V_f ((11-3)-(11.4), ACI 440) = 0.00$   
From (11-11), ACI 440:  $V_s + V_f \leq 873250.061$   
 $bw = 400.00$

End Of Calculation of Shear Capacity ratio for element: column JLC1 of floor 1  
At local axis: 3

Start Of Calculation of Shear Capacity ratio for element: column JLC1 of floor 1  
At Shear local axis: 2  
(Bending local axis: 3)

Section Type: rcjics

## Constant Properties

Knowledge Factor,  $\gamma = 1.00$

Mean strength values are used for both shear and moment calculations.

Consequently:

Jacket

New material of Primary Member: Concrete Strength,  $f_c = f_{cm} = 30.00$

New material of Primary Member: Steel Strength,  $f_s = f_{sm} = 625.00$

Concrete Elasticity,  $E_c = 25742.96$

Steel Elasticity,  $E_s = 200000.00$

Existing Column

New material of Primary Member: Concrete Strength,  $f_c = f_{cm} = 30.00$

New material of Primary Member: Steel Strength,  $f_s = f_{sm} = 625.00$

Concrete Elasticity,  $E_c = 25742.96$

Steel Elasticity,  $E_s = 200000.00$

#####

Note: Especially for the calculation of moment strengths,

the above steel re-bar strengths are multiplied by 1.25 according to R18.6.5, ACI 318-14

Jacket

New material: Steel Strength,  $f_s = 1.25 \cdot f_{sm} = 781.25$

Existing Column

New material: Steel Strength,  $f_s = 1.25 \cdot f_{sm} = 781.25$

#####

Max Height,  $H_{max} = 750.00$

Min Height,  $H_{min} = 400.00$

Max Width,  $W_{max} = 750.00$

Min Width,  $W_{min} = 400.00$

Jacket Thickness,  $t_j = 100.00$

Cover Thickness,  $c = 25.00$

Mean Confinement Factor overall section = 1.27105

Element Length,  $L = 3000.00$

Primary Member

Smooth Bars

Ductile Steel

With Detailing for Earthquake Resistance (including stirrups closed at  $135^\circ$ )

Longitudinal Bars With Ends Lapped Starting at the End Sections

Lap Length  $l_o = 300.00$

No FRP Wrapping

## Stepwise Properties

At local axis: 2

EDGE -A-

Shear Force,  $V_a = -0.0001715$

EDGE -B-

Shear Force,  $V_b = 0.0001715$

BOTH EDGES

Axial Force,  $F = -16273.608$

Longitudinal Reinforcement Area Distribution (in 2 divisions)

-Tension:  $A_{sl,t} = 0.00$

-Compression:  $A_{sl,c} = 5353.274$

Longitudinal Reinforcement Area Distribution (in 3 divisions)

-Tension:  $A_{sl,ten} = 1137.257$

-Compression:  $A_{sl,com} = 2208.54$

-Middle:  $A_{sl,mid} = 2007.478$

Calculation of Shear Capacity ratio,  $V_e/V_r = 0.32266369$

Member Controlled by Flexure ( $V_e/V_r < 1$ )

Calculation of Shear Demand from fig. R18.6.5, ACI 318-14  $V_e = (M_{pr1} + M_{pr2})/l_n = 335307.657$

with

$M_{pr1} = \text{Max}(M_{u1+}, M_{u1-}) = 5.0296E+008$

Mu1+ = 2.3387E+008, is the ultimate moment strength at the edge 1 of the member in the actual moment direction which is defined for the static loading combination

Mu1- = 5.0296E+008, is the ultimate moment strength at the edge 1 of the member in the opposite moment direction which is defined for the static loading combination

Mpr2 = Max(Mu2+ , Mu2-) = 5.0296E+008

Mu2+ = 2.3387E+008, is the ultimate moment strength at the edge 2 of the member in the actual moment direction which is defined for the static loading combination

Mu2- = 5.0296E+008, is the ultimate moment strength at the edge 2 of the member in the opposite moment direction which is defined for the static loading combination

-----  
Calculation of Mu1+  
-----

-----  
Calculation of ultimate curvature  $\phi_u$  according to 4.1, Biskinis/Fardis 2013:

$\phi_u = 4.8099118E-006$

Mu = 2.3387E+008  
-----

with full section properties:

b = 750.00

d = 707.00

d' = 43.00

v = 0.00102301

N = 16273.608

fc = 30.00

co (5A.5, TBDY) = 0.002

Final value of  $\phi_u$ :  $\phi_u^* = \text{shear\_factor} * \text{Max}(\phi_u, \phi_c) = 0.01260361$

The Shear\_factor is considered equal to 1 (pure moment strength)

From (5.4b), TBDY:  $\phi_u = 0.01260361$

we (5.4c) = 0.05179731

ase ((5.4d), TBDY) =  $(\text{ase1} * A_{\text{ext}} + \text{ase2} * A_{\text{int}}) / A_{\text{sec}} = 0.45746528$

ase1 =  $\text{Max}(((A_{\text{conf,max1}} - A_{\text{noConf1}}) / A_{\text{conf,max1}}) * (A_{\text{conf,min1}} / A_{\text{conf,max1}}), 0) = 0.45746528$

The definitions of  $A_{\text{noConf}}$ ,  $A_{\text{conf,min}}$  and  $A_{\text{conf,max}}$  are derived from generalization of the rectangular sections confinement, which is expressed by (5.4d).

The generalization is done according to Mander, J., Priestley, M., and Park, R. (1988)

"Theoretical Stress-Strain Model for Confined Concrete."

J. Struct. Eng., 10.1061/(ASCE)0733-9445(1988)114:8(1804), 1804-1826.

$A_{\text{conf,max1}} = 353600.00$  is the confined core area at levels of member with hoops and is calculated as the area of core enclosed by the center lines of the external perimeter hoops.

$A_{\text{conf,min1}} = 293525.00$  is the confined core area at midway between the levels of hoops and is calculated by reducing all the dimensions of the area  $A_{\text{conf,max1}}$  by a length equal to half the clear spacing between external hoops.

$A_{\text{noConf1}} = 158733.333$  is the unconfined external core area which is equal to  $b_i^2/6$  as defined at (A.2).

ase2 ( $\geq \text{ase1}$ ) =  $\text{Max}(((A_{\text{conf,max2}} - A_{\text{noConf2}}) / A_{\text{conf,max2}}) * (A_{\text{conf,min2}} / A_{\text{conf,max2}}), 0) = 0.45746528$

The definitions of  $A_{\text{noConf}}$ ,  $A_{\text{conf,min}}$  and  $A_{\text{conf,max}}$  are derived from generalization of the rectangular sections confinement, which is expressed by (5.4d).

The generalization is done according to Mander, J., Priestley, M., and Park, R. (1988)

"Theoretical Stress-Strain Model for Confined Concrete."

J. Struct. Eng., 10.1061/(ASCE)0733-9445(1988)114:8(1804), 1804-1826.

$A_{\text{conf,max2}} = 171264.00$  is the confined core area at levels of member with hoops and is calculated as the area of core enclosed by the center lines of the internal perimeter hoops.

$A_{\text{conf,min2}} = 54741.00$  is the confined core area at midway between the levels of hoops and is calculated by reducing all the dimensions of the area  $A_{\text{conf,max2}}$  by a length equal to half the clear spacing between internal hoops.

$A_{\text{noConf2}} = 106242.667$  is the unconfined internal core area which is equal to  $b_i^2/6$  as defined at (A.2).

$\text{psh,min} * F_{ywe} = \text{Min}(\text{psh,x} * F_{ywe}, \text{psh,y} * F_{ywe}) = 3.3968$

-----  
 $\text{psh,x} * F_{ywe} = \text{psh1} * F_{ywe1} + \text{ps2} * F_{ywe2} = 3.3968$

$\text{psh1}$  ((5.4d), TBDY) =  $L_{\text{stir1}} * A_{\text{stir1}} / (A_{\text{sec}} * s_1) = 0.00367709$

$L_{\text{stir1}}$  (Length of stirrups along Y) = 2060.00

$A_{\text{stir1}}$  (stirrups area) = 78.53982

$\text{psh2}$  (5.4d) =  $L_{\text{stir2}} * A_{\text{stir2}} / (A_{\text{sec}} * s_2) = 0.00067082$

$L_{\text{stir2}}$  (Length of stirrups along Y) = 1468.00

$A_{\text{stir2}}$  (stirrups area) = 50.26548

-----  
 $\text{psh,y} * F_{ywe} = \text{psh1} * F_{ywe1} + \text{ps2} * F_{ywe2} = 3.3968$

$psh1 ((5.4d), TBDY) = Lstir1 * Astir1 / (Asec * s1) = 0.00367709$   
 $Lstir1$  (Length of stirrups along X) = 2060.00  
 $Astir1$  (stirrups area) = 78.53982  
 $psh2 ((5.4d), TBDY) = Lstir2 * Astir2 / (Asec * s2) = 0.00067082$   
 $Lstir2$  (Length of stirrups along X) = 1468.00  
 $Astir2$  (stirrups area) = 50.26548

Asec = 440000.00

s1 = 100.00

s2 = 250.00

fywe1 = 781.25

fywe2 = 781.25

fce = 30.00

From ((5.A5), TBDY), TBDY: cc = 0.00471045

c = confinement factor = 1.27105

y1 = 0.00083886

sh1 = 0.00268436

ft1 = 314.5735

fy1 = 262.1446

su1 = 0.00268436

using (30) in Biskinis/Fardis (2013) multiplied with shear\_factor  
and also multiplied by the shear\_factor according to 15.7.1.4, with  
Shear\_factor = 1.00

lo/lou,min = lb/ld = 0.13907892

su1 = 0.4\*esu1\_nominal ((5.5), TBDY) = 0.032

From table 5A.1, TBDY: esu1\_nominal = 0.08,

For calculation of esu1\_nominal and y1, sh1,ft1,fy1, it is considered  
characteristic value fsy1 = fs1/1.2, from table 5.1, TBDY.

y1, sh1,ft1,fy1, are also multiplied by  $\text{Min}(1, 1.25 * (lb/ld)^{2/3})$ , from 10.3.5, ASCE 41-17.

with fs1 = (fs,jacket\*Asl,ten,jacket + fs,core\*Asl,ten,core)/Asl,ten = 262.1446

with Es1 = (Es,jacket\*Asl,ten,jacket + Es,core\*Asl,ten,core)/Asl,ten = 200000.00

y2 = 0.00083886

sh2 = 0.00268436

ft2 = 314.5735

fy2 = 262.1446

su2 = 0.00268436

using (30) in Biskinis/Fardis (2013) multiplied with shear\_factor  
and also multiplied by the shear\_factor according to 15.7.1.4, with  
Shear\_factor = 1.00

lo/lou,min = lb/lb,min = 0.13907892

su2 = 0.4\*esu2\_nominal ((5.5), TBDY) = 0.032

From table 5A.1, TBDY: esu2\_nominal = 0.08,

For calculation of esu2\_nominal and y2, sh2,ft2,fy2, it is considered  
characteristic value fsy2 = fs2/1.2, from table 5.1, TBDY.

y1, sh1,ft1,fy1, are also multiplied by  $\text{Min}(1, 1.25 * (lb/ld)^{2/3})$ , from 10.3.5, ASCE 41-17.

with fs2 = (fs,jacket\*Asl,com,jacket + fs,core\*Asl,com,core)/Asl,com = 262.1446

with Es2 = (Es,jacket\*Asl,com,jacket + Es,core\*Asl,com,core)/Asl,com = 200000.00

yv = 0.00083886

shv = 0.00268436

ftv = 314.5735

fyv = 262.1446

suv = 0.00268436

using (30) in Biskinis/Fardis (2013) multiplied with shear\_factor  
and also multiplied by the shear\_factor according to 15.7.1.4, with  
Shear\_factor = 1.00

lo/lou,min = lb/ld = 0.13907892

suv = 0.4\*esuv\_nominal ((5.5), TBDY) = 0.032

From table 5A.1, TBDY: esuv\_nominal = 0.08,

considering characteristic value fsyv = fsv/1.2, from table 5.1, TBDY

For calculation of esuv\_nominal and yv, shv,ftv,fyv, it is considered  
characteristic value fsyv = fsv/1.2, from table 5.1, TBDY.

y1, sh1,ft1,fy1, are also multiplied by  $\text{Min}(1, 1.25 * (lb/ld)^{2/3})$ , from 10.3.5, ASCE 41-17.

with fsv = (fs,jacket\*Asl,mid,jacket + fs,mid\*Asl,mid,core)/Asl,mid = 262.1446

with Esv = (Es,jacket\*Asl,mid,jacket + Es,mid\*Asl,mid,core)/Asl,mid = 200000.00

1 = Asl,ten/(b\*d)\*(fs1/fc) = 0.0187412

2 = Asl,com/(b\*d)\*(fs2/fc) = 0.03639521

v = Asl,mid/(b\*d)\*(fsv/fc) = 0.03308184

and confined core properties:

$$b = 690.00$$

$$d = 677.00$$

$$d' = 13.00$$

$$fcc(5A.2, TBDY) = 38.13135$$

$$cc(5A.5, TBDY) = 0.00471045$$

$$c = \text{confinement factor} = 1.27105$$

$$1 = A_{sl,ten}/(b*d)*(f_{s1}/f_c) = 0.02127357$$

$$2 = A_{sl,com}/(b*d)*(f_{s2}/f_c) = 0.04131304$$

$$v = A_{sl,mid}/(b*d)*(f_{sv}/f_c) = 0.03755196$$

Case/Assumption: Unconfined full section - Steel rupture

' satisfies Eq. (4.3)

--->

$v < v_{s,y2}$  - LHS eq.(4.5) is satisfied

--->

$$s_u(4.9) = 0.21062322$$

$$M_u = M_{Rc}(4.14) = 2.3387E+008$$

$$u = s_u(4.1) = 4.8099118E-006$$

Calculation of ratio  $l_b/l_d$

Lap Length:  $l_b/l_d = 0.13907892$

$$l_b = 300.00$$

$$l_d = 2157.049$$

Calculation of  $l_b, \min$  according to (25.4.3.2), ACI 318-14, using mean values for all the section re-bars.

$l_d, \min$  from (25.4.3.2) is multiplied 2 times to account for smooth re-bars (9.1.2, TS500 - No provision in ACI 318)

$$= 1$$

$$d_b = 16.66667$$

Mean strength value of all re-bars:  $f_y = 781.25$

Mean concrete strength:  $f'_c = (f'_c_{\text{jacket}} * \text{Area}_{\text{jacket}} + f'_c_{\text{core}} * \text{Area}_{\text{core}}) / \text{Area}_{\text{section}} = 30.00$ , but  $f_c^{0.5} \leq 8.3$  MPa (22.5.3.1, ACI 318-14)

$$t = 1.00$$

$$s = 0.80$$

$$e = 1.00$$

$$c_b = 25.00$$

$$K_{tr} = 1.7174$$

$$A_{tr} = \text{Min}(A_{tr,x}, A_{tr,y}) = 257.6106$$

where  $A_{tr,x}$ ,  $A_{tr,y}$  are the sum of the area of all stirrup legs along X and Y loxal axis

$$s = \text{Max}(s_{\text{external}}, s_{\text{internal}}) = 250.00$$

$$n = 24.00$$

Calculation of  $M_{u1}$ -

Calculation of ultimate curvature  $u$  according to 4.1, Biskinis/Fardis 2013:

$$u = 5.1201636E-006$$

$$M_u = 5.0296E+008$$

with full section properties:

$$b = 400.00$$

$$d = 707.00$$

$$d' = 43.00$$

$$v = 0.00191815$$

$$N = 16273.608$$

$$f_c = 30.00$$

$$c_o(5A.5, TBDY) = 0.002$$

$$\text{Final value of } c_u: c_u^* = \text{shear\_factor} * \text{Max}(c_u, c_o) = 0.01260361$$

The Shear\_factor is considered equal to 1 (pure moment strength)

$$\text{From (5.4b), TBDY: } c_u = 0.01260361$$

$$w_e(5.4c) = 0.05179731$$

$$a_{se}((5.4d), TBDY) = (a_{se1} * A_{ext} + a_{se2} * A_{int}) / A_{sec} = 0.45746528$$

$$a_{se1} = \text{Max}(((A_{conf,max1} - A_{noConf1}) / A_{conf,max1}) * (A_{conf,min1} / A_{conf,max1}), 0) = 0.45746528$$

The definitions of  $A_{noConf}$ ,  $A_{conf,min}$  and  $A_{conf,max}$  are derived from generalization

of the rectangular sections confinement, which is expressed by (5.4d).

The generalization is done according to Mander, J., Priestley, M., and Park, R. (1988)

"Theoretical Stress-Strain Model for Confined Concrete."

J. Struct. Eng., 10.1061/(ASCE)0733-9445(1988)114:8(1804), 1804-1826.

$A_{conf,max1} = 353600.00$  is the confined core area at levels of member with hoops and

is calculated as the area of core enclosed by the center lines of the external perimeter hoops.

$A_{conf,min1} = 293525.00$  is the confined core area at midway between the levels of hoops and

is calculated by reducing all the dimensions of the area  $A_{conf,max1}$  by a length

equal to half the clear spacing between external hoops.

$A_{noConf1} = 158733.333$  is the unconfined external core area which is equal to  $b_i^2/6$  as defined at (A.2).

$ase2 (>= ase1) = \text{Max}(((A_{conf,max2} - A_{noConf2})/A_{conf,max2}) * (A_{conf,min2}/A_{conf,max2}), 0) = 0.45746528$

The definitions of  $A_{noConf}$ ,  $A_{conf,min}$  and  $A_{conf,max}$  are derived from generalization

of the rectangular sections confinement, which is expressed by (5.4d).

The generalization is done according to Mander, J., Priestley, M., and Park, R. (1988)

"Theoretical Stress-Strain Model for Confined Concrete."

J. Struct. Eng., 10.1061/(ASCE)0733-9445(1988)114:8(1804), 1804-1826.

$A_{conf,max2} = 171264.00$  is the confined core area at levels of member with hoops and

is calculated as the area of core enclosed by the center lines of the internal perimeter hoops.

$A_{conf,min2} = 54741.00$  is the confined core area at midway between the levels of hoops and

is calculated by reducing all the dimensions of the area  $A_{conf,max2}$  by a length

equal to half the clear spacing between internal hoops.

$A_{noConf2} = 106242.667$  is the unconfined internal core area which is equal to  $b_i^2/6$  as defined at (A.2).

$psh_{min} * F_{ywe} = \text{Min}(psh_x * F_{ywe}, psh_y * F_{ywe}) = 3.3968$

$psh_x * F_{ywe} = psh1 * F_{ywe1} + ps2 * F_{ywe2} = 3.3968$

$psh1 ((5.4d), TBDY) = L_{stir1} * A_{stir1} / (A_{sec} * s1) = 0.00367709$

$L_{stir1}$  (Length of stirrups along Y) = 2060.00

$A_{stir1}$  (stirrups area) = 78.53982

$psh2 ((5.4d)) = L_{stir2} * A_{stir2} / (A_{sec} * s2) = 0.00067082$

$L_{stir2}$  (Length of stirrups along Y) = 1468.00

$A_{stir2}$  (stirrups area) = 50.26548

$psh_y * F_{ywe} = psh1 * F_{ywe1} + ps2 * F_{ywe2} = 3.3968$

$psh1 ((5.4d), TBDY) = L_{stir1} * A_{stir1} / (A_{sec} * s1) = 0.00367709$

$L_{stir1}$  (Length of stirrups along X) = 2060.00

$A_{stir1}$  (stirrups area) = 78.53982

$psh2 ((5.4d), TBDY) = L_{stir2} * A_{stir2} / (A_{sec} * s2) = 0.00067082$

$L_{stir2}$  (Length of stirrups along X) = 1468.00

$A_{stir2}$  (stirrups area) = 50.26548

$A_{sec} = 440000.00$

$s1 = 100.00$

$s2 = 250.00$

$f_{ywe1} = 781.25$

$f_{ywe2} = 781.25$

$f_{ce} = 30.00$

From ((5.A5), TBDY), TBDY:  $cc = 0.00471045$

$c = \text{confinement factor} = 1.27105$

$y1 = 0.00083886$

$sh1 = 0.00268436$

$ft1 = 314.5735$

$fy1 = 262.1446$

$su1 = 0.00268436$

using (30) in Biskinis/Fardis (2013) multiplied with  $shear\_factor$

and also multiplied by the  $shear\_factor$  according to 15.7.1.4, with

$Shear\_factor = 1.00$

$lo/lo_{u,min} = l_b/l_d = 0.13907892$

$su1 = 0.4 * esu1\_nominal ((5.5), TBDY) = 0.032$

From table 5A.1, TBDY:  $esu1\_nominal = 0.08$ ,

For calculation of  $esu1\_nominal$  and  $y1, sh1, ft1, fy1$ , it is considered

characteristic value  $fsy1 = fs1/1.2$ , from table 5.1, TBDY.

$y1, sh1, ft1, fy1$ , are also multiplied by  $\text{Min}(1, 1.25 * (l_b/l_d)^{2/3})$ , from 10.3.5, ASCE 41-17.

with  $fs1 = (f_{s,jacket} * A_{s1,ten,jacket} + f_{s,core} * A_{s1,ten,core}) / A_{s1,ten} = 262.1446$

with  $Es1 = (E_{s,jacket} * A_{s1,ten,jacket} + E_{s,core} * A_{s1,ten,core}) / A_{s1,ten} = 200000.00$

$y2 = 0.00083886$

$sh2 = 0.00268436$

$ft2 = 314.5735$



```

fy2 = 262.1446
su2 = 0.00268436
    using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
    and also multiplied by the shear_factor according to 15.7.1.4, with
    Shear_factor = 1.00
    lo/lou,min = lb/lb,min = 0.13907892
    su2 = 0.4*esu2_nominal ((5.5), TBDY) = 0.032
    From table 5A.1, TBDY: esu2_nominal = 0.08,
    For calculation of esu2_nominal and y2, sh2,ft2,fy2, it is considered
    characteristic value fsy2 = fs2/1.2, from table 5.1, TBDY.
    y1, sh1,ft1,fy1, are also multiplied by Min(1,1.25*(lb/lb)^ 2/3), from 10.3.5, ASCE 41-17.
    with fs2 = (fs,jacket*Asl,com,jacket + fs,core*Asl,com,core)/Asl,com = 262.1446
    with Es2 = (Es,jacket*Asl,com,jacket + Es,core*Asl,com,core)/Asl,com = 200000.00
    yv = 0.00083886
    shv = 0.00268436
    ftv = 314.5735
    fyv = 262.1446
    suv = 0.00268436
    using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
    and also multiplied by the shear_factor according to 15.7.1.4, with
    Shear_factor = 1.00
    lo/lou,min = lb/lb = 0.13907892
    suv = 0.4*esuv_nominal ((5.5), TBDY) = 0.032
    From table 5A.1, TBDY: esuv_nominal = 0.08,
    considering characteristic value fsyv = fsv/1.2, from table 5.1, TBDY
    For calculation of esuv_nominal and yv, shv,ftv,fyv, it is considered
    characteristic value fsyv = fsv/1.2, from table 5.1, TBDY.
    y1, sh1,ft1,fy1, are also multiplied by Min(1,1.25*(lb/lb)^ 2/3), from 10.3.5, ASCE 41-17.
    with fsv = (fs,jacket*Asl,mid,jacket + fs,mid*Asl,mid,core)/Asl,mid = 262.1446
    with Esv = (Es,jacket*Asl,mid,jacket + Es,mid*Asl,mid,core)/Asl,mid = 200000.00
    1 = Asl,ten/(b*d)*(fs1/fc) = 0.06824101
    2 = Asl,com/(b*d)*(fs2/fc) = 0.03513975
    v = Asl,mid/(b*d)*(fsv/fc) = 0.06202846

```

and confined core properties:

```

b = 340.00
d = 677.00
d' = 13.00
fcc (5A.2, TBDY) = 38.13135
cc (5A.5, TBDY) = 0.00471045
    c = confinement factor = 1.27105
    1 = Asl,ten/(b*d)*(fs1/fc) = 0.08384116
    2 = Asl,com/(b*d)*(fs2/fc) = 0.04317283
    v = Asl,mid/(b*d)*(fsv/fc) = 0.07620839

```

Case/Assumption: Unconfined full section - Steel rupture  
 ' satisfies Eq. (4.3)

```

---->
v < vs,y2 - LHS eq.(4.5) is satisfied
---->
su (4.9) = 0.2584548
Mu = MRc (4.14) = 5.0296E+008
u = su (4.1) = 5.1201636E-006

```

Calculation of ratio lb/lb

```

Lap Length: lb/lb = 0.13907892
lb = 300.00
lb = 2157.049
Calculation of lb,min according to (25.4.3.2), ACI 318-14, using mean values for all the section re-bars.
lb,min from (25.4.3.2) is multiplied 2 times to account for smooth re-bars (9.1.2, TS500 - No provision in ACI 318)
    = 1
db = 16.66667
Mean strength value of all re-bars: fy = 781.25
Mean concrete strength: fc' = (fc'_jacket*Area_jacket + fc'_core*Area_core)/Area_section = 30.00, but fc'^0.5 <= 8.3
MPa (22.5.3.1, ACI 318-14)
    t = 1.00
    s = 0.80

```

$e = 1.00$   
 $cb = 25.00$   
 $Ktr = 1.7174$   
 $Atr = \text{Min}(Atr_x, Atr_y) = 257.6106$   
 where  $Atr_x, Atr_y$  are the sum of the area of all stirrup legs along X and Y loxal axis  
 $s = \text{Max}(s_{\text{external}}, s_{\text{internal}}) = 250.00$   
 $n = 24.00$

Calculation of  $\mu_{2+}$

Calculation of ultimate curvature  $\mu$  according to 4.1, Biskinis/Fardis 2013:  
 $\mu = 4.8099118E-006$   
 $\mu_u = 2.3387E+008$

with full section properties:

$b = 750.00$   
 $d = 707.00$   
 $d' = 43.00$   
 $v = 0.00102301$   
 $N = 16273.608$   
 $f_c = 30.00$   
 $\alpha (5A.5, TBDY) = 0.002$

Final value of  $\mu_u$ :  $\mu_u^* = \text{shear\_factor} * \text{Max}(\mu_u, \mu_c) = 0.01260361$

The Shear\_factor is considered equal to 1 (pure moment strength)

From (5.4b), TBDY:  $\mu_u = 0.01260361$

we (5.4c)  $= 0.05179731$

$\alpha_{se} ((5.4d), TBDY) = (\alpha_{se1} * A_{ext} + \alpha_{se2} * A_{int}) / A_{sec} = 0.45746528$

$\alpha_{se1} = \text{Max}(((A_{conf,max1} - A_{noConf1}) / A_{conf,max1}) * (A_{conf,min1} / A_{conf,max1}), 0) = 0.45746528$

The definitions of  $A_{noConf}$ ,  $A_{conf,min}$  and  $A_{conf,max}$  are derived from generalization of the rectangular sections confinement, which is expressed by (5.4d).

The generalization is done according to Mander, J., Priestley, M., and Park, R. (1988)

"Theoretical Stress-Strain Model for Confined Concrete."

J. Struct. Eng., 10.1061/(ASCE)0733-9445(1988)114:8(1804), 1804-1826.

$A_{conf,max1} = 353600.00$  is the confined core area at levels of member with hoops and is calculated as the area of core enclosed by the center lines of the external perimeter hoops.

$A_{conf,min1} = 293525.00$  is the confined core area at midway between the levels of hoops and is calculated by reducing all the dimensions of the area  $A_{conf,max1}$  by a length equal to half the clear spacing between external hoops.

$A_{noConf1} = 158733.333$  is the unconfined external core area which is equal to  $b_i^2/6$  as defined at (A.2).

$\alpha_{se2} (> \alpha_{se1}) = \text{Max}(((A_{conf,max2} - A_{noConf2}) / A_{conf,max2}) * (A_{conf,min2} / A_{conf,max2}), 0) = 0.45746528$

The definitions of  $A_{noConf}$ ,  $A_{conf,min}$  and  $A_{conf,max}$  are derived from generalization of the rectangular sections confinement, which is expressed by (5.4d).

The generalization is done according to Mander, J., Priestley, M., and Park, R. (1988)

"Theoretical Stress-Strain Model for Confined Concrete."

J. Struct. Eng., 10.1061/(ASCE)0733-9445(1988)114:8(1804), 1804-1826.

$A_{conf,max2} = 171264.00$  is the confined core area at levels of member with hoops and is calculated as the area of core enclosed by the center lines of the internal perimeter hoops.

$A_{conf,min2} = 54741.00$  is the confined core area at midway between the levels of hoops and is calculated by reducing all the dimensions of the area  $A_{conf,max2}$  by a length equal to half the clear spacing between internal hoops.

$A_{noConf2} = 106242.667$  is the unconfined internal core area which is equal to  $b_i^2/6$  as defined at (A.2).

$psh_{min} * F_{ywe} = \text{Min}(psh_x * F_{ywe}, psh_y * F_{ywe}) = 3.3968$

$psh_x * F_{ywe} = psh1 * F_{ywe1} + psh2 * F_{ywe2} = 3.3968$

$psh1 ((5.4d), TBDY) = L_{stir1} * A_{stir1} / (A_{sec} * s1) = 0.00367709$

$L_{stir1}$  (Length of stirrups along Y) = 2060.00

$A_{stir1}$  (stirrups area) = 78.53982

$psh2 ((5.4d)) = L_{stir2} * A_{stir2} / (A_{sec} * s2) = 0.00067082$

$L_{stir2}$  (Length of stirrups along Y) = 1468.00

$A_{stir2}$  (stirrups area) = 50.26548

$psh_y * F_{ywe} = psh1 * F_{ywe1} + psh2 * F_{ywe2} = 3.3968$

$psh1 ((5.4d), TBDY) = L_{stir1} * A_{stir1} / (A_{sec} * s1) = 0.00367709$

Lstir1 (Length of stirrups along X) = 2060.00  
 Astir1 (stirrups area) = 78.53982  
 $psh2 ((5.4d), TBDY) = Lstir2 * Astir2 / (Asec * s2) = 0.00067082$   
 Lstir2 (Length of stirrups along X) = 1468.00  
 Astir2 (stirrups area) = 50.26548

Asec = 440000.00

s1 = 100.00

s2 = 250.00

fywe1 = 781.25

fywe2 = 781.25

fce = 30.00

From ((5.A5), TBDY), TBDY: cc = 0.00471045

c = confinement factor = 1.27105

y1 = 0.00083886

sh1 = 0.00268436

ft1 = 314.5735

fy1 = 262.1446

su1 = 0.00268436

using (30) in Biskinis/Fardis (2013) multiplied with shear\_factor  
 and also multiplied by the shear\_factor according to 15.7.1.4, with  
 Shear\_factor = 1.00

lo/lou,min = lb/ld = 0.13907892

su1 = 0.4\*esu1\_nominal ((5.5), TBDY) = 0.032

From table 5A.1, TBDY: esu1\_nominal = 0.08,

For calculation of esu1\_nominal and y1, sh1,ft1,fy1, it is considered  
 characteristic value fsy1 = fs1/1.2, from table 5.1, TBDY.

y1, sh1,ft1,fy1, are also multiplied by  $\text{Min}(1, 1.25 * (lb/ld)^{2/3})$ , from 10.3.5, ASCE 41-17.

with fs1 = (fs,jacket\*Asl,ten,jacket + fs,core\*Asl,ten,core)/Asl,ten = 262.1446

with Es1 = (Es,jacket\*Asl,ten,jacket + Es,core\*Asl,ten,core)/Asl,ten = 200000.00

y2 = 0.00083886

sh2 = 0.00268436

ft2 = 314.5735

fy2 = 262.1446

su2 = 0.00268436

using (30) in Biskinis/Fardis (2013) multiplied with shear\_factor  
 and also multiplied by the shear\_factor according to 15.7.1.4, with  
 Shear\_factor = 1.00

lo/lou,min = lb/lb,min = 0.13907892

su2 = 0.4\*esu2\_nominal ((5.5), TBDY) = 0.032

From table 5A.1, TBDY: esu2\_nominal = 0.08,

For calculation of esu2\_nominal and y2, sh2,ft2,fy2, it is considered  
 characteristic value fsy2 = fs2/1.2, from table 5.1, TBDY.

y1, sh1,ft1,fy1, are also multiplied by  $\text{Min}(1, 1.25 * (lb/ld)^{2/3})$ , from 10.3.5, ASCE 41-17.

with fs2 = (fs,jacket\*Asl,com,jacket + fs,core\*Asl,com,core)/Asl,com = 262.1446

with Es2 = (Es,jacket\*Asl,com,jacket + Es,core\*Asl,com,core)/Asl,com = 200000.00

yv = 0.00083886

shv = 0.00268436

ftv = 314.5735

fyv = 262.1446

suv = 0.00268436

using (30) in Biskinis/Fardis (2013) multiplied with shear\_factor  
 and also multiplied by the shear\_factor according to 15.7.1.4, with  
 Shear\_factor = 1.00

lo/lou,min = lb/ld = 0.13907892

suv = 0.4\*esuv\_nominal ((5.5), TBDY) = 0.032

From table 5A.1, TBDY: esuv\_nominal = 0.08,

considering characteristic value fsyv = fsv/1.2, from table 5.1, TBDY

For calculation of esuv\_nominal and yv, shv,ftv,fyv, it is considered  
 characteristic value fsyv = fsv/1.2, from table 5.1, TBDY.

y1, sh1,ft1,fy1, are also multiplied by  $\text{Min}(1, 1.25 * (lb/ld)^{2/3})$ , from 10.3.5, ASCE 41-17.

with fsv = (fs,jacket\*Asl,mid,jacket + fs,mid\*Asl,mid,core)/Asl,mid = 262.1446

with Esv = (Es,jacket\*Asl,mid,jacket + Es,mid\*Asl,mid,core)/Asl,mid = 200000.00

1 = Asl,ten/(b\*d)\*(fs1/fc) = 0.0187412

2 = Asl,com/(b\*d)\*(fs2/fc) = 0.03639521

v = Asl,mid/(b\*d)\*(fsv/fc) = 0.03308184

and confined core properties:

$b = 690.00$   
 $d = 677.00$   
 $d' = 13.00$   
 $f_{cc} (5A.2, TBDY) = 38.13135$   
 $cc (5A.5, TBDY) = 0.00471045$   
 $c = \text{confinement factor} = 1.27105$   
 $1 = A_{sl,ten}/(b*d)*(f_{s1}/f_c) = 0.02127357$   
 $2 = A_{sl,com}/(b*d)*(f_{s2}/f_c) = 0.04131304$   
 $v = A_{sl,mid}/(b*d)*(f_{sv}/f_c) = 0.03755196$   
 Case/Assumption: Unconfined full section - Steel rupture  
 ' satisfies Eq. (4.3)

--->  
 $v < v_{s,y2}$  - LHS eq.(4.5) is satisfied  
 --->  
 $su (4.9) = 0.21062322$   
 $Mu = MRc (4.14) = 2.3387E+008$   
 $u = su (4.1) = 4.8099118E-006$

Calculation of ratio  $l_b/l_d$

Lap Length:  $l_b/l_d = 0.13907892$   
 $l_b = 300.00$   
 $l_d = 2157.049$   
 Calculation of  $l_b, \min$  according to (25.4.3.2), ACI 318-14, using mean values for all the section re-bars.  
 $l_d, \min$  from (25.4.3.2) is multiplied 2 times to account for smooth re-bars (9.1.2, TS500 - No provision in ACI 318)  
 $= 1$   
 $db = 16.66667$   
 Mean strength value of all re-bars:  $f_y = 781.25$   
 Mean concrete strength:  $f_c' = (f_c'_{jacket} * Area_{jacket} + f_c'_{core} * Area_{core}) / Area_{section} = 30.00$ , but  $f_c'^{0.5} \leq 8.3$   
 MPa (22.5.3.1, ACI 318-14)  
 $t = 1.00$   
 $s = 0.80$   
 $e = 1.00$   
 $cb = 25.00$   
 $K_{tr} = 1.7174$   
 $A_{tr} = \min(A_{tr,x}, A_{tr,y}) = 257.6106$   
 where  $A_{tr,x}$ ,  $A_{tr,y}$  are the sum of the area of all stirrup legs along X and Y loxal axis  
 $s = \max(s_{external}, s_{internal}) = 250.00$   
 $n = 24.00$

Calculation of  $Mu_2$ -

Calculation of ultimate curvature  $u$  according to 4.1, Biskinis/Fardis 2013:  
 $u = 5.1201636E-006$   
 $Mu = 5.0296E+008$

with full section properties:

$b = 400.00$   
 $d = 707.00$   
 $d' = 43.00$   
 $v = 0.00191815$   
 $N = 16273.608$   
 $f_c = 30.00$   
 $co (5A.5, TBDY) = 0.002$   
 Final value of  $cu$ :  $cu^* = \text{shear\_factor} * \max(cu, cc) = 0.01260361$   
 The Shear\_factor is considered equal to 1 (pure moment strength)  
 From (5.4b), TBDY:  $cu = 0.01260361$   
 $we (5.4c) = 0.05179731$   
 $ase ((5.4d), TBDY) = (ase1 * A_{ext} + ase2 * A_{int}) / A_{sec} = 0.45746528$   
 $ase1 = \max(((A_{conf,max1} - A_{noConf1}) / A_{conf,max1}) * (A_{conf,min1} / A_{conf,max1}), 0) = 0.45746528$   
 The definitions of  $A_{noConf}$ ,  $A_{conf,min}$  and  $A_{conf,max}$  are derived from generalization of the rectangular sections confinement, which is expressed by (5.4d).

The generalization is done according to Mander, J., Priestley, M., and Park, R. (1988)  
"Theoretical Stress-Strain Model for Confined Concrete."

J. Struct. Eng., 10.1061/(ASCE)0733-9445(1988)114:8(1804), 1804-1826.

$A_{conf,max1} = 353600.00$  is the confined core area at levels of member with hoops and  
is calculated as the area of core enclosed by the center lines of the external perimeter hoops.

$A_{conf,min1} = 293525.00$  is the confined core area at midway between the levels of hoops and  
is calculated by reducing all the dimensions of the area  $A_{conf,max1}$  by a length  
equal to half the clear spacing between external hoops.

$A_{noConf1} = 158733.333$  is the unconfined external core area which is equal to  $b_i^2/6$  as defined at (A.2).

$ase2 (>= ase1) = \text{Max}(((A_{conf,max2} - A_{noConf2})/A_{conf,max2}) * (A_{conf,min2}/A_{conf,max2}), 0) = 0.45746528$

The definitions of  $A_{noConf}$ ,  $A_{conf,min}$  and  $A_{conf,max}$  are derived from generalization  
of the rectangular sections confinement, which is expressed by (5.4d).

The generalization is done according to Mander, J., Priestley, M., and Park, R. (1988)  
"Theoretical Stress-Strain Model for Confined Concrete."

J. Struct. Eng., 10.1061/(ASCE)0733-9445(1988)114:8(1804), 1804-1826.

$A_{conf,max2} = 171264.00$  is the confined core area at levels of member with hoops and  
is calculated as the area of core enclosed by the center lines of the internal perimeter hoops.

$A_{conf,min2} = 54741.00$  is the confined core area at midway between the levels of hoops and  
is calculated by reducing all the dimensions of the area  $A_{conf,max2}$  by a length  
equal to half the clear spacing between internal hoops.

$A_{noConf2} = 106242.667$  is the unconfined internal core area which is equal to  $b_i^2/6$  as defined at (A.2).

$psh,min * F_{ywe} = \text{Min}(psh,x * F_{ywe}, psh,y * F_{ywe}) = 3.3968$

$psh_x * F_{ywe} = psh1 * F_{ywe1} + ps2 * F_{ywe2} = 3.3968$

$psh1 ((5.4d), TBDY) = L_{stir1} * A_{stir1} / (A_{sec} * s1) = 0.00367709$

$L_{stir1}$  (Length of stirrups along Y) = 2060.00

$A_{stir1}$  (stirrups area) = 78.53982

$psh2 (5.4d) = L_{stir2} * A_{stir2} / (A_{sec} * s2) = 0.00067082$

$L_{stir2}$  (Length of stirrups along Y) = 1468.00

$A_{stir2}$  (stirrups area) = 50.26548

$psh_y * F_{ywe} = psh1 * F_{ywe1} + ps2 * F_{ywe2} = 3.3968$

$psh1 ((5.4d), TBDY) = L_{stir1} * A_{stir1} / (A_{sec} * s1) = 0.00367709$

$L_{stir1}$  (Length of stirrups along X) = 2060.00

$A_{stir1}$  (stirrups area) = 78.53982

$psh2 ((5.4d), TBDY) = L_{stir2} * A_{stir2} / (A_{sec} * s2) = 0.00067082$

$L_{stir2}$  (Length of stirrups along X) = 1468.00

$A_{stir2}$  (stirrups area) = 50.26548

$A_{sec} = 440000.00$

$s1 = 100.00$

$s2 = 250.00$

$f_{ywe1} = 781.25$

$f_{ywe2} = 781.25$

$f_{ce} = 30.00$

From ((5.A5), TBDY), TBDY:  $cc = 0.00471045$

$c = \text{confinement factor} = 1.27105$

$y1 = 0.00083886$

$sh1 = 0.00268436$

$ft1 = 314.5735$

$fy1 = 262.1446$

$su1 = 0.00268436$

using (30) in Biskinis/Fardis (2013) multiplied with shear\_factor  
and also multiplied by the shear\_factor according to 15.7.1.4, with  
 $\text{Shear\_factor} = 1.00$

$l_o/l_{ou,min} = l_b/l_d = 0.13907892$

$su1 = 0.4 * esu1_{nominal} ((5.5), TBDY) = 0.032$

From table 5A.1, TBDY:  $esu1_{nominal} = 0.08$ ,

For calculation of  $esu1_{nominal}$  and  $y1, sh1, ft1, fy1$ , it is considered  
characteristic value  $fsy1 = fs1/1.2$ , from table 5.1, TBDY.

$y1, sh1, ft1, fy1$ , are also multiplied by  $\text{Min}(1, 1.25 * (l_b/l_d)^{2/3})$ , from 10.3.5, ASCE 41-17.

with  $fs1 = (f_{s,jacket} * A_{s,ten,jacket} + f_{s,core} * A_{s,ten,core}) / A_{s,ten} = 262.1446$

with  $Es1 = (E_{s,jacket} * A_{s,ten,jacket} + E_{s,core} * A_{s,ten,core}) / A_{s,ten} = 200000.00$

$y2 = 0.00083886$

$sh2 = 0.00268436$

$ft2 = 314.5735$

$fy2 = 262.1446$

```

su2 = 0.00268436
using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00
lo/lou,min = lb/lb,min = 0.13907892
su2 = 0.4*esu2_nominal ((5.5), TBDY) = 0.032
From table 5A.1, TBDY: esu2_nominal = 0.08,
For calculation of esu2_nominal and y2, sh2,ft2,fy2, it is considered
characteristic value fsy2 = fs2/1.2, from table 5.1, TBDY.
y1, sh1,ft1,fy1, are also multiplied by Min(1,1.25*(lb/lb)^ 2/3), from 10.3.5, ASCE 41-17.
with fs2 = (fs,jacket*Asl,com,jacket + fs,core*Asl,com,core)/Asl,com = 262.1446
with Es2 = (Es,jacket*Asl,com,jacket + Es,core*Asl,com,core)/Asl,com = 200000.00
yv = 0.00083886
shv = 0.00268436
ftv = 314.5735
fyv = 262.1446
suv = 0.00268436
using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00
lo/lou,min = lb/lb = 0.13907892
suv = 0.4*esuv_nominal ((5.5), TBDY) = 0.032
From table 5A.1, TBDY: esuv_nominal = 0.08,
considering characteristic value fsyv = fsv/1.2, from table 5.1, TBDY
For calculation of esuv_nominal and yv, shv,ftv,fyv, it is considered
characteristic value fsyv = fsv/1.2, from table 5.1, TBDY.
y1, sh1,ft1,fy1, are also multiplied by Min(1,1.25*(lb/lb)^ 2/3), from 10.3.5, ASCE 41-17.
with fsv = (fs,jacket*Asl,mid,jacket + fs,mid*Asl,mid,core)/Asl,mid = 262.1446
with Esv = (Es,jacket*Asl,mid,jacket + Es,mid*Asl,mid,core)/Asl,mid = 200000.00
1 = Asl,ten/(b*d)*(fs1/fc) = 0.06824101
2 = Asl,com/(b*d)*(fs2/fc) = 0.03513975
v = Asl,mid/(b*d)*(fsv/fc) = 0.06202846
and confined core properties:
b = 340.00
d = 677.00
d' = 13.00
fcc (5A.2, TBDY) = 38.13135
cc (5A.5, TBDY) = 0.00471045
c = confinement factor = 1.27105
1 = Asl,ten/(b*d)*(fs1/fc) = 0.08384116
2 = Asl,com/(b*d)*(fs2/fc) = 0.04317283
v = Asl,mid/(b*d)*(fsv/fc) = 0.07620839
Case/Assumption: Unconfined full section - Steel rupture
'satisfies Eq. (4.3)
---->
v < vs,y2 - LHS eq.(4.5) is satisfied
---->
su (4.9) = 0.2584548
Mu = MRc (4.14) = 5.0296E+008
u = su (4.1) = 5.1201636E-006
-----

Calculation of ratio lb/lb
-----
Lap Length: lb/lb = 0.13907892
lb = 300.00
lb = 2157.049
Calculation of lb,min according to (25.4.3.2), ACI 318-14, using mean values for all the section re-bars.
lb,min from (25.4.3.2) is multiplied 2 times to account for smooth re-bars (9.1.2, TS500 - No provision in ACI 318)
= 1
db = 16.66667
Mean strength value of all re-bars: fy = 781.25
Mean concrete strength: fc' = (fc'_jacket*Area_jacket + fc'_core*Area_core)/Area_section = 30.00, but fc'^0.5 <= 8.3
MPa (22.5.3.1, ACI 318-14)
t = 1.00
s = 0.80
e = 1.00

```

$$cb = 25.00$$

$$K_{tr} = 1.7174$$

$$A_{tr} = \text{Min}(A_{tr\_x}, A_{tr\_y}) = 257.6106$$

where  $A_{tr\_x}$ ,  $A_{tr\_y}$  are the sum of the area of all stirrup legs along X and Y loxal axis

$$s = \text{Max}(s_{\text{external}}, s_{\text{internal}}) = 250.00$$

$$n = 24.00$$

$$\text{Calculation of Shear Strength } V_r = \text{Min}(V_{r1}, V_{r2}) = 1.0392\text{E}+006$$

$$\text{Calculation of Shear Strength at edge 1, } V_{r1} = 1.0392\text{E}+006$$

$$V_{r1} = V_{\text{Col}} ((10.3), \text{ASCE 41-17}) = k_{nl} * V_{\text{Col}0}$$

$$V_{\text{Col}0} = 1.0392\text{E}+006$$

$$k_{nl} = 1 \text{ (zero step-static loading)}$$

NOTE: In expression (10-3) ' $V_s = A_v * f_y * d / s$ ' is replaced by ' $V_s + f * V_f$ ' where  $V_f$  is the contribution of FRPs (11.3), ACI 440).

$$= 1 \text{ (normal-weight concrete)}$$

$$\text{Mean concrete strength: } f'_c = (f'_{c\_jacket} * \text{Area}_{jacket} + f'_{c\_core} * \text{Area}_{core}) / \text{Area}_{\text{section}} = 30.00, \text{ but } f'_c^{0.5} \leq 8.3 \text{ MPa (22.5.3.1, ACI 318-14)}$$

$$M/Vd = 4.00$$

$$\mu_u = 1308.675$$

$$V_u = 0.0001715$$

$$d = 0.8 * h = 600.00$$

$$N_u = 16273.608$$

$$A_g = 300000.00$$

$$\text{From (11.5.4.8), ACI 318-14: } V_s = V_{s,jacket} + V_{s,core} = 1.0138\text{E}+006$$

where:

$$V_{s,jacket} = V_{s,j1} + V_{s,j2} = 903207.888$$

$V_{s,j1} = 314159.265$  is calculated for section web jacket, with:

$$d = 320.00$$

$$A_v = 157079.633$$

$$f_y = 625.00$$

$$s = 100.00$$

$$V_{s,j1} \text{ is multiplied by } Col_{j1} = 1.00$$

$$s/d = 0.3125$$

$V_{s,j2} = 589048.623$  is calculated for section flange jacket, with:

$$d = 600.00$$

$$A_v = 157079.633$$

$$f_y = 625.00$$

$$s = 100.00$$

$$V_{s,j2} \text{ is multiplied by } Col_{j2} = 1.00$$

$$s/d = 0.16666667$$

$$V_{s,core} = V_{s,c1} + V_{s,c2} = 110584.061$$

$V_{s,c1} = 0.00$  is calculated for section web core, with:

$$d = 160.00$$

$$A_v = 100530.965$$

$$f_y = 625.00$$

$$s = 250.00$$

$$V_{s,c1} \text{ is multiplied by } Col_{c1} = 0.00$$

$$s/d = 1.5625$$

$V_{s,c2} = 110584.061$  is calculated for section flange core, with:

$$d = 440.00$$

$$A_v = 100530.965$$

$$f_y = 625.00$$

$$s = 250.00$$

$$V_{s,c2} \text{ is multiplied by } Col_{c2} = 1.00$$

$$s/d = 0.56818182$$

$$V_f ((11-3)-(11.4), \text{ACI 440}) = 0.00$$

$$\text{From (11-11), ACI 440: } V_s + V_f \leq 873250.061$$

$$bw = 400.00$$

$$\text{Calculation of Shear Strength at edge 2, } V_{r2} = 1.0392\text{E}+006$$

Vr2 = VCol ((10.3), ASCE 41-17) = knl\*VCol0

VCol0 = 1.0392E+006

knl = 1 (zero step-static loading)

NOTE: In expression (10-3) ' $V_s = A_v \cdot f_y \cdot d / s$ ' is replaced by ' $V_s + f \cdot V_f$ '  
where  $V_f$  is the contribution of FRPs (11.3), ACI 440).

= 1 (normal-weight concrete)

Mean concrete strength:  $f'_c = (f'_{c,jacket} \cdot Area_{jacket} + f'_{c,core} \cdot Area_{core}) / Area_{section} = 30.00$ , but  $f'_c^{0.5} \leq 8.3$  MPa (22.5.3.1, ACI 318-14)

$M/Vd = 4.00$

$\mu_u = 1308.675$

$V_u = 0.0001715$

$d = 0.8 \cdot h = 600.00$

$N_u = 16273.608$

$A_g = 300000.00$

From (11.5.4.8), ACI 318-14:  $V_s = V_{s,jacket} + V_{s,core} = 1.0138E+006$

where:

$V_{s,jacket} = V_{s,j1} + V_{s,j2} = 903207.888$

$V_{s,j1} = 314159.265$  is calculated for section web jacket, with:

$d = 320.00$

$A_v = 157079.633$

$f_y = 625.00$

$s = 100.00$

$V_{s,j1}$  is multiplied by  $Col,j1 = 1.00$

$s/d = 0.3125$

$V_{s,j2} = 589048.623$  is calculated for section flange jacket, with:

$d = 600.00$

$A_v = 157079.633$

$f_y = 625.00$

$s = 100.00$

$V_{s,j2}$  is multiplied by  $Col,j2 = 1.00$

$s/d = 0.16666667$

$V_{s,core} = V_{s,c1} + V_{s,c2} = 110584.061$

$V_{s,c1} = 0.00$  is calculated for section web core, with:

$d = 160.00$

$A_v = 100530.965$

$f_y = 625.00$

$s = 250.00$

$V_{s,c1}$  is multiplied by  $Col,c1 = 0.00$

$s/d = 1.5625$

$V_{s,c2} = 110584.061$  is calculated for section flange core, with:

$d = 440.00$

$A_v = 100530.965$

$f_y = 625.00$

$s = 250.00$

$V_{s,c2}$  is multiplied by  $Col,c2 = 1.00$

$s/d = 0.56818182$

$V_f$  ((11-3)-(11.4), ACI 440) = 0.00

From (11-11), ACI 440:  $V_s + V_f \leq 873250.061$

$bw = 400.00$

End Of Calculation of Shear Capacity ratio for element: column JLC1 of floor 1  
At local axis: 2

Start Of Calculation of Chord Rotation Capacity for element: column JLC1 of floor 1  
At local axis: 2  
Integration Section: (b)  
Section Type: rcjlcs

Constant Properties

Knowledge Factor, = 1.00



Chord Rotation is generally considered as Deformation-Controlled Action according to Table C7-1, ASCE 41-17.  
Mean strengths are used for Deformation-Controlled Actions according to 7.5.1.3, ASCE 41-17  
Consequently:  
Jacket  
New material of Primary Member: Concrete Strength,  $f_c = f_{cm} = 30.00$   
New material of Primary Member: Steel Strength,  $f_s = f_{sm} = 625.00$   
Concrete Elasticity,  $E_c = 25742.96$   
Steel Elasticity,  $E_s = 200000.00$   
Existing Column  
New material of Primary Member: Concrete Strength,  $f_c = f_{cm} = 30.00$   
New material of Primary Member: Steel Strength,  $f_s = f_{sm} = 625.00$   
Concrete Elasticity,  $E_c = 25742.96$   
Steel Elasticity,  $E_s = 200000.00$   
Max Height,  $H_{max} = 750.00$   
Min Height,  $H_{min} = 400.00$   
Max Width,  $W_{max} = 750.00$   
Min Width,  $W_{min} = 400.00$   
Jacket Thickness,  $t_j = 100.00$   
Cover Thickness,  $c = 25.00$   
Element Length,  $L = 3000.00$   
Primary Member  
Smooth Bars  
Ductile Steel  
With Detailing for Earthquake Resistance (including stirrups closed at  $135^\circ$ )  
Longitudinal Bars With Ends Lapped Starting at the End Sections  
Lap Length  $l_b = 300.00$   
No FRP Wrapping

#### Stepwise Properties

Bending Moment,  $M = -112991.609$   
Shear Force,  $V_2 = 4846.489$   
Shear Force,  $V_3 = -135.9404$   
Axial Force,  $F = -17232.621$   
Longitudinal Reinforcement Area Distribution (in 2 divisions)  
-Tension:  $As_t = 0.00$   
-Compression:  $As_c = 5353.274$   
Longitudinal Reinforcement Area Distribution (in 3 divisions)  
-Tension:  $As_{t,ten} = 1137.257$   
-Compression:  $As_{l,com} = 2208.54$   
-Middle:  $As_{l,mid} = 2007.478$   
Longitudinal External Reinforcement Area Distribution (in 3 divisions)  
-Tension:  $As_{l,ten,jacket} = 829.3805$   
-Compression:  $As_{l,com,jacket} = 1746.726$   
-Middle:  $As_{l,mid,jacket} = 1545.664$   
Longitudinal Internal Reinforcement Area Distribution (in 3 divisions)  
-Tension:  $As_{l,ten,core} = 307.8761$   
-Compression:  $As_{l,com,core} = 461.8141$   
-Middle:  $As_{l,mid,core} = 461.8141$   
Mean Diameter of Tension Reinforcement,  $Db_L = 16.80$

New component: From table 7-7, ASCE 41\_17: Final chord rotation Capacity  $u_R = 1.0^*$   $u = 0.00054601$   
 $u = y + p = 0.00054601$

- Calculation of  $y$  -

$y = (M_y * L_s / 3) / E_{eff} = 0.00054601$  ((4.29), Biskinis Phd))  
 $M_y = 2.8693E+008$   
 $L_s = M/V$  (with  $L_s > 0.1 * L$  and  $L_s < 2 * L$ ) = 831.1851  
From table 10.5, ASCE 41\_17:  $E_{eff} = factor * E_c * I_g = 1.4560E+014$   
factor = 0.30  
 $A_g = 440000.00$

Mean concrete strength:  $fc' = (fc'_{jacket} \cdot Area_{jacket} + fc'_{core} \cdot Area_{core}) / Area_{section} = 30.00$

$N = 17232.621$

$Ec \cdot I_g = Ec_{jacket} \cdot I_{g,jacket} + Ec_{core} \cdot I_{g,core} = 4.8532E+014$

#### Calculation of Yielding Moment $M_y$

Calculation of  $y$  and  $M_y$  according to Annex 7 -

Assuming neutral axis within flange (  $y < t/d$ , compression zone rectangular) with:

flange width,  $b = 750.00$

web width,  $b_w = 400.00$

flange thickness,  $t = 400.00$

$y = \text{Min}(y_{ten}, y_{com})$

$y_{ten} = 2.1452649E-006$

with  $((10.1), \text{ASCE } 41-17)$   $f_y = \text{Min}(f_y, 1.25 \cdot f_y \cdot (I_b/I_d)^{2/3}) = 243.3535$

$d = 707.00$

$y = 0.1977546$

$A = 0.0102293$

$B = 0.00453971$

with  $pt = 0.00434791$

$pc = 0.00416509$

$pv = 0.00378591$

$N = 17232.621$

$b = 750.00$

$" = 0.06082037$

$y_{comp} = 1.5203329E-005$

with  $fc = 30.00$

$Ec = 25742.96$

$y = 0.19515388$

$A = 0.01001829$

$B = 0.00440616$

with  $Es = 200000.00$

CONFIRMATION:  $y = 0.19591085 < t/d$

#### Calculation of ratio $I_b/I_d$

Lap Length:  $I_d/I_{d,min} = 0.17384865$

$I_b = 300.00$

$I_d = 1725.639$

Calculation of  $I$  according to (25.4.3.2), ACI 318-14, using mean values for all the section re-bars.

$I_{d,min}$  from (25.4.3.2) is multiplied 2 times to account for smooth re-bars (10.3.5, ASCE 41-17)

$= 1$

$db = 16.66667$

Mean strength value of all re-bars:  $f_y = 625.00$

Mean concrete strength:  $fc' = (fc'_{jacket} \cdot Area_{jacket} + fc'_{core} \cdot Area_{core}) / Area_{section} = 30.00$ , but  $fc'^{0.5} \leq 8.3$  MPa (22.5.3.1, ACI 318-14)

$t = 1.00$

$s = 0.80$

$e = 1.00$

$cb = 25.00$

$K_{tr} = 1.7174$

$A_{tr} = \text{Min}(A_{tr_x}, A_{tr_y}) = 257.6106$

where  $A_{tr_x}$ ,  $A_{tr_y}$  are the sum of the area of all stirrup legs along X and Y loxal axis

$s = \text{Max}(s_{external}, s_{internal}) = 250.00$

$n = 24.00$

- Calculation of  $p$  -

From table 10-8:  $p = 0.00$

with:



- Columns controlled by inadequate development or splicing along the clear height because  $I_b/I_d < 1$

shear control ratio  $V_y E / V_{col} E = 0.32266369$   
 $d = d_{external} = 707.00$   
 $s = s_{external} = 0.00$   
 $t = s_1 + s_2 + 2 * t_f / b_w * (f_{fe} / f_s) = 0.00434791$   
 jacket:  $s_1 = A_{v1} * L_{stir1} / (s_1 * A_g) = 0.00367709$   
 $A_{v1} = 78.53982$ , is the area of every stirrup parallel to loading (shear) direction  
 $L_{stir1} = 2060.00$ , is the total Length of all stirrups parallel to loading (shear) direction  
 $s_1 = 100.00$   
 core:  $s_2 = A_{v2} * L_{stir2} / (s_2 * A_g) = 0.00067082$   
 $A_{v2} = 50.26548$ , is the area of every stirrup parallel to loading (shear) direction  
 $L_{stir2} = 1468.00$ , is the total Length of all stirrups parallel to loading (shear) direction  
 $s_2 = 250.00$   
 The term  $2 * t_f / b_w * (f_{fe} / f_s)$  is implemented to account for FRP contribution  
 where  $f = 2 * t_f / b_w$  is FRP ratio (EC8 - 3, A.4.4.3(6)) and  $f_{fe} / f_s$  normalises  $f$  to steel strength  
 All these variables have already been given in Shear control ratio calculation.  
 For the normalisation  $f_s$  of jacket is used.  
 $NUD = 17232.621$   
 $A_g = 440000.00$   
 $f_{cE} = (f_{c,jacket} * Area_{jacket} + f_{c,core} * Area_{core}) / section\_area = 30.00$   
 $f_{yE} = (f_{y,ext\_Long\_Reinf} * Area_{ext\_Long\_Reinf} + f_{y,int\_Long\_Reinf} * Area_{int\_Long\_Reinf}) / Area_{Tot\_Long\_Rein} = 625.00$   
 $f_{yE} = (f_{y,ext\_Trans\_Reinf} * s_1 + f_{y,int\_Trans\_Reinf} * s_2) / (s_1 + s_2) = 625.00$   
 $\rho_l = Area_{Tot\_Long\_Rein} / (b * d) = 0.01009575$   
 $b = 750.00$   
 $d = 707.00$   
 $f_{cE} = 30.00$

-----  
 End Of Calculation of Chord Rotation Capacity for element: column JLC1 of floor 1  
 At local axis: 2  
 Integration Section: (b)  
 -----

## Calculation No. 7

column C1, Floor 1  
 Limit State: Operational Level (data interpolation between analysis steps 1 and 2)  
 Analysis: Uniform +X  
 Check: Shear capacity  $V_{Rd}$   
 Edge: End  
 Local Axis: (3)



Start Of Calculation of Shear Capacity for element: column JLC1 of floor 1

At local axis: 3

Integration Section: (b)

Section Type: rcjlcs

Constant Properties

Knowledge Factor,  $\gamma = 1.00$

Member Shear Force is generally considered as Force-Controlled Action according to Table C7-1, ASCE 41-17.

Lower-bound strengths are used for Force-Controlled Actions according to 7.5.1.3, ASCE 41-17

Consequently:

Jacket

New material of Primary Member: Concrete Strength,  $f_c = f_{c\_lower\_bound} = 20.00$

New material of Primary Member: Steel Strength,  $f_s = f_{s\_lower\_bound} = 500.00$

Concrete Elasticity,  $E_c = 25742.96$

Steel Elasticity,  $E_s = 200000.00$

Existing Column

New material of Primary Member: Concrete Strength,  $f_c = f_{c\_lower\_bound} = 20.00$

New material of Primary Member: Steel Strength,  $f_s = f_{s\_lower\_bound} = 500.00$

Concrete Elasticity,  $E_c = 25742.96$

Steel Elasticity,  $E_s = 200000.00$

#####

Note: Especially for the calculation of  $\gamma$  for displacement ductility demand, the expected (mean value) strengths are used (7.5.1.3, ASCE 41-17) because bending is considered as Deformation-Controlled Action (Table C7-1, ASCE 41-17).

Jacket

New material: Concrete Strength,  $f_c = f_{cm} = 30.00$

New material: Steel Strength,  $f_s = f_{sm} = 625.00$

Existing Column

New material: Concrete Strength,  $f_c = f_{cm} = 30.00$

New material: Steel Strength,  $f_s = f_{sm} = 625.00$

#####

Max Height,  $H_{max} = 750.00$

Min Height,  $H_{min} = 400.00$

Max Width,  $W_{max} = 750.00$

Min Width,  $W_{min} = 400.00$

Jacket Thickness,  $t_j = 100.00$

Cover Thickness,  $c = 25.00$

Element Length,  $L = 3000.00$

Primary Member

Smooth Bars

Ductile Steel

With Detailing for Earthquake Resistance (including stirrups closed at 135°)

Longitudinal Bars With Ends Lapped Starting at the End Sections

Lap Length  $l_o = l_b = 300.00$

No FRP Wrapping

Stepwise Properties

EDGE -A-

Bending Moment,  $M_a = -293351.828$

Shear Force,  $V_a = 135.9404$   
 EDGE -B-  
 Bending Moment,  $M_b = -112991.609$   
 Shear Force,  $V_b = -135.9404$   
 BOTH EDGES  
 Axial Force,  $F = -17232.621$   
 Longitudinal Reinforcement Area Distribution (in 2 divisions)  
   -Tension:  $A_{st} = 0.00$   
   -Compression:  $A_{sc} = 5353.274$   
 Longitudinal Reinforcement Area Distribution (in 3 divisions)  
   -Tension:  $A_{st,ten} = 1137.257$   
   -Compression:  $A_{sc,com} = 2208.54$   
   -Middle:  $A_{sc,mid} = 2007.478$   
 Mean Diameter of Tension Reinforcement,  $Db_{L,ten} = 16.80$

New component: From table 7-7, ASCE 41\_17: Final Shear Capacity  $V_R = 1.0 \cdot V_n = 984758.516$   
 $V_n ((10.3), ASCE 41-17) = knl \cdot V_{ColO} = 984758.516$   
 $V_{Col} = 984758.516$   
 $knl = 1.00$   
 $displacement\_ductility\_demand = 1.5776519E-005$

NOTE: In expression (10-3) ' $V_s = A_v \cdot f_y \cdot d / s$ ' is replaced by ' $V_s + f \cdot V_f$ '  
 where  $V_f$  is the contribution of FRPs (11.3), ACI 440).

$= 1$  (normal-weight concrete)  
 Mean concrete strength:  $f'_c = (f'_{c,jacket} \cdot Area_{jacket} + f'_{c,core} \cdot Area_{core}) / Area_{section} = 20.00$ , but  $f_c^{0.5} \leq 8.3$   
 MPa (22.5.3.1, ACI 318-14)  
 $M/Vd = 2.00$   
 $M_u = 112991.609$   
 $V_u = 135.9404$   
 $d = 0.8 \cdot h = 600.00$   
 $N_u = 17232.621$   
 $A_g = 300000.00$   
 From (11.5.4.8), ACI 318-14:  $V_s = V_{s,jacket} + V_{s,core} = 811033.559$   
 where:  
 $V_{s,jacket} = V_{s,j1} + V_{s,j2} = 722566.31$   
 $V_{s,j1} = 471238.898$  is calculated for section web jacket, with:  
 $d = 600.00$   
 $A_v = 157079.633$   
 $f_y = 500.00$   
 $s = 100.00$   
 $V_{s,j1}$  is multiplied by  $Col,j1 = 1.00$   
 $s/d = 0.16666667$   
 $V_{s,j2} = 251327.412$  is calculated for section flange jacket, with:  
 $d = 320.00$   
 $A_v = 157079.633$   
 $f_y = 500.00$   
 $s = 100.00$   
 $V_{s,j2}$  is multiplied by  $Col,j2 = 1.00$   
 $s/d = 0.3125$   
 $V_{s,core} = V_{s,c1} + V_{s,c2} = 88467.249$   
 $V_{s,c1} = 88467.249$  is calculated for section web core, with:  
 $d = 440.00$   
 $A_v = 100530.965$   
 $f_y = 500.00$   
 $s = 250.00$   
 $V_{s,c1}$  is multiplied by  $Col,c1 = 1.00$   
 $s/d = 0.56818182$   
 $V_{s,c2} = 0.00$  is calculated for section flange core, with:  
 $d = 160.00$   
 $A_v = 100530.965$   
 $f_y = 500.00$   
 $s = 250.00$   
 $V_{s,c2}$  is multiplied by  $Col,c2 = 0.00$

$s/d = 1.5625$   
 $V_f((11-3)-(11.4), ACI 440) = 0.00$   
 From (11-11), ACI 440:  $V_s + V_f \leq 713005.69$   
 $bw = 400.00$

displacement ductility demand is calculated as  $\phi / \phi_y$

- Calculation of  $\phi / \phi_y$  for END B -  
 for rotation axis 2 and integ. section (b)

From analysis, chord rotation  $\theta = 8.6141257E-009$   
 $y = (M_y * L_s / 3) / E_{eff} = 0.00054601 ((4.29), Biskinis Phd)$   
 $M_y = 2.8693E+008$   
 $L_s = M/V$  (with  $L_s > 0.1 * L$  and  $L_s < 2 * L$ ) = 831.1851  
 From table 10.5, ASCE 41-17:  $E_{eff} = factor * E_c * I_g = 1.4560E+014$   
 $factor = 0.30$   
 $A_g = 440000.00$   
 Mean concrete strength:  $f'_c = (f'_{c\_jacket} * Area_{jacket} + f'_{c\_core} * Area_{core}) / Area_{section} = 30.00$   
 $N = 17232.621$   
 $E_c * I_g = E_{c\_jacket} * I_{g\_jacket} + E_{c\_core} * I_{g\_core} = 4.8532E+014$

Calculation of Yielding Moment  $M_y$

Calculation of  $\phi_y$  and  $M_y$  according to Annex 7 -

Assuming neutral axis within flange ( $y < t/d$ , compression zone rectangular) with:  
 flange width,  $b = 750.00$   
 web width,  $bw = 400.00$   
 flange thickness,  $t = 400.00$

$y = \text{Min}(y_{ten}, y_{com})$   
 $y_{ten} = 2.1452649E-006$   
 with ((10.1), ASCE 41-17)  $f_y = \text{Min}(f_y, 1.25 * f_y * (I_b / I_d)^{2/3}) = 243.3535$   
 $d = 707.00$   
 $y = 0.1977546$   
 $A = 0.0102293$   
 $B = 0.00453971$   
 with  $pt = 0.00214476$   
 $pc = 0.00416509$   
 $pv = 0.00378591$   
 $N = 17232.621$   
 $b = 750.00$   
 $" = 0.06082037$   
 $y_{comp} = 1.5203329E-005$   
 with  $f_c = 30.00$   
 $E_c = 25742.96$   
 $y = 0.19515388$   
 $A = 0.01001829$   
 $B = 0.00440616$   
 with  $E_s = 200000.00$   
 CONFIRMATION:  $y = 0.19591085 < t/d$

Calculation of ratio  $I_b / I_d$


Lap Length:  $I_d / I_{d,min} = 0.17384865$   
 $I_b = 300.00$   
 $I_d = 1725.639$   
 Calculation of  $I$  according to (25.4.3.2), ACI 318-14, using mean values for all the section re-bars.  
 $I_{d,min}$  from (25.4.3.2) is multiplied 2 times to account for smooth re-bars (10.3.5, ASCE 41-17)  
 $= 1$   
 $db = 16.66667$

Mean strength value of all re-bars:  $f_y = 625.00$   
Mean concrete strength:  $f_c' = (f_c'_{\text{jacket}} \cdot \text{Area}_{\text{jacket}} + f_c'_{\text{core}} \cdot \text{Area}_{\text{core}}) / \text{Area}_{\text{section}} = 30.00$ , but  $f_c'^{0.5} \leq 8.3$  MPa (22.5.3.1, ACI 318-14)  
 $t = 1.00$   
 $s = 0.80$   
 $e = 1.00$   
 $cb = 25.00$   
 $K_{tr} = 1.7174$   
 $A_{tr} = \text{Min}(A_{tr_x}, A_{tr_y}) = 257.6106$   
where  $A_{tr_x}$ ,  $A_{tr_y}$  are the sum of the area of all stirrup legs along X and Y local axis  
 $s = \text{Max}(s_{\text{external}}, s_{\text{internal}}) = 250.00$   
 $n = 24.00$

End Of Calculation of Shear Capacity for element: column JLC1 of floor 1  
At local axis: 3  
Integration Section: (b)

## Calculation No. 8

column C1, Floor 1  
Limit State: Operational Level (data interpolation between analysis steps 1 and 2)  
Analysis: Uniform +X  
Check: Chord rotation capacity (  $\phi$  )  
Edge: End  
Local Axis: (3)



Start Of Calculation of Shear Capacity ratio for element: column JLC1 of floor 1  
At Shear local axis: 3  
(Bending local axis: 2)  
Section Type: rcjlc

Constant Properties

Knowledge Factor,  $\phi = 1.00$   
Mean strength values are used for both shear and moment calculations.  
Consequently:  
Jacket

New material of Primary Member: Concrete Strength,  $f_c = f_{cm} = 30.00$   
 New material of Primary Member: Steel Strength,  $f_s = f_{sm} = 625.00$   
 Concrete Elasticity,  $E_c = 25742.96$   
 Steel Elasticity,  $E_s = 200000.00$   
 Existing Column  
 New material of Primary Member: Concrete Strength,  $f_c = f_{cm} = 30.00$   
 New material of Primary Member: Steel Strength,  $f_s = f_{sm} = 625.00$   
 Concrete Elasticity,  $E_c = 25742.96$   
 Steel Elasticity,  $E_s = 200000.00$   
 #####  
 Note: Especially for the calculation of moment strengths,  
 the above steel re-bar strengths are multiplied by 1.25 according to R18.6.5, ACI 318-14  
 Jacket  
 New material: Steel Strength,  $f_s = 1.25 \cdot f_{sm} = 781.25$   
 Existing Column  
 New material: Steel Strength,  $f_s = 1.25 \cdot f_{sm} = 781.25$   
 #####  
 Max Height,  $H_{max} = 750.00$   
 Min Height,  $H_{min} = 400.00$   
 Max Width,  $W_{max} = 750.00$   
 Min Width,  $W_{min} = 400.00$   
 Jacket Thickness,  $t_j = 100.00$   
 Cover Thickness,  $c = 25.00$   
 Mean Confinement Factor overall section = 1.27105  
 Element Length,  $L = 3000.00$   
 Primary Member  
 Smooth Bars  
 Ductile Steel  
 With Detailing for Earthquake Resistance (including stirrups closed at 135°)  
 Longitudinal Bars With Ends Lapped Starting at the End Sections  
 Lap Length  $l_o = 300.00$   
 No FRP Wrapping

#### Stepwise Properties

At local axis: 3  
 EDGE -A-  
 Shear Force,  $V_a = -0.00017144$   
 EDGE -B-  
 Shear Force,  $V_b = 0.00017144$   
 BOTH EDGES  
 Axial Force,  $F = -16273.608$   
 Longitudinal Reinforcement Area Distribution (in 2 divisions)  
 -Tension:  $A_{sl,t} = 0.00$   
 -Compression:  $A_{sl,c} = 5353.274$   
 Longitudinal Reinforcement Area Distribution (in 3 divisions)  
 -Tension:  $A_{sl,ten} = 1137.257$   
 -Compression:  $A_{sl,com} = 2208.54$   
 -Middle:  $A_{sl,mid} = 2007.478$

Calculation of Shear Capacity ratio,  $V_e/V_r = 0.32266369$   
 Member Controlled by Flexure ( $V_e/V_r < 1$ )  
 Calculation of Shear Demand from fig. R18.6.5, ACI 318-14  $V_e = (M_{pr1} + M_{pr2})/l_n = 335307.657$   
 with  
 $M_{pr1} = \max(\mu_{u1+}, \mu_{u1-}) = 5.0296E+008$   
 $\mu_{u1+} = 2.3387E+008$ , is the ultimate moment strength at the edge 1 of the member in the actual moment direction  
 which is defined for the static loading combination  
 $\mu_{u1-} = 5.0296E+008$ , is the ultimate moment strength at the edge 1 of the member in the opposite moment  
 direction which is defined for the static loading combination  
 $M_{pr2} = \max(\mu_{u2+}, \mu_{u2-}) = 5.0296E+008$   
 $\mu_{u2+} = 2.3387E+008$ , is the ultimate moment strength at the edge 2 of the member in the actual moment direction  
 which is defined for the static loading combination  
 $\mu_{u2-} = 5.0296E+008$ , is the ultimate moment strength at the edge 2 of the member in the opposite moment



direction which is defined for the the static loading combination

Calculation of  $\mu_{1+}$

Calculation of ultimate curvature  $\mu$  according to 4.1, Biskinis/Fardis 2013:

$$\mu = 4.8099118E-006$$

$$\mu_{1+} = 2.3387E+008$$

with full section properties:

$$b = 750.00$$

$$d = 707.00$$

$$d' = 43.00$$

$$\nu = 0.00102301$$

$$N = 16273.608$$

$$f_c = 30.00$$

$$\alpha (5A.5, \text{TB DY}) = 0.002$$

$$\text{Final value of } \mu_{1+}: \mu_{1+} = \text{shear\_factor} * \text{Max}(\mu_{1+}, \alpha) = 0.01260361$$

The Shear\_factor is considered equal to 1 (pure moment strength)

$$\text{From (5.4b), TB DY: } \mu_{1+} = 0.01260361$$

$$\mu_{1+} (5.4c) = 0.05179731$$

$$\alpha_{se} ((5.4d), \text{TB DY}) = (\alpha_{se1} * A_{ext} + \alpha_{se2} * A_{int}) / A_{sec} = 0.45746528$$

$$\alpha_{se1} = \text{Max}(((A_{conf,max1} - A_{noConf1}) / A_{conf,max1}) * (A_{conf,min1} / A_{conf,max1}), 0) = 0.45746528$$

The definitions of  $A_{noConf}$ ,  $A_{conf,min}$  and  $A_{conf,max}$  are derived from generalization of the rectangular sections confinement, which is expressed by (5.4d).

The generalization is done according to Mander, J., Priestley, M., and Park, R. (1988)

"Theoretical Stress-Strain Model for Confined Concrete."

J. Struct. Eng., 10.1061/(ASCE)0733-9445(1988)114:8(1804), 1804-1826.

$A_{conf,max1} = 353600.00$  is the confined core area at levels of member with hoops and

is calculated as the area of core enclosed by the center lines of the external perimeter hoops.

$A_{conf,min1} = 293525.00$  is the confined core area at midway between the levels of hoops and

is calculated by reducing all the dimensions of the area  $A_{conf,max1}$  by a length equal to half the clear spacing between external hoops.

$A_{noConf1} = 158733.333$  is the unconfined external core area which is equal to  $b_i^2/6$  as defined at (A.2).

$$\alpha_{se2} (> \alpha_{se1}) = \text{Max}(((A_{conf,max2} - A_{noConf2}) / A_{conf,max2}) * (A_{conf,min2} / A_{conf,max2}), 0) = 0.45746528$$

The definitions of  $A_{noConf}$ ,  $A_{conf,min}$  and  $A_{conf,max}$  are derived from generalization of the rectangular sections confinement, which is expressed by (5.4d).

The generalization is done according to Mander, J., Priestley, M., and Park, R. (1988)

"Theoretical Stress-Strain Model for Confined Concrete."

J. Struct. Eng., 10.1061/(ASCE)0733-9445(1988)114:8(1804), 1804-1826.

$A_{conf,max2} = 171264.00$  is the confined core area at levels of member with hoops and

is calculated as the area of core enclosed by the center lines of the internal perimeter hoops.

$A_{conf,min2} = 54741.00$  is the confined core area at midway between the levels of hoops and

is calculated by reducing all the dimensions of the area  $A_{conf,max2}$  by a length equal to half the clear spacing between internal hoops.

$A_{noConf2} = 106242.667$  is the unconfined internal core area which is equal to  $b_i^2/6$  as defined at (A.2).

$$p_{sh,min} * F_{ywe} = \text{Min}(p_{sh,x} * F_{ywe}, p_{sh,y} * F_{ywe}) = 3.3968$$

$$p_{sh,x} * F_{ywe} = p_{sh1} * F_{ywe1} + p_{sh2} * F_{ywe2} = 3.3968$$

$$p_{sh1} ((5.4d), \text{TB DY}) = L_{stir1} * A_{stir1} / (A_{sec} * s_1) = 0.00367709$$

$$L_{stir1} (\text{Length of stirrups along Y}) = 2060.00$$

$$A_{stir1} (\text{stirrups area}) = 78.53982$$

$$p_{sh2} (5.4d) = L_{stir2} * A_{stir2} / (A_{sec} * s_2) = 0.00067082$$

$$L_{stir2} (\text{Length of stirrups along Y}) = 1468.00$$

$$A_{stir2} (\text{stirrups area}) = 50.26548$$

$$p_{sh,y} * F_{ywe} = p_{sh1} * F_{ywe1} + p_{sh2} * F_{ywe2} = 3.3968$$

$$p_{sh1} ((5.4d), \text{TB DY}) = L_{stir1} * A_{stir1} / (A_{sec} * s_1) = 0.00367709$$

$$L_{stir1} (\text{Length of stirrups along X}) = 2060.00$$

$$A_{stir1} (\text{stirrups area}) = 78.53982$$

$$p_{sh2} ((5.4d), \text{TB DY}) = L_{stir2} * A_{stir2} / (A_{sec} * s_2) = 0.00067082$$

$$L_{stir2} (\text{Length of stirrups along X}) = 1468.00$$

$$A_{stir2} (\text{stirrups area}) = 50.26548$$

$$A_{sec} = 440000.00$$

```

s1 = 100.00
s2 = 250.00
fywe1 = 781.25
fywe2 = 781.25
fce = 30.00
From ((5A.5), TBDY), TBDY: cc = 0.00471045
c = confinement factor = 1.27105
y1 = 0.00083886
sh1 = 0.00268436
ft1 = 314.5735
fy1 = 262.1446
su1 = 0.00268436
using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00
lo/lou,min = lb/lb = 0.13907892
su1 = 0.4*esu1_nominal ((5.5), TBDY) = 0.032
From table 5A.1, TBDY: esu1_nominal = 0.08,
For calculation of esu1_nominal and y1, sh1,ft1,fy1, it is considered
characteristic value fsy1 = fs1/1.2, from table 5.1, TBDY.
y1, sh1,ft1,fy1, are also multiplied by Min(1,1.25*(lb/lb)^2/3), from 10.3.5, ASCE 41-17.
with fs1 = (fs,jacket*Asl,ten,jacket + fs,core*Asl,ten,core)/Asl,ten = 262.1446
with Es1 = (Es,jacket*Asl,ten,jacket + Es,core*Asl,ten,core)/Asl,ten = 200000.00
y2 = 0.00083886
sh2 = 0.00268436
ft2 = 314.5735
fy2 = 262.1446
su2 = 0.00268436
using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00
lo/lou,min = lb/lb,min = 0.13907892
su2 = 0.4*esu2_nominal ((5.5), TBDY) = 0.032
From table 5A.1, TBDY: esu2_nominal = 0.08,
For calculation of esu2_nominal and y2, sh2,ft2,fy2, it is considered
characteristic value fsy2 = fs2/1.2, from table 5.1, TBDY.
y1, sh1,ft1,fy1, are also multiplied by Min(1,1.25*(lb/lb)^2/3), from 10.3.5, ASCE 41-17.
with fs2 = (fs,jacket*Asl,com,jacket + fs,core*Asl,com,core)/Asl,com = 262.1446
with Es2 = (Es,jacket*Asl,com,jacket + Es,core*Asl,com,core)/Asl,com = 200000.00
yv = 0.00083886
shv = 0.00268436
ftv = 314.5735
fyv = 262.1446
suv = 0.00268436
using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00
lo/lou,min = lb/lb = 0.13907892
suv = 0.4*esuv_nominal ((5.5), TBDY) = 0.032
From table 5A.1, TBDY: esuv_nominal = 0.08,
considering characteristic value fsyv = fsv/1.2, from table 5.1, TBDY
For calculation of esuv_nominal and yv, shv,ftv,fyv, it is considered
characteristic value fsyv = fsv/1.2, from table 5.1, TBDY.
y1, sh1,ft1,fy1, are also multiplied by Min(1,1.25*(lb/lb)^2/3), from 10.3.5, ASCE 41-17.
with fsv = (fs,jacket*Asl,mid,jacket + fs,mid*Asl,mid,core)/Asl,mid = 262.1446
with Esv = (Es,jacket*Asl,mid,jacket + Es,mid*Asl,mid,core)/Asl,mid = 200000.00
1 = Asl,ten/(b*d)*(fs1/fc) = 0.0187412
2 = Asl,com/(b*d)*(fs2/fc) = 0.03639521
v = Asl,mid/(b*d)*(fsv/fc) = 0.03308184
and confined core properties:
b = 690.00
d = 677.00
d' = 13.00
fcc (5A.2, TBDY) = 38.13135
cc (5A.5, TBDY) = 0.00471045
c = confinement factor = 1.27105
1 = Asl,ten/(b*d)*(fs1/fc) = 0.02127357

```

$$2 = A_{sl,com}/(b*d)*(f_s2/f_c) = 0.04131304$$

$$v = A_{sl,mid}/(b*d)*(f_{sv}/f_c) = 0.03755196$$

Case/Assumption: Unconfined full section - Steel rupture

' satisfies Eq. (4.3)

---->

$v < v_{s,y2}$  - LHS eq.(4.5) is satisfied

---->

$$s_u(4.9) = 0.21062322$$

$$M_u = M_{Rc}(4.14) = 2.3387E+008$$

$$u = s_u(4.1) = 4.8099118E-006$$

Calculation of ratio  $l_b/l_d$

Lap Length:  $l_b/l_d = 0.13907892$

$$l_b = 300.00$$

$$l_d = 2157.049$$

Calculation of  $l_b, \min$  according to (25.4.3.2), ACI 318-14, using mean values for all the section re-bars.

$l_d, \min$  from (25.4.3.2) is multiplied 2 times to account for smooth re-bars (9.1.2, TS500 - No provision in ACI 318)

$$= 1$$

$$d_b = 16.66667$$

Mean strength value of all re-bars:  $f_y = 781.25$

Mean concrete strength:  $f'_c = (f'_{c,jacket} \cdot Area_{jacket} + f'_{c,core} \cdot Area_{core}) / Area_{section} = 30.00$ , but  $f_c^{0.5} \leq 8.3$  MPa (22.5.3.1, ACI 318-14)

$$t = 1.00$$

$$s = 0.80$$

$$e = 1.00$$

$$c_b = 25.00$$

$$K_{tr} = 1.7174$$

$$A_{tr} = \min(A_{tr,x}, A_{tr,y}) = 257.6106$$

where  $A_{tr,x}$ ,  $A_{tr,y}$  are the sum of the area of all stirrup legs along X and Y loxal axis

$$s = \max(s_{external}, s_{internal}) = 250.00$$

$$n = 24.00$$

Calculation of  $\mu_1$ -

Calculation of ultimate curvature  $u$  according to 4.1, Biskinis/Fardis 2013:

$$u = 5.1201636E-006$$

$$M_u = 5.0296E+008$$

with full section properties:

$$b = 400.00$$

$$d = 707.00$$

$$d' = 43.00$$

$$v = 0.00191815$$

$$N = 16273.608$$

$$f_c = 30.00$$

$$c_o(5A.5, TBDY) = 0.002$$

$$\text{Final value of } c_u: c_u^* = \text{shear\_factor} * \max(c_u, c_c) = 0.01260361$$

The Shear\_factor is considered equal to 1 (pure moment strength)

$$\text{From (5.4b), TBDY: } c_u = 0.01260361$$

$$w_e(5.4c) = 0.05179731$$

$$a_{se}((5.4d), TBDY) = (a_{se1} \cdot A_{ext} + a_{se2} \cdot A_{int}) / A_{sec} = 0.45746528$$

$$a_{se1} = \max(((A_{conf,max1} - A_{noConf1}) / A_{conf,max1}) * (A_{conf,min1} / A_{conf,max1}), 0) = 0.45746528$$

The definitions of  $A_{noConf}$ ,  $A_{conf,min}$  and  $A_{conf,max}$  are derived from generalization of the rectangular sections confinement, which is expressed by (5.4d).

The generalization is done according to Mander, J., Priestley, M., and Park, R. (1988)

"Theoretical Stress-Strain Model for Confined Concrete."

J. Struct. Eng., 10.1061/(ASCE)0733-9445(1988)114:8(1804), 1804-1826.

$A_{conf,max1} = 353600.00$  is the confined core area at levels of member with hoops and

is calculated as the area of core enclosed by the center lines of the external perimeter hoops.

$A_{conf,min1} = 293525.00$  is the confined core area at midway between the levels of hoops and

is calculated by reducing all the dimensions of the area  $A_{conf,max1}$  by a length

equal to half the clear spacing between external hoops.

AnoConf1 = 158733.333 is the unconfined external core area which is equal to  $b_i^2/6$  as defined at (A.2).  
 $ase2 (>= ase1) = \text{Max}(((A_{conf,max2} - \text{AnoConf2})/A_{conf,max2}) * (A_{conf,min2}/A_{conf,max2}), 0) = 0.45746528$

The definitions of AnoConf, Aconf,min and Aconf,max are derived from generalization of the rectangular sections confinement, which is expressed by (5.4d).

The generalization is done according to Mander, J., Priestley, M., and Park, R. (1988)

"Theoretical Stress-Strain Model for Confined Concrete."

J. Struct. Eng., 10.1061/(ASCE)0733-9445(1988)114:8(1804), 1804-1826.

Aconf,max2 = 171264.00 is the confined core area at levels of member with hoops and

is calculated as the area of core enclosed by the center lines of the internal perimeter hoops.

Aconf,min2 = 54741.00 is the confined core area at midway between the levels of hoops and

is calculated by reducing all the dimensions of the area Aconf,max2 by a length

equal to half the clear spacing between internal hoops.

AnoConf2 = 106242.667 is the unconfined internal core area which is equal to  $b_i^2/6$  as defined at (A.2).

$psh,min * Fywe = \text{Min}(psh,x * Fywe, psh,y * Fywe) = 3.3968$

-----  
 $psh,x * Fywe = psh1 * Fywe1 + ps2 * Fywe2 = 3.3968$

$psh1 ((5.4d), TBDY) = Lstir1 * Astir1 / (Asec * s1) = 0.00367709$

Lstir1 (Length of stirrups along Y) = 2060.00

Astir1 (stirrups area) = 78.53982

$psh2 ((5.4d)) = Lstir2 * Astir2 / (Asec * s2) = 0.00067082$

Lstir2 (Length of stirrups along Y) = 1468.00

Astir2 (stirrups area) = 50.26548

-----  
 $psh,y * Fywe = psh1 * Fywe1 + ps2 * Fywe2 = 3.3968$

$psh1 ((5.4d), TBDY) = Lstir1 * Astir1 / (Asec * s1) = 0.00367709$

Lstir1 (Length of stirrups along X) = 2060.00

Astir1 (stirrups area) = 78.53982

$psh2 ((5.4d), TBDY) = Lstir2 * Astir2 / (Asec * s2) = 0.00067082$

Lstir2 (Length of stirrups along X) = 1468.00

Astir2 (stirrups area) = 50.26548

-----  
Asec = 440000.00

s1 = 100.00

s2 = 250.00

fywe1 = 781.25

fywe2 = 781.25

fce = 30.00

From ((5.A5), TBDY), TBDY: cc = 0.00471045

c = confinement factor = 1.27105

y1 = 0.00083886

sh1 = 0.00268436

ft1 = 314.5735

fy1 = 262.1446

su1 = 0.00268436

using (30) in Biskinis/Fardis (2013) multiplied with shear\_factor

and also multiplied by the shear\_factor according to 15.7.1.4, with

Shear\_factor = 1.00

lo/lou,min = lb/ld = 0.13907892

su1 = 0.4 \* esu1\_nominal ((5.5), TBDY) = 0.032

From table 5A.1, TBDY: esu1\_nominal = 0.08,

For calculation of esu1\_nominal and y1, sh1, ft1, fy1, it is considered characteristic value fsy1 = fs1/1.2, from table 5.1, TBDY.

y1, sh1, ft1, fy1, are also multiplied by  $\text{Min}(1, 1.25 * (lb/ld)^{2/3})$ , from 10.3.5, ASCE 41-17.

with fs1 = (fs,jacket \* Asl,ten,jacket + fs,core \* Asl,ten,core) / Asl,ten = 262.1446

with Es1 = (Es,jacket \* Asl,ten,jacket + Es,core \* Asl,ten,core) / Asl,ten = 200000.00

y2 = 0.00083886

sh2 = 0.00268436

ft2 = 314.5735

fy2 = 262.1446

su2 = 0.00268436

using (30) in Biskinis/Fardis (2013) multiplied with shear\_factor

and also multiplied by the shear\_factor according to 15.7.1.4, with

Shear\_factor = 1.00

lo/lou,min = lb/lb,min = 0.13907892

su2 = 0.4 \* esu2\_nominal ((5.5), TBDY) = 0.032

From table 5A.1, TBDY: esu2\_nominal = 0.08,

For calculation of  $es_{u2\_nominal}$  and  $y_2$ ,  $sh_{2,ft2,fy2}$ , it is considered characteristic value  $fs_{y2} = fs_2/1.2$ , from table 5.1, TBDY.

$y_1$ ,  $sh_{1,ft1,fy1}$ , are also multiplied by  $\text{Min}(1, 1.25 \cdot (l_b/l_d)^{2/3})$ , from 10.3.5, ASCE 41-17.

with  $fs_2 = (fs_{jacket} \cdot A_{sl,com,jacket} + fs_{core} \cdot A_{sl,com,core}) / A_{sl,com} = 262.1446$

with  $Es_2 = (Es_{jacket} \cdot A_{sl,com,jacket} + Es_{core} \cdot A_{sl,com,core}) / A_{sl,com} = 200000.00$

$y_v = 0.00083886$

$sh_v = 0.00268436$

$ft_v = 314.5735$

$fy_v = 262.1446$

$suv = 0.00268436$

using (30) in Biskinis/Fardis (2013) multiplied with shear\_factor and also multiplied by the shear\_factor according to 15.7.1.4, with Shear\_factor = 1.00

$l_o/l_{ou,min} = l_b/l_d = 0.13907892$

$suv = 0.4 \cdot es_{u\_nominal} ((5.5), TBDY) = 0.032$

From table 5A.1, TBDY:  $es_{u\_nominal} = 0.08$ , considering characteristic value  $fs_{yv} = fs_v/1.2$ , from table 5.1, TBDY

For calculation of  $es_{u\_nominal}$  and  $y_v$ ,  $sh_v$ ,  $ft_v$ ,  $fy_v$ , it is considered characteristic value  $fs_{yv} = fs_v/1.2$ , from table 5.1, TBDY.

$y_1$ ,  $sh_{1,ft1,fy1}$ , are also multiplied by  $\text{Min}(1, 1.25 \cdot (l_b/l_d)^{2/3})$ , from 10.3.5, ASCE 41-17.

with  $fs_v = (fs_{jacket} \cdot A_{sl,mid,jacket} + fs_{mid} \cdot A_{sl,mid,core}) / A_{sl,mid} = 262.1446$

with  $Es_v = (Es_{jacket} \cdot A_{sl,mid,jacket} + Es_{mid} \cdot A_{sl,mid,core}) / A_{sl,mid} = 200000.00$

$1 = A_{sl,ten}/(b \cdot d) \cdot (fs_1/f_c) = 0.06824101$

$2 = A_{sl,com}/(b \cdot d) \cdot (fs_2/f_c) = 0.03513975$

$v = A_{sl,mid}/(b \cdot d) \cdot (fs_v/f_c) = 0.06202846$

and confined core properties:

$b = 340.00$

$d = 677.00$

$d' = 13.00$

$f_{cc} (5A.2, TBDY) = 38.13135$

$cc (5A.5, TBDY) = 0.00471045$

$c = \text{confinement factor} = 1.27105$

$1 = A_{sl,ten}/(b \cdot d) \cdot (fs_1/f_c) = 0.08384116$

$2 = A_{sl,com}/(b \cdot d) \cdot (fs_2/f_c) = 0.04317283$

$v = A_{sl,mid}/(b \cdot d) \cdot (fs_v/f_c) = 0.07620839$

Case/Assumption: Unconfined full section - Steel rupture

' satisfies Eq. (4.3)

--->

$v < v_{s,y2}$  - LHS eq.(4.5) is satisfied

--->

$su (4.9) = 0.2584548$

$Mu = MR_c (4.14) = 5.0296E+008$

$u = su (4.1) = 5.1201636E-006$

-----

Calculation of ratio  $l_b/l_d$

-----

Lap Length:  $l_b/l_d = 0.13907892$

$l_b = 300.00$

$l_d = 2157.049$

Calculation of  $l_{b,min}$  according to (25.4.3.2), ACI 318-14, using mean values for all the section re-bars.

$l_{d,min}$  from (25.4.3.2) is multiplied 2 times to account for smooth re-bars (9.1.2, TS500 - No provision in ACI 318)

= 1

$db = 16.66667$

Mean strength value of all re-bars:  $fy = 781.25$

Mean concrete strength:  $fc' = (fc'_{jacket} \cdot Area_{jacket} + fc'_{core} \cdot Area_{core}) / Area_{section} = 30.00$ , but  $fc'^{0.5} \leq 8.3$  MPa (22.5.3.1, ACI 318-14)

$t = 1.00$

$s = 0.80$

$e = 1.00$

$cb = 25.00$

$K_{tr} = 1.7174$

$A_{tr} = \text{Min}(A_{tr\_x}, A_{tr\_y}) = 257.6106$

where  $A_{tr\_x}$ ,  $A_{tr\_y}$  are the sum of the area of all stirrup legs along X and Y loxal axis

$s = \text{Max}(s_{external}, s_{internal}) = 250.00$

$n = 24.00$

-----

## Calculation of Mu2+

Calculation of ultimate curvature  $\mu$  according to 4.1, Biskinis/Fardis 2013:

$$\mu = 4.8099118E-006$$

$$Mu = 2.3387E+008$$

with full section properties:

$$b = 750.00$$

$$d = 707.00$$

$$d' = 43.00$$

$$v = 0.00102301$$

$$N = 16273.608$$

$$f_c = 30.00$$

$$c_o \text{ (5A.5, TBDY)} = 0.002$$

$$\text{Final value of } \mu: \mu = \text{shear\_factor} * \text{Max}(\mu_c, \mu_o) = 0.01260361$$

The Shear\_factor is considered equal to 1 (pure moment strength)

$$\text{From (5.4b), TBDY: } \mu_c = 0.01260361$$

$$\mu_o \text{ (5.4c)} = 0.05179731$$

$$a_{se} \text{ ((5.4d), TBDY)} = (a_{se1} * A_{ext} + a_{se2} * A_{int}) / A_{sec} = 0.45746528$$

$$a_{se1} = \text{Max}(((A_{conf,max1} - A_{noConf1}) / A_{conf,max1}) * (A_{conf,min1} / A_{conf,max1}), 0) = 0.45746528$$

The definitions of  $A_{noConf}$ ,  $A_{conf,min}$  and  $A_{conf,max}$  are derived from generalization

of the rectangular sections confinement, which is expressed by (5.4d).

The generalization is done according to Mander, J., Priestley, M., and Park, R. (1988)

"Theoretical Stress-Strain Model for Confined Concrete."

J. Struct. Eng., 10.1061/(ASCE)0733-9445(1988)114:8(1804), 1804-1826.

$A_{conf,max1} = 353600.00$  is the confined core area at levels of member with hoops and

is calculated as the area of core enclosed by the center lines of the external perimeter hoops.

$A_{conf,min1} = 293525.00$  is the confined core area at midway between the levels of hoops and

is calculated by reducing all the dimensions of the area  $A_{conf,max1}$  by a length

equal to half the clear spacing between external hoops.

$A_{noConf1} = 158733.333$  is the unconfined external core area which is equal to  $b_i^2/6$  as defined at (A.2).

$$a_{se2} (>= a_{se1}) = \text{Max}(((A_{conf,max2} - A_{noConf2}) / A_{conf,max2}) * (A_{conf,min2} / A_{conf,max2}), 0) = 0.45746528$$

The definitions of  $A_{noConf}$ ,  $A_{conf,min}$  and  $A_{conf,max}$  are derived from generalization

of the rectangular sections confinement, which is expressed by (5.4d).

The generalization is done according to Mander, J., Priestley, M., and Park, R. (1988)

"Theoretical Stress-Strain Model for Confined Concrete."

J. Struct. Eng., 10.1061/(ASCE)0733-9445(1988)114:8(1804), 1804-1826.

$A_{conf,max2} = 171264.00$  is the confined core area at levels of member with hoops and

is calculated as the area of core enclosed by the center lines of the internal perimeter hoops.

$A_{conf,min2} = 54741.00$  is the confined core area at midway between the levels of hoops and

is calculated by reducing all the dimensions of the area  $A_{conf,max2}$  by a length

equal to half the clear spacing between internal hoops.

$A_{noConf2} = 106242.667$  is the unconfined internal core area which is equal to  $b_i^2/6$  as defined at (A.2).

$$p_{sh,min} * F_{ywe} = \text{Min}(p_{sh,x} * F_{ywe}, p_{sh,y} * F_{ywe}) = 3.3968$$

$$p_{sh,x} * F_{ywe} = p_{sh1} * F_{ywe1} + p_{sh2} * F_{ywe2} = 3.3968$$

$$p_{sh1} \text{ ((5.4d), TBDY)} = L_{stir1} * A_{stir1} / (A_{sec} * s_1) = 0.00367709$$

$$L_{stir1} \text{ (Length of stirrups along Y)} = 2060.00$$

$$A_{stir1} \text{ (stirrups area)} = 78.53982$$

$$p_{sh2} \text{ (5.4d)} = L_{stir2} * A_{stir2} / (A_{sec} * s_2) = 0.00067082$$

$$L_{stir2} \text{ (Length of stirrups along Y)} = 1468.00$$

$$A_{stir2} \text{ (stirrups area)} = 50.26548$$

$$p_{sh,y} * F_{ywe} = p_{sh1} * F_{ywe1} + p_{sh2} * F_{ywe2} = 3.3968$$

$$p_{sh1} \text{ ((5.4d), TBDY)} = L_{stir1} * A_{stir1} / (A_{sec} * s_1) = 0.00367709$$

$$L_{stir1} \text{ (Length of stirrups along X)} = 2060.00$$

$$A_{stir1} \text{ (stirrups area)} = 78.53982$$

$$p_{sh2} \text{ ((5.4d), TBDY)} = L_{stir2} * A_{stir2} / (A_{sec} * s_2) = 0.00067082$$

$$L_{stir2} \text{ (Length of stirrups along X)} = 1468.00$$

$$A_{stir2} \text{ (stirrups area)} = 50.26548$$

$$A_{sec} = 440000.00$$

$$s_1 = 100.00$$

$s_2 = 250.00$   
 $fy_{we1} = 781.25$   
 $fy_{we2} = 781.25$   
 $f_{ce} = 30.00$   
 From ((5A5), TBDY), TBDY:  $cc = 0.00471045$   
 $c = \text{confinement factor} = 1.27105$   
 $y_1 = 0.00083886$   
 $sh_1 = 0.00268436$   
 $ft_1 = 314.5735$   
 $fy_1 = 262.1446$   
 $su_1 = 0.00268436$   
 using (30) in Biskinis/Fardis (2013) multiplied with shear\_factor  
 and also multiplied by the shear\_factor according to 15.7.1.4, with  
 $\text{Shear\_factor} = 1.00$   
 $lo/lou, \min = lb/ld = 0.13907892$   
 $su_1 = 0.4 * esu_1 \text{ nominal ((5.5), TBDY)} = 0.032$   
 From table 5A.1, TBDY:  $esu_1 \text{ nominal} = 0.08$ ,  
 For calculation of  $esu_1 \text{ nominal}$  and  $y_1, sh_1, ft_1, fy_1$ , it is considered  
 characteristic value  $fs_1 = fs_1/1.2$ , from table 5.1, TBDY.  
 $y_1, sh_1, ft_1, fy_1$ , are also multiplied by  $\text{Min}(1, 1.25 * (lb/ld)^{2/3})$ , from 10.3.5, ASCE 41-17.  
 with  $fs_1 = (fs_{jacket} * Asl, \text{ten, jacket} + fs_{core} * Asl, \text{ten, core}) / Asl, \text{ten} = 262.1446$   
 with  $Es_1 = (Es_{jacket} * Asl, \text{ten, jacket} + Es_{core} * Asl, \text{ten, core}) / Asl, \text{ten} = 200000.00$   
 $y_2 = 0.00083886$   
 $sh_2 = 0.00268436$   
 $ft_2 = 314.5735$   
 $fy_2 = 262.1446$   
 $su_2 = 0.00268436$   
 using (30) in Biskinis/Fardis (2013) multiplied with shear\_factor  
 and also multiplied by the shear\_factor according to 15.7.1.4, with  
 $\text{Shear\_factor} = 1.00$   
 $lo/lou, \min = lb/lb, \min = 0.13907892$   
 $su_2 = 0.4 * esu_2 \text{ nominal ((5.5), TBDY)} = 0.032$   
 From table 5A.1, TBDY:  $esu_2 \text{ nominal} = 0.08$ ,  
 For calculation of  $esu_2 \text{ nominal}$  and  $y_2, sh_2, ft_2, fy_2$ , it is considered  
 characteristic value  $fs_2 = fs_2/1.2$ , from table 5.1, TBDY.  
 $y_1, sh_1, ft_1, fy_1$ , are also multiplied by  $\text{Min}(1, 1.25 * (lb/ld)^{2/3})$ , from 10.3.5, ASCE 41-17.  
 with  $fs_2 = (fs_{jacket} * Asl, \text{com, jacket} + fs_{core} * Asl, \text{com, core}) / Asl, \text{com} = 262.1446$   
 with  $Es_2 = (Es_{jacket} * Asl, \text{com, jacket} + Es_{core} * Asl, \text{com, core}) / Asl, \text{com} = 200000.00$   
 $y_v = 0.00083886$   
 $sh_v = 0.00268436$   
 $ft_v = 314.5735$   
 $fy_v = 262.1446$   
 $suv = 0.00268436$   
 using (30) in Biskinis/Fardis (2013) multiplied with shear\_factor  
 and also multiplied by the shear\_factor according to 15.7.1.4, with  
 $\text{Shear\_factor} = 1.00$   
 $lo/lou, \min = lb/ld = 0.13907892$   
 $suv = 0.4 * esuv \text{ nominal ((5.5), TBDY)} = 0.032$   
 From table 5A.1, TBDY:  $esuv \text{ nominal} = 0.08$ ,  
 considering characteristic value  $fs_v = fs_v/1.2$ , from table 5.1, TBDY  
 For calculation of  $esuv \text{ nominal}$  and  $y_v, sh_v, ft_v, fy_v$ , it is considered  
 characteristic value  $fs_v = fs_v/1.2$ , from table 5.1, TBDY.  
 $y_1, sh_1, ft_1, fy_1$ , are also multiplied by  $\text{Min}(1, 1.25 * (lb/ld)^{2/3})$ , from 10.3.5, ASCE 41-17.  
 with  $fs_v = (fs_{jacket} * Asl, \text{mid, jacket} + fs_{mid} * Asl, \text{mid, core}) / Asl, \text{mid} = 262.1446$   
 with  $Es_v = (Es_{jacket} * Asl, \text{mid, jacket} + Es_{mid} * Asl, \text{mid, core}) / Asl, \text{mid} = 200000.00$   
 $1 = Asl, \text{ten} / (b * d) * (fs_1 / f_c) = 0.0187412$   
 $2 = Asl, \text{com} / (b * d) * (fs_2 / f_c) = 0.03639521$   
 $v = Asl, \text{mid} / (b * d) * (fs_v / f_c) = 0.03308184$   
 and confined core properties:  
 $b = 690.00$   
 $d = 677.00$   
 $d' = 13.00$   
 $f_{cc} \text{ (5A.2, TBDY)} = 38.13135$   
 $cc \text{ (5A.5, TBDY)} = 0.00471045$   
 $c = \text{confinement factor} = 1.27105$   
 $1 = Asl, \text{ten} / (b * d) * (fs_1 / f_c) = 0.02127357$   
 $2 = Asl, \text{com} / (b * d) * (fs_2 / f_c) = 0.04131304$

$v = A_{sl, mid} / (b \cdot d) \cdot (f_{sv} / f_c) = 0.03755196$   
Case/Assumption: Unconfined full section - Steel rupture  
'satisfies Eq. (4.3)

--->  
 $v < v_{s, y2}$  - LHS eq.(4.5) is satisfied  
--->  
 $su(4.9) = 0.21062322$   
 $Mu = MRc(4.14) = 2.3387E+008$   
 $u = su(4.1) = 4.8099118E-006$

-----  
Calculation of ratio  $l_b / l_d$

-----  
Lap Length:  $l_b / l_d = 0.13907892$   
 $l_b = 300.00$   
 $l_d = 2157.049$   
Calculation of  $l_b, min$  according to (25.4.3.2), ACI 318-14, using mean values for all the section re-bars.  
 $l_d, min$  from (25.4.3.2) is multiplied 2 times to account for smooth re-bars (9.1.2, TS500 - No provision in ACI 318)  
= 1  
 $db = 16.66667$   
Mean strength value of all re-bars:  $f_y = 781.25$   
Mean concrete strength:  $f_c' = (f_c'_{jacket} \cdot Area_{jacket} + f_c'_{core} \cdot Area_{core}) / Area_{section} = 30.00$ , but  $f_c'^{0.5} \leq 8.3$   
MPa (22.5.3.1, ACI 318-14)  
 $t = 1.00$   
 $s = 0.80$   
 $e = 1.00$   
 $cb = 25.00$   
 $K_{tr} = 1.7174$   
 $A_{tr} = \min(A_{tr, x}, A_{tr, y}) = 257.6106$   
where  $A_{tr, x}$ ,  $A_{tr, y}$  are the sum of the area of all stirrup legs along X and Y loxal axis  
 $s = \max(s_{external}, s_{internal}) = 250.00$   
 $n = 24.00$

-----  
Calculation of  $Mu_2$ -  
-----

-----  
Calculation of ultimate curvature  $u$  according to 4.1, Biskinis/Fardis 2013:  
 $u = 5.1201636E-006$   
 $Mu = 5.0296E+008$

-----  
with full section properties:

$b = 400.00$   
 $d = 707.00$   
 $d' = 43.00$   
 $v = 0.00191815$   
 $N = 16273.608$   
 $f_c = 30.00$   
 $co(5A.5, TBDY) = 0.002$   
Final value of  $cu$ :  $cu^* = shear\_factor \cdot \max(cu, cc) = 0.01260361$   
The Shear\_factor is considered equal to 1 (pure moment strength)  
From (5.4b), TBDY:  $cu = 0.01260361$   
 $w_e(5.4c) = 0.05179731$   
 $ase((5.4d), TBDY) = (ase1 \cdot A_{ext} + ase2 \cdot A_{int}) / A_{sec} = 0.45746528$   
 $ase1 = \max(((A_{conf, max1} - A_{noConf1}) / A_{conf, max1}) \cdot (A_{conf, min1} / A_{conf, max1}), 0) = 0.45746528$   
The definitions of  $A_{noConf}$ ,  $A_{conf, min}$  and  $A_{conf, max}$  are derived from generalization of the rectangular sections confinement, which is expressed by (5.4d).  
The generalization is done according to Mander, J., Priestley, M., and Park, R. (1988) "Theoretical Stress-Strain Model for Confined Concrete."  
J. Struct. Eng., 10.1061/(ASCE)0733-9445(1988)114:8(1804), 1804-1826.  
 $A_{conf, max1} = 353600.00$  is the confined core area at levels of member with hoops and is calculated as the area of core enclosed by the center lines of the external perimeter hoops.  
 $A_{conf, min1} = 293525.00$  is the confined core area at midway between the levels of hoops and is calculated by reducing all the dimensions of the area  $A_{conf, max1}$  by a length equal to half the clear spacing between external hoops.



AnoConf1 = 158733.333 is the unconfined external core area which is equal to  $b_i^2/6$  as defined at (A.2).  
 $ase2 (>=ase1) = \text{Max}(((A_{conf,max2}-AnoConf2)/A_{conf,max2})*(A_{conf,min2}/A_{conf,max2}),0) = 0.45746528$   
The definitions of AnoConf, Aconf,min and Aconf,max are derived from generalization of the rectangular sections confinement, which is expressed by (5.4d).  
The generalization is done according to Mander, J., Priestley, M., and Park, R. (1988) "Theoretical Stress-Strain Model for Confined Concrete."  
J. Struct. Eng., 10.1061/(ASCE)0733-9445(1988)114:8(1804), 1804-1826.  
Aconf,max2 = 171264.00 is the confined core area at levels of member with hoops and is calculated as the area of core enclosed by the center lines of the internal perimeter hoops.  
Aconf,min2 = 54741.00 is the confined core area at midway between the levels of hoops and is calculated by reducing all the dimensions of the area Aconf,max2 by a length equal to half the clear spacing between internal hoops.  
AnoConf2 = 106242.667 is the unconfined internal core area which is equal to  $b_i^2/6$  as defined at (A.2).  
 $psh,min*Fywe = \text{Min}(psh,x*Fywe, psh,y*Fywe) = 3.3968$

$psh_x*Fywe = psh1*Fywe1 + ps2*Fywe2 = 3.3968$   
 $psh1 ((5.4d), TBDY) = Lstir1*Astir1/(Asec*s1) = 0.00367709$   
Lstir1 (Length of stirrups along Y) = 2060.00  
Astir1 (stirrups area) = 78.53982  
 $psh2 ((5.4d) = Lstir2*Astir2/(Asec*s2) = 0.00067082$   
Lstir2 (Length of stirrups along Y) = 1468.00  
Astir2 (stirrups area) = 50.26548

$psh_y*Fywe = psh1*Fywe1 + ps2*Fywe2 = 3.3968$   
 $psh1 ((5.4d), TBDY) = Lstir1*Astir1/(Asec*s1) = 0.00367709$   
Lstir1 (Length of stirrups along X) = 2060.00  
Astir1 (stirrups area) = 78.53982  
 $psh2 ((5.4d), TBDY) = Lstir2*Astir2/(Asec*s2) = 0.00067082$   
Lstir2 (Length of stirrups along X) = 1468.00  
Astir2 (stirrups area) = 50.26548

Asec = 440000.00

s1 = 100.00

s2 = 250.00

fywe1 = 781.25

fywe2 = 781.25

fce = 30.00

From ((5.A5), TBDY), TBDY: cc = 0.00471045

c = confinement factor = 1.27105

y1 = 0.00083886

sh1 = 0.00268436

ft1 = 314.5735

fy1 = 262.1446

su1 = 0.00268436

using (30) in Biskinis/Fardis (2013) multiplied with shear\_factor and also multiplied by the shear\_factor according to 15.7.1.4, with Shear\_factor = 1.00

lo/lou,min = lb/ld = 0.13907892

su1 = 0.4\*esu1\_nominal ((5.5), TBDY) = 0.032

From table 5A.1, TBDY: esu1\_nominal = 0.08,

For calculation of esu1\_nominal and y1, sh1,ft1,fy1, it is considered characteristic value fsy1 = fs1/1.2, from table 5.1, TBDY.

y1, sh1,ft1,fy1, are also multiplied by  $\text{Min}(1, 1.25*(lb/ld)^{2/3})$ , from 10.3.5, ASCE 41-17.

with fs1 = (fs,jacket\*Asl,ten,jacket + fs,core\*Asl,ten,core)/Asl,ten = 262.1446

with Es1 = (Es,jacket\*Asl,ten,jacket + Es,core\*Asl,ten,core)/Asl,ten = 200000.00

y2 = 0.00083886

sh2 = 0.00268436

ft2 = 314.5735

fy2 = 262.1446

su2 = 0.00268436

using (30) in Biskinis/Fardis (2013) multiplied with shear\_factor and also multiplied by the shear\_factor according to 15.7.1.4, with Shear\_factor = 1.00

lo/lou,min = lb/lb,min = 0.13907892

su2 = 0.4\*esu2\_nominal ((5.5), TBDY) = 0.032

From table 5A.1, TBDY: esu2\_nominal = 0.08,

For calculation of esu2\_nominal and y2, sh2,ft2,fy2, it is considered

characteristic value  $fsy2 = fs2/1.2$ , from table 5.1, TBDY.  
 $y1, sh1, ft1, fy1$ , are also multiplied by  $\text{Min}(1, 1.25 \cdot (lb/ld)^{2/3})$ , from 10.3.5, ASCE 41-17.  
 with  $fs2 = (fs_{jacket} \cdot Asl_{com,jacket} + fs_{core} \cdot Asl_{com,core}) / Asl_{com} = 262.1446$   
 with  $Es2 = (Es_{jacket} \cdot Asl_{com,jacket} + Es_{core} \cdot Asl_{com,core}) / Asl_{com} = 200000.00$   
 $yv = 0.00083886$   
 $shv = 0.00268436$   
 $ftv = 314.5735$   
 $fyv = 262.1446$   
 $suv = 0.00268436$   
 using (30) in Biskinis/Fardis (2013) multiplied with shear\_factor  
 and also multiplied by the shear\_factor according to 15.7.1.4, with  
 Shear\_factor = 1.00  
 $lo/lo_{u,min} = lb/ld = 0.13907892$   
 $suv = 0.4 \cdot esuv_{nominal} ((5.5), TBDY) = 0.032$   
 From table 5A.1, TBDY:  $esuv_{nominal} = 0.08$ ,  
 considering characteristic value  $fsyv = fsv/1.2$ , from table 5.1, TBDY  
 For calculation of  $esuv_{nominal}$  and  $yv, shv, ftv, fyv$ , it is considered  
 characteristic value  $fsyv = fsv/1.2$ , from table 5.1, TBDY.  
 $y1, sh1, ft1, fy1$ , are also multiplied by  $\text{Min}(1, 1.25 \cdot (lb/ld)^{2/3})$ , from 10.3.5, ASCE 41-17.  
 with  $fsv = (fs_{jacket} \cdot Asl_{mid,jacket} + fs_{mid} \cdot Asl_{mid,core}) / Asl_{mid} = 262.1446$   
 with  $Esv = (Es_{jacket} \cdot Asl_{mid,jacket} + Es_{mid} \cdot Asl_{mid,core}) / Asl_{mid} = 200000.00$   
 $1 = Asl_{ten} / (b \cdot d) \cdot (fs1 / fc) = 0.06824101$   
 $2 = Asl_{com} / (b \cdot d) \cdot (fs2 / fc) = 0.03513975$   
 $v = Asl_{mid} / (b \cdot d) \cdot (fsv / fc) = 0.06202846$   
 and confined core properties:  
 $b = 340.00$   
 $d = 677.00$   
 $d' = 13.00$   
 $fcc (5A.2, TBDY) = 38.13135$   
 $cc (5A.5, TBDY) = 0.00471045$   
 $c = \text{confinement factor} = 1.27105$   
 $1 = Asl_{ten} / (b \cdot d) \cdot (fs1 / fc) = 0.08384116$   
 $2 = Asl_{com} / (b \cdot d) \cdot (fs2 / fc) = 0.04317283$   
 $v = Asl_{mid} / (b \cdot d) \cdot (fsv / fc) = 0.07620839$   
 Case/Assumption: Unconfined full section - Steel rupture  
 ' satisfies Eq. (4.3)  
 --->  
 $v < v_{s,y2}$  - LHS eq.(4.5) is satisfied  
 --->  
 $su (4.9) = 0.2584548$   
 $Mu = MRc (4.14) = 5.0296E+008$   
 $u = su (4.1) = 5.1201636E-006$   
 -----  
 Calculation of ratio  $lb/ld$   
 -----  
 Lap Length:  $lb/ld = 0.13907892$   
 $lb = 300.00$   
 $ld = 2157.049$   
 Calculation of  $lb_{min}$  according to (25.4.3.2), ACI 318-14, using mean values for all the section re-bars.  
 $ld_{min}$  from (25.4.3.2) is multiplied 2 times to account for smooth re-bars (9.1.2, TS500 - No provision in ACI 318)  
 $= 1$   
 $db = 16.66667$   
 Mean strength value of all re-bars:  $fy = 781.25$   
 Mean concrete strength:  $fc' = (fc'_{jacket} \cdot Area_{jacket} + fc'_{core} \cdot Area_{core}) / Area_{section} = 30.00$ , but  $fc'^{0.5} \leq 8.3$   
 MPa (22.5.3.1, ACI 318-14)  
 $t = 1.00$   
 $s = 0.80$   
 $e = 1.00$   
 $cb = 25.00$   
 $Ktr = 1.7174$   
 $Atr = \text{Min}(Atr_x, Atr_y) = 257.6106$   
 where  $Atr_x, Atr_y$  are the sum of the area of all stirrup legs along X and Y loxal axis  
 $s = \text{Max}(s_{external}, s_{internal}) = 250.00$   
 $n = 24.00$

Calculation of Shear Strength  $V_r = \text{Min}(V_{r1}, V_{r2}) = 1.0392\text{E}+006$

Calculation of Shear Strength at edge 1,  $V_{r1} = 1.0392\text{E}+006$

$V_{r1} = V_{\text{Col}} ((10.3), \text{ASCE } 41-17) = k_{nl} * V_{\text{Col}0}$

$V_{\text{Col}0} = 1.0392\text{E}+006$

$k_{nl} = 1$  (zero step-static loading)

NOTE: In expression (10-3) ' $V_s = A_v * f_y * d / s$ ' is replaced by ' $V_s + f * V_f$ ' where  $V_f$  is the contribution of FRPs (11.3), ACI 440).

$= 1$  (normal-weight concrete)

Mean concrete strength:  $f_c' = (f_c'_{\text{jacket}} * \text{Area}_{\text{jacket}} + f_c'_{\text{core}} * \text{Area}_{\text{core}}) / \text{Area}_{\text{section}} = 30.00$ , but  $f_c'^{0.5} \leq 8.3$  MPa (22.5.3.1, ACI 318-14)

$M/Vd = 4.00$

$\mu_u = 1308.016$

$V_u = 0.00017144$

$d = 0.8 * h = 600.00$

$N_u = 16273.608$

$A_g = 300000.00$

From (11.5.4.8), ACI 318-14:  $V_s = V_{s,\text{jacket}} + V_{s,\text{core}} = 1.0138\text{E}+006$

where:

$V_{s,\text{jacket}} = V_{s,j1} + V_{s,j2} = 903207.888$

$V_{s,j1} = 589048.623$  is calculated for section web jacket, with:

$d = 600.00$

$A_v = 157079.633$

$f_y = 625.00$

$s = 100.00$

$V_{s,j1}$  is multiplied by  $\text{Col},j1 = 1.00$

$s/d = 0.16666667$

$V_{s,j2} = 314159.265$  is calculated for section flange jacket, with:

$d = 320.00$

$A_v = 157079.633$

$f_y = 625.00$

$s = 100.00$

$V_{s,j2}$  is multiplied by  $\text{Col},j2 = 1.00$

$s/d = 0.3125$

$V_{s,\text{core}} = V_{s,c1} + V_{s,c2} = 110584.061$

$V_{s,c1} = 110584.061$  is calculated for section web core, with:

$d = 440.00$

$A_v = 100530.965$

$f_y = 625.00$

$s = 250.00$

$V_{s,c1}$  is multiplied by  $\text{Col},c1 = 1.00$

$s/d = 0.56818182$

$V_{s,c2} = 0.00$  is calculated for section flange core, with:

$d = 160.00$

$A_v = 100530.965$

$f_y = 625.00$

$s = 250.00$

$V_{s,c2}$  is multiplied by  $\text{Col},c2 = 0.00$

$s/d = 1.5625$

$V_f ((11-3)-(11.4), \text{ACI } 440) = 0.00$

From (11-11), ACI 440:  $V_s + V_f \leq 873250.061$

$b_w = 400.00$

Calculation of Shear Strength at edge 2,  $V_{r2} = 1.0392\text{E}+006$

$V_{r2} = V_{\text{Col}} ((10.3), \text{ASCE } 41-17) = k_{nl} * V_{\text{Col}0}$

$V_{\text{Col}0} = 1.0392\text{E}+006$

$k_{nl} = 1$  (zero step-static loading)

NOTE: In expression (10-3) ' $V_s = A_v * f_y * d / s$ ' is replaced by ' $V_s + f * V_f$ ' where  $V_f$  is the contribution of FRPs (11.3), ACI 440).

$= 1$  (normal-weight concrete)

Mean concrete strength:  $fc' = (fc'_{jacket} \cdot Area_{jacket} + fc'_{core} \cdot Area_{core}) / Area_{section} = 30.00$ , but  $fc'^{0.5} \leq 8.3$  MPa (22.5.3.1, ACI 318-14)

$M/Vd = 4.00$

$\mu_u = 1308.016$

$V_u = 0.00017144$

$d = 0.8 \cdot h = 600.00$

$N_u = 16273.608$

$A_g = 300000.00$

From (11.5.4.8), ACI 318-14:  $V_s = V_{sjacket} + V_{s,core} = 1.0138E+006$

where:

$V_{sjacket} = V_{sj1} + V_{sj2} = 903207.888$

$V_{sj1} = 589048.623$  is calculated for section web jacket, with:

$d = 600.00$

$A_v = 157079.633$

$f_y = 625.00$

$s = 100.00$

$V_{sj1}$  is multiplied by  $Col,j1 = 1.00$

$s/d = 0.16666667$

$V_{sj2} = 314159.265$  is calculated for section flange jacket, with:

$d = 320.00$

$A_v = 157079.633$

$f_y = 625.00$

$s = 100.00$

$V_{sj2}$  is multiplied by  $Col,j2 = 1.00$

$s/d = 0.3125$

$V_{s,core} = V_{s,c1} + V_{s,c2} = 110584.061$

$V_{s,c1} = 110584.061$  is calculated for section web core, with:

$d = 440.00$

$A_v = 100530.965$

$f_y = 625.00$

$s = 250.00$

$V_{s,c1}$  is multiplied by  $Col,c1 = 1.00$

$s/d = 0.56818182$

$V_{s,c2} = 0.00$  is calculated for section flange core, with:

$d = 160.00$

$A_v = 100530.965$

$f_y = 625.00$

$s = 250.00$

$V_{s,c2}$  is multiplied by  $Col,c2 = 0.00$

$s/d = 1.5625$

$V_f ((11-3)-(11.4), ACI 440) = 0.00$

From (11-11), ACI 440:  $V_s + V_f \leq 873250.061$

$bw = 400.00$

-----

End Of Calculation of Shear Capacity ratio for element: column JLC1 of floor 1

At local axis: 3

-----

Start Of Calculation of Shear Capacity ratio for element: column JLC1 of floor 1

At Shear local axis: 2

(Bending local axis: 3)

Section Type: rcjlc3

Constant Properties

-----

Knowledge Factor,  $\phi = 1.00$

Mean strength values are used for both shear and moment calculations.

Consequently:

Jacket

New material of Primary Member: Concrete Strength,  $fc = f_{cm} = 30.00$

New material of Primary Member: Steel Strength,  $f_s = f_{sm} = 625.00$

Concrete Elasticity,  $E_c = 25742.96$

Steel Elasticity,  $E_s = 200000.00$

Existing Column

```

New material of Primary Member: Concrete Strength,  $f_c = f_{cm} = 30.00$ 
New material of Primary Member: Steel Strength,  $f_s = f_{sm} = 625.00$ 
Concrete Elasticity,  $E_c = 25742.96$ 
Steel Elasticity,  $E_s = 200000.00$ 
#####
Note: Especially for the calculation of moment strengths,
the above steel re-bar strengths are multiplied by 1.25 according to R18.6.5, ACI 318-14
Jacket
New material: Steel Strength,  $f_s = 1.25 \cdot f_{sm} = 781.25$ 
Existing Column
New material: Steel Strength,  $f_s = 1.25 \cdot f_{sm} = 781.25$ 
#####
Max Height,  $H_{max} = 750.00$ 
Min Height,  $H_{min} = 400.00$ 
Max Width,  $W_{max} = 750.00$ 
Min Width,  $W_{min} = 400.00$ 
Jacket Thickness,  $t_j = 100.00$ 
Cover Thickness,  $c = 25.00$ 
Mean Confinement Factor overall section = 1.27105
Element Length,  $L = 3000.00$ 
Primary Member
Smooth Bars
Ductile Steel
With Detailing for Earthquake Resistance (including stirrups closed at 135°)
Longitudinal Bars With Ends Lapped Starting at the End Sections
Lap Length  $l_o = 300.00$ 
No FRP Wrapping
-----

Stepwise Properties
-----
At local axis: 2
EDGE -A-
Shear Force,  $V_a = -0.0001715$ 
EDGE -B-
Shear Force,  $V_b = 0.0001715$ 
BOTH EDGES
Axial Force,  $F = -16273.608$ 
Longitudinal Reinforcement Area Distribution (in 2 divisions)
  -Tension:  $As_t = 0.00$ 
  -Compression:  $As_c = 5353.274$ 
Longitudinal Reinforcement Area Distribution (in 3 divisions)
  -Tension:  $As_{t,ten} = 1137.257$ 
  -Compression:  $As_{l,com} = 2208.54$ 
  -Middle:  $As_{l,mid} = 2007.478$ 
-----
-----

Calculation of Shear Capacity ratio ,  $V_e/V_r = 0.32266369$ 
Member Controlled by Flexure ( $V_e/V_r < 1$ )
Calculation of Shear Demand from fig. R18.6.5, ACI 318-14  $V_e = (M_{pr1} + M_{pr2})/l_n = 335307.657$ 
with
 $M_{pr1} = \text{Max}(M_{u1+} , M_{u1-}) = 5.0296E+008$ 
 $M_{u1+} = 2.3387E+008$ , is the ultimate moment strength at the edge 1 of the member in the actual moment direction
which is defined for the static loading combination
 $M_{u1-} = 5.0296E+008$ , is the ultimate moment strength at the edge 1 of the member in the opposite moment
direction which is defined for the static loading combination
 $M_{pr2} = \text{Max}(M_{u2+} , M_{u2-}) = 5.0296E+008$ 
 $M_{u2+} = 2.3387E+008$ , is the ultimate moment strength at the edge 2 of the member in the actual moment direction
which is defined for the the static loading combination
 $M_{u2-} = 5.0296E+008$ , is the ultimate moment strength at the edge 2 of the member in the opposite moment
direction which is defined for the the static loading combination
-----

Calculation of  $M_{u1+}$ 
-----

```

Calculation of ultimate curvature  $\phi_u$  according to 4.1, Biskinis/Fardis 2013:

$$u = 4.8099118E-006$$

$$\mu = 2.3387E+008$$

with full section properties:

$$b = 750.00$$

$$d = 707.00$$

$$d' = 43.00$$

$$v = 0.00102301$$

$$N = 16273.608$$

$$f_c = 30.00$$

$$\alpha (5A.5, \text{TB DY}) = 0.002$$

$$\text{Final value of } \phi_u: \phi_u^* = \text{shear\_factor} * \text{Max}(\phi_u, \phi_c) = 0.01260361$$

The Shear\_factor is considered equal to 1 (pure moment strength)

$$\text{From (5.4b), TB DY: } \phi_u = 0.01260361$$

$$\phi_{ue} (5.4c) = 0.05179731$$

$$\phi_{ase} ((5.4d), \text{TB DY}) = (\phi_{ase1} * A_{ext} + \phi_{ase2} * A_{int}) / A_{sec} = 0.45746528$$

$$\phi_{ase1} = \text{Max}(((A_{conf,max1} - A_{noConf1}) / A_{conf,max1}) * (A_{conf,min1} / A_{conf,max1}), 0) = 0.45746528$$

The definitions of  $A_{noConf}$ ,  $A_{conf,min}$  and  $A_{conf,max}$  are derived from generalization of the rectangular sections confinement, which is expressed by (5.4d).

The generalization is done according to Mander, J., Priestley, M., and Park, R. (1988)

"Theoretical Stress-Strain Model for Confined Concrete."

J. Struct. Eng., 10.1061/(ASCE)0733-9445(1988)114:8(1804), 1804-1826.

$A_{conf,max1} = 353600.00$  is the confined core area at levels of member with hoops and is calculated as the area of core enclosed by the center lines of the external perimeter hoops.

$A_{conf,min1} = 293525.00$  is the confined core area at midway between the levels of hoops and is calculated by reducing all the dimensions of the area  $A_{conf,max1}$  by a length equal to half the clear spacing between external hoops.

$A_{noConf1} = 158733.333$  is the unconfined external core area which is equal to  $b_i^2/6$  as defined at (A.2).

$$\phi_{ase2} (> \phi_{ase1}) = \text{Max}(((A_{conf,max2} - A_{noConf2}) / A_{conf,max2}) * (A_{conf,min2} / A_{conf,max2}), 0) = 0.45746528$$

The definitions of  $A_{noConf}$ ,  $A_{conf,min}$  and  $A_{conf,max}$  are derived from generalization of the rectangular sections confinement, which is expressed by (5.4d).

The generalization is done according to Mander, J., Priestley, M., and Park, R. (1988)

"Theoretical Stress-Strain Model for Confined Concrete."

J. Struct. Eng., 10.1061/(ASCE)0733-9445(1988)114:8(1804), 1804-1826.

$A_{conf,max2} = 171264.00$  is the confined core area at levels of member with hoops and is calculated as the area of core enclosed by the center lines of the internal perimeter hoops.

$A_{conf,min2} = 54741.00$  is the confined core area at midway between the levels of hoops and is calculated by reducing all the dimensions of the area  $A_{conf,max2}$  by a length equal to half the clear spacing between internal hoops.

$A_{noConf2} = 106242.667$  is the unconfined internal core area which is equal to  $b_i^2/6$  as defined at (A.2).

$$\phi_{psh,min} * F_{ywe} = \text{Min}(\phi_{psh,x} * F_{ywe}, \phi_{psh,y} * F_{ywe}) = 3.3968$$

$$\phi_{psh,x} * F_{ywe} = \phi_{psh1} * F_{ywe1} + \phi_{ps2} * F_{ywe2} = 3.3968$$

$$\phi_{psh1} ((5.4d), \text{TB DY}) = L_{stir1} * A_{stir1} / (A_{sec} * s_1) = 0.00367709$$

$$L_{stir1} (\text{Length of stirrups along Y}) = 2060.00$$

$$A_{stir1} (\text{stirrups area}) = 78.53982$$

$$\phi_{psh2} (5.4d) = L_{stir2} * A_{stir2} / (A_{sec} * s_2) = 0.00067082$$

$$L_{stir2} (\text{Length of stirrups along Y}) = 1468.00$$

$$A_{stir2} (\text{stirrups area}) = 50.26548$$

$$\phi_{psh,y} * F_{ywe} = \phi_{psh1} * F_{ywe1} + \phi_{ps2} * F_{ywe2} = 3.3968$$

$$\phi_{psh1} ((5.4d), \text{TB DY}) = L_{stir1} * A_{stir1} / (A_{sec} * s_1) = 0.00367709$$

$$L_{stir1} (\text{Length of stirrups along X}) = 2060.00$$

$$A_{stir1} (\text{stirrups area}) = 78.53982$$

$$\phi_{psh2} ((5.4d), \text{TB DY}) = L_{stir2} * A_{stir2} / (A_{sec} * s_2) = 0.00067082$$

$$L_{stir2} (\text{Length of stirrups along X}) = 1468.00$$

$$A_{stir2} (\text{stirrups area}) = 50.26548$$

$$A_{sec} = 440000.00$$

$$s_1 = 100.00$$

$$s_2 = 250.00$$

$$f_{ywe1} = 781.25$$

$$f_{ywe2} = 781.25$$

$$f_{ce} = 30.00$$

From (5A.5, TBDY), TBDY:  $cc = 0.00471045$   
 $c = \text{confinement factor} = 1.27105$   
 $y1 = 0.00083886$   
 $sh1 = 0.00268436$   
 $ft1 = 314.5735$   
 $fy1 = 262.1446$   
 $su1 = 0.00268436$   
 using (30) in Biskinis/Fardis (2013) multiplied with shear\_factor  
 and also multiplied by the shear\_factor according to 15.7.1.4, with  
 $\text{Shear\_factor} = 1.00$   
 $lo/lou,min = lb/ld = 0.13907892$   
 $su1 = 0.4 * esu1\_nominal ((5.5), TBDY) = 0.032$   
 From table 5A.1, TBDY:  $esu1\_nominal = 0.08$ ,  
 For calculation of  $esu1\_nominal$  and  $y1, sh1, ft1, fy1$ , it is considered  
 characteristic value  $fsy1 = fs1/1.2$ , from table 5.1, TBDY.  
 $y1, sh1, ft1, fy1$ , are also multiplied by  $\text{Min}(1, 1.25 * (lb/ld)^{2/3})$ , from 10.3.5, ASCE 41-17.  
 with  $fs1 = (fs\_jacket * Asl\_ten, jacket + fs\_core * Asl\_ten, core) / Asl\_ten = 262.1446$   
 with  $Es1 = (Es\_jacket * Asl\_ten, jacket + Es\_core * Asl\_ten, core) / Asl\_ten = 200000.00$   
 $y2 = 0.00083886$   
 $sh2 = 0.00268436$   
 $ft2 = 314.5735$   
 $fy2 = 262.1446$   
 $su2 = 0.00268436$   
 using (30) in Biskinis/Fardis (2013) multiplied with shear\_factor  
 and also multiplied by the shear\_factor according to 15.7.1.4, with  
 $\text{Shear\_factor} = 1.00$   
 $lo/lou,min = lb/lb,min = 0.13907892$   
 $su2 = 0.4 * esu2\_nominal ((5.5), TBDY) = 0.032$   
 From table 5A.1, TBDY:  $esu2\_nominal = 0.08$ ,  
 For calculation of  $esu2\_nominal$  and  $y2, sh2, ft2, fy2$ , it is considered  
 characteristic value  $fsy2 = fs2/1.2$ , from table 5.1, TBDY.  
 $y1, sh1, ft1, fy1$ , are also multiplied by  $\text{Min}(1, 1.25 * (lb/ld)^{2/3})$ , from 10.3.5, ASCE 41-17.  
 with  $fs2 = (fs\_jacket * Asl\_com, jacket + fs\_core * Asl\_com, core) / Asl\_com = 262.1446$   
 with  $Es2 = (Es\_jacket * Asl\_com, jacket + Es\_core * Asl\_com, core) / Asl\_com = 200000.00$   
 $yv = 0.00083886$   
 $shv = 0.00268436$   
 $ftv = 314.5735$   
 $fyv = 262.1446$   
 $suv = 0.00268436$   
 using (30) in Biskinis/Fardis (2013) multiplied with shear\_factor  
 and also multiplied by the shear\_factor according to 15.7.1.4, with  
 $\text{Shear\_factor} = 1.00$   
 $lo/lou,min = lb/ld = 0.13907892$   
 $suv = 0.4 * esuv\_nominal ((5.5), TBDY) = 0.032$   
 From table 5A.1, TBDY:  $esuv\_nominal = 0.08$ ,  
 considering characteristic value  $fsyv = fsv/1.2$ , from table 5.1, TBDY  
 For calculation of  $esuv\_nominal$  and  $yv, shv, ftv, fyv$ , it is considered  
 characteristic value  $fsyv = fsv/1.2$ , from table 5.1, TBDY.  
 $y1, sh1, ft1, fy1$ , are also multiplied by  $\text{Min}(1, 1.25 * (lb/ld)^{2/3})$ , from 10.3.5, ASCE 41-17.  
 with  $fsv = (fs\_jacket * Asl\_mid, jacket + fs\_mid * Asl\_mid, core) / Asl\_mid = 262.1446$   
 with  $Es_v = (Es\_jacket * Asl\_mid, jacket + Es\_mid * Asl\_mid, core) / Asl\_mid = 200000.00$   
 $1 = Asl\_ten / (b * d) * (fs1 / fc) = 0.0187412$   
 $2 = Asl\_com / (b * d) * (fs2 / fc) = 0.03639521$   
 $v = Asl\_mid / (b * d) * (fsv / fc) = 0.03308184$   
 and confined core properties:  
 $b = 690.00$   
 $d = 677.00$   
 $d' = 13.00$   
 $fcc (5A.2, TBDY) = 38.13135$   
 $cc (5A.5, TBDY) = 0.00471045$   
 $c = \text{confinement factor} = 1.27105$   
 $1 = Asl\_ten / (b * d) * (fs1 / fc) = 0.02127357$   
 $2 = Asl\_com / (b * d) * (fs2 / fc) = 0.04131304$   
 $v = Asl\_mid / (b * d) * (fsv / fc) = 0.03755196$   
 Case/Assumption: Unconfined full section - Steel rupture  
 ' satisfies Eq. (4.3)

---

$v < v_{s,y2}$  - LHS eq.(4.5) is satisfied

---->

$$s_u(4.9) = 0.21062322$$

$$\mu_u = M_{Rc}(4.14) = 2.3387E+008$$

$$u = s_u(4.1) = 4.8099118E-006$$

Calculation of ratio  $I_b/I_d$

$$\text{Lap Length: } I_b/I_d = 0.13907892$$

$$I_b = 300.00$$

$$I_d = 2157.049$$

Calculation of  $I_{b,min}$  according to (25.4.3.2), ACI 318-14, using mean values for all the section re-bars.

$I_{d,min}$  from (25.4.3.2) is multiplied 2 times to account for smooth re-bars (9.1.2, TS500 - No provision in ACI 318)

$$= 1$$

$$d_b = 16.66667$$

$$\text{Mean strength value of all re-bars: } f_y = 781.25$$

$$\text{Mean concrete strength: } f'_c = (f'_{c,jacket} \cdot \text{Area}_{jacket} + f'_{c,core} \cdot \text{Area}_{core}) / \text{Area}_{section} = 30.00, \text{ but } f'_c^{0.5} \leq 8.3 \text{ MPa (22.5.3.1, ACI 318-14)}$$

$$t = 1.00$$

$$s = 0.80$$

$$e = 1.00$$

$$c_b = 25.00$$

$$K_{tr} = 1.7174$$

$$A_{tr} = \text{Min}(A_{tr,x}, A_{tr,y}) = 257.6106$$

where  $A_{tr,x}$ ,  $A_{tr,y}$  are the sum of the area of all stirrup legs along X and Y local axis

$$s = \text{Max}(s_{external}, s_{internal}) = 250.00$$

$$n = 24.00$$

Calculation of  $\mu_{u1}$ -

Calculation of ultimate curvature  $\mu_u$  according to 4.1, Biskinis/Fardis 2013:

$$u = 5.1201636E-006$$

$$\mu_u = 5.0296E+008$$

with full section properties:

$$b = 400.00$$

$$d = 707.00$$

$$d' = 43.00$$

$$v = 0.00191815$$

$$N = 16273.608$$

$$f'_c = 30.00$$

$$\alpha_0(5A.5, \text{TBDY}) = 0.002$$

$$\text{Final value of } \mu_u: \mu_u^* = \text{shear\_factor} \cdot \text{Max}(\mu_u, \alpha_0) = 0.01260361$$

The Shear\_factor is considered equal to 1 (pure moment strength)

$$\text{From (5.4b), TBDY: } \mu_u = 0.01260361$$

$$\mu_{ue}(5.4c) = 0.05179731$$

$$\mu_{ase}((5.4d), \text{TBDY}) = (\mu_{ase1} \cdot A_{ext} + \mu_{ase2} \cdot A_{int}) / A_{sec} = 0.45746528$$

$$\mu_{ase1} = \text{Max}(((A_{conf,max1} - A_{noConf1}) / A_{conf,max1}) \cdot (\mu_{ase,min1} / A_{conf,max1}), 0) = 0.45746528$$

The definitions of  $A_{noConf}$ ,  $A_{conf,min}$  and  $A_{conf,max}$  are derived from generalization of the rectangular sections confinement, which is expressed by (5.4d).

The generalization is done according to Mander, J., Priestley, M., and Park, R. (1988)

"Theoretical Stress-Strain Model for Confined Concrete."

J. Struct. Eng., 10.1061/(ASCE)0733-9445(1988)114:8(1804), 1804-1826.

$A_{conf,max1} = 353600.00$  is the confined core area at levels of member with hoops and is calculated as the area of core enclosed by the center lines of the external perimeter hoops.

$A_{conf,min1} = 293525.00$  is the confined core area at midway between the levels of hoops and is calculated by reducing all the dimensions of the area  $A_{conf,max1}$  by a length equal to half the clear spacing between external hoops.

$A_{noConf1} = 158733.333$  is the unconfined external core area which is equal to  $b^2/6$  as defined at (A.2).

$$\mu_{ase2} (\geq \mu_{ase1}) = \text{Max}(((A_{conf,max2} - A_{noConf2}) / A_{conf,max2}) \cdot (\mu_{ase,min2} / A_{conf,max2}), 0) = 0.45746528$$

The definitions of  $A_{noConf}$ ,  $A_{conf,min}$  and  $A_{conf,max}$  are derived from generalization of the rectangular sections confinement, which is expressed by (5.4d).



The generalization is done according to Mander, J., Priestley, M., and Park, R. (1988)  
"Theoretical Stress-Strain Model for Confined Concrete."

J. Struct. Eng., 10.1061/(ASCE)0733-9445(1988)114:8(1804), 1804-1826.

$A_{conf,max2} = 171264.00$  is the confined core area at levels of member with hoops and  
is calculated as the area of core enclosed by the center lines of the internal perimeter hoops.

$A_{conf,min2} = 54741.00$  is the confined core area at midway between the levels of hoops and  
is calculated by reducing all the dimensions of the area  $A_{conf,max2}$  by a length  
equal to half the clear spacing between internal hoops.

$A_{noConf2} = 106242.667$  is the unconfined internal core area which is equal to  $b_i^2/6$  as defined at (A.2).  
 $p_{sh,min} \cdot F_{ywe} = \text{Min}(p_{sh,x} \cdot F_{ywe}, p_{sh,y} \cdot F_{ywe}) = 3.3968$

-----  
 $p_{sh,x} \cdot F_{ywe} = p_{sh1} \cdot F_{ywe1} + p_{sh2} \cdot F_{ywe2} = 3.3968$   
 $p_{sh1} ((5.4d), \text{TBDY}) = L_{stir1} \cdot A_{stir1} / (A_{sec} \cdot s_1) = 0.00367709$   
 $L_{stir1}$  (Length of stirrups along Y) = 2060.00  
 $A_{stir1}$  (stirrups area) = 78.53982  
 $p_{sh2} (5.4d) = L_{stir2} \cdot A_{stir2} / (A_{sec} \cdot s_2) = 0.00067082$   
 $L_{stir2}$  (Length of stirrups along Y) = 1468.00  
 $A_{stir2}$  (stirrups area) = 50.26548

-----  
 $p_{sh,y} \cdot F_{ywe} = p_{sh1} \cdot F_{ywe1} + p_{sh2} \cdot F_{ywe2} = 3.3968$   
 $p_{sh1} ((5.4d), \text{TBDY}) = L_{stir1} \cdot A_{stir1} / (A_{sec} \cdot s_1) = 0.00367709$   
 $L_{stir1}$  (Length of stirrups along X) = 2060.00  
 $A_{stir1}$  (stirrups area) = 78.53982  
 $p_{sh2} ((5.4d), \text{TBDY}) = L_{stir2} \cdot A_{stir2} / (A_{sec} \cdot s_2) = 0.00067082$   
 $L_{stir2}$  (Length of stirrups along X) = 1468.00  
 $A_{stir2}$  (stirrups area) = 50.26548

-----  
 $A_{sec} = 440000.00$

$s_1 = 100.00$

$s_2 = 250.00$

$f_{ywe1} = 781.25$

$f_{ywe2} = 781.25$

$f_{ce} = 30.00$

From ((5.A5), TBDY), TBDY:  $c_c = 0.00471045$

$c = \text{confinement factor} = 1.27105$

$y_1 = 0.00083886$

$sh_1 = 0.00268436$

$ft_1 = 314.5735$

$fy_1 = 262.1446$

$su_1 = 0.00268436$

using (30) in Biskinis/Fardis (2013) multiplied with shear\_factor  
and also multiplied by the shear\_factor according to 15.7.1.4, with  
Shear\_factor = 1.00

$l_o/l_{ou,min} = l_b/l_d = 0.13907892$

$su_1 = 0.4 \cdot esu1\_nominal ((5.5), \text{TBDY}) = 0.032$

From table 5A.1, TBDY:  $esu1\_nominal = 0.08$ ,

For calculation of  $esu1\_nominal$  and  $y_1, sh_1, ft_1, fy_1$ , it is considered  
characteristic value  $fsy_1 = fs_1/1.2$ , from table 5.1, TBDY.

$y_1, sh_1, ft_1, fy_1$ , are also multiplied by  $\text{Min}(1, 1.25 \cdot (l_b/l_d)^{2/3})$ , from 10.3.5, ASCE 41-17.

with  $fs_1 = (f_{s,jacket} \cdot A_{sl,ten,jacket} + f_{s,core} \cdot A_{sl,ten,core}) / A_{sl,ten} = 262.1446$

with  $Es_1 = (E_{s,jacket} \cdot A_{sl,ten,jacket} + E_{s,core} \cdot A_{sl,ten,core}) / A_{sl,ten} = 200000.00$

$y_2 = 0.00083886$

$sh_2 = 0.00268436$

$ft_2 = 314.5735$

$fy_2 = 262.1446$

$su_2 = 0.00268436$

using (30) in Biskinis/Fardis (2013) multiplied with shear\_factor  
and also multiplied by the shear\_factor according to 15.7.1.4, with  
Shear\_factor = 1.00

$l_o/l_{ou,min} = l_b/l_{b,min} = 0.13907892$

$su_2 = 0.4 \cdot esu2\_nominal ((5.5), \text{TBDY}) = 0.032$

From table 5A.1, TBDY:  $esu2\_nominal = 0.08$ ,

For calculation of  $esu2\_nominal$  and  $y_2, sh_2, ft_2, fy_2$ , it is considered  
characteristic value  $fsy_2 = fs_2/1.2$ , from table 5.1, TBDY.

$y_1, sh_1, ft_1, fy_1$ , are also multiplied by  $\text{Min}(1, 1.25 \cdot (l_b/l_d)^{2/3})$ , from 10.3.5, ASCE 41-17.

with  $fs_2 = (f_{s,jacket} \cdot A_{sl,com,jacket} + f_{s,core} \cdot A_{sl,com,core}) / A_{sl,com} = 262.1446$

with  $Es_2 = (E_{s,jacket} \cdot A_{sl,com,jacket} + E_{s,core} \cdot A_{sl,com,core}) / A_{sl,com} = 200000.00$

```

yv = 0.00083886
shv = 0.00268436
ftv = 314.5735
fyv = 262.1446
suv = 0.00268436
using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00
lo/lou,min = lb/ld = 0.13907892
suv = 0.4*esuv_nominal ((5.5), TBDY) = 0.032
From table 5A.1, TBDY: esuv_nominal = 0.08,
considering characteristic value fsyv = fsv/1.2, from table 5.1, TBDY
For calculation of esuv_nominal and yv, shv,ftv,fyv, it is considered
characteristic value fsyv = fsv/1.2, from table 5.1, TBDY.
y1, sh1,ft1,fy1, are also multiplied by Min(1,1.25*(lb/ld)^2/3), from 10.3.5, ASCE 41-17.
with fsv = (fs,jacket*Asl,mid,jacket + fs,mid*Asl,mid,core)/Asl,mid = 262.1446
with Esv = (Es,jacket*Asl,mid,jacket + Es,mid*Asl,mid,core)/Asl,mid = 200000.00
1 = Asl,ten/(b*d)*(fs1/fc) = 0.06824101
2 = Asl,com/(b*d)*(fs2/fc) = 0.03513975
v = Asl,mid/(b*d)*(fsv/fc) = 0.06202846
and confined core properties:
b = 340.00
d = 677.00
d' = 13.00
fcc (5A.2, TBDY) = 38.13135
cc (5A.5, TBDY) = 0.00471045
c = confinement factor = 1.27105
1 = Asl,ten/(b*d)*(fs1/fc) = 0.08384116
2 = Asl,com/(b*d)*(fs2/fc) = 0.04317283
v = Asl,mid/(b*d)*(fsv/fc) = 0.07620839
Case/Assumption: Unconfined full section - Steel rupture
' satisfies Eq. (4.3)
--->
v < vs,y2 - LHS eq.(4.5) is satisfied
--->
su (4.9) = 0.2584548
Mu = MRc (4.14) = 5.0296E+008
u = su (4.1) = 5.1201636E-006
-----

Calculation of ratio lb/ld
-----

Lap Length: lb/ld = 0.13907892
lb = 300.00
ld = 2157.049
Calculation of lb,min according to (25.4.3.2), ACI 318-14, using mean values for all the section re-bars.
ld,min from (25.4.3.2) is multiplied 2 times to account for smooth re-bars (9.1.2, TS500 - No provision in ACI 318)
= 1
db = 16.66667
Mean strength value of all re-bars: fy = 781.25
Mean concrete strength: fc' = (fc'_jacket*Area_jacket + fc'_core*Area_core)/Area_section = 30.00, but fc'^0.5 <= 8.3
MPa (22.5.3.1, ACI 318-14)
t = 1.00
s = 0.80
e = 1.00
cb = 25.00
Ktr = 1.7174
Atr = Min(Atr_x,Atr_y) = 257.6106
where Atr_x, Atr_y are the sum of the area of all stirrup legs along X and Y loxal axis
s = Max(s_external,s_internal) = 250.00
n = 24.00
-----

Calculation of Mu2+
-----

```

Calculation of ultimate curvature  $\phi_u$  according to 4.1, Biskinis/Fardis 2013:

$$u = 4.8099118E-006$$

$$Mu = 2.3387E+008$$

with full section properties:

$$b = 750.00$$

$$d = 707.00$$

$$d' = 43.00$$

$$v = 0.00102301$$

$$N = 16273.608$$

$$f_c = 30.00$$

$$\alpha (5A.5, TBDY) = 0.002$$

$$\text{Final value of } \phi_u: \phi_u^* = \text{shear\_factor} * \text{Max}(\phi_u, \phi_c) = 0.01260361$$

The Shear\_factor is considered equal to 1 (pure moment strength)

$$\text{From (5.4b), TBDY: } \phi_u = 0.01260361$$

$$\text{we (5.4c) } = 0.05179731$$

$$\text{ase ((5.4d), TBDY) } = (\text{ase1} * A_{ext} + \text{ase2} * A_{int}) / A_{sec} = 0.45746528$$

$$\text{ase1} = \text{Max}(((A_{conf,max1} - A_{noConf1}) / A_{conf,max1}) * (A_{conf,min1} / A_{conf,max1}), 0) = 0.45746528$$

The definitions of  $A_{noConf}$ ,  $A_{conf,min}$  and  $A_{conf,max}$  are derived from generalization of the rectangular sections confinement, which is expressed by (5.4d).

The generalization is done according to Mander, J., Priestley, M., and Park, R. (1988)

"Theoretical Stress-Strain Model for Confined Concrete."

J. Struct. Eng., 10.1061/(ASCE)0733-9445(1988)114:8(1804), 1804-1826.

$A_{conf,max1} = 353600.00$  is the confined core area at levels of member with hoops and

is calculated as the area of core enclosed by the center lines of the external perimeter hoops.

$A_{conf,min1} = 293525.00$  is the confined core area at midway between the levels of hoops and

is calculated by reducing all the dimensions of the area  $A_{conf,max1}$  by a length

equal to half the clear spacing between external hoops.

$A_{noConf1} = 158733.333$  is the unconfined external core area which is equal to  $b_i^2/6$  as defined at (A.2).

$$\text{ase2 } (>= \text{ase1}) = \text{Max}(((A_{conf,max2} - A_{noConf2}) / A_{conf,max2}) * (A_{conf,min2} / A_{conf,max2}), 0) = 0.45746528$$

The definitions of  $A_{noConf}$ ,  $A_{conf,min}$  and  $A_{conf,max}$  are derived from generalization of the rectangular sections confinement, which is expressed by (5.4d).

The generalization is done according to Mander, J., Priestley, M., and Park, R. (1988)

"Theoretical Stress-Strain Model for Confined Concrete."

J. Struct. Eng., 10.1061/(ASCE)0733-9445(1988)114:8(1804), 1804-1826.

$A_{conf,max2} = 171264.00$  is the confined core area at levels of member with hoops and

is calculated as the area of core enclosed by the center lines of the internal perimeter hoops.

$A_{conf,min2} = 54741.00$  is the confined core area at midway between the levels of hoops and

is calculated by reducing all the dimensions of the area  $A_{conf,max2}$  by a length

equal to half the clear spacing between internal hoops.

$A_{noConf2} = 106242.667$  is the unconfined internal core area which is equal to  $b_i^2/6$  as defined at (A.2).

$$\text{psh}_{min} * F_{ywe} = \text{Min}(\text{psh}_x * F_{ywe}, \text{psh}_y * F_{ywe}) = 3.3968$$

$$\text{psh}_x * F_{ywe} = \text{psh1} * F_{ywe1} + \text{ps2} * F_{ywe2} = 3.3968$$

$$\text{psh1 ((5.4d), TBDY) } = L_{stir1} * A_{stir1} / (A_{sec} * s1) = 0.00367709$$

$$L_{stir1} \text{ (Length of stirrups along Y) } = 2060.00$$

$$A_{stir1} \text{ (stirrups area) } = 78.53982$$

$$\text{psh2 (5.4d) } = L_{stir2} * A_{stir2} / (A_{sec} * s2) = 0.00067082$$

$$L_{stir2} \text{ (Length of stirrups along Y) } = 1468.00$$

$$A_{stir2} \text{ (stirrups area) } = 50.26548$$

$$\text{psh}_y * F_{ywe} = \text{psh1} * F_{ywe1} + \text{ps2} * F_{ywe2} = 3.3968$$

$$\text{psh1 ((5.4d), TBDY) } = L_{stir1} * A_{stir1} / (A_{sec} * s1) = 0.00367709$$

$$L_{stir1} \text{ (Length of stirrups along X) } = 2060.00$$

$$A_{stir1} \text{ (stirrups area) } = 78.53982$$

$$\text{psh2 ((5.4d), TBDY) } = L_{stir2} * A_{stir2} / (A_{sec} * s2) = 0.00067082$$

$$L_{stir2} \text{ (Length of stirrups along X) } = 1468.00$$

$$A_{stir2} \text{ (stirrups area) } = 50.26548$$

$$A_{sec} = 440000.00$$

$$s1 = 100.00$$

$$s2 = 250.00$$

$$f_{ywe1} = 781.25$$

$$f_{ywe2} = 781.25$$

$$f_{ce} = 30.00$$

$$\text{From ((5.A5), TBDY), TBDY: } \phi_c = 0.00471045$$

```

c = confinement factor = 1.27105
y1 = 0.00083886
sh1 = 0.00268436
ft1 = 314.5735
fy1 = 262.1446
su1 = 0.00268436
using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00
lo/lou,min = lb/ld = 0.13907892
su1 = 0.4*esu1_nominal ((5.5), TBDY) = 0.032
From table 5A.1, TBDY: esu1_nominal = 0.08,
For calculation of esu1_nominal and y1, sh1,ft1,fy1, it is considered
characteristic value fsy1 = fs1/1.2, from table 5.1, TBDY.
y1, sh1,ft1,fy1, are also multiplied by Min(1,1.25*(lb/ld)^ 2/3), from 10.3.5, ASCE 41-17.
with fs1 = (fs,jacket*Asl,ten,jacket + fs,core*Asl,ten,core)/Asl,ten = 262.1446
with Es1 = (Es,jacket*Asl,ten,jacket + Es,core*Asl,ten,core)/Asl,ten = 200000.00
y2 = 0.00083886
sh2 = 0.00268436
ft2 = 314.5735
fy2 = 262.1446
su2 = 0.00268436
using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00
lo/lou,min = lb/lb,min = 0.13907892
su2 = 0.4*esu2_nominal ((5.5), TBDY) = 0.032
From table 5A.1, TBDY: esu2_nominal = 0.08,
For calculation of esu2_nominal and y2, sh2,ft2,fy2, it is considered
characteristic value fsy2 = fs2/1.2, from table 5.1, TBDY.
y1, sh1,ft1,fy1, are also multiplied by Min(1,1.25*(lb/ld)^ 2/3), from 10.3.5, ASCE 41-17.
with fs2 = (fs,jacket*Asl,com,jacket + fs,core*Asl,com,core)/Asl,com = 262.1446
with Es2 = (Es,jacket*Asl,com,jacket + Es,core*Asl,com,core)/Asl,com = 200000.00
yv = 0.00083886
shv = 0.00268436
ftv = 314.5735
fyv = 262.1446
suv = 0.00268436
using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00
lo/lou,min = lb/ld = 0.13907892
suv = 0.4*esuv_nominal ((5.5), TBDY) = 0.032
From table 5A.1, TBDY: esuv_nominal = 0.08,
considering characteristic value fsyv = fsv/1.2, from table 5.1, TBDY
For calculation of esuv_nominal and yv, shv,ftv,fyv, it is considered
characteristic value fsyv = fsv/1.2, from table 5.1, TBDY.
y1, sh1,ft1,fy1, are also multiplied by Min(1,1.25*(lb/ld)^ 2/3), from 10.3.5, ASCE 41-17.
with fsv = (fs,jacket*Asl,mid,jacket + fs,mid*Asl,mid,core)/Asl,mid = 262.1446
with Esv = (Es,jacket*Asl,mid,jacket + Es,mid*Asl,mid,core)/Asl,mid = 200000.00
1 = Asl,ten/(b*d)*(fs1/fc) = 0.0187412
2 = Asl,com/(b*d)*(fs2/fc) = 0.03639521
v = Asl,mid/(b*d)*(fsv/fc) = 0.03308184
and confined core properties:
b = 690.00
d = 677.00
d' = 13.00
fcc (5A.2, TBDY) = 38.13135
cc (5A.5, TBDY) = 0.00471045
c = confinement factor = 1.27105
1 = Asl,ten/(b*d)*(fs1/fc) = 0.02127357
2 = Asl,com/(b*d)*(fs2/fc) = 0.04131304
v = Asl,mid/(b*d)*(fsv/fc) = 0.03755196
Case/Assumption: Unconfined full section - Steel rupture
'satisfies Eq. (4.3)
--->
v < vs,y2 - LHS eq.(4.5) is satisfied

```

```

--->
su (4.9) = 0.21062322
Mu = MRc (4.14) = 2.3387E+008
u = su (4.1) = 4.8099118E-006
-----

Calculation of ratio lb/ld
-----
Lap Length: lb/ld = 0.13907892
lb = 300.00
ld = 2157.049
Calculation of lb,min according to (25.4.3.2), ACI 318-14, using mean values for all the section re-bars.
ld,min from (25.4.3.2) is multiplied 2 times to account for smooth re-bars (9.1.2, TS500 - No provision in ACI 318)
= 1
db = 16.66667
Mean strength value of all re-bars: fy = 781.25
Mean concrete strength: fc' = (fc'jacket*Areajacket + fc'core*Areacore)/Areasection = 30.00, but fc'0.5 ≤ 8.3
MPa (22.5.3.1, ACI 318-14)
t = 1.00
s = 0.80
e = 1.00
cb = 25.00
Ktr = 1.7174
Atr = Min(Atr_x, Atr_y) = 257.6106
where Atr_x, Atr_y are the sum of the area of all stirrup legs along X and Y loxal axis
s = Max(sexternal, sinternal) = 250.00
n = 24.00
-----
-----
-----

Calculation of Mu2-
-----
-----

Calculation of ultimate curvature u according to 4.1, Biskinis/Fardis 2013:
u = 5.1201636E-006
Mu = 5.0296E+008
-----

with full section properties:
b = 400.00
d = 707.00
d' = 43.00
v = 0.00191815
N = 16273.608
fc = 30.00
co (5A.5, TBDY) = 0.002
Final value of cu: cu* = shear_factor * Max( cu, cc) = 0.01260361
The Shear_factor is considered equal to 1 (pure moment strength)
From (5.4b), TBDY: cu = 0.01260361
we (5.4c) = 0.05179731
ase ((5.4d), TBDY) = (ase1*Aext+ase2*Aint)/Asec = 0.45746528
ase1 = Max(((Aconf,max1-AnoConf1)/Aconf,max1)*(Aconf,min1/Aconf,max1),0) = 0.45746528
The definitions of AnoConf, Aconf,min and Aconf,max are derived from generalization
of the rectangular sections confinement, which is expressed by (5.4d).
The generalization is done according to Mander, J., Priestley, M., and Park, R. (1988)
"Theoretical Stress-Strain Model for Confined Concrete."
J. Struct. Eng., 10.1061/(ASCE)0733-9445(1988)114:8(1804), 1804-1826.
Aconf,max1 = 353600.00 is the confined core area at levels of member with hoops and
is calculated as the area of core enclosed by the center lines of the external perimeter hoops.
Aconf,min1 = 293525.00 is the confined core area at midway between the levels of hoops and
is calculated by reducing all the dimensions of the area Aconf,max1 by a length
equal to half the clear spacing between external hoops.
AnoConf1 = 158733.333 is the unconfined external core area which is equal to bi2/6 as defined at (A.2).
ase2 (>=ase1) = Max(((Aconf,max2-AnoConf2)/Aconf,max2)*(Aconf,min2/Aconf,max2),0) = 0.45746528
The definitions of AnoConf, Aconf,min and Aconf,max are derived from generalization
of the rectangular sections confinement, which is expressed by (5.4d).
The generalization is done according to Mander, J., Priestley, M., and Park, R. (1988)

```

"Theoretical Stress-Strain Model for Confined Concrete."

J. Struct. Eng., 10.1061/(ASCE)0733-9445(1988)114:8(1804), 1804-1826.

$A_{conf,max2} = 171264.00$  is the confined core area at levels of member with hoops and is calculated as the area of core enclosed by the center lines of the internal perimeter hoops.  
 $A_{conf,min2} = 54741.00$  is the confined core area at midway between the levels of hoops and is calculated by reducing all the dimensions of the area  $A_{conf,max2}$  by a length equal to half the clear spacing between internal hoops.

$A_{noConf2} = 106242.667$  is the unconfined internal core area which is equal to  $b_i^2/6$  as defined at (A.2).  
 $psh_{min} * F_{ywe} = \text{Min}(psh_x * F_{ywe}, psh_y * F_{ywe}) = 3.3968$

$psh_x * F_{ywe} = psh1 * F_{ywe1} + ps2 * F_{ywe2} = 3.3968$   
 $psh1 ((5.4d), TBDY) = L_{stir1} * A_{stir1} / (A_{sec} * s1) = 0.00367709$   
 $L_{stir1}$  (Length of stirrups along Y) = 2060.00  
 $A_{stir1}$  (stirrups area) = 78.53982  
 $psh2 (5.4d) = L_{stir2} * A_{stir2} / (A_{sec} * s2) = 0.00067082$   
 $L_{stir2}$  (Length of stirrups along Y) = 1468.00  
 $A_{stir2}$  (stirrups area) = 50.26548

$psh_y * F_{ywe} = psh1 * F_{ywe1} + ps2 * F_{ywe2} = 3.3968$   
 $psh1 ((5.4d), TBDY) = L_{stir1} * A_{stir1} / (A_{sec} * s1) = 0.00367709$   
 $L_{stir1}$  (Length of stirrups along X) = 2060.00  
 $A_{stir1}$  (stirrups area) = 78.53982  
 $psh2 ((5.4d), TBDY) = L_{stir2} * A_{stir2} / (A_{sec} * s2) = 0.00067082$   
 $L_{stir2}$  (Length of stirrups along X) = 1468.00  
 $A_{stir2}$  (stirrups area) = 50.26548

$A_{sec} = 440000.00$

$s1 = 100.00$

$s2 = 250.00$

$f_{ywe1} = 781.25$

$f_{ywe2} = 781.25$

$f_{ce} = 30.00$

From ((5.A5), TBDY), TBDY:  $cc = 0.00471045$

$c$  = confinement factor = 1.27105

$y1 = 0.00083886$

$sh1 = 0.00268436$

$ft1 = 314.5735$

$fy1 = 262.1446$

$su1 = 0.00268436$

using (30) in Biskinis/Fardis (2013) multiplied with shear\_factor and also multiplied by the shear\_factor according to 15.7.1.4, with Shear\_factor = 1.00

$lo/lou_{min} = lb/ld = 0.13907892$

$su1 = 0.4 * esu1_{nominal} ((5.5), TBDY) = 0.032$

From table 5A.1, TBDY:  $esu1_{nominal} = 0.08$ ,

For calculation of  $esu1_{nominal}$  and  $y1$ ,  $sh1$ ,  $ft1$ ,  $fy1$ , it is considered characteristic value  $fsy1 = fs1/1.2$ , from table 5.1, TBDY.

$y1$ ,  $sh1$ ,  $ft1$ ,  $fy1$ , are also multiplied by  $\text{Min}(1, 1.25 * (lb/ld)^{2/3})$ , from 10.3.5, ASCE 41-17.

with  $fs1 = (fs_{jacket} * A_{sl,ten,jacket} + fs_{core} * A_{sl,ten,core}) / A_{sl,ten} = 262.1446$

with  $Es1 = (Es_{jacket} * A_{sl,ten,jacket} + Es_{core} * A_{sl,ten,core}) / A_{sl,ten} = 200000.00$

$y2 = 0.00083886$

$sh2 = 0.00268436$

$ft2 = 314.5735$

$fy2 = 262.1446$

$su2 = 0.00268436$

using (30) in Biskinis/Fardis (2013) multiplied with shear\_factor and also multiplied by the shear\_factor according to 15.7.1.4, with Shear\_factor = 1.00

$lo/lou_{min} = lb/lb_{min} = 0.13907892$

$su2 = 0.4 * esu2_{nominal} ((5.5), TBDY) = 0.032$

From table 5A.1, TBDY:  $esu2_{nominal} = 0.08$ ,

For calculation of  $esu2_{nominal}$  and  $y2$ ,  $sh2$ ,  $ft2$ ,  $fy2$ , it is considered characteristic value  $fsy2 = fs2/1.2$ , from table 5.1, TBDY.

$y1$ ,  $sh1$ ,  $ft1$ ,  $fy1$ , are also multiplied by  $\text{Min}(1, 1.25 * (lb/ld)^{2/3})$ , from 10.3.5, ASCE 41-17.

with  $fs2 = (fs_{jacket} * A_{sl,com,jacket} + fs_{core} * A_{sl,com,core}) / A_{sl,com} = 262.1446$

with  $Es2 = (Es_{jacket} * A_{sl,com,jacket} + Es_{core} * A_{sl,com,core}) / A_{sl,com} = 200000.00$

$yv = 0.00083886$

```

shv = 0.00268436
ftv = 314.5735
fyv = 262.1446
suv = 0.00268436
    using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
    and also multiplied by the shear_factor according to 15.7.1.4, with
    Shear_factor = 1.00
    lo/lo,min = lb/ld = 0.13907892
    suv = 0.4*esuv_nominal ((5.5), TBDY) = 0.032
    From table 5A.1, TBDY: esuv_nominal = 0.08,
    considering characteristic value fsyv = fsv/1.2, from table 5.1, TBDY
    For calculation of esuv_nominal and yv, shv,ftv,fyv, it is considered
    characteristic value fsyv = fsv/1.2, from table 5.1, TBDY.
    y1, sh1,ft1,fy1, are also multiplied by Min(1,1.25*(lb/ld)^2/3), from 10.3.5, ASCE 41-17.
    with fsv = (fs,jacket*Asl,mid,jacket + fs,mid*Asl,mid,core)/Asl,mid = 262.1446
    with Esv = (Es,jacket*Asl,mid,jacket + Es,mid*Asl,mid,core)/Asl,mid = 200000.00
    1 = Asl,ten/(b*d)*(fs1/fc) = 0.06824101
    2 = Asl,com/(b*d)*(fs2/fc) = 0.03513975
    v = Asl,mid/(b*d)*(fsv/fc) = 0.06202846
and confined core properties:
b = 340.00
d = 677.00
d' = 13.00
fcc (5A.2, TBDY) = 38.13135
cc (5A.5, TBDY) = 0.00471045
    c = confinement factor = 1.27105
    1 = Asl,ten/(b*d)*(fs1/fc) = 0.08384116
    2 = Asl,com/(b*d)*(fs2/fc) = 0.04317283
    v = Asl,mid/(b*d)*(fsv/fc) = 0.07620839
Case/Assumption: Unconfined full section - Steel rupture
' satisfies Eq. (4.3)
--->
v < vs,y2 - LHS eq.(4.5) is satisfied
--->
su (4.9) = 0.2584548
Mu = MRc (4.14) = 5.0296E+008
u = su (4.1) = 5.1201636E-006
-----

Calculation of ratio lb/ld
-----
Lap Length: lb/ld = 0.13907892
lb = 300.00
ld = 2157.049
Calculation of lb,min according to (25.4.3.2), ACI 318-14, using mean values for all the section re-bars.
ld,min from (25.4.3.2) is multiplied 2 times to account for smooth re-bars (9.1.2, TS500 - No provision in ACI 318)
= 1
db = 16.66667
Mean strength value of all re-bars: fy = 781.25
Mean concrete strength: fc' = (fc'_jacket*Area_jacket + fc'_core*Area_core)/Area_section = 30.00, but fc'^0.5 <= 8.3
MPa (22.5.3.1, ACI 318-14)
t = 1.00
s = 0.80
e = 1.00
cb = 25.00
Ktr = 1.7174
Atr = Min(Atr_x,Atr_y) = 257.6106
where Atr_x, Atr_y are the sum of the area of all stirrup legs along X and Y loxal axis
s = Max(s_external,s_internal) = 250.00
n = 24.00
-----
-----
-----
Calculation of Shear Strength Vr = Min(Vr1,Vr2) = 1.0392E+006
-----
Calculation of Shear Strength at edge 1, Vr1 = 1.0392E+006

```

$Vr1 = VCol \text{ ((10.3), ASCE 41-17)} = knl * VCol0$

$VCol0 = 1.0392E+006$

$knl = 1$  (zero step-static loading)

NOTE: In expression (10-3) ' $V_s = A_v * f_y * d / s$ ' is replaced by ' $V_s + f * V_f$ ' where  $V_f$  is the contribution of FRPs (11.3), ACI 440).

$= 1$  (normal-weight concrete)

Mean concrete strength:  $f_c' = (f_c'_{jacket} * Area_{jacket} + f_c'_{core} * Area_{core}) / Area_{section} = 30.00$ , but  $f_c'^{0.5} \leq 8.3$  MPa (22.5.3.1, ACI 318-14)

$M/Vd = 4.00$

$\mu_u = 1308.675$

$V_u = 0.0001715$

$d = 0.8 * h = 600.00$

$N_u = 16273.608$

$A_g = 300000.00$

From (11.5.4.8), ACI 318-14:  $V_s = V_{s,jacket} + V_{s,core} = 1.0138E+006$

where:

$V_{s,jacket} = V_{s,j1} + V_{s,j2} = 903207.888$

$V_{s,j1} = 314159.265$  is calculated for section web jacket, with:

$d = 320.00$

$A_v = 157079.633$

$f_y = 625.00$

$s = 100.00$

$V_{s,j1}$  is multiplied by  $Col,j1 = 1.00$

$s/d = 0.3125$

$V_{s,j2} = 589048.623$  is calculated for section flange jacket, with:

$d = 600.00$

$A_v = 157079.633$

$f_y = 625.00$

$s = 100.00$

$V_{s,j2}$  is multiplied by  $Col,j2 = 1.00$

$s/d = 0.16666667$

$V_{s,core} = V_{s,c1} + V_{s,c2} = 110584.061$

$V_{s,c1} = 0.00$  is calculated for section web core, with:

$d = 160.00$

$A_v = 100530.965$

$f_y = 625.00$

$s = 250.00$

$V_{s,c1}$  is multiplied by  $Col,c1 = 0.00$

$s/d = 1.5625$

$V_{s,c2} = 110584.061$  is calculated for section flange core, with:

$d = 440.00$

$A_v = 100530.965$

$f_y = 625.00$

$s = 250.00$

$V_{s,c2}$  is multiplied by  $Col,c2 = 1.00$

$s/d = 0.56818182$

$V_f \text{ ((11-3)-(11.4), ACI 440)} = 0.00$

From (11-11), ACI 440:  $V_s + V_f \leq 873250.061$

$bw = 400.00$

Calculation of Shear Strength at edge 2,  $Vr2 = 1.0392E+006$

$Vr2 = VCol \text{ ((10.3), ASCE 41-17)} = knl * VCol0$

$VCol0 = 1.0392E+006$

$knl = 1$  (zero step-static loading)

NOTE: In expression (10-3) ' $V_s = A_v * f_y * d / s$ ' is replaced by ' $V_s + f * V_f$ ' where  $V_f$  is the contribution of FRPs (11.3), ACI 440).

$= 1$  (normal-weight concrete)

Mean concrete strength:  $f_c' = (f_c'_{jacket} * Area_{jacket} + f_c'_{core} * Area_{core}) / Area_{section} = 30.00$ , but  $f_c'^{0.5} \leq 8.3$  MPa (22.5.3.1, ACI 318-14)

$M/Vd = 4.00$

$\mu_u = 1308.675$

$V_u = 0.0001715$



$d = 0.8 \cdot h = 600.00$   
 $Nu = 16273.608$   
 $Ag = 300000.00$   
 From (11.5.4.8), ACI 318-14:  $V_s = V_{s,jacket} + V_{s,core} = 1.0138E+006$   
 where:  
 $V_{s,jacket} = V_{s,j1} + V_{s,j2} = 903207.888$   
 $V_{s,j1} = 314159.265$  is calculated for section web jacket, with:  
 $d = 320.00$   
 $A_v = 157079.633$   
 $f_y = 625.00$   
 $s = 100.00$   
 $V_{s,j1}$  is multiplied by  $Col,j1 = 1.00$   
 $s/d = 0.3125$   
 $V_{s,j2} = 589048.623$  is calculated for section flange jacket, with:  
 $d = 600.00$   
 $A_v = 157079.633$   
 $f_y = 625.00$   
 $s = 100.00$   
 $V_{s,j2}$  is multiplied by  $Col,j2 = 1.00$   
 $s/d = 0.16666667$   
 $V_{s,core} = V_{s,c1} + V_{s,c2} = 110584.061$   
 $V_{s,c1} = 0.00$  is calculated for section web core, with:  
 $d = 160.00$   
 $A_v = 100530.965$   
 $f_y = 625.00$   
 $s = 250.00$   
 $V_{s,c1}$  is multiplied by  $Col,c1 = 0.00$   
 $s/d = 1.5625$   
 $V_{s,c2} = 110584.061$  is calculated for section flange core, with:  
 $d = 440.00$   
 $A_v = 100530.965$   
 $f_y = 625.00$   
 $s = 250.00$   
 $V_{s,c2}$  is multiplied by  $Col,c2 = 1.00$   
 $s/d = 0.56818182$   
 $V_f ((11-3)-(11.4), ACI 440) = 0.00$   
 From (11-11), ACI 440:  $V_s + V_f \leq 873250.061$   
 $bw = 400.00$

-----  
 End Of Calculation of Shear Capacity ratio for element: column JLC1 of floor 1  
 At local axis: 2  
 -----

-----  
 Start Of Calculation of Chord Rotation Capacity for element: column JLC1 of floor 1  
 At local axis: 3  
 Integration Section: (b)  
 Section Type: rcjlc

Constant Properties

-----  
 Knowledge Factor,  $\phi = 1.00$   
 Chord Rotation is generally considered as Deformation-Controlled Action according to Table C7-1, ASCE 41-17.  
 Mean strengths are used for Deformation-Controlled Actions according to 7.5.1.3, ASCE 41-17  
 Consequently:  
 Jacket  
 New material of Primary Member: Concrete Strength,  $f_c = f_{cm} = 30.00$   
 New material of Primary Member: Steel Strength,  $f_s = f_{sm} = 625.00$   
 Concrete Elasticity,  $E_c = 25742.96$   
 Steel Elasticity,  $E_s = 200000.00$   
 Existing Column  
 New material of Primary Member: Concrete Strength,  $f_c = f_{cm} = 30.00$   
 New material of Primary Member: Steel Strength,  $f_s = f_{sm} = 625.00$   
 Concrete Elasticity,  $E_c = 25742.96$   
 Steel Elasticity,  $E_s = 200000.00$

Max Height, Hmax = 750.00  
 Min Height, Hmin = 400.00  
 Max Width, Wmax = 750.00  
 Min Width, Wmin = 400.00  
 Jacket Thickness, tj = 100.00  
 Cover Thickness, c = 25.00  
 Element Length, L = 3000.00  
 Primary Member  
 Smooth Bars  
 Ductile Steel  
 With Detailing for Earthquake Resistance (including stirrups closed at 135°)  
 Longitudinal Bars With Ends Lapped Starting at the End Sections  
 Lap Length lb = 300.00  
 No FRP Wrapping

#### Stepwise Properties

Bending Moment, M = 186273.79  
 Shear Force, V2 = 4846.489  
 Shear Force, V3 = -135.9404  
 Axial Force, F = -17232.621  
 Longitudinal Reinforcement Area Distribution (in 2 divisions)  
   -Tension: Aslt = 0.00  
   -Compression: Aslc = 5353.274  
 Longitudinal Reinforcement Area Distribution (in 3 divisions)  
   -Tension: Asl,ten = 1137.257  
   -Compression: Asl,com = 2208.54  
   -Middle: Asl,mid = 2007.478  
 Longitudinal External Reinforcement Area Distribution (in 3 divisions)  
   -Tension: Asl,ten,jacket = 829.3805  
   -Compression: Asl,com,jacket = 1746.726  
   -Middle: Asl,mid,jacket = 1545.664  
 Longitudinal Internal Reinforcement Area Distribution (in 3 divisions)  
   -Tension: Asl,ten,core = 307.8761  
   -Compression: Asl,com,core = 461.8141  
   -Middle: Asl,mid,core = 461.8141  
 Mean Diameter of Tension Reinforcement, DbL = 16.80

New component: From table 7-7, ASCE 41\_17: Final chord rotation Capacity  $u_R = 1.0^*$   $u = 0.00019707$   
 $u = y + p = 0.00019707$

- Calculation of  $y$  -

$y = (M_y * L_s / 3) / E_{eff} = 0.00019707$  ((4.29), Biskinis Phd))  
 $M_y = 2.8693E+008$   
 $L_s = M/V$  (with  $L_s > 0.1 * L$  and  $L_s < 2 * L$ ) = 300.00  
 From table 10.5, ASCE 41\_17:  $E_{eff} = factor * E_c * I_g = 1.4560E+014$   
 $factor = 0.30$   
 $A_g = 440000.00$   
 Mean concrete strength:  $f'_c = (f'_{c,jacket} * Area_{jacket} + f'_{c,core} * Area_{core}) / Area_{section} = 30.00$   
 $N = 17232.621$   
 $E_c * I_g = E_{c,jacket} * I_{g,jacket} + E_{c,core} * I_{g,core} = 4.8532E+014$

Calculation of Yielding Moment  $M_y$

Calculation of  $y$  and  $M_y$  according to Annex 7 -

Assuming neutral axis within flange ( $y < t/d$ , compression zone rectangular) with:  
 flange width, b = 750.00  
 web width, bw = 400.00

flange thickness,  $t = 400.00$

$y = \text{Min}(y_{\text{ten}}, y_{\text{com}})$

$y_{\text{ten}} = 2.1452649\text{E}-006$

with  $((10.1), \text{ASCE } 41-17) f_y = \text{Min}(f_y, 1.25 \cdot f_y \cdot (l_b/d)^{2/3}) = 243.3535$

$d = 707.00$

$y = 0.1977546$

$A = 0.0102293$

$B = 0.00453971$

with  $p_t = 0.00434791$

$p_c = 0.00416509$

$p_v = 0.00378591$

$N = 17232.621$

$b = 750.00$

$" = 0.06082037$

$y_{\text{comp}} = 1.5203329\text{E}-005$

with  $f_c = 30.00$

$E_c = 25742.96$

$y = 0.19515388$

$A = 0.01001829$

$B = 0.00440616$

with  $E_s = 200000.00$

CONFIRMATION:  $y = 0.19591085 < t/d$

Calculation of ratio  $l_b/d$

Lap Length:  $l_d/l_{d,\text{min}} = 0.17384865$

$l_b = 300.00$

$l_d = 1725.639$

Calculation of  $l$  according to (25.4.3.2), ACI 318-14, using mean values for all the section re-bars.

$l_{d,\text{min}}$  from (25.4.3.2) is multiplied 2 times to account for smooth re-bars (10.3.5, ASCE 41-17)

$= 1$

$db = 16.66667$

Mean strength value of all re-bars:  $f_y = 625.00$

Mean concrete strength:  $f'_c = (f'_c_{\text{jacket}} \cdot \text{Area}_{\text{jacket}} + f'_c_{\text{core}} \cdot \text{Area}_{\text{core}}) / \text{Area}_{\text{section}} = 30.00$ , but  $f'_c^{0.5} \leq 8.3$  MPa (22.5.3.1, ACI 318-14)

$t = 1.00$

$s = 0.80$

$e = 1.00$

$cb = 25.00$

$K_{tr} = 1.7174$

$A_{tr} = \text{Min}(A_{tr_x}, A_{tr_y}) = 257.6106$

where  $A_{tr_x}$ ,  $A_{tr_y}$  are the sum of the area of all stirrup legs along X and Y local axis

$s = \text{Max}(s_{\text{external}}, s_{\text{internal}}) = 250.00$

$n = 24.00$

- Calculation of  $p$  -

From table 10-8:  $p = 0.00$

with:

- Columns controlled by inadequate development or splicing along the clear height because  $l_b/d < 1$

shear control ratio  $V_y E / V_{co} I_E = 0.32266369$

$d = d_{\text{external}} = 707.00$

$s = s_{\text{external}} = 0.00$

-  $t = s_1 + s_2 + 2 \cdot t_f / b_w \cdot (f_{fe} / f_s) = 0.00434791$

jacket:  $s_1 = A_{v1} \cdot L_{\text{stir1}} / (s_1 \cdot A_g) = 0.00367709$

$A_{v1} = 78.53982$ , is the area of every stirrup parallel to loading (shear) direction

$L_{\text{stir1}} = 2060.00$ , is the total Length of all stirrups parallel to loading (shear) direction

$s_1 = 100.00$

core:  $s_2 = A_{v2} \cdot L_{\text{stir2}} / (s_2 \cdot A_g) = 0.00067082$

$A_{v2} = 50.26548$ , is the area of every stirrup parallel to loading (shear) direction

$L_{\text{stir2}} = 1468.00$ , is the total Length of all stirrups parallel to loading (shear) direction

$s_2 = 250.00$

The term  $2 \cdot t_f / b_w \cdot (f_{fe} / f_s)$  is implemented to account for FRP contribution

where  $f = 2 \cdot t_f / b_w$  is FRP ratio (EC8 - 3, A.4.4.3(6)) and  $f_{fe}/f_s$  normalises  $f$  to steel strength

All these variables have already been given in Shear control ratio calculation.

For the normalisation  $f_s$  of jacket is used.

$$N_{UD} = 17232.621$$

$$A_g = 440000.00$$

$$f_{cE} = (f_{c\_jacket} \cdot Area\_jacket + f_{c\_core} \cdot Area\_core) / section\_area = 30.00$$

$$f_{yIE} = (f_{y\_ext\_Long\_Reinf} \cdot Area\_ext\_Long\_Reinf + f_{y\_int\_Long\_Reinf} \cdot Area\_int\_Long\_Reinf) / Area\_Tot\_Long\_Rein = 625.00$$

$$f_{yIE} = (f_{y\_ext\_Trans\_Reinf} \cdot s_1 + f_{y\_int\_Trans\_Reinf} \cdot s_2) / (s_1 + s_2) = 625.00$$

$$\rho_l = Area\_Tot\_Long\_Rein / (b \cdot d) = 0.01009575$$

$$b = 750.00$$

$$d = 707.00$$

$$f_{cE} = 30.00$$

End Of Calculation of Chord Rotation Capacity for element: column JLC1 of floor 1

At local axis: 3

Integration Section: (b)

## Calculation No. 9

column C1, Floor 1



Limit State: Collapse Prevention (data interpolation between analysis steps 1 and 2)

Analysis: Uniform +X

Check: Shear capacity  $V_{Rd}$

Edge: Start

Local Axis: (2)



Start Of Calculation of Shear Capacity for element: column JLC1 of floor 1

At local axis: 2

Integration Section: (a)

Section Type: rcjlc

Constant Properties

```

Knowledge Factor,  $\gamma = 1.00$ 
Member Shear Force is generally considered as Force-Controlled Action according to Table C7-1, ASCE 41-17.
Lower-bound strengths are used for Force-Controlled Actions according to 7.5.1.3, ASCE 41-17
Consequently:
Jacket
New material of Primary Member: Concrete Strength,  $f_c = f_{c\_lower\_bound} = 20.00$ 
New material of Primary Member: Steel Strength,  $f_s = f_{s\_lower\_bound} = 500.00$ 
Concrete Elasticity,  $E_c = 25742.96$ 
Steel Elasticity,  $E_s = 200000.00$ 
Existing Column
New material of Primary Member: Concrete Strength,  $f_c = f_{c\_lower\_bound} = 20.00$ 
New material of Primary Member: Steel Strength,  $f_s = f_{s\_lower\_bound} = 500.00$ 
Concrete Elasticity,  $E_c = 25742.96$ 
Steel Elasticity,  $E_s = 200000.00$ 
#####
Note: Especially for the calculation of  $\gamma$  for displacement ductility demand,
the expected (mean value) strengths are used (7.5.1.3, ASCE 41-17) because bending is considered as
Deformation-Controlled Action (Table C7-1, ASCE 41-17).
Jacket
New material: Concrete Strength,  $f_c = f_{cm} = 30.00$ 
New material: Steel Strength,  $f_s = f_{sm} = 625.00$ 
Existing Column
New material: Concrete Strength,  $f_c = f_{cm} = 30.00$ 
New material: Steel Strength,  $f_s = f_{sm} = 625.00$ 
#####
Max Height,  $H_{max} = 750.00$ 
Min Height,  $H_{min} = 400.00$ 
Max Width,  $W_{max} = 750.00$ 
Min Width,  $W_{min} = 400.00$ 
Jacket Thickness,  $t_j = 100.00$ 
Cover Thickness,  $c = 25.00$ 
Element Length,  $L = 3000.00$ 
Primary Member
Smooth Bars
Ductile Steel
With Detailing for Earthquake Resistance (including stirrups closed at 135°)
Longitudinal Bars With Ends Lapped Starting at the End Sections
Lap Length  $l_o = l_b = 300.00$ 
No FRP Wrapping
-----

Stepwise Properties
-----
EDGE -A-
Bending Moment,  $M_a = -2.3128E+007$ 
Shear Force,  $V_a = -7609.421$ 
EDGE -B-
Bending Moment,  $M_b = 293212.583$ 
Shear Force,  $V_b = 7609.421$ 
BOTH EDGES
Axial Force,  $F = -17779.344$ 
Longitudinal Reinforcement Area Distribution (in 2 divisions)
-Tension:  $A_{slt} = 0.00$ 
-Compression:  $A_{slc} = 5353.274$ 
Longitudinal Reinforcement Area Distribution (in 3 divisions)
-Tension:  $A_{sl,ten} = 1137.257$ 
-Compression:  $A_{sl,com} = 2208.54$ 
-Middle:  $A_{sl,mid} = 2007.478$ 
Mean Diameter of Tension Reinforcement,  $Db_{L,ten} = 16.80$ 
-----
-----

New component: From table 7-7, ASCE 41_17: Final Shear Capacity  $V_R = 1.0 * V_n = 848936.076$ 
 $V_n$  ((10.3), ASCE 41-17) =  $k_n * V_{CoIO} = 848936.076$ 
 $V_{CoI} = 848936.076$ 
 $k_n = 1.00$ 

```

displacement\_ductility\_demand = 0.04334623

NOTE: In expression (10-3) ' $V_s = A_v \cdot f_y \cdot d / s$ ' is replaced by ' $V_s + f \cdot V_f$ ' where  $V_f$  is the contribution of FRPs (11.3), ACI 440).

= 1 (normal-weight concrete)

Mean concrete strength:  $f_c' = (f_c'_{\text{jacket}} \cdot \text{Area}_{\text{jacket}} + f_c'_{\text{core}} \cdot \text{Area}_{\text{core}}) / \text{Area}_{\text{section}} = 20.00$ , but  $f_c'^{0.5} \leq 8.3$  MPa (22.5.3.1, ACI 318-14)

$M/Vd = 4.00$

$\mu_u = 2.3128 \times 10^7$

$V_u = 7609.421$

$d = 0.8 \cdot h = 600.00$

$N_u = 17779.344$

$A_g = 300000.00$

From (11.5.4.8), ACI 318-14:  $V_s = V_{s,\text{jacket}} + V_{s,\text{core}} = 811033.559$

where:

$V_{s,\text{jacket}} = V_{s,j1} + V_{s,j2} = 722566.31$

$V_{s,j1} = 251327.412$  is calculated for section web jacket, with:

$d = 320.00$

$A_v = 157079.633$

$f_y = 500.00$

$s = 100.00$

$V_{s,j1}$  is multiplied by  $\text{Col},j1 = 1.00$

$s/d = 0.3125$

$V_{s,j2} = 471238.898$  is calculated for section flange jacket, with:

$d = 600.00$

$A_v = 157079.633$

$f_y = 500.00$

$s = 100.00$

$V_{s,j2}$  is multiplied by  $\text{Col},j2 = 1.00$

$s/d = 0.16666667$

$V_{s,\text{core}} = V_{s,c1} + V_{s,c2} = 88467.249$

$V_{s,c1} = 0.00$  is calculated for section web core, with:

$d = 160.00$

$A_v = 100530.965$

$f_y = 500.00$

$s = 250.00$

$V_{s,c1}$  is multiplied by  $\text{Col},c1 = 0.00$

$s/d = 1.5625$

$V_{s,c2} = 88467.249$  is calculated for section flange core, with:

$d = 440.00$

$A_v = 100530.965$

$f_y = 500.00$

$s = 250.00$

$V_{s,c2}$  is multiplied by  $\text{Col},c2 = 1.00$

$s/d = 0.56818182$

$V_f$  ((11-3)-(11.4), ACI 440) = 0.00

From (11-11), ACI 440:  $V_s + V_f \leq 713005.69$

$b_w = 400.00$

displacement\_ductility\_demand is calculated as  $\phi / y$

- Calculation of  $\phi / y$  for END A -  
for rotation axis 3 and integ. section (a)

From analysis, chord rotation  $\phi = 8.6592743 \times 10^{-5}$

$y = (M_y \cdot L_s / 3) / \text{Eleff} = 0.0019977$  ((4.29), Biskinis Phd)

$M_y = 2.8709 \times 10^8$

$L_s = M/V$  (with  $L_s > 0.1 \cdot L$  and  $L_s < 2 \cdot L$ ) = 3039.351

From table 10.5, ASCE 41\_17:  $\text{Eleff} = \text{factor} \cdot E_c \cdot I_g = 1.4560 \times 10^{14}$

factor = 0.30

$A_g = 440000.00$

Mean concrete strength:  $f_c' = (f_c'_{\text{jacket}} \cdot \text{Area}_{\text{jacket}} + f_c'_{\text{core}} \cdot \text{Area}_{\text{core}}) / \text{Area}_{\text{section}} = 30.00$

$N = 17779.344$

$E_c \cdot I_g = E_{c,\text{jacket}} \cdot I_{g,\text{jacket}} + E_{c,\text{core}} \cdot I_{g,\text{core}} = 4.8532 \times 10^{14}$

Calculation of Yielding Moment  $M_y$

Calculation of  $y$  and  $M_y$  according to Annex 7 -

Assuming neutral axis within flange ( $y < t/d$ , compression zone rectangular) with:

flange width,  $b = 750.00$

web width,  $b_w = 400.00$

flange thickness,  $t = 400.00$

$y = \text{Min}(y_{\text{ten}}, y_{\text{com}})$

$y_{\text{ten}} = 2.1455196\text{E-}006$

with ((10.1), ASCE 41-17)  $f_y = \text{Min}(f_y, 1.25*f_y*(l_b/d)^{2/3}) = 243.3535$

$d = 707.00$

$y = 0.19784983$

$A = 0.01023354$

$B = 0.00454395$

with  $p_t = 0.00214476$

$p_c = 0.00416509$

$p_v = 0.00378591$

$N = 17779.344$

$b = 750.00$

" = 0.06082037

$y_{\text{comp}} = 1.5202265\text{E-}005$

with  $f_c = 30.00$

$E_c = 25742.96$

$y = 0.19516753$

$A = 0.01001583$

$B = 0.00440616$

with  $E_s = 200000.00$

CONFIRMATION:  $y = 0.19594836 < t/d$

Calculation of ratio  $l_b/d$

Lap Length:  $l_d/l_{d,\text{min}} = 0.17384865$

$l_b = 300.00$

$l_d = 1725.639$

Calculation of  $l$  according to (25.4.3.2), ACI 318-14, using mean values for all the section re-bars.

$l_{d,\text{min}}$  from (25.4.3.2) is multiplied 2 times to account for smooth re-bars (10.3.5, ASCE 41-17)

= 1

$d_b = 16.66667$

Mean strength value of all re-bars:  $f_y = 625.00$

Mean concrete strength:  $f'_c = (f'_{c,\text{jacket}}*Area_{\text{jacket}} + f'_{c,\text{core}}*Area_{\text{core}})/Area_{\text{section}} = 30.00$ , but  $f_c^{0.5} \leq 8.3$

MPa (22.5.3.1, ACI 318-14)

$t = 1.00$

$s = 0.80$

$e = 1.00$

$c_b = 25.00$

$K_{tr} = 1.7174$

$A_{tr} = \text{Min}(A_{tr_x}, A_{tr_y}) = 257.6106$

where  $A_{tr_x}$ ,  $A_{tr_y}$  are the sum of the area of all stirrup legs along X and Y local axis

$s = \text{Max}(s_{\text{external}}, s_{\text{internal}}) = 250.00$

$n = 24.00$

End Of Calculation of Shear Capacity for element: column JLC1 of floor 1

At local axis: 2

Integration Section: (a)

## Calculation No. 10

column C1, Floor 1


Limit State: Collapse Prevention (data interpolation between analysis steps 1 and 2)

Analysis: Uniform +X

Check: Chord rotation capacity (  $\phi$  )

Edge: Start

Local Axis: (2)



Start Of Calculation of Shear Capacity ratio for element: column JLC1 of floor 1

At Shear local axis: 3

(Bending local axis: 2)

Section Type: rcjlcs

Constant Properties

Knowledge Factor,  $\gamma = 1.00$

Mean strength values are used for both shear and moment calculations.

Consequently:

Jacket

New material of Primary Member: Concrete Strength,  $f_c = f_{cm} = 30.00$

New material of Primary Member: Steel Strength,  $f_s = f_{sm} = 625.00$

Concrete Elasticity,  $E_c = 25742.96$

Steel Elasticity,  $E_s = 200000.00$

Existing Column

New material of Primary Member: Concrete Strength,  $f_c = f_{cm} = 30.00$

New material of Primary Member: Steel Strength,  $f_s = f_{sm} = 625.00$

Concrete Elasticity,  $E_c = 25742.96$

Steel Elasticity,  $E_s = 200000.00$

#####

Note: Especially for the calculation of moment strengths,

the above steel re-bar strengths are multiplied by 1.25 according to R18.6.5, ACI 318-14

Jacket

New material: Steel Strength,  $f_s = 1.25 \cdot f_{sm} = 781.25$

Existing Column

New material: Steel Strength,  $f_s = 1.25 \cdot f_{sm} = 781.25$

#####

Max Height,  $H_{max} = 750.00$

Min Height,  $H_{min} = 400.00$

Max Width,  $W_{max} = 750.00$

Min Width,  $W_{min} = 400.00$



Jacket Thickness,  $t_j = 100.00$   
 Cover Thickness,  $c = 25.00$   
 Mean Confinement Factor overall section = 1.27105  
 Element Length,  $L = 3000.00$   
 Primary Member  
 Smooth Bars  
 Ductile Steel  
 With Detailing for Earthquake Resistance (including stirrups closed at  $135^\circ$ )  
 Longitudinal Bars With Ends Lapped Starting at the End Sections  
 Lap Length  $l_o = 300.00$   
 No FRP Wrapping

#### Stepwise Properties

At local axis: 3  
 EDGE -A-  
 Shear Force,  $V_a = -0.00017144$   
 EDGE -B-  
 Shear Force,  $V_b = 0.00017144$   
 BOTH EDGES  
 Axial Force,  $F = -16273.608$   
 Longitudinal Reinforcement Area Distribution (in 2 divisions)  
   -Tension:  $As_t = 0.00$   
   -Compression:  $As_c = 5353.274$   
 Longitudinal Reinforcement Area Distribution (in 3 divisions)  
   -Tension:  $As_{t,ten} = 1137.257$   
   -Compression:  $As_{c,com} = 2208.54$   
   -Middle:  $As_{mid} = 2007.478$

Calculation of Shear Capacity ratio,  $V_e/V_r = 0.32266369$   
 Member Controlled by Flexure ( $V_e/V_r < 1$ )  
 Calculation of Shear Demand from fig. R18.6.5, ACI 318-14  $V_e = (M_{pr1} + M_{pr2})/l_n = 335307.657$   
 with  
 $M_{pr1} = \text{Max}(\mu_{u1+}, \mu_{u1-}) = 5.0296\text{E}+008$   
 $\mu_{u1+} = 2.3387\text{E}+008$ , is the ultimate moment strength at the edge 1 of the member in the actual moment direction which is defined for the static loading combination  
 $\mu_{u1-} = 5.0296\text{E}+008$ , is the ultimate moment strength at the edge 1 of the member in the opposite moment direction which is defined for the static loading combination  
 $M_{pr2} = \text{Max}(\mu_{u2+}, \mu_{u2-}) = 5.0296\text{E}+008$   
 $\mu_{u2+} = 2.3387\text{E}+008$ , is the ultimate moment strength at the edge 2 of the member in the actual moment direction which is defined for the static loading combination  
 $\mu_{u2-} = 5.0296\text{E}+008$ , is the ultimate moment strength at the edge 2 of the member in the opposite moment direction which is defined for the static loading combination

#### Calculation of $\mu_{u1+}$

Calculation of ultimate curvature  $\phi_u$  according to 4.1, Biskinis/Fardis 2013:  
 $\phi_u = 4.8099118\text{E}-006$   
 $\mu_u = 2.3387\text{E}+008$

with full section properties:

$b = 750.00$   
 $d = 707.00$   
 $d' = 43.00$   
 $v = 0.00102301$   
 $N = 16273.608$   
 $f_c = 30.00$   
 $\phi_{co} \text{ (5A.5, TBDY)} = 0.002$   
 Final value of  $\phi_u$ :  $\phi_u^* = \text{shear\_factor} * \text{Max}(\phi_{cu}, \phi_{cc}) = 0.01260361$   
 The Shear\_factor is considered equal to 1 (pure moment strength)

From (5.4b), TBDY:  $c_u = 0.01260361$

$w_e$  (5.4c) = 0.05179731

$a_{se}$  ((5.4d), TBDY) =  $(a_{se1} \cdot A_{ext} + a_{se2} \cdot A_{int}) / A_{sec} = 0.45746528$

$a_{se1} = \text{Max}(((A_{conf,max1} - A_{noConf1}) / A_{conf,max1}) \cdot (A_{conf,min1} / A_{conf,max1}), 0) = 0.45746528$

The definitions of  $A_{noConf}$ ,  $A_{conf,min}$  and  $A_{conf,max}$  are derived from generalization of the rectangular sections confinement, which is expressed by (5.4d).

The generalization is done according to Mander, J., Priestley, M., and Park, R. (1988)

"Theoretical Stress-Strain Model for Confined Concrete."

J. Struct. Eng., 10.1061/(ASCE)0733-9445(1988)114:8(1804), 1804-1826.

$A_{conf,max1} = 353600.00$  is the confined core area at levels of member with hoops and

is calculated as the area of core enclosed by the center lines of the external perimeter hoops.

$A_{conf,min1} = 293525.00$  is the confined core area at midway between the levels of hoops and

is calculated by reducing all the dimensions of the area  $A_{conf,max1}$  by a length equal to half the clear spacing between external hoops.

$A_{noConf1} = 158733.333$  is the unconfined external core area which is equal to  $b_i^2/6$  as defined at (A.2).

$a_{se2} (>= a_{se1}) = \text{Max}(((A_{conf,max2} - A_{noConf2}) / A_{conf,max2}) \cdot (A_{conf,min2} / A_{conf,max2}), 0) = 0.45746528$

The definitions of  $A_{noConf}$ ,  $A_{conf,min}$  and  $A_{conf,max}$  are derived from generalization of the rectangular sections confinement, which is expressed by (5.4d).

The generalization is done according to Mander, J., Priestley, M., and Park, R. (1988)

"Theoretical Stress-Strain Model for Confined Concrete."

J. Struct. Eng., 10.1061/(ASCE)0733-9445(1988)114:8(1804), 1804-1826.

$A_{conf,max2} = 171264.00$  is the confined core area at levels of member with hoops and

is calculated as the area of core enclosed by the center lines of the internal perimeter hoops.

$A_{conf,min2} = 54741.00$  is the confined core area at midway between the levels of hoops and

is calculated by reducing all the dimensions of the area  $A_{conf,max2}$  by a length equal to half the clear spacing between internal hoops.

$A_{noConf2} = 106242.667$  is the unconfined internal core area which is equal to  $b_i^2/6$  as defined at (A.2).

$p_{sh,min} \cdot F_{ywe} = \text{Min}(p_{sh,x} \cdot F_{ywe}, p_{sh,y} \cdot F_{ywe}) = 3.3968$

$p_{sh,x} \cdot F_{ywe} = p_{sh1} \cdot F_{ywe1} + p_{s2} \cdot F_{ywe2} = 3.3968$

$p_{sh1}$  ((5.4d), TBDY) =  $L_{stir1} \cdot A_{stir1} / (A_{sec} \cdot s_1) = 0.00367709$

$L_{stir1}$  (Length of stirrups along Y) = 2060.00

$A_{stir1}$  (stirrups area) = 78.53982

$p_{sh2}$  (5.4d) =  $L_{stir2} \cdot A_{stir2} / (A_{sec} \cdot s_2) = 0.00067082$

$L_{stir2}$  (Length of stirrups along Y) = 1468.00

$A_{stir2}$  (stirrups area) = 50.26548

$p_{sh,y} \cdot F_{ywe} = p_{sh1} \cdot F_{ywe1} + p_{s2} \cdot F_{ywe2} = 3.3968$

$p_{sh1}$  ((5.4d), TBDY) =  $L_{stir1} \cdot A_{stir1} / (A_{sec} \cdot s_1) = 0.00367709$

$L_{stir1}$  (Length of stirrups along X) = 2060.00

$A_{stir1}$  (stirrups area) = 78.53982

$p_{sh2}$  ((5.4d), TBDY) =  $L_{stir2} \cdot A_{stir2} / (A_{sec} \cdot s_2) = 0.00067082$

$L_{stir2}$  (Length of stirrups along X) = 1468.00

$A_{stir2}$  (stirrups area) = 50.26548

$A_{sec} = 440000.00$

$s_1 = 100.00$

$s_2 = 250.00$

$f_{ywe1} = 781.25$

$f_{ywe2} = 781.25$

$f_{ce} = 30.00$

From ((5.A5), TBDY), TBDY:  $c_c = 0.00471045$

$c$  = confinement factor = 1.27105

$y_1 = 0.00083886$

$sh_1 = 0.00268436$

$ft_1 = 314.5735$

$fy_1 = 262.1446$

$su_1 = 0.00268436$

using (30) in Biskinis/Fardis (2013) multiplied with shear\_factor

and also multiplied by the shear\_factor according to 15.7.1.4, with

Shear\_factor = 1.00

$l_o/l_{ou,min} = l_b/l_d = 0.13907892$

$su_1 = 0.4 \cdot esu_{1,nominal}$  ((5.5), TBDY) = 0.032

From table 5A.1, TBDY:  $esu_{1,nominal} = 0.08$ ,

For calculation of  $esu_{1,nominal}$  and  $y_1$ ,  $sh_1$ ,  $ft_1$ ,  $fy_1$ , it is considered characteristic value  $fsy_1 = f_{s1}/1.2$ , from table 5.1, TBDY.

$y_1$ ,  $sh_1$ ,  $ft_1$ ,  $fy_1$ , are also multiplied by  $\text{Min}(1, 1.25 \cdot (l_b/l_d)^{2/3})$ , from 10.3.5, ASCE 41-17.

```

with fs1 = (fs,jacket*Asl,ten,jacket + fs,core*Asl,ten,core)/Asl,ten = 262.1446
with Es1 = (Es,jacket*Asl,ten,jacket + Es,core*Asl,ten,core)/Asl,ten = 200000.00
y2 = 0.00083886
sh2 = 0.00268436
ft2 = 314.5735
fy2 = 262.1446
su2 = 0.00268436
using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00
lo/lou,min = lb/lb,min = 0.13907892
su2 = 0.4*esu2_nominal ((5.5), TBDY) = 0.032
From table 5A.1, TBDY: esu2_nominal = 0.08,
For calculation of esu2_nominal and y2, sh2,ft2,fy2, it is considered
characteristic value fsy2 = fs2/1.2, from table 5.1, TBDY.
y1, sh1,ft1,fy1, are also multiplied by Min(1,1.25*(lb/lb,min)^2/3), from 10.3.5, ASCE 41-17.
with fs2 = (fs,jacket*Asl,com,jacket + fs,core*Asl,com,core)/Asl,com = 262.1446
with Es2 = (Es,jacket*Asl,com,jacket + Es,core*Asl,com,core)/Asl,com = 200000.00
yv = 0.00083886
shv = 0.00268436
ftv = 314.5735
fyv = 262.1446
suv = 0.00268436
using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00
lo/lou,min = lb/lb,min = 0.13907892
suv = 0.4*esuv_nominal ((5.5), TBDY) = 0.032
From table 5A.1, TBDY: esuv_nominal = 0.08,
considering characteristic value fsyv = fsv/1.2, from table 5.1, TBDY
For calculation of esuv_nominal and yv, shv,ftv,fyv, it is considered
characteristic value fsyv = fsv/1.2, from table 5.1, TBDY.
y1, sh1,ft1,fy1, are also multiplied by Min(1,1.25*(lb/lb,min)^2/3), from 10.3.5, ASCE 41-17.
with fsv = (fs,jacket*Asl,mid,jacket + fs,mid*Asl,mid,core)/Asl,mid = 262.1446
with Esv = (Es,jacket*Asl,mid,jacket + Es,mid*Asl,mid,core)/Asl,mid = 200000.00
1 = Asl,ten/(b*d)*(fs1/fc) = 0.0187412
2 = Asl,com/(b*d)*(fs2/fc) = 0.03639521
v = Asl,mid/(b*d)*(fsv/fc) = 0.03308184
and confined core properties:
b = 690.00
d = 677.00
d' = 13.00
fcc (5A.2, TBDY) = 38.13135
cc (5A.5, TBDY) = 0.00471045
c = confinement factor = 1.27105
1 = Asl,ten/(b*d)*(fs1/fc) = 0.02127357
2 = Asl,com/(b*d)*(fs2/fc) = 0.04131304
v = Asl,mid/(b*d)*(fsv/fc) = 0.03755196
Case/Assumption: Unconfined full section - Steel rupture
'satisfies Eq. (4.3)
--->
v < vs,y2 - LHS eq.(4.5) is satisfied
--->
su (4.9) = 0.21062322
Mu = MRc (4.14) = 2.3387E+008
u = su (4.1) = 4.8099118E-006

```

Calculation of ratio lb/lb

```

Lap Length: lb/lb = 0.13907892
lb = 300.00
lb = 2157.049
Calculation of lb,min according to (25.4.3.2), ACI 318-14, using mean values for all the section re-bars.
lb,min from (25.4.3.2) is multiplied 2 times to account for smooth re-bars (9.1.2, TS500 - No provision in ACI 318)
= 1
db = 16.66667

```

Mean strength value of all re-bars:  $f_y = 781.25$   
Mean concrete strength:  $f_c' = (f_c'_{\text{jacket}} \cdot \text{Area}_{\text{jacket}} + f_c'_{\text{core}} \cdot \text{Area}_{\text{core}}) / \text{Area}_{\text{section}} = 30.00$ , but  $f_c'^{0.5} \leq 8.3$  MPa (22.5.3.1, ACI 318-14)  
 $t = 1.00$   
 $s = 0.80$   
 $e = 1.00$   
 $cb = 25.00$   
 $K_{tr} = 1.7174$   
 $A_{tr} = \text{Min}(A_{tr\_x}, A_{tr\_y}) = 257.6106$   
where  $A_{tr\_x}$ ,  $A_{tr\_y}$  are the sum of the area of all stirrup legs along X and Y loxal axis  
 $s = \text{Max}(s_{\text{external}}, s_{\text{internal}}) = 250.00$   
 $n = 24.00$

#### Calculation of $\mu_1$ -

Calculation of ultimate curvature  $\mu$  according to 4.1, Biskinis/Fardis 2013:  
 $\mu = 5.1201636E-006$   
 $\mu_1 = 5.0296E+008$

with full section properties:

$b = 400.00$   
 $d = 707.00$   
 $d' = 43.00$   
 $v = 0.00191815$   
 $N = 16273.608$   
 $f_c = 30.00$   
 $\alpha_1$  (5A.5, TBDY) = 0.002  
Final value of  $\mu_1$ :  $\mu_1^* = \text{shear\_factor} \cdot \text{Max}(\mu_1, \mu_2) = 0.01260361$   
The Shear\_factor is considered equal to 1 (pure moment strength)  
From (5.4b), TBDY:  $\mu_1 = 0.01260361$   
we (5.4c) = 0.05179731  
 $\alpha_2$  ((5.4d), TBDY) =  $(\alpha_1 \cdot A_{\text{ext}} + \alpha_2 \cdot A_{\text{int}}) / A_{\text{sec}} = 0.45746528$   
 $\alpha_1 = \text{Max}(((A_{\text{conf,max1}} - A_{\text{noConf1}}) / A_{\text{conf,max1}}) \cdot (A_{\text{conf,min1}} / A_{\text{conf,max1}}), 0) = 0.45746528$   
The definitions of  $A_{\text{noConf}}$ ,  $A_{\text{conf,min}}$  and  $A_{\text{conf,max}}$  are derived from generalization of the rectangular sections confinement, which is expressed by (5.4d).  
The generalization is done according to Mander, J., Priestley, M., and Park, R. (1988) "Theoretical Stress-Strain Model for Confined Concrete."  
J. Struct. Eng., 10.1061/(ASCE)0733-9445(1988)114:8(1804), 1804-1826.  
 $A_{\text{conf,max1}} = 353600.00$  is the confined core area at levels of member with hoops and is calculated as the area of core enclosed by the center lines of the external perimeter hoops.  
 $A_{\text{conf,min1}} = 293525.00$  is the confined core area at midway between the levels of hoops and is calculated by reducing all the dimensions of the area  $A_{\text{conf,max1}}$  by a length equal to half the clear spacing between external hoops.  
 $A_{\text{noConf1}} = 158733.333$  is the unconfined external core area which is equal to  $b_i^2/6$  as defined at (A.2).  
 $\alpha_2 (> \alpha_1) = \text{Max}(((A_{\text{conf,max2}} - A_{\text{noConf2}}) / A_{\text{conf,max2}}) \cdot (A_{\text{conf,min2}} / A_{\text{conf,max2}}), 0) = 0.45746528$   
The definitions of  $A_{\text{noConf}}$ ,  $A_{\text{conf,min}}$  and  $A_{\text{conf,max}}$  are derived from generalization of the rectangular sections confinement, which is expressed by (5.4d).  
The generalization is done according to Mander, J., Priestley, M., and Park, R. (1988) "Theoretical Stress-Strain Model for Confined Concrete."  
J. Struct. Eng., 10.1061/(ASCE)0733-9445(1988)114:8(1804), 1804-1826.  
 $A_{\text{conf,max2}} = 171264.00$  is the confined core area at levels of member with hoops and is calculated as the area of core enclosed by the center lines of the internal perimeter hoops.  
 $A_{\text{conf,min2}} = 54741.00$  is the confined core area at midway between the levels of hoops and is calculated by reducing all the dimensions of the area  $A_{\text{conf,max2}}$  by a length equal to half the clear spacing between internal hoops.  
 $A_{\text{noConf2}} = 106242.667$  is the unconfined internal core area which is equal to  $b_i^2/6$  as defined at (A.2).  
 $p_{sh,min} \cdot F_{ywe} = \text{Min}(p_{sh,x} \cdot F_{ywe}, p_{sh,y} \cdot F_{ywe}) = 3.3968$

$p_{sh,x} \cdot F_{ywe} = p_{sh1} \cdot F_{ywe1} + p_{sh2} \cdot F_{ywe2} = 3.3968$   
 $p_{sh1}$  ((5.4d), TBDY) =  $L_{stir1} \cdot A_{stir1} / (A_{\text{sec}} \cdot s_1) = 0.00367709$   
 $L_{stir1}$  (Length of stirrups along Y) = 2060.00  
 $A_{stir1}$  (stirrups area) = 78.53982  
 $p_{sh2}$  (5.4d) =  $L_{stir2} \cdot A_{stir2} / (A_{\text{sec}} \cdot s_2) = 0.00067082$

Lstir2 (Length of stirrups along Y) = 1468.00  
Astir2 (stirrups area) = 50.26548

psh\_y\*Fywe = psh1\*Fywe1+ps2\*Fywe2 = 3.3968  
psh1 ((5.4d), TBDY) = Lstir1\*Astir1/(Asec\*s1) = 0.00367709  
Lstir1 (Length of stirrups along X) = 2060.00  
Astir1 (stirrups area) = 78.53982  
psh2 ((5.4d), TBDY) = Lstir2\*Astir2/(Asec\*s2) = 0.00067082  
Lstir2 (Length of stirrups along X) = 1468.00  
Astir2 (stirrups area) = 50.26548

Asec = 440000.00  
s1 = 100.00  
s2 = 250.00

fywe1 = 781.25  
fywe2 = 781.25  
fce = 30.00

From ((5.A5), TBDY), TBDY: cc = 0.00471045  
c = confinement factor = 1.27105

y1 = 0.00083886  
sh1 = 0.00268436  
ft1 = 314.5735  
fy1 = 262.1446

su1 = 0.00268436

using (30) in Biskinis/Fardis (2013) multiplied with shear\_factor  
and also multiplied by the shear\_factor according to 15.7.1.4, with  
Shear\_factor = 1.00

lo/lou,min = lb/lb = 0.13907892

su1 = 0.4\*esu1\_nominal ((5.5), TBDY) = 0.032

From table 5A.1, TBDY: esu1\_nominal = 0.08,

For calculation of esu1\_nominal and y1, sh1,ft1,fy1, it is considered  
characteristic value fsy1 = fs1/1.2, from table 5.1, TBDY.

y1, sh1,ft1,fy1, are also multiplied by  $\text{Min}(1, 1.25 \cdot (lb/lb)^{2/3})$ , from 10.3.5, ASCE 41-17.

with fs1 = (fsjacket\*Asl,ten,jacket + fs,core\*Asl,ten,core)/Asl,ten = 262.1446

with Es1 = (Esjacket\*Asl,ten,jacket + Es,core\*Asl,ten,core)/Asl,ten = 200000.00

y2 = 0.00083886

sh2 = 0.00268436

ft2 = 314.5735

fy2 = 262.1446

su2 = 0.00268436

using (30) in Biskinis/Fardis (2013) multiplied with shear\_factor  
and also multiplied by the shear\_factor according to 15.7.1.4, with  
Shear\_factor = 1.00

lo/lou,min = lb/lb,min = 0.13907892

su2 = 0.4\*esu2\_nominal ((5.5), TBDY) = 0.032

From table 5A.1, TBDY: esu2\_nominal = 0.08,

For calculation of esu2\_nominal and y2, sh2,ft2,fy2, it is considered  
characteristic value fsy2 = fs2/1.2, from table 5.1, TBDY.

y1, sh1,ft1,fy1, are also multiplied by  $\text{Min}(1, 1.25 \cdot (lb/lb)^{2/3})$ , from 10.3.5, ASCE 41-17.

with fs2 = (fsjacket\*Asl,com,jacket + fs,core\*Asl,com,core)/Asl,com = 262.1446

with Es2 = (Esjacket\*Asl,com,jacket + Es,core\*Asl,com,core)/Asl,com = 200000.00

yv = 0.00083886

shv = 0.00268436

ftv = 314.5735

fyv = 262.1446

suv = 0.00268436

using (30) in Biskinis/Fardis (2013) multiplied with shear\_factor  
and also multiplied by the shear\_factor according to 15.7.1.4, with  
Shear\_factor = 1.00

lo/lou,min = lb/lb = 0.13907892

suv = 0.4\*esuv\_nominal ((5.5), TBDY) = 0.032

From table 5A.1, TBDY: esuv\_nominal = 0.08,

considering characteristic value fsyv = fsv/1.2, from table 5.1, TBDY  
For calculation of esuv\_nominal and yv, shv,ftv,fyv, it is considered  
characteristic value fsyv = fsv/1.2, from table 5.1, TBDY.

y1, sh1,ft1,fy1, are also multiplied by  $\text{Min}(1, 1.25 \cdot (lb/lb)^{2/3})$ , from 10.3.5, ASCE 41-17.

with fsv = (fsjacket\*Asl,mid,jacket + fs,mid\*Asl,mid,core)/Asl,mid = 262.1446

```

with Esv = (Esjacket*Aslmid,jacket + Esmid*Aslmid,core)/Aslmid = 200000.00
1 = Aslten/(b*d)*(fs1/fc) = 0.06824101
2 = Aslcom/(b*d)*(fs2/fc) = 0.03513975
v = Aslmid/(b*d)*(fsv/fc) = 0.06202846
and confined core properties:
b = 340.00
d = 677.00
d' = 13.00
fcc (5A.2, TBDY) = 38.13135
cc (5A.5, TBDY) = 0.00471045
c = confinement factor = 1.27105
1 = Aslten/(b*d)*(fs1/fc) = 0.08384116
2 = Aslcom/(b*d)*(fs2/fc) = 0.04317283
v = Aslmid/(b*d)*(fsv/fc) = 0.07620839
Case/Assumption: Unconfined full section - Steel rupture
'satisfies Eq. (4.3)
--->
v < vs,y2 - LHS eq.(4.5) is satisfied
--->
su (4.9) = 0.2584548
Mu = MRc (4.14) = 5.0296E+008
u = su (4.1) = 5.1201636E-006
-----

Calculation of ratio lb/d
-----
Lap Length: lb/d = 0.13907892
lb = 300.00
ld = 2157.049
Calculation of lb,min according to (25.4.3.2), ACI 318-14, using mean values for all the section re-bars.
ld,min from (25.4.3.2) is multiplied 2 times to account for smooth re-bars (9.1.2, TS500 - No provision in ACI 318)
= 1
db = 16.66667
Mean strength value of all re-bars: fy = 781.25
Mean concrete strength: fc' = (fc'_jacket*Area_jacket + fc'_core*Area_core)/Area_section = 30.00, but fc'^0.5 <= 8.3
MPa (22.5.3.1, ACI 318-14)
t = 1.00
s = 0.80
e = 1.00
cb = 25.00
Ktr = 1.7174
Atr = Min(Atrx,Atry) = 257.6106
where Atrx, Atry are the sum of the area of all stirrup legs along X and Y loxal axis
s = Max(sexternal,sinternal) = 250.00
n = 24.00
-----
-----
-----

Calculation of Mu2+
-----
-----

Calculation of ultimate curvature u according to 4.1, Biskinis/Fardis 2013:
u = 4.8099118E-006
Mu = 2.3387E+008
-----

with full section properties:
b = 750.00
d = 707.00
d' = 43.00
v = 0.00102301
N = 16273.608
fc = 30.00
co (5A.5, TBDY) = 0.002
Final value of cu: cu* = shear_factor * Max( cu, cc) = 0.01260361
The Shear_factor is considered equal to 1 (pure moment strength)
From (5.4b), TBDY: cu = 0.01260361

```

$$w_e (5.4c) = 0.05179731$$

$$ase ((5.4d), TBDY) = (ase1 * A_{ext} + ase2 * A_{int}) / A_{sec} = 0.45746528$$

$$ase1 = \text{Max}(((A_{conf,max1} - A_{noConf1}) / A_{conf,max1}) * (A_{conf,min1} / A_{conf,max1}), 0) = 0.45746528$$

The definitions of  $A_{noConf}$ ,  $A_{conf,min}$  and  $A_{conf,max}$  are derived from generalization of the rectangular sections confinement, which is expressed by (5.4d).

The generalization is done according to Mander, J., Priestley, M., and Park, R. (1988)

"Theoretical Stress-Strain Model for Confined Concrete."

J. Struct. Eng., 10.1061/(ASCE)0733-9445(1988)114:8(1804), 1804-1826.

$A_{conf,max1} = 353600.00$  is the confined core area at levels of member with hoops and is calculated as the area of core enclosed by the center lines of the external perimeter hoops.

$A_{conf,min1} = 293525.00$  is the confined core area at midway between the levels of hoops and is calculated by reducing all the dimensions of the area  $A_{conf,max1}$  by a length equal to half the clear spacing between external hoops.

$A_{noConf1} = 158733.333$  is the unconfined external core area which is equal to  $b_i^2/6$  as defined at (A.2).

$$ase2 (>= ase1) = \text{Max}(((A_{conf,max2} - A_{noConf2}) / A_{conf,max2}) * (A_{conf,min2} / A_{conf,max2}), 0) = 0.45746528$$

The definitions of  $A_{noConf}$ ,  $A_{conf,min}$  and  $A_{conf,max}$  are derived from generalization of the rectangular sections confinement, which is expressed by (5.4d).

The generalization is done according to Mander, J., Priestley, M., and Park, R. (1988)

"Theoretical Stress-Strain Model for Confined Concrete."

J. Struct. Eng., 10.1061/(ASCE)0733-9445(1988)114:8(1804), 1804-1826.

$A_{conf,max2} = 171264.00$  is the confined core area at levels of member with hoops and is calculated as the area of core enclosed by the center lines of the internal perimeter hoops.

$A_{conf,min2} = 54741.00$  is the confined core area at midway between the levels of hoops and is calculated by reducing all the dimensions of the area  $A_{conf,max2}$  by a length equal to half the clear spacing between internal hoops.

$A_{noConf2} = 106242.667$  is the unconfined internal core area which is equal to  $b_i^2/6$  as defined at (A.2).

$$psh_{min} * F_{ywe} = \text{Min}(psh_x * F_{ywe}, psh_y * F_{ywe}) = 3.3968$$

$$psh_x * F_{ywe} = psh1 * F_{ywe1} + ps2 * F_{ywe2} = 3.3968$$

$$psh1 ((5.4d), TBDY) = L_{stir1} * A_{stir1} / (A_{sec} * s1) = 0.00367709$$

$L_{stir1}$  (Length of stirrups along Y) = 2060.00

$A_{stir1}$  (stirrups area) = 78.53982

$$psh2 (5.4d) = L_{stir2} * A_{stir2} / (A_{sec} * s2) = 0.00067082$$

$L_{stir2}$  (Length of stirrups along Y) = 1468.00

$A_{stir2}$  (stirrups area) = 50.26548

$$psh_y * F_{ywe} = psh1 * F_{ywe1} + ps2 * F_{ywe2} = 3.3968$$

$$psh1 ((5.4d), TBDY) = L_{stir1} * A_{stir1} / (A_{sec} * s1) = 0.00367709$$

$L_{stir1}$  (Length of stirrups along X) = 2060.00

$A_{stir1}$  (stirrups area) = 78.53982

$$psh2 ((5.4d), TBDY) = L_{stir2} * A_{stir2} / (A_{sec} * s2) = 0.00067082$$

$L_{stir2}$  (Length of stirrups along X) = 1468.00

$A_{stir2}$  (stirrups area) = 50.26548

$$A_{sec} = 440000.00$$

$$s1 = 100.00$$

$$s2 = 250.00$$

$$f_{ywe1} = 781.25$$

$$f_{ywe2} = 781.25$$

$$f_{ce} = 30.00$$

$$\text{From } ((5.A5), TBDY), TBDY: cc = 0.00471045$$

$$c = \text{confinement factor} = 1.27105$$

$$y1 = 0.00083886$$

$$sh1 = 0.00268436$$

$$ft1 = 314.5735$$

$$fy1 = 262.1446$$

$$su1 = 0.00268436$$

using (30) in Biskinis/Fardis (2013) multiplied with shear\_factor and also multiplied by the shear\_factor according to 15.7.1.4, with Shear\_factor = 1.00

$$l_o/l_{ou,min} = l_b/l_d = 0.13907892$$

$$su1 = 0.4 * esu1_{nominal} ((5.5), TBDY) = 0.032$$

From table 5A.1, TBDY:  $esu1_{nominal} = 0.08$ ,

For calculation of  $esu1_{nominal}$  and  $y1$ ,  $sh1$ ,  $ft1$ ,  $fy1$ , it is considered characteristic value  $fsy1 = fs1/1.2$ , from table 5.1, TBDY.

$y1$ ,  $sh1$ ,  $ft1$ ,  $fy1$ , are also multiplied by  $\text{Min}(1, 1.25 * (l_b/l_d)^{2/3})$ , from 10.3.5, ASCE 41-17.

$$\text{with } fs1 = (f_{s,jacket} * A_{sl,ten,jacket} + f_{s,core} * A_{sl,ten,core}) / A_{sl,ten} = 262.1446$$

with  $E_{s1} = (E_{s,jacket} \cdot A_{s,ten,jacket} + E_{s,core} \cdot A_{s,ten,core}) / A_{s,ten} = 200000.00$   
 $y_2 = 0.00083886$   
 $sh_2 = 0.00268436$   
 $ft_2 = 314.5735$   
 $fy_2 = 262.1446$   
 $su_2 = 0.00268436$   
 using (30) in Biskinis/Fardis (2013) multiplied with shear\_factor  
 and also multiplied by the shear\_factor according to 15.7.1.4, with  
 Shear\_factor = 1.00  
 $l_o/l_{ou,min} = l_b/l_{b,min} = 0.13907892$   
 $su_2 = 0.4 \cdot esu_{2,nominal} ((5.5), TBDY) = 0.032$   
 From table 5A.1, TBDY:  $esu_{2,nominal} = 0.08$ ,  
 For calculation of  $esu_{2,nominal}$  and  $y_2, sh_2, ft_2, fy_2$ , it is considered  
 characteristic value  $fs_2 = fs_2/1.2$ , from table 5.1, TBDY.  
 $y_1, sh_1, ft_1, fy_1$ , are also multiplied by  $\text{Min}(1, 1.25 \cdot (l_b/l_d)^{2/3})$ , from 10.3.5, ASCE 41-17.  
 with  $fs_2 = (f_{s,jacket} \cdot A_{s,com,jacket} + f_{s,core} \cdot A_{s,com,core}) / A_{s,com} = 262.1446$   
 with  $E_{s2} = (E_{s,jacket} \cdot A_{s,com,jacket} + E_{s,core} \cdot A_{s,com,core}) / A_{s,com} = 200000.00$   
 $y_v = 0.00083886$   
 $sh_v = 0.00268436$   
 $ft_v = 314.5735$   
 $fy_v = 262.1446$   
 $suv = 0.00268436$   
 using (30) in Biskinis/Fardis (2013) multiplied with shear\_factor  
 and also multiplied by the shear\_factor according to 15.7.1.4, with  
 Shear\_factor = 1.00  
 $l_o/l_{ou,min} = l_b/l_d = 0.13907892$   
 $suv = 0.4 \cdot esuv_{nominal} ((5.5), TBDY) = 0.032$   
 From table 5A.1, TBDY:  $esuv_{nominal} = 0.08$ ,  
 considering characteristic value  $fs_v = fs_v/1.2$ , from table 5.1, TBDY  
 For calculation of  $esuv_{nominal}$  and  $y_v, sh_v, ft_v, fy_v$ , it is considered  
 characteristic value  $fs_v = fs_v/1.2$ , from table 5.1, TBDY.  
 $y_1, sh_1, ft_1, fy_1$ , are also multiplied by  $\text{Min}(1, 1.25 \cdot (l_b/l_d)^{2/3})$ , from 10.3.5, ASCE 41-17.  
 with  $fs_v = (f_{s,jacket} \cdot A_{s,mid,jacket} + f_{s,mid} \cdot A_{s,mid,core}) / A_{s,mid} = 262.1446$   
 with  $E_{sv} = (E_{s,jacket} \cdot A_{s,mid,jacket} + E_{s,mid} \cdot A_{s,mid,core}) / A_{s,mid} = 200000.00$   
 $1 = A_{s,ten} / (b \cdot d) \cdot (f_{s1} / f_c) = 0.0187412$   
 $2 = A_{s,com} / (b \cdot d) \cdot (f_{s2} / f_c) = 0.03639521$   
 $v = A_{s,mid} / (b \cdot d) \cdot (f_{sv} / f_c) = 0.03308184$

and confined core properties:

$b = 690.00$   
 $d = 677.00$   
 $d' = 13.00$   
 $f_{cc} (5A.2, TBDY) = 38.13135$   
 $cc (5A.5, TBDY) = 0.00471045$   
 $c = \text{confinement factor} = 1.27105$   
 $1 = A_{s,ten} / (b \cdot d) \cdot (f_{s1} / f_c) = 0.02127357$   
 $2 = A_{s,com} / (b \cdot d) \cdot (f_{s2} / f_c) = 0.04131304$   
 $v = A_{s,mid} / (b \cdot d) \cdot (f_{sv} / f_c) = 0.03755196$

Case/Assumption: Unconfined full section - Steel rupture

' satisfies Eq. (4.3)

--->

$v < v_{s,y2}$  - LHS eq.(4.5) is satisfied

--->

$su (4.9) = 0.21062322$

$\mu_u = M_{Rc} (4.14) = 2.3387E+008$

$u = su (4.1) = 4.8099118E-006$

Calculation of ratio  $l_b/l_d$

Lap Length:  $l_b/l_d = 0.13907892$

$l_b = 300.00$

$l_d = 2157.049$

Calculation of  $l_{b,min}$  according to (25.4.3.2), ACI 318-14, using mean values for all the section re-bars.

$l_{d,min}$  from (25.4.3.2) is multiplied 2 times to account for smooth re-bars (9.1.2, TS500 - No provision in ACI 318)

= 1

$db = 16.66667$

Mean strength value of all re-bars:  $f_y = 781.25$



Mean concrete strength:  $fc' = (fc'_{jacket} \cdot Area_{jacket} + fc'_{core} \cdot Area_{core}) / Area_{section} = 30.00$ , but  $fc'^{0.5} \leq 8.3$  MPa (22.5.3.1, ACI 318-14)

$t = 1.00$

$s = 0.80$

$e = 1.00$

$cb = 25.00$

$K_{tr} = 1.7174$

$A_{tr} = \text{Min}(A_{tr\_x}, A_{tr\_y}) = 257.6106$

where  $A_{tr\_x}$ ,  $A_{tr\_y}$  are the sum of the area of all stirrup legs along X and Y loxal axis

$s = \text{Max}(s_{external}, s_{internal}) = 250.00$

$n = 24.00$

Calculation of  $\mu_2$ -

Calculation of ultimate curvature  $\mu$  according to 4.1, Biskinis/Fardis 2013:

$\mu = 5.1201636E-006$

$\mu_u = 5.0296E+008$

with full section properties:

$b = 400.00$

$d = 707.00$

$d' = 43.00$

$v = 0.00191815$

$N = 16273.608$

$fc = 30.00$

$\phi$  (5A.5, TBDY) = 0.002

Final value of  $\phi$ :  $\phi_u = \text{shear\_factor} \cdot \text{Max}(\phi_u, \phi_c) = 0.01260361$

The Shear\_factor is considered equal to 1 (pure moment strength)

From (5.4b), TBDY:  $\phi_u = 0.01260361$

we (5.4c) = 0.05179731

$\phi_{ase} ((5.4d), \text{TBDY}) = (\phi_{ase1} \cdot A_{ext} + \phi_{ase2} \cdot A_{int}) / A_{sec} = 0.45746528$

$\phi_{ase1} = \text{Max}(((A_{conf,max1} - A_{noConf1}) / A_{conf,max1}) \cdot (A_{conf,min1} / A_{conf,max1}), 0) = 0.45746528$

The definitions of  $A_{noConf}$ ,  $A_{conf,min}$  and  $A_{conf,max}$  are derived from generalization

of the rectangular sections confinement, which is expressed by (5.4d).

The generalization is done according to Mander, J., Priestley, M., and Park, R. (1988)

"Theoretical Stress-Strain Model for Confined Concrete."

J. Struct. Eng., 10.1061/(ASCE)0733-9445(1988)114:8(1804), 1804-1826.

$A_{conf,max1} = 353600.00$  is the confined core area at levels of member with hoops and

is calculated as the area of core enclosed by the center lines of the external perimeter hoops.

$A_{conf,min1} = 293525.00$  is the confined core area at midway between the levels of hoops and

is calculated by reducing all the dimensions of the area  $A_{conf,max1}$  by a length

equal to half the clear spacing between external hoops.

$A_{noConf1} = 158733.333$  is the unconfined external core area which is equal to  $b_i^2/6$  as defined at (A.2).

$\phi_{ase2} (> \phi_{ase1}) = \text{Max}(((A_{conf,max2} - A_{noConf2}) / A_{conf,max2}) \cdot (A_{conf,min2} / A_{conf,max2}), 0) = 0.45746528$

The definitions of  $A_{noConf}$ ,  $A_{conf,min}$  and  $A_{conf,max}$  are derived from generalization

of the rectangular sections confinement, which is expressed by (5.4d).

The generalization is done according to Mander, J., Priestley, M., and Park, R. (1988)

"Theoretical Stress-Strain Model for Confined Concrete."

J. Struct. Eng., 10.1061/(ASCE)0733-9445(1988)114:8(1804), 1804-1826.

$A_{conf,max2} = 171264.00$  is the confined core area at levels of member with hoops and

is calculated as the area of core enclosed by the center lines of the internal perimeter hoops.

$A_{conf,min2} = 54741.00$  is the confined core area at midway between the levels of hoops and

is calculated by reducing all the dimensions of the area  $A_{conf,max2}$  by a length

equal to half the clear spacing between internal hoops.

$A_{noConf2} = 106242.667$  is the unconfined internal core area which is equal to  $b_i^2/6$  as defined at (A.2).

$\phi_{psh,min} \cdot \phi_{fywe} = \text{Min}(\phi_{psh,x} \cdot \phi_{fywe}, \phi_{psh,y} \cdot \phi_{fywe}) = 3.3968$

$\phi_{psh,x} \cdot \phi_{fywe} = \phi_{psh1} \cdot \phi_{fywe1} + \phi_{psh2} \cdot \phi_{fywe2} = 3.3968$

$\phi_{psh1} ((5.4d), \text{TBDY}) = L_{stir1} \cdot A_{stir1} / (A_{sec} \cdot s_1) = 0.00367709$

$L_{stir1}$  (Length of stirrups along Y) = 2060.00

$A_{stir1}$  (stirrups area) = 78.53982

$\phi_{psh2} (5.4d) = L_{stir2} \cdot A_{stir2} / (A_{sec} \cdot s_2) = 0.00067082$

$L_{stir2}$  (Length of stirrups along Y) = 1468.00

Astir2 (stirrups area) = 50.26548

psh\_y\*Fywe = psh1\*Fywe1+ps2\*Fywe2 = 3.3968  
psh1 ((5.4d), TBDY) = Lstir1\*Astir1/(Asec\*s1) = 0.00367709  
Lstir1 (Length of stirrups along X) = 2060.00  
Astir1 (stirrups area) = 78.53982  
psh2 ((5.4d), TBDY) = Lstir2\*Astir2/(Asec\*s2) = 0.00067082  
Lstir2 (Length of stirrups along X) = 1468.00  
Astir2 (stirrups area) = 50.26548

Asec = 440000.00

s1 = 100.00

s2 = 250.00

fywe1 = 781.25

fywe2 = 781.25

fce = 30.00

From ((5.A5), TBDY), TBDY: cc = 0.00471045

c = confinement factor = 1.27105

y1 = 0.00083886

sh1 = 0.00268436

ft1 = 314.5735

fy1 = 262.1446

su1 = 0.00268436

using (30) in Biskinis/Fardis (2013) multiplied with shear\_factor  
and also multiplied by the shear\_factor according to 15.7.1.4, with  
Shear\_factor = 1.00

lo/lou,min = lb/ld = 0.13907892

su1 = 0.4\*esu1\_nominal ((5.5), TBDY) = 0.032

From table 5A.1, TBDY: esu1\_nominal = 0.08,

For calculation of esu1\_nominal and y1, sh1,ft1,fy1, it is considered  
characteristic value fsy1 = fs1/1.2, from table 5.1, TBDY.

y1, sh1,ft1,fy1, are also multiplied by  $\text{Min}(1, 1.25 \cdot (lb/ld)^{2/3})$ , from 10.3.5, ASCE 41-17.

with fs1 = (fs,jacket\*Asl,ten,jacket + fs,core\*Asl,ten,core)/Asl,ten = 262.1446

with Es1 = (Es,jacket\*Asl,ten,jacket + Es,core\*Asl,ten,core)/Asl,ten = 200000.00

y2 = 0.00083886

sh2 = 0.00268436

ft2 = 314.5735

fy2 = 262.1446

su2 = 0.00268436

using (30) in Biskinis/Fardis (2013) multiplied with shear\_factor  
and also multiplied by the shear\_factor according to 15.7.1.4, with  
Shear\_factor = 1.00

lo/lou,min = lb/lb,min = 0.13907892

su2 = 0.4\*esu2\_nominal ((5.5), TBDY) = 0.032

From table 5A.1, TBDY: esu2\_nominal = 0.08,

For calculation of esu2\_nominal and y2, sh2,ft2,fy2, it is considered  
characteristic value fsy2 = fs2/1.2, from table 5.1, TBDY.

y1, sh1,ft1,fy1, are also multiplied by  $\text{Min}(1, 1.25 \cdot (lb/ld)^{2/3})$ , from 10.3.5, ASCE 41-17.

with fs2 = (fs,jacket\*Asl,com,jacket + fs,core\*Asl,com,core)/Asl,com = 262.1446

with Es2 = (Es,jacket\*Asl,com,jacket + Es,core\*Asl,com,core)/Asl,com = 200000.00

yv = 0.00083886

shv = 0.00268436

ftv = 314.5735

fyv = 262.1446

suv = 0.00268436

using (30) in Biskinis/Fardis (2013) multiplied with shear\_factor  
and also multiplied by the shear\_factor according to 15.7.1.4, with  
Shear\_factor = 1.00

lo/lou,min = lb/ld = 0.13907892

suv = 0.4\*esuv\_nominal ((5.5), TBDY) = 0.032

From table 5A.1, TBDY: esuv\_nominal = 0.08,

considering characteristic value fsyv = fsv/1.2, from table 5.1, TBDY

For calculation of esuv\_nominal and yv, shv,ftv,fyv, it is considered  
characteristic value fsyv = fsv/1.2, from table 5.1, TBDY.

y1, sh1,ft1,fy1, are also multiplied by  $\text{Min}(1, 1.25 \cdot (lb/ld)^{2/3})$ , from 10.3.5, ASCE 41-17.

with fsv = (fs,jacket\*Asl,mid,jacket + fs,mid\*Asl,mid,core)/Asl,mid = 262.1446

with Esv = (Es,jacket\*Asl,mid,jacket + Es,mid\*Asl,mid,core)/Asl,mid = 200000.00

$$1 = A_{sl,ten}/(b*d)*(f_{s1}/f_c) = 0.06824101$$

$$2 = A_{sl,com}/(b*d)*(f_{s2}/f_c) = 0.03513975$$

$$v = A_{sl,mid}/(b*d)*(f_{sv}/f_c) = 0.06202846$$

and confined core properties:

$$b = 340.00$$

$$d = 677.00$$

$$d' = 13.00$$

$$f_{cc} (5A.2, TBDY) = 38.13135$$

$$cc (5A.5, TBDY) = 0.00471045$$

$$c = \text{confinement factor} = 1.27105$$

$$1 = A_{sl,ten}/(b*d)*(f_{s1}/f_c) = 0.08384116$$

$$2 = A_{sl,com}/(b*d)*(f_{s2}/f_c) = 0.04317283$$

$$v = A_{sl,mid}/(b*d)*(f_{sv}/f_c) = 0.07620839$$

Case/Assumption: Unconfined full section - Steel rupture

' satisfies Eq. (4.3)

--->

$v < v_{s,y2}$  - LHS eq.(4.5) is satisfied

--->

$$su (4.9) = 0.2584548$$

$$Mu = MR_c (4.14) = 5.0296E+008$$

$$u = su (4.1) = 5.1201636E-006$$

Calculation of ratio  $l_b/d$

Lap Length:  $l_b/d = 0.13907892$

$$l_b = 300.00$$

$$l_d = 2157.049$$

Calculation of  $l_b, \min$  according to (25.4.3.2), ACI 318-14, using mean values for all the section re-bars.

$l_d, \min$  from (25.4.3.2) is multiplied 2 times to account for smooth re-bars (9.1.2, TS500 - No provision in ACI 318)

$$= 1$$

$$d_b = 16.66667$$

Mean strength value of all re-bars:  $f_y = 781.25$

Mean concrete strength:  $f'_c = (f'_c_{jacket} * Area_{jacket} + f'_c_{core} * Area_{core}) / Area_{section} = 30.00$ , but  $f_c^{0.5} \leq 8.3$  MPa (22.5.3.1, ACI 318-14)

$$t = 1.00$$

$$s = 0.80$$

$$e = 1.00$$

$$c_b = 25.00$$

$$K_{tr} = 1.7174$$

$$A_{tr} = \min(A_{tr_x}, A_{tr_y}) = 257.6106$$

where  $A_{tr_x}$ ,  $A_{tr_y}$  are the sum of the area of all stirrup legs along X and Y loxal axis

$$s = \max(s_{external}, s_{internal}) = 250.00$$

$$n = 24.00$$

Calculation of Shear Strength  $V_r = \min(V_{r1}, V_{r2}) = 1.0392E+006$

Calculation of Shear Strength at edge 1,  $V_{r1} = 1.0392E+006$

$$V_{r1} = V_{Col} ((10.3), ASCE 41-17) = k_{nl} * V_{Col0}$$

$$V_{Col0} = 1.0392E+006$$

$$k_{nl} = 1 \text{ (zero step-static loading)}$$

NOTE: In expression (10-3) ' $V_s = A_v * f_y * d / s$ ' is replaced by ' $V_{s+} + f * V_f$ '

where  $V_f$  is the contribution of FRPs (11.3), ACI 440).

$$= 1 \text{ (normal-weight concrete)}$$

Mean concrete strength:  $f'_c = (f'_c_{jacket} * Area_{jacket} + f'_c_{core} * Area_{core}) / Area_{section} = 30.00$ , but  $f_c^{0.5} \leq 8.3$  MPa (22.5.3.1, ACI 318-14)

$$M/Vd = 4.00$$

$$Mu = 1308.016$$

$$Vu = 0.00017144$$

$$d = 0.8 * h = 600.00$$

$$Nu = 16273.608$$

$$Ag = 300000.00$$

From (11.5.4.8), ACI 318-14:  $V_s = V_{s,jacket} + V_{s,core} = 1.0138E+006$

where:

$V_{s,jacket} = V_{s,j1} + V_{s,j2} = 903207.888$

$V_{s,j1} = 589048.623$  is calculated for section web jacket, with:

$d = 600.00$

$A_v = 157079.633$

$f_y = 625.00$

$s = 100.00$

$V_{s,j1}$  is multiplied by  $Col,j1 = 1.00$

$s/d = 0.16666667$

$V_{s,j2} = 314159.265$  is calculated for section flange jacket, with:

$d = 320.00$

$A_v = 157079.633$

$f_y = 625.00$

$s = 100.00$

$V_{s,j2}$  is multiplied by  $Col,j2 = 1.00$

$s/d = 0.3125$

$V_{s,core} = V_{s,c1} + V_{s,c2} = 110584.061$

$V_{s,c1} = 110584.061$  is calculated for section web core, with:

$d = 440.00$

$A_v = 100530.965$

$f_y = 625.00$

$s = 250.00$

$V_{s,c1}$  is multiplied by  $Col,c1 = 1.00$

$s/d = 0.56818182$

$V_{s,c2} = 0.00$  is calculated for section flange core, with:

$d = 160.00$

$A_v = 100530.965$

$f_y = 625.00$

$s = 250.00$

$V_{s,c2}$  is multiplied by  $Col,c2 = 0.00$

$s/d = 1.5625$

$V_f$  ((11-3)-(11.4), ACI 440) = 0.00

From (11-11), ACI 440:  $V_s + V_f \leq 873250.061$

$bw = 400.00$

Calculation of Shear Strength at edge 2,  $V_{r2} = 1.0392E+006$

$V_{r2} = V_{Col}$  ((10.3), ASCE 41-17) =  $k_{nl} * V_{Col0}$

$V_{Col0} = 1.0392E+006$

$k_{nl} = 1$  (zero step-static loading)

NOTE: In expression (10-3) ' $V_s = A_v * f_y * d / s$ ' is replaced by ' $V_s + f * V_f$ ' where  $V_f$  is the contribution of FRPs (11.3), ACI 440).

= 1 (normal-weight concrete)

Mean concrete strength:  $f'_c = (f'_{c,jacket} * Area_{jacket} + f'_{c,core} * Area_{core}) / Area_{section} = 30.00$ , but  $f'_c^{0.5} \leq 8.3$  MPa (22.5.3.1, ACI 318-14)

$M/Vd = 4.00$

$\mu_u = 1308.016$

$V_u = 0.00017144$

$d = 0.8 * h = 600.00$

$N_u = 16273.608$

$A_g = 300000.00$

From (11.5.4.8), ACI 318-14:  $V_s = V_{s,jacket} + V_{s,core} = 1.0138E+006$

where:

$V_{s,jacket} = V_{s,j1} + V_{s,j2} = 903207.888$

$V_{s,j1} = 589048.623$  is calculated for section web jacket, with:

$d = 600.00$

$A_v = 157079.633$

$f_y = 625.00$

$s = 100.00$

$V_{s,j1}$  is multiplied by  $Col,j1 = 1.00$

$s/d = 0.16666667$

$V_{s,j2} = 314159.265$  is calculated for section flange jacket, with:

$d = 320.00$

$A_v = 157079.633$

```

fy = 625.00
s = 100.00
Vs,j2 is multiplied by Col,j2 = 1.00
s/d = 0.3125
Vs,core = Vs,c1 + Vs,c2 = 110584.061
Vs,c1 = 110584.061 is calculated for section web core, with:
d = 440.00
Av = 100530.965
fy = 625.00
s = 250.00
Vs,c1 is multiplied by Col,c1 = 1.00
s/d = 0.56818182
Vs,c2 = 0.00 is calculated for section flange core, with:
d = 160.00
Av = 100530.965
fy = 625.00
s = 250.00
Vs,c2 is multiplied by Col,c2 = 0.00
s/d = 1.5625
Vf ((11-3)-(11.4), ACI 440) = 0.00
From (11-11), ACI 440: Vs + Vf <= 873250.061
bw = 400.00

```

-----

End Of Calculation of Shear Capacity ratio for element: column JLC1 of floor 1  
At local axis: 3

-----

Start Of Calculation of Shear Capacity ratio for element: column JLC1 of floor 1  
At Shear local axis: 2  
(Bending local axis: 3)  
Section Type: rcjcs

#### Constant Properties

-----

Knowledge Factor, = 1.00  
Mean strength values are used for both shear and moment calculations.  
Consequently:

Jacket

New material of Primary Member: Concrete Strength,  $f_c = f_{cm} = 30.00$

New material of Primary Member: Steel Strength,  $f_s = f_{sm} = 625.00$

Concrete Elasticity,  $E_c = 25742.96$

Steel Elasticity,  $E_s = 200000.00$

Existing Column

New material of Primary Member: Concrete Strength,  $f_c = f_{cm} = 30.00$

New material of Primary Member: Steel Strength,  $f_s = f_{sm} = 625.00$

Concrete Elasticity,  $E_c = 25742.96$

Steel Elasticity,  $E_s = 200000.00$

#####

Note: Especially for the calculation of moment strengths,  
the above steel re-bar strengths are multiplied by 1.25 according to R18.6.5, ACI 318-14

Jacket

New material: Steel Strength,  $f_s = 1.25 \cdot f_{sm} = 781.25$

Existing Column

New material: Steel Strength,  $f_s = 1.25 \cdot f_{sm} = 781.25$

#####

Max Height,  $H_{max} = 750.00$

Min Height,  $H_{min} = 400.00$

Max Width,  $W_{max} = 750.00$

Min Width,  $W_{min} = 400.00$

Jacket Thickness,  $t_j = 100.00$

Cover Thickness,  $c = 25.00$

Mean Confinement Factor overall section = 1.27105

Element Length,  $L = 3000.00$

Primary Member

Smooth Bars  
 Ductile Steel  
 With Detailing for Earthquake Resistance (including stirrups closed at 135°)  
 Longitudinal Bars With Ends Lapped Starting at the End Sections  
 Lap Length  $l_o = 300.00$   
 No FRP Wrapping

#### Stepwise Properties

At local axis: 2  
 EDGE -A-  
 Shear Force,  $V_a = -0.0001715$   
 EDGE -B-  
 Shear Force,  $V_b = 0.0001715$   
 BOTH EDGES  
 Axial Force,  $F = -16273.608$   
 Longitudinal Reinforcement Area Distribution (in 2 divisions)  
   -Tension:  $As_t = 0.00$   
   -Compression:  $As_c = 5353.274$   
 Longitudinal Reinforcement Area Distribution (in 3 divisions)  
   -Tension:  $As_{t,ten} = 1137.257$   
   -Compression:  $As_{l,com} = 2208.54$   
   -Middle:  $As_{l,mid} = 2007.478$

Calculation of Shear Capacity ratio ,  $V_e/V_r = 0.32266369$   
 Member Controlled by Flexure ( $V_e/V_r < 1$ )  
 Calculation of Shear Demand from fig. R18.6.5, ACI 318-14  $V_e = (M_{pr1} + M_{pr2})/l_n = 335307.657$   
 with  
 $M_{pr1} = \text{Max}(Mu_{1+}, Mu_{1-}) = 5.0296E+008$   
 $Mu_{1+} = 2.3387E+008$ , is the ultimate moment strength at the edge 1 of the member in the actual moment direction which is defined for the static loading combination  
 $Mu_{1-} = 5.0296E+008$ , is the ultimate moment strength at the edge 1 of the member in the opposite moment direction which is defined for the static loading combination  
 $M_{pr2} = \text{Max}(Mu_{2+}, Mu_{2-}) = 5.0296E+008$   
 $Mu_{2+} = 2.3387E+008$ , is the ultimate moment strength at the edge 2 of the member in the actual moment direction which is defined for the the static loading combination  
 $Mu_{2-} = 5.0296E+008$ , is the ultimate moment strength at the edge 2 of the member in the opposite moment direction which is defined for the the static loading combination

#### Calculation of $Mu_{1+}$

Calculation of ultimate curvature  $\phi_u$  according to 4.1, Biskinis/Fardis 2013:  
 $\phi_u = 4.8099118E-006$   
 $M_u = 2.3387E+008$

with full section properties:

$b = 750.00$   
 $d = 707.00$   
 $d' = 43.00$   
 $v = 0.00102301$   
 $N = 16273.608$   
 $f_c = 30.00$   
 $\phi_c$  (5A.5, TBDY) = 0.002  
 Final value of  $\phi_u$ :  $\phi_u^* = \text{shear\_factor} * \text{Max}(\phi_u, \phi_c) = 0.01260361$   
 The Shear\_factor is considered equal to 1 (pure moment strength)  
 From (5.4b), TBDY:  $\phi_u = 0.01260361$   
 $\phi_{ue}$  (5.4c) = 0.05179731  
 $\phi_{ase}$  ((5.4d), TBDY) =  $(\phi_{ase1} * A_{ext} + \phi_{ase2} * A_{int}) / A_{sec} = 0.45746528$   
 $\phi_{ase1} = \text{Max}(((A_{conf,max1} - A_{noConf1}) / A_{conf,max1}) * (A_{conf,min1} / A_{conf,max1}), 0) = 0.45746528$   
 The definitions of  $A_{noConf}$ ,  $A_{conf,min}$  and  $A_{conf,max}$  are derived from generalization

of the rectangular sections confinement, which is expressed by (5.4d).

The generalization is done according to Mander, J., Priestley, M., and Park, R. (1988)

"Theoretical Stress-Strain Model for Confined Concrete."

J. Struct. Eng., 10.1061/(ASCE)0733-9445(1988)114:8(1804), 1804-1826.

$A_{conf,max1} = 353600.00$  is the confined core area at levels of member with hoops and

is calculated as the area of core enclosed by the center lines of the external perimeter hoops.

$A_{conf,min1} = 293525.00$  is the confined core area at midway between the levels of hoops and

is calculated by reducing all the dimensions of the area  $A_{conf,max1}$  by a length equal to half the clear spacing between external hoops.

$A_{noConf1} = 158733.333$  is the unconfined external core area which is equal to  $b_i^2/6$  as defined at (A.2).

$ase2 (>= ase1) = \text{Max}(((A_{conf,max2} - A_{noConf2})/A_{conf,max2}) * (A_{conf,min2}/A_{conf,max2}), 0) = 0.45746528$

The definitions of  $A_{noConf}$ ,  $A_{conf,min}$  and  $A_{conf,max}$  are derived from generalization of the rectangular sections confinement, which is expressed by (5.4d).

The generalization is done according to Mander, J., Priestley, M., and Park, R. (1988)

"Theoretical Stress-Strain Model for Confined Concrete."

J. Struct. Eng., 10.1061/(ASCE)0733-9445(1988)114:8(1804), 1804-1826.

$A_{conf,max2} = 171264.00$  is the confined core area at levels of member with hoops and

is calculated as the area of core enclosed by the center lines of the internal perimeter hoops.

$A_{conf,min2} = 54741.00$  is the confined core area at midway between the levels of hoops and

is calculated by reducing all the dimensions of the area  $A_{conf,max2}$  by a length equal to half the clear spacing between internal hoops.

$A_{noConf2} = 106242.667$  is the unconfined internal core area which is equal to  $b_i^2/6$  as defined at (A.2).

$p_{sh,min} * F_{ywe} = \text{Min}(p_{sh,x} * F_{ywe}, p_{sh,y} * F_{ywe}) = 3.3968$

$p_{sh,x} * F_{ywe} = p_{sh1} * F_{ywe1} + p_{s2} * F_{ywe2} = 3.3968$

$p_{sh1} ((5.4d), \text{TBDY}) = L_{stir1} * A_{stir1} / (A_{sec} * s1) = 0.00367709$

$L_{stir1}$  (Length of stirrups along Y) = 2060.00

$A_{stir1}$  (stirrups area) = 78.53982

$p_{sh2} ((5.4d), \text{TBDY}) = L_{stir2} * A_{stir2} / (A_{sec} * s2) = 0.00067082$

$L_{stir2}$  (Length of stirrups along Y) = 1468.00

$A_{stir2}$  (stirrups area) = 50.26548

$p_{sh,y} * F_{ywe} = p_{sh1} * F_{ywe1} + p_{s2} * F_{ywe2} = 3.3968$

$p_{sh1} ((5.4d), \text{TBDY}) = L_{stir1} * A_{stir1} / (A_{sec} * s1) = 0.00367709$

$L_{stir1}$  (Length of stirrups along X) = 2060.00

$A_{stir1}$  (stirrups area) = 78.53982

$p_{sh2} ((5.4d), \text{TBDY}) = L_{stir2} * A_{stir2} / (A_{sec} * s2) = 0.00067082$

$L_{stir2}$  (Length of stirrups along X) = 1468.00

$A_{stir2}$  (stirrups area) = 50.26548

$A_{sec} = 440000.00$

$s1 = 100.00$

$s2 = 250.00$

$f_{ywe1} = 781.25$

$f_{ywe2} = 781.25$

$f_{ce} = 30.00$

From ((5.A5), TBDY), TBDY:  $cc = 0.00471045$

$c = \text{confinement factor} = 1.27105$

$y1 = 0.00083886$

$sh1 = 0.00268436$

$ft1 = 314.5735$

$fy1 = 262.1446$

$su1 = 0.00268436$

using (30) in Biskinis/Fardis (2013) multiplied with  $\text{shear\_factor}$

and also multiplied by the  $\text{shear\_factor}$  according to 15.7.1.4, with

$\text{Shear\_factor} = 1.00$

$l_o/l_{ou,min} = l_b/l_d = 0.13907892$

$su1 = 0.4 * esu1_{nominal} ((5.5), \text{TBDY}) = 0.032$

From table 5A.1, TBDY:  $esu1_{nominal} = 0.08$ ,

For calculation of  $esu1_{nominal}$  and  $y1, sh1, ft1, fy1$ , it is considered

characteristic value  $fsy1 = fs1/1.2$ , from table 5.1, TBDY.

$y1, sh1, ft1, fy1$ , are also multiplied by  $\text{Min}(1, 1.25 * (l_b/l_d)^{2/3})$ , from 10.3.5, ASCE 41-17.

with  $fs1 = (f_{s,jacket} * A_{s1,ten,jacket} + f_{s,core} * A_{s1,ten,core}) / A_{s1,ten} = 262.1446$

with  $Es1 = (E_{s,jacket} * A_{s1,ten,jacket} + E_{s,core} * A_{s1,ten,core}) / A_{s1,ten} = 200000.00$

$y2 = 0.00083886$

$sh2 = 0.00268436$

$ft2 = 314.5735$

```

fy2 = 262.1446
su2 = 0.00268436
    using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
    and also multiplied by the shear_factor according to 15.7.1.4, with
    Shear_factor = 1.00
    lo/lou,min = lb/lb,min = 0.13907892
    su2 = 0.4*esu2_nominal ((5.5), TBDY) = 0.032
    From table 5A.1, TBDY: esu2_nominal = 0.08,
    For calculation of esu2_nominal and y2, sh2,ft2,fy2, it is considered
    characteristic value fsy2 = fs2/1.2, from table 5.1, TBDY.
    y1, sh1,ft1,fy1, are also multiplied by Min(1,1.25*(lb/ld)^ 2/3), from 10.3.5, ASCE 41-17.
    with fs2 = (fs,jacket*Asl,com,jacket + fs,core*Asl,com,core)/Asl,com = 262.1446
    with Es2 = (Es,jacket*Asl,com,jacket + Es,core*Asl,com,core)/Asl,com = 200000.00
    yv = 0.00083886
    shv = 0.00268436
    ftv = 314.5735
    fyv = 262.1446
    suv = 0.00268436
    using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
    and also multiplied by the shear_factor according to 15.7.1.4, with
    Shear_factor = 1.00
    lo/lou,min = lb/ld = 0.13907892
    suv = 0.4*esuv_nominal ((5.5), TBDY) = 0.032
    From table 5A.1, TBDY: esuv_nominal = 0.08,
    considering characteristic value fsyv = fsv/1.2, from table 5.1, TBDY
    For calculation of esuv_nominal and yv, shv,ftv,fyv, it is considered
    characteristic value fsyv = fsv/1.2, from table 5.1, TBDY.
    y1, sh1,ft1,fy1, are also multiplied by Min(1,1.25*(lb/ld)^ 2/3), from 10.3.5, ASCE 41-17.
    with fsv = (fs,jacket*Asl,mid,jacket + fs,mid*Asl,mid,core)/Asl,mid = 262.1446
    with Esv = (Es,jacket*Asl,mid,jacket + Es,mid*Asl,mid,core)/Asl,mid = 200000.00
    1 = Asl,ten/(b*d)*(fs1/fc) = 0.0187412
    2 = Asl,com/(b*d)*(fs2/fc) = 0.03639521
    v = Asl,mid/(b*d)*(fsv/fc) = 0.03308184
    and confined core properties:
    b = 690.00
    d = 677.00
    d' = 13.00
    fcc (5A.2, TBDY) = 38.13135
    cc (5A.5, TBDY) = 0.00471045
    c = confinement factor = 1.27105
    1 = Asl,ten/(b*d)*(fs1/fc) = 0.02127357
    2 = Asl,com/(b*d)*(fs2/fc) = 0.04131304
    v = Asl,mid/(b*d)*(fsv/fc) = 0.03755196

```

Case/Assumption: Unconfined full section - Steel rupture  
 ' satisfies Eq. (4.3)

```

---->
v < vs,y2 - LHS eq.(4.5) is satisfied
---->
su (4.9) = 0.21062322
Mu = MRc (4.14) = 2.3387E+008
u = su (4.1) = 4.8099118E-006

```

#### Calculation of ratio lb/ld

```

Lap Length: lb/ld = 0.13907892
lb = 300.00
ld = 2157.049
Calculation of lb,min according to (25.4.3.2), ACI 318-14, using mean values for all the section re-bars.
ld,min from (25.4.3.2) is multiplied 2 times to account for smooth re-bars (9.1.2, TS500 - No provision in ACI 318)
= 1
db = 16.66667
Mean strength value of all re-bars: fy = 781.25
Mean concrete strength: fc' = (fc'_jacket*Area_jacket + fc'_core*Area_core)/Area_section = 30.00, but fc'^0.5 <= 8.3
MPa (22.5.3.1, ACI 318-14)
t = 1.00
s = 0.80

```



$e = 1.00$   
 $cb = 25.00$   
 $Ktr = 1.7174$   
 $Atr = \text{Min}(Atr_x, Atr_y) = 257.6106$   
 where  $Atr_x, Atr_y$  are the sum of the area of all stirrup legs along X and Y loxal axis  
 $s = \text{Max}(s_{\text{external}}, s_{\text{internal}}) = 250.00$   
 $n = 24.00$

Calculation of  $\mu_1$ -

Calculation of ultimate curvature  $\mu$  according to 4.1, Biskinis/Fardis 2013:  
 $u = 5.1201636E-006$   
 $\mu = 5.0296E+008$

with full section properties:

$b = 400.00$   
 $d = 707.00$   
 $d' = 43.00$   
 $v = 0.00191815$   
 $N = 16273.608$   
 $fc = 30.00$   
 $co(5A.5, TBDY) = 0.002$   
 Final value of  $\mu$ :  $\mu^* = \text{shear\_factor} * \text{Max}(\mu, cc) = 0.01260361$   
 The Shear\_factor is considered equal to 1 (pure moment strength)  
 From (5.4b), TBDY:  $\mu = 0.01260361$   
 $w_e(5.4c) = 0.05179731$   
 $ase((5.4d), TBDY) = (ase1 * A_{ext} + ase2 * A_{int}) / A_{sec} = 0.45746528$   
 $ase1 = \text{Max}(((A_{conf,max1} - A_{noConf1}) / A_{conf,max1}) * (A_{conf,min1} / A_{conf,max1}), 0) = 0.45746528$   
 The definitions of  $A_{noConf}$ ,  $A_{conf,min}$  and  $A_{conf,max}$  are derived from generalization of the rectangular sections confinement, which is expressed by (5.4d).  
 The generalization is done according to Mander, J., Priestley, M., and Park, R. (1988) "Theoretical Stress-Strain Model for Confined Concrete."  
 J. Struct. Eng., 10.1061/(ASCE)0733-9445(1988)114:8(1804), 1804-1826.  
 $A_{conf,max1} = 353600.00$  is the confined core area at levels of member with hoops and is calculated as the area of core enclosed by the center lines of the external perimeter hoops.  
 $A_{conf,min1} = 293525.00$  is the confined core area at midway between the levels of hoops and is calculated by reducing all the dimensions of the area  $A_{conf,max1}$  by a length equal to half the clear spacing between external hoops.  
 $A_{noConf1} = 158733.333$  is the unconfined external core area which is equal to  $b_i^2/6$  as defined at (A.2).  
 $ase2 (>= ase1) = \text{Max}(((A_{conf,max2} - A_{noConf2}) / A_{conf,max2}) * (A_{conf,min2} / A_{conf,max2}), 0) = 0.45746528$   
 The definitions of  $A_{noConf}$ ,  $A_{conf,min}$  and  $A_{conf,max}$  are derived from generalization of the rectangular sections confinement, which is expressed by (5.4d).  
 The generalization is done according to Mander, J., Priestley, M., and Park, R. (1988) "Theoretical Stress-Strain Model for Confined Concrete."  
 J. Struct. Eng., 10.1061/(ASCE)0733-9445(1988)114:8(1804), 1804-1826.  
 $A_{conf,max2} = 171264.00$  is the confined core area at levels of member with hoops and is calculated as the area of core enclosed by the center lines of the internal perimeter hoops.  
 $A_{conf,min2} = 54741.00$  is the confined core area at midway between the levels of hoops and is calculated by reducing all the dimensions of the area  $A_{conf,max2}$  by a length equal to half the clear spacing between internal hoops.  
 $A_{noConf2} = 106242.667$  is the unconfined internal core area which is equal to  $b_i^2/6$  as defined at (A.2).  
 $psh_{min} * F_{ywe} = \text{Min}(psh_x * F_{ywe}, psh_y * F_{ywe}) = 3.3968$

$psh_x * F_{ywe} = psh1 * F_{ywe1} + ps2 * F_{ywe2} = 3.3968$   
 $psh1((5.4d), TBDY) = L_{stir1} * A_{stir1} / (A_{sec} * s1) = 0.00367709$   
 $L_{stir1}$  (Length of stirrups along Y) = 2060.00  
 $A_{stir1}$  (stirrups area) = 78.53982  
 $psh2(5.4d) = L_{stir2} * A_{stir2} / (A_{sec} * s2) = 0.00067082$   
 $L_{stir2}$  (Length of stirrups along Y) = 1468.00  
 $A_{stir2}$  (stirrups area) = 50.26548

$psh_y * F_{ywe} = psh1 * F_{ywe1} + ps2 * F_{ywe2} = 3.3968$   
 $psh1((5.4d), TBDY) = L_{stir1} * A_{stir1} / (A_{sec} * s1) = 0.00367709$

Lstir1 (Length of stirrups along X) = 2060.00  
 Astir1 (stirrups area) = 78.53982  
 $psh2 ((5.4d), TBDY) = Lstir2 * Astir2 / (Asec * s2) = 0.00067082$   
 Lstir2 (Length of stirrups along X) = 1468.00  
 Astir2 (stirrups area) = 50.26548

Asec = 440000.00

s1 = 100.00

s2 = 250.00

fywe1 = 781.25

fywe2 = 781.25

fce = 30.00

From ((5.A5), TBDY), TBDY: cc = 0.00471045

c = confinement factor = 1.27105

y1 = 0.00083886

sh1 = 0.00268436

ft1 = 314.5735

fy1 = 262.1446

su1 = 0.00268436

using (30) in Biskinis/Fardis (2013) multiplied with shear\_factor  
 and also multiplied by the shear\_factor according to 15.7.1.4, with  
 Shear\_factor = 1.00

lo/lou,min = lb/ld = 0.13907892

su1 = 0.4\*esu1\_nominal ((5.5), TBDY) = 0.032

From table 5A.1, TBDY: esu1\_nominal = 0.08,

For calculation of esu1\_nominal and y1, sh1,ft1,fy1, it is considered  
 characteristic value fsy1 = fs1/1.2, from table 5.1, TBDY.

y1, sh1,ft1,fy1, are also multiplied by  $\text{Min}(1, 1.25 * (lb/ld)^{2/3})$ , from 10.3.5, ASCE 41-17.

with fs1 = (fs,jacket\*Asl,ten,jacket + fs,core\*Asl,ten,core)/Asl,ten = 262.1446

with Es1 = (Es,jacket\*Asl,ten,jacket + Es,core\*Asl,ten,core)/Asl,ten = 200000.00

y2 = 0.00083886

sh2 = 0.00268436

ft2 = 314.5735

fy2 = 262.1446

su2 = 0.00268436

using (30) in Biskinis/Fardis (2013) multiplied with shear\_factor  
 and also multiplied by the shear\_factor according to 15.7.1.4, with  
 Shear\_factor = 1.00

lo/lou,min = lb/lb,min = 0.13907892

su2 = 0.4\*esu2\_nominal ((5.5), TBDY) = 0.032

From table 5A.1, TBDY: esu2\_nominal = 0.08,

For calculation of esu2\_nominal and y2, sh2,ft2,fy2, it is considered  
 characteristic value fsy2 = fs2/1.2, from table 5.1, TBDY.

y1, sh1,ft1,fy1, are also multiplied by  $\text{Min}(1, 1.25 * (lb/ld)^{2/3})$ , from 10.3.5, ASCE 41-17.

with fs2 = (fs,jacket\*Asl,com,jacket + fs,core\*Asl,com,core)/Asl,com = 262.1446

with Es2 = (Es,jacket\*Asl,com,jacket + Es,core\*Asl,com,core)/Asl,com = 200000.00

yv = 0.00083886

shv = 0.00268436

ftv = 314.5735

fyv = 262.1446

suv = 0.00268436

using (30) in Biskinis/Fardis (2013) multiplied with shear\_factor  
 and also multiplied by the shear\_factor according to 15.7.1.4, with  
 Shear\_factor = 1.00

lo/lou,min = lb/ld = 0.13907892

suv = 0.4\*esuv\_nominal ((5.5), TBDY) = 0.032

From table 5A.1, TBDY: esuv\_nominal = 0.08,

considering characteristic value fsyv = fsv/1.2, from table 5.1, TBDY

For calculation of esuv\_nominal and yv, shv,ftv,fyv, it is considered  
 characteristic value fsyv = fsv/1.2, from table 5.1, TBDY.

y1, sh1,ft1,fy1, are also multiplied by  $\text{Min}(1, 1.25 * (lb/ld)^{2/3})$ , from 10.3.5, ASCE 41-17.

with fsv = (fs,jacket\*Asl,mid,jacket + fs,mid\*Asl,mid,core)/Asl,mid = 262.1446

with Esv = (Es,jacket\*Asl,mid,jacket + Es,mid\*Asl,mid,core)/Asl,mid = 200000.00

1 = Asl,ten/(b\*d)\*(fs1/fc) = 0.06824101

2 = Asl,com/(b\*d)\*(fs2/fc) = 0.03513975

v = Asl,mid/(b\*d)\*(fsv/fc) = 0.06202846

and confined core properties:

$b = 340.00$   
 $d = 677.00$   
 $d' = 13.00$   
 $f_{cc} (5A.2, TBDY) = 38.13135$   
 $cc (5A.5, TBDY) = 0.00471045$   
 $c = \text{confinement factor} = 1.27105$   
 $1 = A_{sl,ten}/(b*d)*(f_{s1}/f_c) = 0.08384116$   
 $2 = A_{sl,com}/(b*d)*(f_{s2}/f_c) = 0.04317283$   
 $v = A_{sl,mid}/(b*d)*(f_{sv}/f_c) = 0.07620839$   
 Case/Assumption: Unconfined full section - Steel rupture  
 ' satisfies Eq. (4.3)

--->  
 $v < v_{s,y2}$  - LHS eq.(4.5) is satisfied  
 --->  
 $su (4.9) = 0.2584548$   
 $Mu = MRc (4.14) = 5.0296E+008$   
 $u = su (4.1) = 5.1201636E-006$

Calculation of ratio  $l_b/l_d$

Lap Length:  $l_b/l_d = 0.13907892$   
 $l_b = 300.00$   
 $l_d = 2157.049$   
 Calculation of  $l_b$ ,min according to (25.4.3.2), ACI 318-14, using mean values for all the section re-bars.  
 $l_d$ ,min from (25.4.3.2) is multiplied 2 times to account for smooth re-bars (9.1.2, TS500 - No provision in ACI 318)  
 $= 1$   
 $db = 16.66667$   
 Mean strength value of all re-bars:  $f_y = 781.25$   
 Mean concrete strength:  $f_c' = (f_c'_{jacket} * Area_{jacket} + f_c'_{core} * Area_{core}) / Area_{section} = 30.00$ , but  $f_c'^{0.5} \leq 8.3$   
 MPa (22.5.3.1, ACI 318-14)  
 $t = 1.00$   
 $s = 0.80$   
 $e = 1.00$   
 $cb = 25.00$   
 $K_{tr} = 1.7174$   
 $A_{tr} = \text{Min}(A_{tr,x}, A_{tr,y}) = 257.6106$   
 where  $A_{tr,x}$ ,  $A_{tr,y}$  are the sum of the area of all stirrup legs along X and Y loxal axis  
 $s = \text{Max}(s_{external}, s_{internal}) = 250.00$   
 $n = 24.00$

Calculation of  $Mu_{2+}$

Calculation of ultimate curvature  $u$  according to 4.1, Biskinis/Fardis 2013:  
 $u = 4.8099118E-006$   
 $Mu = 2.3387E+008$

with full section properties:

$b = 750.00$   
 $d = 707.00$   
 $d' = 43.00$   
 $v = 0.00102301$   
 $N = 16273.608$   
 $f_c = 30.00$   
 $co (5A.5, TBDY) = 0.002$   
 Final value of  $cu$ :  $cu^* = \text{shear\_factor} * \text{Max}(cu, cc) = 0.01260361$   
 The Shear\_factor is considered equal to 1 (pure moment strength)  
 From (5.4b), TBDY:  $cu = 0.01260361$   
 $we (5.4c) = 0.05179731$   
 $ase ((5.4d), TBDY) = (ase1 * A_{ext} + ase2 * A_{int}) / A_{sec} = 0.45746528$   
 $ase1 = \text{Max}(((A_{conf,max1} - A_{noConf1}) / A_{conf,max1}) * (A_{conf,min1} / A_{conf,max1}), 0) = 0.45746528$   
 The definitions of  $A_{noConf}$ ,  $A_{conf,min}$  and  $A_{conf,max}$  are derived from generalization of the rectangular sections confinement, which is expressed by (5.4d).

The generalization is done according to Mander, J., Priestley, M., and Park, R. (1988)  
"Theoretical Stress-Strain Model for Confined Concrete."

J. Struct. Eng., 10.1061/(ASCE)0733-9445(1988)114:8(1804), 1804-1826.

$A_{conf,max1} = 353600.00$  is the confined core area at levels of member with hoops and  
is calculated as the area of core enclosed by the center lines of the external perimeter hoops.

$A_{conf,min1} = 293525.00$  is the confined core area at midway between the levels of hoops and  
is calculated by reducing all the dimensions of the area  $A_{conf,max1}$  by a length  
equal to half the clear spacing between external hoops.

$A_{noConf1} = 158733.333$  is the unconfined external core area which is equal to  $b_i^2/6$  as defined at (A.2).

$ase2 (>= ase1) = \text{Max}(((A_{conf,max2} - A_{noConf2})/A_{conf,max2}) * (A_{conf,min2}/A_{conf,max2}), 0) = 0.45746528$

The definitions of  $A_{noConf}$ ,  $A_{conf,min}$  and  $A_{conf,max}$  are derived from generalization  
of the rectangular sections confinement, which is expressed by (5.4d).

The generalization is done according to Mander, J., Priestley, M., and Park, R. (1988)  
"Theoretical Stress-Strain Model for Confined Concrete."

J. Struct. Eng., 10.1061/(ASCE)0733-9445(1988)114:8(1804), 1804-1826.

$A_{conf,max2} = 171264.00$  is the confined core area at levels of member with hoops and  
is calculated as the area of core enclosed by the center lines of the internal perimeter hoops.

$A_{conf,min2} = 54741.00$  is the confined core area at midway between the levels of hoops and  
is calculated by reducing all the dimensions of the area  $A_{conf,max2}$  by a length  
equal to half the clear spacing between internal hoops.

$A_{noConf2} = 106242.667$  is the unconfined internal core area which is equal to  $b_i^2/6$  as defined at (A.2).

$psh_{min} * F_{ywe} = \text{Min}(psh_x * F_{ywe}, psh_y * F_{ywe}) = 3.3968$

$psh_x * F_{ywe} = psh1 * F_{ywe1} + ps2 * F_{ywe2} = 3.3968$

$psh1 ((5.4d), TBDY) = L_{stir1} * A_{stir1} / (A_{sec} * s1) = 0.00367709$

$L_{stir1}$  (Length of stirrups along Y) = 2060.00

$A_{stir1}$  (stirrups area) = 78.53982

$psh2 (5.4d) = L_{stir2} * A_{stir2} / (A_{sec} * s2) = 0.00067082$

$L_{stir2}$  (Length of stirrups along Y) = 1468.00

$A_{stir2}$  (stirrups area) = 50.26548

$psh_y * F_{ywe} = psh1 * F_{ywe1} + ps2 * F_{ywe2} = 3.3968$

$psh1 ((5.4d), TBDY) = L_{stir1} * A_{stir1} / (A_{sec} * s1) = 0.00367709$

$L_{stir1}$  (Length of stirrups along X) = 2060.00

$A_{stir1}$  (stirrups area) = 78.53982

$psh2 ((5.4d), TBDY) = L_{stir2} * A_{stir2} / (A_{sec} * s2) = 0.00067082$

$L_{stir2}$  (Length of stirrups along X) = 1468.00

$A_{stir2}$  (stirrups area) = 50.26548

$A_{sec} = 440000.00$

$s1 = 100.00$

$s2 = 250.00$

$f_{ywe1} = 781.25$

$f_{ywe2} = 781.25$

$f_{ce} = 30.00$

From ((5.A5), TBDY), TBDY:  $cc = 0.00471045$

$c = \text{confinement factor} = 1.27105$

$y1 = 0.00083886$

$sh1 = 0.00268436$

$ft1 = 314.5735$

$fy1 = 262.1446$

$su1 = 0.00268436$

using (30) in Biskinis/Fardis (2013) multiplied with shear\_factor  
and also multiplied by the shear\_factor according to 15.7.1.4, with  
 $\text{Shear\_factor} = 1.00$

$l_o/l_{ou,min} = l_b/l_d = 0.13907892$

$su1 = 0.4 * esu1_{nominal} ((5.5), TBDY) = 0.032$

From table 5A.1, TBDY:  $esu1_{nominal} = 0.08$ ,

For calculation of  $esu1_{nominal}$  and  $y1, sh1, ft1, fy1$ , it is considered  
characteristic value  $fsy1 = fs1/1.2$ , from table 5.1, TBDY.

$y1, sh1, ft1, fy1$ , are also multiplied by  $\text{Min}(1, 1.25 * (l_b/l_d)^{2/3})$ , from 10.3.5, ASCE 41-17.

with  $fs1 = (f_{s,jacket} * A_{s,ten,jacket} + f_{s,core} * A_{s,ten,core}) / A_{s,ten} = 262.1446$

with  $Es1 = (E_{s,jacket} * A_{s,ten,jacket} + E_{s,core} * A_{s,ten,core}) / A_{s,ten} = 200000.00$

$y2 = 0.00083886$

$sh2 = 0.00268436$

$ft2 = 314.5735$

$fy2 = 262.1446$

```

su2 = 0.00268436
using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00
lo/lou,min = lb/lb,min = 0.13907892
su2 = 0.4*esu2_nominal ((5.5), TBDY) = 0.032
From table 5A.1, TBDY: esu2_nominal = 0.08,
For calculation of esu2_nominal and y2, sh2,ft2,fy2, it is considered
characteristic value fsy2 = fs2/1.2, from table 5.1, TBDY.
y1, sh1,ft1,fy1, are also multiplied by Min(1,1.25*(lb/lb)^ 2/3), from 10.3.5, ASCE 41-17.
with fs2 = (fs,jacket*Asl,com,jacket + fs,core*Asl,com,core)/Asl,com = 262.1446
with Es2 = (Es,jacket*Asl,com,jacket + Es,core*Asl,com,core)/Asl,com = 200000.00
yv = 0.00083886
shv = 0.00268436
ftv = 314.5735
fyv = 262.1446
suv = 0.00268436
using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00
lo/lou,min = lb/lb = 0.13907892
suv = 0.4*esuv_nominal ((5.5), TBDY) = 0.032
From table 5A.1, TBDY: esuv_nominal = 0.08,
considering characteristic value fsyv = fsv/1.2, from table 5.1, TBDY
For calculation of esuv_nominal and yv, shv,ftv,fyv, it is considered
characteristic value fsyv = fsv/1.2, from table 5.1, TBDY.
y1, sh1,ft1,fy1, are also multiplied by Min(1,1.25*(lb/lb)^ 2/3), from 10.3.5, ASCE 41-17.
with fsv = (fs,jacket*Asl,mid,jacket + fs,mid*Asl,mid,core)/Asl,mid = 262.1446
with Esv = (Es,jacket*Asl,mid,jacket + Es,mid*Asl,mid,core)/Asl,mid = 200000.00
1 = Asl,ten/(b*d)*(fs1/fc) = 0.0187412
2 = Asl,com/(b*d)*(fs2/fc) = 0.03639521
v = Asl,mid/(b*d)*(fsv/fc) = 0.03308184
and confined core properties:
b = 690.00
d = 677.00
d' = 13.00
fcc (5A.2, TBDY) = 38.13135
cc (5A.5, TBDY) = 0.00471045
c = confinement factor = 1.27105
1 = Asl,ten/(b*d)*(fs1/fc) = 0.02127357
2 = Asl,com/(b*d)*(fs2/fc) = 0.04131304
v = Asl,mid/(b*d)*(fsv/fc) = 0.03755196
Case/Assumption: Unconfined full section - Steel rupture
' satisfies Eq. (4.3)
---->
v < vs,y2 - LHS eq.(4.5) is satisfied
---->
su (4.9) = 0.21062322
Mu = MRc (4.14) = 2.3387E+008
u = su (4.1) = 4.8099118E-006
-----

Calculation of ratio lb/lb
-----
Lap Length: lb/lb = 0.13907892
lb = 300.00
lb = 2157.049
Calculation of lb,min according to (25.4.3.2), ACI 318-14, using mean values for all the section re-bars.
lb,min from (25.4.3.2) is multiplied 2 times to account for smooth re-bars (9.1.2, TS500 - No provision in ACI 318)
= 1
db = 16.66667
Mean strength value of all re-bars: fy = 781.25
Mean concrete strength: fc' = (fc'_jacket*Area_jacket + fc'_core*Area_core)/Area_section = 30.00, but fc'^0.5 <= 8.3
MPa (22.5.3.1, ACI 318-14)
t = 1.00
s = 0.80
e = 1.00

```

$cb = 25.00$   
 $Ktr = 1.7174$   
 $Atr = \text{Min}(Atr_x, Atr_y) = 257.6106$   
 where  $Atr_x, Atr_y$  are the sum of the area of all stirrup legs along X and Y local axis  
 $s = \text{Max}(s_{\text{external}}, s_{\text{internal}}) = 250.00$   
 $n = 24.00$

Calculation of  $\mu_2$ -

Calculation of ultimate curvature  $\mu$  according to 4.1, Biskinis/Fardis 2013:

$\mu = 5.1201636E-006$   
 $\mu_u = 5.0296E+008$

with full section properties:

$b = 400.00$   
 $d = 707.00$   
 $d' = 43.00$   
 $v = 0.00191815$   
 $N = 16273.608$   
 $f_c = 30.00$   
 $\alpha_1(5A.5, \text{TB DY}) = 0.002$

Final value of  $\mu_u$ :  $\mu_u^* = \text{shear\_factor} * \text{Max}(\mu_u, \mu_c) = 0.01260361$

The Shear\_factor is considered equal to 1 (pure moment strength)

From (5.4b), TB DY:  $\mu_u = 0.01260361$

we (5.4c) = 0.05179731

$\alpha_{se}((5.4d), \text{TB DY}) = (\alpha_{se1} * A_{ext} + \alpha_{se2} * A_{int}) / A_{sec} = 0.45746528$

$\alpha_{se1} = \text{Max}(((A_{conf,max1} - A_{noConf1}) / A_{conf,max1}) * (A_{conf,min1} / A_{conf,max1}), 0) = 0.45746528$

The definitions of  $A_{noConf}$ ,  $A_{conf,min}$  and  $A_{conf,max}$  are derived from generalization of the rectangular sections confinement, which is expressed by (5.4d).

The generalization is done according to Mander, J., Priestley, M., and Park, R. (1988)

"Theoretical Stress-Strain Model for Confined Concrete."

J. Struct. Eng., 10.1061/(ASCE)0733-9445(1988)114:8(1804), 1804-1826.

$A_{conf,max1} = 353600.00$  is the confined core area at levels of member with hoops and is calculated as the area of core enclosed by the center lines of the external perimeter hoops.

$A_{conf,min1} = 293525.00$  is the confined core area at midway between the levels of hoops and is calculated by reducing all the dimensions of the area  $A_{conf,max1}$  by a length equal to half the clear spacing between external hoops.

$A_{noConf1} = 158733.333$  is the unconfined external core area which is equal to  $b_i^2/6$  as defined at (A.2).

$\alpha_{se2} (\geq \alpha_{se1}) = \text{Max}(((A_{conf,max2} - A_{noConf2}) / A_{conf,max2}) * (A_{conf,min2} / A_{conf,max2}), 0) = 0.45746528$

The definitions of  $A_{noConf}$ ,  $A_{conf,min}$  and  $A_{conf,max}$  are derived from generalization of the rectangular sections confinement, which is expressed by (5.4d).

The generalization is done according to Mander, J., Priestley, M., and Park, R. (1988)

"Theoretical Stress-Strain Model for Confined Concrete."

J. Struct. Eng., 10.1061/(ASCE)0733-9445(1988)114:8(1804), 1804-1826.

$A_{conf,max2} = 171264.00$  is the confined core area at levels of member with hoops and is calculated as the area of core enclosed by the center lines of the internal perimeter hoops.

$A_{conf,min2} = 54741.00$  is the confined core area at midway between the levels of hoops and is calculated by reducing all the dimensions of the area  $A_{conf,max2}$  by a length equal to half the clear spacing between internal hoops.

$A_{noConf2} = 106242.667$  is the unconfined internal core area which is equal to  $b_i^2/6$  as defined at (A.2).

$psh_{min} * F_{ywe} = \text{Min}(psh_x * F_{ywe}, psh_y * F_{ywe}) = 3.3968$

$psh_x * F_{ywe} = psh1 * F_{ywe1} + psh2 * F_{ywe2} = 3.3968$

$psh1((5.4d), \text{TB DY}) = L_{stir1} * A_{stir1} / (A_{sec} * s1) = 0.00367709$

$L_{stir1}$  (Length of stirrups along Y) = 2060.00

$A_{stir1}$  (stirrups area) = 78.53982

$psh2(5.4d) = L_{stir2} * A_{stir2} / (A_{sec} * s2) = 0.00067082$

$L_{stir2}$  (Length of stirrups along Y) = 1468.00

$A_{stir2}$  (stirrups area) = 50.26548

$psh_y * F_{ywe} = psh1 * F_{ywe1} + psh2 * F_{ywe2} = 3.3968$

$psh1((5.4d), \text{TB DY}) = L_{stir1} * A_{stir1} / (A_{sec} * s1) = 0.00367709$

$L_{stir1}$  (Length of stirrups along X) = 2060.00

Astir1 (stirrups area) = 78.53982  
 psh2 ((5.4d), TBDY) = Lstir2\*Astir2/(Asec\*s2) = 0.00067082  
 Lstir2 (Length of stirrups along X) = 1468.00  
 Astir2 (stirrups area) = 50.26548

Asec = 440000.00

s1 = 100.00

s2 = 250.00

fywe1 = 781.25

fywe2 = 781.25

fce = 30.00

From ((5.A5), TBDY), TBDY: cc = 0.00471045

c = confinement factor = 1.27105

y1 = 0.00083886

sh1 = 0.00268436

ft1 = 314.5735

fy1 = 262.1446

su1 = 0.00268436

using (30) in Biskinis/Fardis (2013) multiplied with shear\_factor  
 and also multiplied by the shear\_factor according to 15.7.1.4, with  
 Shear\_factor = 1.00

lo/lou,min = lb/ld = 0.13907892

su1 = 0.4\*esu1\_nominal ((5.5), TBDY) = 0.032

From table 5A.1, TBDY: esu1\_nominal = 0.08,

For calculation of esu1\_nominal and y1, sh1,ft1,fy1, it is considered  
 characteristic value fsy1 = fs1/1.2, from table 5.1, TBDY.

y1, sh1,ft1,fy1, are also multiplied by Min(1,1.25\*(lb/ld)^2/3), from 10.3.5, ASCE 41-17.

with fs1 = (fs,jacket\*Asl,ten,jacket + fs,core\*Asl,ten,core)/Asl,ten = 262.1446

with Es1 = (Es,jacket\*Asl,ten,jacket + Es,core\*Asl,ten,core)/Asl,ten = 200000.00

y2 = 0.00083886

sh2 = 0.00268436

ft2 = 314.5735

fy2 = 262.1446

su2 = 0.00268436

using (30) in Biskinis/Fardis (2013) multiplied with shear\_factor  
 and also multiplied by the shear\_factor according to 15.7.1.4, with  
 Shear\_factor = 1.00

lo/lou,min = lb/lb,min = 0.13907892

su2 = 0.4\*esu2\_nominal ((5.5), TBDY) = 0.032

From table 5A.1, TBDY: esu2\_nominal = 0.08,

For calculation of esu2\_nominal and y2, sh2,ft2,fy2, it is considered  
 characteristic value fsy2 = fs2/1.2, from table 5.1, TBDY.

y1, sh1,ft1,fy1, are also multiplied by Min(1,1.25\*(lb/ld)^2/3), from 10.3.5, ASCE 41-17.

with fs2 = (fs,jacket\*Asl,com,jacket + fs,core\*Asl,com,core)/Asl,com = 262.1446

with Es2 = (Es,jacket\*Asl,com,jacket + Es,core\*Asl,com,core)/Asl,com = 200000.00

yv = 0.00083886

shv = 0.00268436

ftv = 314.5735

fyv = 262.1446

suv = 0.00268436

using (30) in Biskinis/Fardis (2013) multiplied with shear\_factor  
 and also multiplied by the shear\_factor according to 15.7.1.4, with  
 Shear\_factor = 1.00

lo/lou,min = lb/ld = 0.13907892

suv = 0.4\*esuv\_nominal ((5.5), TBDY) = 0.032

From table 5A.1, TBDY: esuv\_nominal = 0.08,

considering characteristic value fsyv = fsv/1.2, from table 5.1, TBDY

For calculation of esuv\_nominal and yv, shv,ftv,fyv, it is considered  
 characteristic value fsyv = fsv/1.2, from table 5.1, TBDY.

y1, sh1,ft1,fy1, are also multiplied by Min(1,1.25\*(lb/ld)^2/3), from 10.3.5, ASCE 41-17.

with fsv = (fs,jacket\*Asl,mid,jacket + fs,mid\*Asl,mid,core)/Asl,mid = 262.1446

with Esv = (Es,jacket\*Asl,mid,jacket + Es,mid\*Asl,mid,core)/Asl,mid = 200000.00

1 = Asl,ten/(b\*d)\*(fs1/fc) = 0.06824101

2 = Asl,com/(b\*d)\*(fs2/fc) = 0.03513975

v = Asl,mid/(b\*d)\*(fsv/fc) = 0.06202846

and confined core properties:

b = 340.00

$d = 677.00$   
 $d' = 13.00$   
 $f_{cc} (5A.2, TBDY) = 38.13135$   
 $cc (5A.5, TBDY) = 0.00471045$   
 $c = \text{confinement factor} = 1.27105$   
 $1 = A_{sl,ten}/(b*d)*(f_{s1}/f_c) = 0.08384116$   
 $2 = A_{sl,com}/(b*d)*(f_{s2}/f_c) = 0.04317283$   
 $v = A_{sl,mid}/(b*d)*(f_{sv}/f_c) = 0.07620839$   
 Case/Assumption: Unconfined full section - Steel rupture  
 ' satisfies Eq. (4.3)

--->  
 $v < v_{s,y2}$  - LHS eq.(4.5) is satisfied  
 --->  
 $su (4.9) = 0.2584548$   
 $Mu = MRc (4.14) = 5.0296E+008$   
 $u = su (4.1) = 5.1201636E-006$

Calculation of ratio  $l_b/l_d$

Lap Length:  $l_b/l_d = 0.13907892$   
 $l_b = 300.00$   
 $l_d = 2157.049$   
 Calculation of  $l_b, \min$  according to (25.4.3.2), ACI 318-14, using mean values for all the section re-bars.  
 $l_d, \min$  from (25.4.3.2) is multiplied 2 times to account for smooth re-bars (9.1.2, TS500 - No provision in ACI 318)  
 $= 1$   
 $db = 16.66667$   
 Mean strength value of all re-bars:  $f_y = 781.25$   
 Mean concrete strength:  $f_c' = (f_c'_{jacket} * Area_{jacket} + f_c'_{core} * Area_{core}) / Area_{section} = 30.00$ , but  $f_c'^{0.5} \leq 8.3$   
 MPa (22.5.3.1, ACI 318-14)  
 $t = 1.00$   
 $s = 0.80$   
 $e = 1.00$   
 $cb = 25.00$   
 $K_{tr} = 1.7174$   
 $A_{tr} = \min(A_{tr,x}, A_{tr,y}) = 257.6106$   
 where  $A_{tr,x}, A_{tr,y}$  are the sum of the area of all stirrup legs along X and Y loxal axis  
 $s = \max(s_{external}, s_{internal}) = 250.00$   
 $n = 24.00$

Calculation of Shear Strength  $V_r = \min(V_{r1}, V_{r2}) = 1.0392E+006$

Calculation of Shear Strength at edge 1,  $V_{r1} = 1.0392E+006$   
 $V_{r1} = V_{Col} ((10.3), ASCE 41-17) = knl * V_{Col0}$   
 $V_{Col0} = 1.0392E+006$   
 $knl = 1$  (zero step-static loading)

NOTE: In expression (10-3) ' $V_s = A_v * f_y * d / s$ ' is replaced by ' $V_s + f * V_f$ '  
 where  $V_f$  is the contribution of FRPs (11.3), ACI 440).

$= 1$  (normal-weight concrete)  
 Mean concrete strength:  $f_c' = (f_c'_{jacket} * Area_{jacket} + f_c'_{core} * Area_{core}) / Area_{section} = 30.00$ , but  $f_c'^{0.5} \leq 8.3$   
 MPa (22.5.3.1, ACI 318-14)  
 $M/Vd = 4.00$   
 $Mu = 1308.675$   
 $Vu = 0.0001715$   
 $d = 0.8 * h = 600.00$   
 $Nu = 16273.608$   
 $Ag = 300000.00$   
 From (11.5.4.8), ACI 318-14:  $V_s = V_{sjacket} + V_{s,core} = 1.0138E+006$   
 where:  
 $V_{sjacket} = V_{sj1} + V_{sj2} = 903207.888$   
 $V_{sj1} = 314159.265$  is calculated for section web jacket, with:  
 $d = 320.00$



$A_v = 157079.633$   
 $f_y = 625.00$   
 $s = 100.00$   
 $V_{s,j1}$  is multiplied by  $Col,j1 = 1.00$   
 $s/d = 0.3125$   
 $V_{s,j2} = 589048.623$  is calculated for section flange jacket, with:  
 $d = 600.00$   
 $A_v = 157079.633$   
 $f_y = 625.00$   
 $s = 100.00$   
 $V_{s,j2}$  is multiplied by  $Col,j2 = 1.00$   
 $s/d = 0.16666667$   
 $V_{s,core} = V_{s,c1} + V_{s,c2} = 110584.061$   
 $V_{s,c1} = 0.00$  is calculated for section web core, with:  
 $d = 160.00$   
 $A_v = 100530.965$   
 $f_y = 625.00$   
 $s = 250.00$   
 $V_{s,c1}$  is multiplied by  $Col,c1 = 0.00$   
 $s/d = 1.5625$   
 $V_{s,c2} = 110584.061$  is calculated for section flange core, with:  
 $d = 440.00$   
 $A_v = 100530.965$   
 $f_y = 625.00$   
 $s = 250.00$   
 $V_{s,c2}$  is multiplied by  $Col,c2 = 1.00$   
 $s/d = 0.56818182$   
 $V_f ((11-3)-(11.4), ACI 440) = 0.00$   
 From (11-11), ACI 440:  $V_s + V_f \leq 873250.061$   
 $bw = 400.00$

Calculation of Shear Strength at edge 2,  $V_{r2} = 1.0392E+006$   
 $V_{r2} = V_{Col} ((10.3), ASCE 41-17) = knl * V_{Col0}$   
 $V_{Col0} = 1.0392E+006$   
 $knl = 1$  (zero step-static loading)

NOTE: In expression (10-3) ' $V_s = A_v * f_y * d / s$ ' is replaced by ' $V_s + f * V_f$ ' where  $V_f$  is the contribution of FRPs (11.3), ACI 440).

$= 1$  (normal-weight concrete)  
 Mean concrete strength:  $f_c' = (f_c'_{jacket} * Area_{jacket} + f_c'_{core} * Area_{core}) / Area_{section} = 30.00$ , but  $f_c'^{0.5} \leq 8.3$  MPa (22.5.3.1, ACI 318-14)  
 $M/Vd = 4.00$   
 $M_u = 1308.675$   
 $V_u = 0.0001715$   
 $d = 0.8 * h = 600.00$   
 $N_u = 16273.608$   
 $A_g = 300000.00$   
 From (11.5.4.8), ACI 318-14:  $V_s = V_{sjacket} + V_{s,core} = 1.0138E+006$   
 where:  
 $V_{sjacket} = V_{sj1} + V_{sj2} = 903207.888$   
 $V_{sj1} = 314159.265$  is calculated for section web jacket, with:  
 $d = 320.00$   
 $A_v = 157079.633$   
 $f_y = 625.00$   
 $s = 100.00$   
 $V_{sj1}$  is multiplied by  $Col,j1 = 1.00$   
 $s/d = 0.3125$   
 $V_{sj2} = 589048.623$  is calculated for section flange jacket, with:  
 $d = 600.00$   
 $A_v = 157079.633$   
 $f_y = 625.00$   
 $s = 100.00$   
 $V_{sj2}$  is multiplied by  $Col,j2 = 1.00$   
 $s/d = 0.16666667$   
 $V_{s,core} = V_{s,c1} + V_{s,c2} = 110584.061$

V<sub>s,c1</sub> = 0.00 is calculated for section web core, with:

d = 160.00

A<sub>v</sub> = 100530.965

f<sub>y</sub> = 625.00

s = 250.00

V<sub>s,c1</sub> is multiplied by Col,c1 = 0.00

s/d = 1.5625

V<sub>s,c2</sub> = 110584.061 is calculated for section flange core, with:

d = 440.00

A<sub>v</sub> = 100530.965

f<sub>y</sub> = 625.00

s = 250.00

V<sub>s,c2</sub> is multiplied by Col,c2 = 1.00

s/d = 0.56818182

V<sub>f</sub> ((11-3)-(11.4), ACI 440) = 0.00

From (11-11), ACI 440: V<sub>s</sub> + V<sub>f</sub> ≤ 873250.061

b<sub>w</sub> = 400.00

End Of Calculation of Shear Capacity ratio for element: column JLC1 of floor 1  
At local axis: 2

Start Of Calculation of Chord Rotation Capacity for element: column JLC1 of floor 1  
At local axis: 2  
Integration Section: (a)  
Section Type: rcjlc

Constant Properties

Knowledge Factor, = 1.00

Chord Rotation is generally considered as Deformation-Controlled Action according to Table C7-1, ASCE 41-17.

Mean strengths are used for Deformation-Controlled Actions according to 7.5.1.3, ASCE 41-17

Consequently:

Jacket

New material of Primary Member: Concrete Strength, f<sub>c</sub> = f<sub>cm</sub> = 30.00

New material of Primary Member: Steel Strength, f<sub>s</sub> = f<sub>sm</sub> = 625.00

Concrete Elasticity, E<sub>c</sub> = 25742.96

Steel Elasticity, E<sub>s</sub> = 200000.00

Existing Column

New material of Primary Member: Concrete Strength, f<sub>c</sub> = f<sub>cm</sub> = 30.00

New material of Primary Member: Steel Strength, f<sub>s</sub> = f<sub>sm</sub> = 625.00

Concrete Elasticity, E<sub>c</sub> = 25742.96

Steel Elasticity, E<sub>s</sub> = 200000.00

Max Height, H<sub>max</sub> = 750.00

Min Height, H<sub>min</sub> = 400.00

Max Width, W<sub>max</sub> = 750.00

Min Width, W<sub>min</sub> = 400.00

Jacket Thickness, t<sub>j</sub> = 100.00

Cover Thickness, c = 25.00

Element Length, L = 3000.00

Primary Member

Smooth Bars

Ductile Steel

With Detailing for Earthquake Resistance (including stirrups closed at 135°)

Longitudinal Bars With Ends Lapped Starting at the End Sections

Lap Length l<sub>b</sub> = 300.00

No FRP Wrapping

Stepwise Properties

Bending Moment, M = -459842.936

Shear Force, V<sub>2</sub> = -7609.421

Shear Force, V<sub>3</sub> = 213.4386

Axial Force,  $F = -17779.344$   
 Longitudinal Reinforcement Area Distribution (in 2 divisions)  
   -Tension:  $As_t = 0.00$   
   -Compression:  $As_c = 5353.274$   
 Longitudinal Reinforcement Area Distribution (in 3 divisions)  
   -Tension:  $As_{t,ten} = 1137.257$   
   -Compression:  $As_{c,com} = 2208.54$   
   -Middle:  $As_{mid} = 2007.478$   
 Longitudinal External Reinforcement Area Distribution (in 3 divisions)  
   -Tension:  $As_{t,ten,jacket} = 829.3805$   
   -Compression:  $As_{c,com,jacket} = 1746.726$   
   -Middle:  $As_{mid,jacket} = 1545.664$   
 Longitudinal Internal Reinforcement Area Distribution (in 3 divisions)  
   -Tension:  $As_{t,ten,core} = 307.8761$   
   -Compression:  $As_{c,com,core} = 461.8141$   
   -Middle:  $As_{mid,core} = 461.8141$   
 Mean Diameter of Tension Reinforcement,  $Db_L = 16.80$

New component: From table 7-7, ASCE 41\_17: Final chord rotation Capacity  $u_R = 1.0^*$   $u = 0.04038849$   
 $u = y + p = 0.04038849$

- Calculation of  $y$  -

$y = (M_y * L_s / 3) / E_{eff} = 0.00141607$  ((4.29), Biskinis Phd))  
 $M_y = 2.8709E+008$   
 $L_s = M/V$  (with  $L_s > 0.1 * L$  and  $L_s < 2 * L$ ) = 2154.45  
 From table 10.5, ASCE 41\_17:  $E_{eff} = factor * E_c * I_g = 1.4560E+014$   
 $factor = 0.30$   
 $A_g = 440000.00$   
 Mean concrete strength:  $fc' = (fc'_{jacket} * Area_{jacket} + fc'_{core} * Area_{core}) / Area_{section} = 30.00$   
 $N = 17779.344$   
 $E_c * I_g = E_{c,jacket} * I_{g,jacket} + E_{c,core} * I_{g,core} = 4.8532E+014$

Calculation of Yielding Moment  $M_y$

Calculation of  $y$  and  $M_y$  according to Annex 7 -

Assuming neutral axis within flange ( $y < t/d$ , compression zone rectangular) with:  
 flange width,  $b = 750.00$   
 web width,  $b_w = 400.00$   
 flange thickness,  $t = 400.00$

$y = \text{Min}(y_{ten}, y_{com})$   
 $y_{ten} = 2.1455196E-006$   
 with ((10.1), ASCE 41-17)  $f_y = \text{Min}(f_y, 1.25 * f_y * (I_b / I_d)^{2/3}) = 243.3535$   
 $d = 707.00$   
 $y = 0.19784983$   
 $A = 0.01023354$   
 $B = 0.00454395$   
 with  $p_t = 0.00434791$   
 $p_c = 0.00416509$   
 $p_v = 0.00378591$   
 $N = 17779.344$   
 $b = 750.00$   
 $" = 0.06082037$   
 $y_{comp} = 1.5202265E-005$   
 with  $fc = 30.00$   
 $E_c = 25742.96$   
 $y = 0.19516753$   
 $A = 0.01001583$   
 $B = 0.00440616$

with  $E_s = 200000.00$   
 CONFIRMATION:  $y = 0.19594836 < t/d$

---

Calculation of ratio  $l_b/l_d$

---

Lap Length:  $l_d/l_{d,min} = 0.17384865$   
 $l_b = 300.00$   
 $l_d = 1725.639$   
 Calculation of  $l$  according to (25.4.3.2), ACI 318-14, using mean values for all the section re-bars.  
 $l_{d,min}$  from (25.4.3.2) is multiplied 2 times to account for smooth re-bars (10.3.5, ASCE 41-17)  
 $= 1$   
 $db = 16.66667$   
 Mean strength value of all re-bars:  $f_y = 625.00$   
 Mean concrete strength:  $f'_c = (f'_{c,jacket} \cdot Area_{jacket} + f'_{c,core} \cdot Area_{core}) / Area_{section} = 30.00$ , but  $f'_c^{0.5} \leq 8.3$  MPa (22.5.3.1, ACI 318-14)  
 $t = 1.00$   
 $s = 0.80$   
 $e = 1.00$   
 $cb = 25.00$   
 $K_{tr} = 1.7174$   
 $A_{tr} = \text{Min}(A_{tr,x}, A_{tr,y}) = 257.6106$   
 where  $A_{tr,x}$ ,  $A_{tr,y}$  are the sum of the area of all stirrup legs along X and Y local axis  
 $s = \text{Max}(s_{external}, s_{internal}) = 250.00$   
 $n = 24.00$

---

- Calculation of  $p$  -

---

From table 10-8:  $p = 0.03897242$   
 with:

- Columns controlled by inadequate development or splicing along the clear height because  $l_b/l_d < 1$   
 shear control ratio  $V_y E / V_{col} E = 0.32266369$   
 $d = d_{external} = 707.00$   
 $s = s_{external} = 0.00$
- $t = s_1 + s_2 + 2 \cdot t_f / b_w \cdot (f_{fe} / f_s) = 0.00434791$   
 jacket:  $s_1 = A_{v1} \cdot L_{stir1} / (s_1 \cdot A_g) = 0.00367709$   
 $A_{v1} = 78.53982$ , is the area of every stirrup parallel to loading (shear) direction  
 $L_{stir1} = 2060.00$ , is the total Length of all stirrups parallel to loading (shear) direction  
 $s_1 = 100.00$   
 core:  $s_2 = A_{v2} \cdot L_{stir2} / (s_2 \cdot A_g) = 0.00067082$   
 $A_{v2} = 50.26548$ , is the area of every stirrup parallel to loading (shear) direction  
 $L_{stir2} = 1468.00$ , is the total Length of all stirrups parallel to loading (shear) direction  
 $s_2 = 250.00$

The term  $2 \cdot t_f / b_w \cdot (f_{fe} / f_s)$  is implemented to account for FRP contribution  
 where  $f = 2 \cdot t_f / b_w$  is FRP ratio (EC8 - 3, A.4.4.3(6)) and  $f_{fe} / f_s$  normalises  $f$  to steel strength  
 All these variables have already been given in Shear control ratio calculation.  
 For the normalisation  $f_s$  of jacket is used.  
 $NUD = 17779.344$   
 $A_g = 440000.00$   
 $f'_{cE} = (f'_{c,jacket} \cdot Area_{jacket} + f'_{c,core} \cdot Area_{core}) / section\_area = 30.00$   
 $f_{yIE} = (f_{y,ext\_Long\_Reinf} \cdot Area_{ext\_Long\_Reinf} + f_{y,int\_Long\_Reinf} \cdot Area_{int\_Long\_Reinf}) / Area_{Tot\_Long\_Rein} = 625.00$   
 $f_{yTE} = (f_{y,ext\_Trans\_Reinf} \cdot s_1 + f_{y,int\_Trans\_Reinf} \cdot s_2) / (s_1 + s_2) = 625.00$   
 $p_l = Area_{Tot\_Long\_Rein} / (b \cdot d) = 0.01009575$   
 $b = 750.00$   
 $d = 707.00$   
 $f'_{cE} = 30.00$

---

End Of Calculation of Chord Rotation Capacity for element: column JLC1 of floor 1  
 At local axis: 2  
 Integration Section: (a)

---

## Calculation No. 11

column C1, Floor 1


Limit State: Collapse Prevention (data interpolation between analysis steps 1 and 2)

Analysis: Uniform +X

Check: Shear capacity  $VR_d$

Edge: Start

Local Axis: (3)



Start Of Calculation of Shear Capacity for element: column JLC1 of floor 1

At local axis: 3

Integration Section: (a)

Section Type: rcjlc

Constant Properties

Knowledge Factor,  $\gamma = 1.00$

Member Shear Force is generally considered as Force-Controlled Action according to Table C7-1, ASCE 41-17.

Lower-bound strengths are used for Force-Controlled Actions according to 7.5.1.3, ASCE 41-17

Consequently:

Jacket

New material of Primary Member: Concrete Strength,  $f_c = f_{c\_lower\_bound} = 20.00$

New material of Primary Member: Steel Strength,  $f_s = f_{s\_lower\_bound} = 500.00$

Concrete Elasticity,  $E_c = 25742.96$

Steel Elasticity,  $E_s = 200000.00$

Existing Column

New material of Primary Member: Concrete Strength,  $f_c = f_{c\_lower\_bound} = 20.00$

New material of Primary Member: Steel Strength,  $f_s = f_{s\_lower\_bound} = 500.00$

Concrete Elasticity,  $E_c = 25742.96$

Steel Elasticity,  $E_s = 200000.00$

#####

Note: Especially for the calculation of  $\gamma$  for displacement ductility demand, the expected (mean value) strengths are used (7.5.1.3, ASCE 41-17) because bending is considered as Deformation-Controlled Action (Table C7-1, ASCE 41-17).

Jacket

New material: Concrete Strength,  $f_c = f_{cm} = 30.00$

New material: Steel Strength,  $f_s = f_{sm} = 625.00$

Existing Column

New material: Concrete Strength,  $f_c = f_{cm} = 30.00$

New material: Steel Strength,  $f_s = f_{sm} = 625.00$

#####

Max Height,  $H_{max} = 750.00$

Min Height,  $H_{min} = 400.00$

Max Width,  $W_{max} = 750.00$

Min Width,  $W_{min} = 400.00$

Jacket Thickness,  $t_j = 100.00$

Cover Thickness,  $c = 25.00$

Element Length,  $L = 3000.00$

Primary Member

Smooth Bars

Ductile Steel

With Detailing for Earthquake Resistance (including stirrups closed at  $135^\circ$ )

Longitudinal Bars With Ends Lapped Starting at the End Sections

Lap Length  $l_o = l_b = 300.00$

No FRP Wrapping

-----  
Stepwise Properties

-----  
EDGE -A-

Bending Moment,  $M_a = -459842.936$

Shear Force,  $V_a = 213.4386$

EDGE -B-

Bending Moment,  $M_b = -178152.624$

Shear Force,  $V_b = -213.4386$

BOTH EDGES

Axial Force,  $F = -17779.344$

Longitudinal Reinforcement Area Distribution (in 2 divisions)

-Tension:  $A_{sl,t} = 0.00$

-Compression:  $A_{sl,c} = 5353.274$

Longitudinal Reinforcement Area Distribution (in 3 divisions)

-Tension:  $A_{sl,ten} = 1137.257$

-Compression:  $A_{sl,com} = 2208.54$

-Middle:  $A_{sl,mid} = 2007.478$

Mean Diameter of Tension Reinforcement,  $Db_{L,ten} = 16.80$

-----  
New component: From table 7-7, ASCE 41\_17: Final Shear Capacity  $V_R = 1.0 \cdot V_n = 864428.503$

$V_n$  ((10.3), ASCE 41-17) =  $k_n \cdot V_{CoI0} = 864428.503$

$V_{CoI} = 864428.503$

$k_n = 1.00$

displacement\_ductility\_demand = 0.02355546

-----  
NOTE: In expression (10-3) ' $V_s = A_v \cdot f_y \cdot d/s$ ' is replaced by ' $V_s + f \cdot V_f$ '  
where  $V_f$  is the contribution of FRPs (11.3), ACI 440).

-----  
= 1 (normal-weight concrete)

Mean concrete strength:  $f_c' = (f_c'_{jacket} \cdot Area_{jacket} + f_c'_{core} \cdot Area_{core}) / Area_{section} = 20.00$ , but  $f_c'^{0.5} \leq 8.3$   
MPa (22.5.3.1, ACI 318-14)

$M/V_d = 3.59075$

$M_u = 459842.936$

$V_u = 213.4386$

$d = 0.8 \cdot h = 600.00$

$N_u = 17779.344$

$A_g = 300000.00$

From (11.5.4.8), ACI 318-14:  $V_s = V_{sjacket} + V_{s,core} = 811033.559$

where:

$V_{sjacket} = V_{sj1} + V_{sj2} = 722566.31$

$V_{sj1} = 471238.898$  is calculated for section web jacket, with:

$d = 600.00$

$A_v = 157079.633$

$f_y = 500.00$

$s = 100.00$   
 $V_{s,j1}$  is multiplied by  $Col,j1 = 1.00$   
 $s/d = 0.16666667$   
 $V_{s,j2} = 251327.412$  is calculated for section flange jacket, with:  
 $d = 320.00$   
 $A_v = 157079.633$   
 $f_y = 500.00$   
 $s = 100.00$   
 $V_{s,j2}$  is multiplied by  $Col,j2 = 1.00$   
 $s/d = 0.3125$   
 $V_{s,core} = V_{s,c1} + V_{s,c2} = 88467.249$   
 $V_{s,c1} = 88467.249$  is calculated for section web core, with:  
 $d = 440.00$   
 $A_v = 100530.965$   
 $f_y = 500.00$   
 $s = 250.00$   
 $V_{s,c1}$  is multiplied by  $Col,c1 = 1.00$   
 $s/d = 0.56818182$   
 $V_{s,c2} = 0.00$  is calculated for section flange core, with:  
 $d = 160.00$   
 $A_v = 100530.965$   
 $f_y = 500.00$   
 $s = 250.00$   
 $V_{s,c2}$  is multiplied by  $Col,c2 = 0.00$   
 $s/d = 1.5625$   
 $V_f ((11-3)-(11.4), ACI 440) = 0.00$   
 From (11-11), ACI 440:  $V_s + V_f \leq 713005.69$   
 $bw = 400.00$

displacement\_ductility\_demand is calculated as  $\gamma / y$

- Calculation of  $\gamma / y$  for END A -  
 for rotation axis 2 and integ. section (a)

From analysis, chord rotation  $\theta = 3.3356266E-005$   
 $y = (M_y * L_s / 3) / E_{eff} = 0.00141607$  ((4.29), Biskinis Phd))  
 $M_y = 2.8709E+008$   
 $L_s = M/V$  (with  $L_s > 0.1 * L$  and  $L_s < 2 * L$ ) = 2154.45  
 From table 10.5, ASCE 41\_17:  $E_{eff} = factor * E_c * I_g = 1.4560E+014$   
 $factor = 0.30$   
 $A_g = 440000.00$   
 Mean concrete strength:  $f_c' = (f_c'_{jacket} * Area_{jacket} + f_c'_{core} * Area_{core}) / Area_{section} = 30.00$   
 $N = 17779.344$   
 $E_c * I_g = E_c_{jacket} * I_{g,jacket} + E_c_{core} * I_{g,core} = 4.8532E+014$

Calculation of Yielding Moment  $M_y$

Calculation of  $\gamma$  and  $M_y$  according to Annex 7 -

Assuming neutral axis within flange ( $\gamma < t/d$ , compression zone rectangular) with:

flange width,  $b = 750.00$   
 web width,  $bw = 400.00$   
 flange thickness,  $t = 400.00$

$y = \text{Min}(y_{ten}, y_{com})$   
 $y_{ten} = 2.1455196E-006$   
 with ((10.1), ASCE 41-17)  $f_y = \text{Min}(f_y, 1.25 * f_y * (I_b / I_d)^{2/3}) = 243.3535$   
 $d = 707.00$   
 $y = 0.19784983$   
 $A = 0.01023354$   
 $B = 0.00454395$   
 with  $pt = 0.00214476$   
 $pc = 0.00416509$

$p_v = 0.00378591$   
 $N = 17779.344$   
 $b = 750.00$   
 $" = 0.06082037$   
 $y_{comp} = 1.5202265E-005$   
 with  $f_c = 30.00$   
 $E_c = 25742.96$   
 $y = 0.19516753$   
 $A = 0.01001583$   
 $B = 0.00440616$   
 with  $E_s = 200000.00$

CONFIRMATION:  $y = 0.19594836 < t/d$

Calculation of ratio  $I_b/I_d$

Lap Length:  $I_d/I_{d,min} = 0.17384865$

$I_b = 300.00$

$I_d = 1725.639$

Calculation of  $I$  according to (25.4.3.2), ACI 318-14, using mean values for all the section re-bars.

$I_{d,min}$  from (25.4.3.2) is multiplied 2 times to account for smooth re-bars (10.3.5, ASCE 41-17)

$= 1$

$db = 16.66667$

Mean strength value of all re-bars:  $f_y = 625.00$

Mean concrete strength:  $f_c' = (f_c'_{jacket} \cdot Area_{jacket} + f_c'_{core} \cdot Area_{core}) / Area_{section} = 30.00$ , but  $f_c'^{0.5} \leq 8.3$  MPa (22.5.3.1, ACI 318-14)

$t = 1.00$

$s = 0.80$

$e = 1.00$

$cb = 25.00$

$K_{tr} = 1.7174$

$A_{tr} = \text{Min}(A_{tr_x}, A_{tr_y}) = 257.6106$

where  $A_{tr_x}$ ,  $A_{tr_y}$  are the sum of the area of all stirrup legs along X and Y local axis

$s = \text{Max}(s_{external}, s_{internal}) = 250.00$

$n = 24.00$

End Of Calculation of Shear Capacity for element: column JLC1 of floor 1

At local axis: 3

Integration Section: (a)

## Calculation No. 12

column C1, Floor 1

Limit State: Collapse Prevention (data interpolation between analysis steps 1 and 2)



Analysis: Uniform +X

Check: Chord rotation capacity ( $\phi_r$ )

Edge: Start

Local Axis: (3)





Start Of Calculation of Shear Capacity ratio for element: column JLC1 of floor 1

At Shear local axis: 3

(Bending local axis: 2)

Section Type: rcjlcs

Constant Properties

Knowledge Factor,  $\gamma = 1.00$

Mean strength values are used for both shear and moment calculations.

Consequently:

Jacket

New material of Primary Member: Concrete Strength,  $f_c = f_{cm} = 30.00$

New material of Primary Member: Steel Strength,  $f_s = f_{sm} = 625.00$

Concrete Elasticity,  $E_c = 25742.96$

Steel Elasticity,  $E_s = 200000.00$

Existing Column

New material of Primary Member: Concrete Strength,  $f_c = f_{cm} = 30.00$

New material of Primary Member: Steel Strength,  $f_s = f_{sm} = 625.00$

Concrete Elasticity,  $E_c = 25742.96$

Steel Elasticity,  $E_s = 200000.00$

#####

Note: Especially for the calculation of moment strengths,

the above steel re-bar strengths are multiplied by 1.25 according to R18.6.5, ACI 318-14

Jacket

New material: Steel Strength,  $f_s = 1.25 \cdot f_{sm} = 781.25$

Existing Column

New material: Steel Strength,  $f_s = 1.25 \cdot f_{sm} = 781.25$

#####

Max Height,  $H_{max} = 750.00$

Min Height,  $H_{min} = 400.00$

Max Width,  $W_{max} = 750.00$

Min Width,  $W_{min} = 400.00$

Jacket Thickness,  $t_j = 100.00$

Cover Thickness,  $c = 25.00$

Mean Confinement Factor overall section = 1.27105

Element Length,  $L = 3000.00$

Primary Member

Smooth Bars

Ductile Steel

With Detailing for Earthquake Resistance (including stirrups closed at  $135^\circ$ )

Longitudinal Bars With Ends Lapped Starting at the End Sections

Lap Length  $l_o = 300.00$

No FRP Wrapping

Stepwise Properties

At local axis: 3

EDGE -A-

Shear Force,  $V_a = -0.00017144$

EDGE -B-

Shear Force,  $V_b = 0.00017144$

BOTH EDGES

Axial Force,  $F = -16273.608$

Longitudinal Reinforcement Area Distribution (in 2 divisions)

-Tension:  $As_t = 0.00$

-Compression:  $As_c = 5353.274$

Longitudinal Reinforcement Area Distribution (in 3 divisions)

-Tension:  $As_{t,ten} = 1137.257$

-Compression:  $As_{c,com} = 2208.54$

-Middle:  $As_{c,mid} = 2007.478$

Calculation of Shear Capacity ratio,  $V_e/V_r = 0.32266369$

Member Controlled by Flexure ( $V_e/V_r < 1$ )

Calculation of Shear Demand from fig. R18.6.5, ACI 318-14  $V_e = (M_{pr1} + M_{pr2})/l_n = 335307.657$   
with

$M_{pr1} = \text{Max}(Mu_{1+}, Mu_{1-}) = 5.0296E+008$

$Mu_{1+} = 2.3387E+008$ , is the ultimate moment strength at the edge 1 of the member in the actual moment direction which is defined for the static loading combination

$Mu_{1-} = 5.0296E+008$ , is the ultimate moment strength at the edge 1 of the member in the opposite moment direction which is defined for the static loading combination

$M_{pr2} = \text{Max}(Mu_{2+}, Mu_{2-}) = 5.0296E+008$

$Mu_{2+} = 2.3387E+008$ , is the ultimate moment strength at the edge 2 of the member in the actual moment direction which is defined for the static loading combination

$Mu_{2-} = 5.0296E+008$ , is the ultimate moment strength at the edge 2 of the member in the opposite moment direction which is defined for the static loading combination

Calculation of  $Mu_{1+}$

Calculation of ultimate curvature  $\phi_u$  according to 4.1, Biskinis/Fardis 2013:

$\phi_u = 4.8099118E-006$

$M_u = 2.3387E+008$

with full section properties:

$b = 750.00$

$d = 707.00$

$d' = 43.00$

$v = 0.00102301$

$N = 16273.608$

$f_c = 30.00$

$\phi_c$  (5A.5, TBDY) = 0.002

Final value of  $\phi_u$ :  $\phi_u^* = \text{shear\_factor} * \text{Max}(\phi_u, \phi_c) = 0.01260361$

The Shear\_factor is considered equal to 1 (pure moment strength)

From (5.4b), TBDY:  $\phi_u = 0.01260361$

we (5.4c) = 0.05179731

$a_{se}$  ((5.4d), TBDY) =  $(a_{se1} * A_{ext} + a_{se2} * A_{int}) / A_{sec} = 0.45746528$

$a_{se1} = \text{Max}(((A_{conf,max1} - A_{noConf1}) / A_{conf,max1}) * (A_{conf,min1} / A_{conf,max1}), 0) = 0.45746528$

The definitions of  $A_{noConf}$ ,  $A_{conf,min}$  and  $A_{conf,max}$  are derived from generalization of the rectangular sections confinement, which is expressed by (5.4d).

The generalization is done according to Mander, J., Priestley, M., and Park, R. (1988)

"Theoretical Stress-Strain Model for Confined Concrete."

J. Struct. Eng., 10.1061/(ASCE)0733-9445(1988)114:8(1804), 1804-1826.

$A_{conf,max1} = 353600.00$  is the confined core area at levels of member with hoops and is calculated as the area of core enclosed by the center lines of the external perimeter hoops.

$A_{conf,min1} = 293525.00$  is the confined core area at midway between the levels of hoops and is calculated by reducing all the dimensions of the area  $A_{conf,max1}$  by a length equal to half the clear spacing between external hoops.

$A_{noConf1} = 158733.333$  is the unconfined external core area which is equal to  $b_i^2/6$  as defined at (A.2).

$a_{se2} (>= a_{se1}) = \text{Max}(((A_{conf,max2} - A_{noConf2}) / A_{conf,max2}) * (A_{conf,min2} / A_{conf,max2}), 0) = 0.45746528$

The definitions of  $A_{noConf}$ ,  $A_{conf,min}$  and  $A_{conf,max}$  are derived from generalization of the rectangular sections confinement, which is expressed by (5.4d).

The generalization is done according to Mander, J., Priestley, M., and Park, R. (1988)

"Theoretical Stress-Strain Model for Confined Concrete."

J. Struct. Eng., 10.1061/(ASCE)0733-9445(1988)114:8(1804), 1804-1826.

Aconf,max2 = 171264.00 is the confined core area at levels of member with hoops and is calculated as the area of core enclosed by the center lines of the internal perimeter hoops.

Aconf,min2 = 54741.00 is the confined core area at midway between the levels of hoops and is calculated by reducing all the dimensions of the area Aconf,max2 by a length equal to half the clear spacing between internal hoops.

AnoConf2 = 106242.667 is the unconfined internal core area which is equal to  $b_i^2/6$  as defined at (A.2).  
 $psh,min*Fywe = \text{Min}(psh,x*Fywe, psh,y*Fywe) = 3.3968$

-----  
 $psh_x*Fywe = psh1*Fywe1 + ps2*Fywe2 = 3.3968$   
 $psh1 ((5.4d), TBDY) = Lstir1*Astir1/(Asec*s1) = 0.00367709$   
Lstir1 (Length of stirrups along Y) = 2060.00  
Astir1 (stirrups area) = 78.53982  
 $psh2 ((5.4d) = Lstir2*Astir2/(Asec*s2) = 0.00067082$   
Lstir2 (Length of stirrups along Y) = 1468.00  
Astir2 (stirrups area) = 50.26548

-----  
 $psh_y*Fywe = psh1*Fywe1 + ps2*Fywe2 = 3.3968$   
 $psh1 ((5.4d), TBDY) = Lstir1*Astir1/(Asec*s1) = 0.00367709$   
Lstir1 (Length of stirrups along X) = 2060.00  
Astir1 (stirrups area) = 78.53982  
 $psh2 ((5.4d), TBDY) = Lstir2*Astir2/(Asec*s2) = 0.00067082$   
Lstir2 (Length of stirrups along X) = 1468.00  
Astir2 (stirrups area) = 50.26548

-----  
Asec = 440000.00

s1 = 100.00

s2 = 250.00

fywe1 = 781.25

fywe2 = 781.25

fce = 30.00

From ((5.A5), TBDY), TBDY: cc = 0.00471045

c = confinement factor = 1.27105

y1 = 0.00083886

sh1 = 0.00268436

ft1 = 314.5735

fy1 = 262.1446

su1 = 0.00268436

using (30) in Biskinis/Fardis (2013) multiplied with shear\_factor and also multiplied by the shear\_factor according to 15.7.1.4, with Shear\_factor = 1.00

lo/lou,min = lb/lb = 0.13907892

su1 = 0.4\*esu1\_nominal ((5.5), TBDY) = 0.032

From table 5A.1, TBDY: esu1\_nominal = 0.08,

For calculation of esu1\_nominal and y1, sh1,ft1,fy1, it is considered characteristic value fsy1 = fs1/1.2, from table 5.1, TBDY.

y1, sh1,ft1,fy1, are also multiplied by  $\text{Min}(1, 1.25*(lb/lb)^{2/3})$ , from 10.3.5, ASCE 41-17.

with fs1 = (fs,jacket\*Asl,ten,jacket + fs,core\*Asl,ten,core)/Asl,ten = 262.1446

with Es1 = (Es,jacket\*Asl,ten,jacket + Es,core\*Asl,ten,core)/Asl,ten = 200000.00

y2 = 0.00083886

sh2 = 0.00268436

ft2 = 314.5735

fy2 = 262.1446

su2 = 0.00268436

using (30) in Biskinis/Fardis (2013) multiplied with shear\_factor and also multiplied by the shear\_factor according to 15.7.1.4, with Shear\_factor = 1.00

lo/lou,min = lb/lb,min = 0.13907892

su2 = 0.4\*esu2\_nominal ((5.5), TBDY) = 0.032

From table 5A.1, TBDY: esu2\_nominal = 0.08,

For calculation of esu2\_nominal and y2, sh2,ft2,fy2, it is considered characteristic value fsy2 = fs2/1.2, from table 5.1, TBDY.

y1, sh1,ft1,fy1, are also multiplied by  $\text{Min}(1, 1.25*(lb/lb)^{2/3})$ , from 10.3.5, ASCE 41-17.

with fs2 = (fs,jacket\*Asl,com,jacket + fs,core\*Asl,com,core)/Asl,com = 262.1446

with Es2 = (Es,jacket\*Asl,com,jacket + Es,core\*Asl,com,core)/Asl,com = 200000.00

yv = 0.00083886

shv = 0.00268436

```

ftv = 314.5735
fyv = 262.1446
suv = 0.00268436
    using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
    and also multiplied by the shear_factor according to 15.7.1.4, with
    Shear_factor = 1.00
    lo/lo,min = lb/ld = 0.13907892
    suv = 0.4*esuv_nominal ((5.5), TBDY) = 0.032
    From table 5A.1, TBDY: esuv_nominal = 0.08,
    considering characteristic value fsyv = fsv/1.2, from table 5.1, TBDY
    For calculation of esuv_nominal and yv, shv,ftv,fyv, it is considered
    characteristic value fsyv = fsv/1.2, from table 5.1, TBDY.
    y1, sh1,ft1,fy1, are also multiplied by Min(1,1.25*(lb/ld)^2/3), from 10.3.5, ASCE 41-17.
    with fsv = (fsjacket*Asl,mid,jacket + fs,mid*Asl,mid,core)/Asl,mid = 262.1446
    with Esv = (Es,jacket*Asl,mid,jacket + Es,mid*Asl,mid,core)/Asl,mid = 200000.00
    1 = Asl,ten/(b*d)*(fs1/fc) = 0.0187412
    2 = Asl,com/(b*d)*(fs2/fc) = 0.03639521
    v = Asl,mid/(b*d)*(fsv/fc) = 0.03308184
and confined core properties:
b = 690.00
d = 677.00
d' = 13.00
fcc (5A.2, TBDY) = 38.13135
cc (5A.5, TBDY) = 0.00471045
    c = confinement factor = 1.27105
    1 = Asl,ten/(b*d)*(fs1/fc) = 0.02127357
    2 = Asl,com/(b*d)*(fs2/fc) = 0.04131304
    v = Asl,mid/(b*d)*(fsv/fc) = 0.03755196
Case/Assumption: Unconfined full section - Steel rupture
' satisfies Eq. (4.3)
--->
v < vs,y2 - LHS eq.(4.5) is satisfied
--->
su (4.9) = 0.21062322
Mu = MRc (4.14) = 2.3387E+008
u = su (4.1) = 4.8099118E-006
-----

Calculation of ratio lb/ld
-----
Lap Length: lb/ld = 0.13907892
lb = 300.00
ld = 2157.049
Calculation of lb,min according to (25.4.3.2), ACI 318-14, using mean values for all the section re-bars.
ld,min from (25.4.3.2) is multiplied 2 times to account for smooth re-bars (9.1.2, TS500 - No provision in ACI 318)
= 1
db = 16.66667
Mean strength value of all re-bars: fy = 781.25
Mean concrete strength: fc' = (fc'_jacket*Area_jacket + fc'_core*Area_core)/Area_section = 30.00, but fc'^0.5 <= 8.3
MPa (22.5.3.1, ACI 318-14)
t = 1.00
s = 0.80
e = 1.00
cb = 25.00
Ktr = 1.7174
Atr = Min(Atr_x,Atr_y) = 257.6106
where Atr_x, Atr_y are the sum of the area of all stirrup legs along X and Y loxal axis
s = Max(s_external,s_internal) = 250.00
n = 24.00
-----

Calculation of Mu1-
-----

Calculation of ultimate curvature u according to 4.1, Biskinis/Fardis 2013:

```

u = 5.1201636E-006  
Mu = 5.0296E+008

with full section properties:

b = 400.00  
d = 707.00  
d' = 43.00  
v = 0.00191815  
N = 16273.608

fc = 30.00

co (5A.5, TBDY) = 0.002

Final value of cu: cu\* = shear\_factor \* Max( cu, cc) = 0.01260361

The Shear\_factor is considered equal to 1 (pure moment strength)

From (5.4b), TBDY: cu = 0.01260361

we (5.4c) = 0.05179731

ase ((5.4d), TBDY) = (ase1\*Aext+ase2\*Aint)/Asec = 0.45746528

ase1 = Max(((Aconf,max1-AnoConf1)/Aconf,max1)\*(Aconf,min1/Aconf,max1),0) = 0.45746528

The definitions of AnoConf, Aconf,min and Aconf,max are derived from generalization of the rectangular sections confinement, which is expressed by (5.4d).

The generalization is done according to Mander, J., Priestley, M., and Park, R. (1988)

"Theoretical Stress-Strain Model for Confined Concrete."

J. Struct. Eng., 10.1061/(ASCE)0733-9445(1988)114:8(1804), 1804-1826.

Aconf,max1 = 353600.00 is the confined core area at levels of member with hoops and

is calculated as the area of core enclosed by the center lines of the external perimeter hoops.

Aconf,min1 = 293525.00 is the confined core area at midway between the levels of hoops and

is calculated by reducing all the dimensions of the area Aconf,max1 by a length equal to half the clear spacing between external hoops.

AnoConf1 = 158733.333 is the unconfined external core area which is equal to bi2/6 as defined at (A.2).

ase2 (>=ase1) = Max(((Aconf,max2-AnoConf2)/Aconf,max2)\*(Aconf,min2/Aconf,max2),0) = 0.45746528

The definitions of AnoConf, Aconf,min and Aconf,max are derived from generalization of the rectangular sections confinement, which is expressed by (5.4d).

The generalization is done according to Mander, J., Priestley, M., and Park, R. (1988)

"Theoretical Stress-Strain Model for Confined Concrete."

J. Struct. Eng., 10.1061/(ASCE)0733-9445(1988)114:8(1804), 1804-1826.

Aconf,max2 = 171264.00 is the confined core area at levels of member with hoops and

is calculated as the area of core enclosed by the center lines of the internal perimeter hoops.

Aconf,min2 = 54741.00 is the confined core area at midway between the levels of hoops and

is calculated by reducing all the dimensions of the area Aconf,max2 by a length equal to half the clear spacing between internal hoops.

AnoConf2 = 106242.667 is the unconfined internal core area which is equal to bi2/6 as defined at (A.2).

psh,min\*Fywe = Min(psh,x\*Fywe , psh,y\*Fywe) = 3.3968

psh\_x\*Fywe = psh1\*Fywe1+ps2\*Fywe2 = 3.3968

psh1 ((5.4d), TBDY) = Lstir1\*Astir1/(Asec\*s1) = 0.00367709

Lstir1 (Length of stirrups along Y) = 2060.00

Astir1 (stirrups area) = 78.53982

psh2 (5.4d) = Lstir2\*Astir2/(Asec\*s2) = 0.00067082

Lstir2 (Length of stirrups along Y) = 1468.00

Astir2 (stirrups area) = 50.26548

psh\_y\*Fywe = psh1\*Fywe1+ps2\*Fywe2 = 3.3968

psh1 ((5.4d), TBDY) = Lstir1\*Astir1/(Asec\*s1) = 0.00367709

Lstir1 (Length of stirrups along X) = 2060.00

Astir1 (stirrups area) = 78.53982

psh2 ((5.4d), TBDY) = Lstir2\*Astir2/(Asec\*s2) = 0.00067082

Lstir2 (Length of stirrups along X) = 1468.00

Astir2 (stirrups area) = 50.26548

Asec = 440000.00

s1 = 100.00

s2 = 250.00

fywe1 = 781.25

fywe2 = 781.25

fce = 30.00

From ((5.A5), TBDY), TBDY: cc = 0.00471045

c = confinement factor = 1.27105

y1 = 0.00083886

```

sh1 = 0.00268436
ft1 = 314.5735
fy1 = 262.1446
su1 = 0.00268436
    using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
    and also multiplied by the shear_factor according to 15.7.1.4, with
    Shear_factor = 1.00
    lo/lou,min = lb/ld = 0.13907892
    su1 = 0.4*esu1_nominal ((5.5), TBDY) = 0.032
    From table 5A.1, TBDY: esu1_nominal = 0.08,
    For calculation of esu1_nominal and y1, sh1,ft1,fy1, it is considered
    characteristic value fsy1 = fs1/1.2, from table 5.1, TBDY.
    y1, sh1,ft1,fy1, are also multiplied by Min(1,1.25*(lb/ld)^ 2/3), from 10.3.5, ASCE 41-17.
    with fs1 = (fs,jacket*Asl,ten,jacket + fs,core*Asl,ten,core)/Asl,ten = 262.1446
    with Es1 = (Es,jacket*Asl,ten,jacket + Es,core*Asl,ten,core)/Asl,ten = 200000.00
y2 = 0.00083886
sh2 = 0.00268436
ft2 = 314.5735
fy2 = 262.1446
su2 = 0.00268436
    using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
    and also multiplied by the shear_factor according to 15.7.1.4, with
    Shear_factor = 1.00
    lo/lou,min = lb/lb,min = 0.13907892
    su2 = 0.4*esu2_nominal ((5.5), TBDY) = 0.032
    From table 5A.1, TBDY: esu2_nominal = 0.08,
    For calculation of esu2_nominal and y2, sh2,ft2,fy2, it is considered
    characteristic value fsy2 = fs2/1.2, from table 5.1, TBDY.
    y1, sh1,ft1,fy1, are also multiplied by Min(1,1.25*(lb/ld)^ 2/3), from 10.3.5, ASCE 41-17.
    with fs2 = (fs,jacket*Asl,com,jacket + fs,core*Asl,com,core)/Asl,com = 262.1446
    with Es2 = (Es,jacket*Asl,com,jacket + Es,core*Asl,com,core)/Asl,com = 200000.00
yv = 0.00083886
shv = 0.00268436
ftv = 314.5735
fyv = 262.1446
suv = 0.00268436
    using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
    and also multiplied by the shear_factor according to 15.7.1.4, with
    Shear_factor = 1.00
    lo/lou,min = lb/ld = 0.13907892
    suv = 0.4*esuv_nominal ((5.5), TBDY) = 0.032
    From table 5A.1, TBDY: esuv_nominal = 0.08,
    considering characteristic value fsyv = fsv/1.2, from table 5.1, TBDY
    For calculation of esuv_nominal and yv, shv,ftv,fyv, it is considered
    characteristic value fsyv = fsv/1.2, from table 5.1, TBDY.
    y1, sh1,ft1,fy1, are also multiplied by Min(1,1.25*(lb/ld)^ 2/3), from 10.3.5, ASCE 41-17.
    with fsv = (fs,jacket*Asl,mid,jacket + fs,mid*Asl,mid,core)/Asl,mid = 262.1446
    with Esv = (Es,jacket*Asl,mid,jacket + Es,mid*Asl,mid,core)/Asl,mid = 200000.00
1 = Asl,ten/(b*d)*(fs1/fc) = 0.06824101
2 = Asl,com/(b*d)*(fs2/fc) = 0.03513975
v = Asl,mid/(b*d)*(fsv/fc) = 0.06202846
and confined core properties:
b = 340.00
d = 677.00
d' = 13.00
fcc (5A.2, TBDY) = 38.13135
cc (5A.5, TBDY) = 0.00471045
    c = confinement factor = 1.27105
    1 = Asl,ten/(b*d)*(fs1/fc) = 0.08384116
    2 = Asl,com/(b*d)*(fs2/fc) = 0.04317283
    v = Asl,mid/(b*d)*(fsv/fc) = 0.07620839
Case/Assumption: Unconfined full section - Steel rupture
' satisfies Eq. (4.3)
--->
v < vs,y2 - LHS eq.(4.5) is satisfied
--->
su (4.9) = 0.2584548

```

$$\begin{aligned} \mu &= MRC(4.14) = 5.0296E+008 \\ u &= su(4.1) = 5.1201636E-006 \end{aligned}$$

Calculation of ratio  $l_b/l_d$

Lap Length:  $l_b/l_d = 0.13907892$

$l_b = 300.00$

$l_d = 2157.049$

Calculation of  $l_b, \min$  according to (25.4.3.2), ACI 318-14, using mean values for all the section re-bars.

$l_d, \min$  from (25.4.3.2) is multiplied 2 times to account for smooth re-bars (9.1.2, TS500 - No provision in ACI 318)

$= 1$

$db = 16.66667$

Mean strength value of all re-bars:  $f_y = 781.25$

Mean concrete strength:  $f_c' = (f_c'_{\text{jacket}} \cdot \text{Area}_{\text{jacket}} + f_c'_{\text{core}} \cdot \text{Area}_{\text{core}}) / \text{Area}_{\text{section}} = 30.00$ , but  $f_c'^{0.5} \leq 8.3$  MPa (22.5.3.1, ACI 318-14)

$t = 1.00$

$s = 0.80$

$e = 1.00$

$cb = 25.00$

$K_{tr} = 1.7174$

$A_{tr} = \min(A_{tr_x}, A_{tr_y}) = 257.6106$

where  $A_{tr_x}, A_{tr_y}$  are the sum of the area of all stirrup legs along X and Y loxal axis

$s = \max(s_{\text{external}}, s_{\text{internal}}) = 250.00$

$n = 24.00$

Calculation of  $\mu_{u2+}$

Calculation of ultimate curvature  $\mu$  according to 4.1, Biskinis/Fardis 2013:

$u = 4.8099118E-006$

$\mu = 2.3387E+008$

with full section properties:

$b = 750.00$

$d = 707.00$

$d' = 43.00$

$v = 0.00102301$

$N = 16273.608$

$f_c = 30.00$

$\phi$  (5A.5, TBDY) = 0.002

Final value of  $\phi$ :  $\phi^* = \text{shear\_factor} \cdot \max(\phi_u, \phi_c) = 0.01260361$

The Shear\_factor is considered equal to 1 (pure moment strength)

From (5.4b), TBDY:  $\phi_u = 0.01260361$

we (5.4c) = 0.05179731

$a_{se}((5.4d), \text{TBDY}) = (a_{se1} \cdot A_{ext} + a_{se2} \cdot A_{int}) / A_{sec} = 0.45746528$

$a_{se1} = \max(((A_{conf, \max 1} - A_{noConf1}) / A_{conf, \max 1}) \cdot (A_{conf, \min 1} / A_{conf, \max 1}), 0) = 0.45746528$

The definitions of  $A_{noConf}$ ,  $A_{conf, \min}$  and  $A_{conf, \max}$  are derived from generalization of the rectangular sections confinement, which is expressed by (5.4d).

The generalization is done according to Mander, J., Priestley, M., and Park, R. (1988)

"Theoretical Stress-Strain Model for Confined Concrete."

J. Struct. Eng., 10.1061/(ASCE)0733-9445(1988)114:8(1804), 1804-1826.

$A_{conf, \max 1} = 353600.00$  is the confined core area at levels of member with hoops and is calculated as the area of core enclosed by the center lines of the external perimeter hoops.

$A_{conf, \min 1} = 293525.00$  is the confined core area at midway between the levels of hoops and is calculated by reducing all the dimensions of the area  $A_{conf, \max 1}$  by a length equal to half the clear spacing between external hoops.

$A_{noConf1} = 158733.333$  is the unconfined external core area which is equal to  $b_i^2/6$  as defined at (A.2).

$a_{se2} (\geq a_{se1}) = \max(((A_{conf, \max 2} - A_{noConf2}) / A_{conf, \max 2}) \cdot (A_{conf, \min 2} / A_{conf, \max 2}), 0) = 0.45746528$

The definitions of  $A_{noConf}$ ,  $A_{conf, \min}$  and  $A_{conf, \max}$  are derived from generalization of the rectangular sections confinement, which is expressed by (5.4d).

The generalization is done according to Mander, J., Priestley, M., and Park, R. (1988)

"Theoretical Stress-Strain Model for Confined Concrete."

J. Struct. Eng., 10.1061/(ASCE)0733-9445(1988)114:8(1804), 1804-1826.

Aconf,max2 = 171264.00 is the confined core area at levels of member with hoops and is calculated as the area of core enclosed by the center lines of the internal perimeter hoops.

Aconf,min2 = 54741.00 is the confined core area at midway between the levels of hoops and is calculated by reducing all the dimensions of the area Aconf,max2 by a length equal to half the clear spacing between internal hoops.

AnoConf2 = 106242.667 is the unconfined internal core area which is equal to  $b_i^2/6$  as defined at (A.2).  
 $psh,min*Fywe = \text{Min}(psh,x*Fywe, psh,y*Fywe) = 3.3968$

---

$psh_x*Fywe = psh1*Fywe1 + ps2*Fywe2 = 3.3968$   
 $psh1 \text{ ((5.4d), TBDY)} = Lstir1*Astir1/(Asec*s1) = 0.00367709$   
 Lstir1 (Length of stirrups along Y) = 2060.00  
 Astir1 (stirrups area) = 78.53982  
 $psh2 \text{ (5.4d)} = Lstir2*Astir2/(Asec*s2) = 0.00067082$   
 Lstir2 (Length of stirrups along Y) = 1468.00  
 Astir2 (stirrups area) = 50.26548

---

$psh_y*Fywe = psh1*Fywe1 + ps2*Fywe2 = 3.3968$   
 $psh1 \text{ ((5.4d), TBDY)} = Lstir1*Astir1/(Asec*s1) = 0.00367709$   
 Lstir1 (Length of stirrups along X) = 2060.00  
 Astir1 (stirrups area) = 78.53982  
 $psh2 \text{ ((5.4d), TBDY)} = Lstir2*Astir2/(Asec*s2) = 0.00067082$   
 Lstir2 (Length of stirrups along X) = 1468.00  
 Astir2 (stirrups area) = 50.26548

---

Asec = 440000.00

s1 = 100.00

s2 = 250.00

fywe1 = 781.25

fywe2 = 781.25

fce = 30.00

From ((5.A5), TBDY), TBDY: cc = 0.00471045

c = confinement factor = 1.27105

y1 = 0.00083886

sh1 = 0.00268436

ft1 = 314.5735

fy1 = 262.1446

su1 = 0.00268436

using (30) in Biskinis/Fardis (2013) multiplied with shear\_factor and also multiplied by the shear\_factor according to 15.7.1.4, with Shear\_factor = 1.00

lo/lou,min = lb/lb,min = 0.13907892

su1 = 0.4\*esu1\_nominal ((5.5), TBDY) = 0.032

From table 5A.1, TBDY: esu1\_nominal = 0.08,

For calculation of esu1\_nominal and y1, sh1,ft1,fy1, it is considered characteristic value fsy1 = fs1/1.2, from table 5.1, TBDY.

y1, sh1,ft1,fy1, are also multiplied by  $\text{Min}(1, 1.25*(lb/lb)^{2/3})$ , from 10.3.5, ASCE 41-17.

with fs1 = (fs,jacket\*Asl,ten,jacket + fs,core\*Asl,ten,core)/Asl,ten = 262.1446

with Es1 = (Es,jacket\*Asl,ten,jacket + Es,core\*Asl,ten,core)/Asl,ten = 200000.00

y2 = 0.00083886

sh2 = 0.00268436

ft2 = 314.5735

fy2 = 262.1446

su2 = 0.00268436

using (30) in Biskinis/Fardis (2013) multiplied with shear\_factor and also multiplied by the shear\_factor according to 15.7.1.4, with Shear\_factor = 1.00

lo/lou,min = lb/lb,min = 0.13907892

su2 = 0.4\*esu2\_nominal ((5.5), TBDY) = 0.032

From table 5A.1, TBDY: esu2\_nominal = 0.08,

For calculation of esu2\_nominal and y2, sh2,ft2,fy2, it is considered characteristic value fsy2 = fs2/1.2, from table 5.1, TBDY.

y1, sh1,ft1,fy1, are also multiplied by  $\text{Min}(1, 1.25*(lb/lb)^{2/3})$ , from 10.3.5, ASCE 41-17.

with fs2 = (fs,jacket\*Asl,com,jacket + fs,core\*Asl,com,core)/Asl,com = 262.1446

with Es2 = (Es,jacket\*Asl,com,jacket + Es,core\*Asl,com,core)/Asl,com = 200000.00

yv = 0.00083886

shv = 0.00268436

ftv = 314.5735



```

fyv = 262.1446
suv = 0.00268436
using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00
lo/lo,min = lb/ld = 0.13907892
suv = 0.4*esuv_nominal ((5.5), TBDY) = 0.032
From table 5A.1, TBDY: esuv_nominal = 0.08,
considering characteristic value fsyv = fsv/1.2, from table 5.1, TBDY
For calculation of esuv_nominal and yv, shv,ftv,fyv, it is considered
characteristic value fsyv = fsv/1.2, from table 5.1, TBDY.
y1, sh1,ft1,fy1, are also multiplied by Min(1,1.25*(lb/ld)^ 2/3), from 10.3.5, ASCE 41-17.
with fsv = (fsjacket*Asl,mid,jacket + fs,mid*Asl,mid,core)/Asl,mid = 262.1446
with Esv = (Es,jacket*Asl,mid,jacket + Es,mid*Asl,mid,core)/Asl,mid = 200000.00
1 = Asl,ten/(b*d)*(fs1/fc) = 0.0187412
2 = Asl,com/(b*d)*(fs2/fc) = 0.03639521
v = Asl,mid/(b*d)*(fsv/fc) = 0.03308184
and confined core properties:
b = 690.00
d = 677.00
d' = 13.00
fcc (5A.2, TBDY) = 38.13135
cc (5A.5, TBDY) = 0.00471045
c = confinement factor = 1.27105
1 = Asl,ten/(b*d)*(fs1/fc) = 0.02127357
2 = Asl,com/(b*d)*(fs2/fc) = 0.04131304
v = Asl,mid/(b*d)*(fsv/fc) = 0.03755196
Case/Assumption: Unconfined full section - Steel rupture
'satisfies Eq. (4.3)
--->
v < vs,y2 - LHS eq.(4.5) is satisfied
--->
su (4.9) = 0.21062322
Mu = MRc (4.14) = 2.3387E+008
u = su (4.1) = 4.8099118E-006
-----

Calculation of ratio lb/ld
-----
Lap Length: lb/ld = 0.13907892
lb = 300.00
ld = 2157.049
Calculation of lb,min according to (25.4.3.2), ACI 318-14, using mean values for all the section re-bars.
ld,min from (25.4.3.2) is multiplied 2 times to account for smooth re-bars (9.1.2, TS500 - No provision in ACI 318)
= 1
db = 16.66667
Mean strength value of all re-bars: fy = 781.25
Mean concrete strength: fc' = (fc'_jacket*Area_jacket + fc'_core*Area_core)/Area_section = 30.00, but fc'^0.5 <= 8.3
MPa (22.5.3.1, ACI 318-14)
t = 1.00
s = 0.80
e = 1.00
cb = 25.00
Ktr = 1.7174
Atr = Min(Atr_x,Atr_y) = 257.6106
where Atr_x, Atr_y are the sum of the area of all stirrup legs along X and Y loxal axis
s = Max(s_external,s_internal) = 250.00
n = 24.00
-----

Calculation of Mu2-
-----

Calculation of ultimate curvature u according to 4.1, Biskinis/Fardis 2013:
u = 5.1201636E-006

```

$$\mu = 5.0296E+008$$

with full section properties:

$$b = 400.00$$

$$d = 707.00$$

$$d' = 43.00$$

$$v = 0.00191815$$

$$N = 16273.608$$

$$f_c = 30.00$$

$$\alpha (5A.5, \text{TB DY}) = 0.002$$

$$\text{Final value of } \mu: \mu^* = \text{shear\_factor} * \text{Max}(\mu, \alpha) = 0.01260361$$

The Shear\_factor is considered equal to 1 (pure moment strength)

$$\text{From (5.4b), TB DY: } \mu = 0.01260361$$

$$\mu_e (5.4c) = 0.05179731$$

$$\alpha_e ((5.4d), \text{TB DY}) = (\alpha_1 * A_{ext} + \alpha_2 * A_{int}) / A_{sec} = 0.45746528$$

$$\alpha_1 = \text{Max}(((A_{conf,max1} - A_{noConf1}) / A_{conf,max1}) * (A_{conf,min1} / A_{conf,max1}), 0) = 0.45746528$$

The definitions of  $A_{noConf}$ ,  $A_{conf,min}$  and  $A_{conf,max}$  are derived from generalization of the rectangular sections confinement, which is expressed by (5.4d).

The generalization is done according to Mander, J., Priestley, M., and Park, R. (1988)

"Theoretical Stress-Strain Model for Confined Concrete."

J. Struct. Eng., 10.1061/(ASCE)0733-9445(1988)114:8(1804), 1804-1826.

$A_{conf,max1} = 353600.00$  is the confined core area at levels of member with hoops and is calculated as the area of core enclosed by the center lines of the external perimeter hoops.

$A_{conf,min1} = 293525.00$  is the confined core area at midway between the levels of hoops and is calculated by reducing all the dimensions of the area  $A_{conf,max1}$  by a length equal to half the clear spacing between external hoops.

$A_{noConf1} = 158733.333$  is the unconfined external core area which is equal to  $b_i^2/6$  as defined at (A.2).

$$\alpha_2 (> \alpha_1) = \text{Max}(((A_{conf,max2} - A_{noConf2}) / A_{conf,max2}) * (A_{conf,min2} / A_{conf,max2}), 0) = 0.45746528$$

The definitions of  $A_{noConf}$ ,  $A_{conf,min}$  and  $A_{conf,max}$  are derived from generalization of the rectangular sections confinement, which is expressed by (5.4d).

The generalization is done according to Mander, J., Priestley, M., and Park, R. (1988)

"Theoretical Stress-Strain Model for Confined Concrete."

J. Struct. Eng., 10.1061/(ASCE)0733-9445(1988)114:8(1804), 1804-1826.

$A_{conf,max2} = 171264.00$  is the confined core area at levels of member with hoops and is calculated as the area of core enclosed by the center lines of the internal perimeter hoops.

$A_{conf,min2} = 54741.00$  is the confined core area at midway between the levels of hoops and is calculated by reducing all the dimensions of the area  $A_{conf,max2}$  by a length equal to half the clear spacing between internal hoops.

$A_{noConf2} = 106242.667$  is the unconfined internal core area which is equal to  $b_i^2/6$  as defined at (A.2).

$$p_{sh,min} * F_{ywe} = \text{Min}(p_{sh,x} * F_{ywe}, p_{sh,y} * F_{ywe}) = 3.3968$$

$$p_{sh,x} * F_{ywe} = p_{sh1} * F_{ywe1} + p_{sh2} * F_{ywe2} = 3.3968$$

$$p_{sh1} ((5.4d), \text{TB DY}) = L_{stir1} * A_{stir1} / (A_{sec} * s_1) = 0.00367709$$

$$L_{stir1} \text{ (Length of stirrups along Y)} = 2060.00$$

$$A_{stir1} \text{ (stirrups area)} = 78.53982$$

$$p_{sh2} (5.4d) = L_{stir2} * A_{stir2} / (A_{sec} * s_2) = 0.00067082$$

$$L_{stir2} \text{ (Length of stirrups along Y)} = 1468.00$$

$$A_{stir2} \text{ (stirrups area)} = 50.26548$$

$$p_{sh,y} * F_{ywe} = p_{sh1} * F_{ywe1} + p_{sh2} * F_{ywe2} = 3.3968$$

$$p_{sh1} ((5.4d), \text{TB DY}) = L_{stir1} * A_{stir1} / (A_{sec} * s_1) = 0.00367709$$

$$L_{stir1} \text{ (Length of stirrups along X)} = 2060.00$$

$$A_{stir1} \text{ (stirrups area)} = 78.53982$$

$$p_{sh2} ((5.4d), \text{TB DY}) = L_{stir2} * A_{stir2} / (A_{sec} * s_2) = 0.00067082$$

$$L_{stir2} \text{ (Length of stirrups along X)} = 1468.00$$

$$A_{stir2} \text{ (stirrups area)} = 50.26548$$

$$A_{sec} = 440000.00$$

$$s_1 = 100.00$$

$$s_2 = 250.00$$

$$f_{ywe1} = 781.25$$

$$f_{ywe2} = 781.25$$

$$f_{ce} = 30.00$$

$$\text{From ((5.A5), TB DY), TB DY: } \alpha_c = 0.00471045$$

$$\alpha_c = \text{confinement factor} = 1.27105$$

$$y_1 = 0.00083886$$

$$sh_1 = 0.00268436$$

```

ft1 = 314.5735
fy1 = 262.1446
su1 = 0.00268436
    using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
    and also multiplied by the shear_factor according to 15.7.1.4, with
    Shear_factor = 1.00
    lo/lou,min = lb/lb = 0.13907892
    su1 = 0.4*esu1_nominal ((5.5), TBDY) = 0.032
    From table 5A.1, TBDY: esu1_nominal = 0.08,
    For calculation of esu1_nominal and y1, sh1,ft1,fy1, it is considered
    characteristic value fsy1 = fs1/1.2, from table 5.1, TBDY.
    y1, sh1,ft1,fy1, are also multiplied by Min(1,1.25*(lb/lb)^2/3), from 10.3.5, ASCE 41-17.
    with fs1 = (fs,jacket*Asl,ten,jacket + fs,core*Asl,ten,core)/Asl,ten = 262.1446
    with Es1 = (Es,jacket*Asl,ten,jacket + Es,core*Asl,ten,core)/Asl,ten = 200000.00
y2 = 0.00083886
sh2 = 0.00268436
ft2 = 314.5735
fy2 = 262.1446
su2 = 0.00268436
    using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
    and also multiplied by the shear_factor according to 15.7.1.4, with
    Shear_factor = 1.00
    lo/lou,min = lb/lb,min = 0.13907892
    su2 = 0.4*esu2_nominal ((5.5), TBDY) = 0.032
    From table 5A.1, TBDY: esu2_nominal = 0.08,
    For calculation of esu2_nominal and y2, sh2,ft2,fy2, it is considered
    characteristic value fsy2 = fs2/1.2, from table 5.1, TBDY.
    y1, sh1,ft1,fy1, are also multiplied by Min(1,1.25*(lb/lb)^2/3), from 10.3.5, ASCE 41-17.
    with fs2 = (fs,jacket*Asl,com,jacket + fs,core*Asl,com,core)/Asl,com = 262.1446
    with Es2 = (Es,jacket*Asl,com,jacket + Es,core*Asl,com,core)/Asl,com = 200000.00
yv = 0.00083886
shv = 0.00268436
ftv = 314.5735
fyv = 262.1446
suv = 0.00268436
    using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
    and also multiplied by the shear_factor according to 15.7.1.4, with
    Shear_factor = 1.00
    lo/lou,min = lb/lb = 0.13907892
    suv = 0.4*esuv_nominal ((5.5), TBDY) = 0.032
    From table 5A.1, TBDY: esuv_nominal = 0.08,
    considering characteristic value fsyv = fsv/1.2, from table 5.1, TBDY
    For calculation of esuv_nominal and yv, shv,ftv,fyv, it is considered
    characteristic value fsyv = fsv/1.2, from table 5.1, TBDY.
    y1, sh1,ft1,fy1, are also multiplied by Min(1,1.25*(lb/lb)^2/3), from 10.3.5, ASCE 41-17.
    with fsv = (fs,jacket*Asl,mid,jacket + fs,mid*Asl,mid,core)/Asl,mid = 262.1446
    with Esv = (Es,jacket*Asl,mid,jacket + Es,mid*Asl,mid,core)/Asl,mid = 200000.00
1 = Asl,ten/(b*d)*(fs1/fc) = 0.06824101
2 = Asl,com/(b*d)*(fs2/fc) = 0.03513975
v = Asl,mid/(b*d)*(fsv/fc) = 0.06202846
and confined core properties:
b = 340.00
d = 677.00
d' = 13.00
fcc (5A.2, TBDY) = 38.13135
cc (5A.5, TBDY) = 0.00471045
    c = confinement factor = 1.27105
    1 = Asl,ten/(b*d)*(fs1/fc) = 0.08384116
    2 = Asl,com/(b*d)*(fs2/fc) = 0.04317283
    v = Asl,mid/(b*d)*(fsv/fc) = 0.07620839
Case/Assumption: Unconfined full section - Steel rupture
' satisfies Eq. (4.3)
--->
v < vs,y2 - LHS eq.(4.5) is satisfied
--->
su (4.9) = 0.2584548
Mu = MRc (4.14) = 5.0296E+008

```

$$u = s_u(4.1) = 5.1201636E-006$$

Calculation of ratio  $l_b/d$

Lap Length:  $l_b/d = 0.13907892$

$l_b = 300.00$

$d = 2157.049$

Calculation of  $l_b$ ,min according to (25.4.3.2), ACI 318-14, using mean values for all the section re-bars.

$l_b$ ,min from (25.4.3.2) is multiplied 2 times to account for smooth re-bars (9.1.2, TS500 - No provision in ACI 318)

$= 1$

$db = 16.66667$

Mean strength value of all re-bars:  $f_y = 781.25$

Mean concrete strength:  $f_c' = (f_c'_{\text{jacket}} \cdot \text{Area}_{\text{jacket}} + f_c'_{\text{core}} \cdot \text{Area}_{\text{core}}) / \text{Area}_{\text{section}} = 30.00$ , but  $f_c'^{0.5} \leq 8.3$  MPa (22.5.3.1, ACI 318-14)

$t = 1.00$

$s = 0.80$

$e = 1.00$

$cb = 25.00$

$K_{tr} = 1.7174$

$A_{tr} = \text{Min}(A_{tr\_x}, A_{tr\_y}) = 257.6106$

where  $A_{tr\_x}$ ,  $A_{tr\_y}$  are the sum of the area of all stirrup legs along X and Y loxal axis

$s = \text{Max}(s_{\text{external}}, s_{\text{internal}}) = 250.00$

$n = 24.00$

Calculation of Shear Strength  $V_r = \text{Min}(V_{r1}, V_{r2}) = 1.0392E+006$

Calculation of Shear Strength at edge 1,  $V_{r1} = 1.0392E+006$

$V_{r1} = V_{Co1} ((10.3), \text{ASCE } 41-17) = k_{nl} \cdot V_{Co10}$

$V_{Co10} = 1.0392E+006$

$k_{nl} = 1$  (zero step-static loading)

NOTE: In expression (10-3) ' $V_s = A_v \cdot f_y \cdot d / s$ ' is replaced by ' $V_s + f \cdot V_f$ ' where  $V_f$  is the contribution of FRPs (11.3), ACI 440).

$= 1$  (normal-weight concrete)

Mean concrete strength:  $f_c' = (f_c'_{\text{jacket}} \cdot \text{Area}_{\text{jacket}} + f_c'_{\text{core}} \cdot \text{Area}_{\text{core}}) / \text{Area}_{\text{section}} = 30.00$ , but  $f_c'^{0.5} \leq 8.3$  MPa (22.5.3.1, ACI 318-14)

$M/Vd = 4.00$

$\mu_u = 1308.016$

$V_u = 0.00017144$

$d = 0.8 \cdot h = 600.00$

$N_u = 16273.608$

$A_g = 300000.00$

From (11.5.4.8), ACI 318-14:  $V_s = V_{sj1} + V_{sj2} = 1.0138E+006$

where:

$V_{sj1} = V_{sj1} + V_{sj2} = 903207.888$

$V_{sj1} = 589048.623$  is calculated for section web jacket, with:

$d = 600.00$

$A_v = 157079.633$

$f_y = 625.00$

$s = 100.00$

$V_{sj1}$  is multiplied by  $Col_{j1} = 1.00$

$s/d = 0.16666667$

$V_{sj2} = 314159.265$  is calculated for section flange jacket, with:

$d = 320.00$

$A_v = 157079.633$

$f_y = 625.00$

$s = 100.00$

$V_{sj2}$  is multiplied by  $Col_{j2} = 1.00$

$s/d = 0.3125$

$V_{s,core} = V_{sc1} + V_{sc2} = 110584.061$

$V_{sc1} = 110584.061$  is calculated for section web core, with:

$d = 440.00$

$A_v = 100530.965$   
 $f_y = 625.00$   
 $s = 250.00$   
 $V_{s,c1}$  is multiplied by  $Col,c1 = 1.00$   
 $s/d = 0.56818182$   
 $V_{s,c2} = 0.00$  is calculated for section flange core, with:  
 $d = 160.00$   
 $A_v = 100530.965$   
 $f_y = 625.00$   
 $s = 250.00$   
 $V_{s,c2}$  is multiplied by  $Col,c2 = 0.00$   
 $s/d = 1.5625$   
 $V_f ((11-3)-(11.4), ACI 440) = 0.00$   
 From (11-11), ACI 440:  $V_s + V_f \leq 873250.061$   
 $bw = 400.00$

Calculation of Shear Strength at edge 2,  $V_{r2} = 1.0392E+006$   
 $V_{r2} = V_{Col} ((10.3), ASCE 41-17) = knl * V_{Col0}$   
 $V_{Col0} = 1.0392E+006$   
 $knl = 1$  (zero step-static loading)

NOTE: In expression (10-3) ' $V_s = A_v * f_y * d / s$ ' is replaced by ' $V_s + f * V_f$ ' where  $V_f$  is the contribution of FRPs (11.3), ACI 440).

$= 1$  (normal-weight concrete)  
 Mean concrete strength:  $f'_c = (f'_c\_jacket * Area\_jacket + f'_c\_core * Area\_core) / Area\_section = 30.00$ , but  $f'_c^{0.5} \leq 8.3$  MPa (22.5.3.1, ACI 318-14)

$M/Vd = 4.00$   
 $\mu_u = 1308.016$   
 $V_u = 0.00017144$   
 $d = 0.8 * h = 600.00$   
 $N_u = 16273.608$   
 $A_g = 300000.00$   
 From (11.5.4.8), ACI 318-14:  $V_s = V_{s,jacket} + V_{s,core} = 1.0138E+006$   
 where:

$V_{s,jacket} = V_{s,j1} + V_{s,j2} = 903207.888$   
 $V_{s,j1} = 589048.623$  is calculated for section web jacket, with:  
 $d = 600.00$   
 $A_v = 157079.633$   
 $f_y = 625.00$   
 $s = 100.00$   
 $V_{s,j1}$  is multiplied by  $Col,j1 = 1.00$   
 $s/d = 0.16666667$   
 $V_{s,j2} = 314159.265$  is calculated for section flange jacket, with:  
 $d = 320.00$   
 $A_v = 157079.633$   
 $f_y = 625.00$   
 $s = 100.00$   
 $V_{s,j2}$  is multiplied by  $Col,j2 = 1.00$   
 $s/d = 0.3125$   
 $V_{s,core} = V_{s,c1} + V_{s,c2} = 110584.061$   
 $V_{s,c1} = 110584.061$  is calculated for section web core, with:  
 $d = 440.00$   
 $A_v = 100530.965$   
 $f_y = 625.00$   
 $s = 250.00$   
 $V_{s,c1}$  is multiplied by  $Col,c1 = 1.00$   
 $s/d = 0.56818182$   
 $V_{s,c2} = 0.00$  is calculated for section flange core, with:  
 $d = 160.00$   
 $A_v = 100530.965$   
 $f_y = 625.00$   
 $s = 250.00$   
 $V_{s,c2}$  is multiplied by  $Col,c2 = 0.00$   
 $s/d = 1.5625$   
 $V_f ((11-3)-(11.4), ACI 440) = 0.00$

From (11-11), ACI 440:  $V_s + V_f \leq 873250.061$   
 $bw = 400.00$

End Of Calculation of Shear Capacity ratio for element: column JLC1 of floor 1  
At local axis: 3

Start Of Calculation of Shear Capacity ratio for element: column JLC1 of floor 1  
At Shear local axis: 2  
(Bending local axis: 3)  
Section Type: rcjcs

#### Constant Properties

Knowledge Factor,  $= 1.00$   
Mean strength values are used for both shear and moment calculations.  
Consequently:  
Jacket  
New material of Primary Member: Concrete Strength,  $f_c = f_{cm} = 30.00$   
New material of Primary Member: Steel Strength,  $f_s = f_{sm} = 625.00$   
Concrete Elasticity,  $E_c = 25742.96$   
Steel Elasticity,  $E_s = 200000.00$   
Existing Column  
New material of Primary Member: Concrete Strength,  $f_c = f_{cm} = 30.00$   
New material of Primary Member: Steel Strength,  $f_s = f_{sm} = 625.00$   
Concrete Elasticity,  $E_c = 25742.96$   
Steel Elasticity,  $E_s = 200000.00$   
#####  
Note: Especially for the calculation of moment strengths,  
the above steel re-bar strengths are multiplied by 1.25 according to R18.6.5, ACI 318-14  
Jacket  
New material: Steel Strength,  $f_s = 1.25 \cdot f_{sm} = 781.25$   
Existing Column  
New material: Steel Strength,  $f_s = 1.25 \cdot f_{sm} = 781.25$   
#####  
Max Height,  $H_{max} = 750.00$   
Min Height,  $H_{min} = 400.00$   
Max Width,  $W_{max} = 750.00$   
Min Width,  $W_{min} = 400.00$   
Jacket Thickness,  $t_j = 100.00$   
Cover Thickness,  $c = 25.00$   
Mean Confinement Factor overall section  $= 1.27105$   
Element Length,  $L = 3000.00$   
Primary Member  
Smooth Bars  
Ductile Steel  
With Detailing for Earthquake Resistance (including stirrups closed at  $135^\circ$ )  
Longitudinal Bars With Ends Lapped Starting at the End Sections  
Lap Length  $l_o = 300.00$   
No FRP Wrapping

#### Stepwise Properties

At local axis: 2  
EDGE -A-  
Shear Force,  $V_a = -0.0001715$   
EDGE -B-  
Shear Force,  $V_b = 0.0001715$   
BOTH EDGES  
Axial Force,  $F = -16273.608$   
Longitudinal Reinforcement Area Distribution (in 2 divisions)  
-Tension:  $A_{st} = 0.00$   
-Compression:  $A_{sc} = 5353.274$

Longitudinal Reinforcement Area Distribution (in 3 divisions)

-Tension:  $A_{s,ten} = 1137.257$

-Compression:  $A_{s,com} = 2208.54$

-Middle:  $A_{s,mid} = 2007.478$

Calculation of Shear Capacity ratio ,  $V_e/V_r = 0.32266369$

Member Controlled by Flexure ( $V_e/V_r < 1$ )

Calculation of Shear Demand from fig. R18.6.5, ACI 318-14  $V_e = (M_{pr1} + M_{pr2})/l_n = 335307.657$

with

$M_{pr1} = \text{Max}(M_{u1+}, M_{u1-}) = 5.0296E+008$

$M_{u1+} = 2.3387E+008$ , is the ultimate moment strength at the edge 1 of the member in the actual moment direction which is defined for the static loading combination

$M_{u1-} = 5.0296E+008$ , is the ultimate moment strength at the edge 1 of the member in the opposite moment direction which is defined for the static loading combination

$M_{pr2} = \text{Max}(M_{u2+}, M_{u2-}) = 5.0296E+008$

$M_{u2+} = 2.3387E+008$ , is the ultimate moment strength at the edge 2 of the member in the actual moment direction which is defined for the static loading combination

$M_{u2-} = 5.0296E+008$ , is the ultimate moment strength at the edge 2 of the member in the opposite moment direction which is defined for the static loading combination

Calculation of  $M_{u1+}$

Calculation of ultimate curvature  $\phi_u$  according to 4.1, Biskinis/Fardis 2013:

$\phi_u = 4.8099118E-006$

$M_u = 2.3387E+008$

with full section properties:

$b = 750.00$

$d = 707.00$

$d' = 43.00$

$v = 0.00102301$

$N = 16273.608$

$f_c = 30.00$

$\phi_c$  (5A.5, TBDY) = 0.002

Final value of  $\phi_u$ :  $\phi_u^* = \text{shear\_factor} * \text{Max}(\phi_u, \phi_c) = 0.01260361$

The Shear\_factor is considered equal to 1 (pure moment strength)

From (5.4b), TBDY:  $\phi_u = 0.01260361$

$\phi_{ue}$  (5.4c) = 0.05179731

$\phi_{ase}$  ((5.4d), TBDY) =  $(\phi_{ase1} * A_{ext} + \phi_{ase2} * A_{int}) / A_{sec} = 0.45746528$

$\phi_{ase1} = \text{Max}(((A_{conf,max1} - A_{noConf1}) / A_{conf,max1}) * (A_{conf,min1} / A_{conf,max1}), 0) = 0.45746528$

The definitions of  $A_{noConf}$ ,  $A_{conf,min}$  and  $A_{conf,max}$  are derived from generalization of the rectangular sections confinement, which is expressed by (5.4d).

The generalization is done according to Mander, J., Priestley, M., and Park, R. (1988)

"Theoretical Stress-Strain Model for Confined Concrete."

J. Struct. Eng., 10.1061/(ASCE)0733-9445(1988)114:8(1804), 1804-1826.

$A_{conf,max1} = 353600.00$  is the confined core area at levels of member with hoops and is calculated as the area of core enclosed by the center lines of the external perimeter hoops.

$A_{conf,min1} = 293525.00$  is the confined core area at midway between the levels of hoops and is calculated by reducing all the dimensions of the area  $A_{conf,max1}$  by a length equal to half the clear spacing between external hoops.

$A_{noConf1} = 158733.333$  is the unconfined external core area which is equal to  $b_i^2/6$  as defined at (A.2).

$\phi_{ase2} (> \phi_{ase1}) = \text{Max}(((A_{conf,max2} - A_{noConf2}) / A_{conf,max2}) * (A_{conf,min2} / A_{conf,max2}), 0) = 0.45746528$

The definitions of  $A_{noConf}$ ,  $A_{conf,min}$  and  $A_{conf,max}$  are derived from generalization of the rectangular sections confinement, which is expressed by (5.4d).

The generalization is done according to Mander, J., Priestley, M., and Park, R. (1988)

"Theoretical Stress-Strain Model for Confined Concrete."

J. Struct. Eng., 10.1061/(ASCE)0733-9445(1988)114:8(1804), 1804-1826.

$A_{conf,max2} = 171264.00$  is the confined core area at levels of member with hoops and is calculated as the area of core enclosed by the center lines of the internal perimeter hoops.

$A_{conf,min2} = 54741.00$  is the confined core area at midway between the levels of hoops and is calculated by reducing all the dimensions of the area  $A_{conf,max2}$  by a length

equal to half the clear spacing between internal hoops.

AnoConf2 = 106242.667 is the unconfined internal core area which is equal to  $b_i^2/6$  as defined at (A.2).  
 $psh_{min} \cdot F_{ywe} = \text{Min}(psh_x \cdot F_{ywe}, psh_y \cdot F_{ywe}) = 3.3968$

$psh_x \cdot F_{ywe} = psh1 \cdot F_{ywe1} + ps2 \cdot F_{ywe2} = 3.3968$   
 $psh1$  ((5.4d), TBDY) =  $Lstir1 \cdot Astir1 / (Asec \cdot s1) = 0.00367709$   
Lstir1 (Length of stirrups along Y) = 2060.00  
Astir1 (stirrups area) = 78.53982  
 $psh2$  (5.4d) =  $Lstir2 \cdot Astir2 / (Asec \cdot s2) = 0.00067082$   
Lstir2 (Length of stirrups along Y) = 1468.00  
Astir2 (stirrups area) = 50.26548

$psh_y \cdot F_{ywe} = psh1 \cdot F_{ywe1} + ps2 \cdot F_{ywe2} = 3.3968$   
 $psh1$  ((5.4d), TBDY) =  $Lstir1 \cdot Astir1 / (Asec \cdot s1) = 0.00367709$   
Lstir1 (Length of stirrups along X) = 2060.00  
Astir1 (stirrups area) = 78.53982  
 $psh2$  ((5.4d), TBDY) =  $Lstir2 \cdot Astir2 / (Asec \cdot s2) = 0.00067082$   
Lstir2 (Length of stirrups along X) = 1468.00  
Astir2 (stirrups area) = 50.26548

Asec = 440000.00

s1 = 100.00

s2 = 250.00

fywe1 = 781.25

fywe2 = 781.25

fce = 30.00

From ((5.A5), TBDY), TBDY: cc = 0.00471045

c = confinement factor = 1.27105

y1 = 0.00083886

sh1 = 0.00268436

ft1 = 314.5735

fy1 = 262.1446

su1 = 0.00268436

using (30) in Biskinis/Fardis (2013) multiplied with shear\_factor  
and also multiplied by the shear\_factor according to 15.7.1.4, with  
Shear\_factor = 1.00

lo/lou,min = lb/lb = 0.13907892

su1 =  $0.4 \cdot esu1_{nominal}$  ((5.5), TBDY) = 0.032

From table 5A.1, TBDY: esu1\_nominal = 0.08,

For calculation of esu1\_nominal and y1, sh1, ft1, fy1, it is considered  
characteristic value fsy1 = fs1/1.2, from table 5.1, TBDY.

y1, sh1, ft1, fy1, are also multiplied by  $\text{Min}(1, 1.25 \cdot (lb/lb)^{2/3})$ , from 10.3.5, ASCE 41-17.

with fs1 =  $(fs_{jacket} \cdot Asl_{ten,jacket} + fs_{core} \cdot Asl_{ten,core}) / Asl_{ten} = 262.1446$

with Es1 =  $(Es_{jacket} \cdot Asl_{ten,jacket} + Es_{core} \cdot Asl_{ten,core}) / Asl_{ten} = 200000.00$

y2 = 0.00083886

sh2 = 0.00268436

ft2 = 314.5735

fy2 = 262.1446

su2 = 0.00268436

using (30) in Biskinis/Fardis (2013) multiplied with shear\_factor  
and also multiplied by the shear\_factor according to 15.7.1.4, with  
Shear\_factor = 1.00

lo/lou,min = lb/lb,min = 0.13907892

su2 =  $0.4 \cdot esu2_{nominal}$  ((5.5), TBDY) = 0.032

From table 5A.1, TBDY: esu2\_nominal = 0.08,

For calculation of esu2\_nominal and y2, sh2, ft2, fy2, it is considered  
characteristic value fsy2 = fs2/1.2, from table 5.1, TBDY.

y1, sh1, ft1, fy1, are also multiplied by  $\text{Min}(1, 1.25 \cdot (lb/lb)^{2/3})$ , from 10.3.5, ASCE 41-17.

with fs2 =  $(fs_{jacket} \cdot Asl_{com,jacket} + fs_{core} \cdot Asl_{com,core}) / Asl_{com} = 262.1446$

with Es2 =  $(Es_{jacket} \cdot Asl_{com,jacket} + Es_{core} \cdot Asl_{com,core}) / Asl_{com} = 200000.00$

yv = 0.00083886

shv = 0.00268436

ftv = 314.5735

fyv = 262.1446

suv = 0.00268436

using (30) in Biskinis/Fardis (2013) multiplied with shear\_factor  
and also multiplied by the shear\_factor according to 15.7.1.4, with



```

Shear_factor = 1.00
lo/lou,min = lb/ld = 0.13907892
suv = 0.4*esuv_nominal ((5.5), TBDY) = 0.032
From table 5A.1, TBDY: esuv_nominal = 0.08,
considering characteristic value fsyv = fsv/1.2, from table 5.1, TBDY
For calculation of esuv_nominal and yv, shv,ftv,fyv, it is considered
characteristic value fsyv = fsv/1.2, from table 5.1, TBDY.
y1, sh1,ft1,fy1, are also multiplied by Min(1,1.25*(lb/ld)^ 2/3), from 10.3.5, ASCE 41-17.
with fsv = (fsjacket*Asl,mid,jacket + fs,mid*Asl,mid,core)/Asl,mid = 262.1446
with Esv = (Esjacket*Asl,mid,jacket + Es,mid*Asl,mid,core)/Asl,mid = 200000.00
1 = Asl,ten/(b*d)*(fs1/fc) = 0.0187412
2 = Asl,com/(b*d)*(fs2/fc) = 0.03639521
v = Asl,mid/(b*d)*(fsv/fc) = 0.03308184
and confined core properties:
b = 690.00
d = 677.00
d' = 13.00
fcc (5A.2, TBDY) = 38.13135
cc (5A.5, TBDY) = 0.00471045
c = confinement factor = 1.27105
1 = Asl,ten/(b*d)*(fs1/fc) = 0.02127357
2 = Asl,com/(b*d)*(fs2/fc) = 0.04131304
v = Asl,mid/(b*d)*(fsv/fc) = 0.03755196
Case/Assumption: Unconfined full section - Steel rupture
' satisfies Eq. (4.3)
---->
v < vs,y2 - LHS eq.(4.5) is satisfied
---->
su (4.9) = 0.21062322
Mu = MRc (4.14) = 2.3387E+008
u = su (4.1) = 4.8099118E-006
-----

Calculation of ratio lb/ld
-----
Lap Length: lb/ld = 0.13907892
lb = 300.00
ld = 2157.049
Calculation of lb,min according to (25.4.3.2), ACI 318-14, using mean values for all the section re-bars.
ld,min from (25.4.3.2) is multiplied 2 times to account for smooth re-bars (9.1.2, TS500 - No provision in ACI 318)
= 1
db = 16.66667
Mean strength value of all re-bars: fy = 781.25
Mean concrete strength: fc' = (fc'_jacket*Area_jacket + fc'_core*Area_core)/Area_section = 30.00, but fc'^0.5 <= 8.3
MPa (22.5.3.1, ACI 318-14)
t = 1.00
s = 0.80
e = 1.00
cb = 25.00
Ktr = 1.7174
Atr = Min(Atr_x,Atr_y) = 257.6106
where Atr_x, Atr_y are the sum of the area of all stirrup legs along X and Y loxal axis
s = Max(s_external,s_internal) = 250.00
n = 24.00
-----

Calculation of Mu1-
-----

Calculation of ultimate curvature u according to 4.1, Biskinis/Fardis 2013:
u = 5.1201636E-006
Mu = 5.0296E+008
-----

with full section properties:
b = 400.00

```

$d = 707.00$   
 $d' = 43.00$   
 $v = 0.00191815$   
 $N = 16273.608$   
 $f_c = 30.00$   
 $co (5A.5, TBDY) = 0.002$   
 Final value of  $cu$ :  $cu^* = shear\_factor * Max(cu, cc) = 0.01260361$   
 The Shear\_factor is considered equal to 1 (pure moment strength)  
 From (5.4b), TBDY:  $cu = 0.01260361$   
 $we (5.4c) = 0.05179731$   
 $ase ((5.4d), TBDY) = (ase1 * A_{ext} + ase2 * A_{int}) / A_{sec} = 0.45746528$   
 $ase1 = Max(((A_{conf,max1} - A_{noConf1}) / A_{conf,max1}) * (A_{conf,min1} / A_{conf,max1}), 0) = 0.45746528$   
 The definitions of  $A_{noConf}$ ,  $A_{conf,min}$  and  $A_{conf,max}$  are derived from generalization of the rectangular sections confinement, which is expressed by (5.4d).  
 The generalization is done according to Mander, J., Priestley, M., and Park, R. (1988) "Theoretical Stress-Strain Model for Confined Concrete."  
 J. Struct. Eng., 10.1061/(ASCE)0733-9445(1988)114:8(1804), 1804-1826.  
 $A_{conf,max1} = 353600.00$  is the confined core area at levels of member with hoops and is calculated as the area of core enclosed by the center lines of the external perimeter hoops.  
 $A_{conf,min1} = 293525.00$  is the confined core area at midway between the levels of hoops and is calculated by reducing all the dimensions of the area  $A_{conf,max1}$  by a length equal to half the clear spacing between external hoops.  
 $A_{noConf1} = 158733.333$  is the unconfined external core area which is equal to  $b_i^2/6$  as defined at (A.2).  
 $ase2 (>= ase1) = Max(((A_{conf,max2} - A_{noConf2}) / A_{conf,max2}) * (A_{conf,min2} / A_{conf,max2}), 0) = 0.45746528$   
 The definitions of  $A_{noConf}$ ,  $A_{conf,min}$  and  $A_{conf,max}$  are derived from generalization of the rectangular sections confinement, which is expressed by (5.4d).  
 The generalization is done according to Mander, J., Priestley, M., and Park, R. (1988) "Theoretical Stress-Strain Model for Confined Concrete."  
 J. Struct. Eng., 10.1061/(ASCE)0733-9445(1988)114:8(1804), 1804-1826.  
 $A_{conf,max2} = 171264.00$  is the confined core area at levels of member with hoops and is calculated as the area of core enclosed by the center lines of the internal perimeter hoops.  
 $A_{conf,min2} = 54741.00$  is the confined core area at midway between the levels of hoops and is calculated by reducing all the dimensions of the area  $A_{conf,max2}$  by a length equal to half the clear spacing between internal hoops.  
 $A_{noConf2} = 106242.667$  is the unconfined internal core area which is equal to  $b_i^2/6$  as defined at (A.2).  
 $psh,min * F_{ywe} = Min(psh,x * F_{ywe}, psh,y * F_{ywe}) = 3.3968$

---

$psh,x * F_{ywe} = psh1 * F_{ywe1} + ps2 * F_{ywe2} = 3.3968$   
 $psh1 ((5.4d), TBDY) = L_{stir1} * A_{stir1} / (A_{sec} * s1) = 0.00367709$   
 $L_{stir1}$  (Length of stirrups along Y) = 2060.00  
 $A_{stir1}$  (stirrups area) = 78.53982  
 $psh2 (5.4d) = L_{stir2} * A_{stir2} / (A_{sec} * s2) = 0.00067082$   
 $L_{stir2}$  (Length of stirrups along Y) = 1468.00  
 $A_{stir2}$  (stirrups area) = 50.26548

---

$psh,y * F_{ywe} = psh1 * F_{ywe1} + ps2 * F_{ywe2} = 3.3968$   
 $psh1 ((5.4d), TBDY) = L_{stir1} * A_{stir1} / (A_{sec} * s1) = 0.00367709$   
 $L_{stir1}$  (Length of stirrups along X) = 2060.00  
 $A_{stir1}$  (stirrups area) = 78.53982  
 $psh2 ((5.4d), TBDY) = L_{stir2} * A_{stir2} / (A_{sec} * s2) = 0.00067082$   
 $L_{stir2}$  (Length of stirrups along X) = 1468.00  
 $A_{stir2}$  (stirrups area) = 50.26548

---

$A_{sec} = 440000.00$   
 $s1 = 100.00$   
 $s2 = 250.00$   
 $f_{ywe1} = 781.25$   
 $f_{ywe2} = 781.25$   
 $f_{ce} = 30.00$   
 From ((5.A5), TBDY), TBDY:  $cc = 0.00471045$   
 $c =$  confinement factor = 1.27105  
 $y1 = 0.00083886$   
 $sh1 = 0.00268436$   
 $ft1 = 314.5735$   
 $fy1 = 262.1446$   
 $su1 = 0.00268436$   
 using (30) in Biskinis/Fardis (2013) multiplied with shear\_factor

and also multiplied by the shear\_factor according to 15.7.1.4, with  
 Shear\_factor = 1.00  
 $lo/lou,min = lb/ld = 0.13907892$   
 $su1 = 0.4*esu1\_nominal ((5.5), TBDY) = 0.032$   
 From table 5A.1, TBDY:  $esu1\_nominal = 0.08$ ,  
 For calculation of  $esu1\_nominal$  and  $y1, sh1,ft1,fy1$ , it is considered  
 characteristic value  $fsy1 = fs1/1.2$ , from table 5.1, TBDY.  
 $y1, sh1,ft1,fy1$ , are also multiplied by  $Min(1,1.25*(lb/ld)^{2/3})$ , from 10.3.5, ASCE 41-17.  
 with  $fs1 = (fs,jacket*Asl,ten,jacket + fs,core*Asl,ten,core)/Asl,ten = 262.1446$   
 with  $Es1 = (Es,jacket*Asl,ten,jacket + Es,core*Asl,ten,core)/Asl,ten = 200000.00$   
 $y2 = 0.00083886$   
 $sh2 = 0.00268436$   
 $ft2 = 314.5735$   
 $fy2 = 262.1446$   
 $su2 = 0.00268436$   
 using (30) in Biskinis/Fardis (2013) multiplied with shear\_factor  
 and also multiplied by the shear\_factor according to 15.7.1.4, with  
 Shear\_factor = 1.00  
 $lo/lou,min = lb/lb,min = 0.13907892$   
 $su2 = 0.4*esu2\_nominal ((5.5), TBDY) = 0.032$   
 From table 5A.1, TBDY:  $esu2\_nominal = 0.08$ ,  
 For calculation of  $esu2\_nominal$  and  $y2, sh2,ft2,fy2$ , it is considered  
 characteristic value  $fsy2 = fs2/1.2$ , from table 5.1, TBDY.  
 $y1, sh1,ft1,fy1$ , are also multiplied by  $Min(1,1.25*(lb/ld)^{2/3})$ , from 10.3.5, ASCE 41-17.  
 with  $fs2 = (fs,jacket*Asl,com,jacket + fs,core*Asl,com,core)/Asl,com = 262.1446$   
 with  $Es2 = (Es,jacket*Asl,com,jacket + Es,core*Asl,com,core)/Asl,com = 200000.00$   
 $yv = 0.00083886$   
 $shv = 0.00268436$   
 $ftv = 314.5735$   
 $fyv = 262.1446$   
 $suv = 0.00268436$   
 using (30) in Biskinis/Fardis (2013) multiplied with shear\_factor  
 and also multiplied by the shear\_factor according to 15.7.1.4, with  
 Shear\_factor = 1.00  
 $lo/lou,min = lb/ld = 0.13907892$   
 $suv = 0.4*esuv\_nominal ((5.5), TBDY) = 0.032$   
 From table 5A.1, TBDY:  $esuv\_nominal = 0.08$ ,  
 considering characteristic value  $fsyv = fsv/1.2$ , from table 5.1, TBDY  
 For calculation of  $esuv\_nominal$  and  $yv, shv,ftv,fyv$ , it is considered  
 characteristic value  $fsyv = fsv/1.2$ , from table 5.1, TBDY.  
 $y1, sh1,ft1,fy1$ , are also multiplied by  $Min(1,1.25*(lb/ld)^{2/3})$ , from 10.3.5, ASCE 41-17.  
 with  $fsv = (fs,jacket*Asl,mid,jacket + fs,mid*Asl,mid,core)/Asl,mid = 262.1446$   
 with  $Esv = (Es,jacket*Asl,mid,jacket + Es,mid*Asl,mid,core)/Asl,mid = 200000.00$   
 $1 = Asl,ten/(b*d)*(fs1/fc) = 0.06824101$   
 $2 = Asl,com/(b*d)*(fs2/fc) = 0.03513975$   
 $v = Asl,mid/(b*d)*(fsv/fc) = 0.06202846$   
 and confined core properties:  
 $b = 340.00$   
 $d = 677.00$   
 $d' = 13.00$   
 $fcc (5A.2, TBDY) = 38.13135$   
 $cc (5A.5, TBDY) = 0.00471045$   
 $c = \text{confinement factor} = 1.27105$   
 $1 = Asl,ten/(b*d)*(fs1/fc) = 0.08384116$   
 $2 = Asl,com/(b*d)*(fs2/fc) = 0.04317283$   
 $v = Asl,mid/(b*d)*(fsv/fc) = 0.07620839$   
 Case/Assumption: Unconfined full section - Steel rupture  
 ' satisfies Eq. (4.3)  
 --->  
 $v < vs,y2$  - LHS eq.(4.5) is satisfied  
 --->  
 $su (4.9) = 0.2584548$   
 $Mu = MRc (4.14) = 5.0296E+008$   
 $u = su (4.1) = 5.1201636E-006$

-----  
 Calculation of ratio  $lb/ld$

Lap Length:  $l_b/l_d = 0.13907892$   
 $l_b = 300.00$   
 $l_d = 2157.049$   
 Calculation of  $l_b$ ,min according to (25.4.3.2), ACI 318-14, using mean values for all the section re-bars.  
 $l_d$ ,min from (25.4.3.2) is multiplied 2 times to account for smooth re-bars (9.1.2, TS500 - No provision in ACI 318)  
 $= 1$   
 $db = 16.66667$   
 Mean strength value of all re-bars:  $f_y = 781.25$   
 Mean concrete strength:  $f'_c = (f'_{c\_jacket} \cdot Area_{jacket} + f'_{c\_core} \cdot Area_{core}) / Area_{section} = 30.00$ , but  $f_c^{0.5} \leq 8.3$   
 MPa (22.5.3.1, ACI 318-14)  
 $t = 1.00$   
 $s = 0.80$   
 $e = 1.00$   
 $cb = 25.00$   
 $K_{tr} = 1.7174$   
 $A_{tr} = \text{Min}(A_{tr\_x}, A_{tr\_y}) = 257.6106$   
 where  $A_{tr\_x}$ ,  $A_{tr\_y}$  are the sum of the area of all stirrup legs along X and Y loxal axis  
 $s = \text{Max}(s_{external}, s_{internal}) = 250.00$   
 $n = 24.00$

Calculation of  $\mu_{2+}$

Calculation of ultimate curvature  $\mu$  according to 4.1, Biskinis/Fardis 2013:

$\mu = 4.8099118E-006$   
 $\mu_u = 2.3387E+008$

with full section properties:

$b = 750.00$   
 $d = 707.00$   
 $d' = 43.00$   
 $v = 0.00102301$   
 $N = 16273.608$   
 $f_c = 30.00$   
 $co$  (5A.5, TBDY) = 0.002  
 Final value of  $\mu_u$ :  $\mu_u = \text{shear\_factor} \cdot \text{Max}(\mu_u, \mu_c) = 0.01260361$   
 The Shear\_factor is considered equal to 1 (pure moment strength)  
 From (5.4b), TBDY:  $\mu_u = 0.01260361$   
 we (5.4c) = 0.05179731  
 $ase$  ((5.4d), TBDY) =  $(ase1 \cdot A_{ext} + ase2 \cdot A_{int}) / A_{sec} = 0.45746528$   
 $ase1 = \text{Max}(((A_{conf,max1} - A_{noConf1}) / A_{conf,max1}) \cdot (A_{conf,min1} / A_{conf,max1}), 0) = 0.45746528$   
 The definitions of  $A_{noConf}$ ,  $A_{conf,min}$  and  $A_{conf,max}$  are derived from generalization of the rectangular sections confinement, which is expressed by (5.4d).  
 The generalization is done according to Mander, J., Priestley, M., and Park, R. (1988) "Theoretical Stress-Strain Model for Confined Concrete." J. Struct. Eng., 10.1061/(ASCE)0733-9445(1988)114:8(1804), 1804-1826.  
 $A_{conf,max1} = 353600.00$  is the confined core area at levels of member with hoops and is calculated as the area of core enclosed by the center lines of the external perimeter hoops.  
 $A_{conf,min1} = 293525.00$  is the confined core area at midway between the levels of hoops and is calculated by reducing all the dimensions of the area  $A_{conf,max1}$  by a length equal to half the clear spacing between external hoops.  
 $A_{noConf1} = 158733.333$  is the unconfined external core area which is equal to  $b_i^2/6$  as defined at (A.2).  
 $ase2$  ( $\geq ase1$ ) =  $\text{Max}(((A_{conf,max2} - A_{noConf2}) / A_{conf,max2}) \cdot (A_{conf,min2} / A_{conf,max2}), 0) = 0.45746528$   
 The definitions of  $A_{noConf}$ ,  $A_{conf,min}$  and  $A_{conf,max}$  are derived from generalization of the rectangular sections confinement, which is expressed by (5.4d).  
 The generalization is done according to Mander, J., Priestley, M., and Park, R. (1988) "Theoretical Stress-Strain Model for Confined Concrete." J. Struct. Eng., 10.1061/(ASCE)0733-9445(1988)114:8(1804), 1804-1826.  
 $A_{conf,max2} = 171264.00$  is the confined core area at levels of member with hoops and is calculated as the area of core enclosed by the center lines of the internal perimeter hoops.  
 $A_{conf,min2} = 54741.00$  is the confined core area at midway between the levels of hoops and is calculated by reducing all the dimensions of the area  $A_{conf,max2}$  by a length equal to half the clear spacing between internal hoops.

AnoConf2 = 106242.667 is the unconfined internal core area which is equal to  $b_i^2/6$  as defined at (A.2).  
 $psh_{min} \cdot F_{ywe} = \min(psh_x \cdot F_{ywe}, psh_y \cdot F_{ywe}) = 3.3968$

$psh_x \cdot F_{ywe} = psh1 \cdot F_{ywe1} + ps2 \cdot F_{ywe2} = 3.3968$   
 $psh1 \text{ ((5.4d), TBDY)} = Lstir1 \cdot Astir1 / (Asec \cdot s1) = 0.00367709$   
 $Lstir1 \text{ (Length of stirrups along Y)} = 2060.00$   
 $Astir1 \text{ (stirrups area)} = 78.53982$   
 $psh2 \text{ (5.4d)} = Lstir2 \cdot Astir2 / (Asec \cdot s2) = 0.00067082$   
 $Lstir2 \text{ (Length of stirrups along Y)} = 1468.00$   
 $Astir2 \text{ (stirrups area)} = 50.26548$

$psh_y \cdot F_{ywe} = psh1 \cdot F_{ywe1} + ps2 \cdot F_{ywe2} = 3.3968$   
 $psh1 \text{ ((5.4d), TBDY)} = Lstir1 \cdot Astir1 / (Asec \cdot s1) = 0.00367709$   
 $Lstir1 \text{ (Length of stirrups along X)} = 2060.00$   
 $Astir1 \text{ (stirrups area)} = 78.53982$   
 $psh2 \text{ ((5.4d), TBDY)} = Lstir2 \cdot Astir2 / (Asec \cdot s2) = 0.00067082$   
 $Lstir2 \text{ (Length of stirrups along X)} = 1468.00$   
 $Astir2 \text{ (stirrups area)} = 50.26548$

$Asec = 440000.00$   
 $s1 = 100.00$   
 $s2 = 250.00$   
 $fywe1 = 781.25$   
 $fywe2 = 781.25$   
 $fce = 30.00$

From ((5.A5), TBDY), TBDY:  $cc = 0.00471045$   
 $c = \text{confinement factor} = 1.27105$

$y1 = 0.00083886$   
 $sh1 = 0.00268436$   
 $ft1 = 314.5735$   
 $fy1 = 262.1446$   
 $su1 = 0.00268436$

using (30) in Biskinis/Fardis (2013) multiplied with shear\_factor  
and also multiplied by the shear\_factor according to 15.7.1.4, with  
 $\text{Shear\_factor} = 1.00$

$lo/lou_{min} = lb/ld = 0.13907892$   
 $su1 = 0.4 \cdot esu1_{nominal} \text{ ((5.5), TBDY)} = 0.032$

From table 5A.1, TBDY:  $esu1_{nominal} = 0.08$ ,

For calculation of  $esu1_{nominal}$  and  $y1, sh1, ft1, fy1$ , it is considered  
characteristic value  $fsy1 = fs1/1.2$ , from table 5.1, TBDY.

$y1, sh1, ft1, fy1$ , are also multiplied by  $\min(1, 1.25 \cdot (lb/ld)^{2/3})$ , from 10.3.5, ASCE 41-17.

with  $fs1 = (fs_{jacket} \cdot Asl_{ten,jacket} + fs_{core} \cdot Asl_{ten,core}) / Asl_{ten} = 262.1446$

with  $Es1 = (Es_{jacket} \cdot Asl_{ten,jacket} + Es_{core} \cdot Asl_{ten,core}) / Asl_{ten} = 200000.00$

$y2 = 0.00083886$   
 $sh2 = 0.00268436$   
 $ft2 = 314.5735$   
 $fy2 = 262.1446$   
 $su2 = 0.00268436$

using (30) in Biskinis/Fardis (2013) multiplied with shear\_factor  
and also multiplied by the shear\_factor according to 15.7.1.4, with  
 $\text{Shear\_factor} = 1.00$

$lo/lou_{min} = lb/lb_{min} = 0.13907892$   
 $su2 = 0.4 \cdot esu2_{nominal} \text{ ((5.5), TBDY)} = 0.032$

From table 5A.1, TBDY:  $esu2_{nominal} = 0.08$ ,

For calculation of  $esu2_{nominal}$  and  $y2, sh2, ft2, fy2$ , it is considered  
characteristic value  $fsy2 = fs2/1.2$ , from table 5.1, TBDY.

$y1, sh1, ft1, fy1$ , are also multiplied by  $\min(1, 1.25 \cdot (lb/ld)^{2/3})$ , from 10.3.5, ASCE 41-17.

with  $fs2 = (fs_{jacket} \cdot Asl_{com,jacket} + fs_{core} \cdot Asl_{com,core}) / Asl_{com} = 262.1446$

with  $Es2 = (Es_{jacket} \cdot Asl_{com,jacket} + Es_{core} \cdot Asl_{com,core}) / Asl_{com} = 200000.00$

$yv = 0.00083886$   
 $shv = 0.00268436$   
 $ftv = 314.5735$   
 $fyv = 262.1446$   
 $suv = 0.00268436$

using (30) in Biskinis/Fardis (2013) multiplied with shear\_factor  
and also multiplied by the shear\_factor according to 15.7.1.4, with  
 $\text{Shear\_factor} = 1.00$

$l_o/l_{ou,min} = l_b/l_d = 0.13907892$   
 $s_{uv} = 0.4 * e_{suv\_nominal} ((5.5), TBDY) = 0.032$   
 From table 5A.1, TBDY:  $e_{suv\_nominal} = 0.08$ ,  
 considering characteristic value  $f_{syv} = f_{sv}/1.2$ , from table 5.1, TBDY  
 For calculation of  $e_{suv\_nominal}$  and  $y_v$ ,  $sh_v$ ,  $ft_v$ ,  $f_{yv}$ , it is considered  
 characteristic value  $f_{syv} = f_{sv}/1.2$ , from table 5.1, TBDY.  
 $y_1$ ,  $sh_1$ ,  $ft_1$ ,  $f_{y1}$ , are also multiplied by  $\text{Min}(1, 1.25 * (l_b/l_d)^{2/3})$ , from 10.3.5, ASCE 41-17.  
 with  $f_{sv} = (f_{sj\_jacket} * A_{sl,mid,jacket} + f_{s,mid} * A_{sl,mid,core}) / A_{sl,mid} = 262.1446$   
 with  $E_{sv} = (E_{sj\_jacket} * A_{sl,mid,jacket} + E_{s,mid} * A_{sl,mid,core}) / A_{sl,mid} = 200000.00$   
 $1 = A_{sl,ten} / (b * d) * (f_{s1} / f_c) = 0.0187412$   
 $2 = A_{sl,com} / (b * d) * (f_{s2} / f_c) = 0.03639521$   
 $v = A_{sl,mid} / (b * d) * (f_{sv} / f_c) = 0.03308184$

and confined core properties:

$b = 690.00$   
 $d = 677.00$   
 $d' = 13.00$   
 $f_{cc} (5A.2, TBDY) = 38.13135$   
 $cc (5A.5, TBDY) = 0.00471045$   
 $c = \text{confinement factor} = 1.27105$   
 $1 = A_{sl,ten} / (b * d) * (f_{s1} / f_c) = 0.02127357$   
 $2 = A_{sl,com} / (b * d) * (f_{s2} / f_c) = 0.04131304$   
 $v = A_{sl,mid} / (b * d) * (f_{sv} / f_c) = 0.03755196$

Case/Assumption: Unconfined full section - Steel rupture  
 ' satisfies Eq. (4.3)

--->  
 $v < v_{s,y2}$  - LHS eq.(4.5) is satisfied  
 --->  
 $su (4.9) = 0.21062322$   
 $M_u = M_{Rc} (4.14) = 2.3387E+008$   
 $u = su (4.1) = 4.8099118E-006$

Calculation of ratio  $l_b/l_d$

Lap Length:  $l_b/l_d = 0.13907892$   
 $l_b = 300.00$   
 $l_d = 2157.049$   
 Calculation of  $l_b,min$  according to (25.4.3.2), ACI 318-14, using mean values for all the section re-bars.  
 $l_d,min$  from (25.4.3.2) is multiplied 2 times to account for smooth re-bars (9.1.2, TS500 - No provision in ACI 318)  
 $= 1$   
 $db = 16.66667$   
 Mean strength value of all re-bars:  $f_y = 781.25$   
 Mean concrete strength:  $f_c' = (f_c'_{jacket} * Area_{jacket} + f_c'_{core} * Area_{core}) / Area_{section} = 30.00$ , but  $f_c'^{0.5} \leq 8.3$   
 MPa (22.5.3.1, ACI 318-14)  
 $t = 1.00$   
 $s = 0.80$   
 $e = 1.00$   
 $cb = 25.00$   
 $K_{tr} = 1.7174$   
 $A_{tr} = \text{Min}(A_{tr\_x}, A_{tr\_y}) = 257.6106$   
 where  $A_{tr\_x}$ ,  $A_{tr\_y}$  are the sum of the area of all stirrup legs along X and Y loxal axis  
 $s = \text{Max}(s_{external}, s_{internal}) = 250.00$   
 $n = 24.00$

Calculation of  $M_{u2}$ -

Calculation of ultimate curvature  $u$  according to 4.1, Biskinis/Fardis 2013:

$u = 5.1201636E-006$   
 $M_u = 5.0296E+008$

with full section properties:

$b = 400.00$   
 $d = 707.00$

$d' = 43.00$   
 $v = 0.00191815$   
 $N = 16273.608$   
 $f_c = 30.00$   
 $co (5A.5, TBDY) = 0.002$   
 Final value of  $cu$ :  $cu^* = shear\_factor * Max(cu, cc) = 0.01260361$   
 The Shear\_factor is considered equal to 1 (pure moment strength)  
 From (5.4b), TBDY:  $cu = 0.01260361$   
 $we (5.4c) = 0.05179731$   
 $ase ((5.4d), TBDY) = (ase1 * A_{ext} + ase2 * A_{int}) / A_{sec} = 0.45746528$   
 $ase1 = Max(((A_{conf,max1} - A_{noConf1}) / A_{conf,max1}) * (A_{conf,min1} / A_{conf,max1}), 0) = 0.45746528$   
 The definitions of  $A_{noConf}$ ,  $A_{conf,min}$  and  $A_{conf,max}$  are derived from generalization of the rectangular sections confinement, which is expressed by (5.4d).  
 The generalization is done according to Mander, J., Priestley, M., and Park, R. (1988) "Theoretical Stress-Strain Model for Confined Concrete."  
 J. Struct. Eng., 10.1061/(ASCE)0733-9445(1988)114:8(1804), 1804-1826.  
 $A_{conf,max1} = 353600.00$  is the confined core area at levels of member with hoops and is calculated as the area of core enclosed by the center lines of the external perimeter hoops.  
 $A_{conf,min1} = 293525.00$  is the confined core area at midway between the levels of hoops and is calculated by reducing all the dimensions of the area  $A_{conf,max1}$  by a length equal to half the clear spacing between external hoops.  
 $A_{noConf1} = 158733.333$  is the unconfined external core area which is equal to  $b_i^2/6$  as defined at (A.2).  
 $ase2 (>= ase1) = Max(((A_{conf,max2} - A_{noConf2}) / A_{conf,max2}) * (A_{conf,min2} / A_{conf,max2}), 0) = 0.45746528$   
 The definitions of  $A_{noConf}$ ,  $A_{conf,min}$  and  $A_{conf,max}$  are derived from generalization of the rectangular sections confinement, which is expressed by (5.4d).  
 The generalization is done according to Mander, J., Priestley, M., and Park, R. (1988) "Theoretical Stress-Strain Model for Confined Concrete."  
 J. Struct. Eng., 10.1061/(ASCE)0733-9445(1988)114:8(1804), 1804-1826.  
 $A_{conf,max2} = 171264.00$  is the confined core area at levels of member with hoops and is calculated as the area of core enclosed by the center lines of the internal perimeter hoops.  
 $A_{conf,min2} = 54741.00$  is the confined core area at midway between the levels of hoops and is calculated by reducing all the dimensions of the area  $A_{conf,max2}$  by a length equal to half the clear spacing between internal hoops.  
 $A_{noConf2} = 106242.667$  is the unconfined internal core area which is equal to  $b_i^2/6$  as defined at (A.2).  
 $psh,min * F_{ywe} = Min(psh,x * F_{ywe}, psh,y * F_{ywe}) = 3.3968$

---

$psh_x * F_{ywe} = psh1 * F_{ywe1} + ps2 * F_{ywe2} = 3.3968$   
 $psh1 ((5.4d), TBDY) = L_{stir1} * A_{stir1} / (A_{sec} * s1) = 0.00367709$   
 $L_{stir1}$  (Length of stirrups along Y) = 2060.00  
 $A_{stir1}$  (stirrups area) = 78.53982  
 $psh2 (5.4d) = L_{stir2} * A_{stir2} / (A_{sec} * s2) = 0.00067082$   
 $L_{stir2}$  (Length of stirrups along Y) = 1468.00  
 $A_{stir2}$  (stirrups area) = 50.26548

---

$psh_y * F_{ywe} = psh1 * F_{ywe1} + ps2 * F_{ywe2} = 3.3968$   
 $psh1 ((5.4d), TBDY) = L_{stir1} * A_{stir1} / (A_{sec} * s1) = 0.00367709$   
 $L_{stir1}$  (Length of stirrups along X) = 2060.00  
 $A_{stir1}$  (stirrups area) = 78.53982  
 $psh2 ((5.4d), TBDY) = L_{stir2} * A_{stir2} / (A_{sec} * s2) = 0.00067082$   
 $L_{stir2}$  (Length of stirrups along X) = 1468.00  
 $A_{stir2}$  (stirrups area) = 50.26548

---

$A_{sec} = 440000.00$   
 $s1 = 100.00$   
 $s2 = 250.00$   
 $f_{ywe1} = 781.25$   
 $f_{ywe2} = 781.25$   
 $f_{ce} = 30.00$   
 From ((5.A5), TBDY), TBDY:  $cc = 0.00471045$   
 $c =$  confinement factor = 1.27105  
 $y1 = 0.00083886$   
 $sh1 = 0.00268436$   
 $ft1 = 314.5735$   
 $fy1 = 262.1446$   
 $su1 = 0.00268436$   
 using (30) in Biskinis/Fardis (2013) multiplied with shear\_factor and also multiplied by the shear\_factor according to 15.7.1.4, with

```

Shear_factor = 1.00
lo/lou,min = lb/ld = 0.13907892
su1 = 0.4*esu1_nominal ((5.5), TBDY) = 0.032
From table 5A.1, TBDY: esu1_nominal = 0.08,
For calculation of esu1_nominal and y1, sh1,ft1,fy1, it is considered
characteristic value fsy1 = fs1/1.2, from table 5.1, TBDY.
y1, sh1,ft1,fy1, are also multiplied by Min(1,1.25*(lb/ld)^ 2/3), from 10.3.5, ASCE 41-17.
with fs1 = (fs,jacket*Asl,ten,jacket + fs,core*Asl,ten,core)/Asl,ten = 262.1446
with Es1 = (Es,jacket*Asl,ten,jacket + Es,core*Asl,ten,core)/Asl,ten = 200000.00
y2 = 0.00083886
sh2 = 0.00268436
ft2 = 314.5735
fy2 = 262.1446
su2 = 0.00268436
using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00
lo/lou,min = lb/lb,min = 0.13907892
su2 = 0.4*esu2_nominal ((5.5), TBDY) = 0.032
From table 5A.1, TBDY: esu2_nominal = 0.08,
For calculation of esu2_nominal and y2, sh2,ft2,fy2, it is considered
characteristic value fsy2 = fs2/1.2, from table 5.1, TBDY.
y1, sh1,ft1,fy1, are also multiplied by Min(1,1.25*(lb/ld)^ 2/3), from 10.3.5, ASCE 41-17.
with fs2 = (fs,jacket*Asl,com,jacket + fs,core*Asl,com,core)/Asl,com = 262.1446
with Es2 = (Es,jacket*Asl,com,jacket + Es,core*Asl,com,core)/Asl,com = 200000.00
yv = 0.00083886
shv = 0.00268436
ftv = 314.5735
fyv = 262.1446
suv = 0.00268436
using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00
lo/lou,min = lb/ld = 0.13907892
suv = 0.4*esuv_nominal ((5.5), TBDY) = 0.032
From table 5A.1, TBDY: esuv_nominal = 0.08,
considering characteristic value fsyv = fsv/1.2, from table 5.1, TBDY
For calculation of esuv_nominal and yv, shv,ftv,fyv, it is considered
characteristic value fsyv = fsv/1.2, from table 5.1, TBDY.
y1, sh1,ft1,fy1, are also multiplied by Min(1,1.25*(lb/ld)^ 2/3), from 10.3.5, ASCE 41-17.
with fsv = (fs,jacket*Asl,mid,jacket + fs,mid*Asl,mid,core)/Asl,mid = 262.1446
with Esv = (Es,jacket*Asl,mid,jacket + Es,mid*Asl,mid,core)/Asl,mid = 200000.00
1 = Asl,ten/(b*d)*(fs1/fc) = 0.06824101
2 = Asl,com/(b*d)*(fs2/fc) = 0.03513975
v = Asl,mid/(b*d)*(fsv/fc) = 0.06202846
and confined core properties:
b = 340.00
d = 677.00
d' = 13.00
fcc (5A.2, TBDY) = 38.13135
cc (5A.5, TBDY) = 0.00471045
c = confinement factor = 1.27105
1 = Asl,ten/(b*d)*(fs1/fc) = 0.08384116
2 = Asl,com/(b*d)*(fs2/fc) = 0.04317283
v = Asl,mid/(b*d)*(fsv/fc) = 0.07620839
Case/Assumption: Unconfined full section - Steel rupture
' satisfies Eq. (4.3)
--->
v < vsy2 - LHS eq.(4.5) is satisfied
--->
su (4.9) = 0.2584548
Mu = MRc (4.14) = 5.0296E+008
u = su (4.1) = 5.1201636E-006

```

Calculation of ratio lb/ld



Lap Length:  $l_b/l_d = 0.13907892$   
 $l_b = 300.00$   
 $l_d = 2157.049$   
 Calculation of  $l_b$ , min according to (25.4.3.2), ACI 318-14, using mean values for all the section re-bars.  
 $l_d$ , min from (25.4.3.2) is multiplied 2 times to account for smooth re-bars (9.1.2, TS500 - No provision in ACI 318)  
 $= 1$   
 $db = 16.66667$   
 Mean strength value of all re-bars:  $f_y = 781.25$   
 Mean concrete strength:  $f'_c = (f'_{c\_jacket} \cdot Area\_jacket + f'_{c\_core} \cdot Area\_core) / Area\_section = 30.00$ , but  $f_c^{0.5} \leq 8.3$   
 MPa (22.5.3.1, ACI 318-14)  
 $t = 1.00$   
 $s = 0.80$   
 $e = 1.00$   
 $cb = 25.00$   
 $K_{tr} = 1.7174$   
 $A_{tr} = \text{Min}(A_{tr\_x}, A_{tr\_y}) = 257.6106$   
 where  $A_{tr\_x}$ ,  $A_{tr\_y}$  are the sum of the area of all stirrup legs along X and Y loxal axis  
 $s = \text{Max}(s_{external}, s_{internal}) = 250.00$   
 $n = 24.00$

Calculation of Shear Strength  $V_r = \text{Min}(V_{r1}, V_{r2}) = 1.0392E+006$

Calculation of Shear Strength at edge 1,  $V_{r1} = 1.0392E+006$

$V_{r1} = V_{Col} ((10.3), \text{ASCE } 41-17) = k_{nl} \cdot V_{Col0}$

$V_{Col0} = 1.0392E+006$

$k_{nl} = 1$  (zero step-static loading)

NOTE: In expression (10-3) ' $V_s = A_v \cdot f_y \cdot d / s$ ' is replaced by ' $V_s + f \cdot V_f$ '  
 where  $V_f$  is the contribution of FRPs (11.3), ACI 440).

$= 1$  (normal-weight concrete)

Mean concrete strength:  $f'_c = (f'_{c\_jacket} \cdot Area\_jacket + f'_{c\_core} \cdot Area\_core) / Area\_section = 30.00$ , but  $f_c^{0.5} \leq 8.3$   
 MPa (22.5.3.1, ACI 318-14)

$M/Vd = 4.00$

$\mu_u = 1308.675$

$V_u = 0.0001715$

$d = 0.8 \cdot h = 600.00$

$N_u = 16273.608$

$A_g = 300000.00$

From (11.5.4.8), ACI 318-14:  $V_s = V_{s,jacket} + V_{s,core} = 1.0138E+006$

where:

$V_{s,jacket} = V_{s,j1} + V_{s,j2} = 903207.888$

$V_{s,j1} = 314159.265$  is calculated for section web jacket, with:

$d = 320.00$

$A_v = 157079.633$

$f_y = 625.00$

$s = 100.00$

$V_{s,j1}$  is multiplied by  $Col,j1 = 1.00$

$s/d = 0.3125$

$V_{s,j2} = 589048.623$  is calculated for section flange jacket, with:

$d = 600.00$

$A_v = 157079.633$

$f_y = 625.00$

$s = 100.00$

$V_{s,j2}$  is multiplied by  $Col,j2 = 1.00$

$s/d = 0.16666667$

$V_{s,core} = V_{s,c1} + V_{s,c2} = 110584.061$

$V_{s,c1} = 0.00$  is calculated for section web core, with:

$d = 160.00$

$A_v = 100530.965$

$f_y = 625.00$

$s = 250.00$

$V_{s,c1}$  is multiplied by  $Col,c1 = 0.00$

$s/d = 1.5625$

$V_{s,c2} = 110584.061$  is calculated for section flange core, with:

$$d = 440.00$$

$$A_v = 100530.965$$

$$f_y = 625.00$$

$$s = 250.00$$

$V_{s,c2}$  is multiplied by  $Col,c2 = 1.00$

$$s/d = 0.56818182$$

$V_f ((11-3)-(11.4), ACI 440) = 0.00$

From (11-11), ACI 440:  $V_s + V_f \leq 873250.061$

$$bw = 400.00$$

Calculation of Shear Strength at edge 2,  $V_{r2} = 1.0392E+006$

$V_{r2} = V_{Col} ((10.3), ASCE 41-17) = knl * V_{Col0}$

$$V_{Col0} = 1.0392E+006$$

$knl = 1$  (zero step-static loading)

NOTE: In expression (10-3) ' $V_s = A_v * f_y * d / s$ ' is replaced by ' $V_s + f * V_f$ ' where  $V_f$  is the contribution of FRPs (11.3), ACI 440).

$= 1$  (normal-weight concrete)

Mean concrete strength:  $f'_c = (f'_c_{jacket} * Area_{jacket} + f'_c_{core} * Area_{core}) / Area_{section} = 30.00$ , but  $f'_c^{0.5} \leq 8.3$  MPa (22.5.3.1, ACI 318-14)

$$M/Vd = 4.00$$

$$\mu_u = 1308.675$$

$$\nu_u = 0.0001715$$

$$d = 0.8 * h = 600.00$$

$$\mu_u = 16273.608$$

$$A_g = 300000.00$$

From (11.5.4.8), ACI 318-14:  $V_s = V_{sjacket} + V_{s,core} = 1.0138E+006$

where:

$$V_{sjacket} = V_{sj1} + V_{sj2} = 903207.888$$

$V_{sj1} = 314159.265$  is calculated for section web jacket, with:

$$d = 320.00$$

$$A_v = 157079.633$$

$$f_y = 625.00$$

$$s = 100.00$$

$V_{sj1}$  is multiplied by  $Col,j1 = 1.00$

$$s/d = 0.3125$$

$V_{sj2} = 589048.623$  is calculated for section flange jacket, with:

$$d = 600.00$$

$$A_v = 157079.633$$

$$f_y = 625.00$$

$$s = 100.00$$

$V_{sj2}$  is multiplied by  $Col,j2 = 1.00$

$$s/d = 0.16666667$$

$$V_{s,core} = V_{s,c1} + V_{s,c2} = 110584.061$$

$V_{s,c1} = 0.00$  is calculated for section web core, with:

$$d = 160.00$$

$$A_v = 100530.965$$

$$f_y = 625.00$$

$$s = 250.00$$

$V_{s,c1}$  is multiplied by  $Col,c1 = 0.00$

$$s/d = 1.5625$$

$V_{s,c2} = 110584.061$  is calculated for section flange core, with:

$$d = 440.00$$

$$A_v = 100530.965$$

$$f_y = 625.00$$

$$s = 250.00$$

$V_{s,c2}$  is multiplied by  $Col,c2 = 1.00$

$$s/d = 0.56818182$$

$V_f ((11-3)-(11.4), ACI 440) = 0.00$

From (11-11), ACI 440:  $V_s + V_f \leq 873250.061$

$$bw = 400.00$$

End Of Calculation of Shear Capacity ratio for element: column JLC1 of floor 1

At local axis: 2

Start Of Calculation of Chord Rotation Capacity for element: column JLC1 of floor 1

At local axis: 3

Integration Section: (a)

Section Type: rcjlc3

#### Constant Properties

Knowledge Factor,  $\gamma = 1.00$

Chord Rotation is generally considered as Deformation-Controlled Action according to Table C7-1, ASCE 41-17.

Mean strengths are used for Deformation-Controlled Actions according to 7.5.1.3, ASCE 41-17

Consequently:

Jacket

New material of Primary Member: Concrete Strength,  $f_c = f_{cm} = 30.00$

New material of Primary Member: Steel Strength,  $f_s = f_{sm} = 625.00$

Concrete Elasticity,  $E_c = 25742.96$

Steel Elasticity,  $E_s = 200000.00$

Existing Column

New material of Primary Member: Concrete Strength,  $f_c = f_{cm} = 30.00$

New material of Primary Member: Steel Strength,  $f_s = f_{sm} = 625.00$

Concrete Elasticity,  $E_c = 25742.96$

Steel Elasticity,  $E_s = 200000.00$

Max Height,  $H_{max} = 750.00$

Min Height,  $H_{min} = 400.00$

Max Width,  $W_{max} = 750.00$

Min Width,  $W_{min} = 400.00$

Jacket Thickness,  $t_j = 100.00$

Cover Thickness,  $c = 25.00$

Element Length,  $L = 3000.00$

Primary Member

Smooth Bars

Ductile Steel

With Detailing for Earthquake Resistance (including stirrups closed at  $135^\circ$ )

Longitudinal Bars With Ends Lapped Starting at the End Sections

Lap Length  $l_b = 300.00$

No FRP Wrapping

#### Stepwise Properties

Bending Moment,  $M = -2.3128E+007$

Shear Force,  $V_2 = -7609.421$

Shear Force,  $V_3 = 213.4386$

Axial Force,  $F = -17779.344$

Longitudinal Reinforcement Area Distribution (in 2 divisions)

-Tension:  $A_{sl,t} = 0.00$

-Compression:  $A_{sl,c} = 5353.274$

Longitudinal Reinforcement Area Distribution (in 3 divisions)

-Tension:  $A_{sl,ten} = 1137.257$

-Compression:  $A_{sl,com} = 2208.54$

-Middle:  $A_{sl,mid} = 2007.478$

Longitudinal External Reinforcement Area Distribution (in 3 divisions)

-Tension:  $A_{sl,ten,jacket} = 829.3805$

-Compression:  $A_{sl,com,jacket} = 1746.726$

-Middle:  $A_{sl,mid,jacket} = 1545.664$

Longitudinal Internal Reinforcement Area Distribution (in 3 divisions)

-Tension:  $A_{sl,ten,core} = 307.8761$

-Compression:  $A_{sl,com,core} = 461.8141$

-Middle:  $A_{sl,mid,core} = 461.8141$

Mean Diameter of Tension Reinforcement,  $Db_L = 16.80$

New component: From table 7-7, ASCE 41\_17: Final chord rotation Capacity  $u_R = 1.0$   $u = 0.04097012$   
 $u = y + p = 0.04097012$

- Calculation of  $y$  -

$y = (M_y * L_s / 3) / E_{eff} = 0.0019977$  ((4.29), Biskinis Phd))  
 $M_y = 2.8709E+008$   
 $L_s = M/V$  (with  $L_s > 0.1 * L$  and  $L_s < 2 * L$ ) = 3039.351  
From table 10.5, ASCE 41\_17:  $E_{eff} = factor * E_c * I_g = 1.4560E+014$   
 $factor = 0.30$   
 $A_g = 440000.00$   
Mean concrete strength:  $f'_c = (f'_{c\_jacket} * Area\_jacket + f'_{c\_core} * Area\_core) / Area\_section = 30.00$   
 $N = 17779.344$   
 $E_c * I_g = E_{c\_jacket} * I_{g\_jacket} + E_{c\_core} * I_{g\_core} = 4.8532E+014$

Calculation of Yielding Moment  $M_y$

Calculation of  $y$  and  $M_y$  according to Annex 7 -

Assuming neutral axis within flange ( $y < t/d$ , compression zone rectangular) with:

flange width,  $b = 750.00$

web width,  $b_w = 400.00$

flange thickness,  $t = 400.00$

$y = \text{Min}(y_{ten}, y_{com})$   
 $y_{ten} = 2.1455196E-006$   
with ((10.1), ASCE 41-17)  $f_y = \text{Min}(f_y, 1.25 * f_y * (I_b / I_d)^{2/3}) = 243.3535$   
 $d = 707.00$   
 $y = 0.19784983$   
 $A = 0.01023354$   
 $B = 0.00454395$   
with  $p_t = 0.00434791$   
 $p_c = 0.00416509$   
 $p_v = 0.00378591$   
 $N = 17779.344$   
 $b = 750.00$   
 $" = 0.06082037$   
 $y_{comp} = 1.5202265E-005$   
with  $f_c = 30.00$   
 $E_c = 25742.96$   
 $y = 0.19516753$   
 $A = 0.01001583$   
 $B = 0.00440616$   
with  $E_s = 200000.00$   
CONFIRMATION:  $y = 0.19594836 < t/d$

Calculation of ratio  $I_b / I_d$

Lap Length:  $I_d / I_{d,min} = 0.17384865$

$I_b = 300.00$

$I_d = 1725.639$

Calculation of  $I$  according to (25.4.3.2), ACI 318-14, using mean values for all the section re-bars.

$I_{d,min}$  from (25.4.3.2) is multiplied 2 times to account for smooth re-bars (10.3.5, ASCE 41-17)

= 1

$d_b = 16.66667$

Mean strength value of all re-bars:  $f_y = 625.00$

Mean concrete strength:  $f'_c = (f'_{c\_jacket} * Area\_jacket + f'_{c\_core} * Area\_core) / Area\_section = 30.00$ , but  $f_c^{0.5} \leq 8.3$  MPa (22.5.3.1, ACI 318-14)

$t = 1.00$

$s = 0.80$

$e = 1.00$

$cb = 25.00$   
 $K_{tr} = 1.7174$   
 $A_{tr} = \text{Min}(A_{tr\_x}, A_{tr\_y}) = 257.6106$   
 where  $A_{tr\_x}$ ,  $A_{tr\_y}$  are the sum of the area of all stirrup legs along X and Y loxal axis  
 $s = \text{Max}(s_{\text{external}}, s_{\text{internal}}) = 250.00$   
 $n = 24.00$

-----  
 - Calculation of  $p$  -  
 -----

From table 10-8:  $p = 0.03897242$

with:

- Columns controlled by inadequate development or splicing along the clear height because  $l_b/l_d < 1$

shear control ratio  $V_y E / V_{ColOE} = 0.32266369$

$d = d_{\text{external}} = 707.00$

$s = s_{\text{external}} = 0.00$

-  $t = s_1 + s_2 + 2 \cdot t_f / b_w \cdot (f_{fe} / f_s) = 0.00434791$

jacket:  $s_1 = A_{v1} \cdot L_{stir1} / (s_1 \cdot A_g) = 0.00367709$

$A_{v1} = 78.53982$ , is the area of every stirrup parallel to loading (shear) direction

$L_{stir1} = 2060.00$ , is the total Length of all stirrups parallel to loading (shear) direction

$s_1 = 100.00$

core:  $s_2 = A_{v2} \cdot L_{stir2} / (s_2 \cdot A_g) = 0.00067082$

$A_{v2} = 50.26548$ , is the area of every stirrup parallel to loading (shear) direction

$L_{stir2} = 1468.00$ , is the total Length of all stirrups parallel to loading (shear) direction

$s_2 = 250.00$

The term  $2 \cdot t_f / b_w \cdot (f_{fe} / f_s)$  is implemented to account for FRP contribution

where  $f = 2 \cdot t_f / b_w$  is FRP ratio (EC8 - 3, A.4.4.3(6)) and  $f_{fe} / f_s$  normalises  $f$  to steel strength

All these variables have already been given in Shear control ratio calculation.

For the normalisation  $f_s$  of jacket is used.

$NUD = 17779.344$

$A_g = 440000.00$

$f_{cE} = (f_{c\_jacket} \cdot \text{Area\_jacket} + f_{c\_core} \cdot \text{Area\_core}) / \text{section\_area} = 30.00$

$f_{yE} = (f_{y\_ext\_Long\_Reinf} \cdot \text{Area\_ext\_Long\_Reinf} + f_{y\_int\_Long\_Reinf} \cdot \text{Area\_int\_Long\_Reinf}) / \text{Area\_Tot\_Long\_Rein} = 625.00$

$f_{ytE} = (f_{y\_ext\_Trans\_Reinf} \cdot s_1 + f_{y\_int\_Trans\_Reinf} \cdot s_2) / (s_1 + s_2) = 625.00$

$\rho_l = \text{Area\_Tot\_Long\_Rein} / (b \cdot d) = 0.01009575$

$b = 750.00$

$d = 707.00$

$f_{cE} = 30.00$

-----  
 End Of Calculation of Chord Rotation Capacity for element: column JLC1 of floor 1

At local axis: 3

Integration Section: (a)  
 -----

## Calculation No. 13

column C1, Floor 1


Limit State: Collapse Prevention (data interpolation between analysis steps 1 and 2)

Analysis: Uniform +X

Check: Shear capacity VRd

Edge: End

Local Axis: (2)



Start Of Calculation of Shear Capacity for element: column JLC1 of floor 1

At local axis: 2

Integration Section: (b)

Section Type: rcjlcs

Constant Properties

Knowledge Factor,  $\gamma = 1.00$

Member Shear Force is generally considered as Force-Controlled Action according to Table C7-1, ASCE 41-17.

Lower-bound strengths are used for Force-Controlled Actions according to 7.5.1.3, ASCE 41-17

Consequently:

Jacket

New material of Primary Member: Concrete Strength,  $f_c = f_{c\_lower\_bound} = 20.00$

New material of Primary Member: Steel Strength,  $f_s = f_{s\_lower\_bound} = 500.00$

Concrete Elasticity,  $E_c = 25742.96$

Steel Elasticity,  $E_s = 200000.00$

Existing Column

New material of Primary Member: Concrete Strength,  $f_c = f_{c\_lower\_bound} = 20.00$

New material of Primary Member: Steel Strength,  $f_s = f_{s\_lower\_bound} = 500.00$

Concrete Elasticity,  $E_c = 25742.96$

Steel Elasticity,  $E_s = 200000.00$

#####

Note: Especially for the calculation of  $\gamma$  for displacement ductility demand, the expected (mean value) strengths are used (7.5.1.3, ASCE 41-17) because bending is considered as Deformation-Controlled Action (Table C7-1, ASCE 41-17).

Jacket

New material: Concrete Strength,  $f_c = f_{cm} = 30.00$

New material: Steel Strength,  $f_s = f_{sm} = 625.00$

Existing Column

New material: Concrete Strength,  $f_c = f_{cm} = 30.00$

New material: Steel Strength,  $f_s = f_{sm} = 625.00$

#####

Max Height,  $H_{max} = 750.00$

Min Height,  $H_{min} = 400.00$

Max Width,  $W_{max} = 750.00$

Min Width,  $W_{min} = 400.00$

Jacket Thickness,  $t_j = 100.00$

Cover Thickness,  $c = 25.00$

Element Length,  $L = 3000.00$

Primary Member  
Smooth Bars  
Ductile Steel  
With Detailing for Earthquake Resistance (including stirrups closed at 135°)  
Longitudinal Bars With Ends Lapped Starting at the End Sections  
Lap Length  $l_o = l_b = 300.00$   
No FRP Wrapping

#### Stepwise Properties

EDGE -A-  
Bending Moment,  $M_a = -2.3128E+007$   
Shear Force,  $V_a = -7609.421$   
EDGE -B-  
Bending Moment,  $M_b = 293212.583$   
Shear Force,  $V_b = 7609.421$   
BOTH EDGES  
Axial Force,  $F = -17779.344$   
Longitudinal Reinforcement Area Distribution (in 2 divisions)  
-Tension:  $A_{sl,t} = 0.00$   
-Compression:  $A_{sl,c} = 5353.274$   
Longitudinal Reinforcement Area Distribution (in 3 divisions)  
-Tension:  $A_{sl,ten} = 1137.257$   
-Compression:  $A_{sl,com} = 2208.54$   
-Middle:  $A_{sl,mid} = 2007.478$   
Mean Diameter of Tension Reinforcement,  $Db_{L,ten} = 16.80$

New component: From table 7-7, ASCE 41\_17: Final Shear Capacity  $V_R = 1.0 \cdot V_n = 984866.462$   
 $V_n$  ((10.3), ASCE 41-17) =  $k_{nl} \cdot V_{CoI} = 984866.462$   
 $V_{CoI} = 984866.462$   
 $k_{nl} = 1.00$   
 $displacement\_ductility\_demand = 0.12420401$

NOTE: In expression (10-3) ' $V_s = A_v \cdot f_y \cdot d/s$ ' is replaced by ' $V_{s+} = f \cdot V_f$ '  
where  $V_f$  is the contribution of FRPs ((11.3), ACI 440).

= 1 (normal-weight concrete)  
Mean concrete strength:  $f'_c = (f'_{c,jacket} \cdot Area_{jacket} + f'_{c,core} \cdot Area_{core}) / Area_{section} = 20.00$ , but  $f'_c^{0.5} \leq 8.3$   
MPa ((22.5.3.1, ACI 318-14))  
 $M/V_d = 2.00$   
 $M_u = 293212.583$   
 $V_u = 7609.421$   
 $d = 0.8 \cdot h = 600.00$   
 $N_u = 17779.344$   
 $A_g = 300000.00$   
From ((11.5.4.8), ACI 318-14:  $V_s = V_{s,jacket} + V_{s,core} = 811033.559$   
where:  
 $V_{s,jacket} = V_{s,j1} + V_{s,j2} = 722566.31$   
 $V_{s,j1} = 251327.412$  is calculated for section web jacket, with:  
 $d = 320.00$   
 $A_v = 157079.633$   
 $f_y = 500.00$   
 $s = 100.00$   
 $V_{s,j1}$  is multiplied by  $Col_{j1} = 1.00$   
 $s/d = 0.3125$   
 $V_{s,j2} = 471238.898$  is calculated for section flange jacket, with:  
 $d = 600.00$   
 $A_v = 157079.633$   
 $f_y = 500.00$   
 $s = 100.00$   
 $V_{s,j2}$  is multiplied by  $Col_{j2} = 1.00$   
 $s/d = 0.16666667$   
 $V_{s,core} = V_{s,c1} + V_{s,c2} = 88467.249$

$V_{s,c1} = 0.00$  is calculated for section web core, with:

$$d = 160.00$$

$$A_v = 100530.965$$

$$f_y = 500.00$$

$$s = 250.00$$

$V_{s,c1}$  is multiplied by  $Col,c1 = 0.00$

$$s/d = 1.5625$$

$V_{s,c2} = 88467.249$  is calculated for section flange core, with:

$$d = 440.00$$

$$A_v = 100530.965$$

$$f_y = 500.00$$

$$s = 250.00$$

$V_{s,c2}$  is multiplied by  $Col,c2 = 1.00$

$$s/d = 0.56818182$$

$V_f ((11-3)-(11.4), ACI 440) = 0.00$

From (11-11), ACI 440:  $V_s + V_f \leq 713005.69$

$$bw = 400.00$$

displacement ductility demand is calculated as  $\phi / y$

- Calculation of  $\phi / y$  for END B -

for rotation axis 3 and integ. section (b)

From analysis, chord rotation  $\phi = 2.4490984E-005$

$$y = (M_y * L_s / 3) / E_{eff} = 0.00019718 ((4.29), Biskinis Phd))$$

$$M_y = 2.8709E+008$$

$$L_s = M/V \text{ (with } L_s > 0.1 * L \text{ and } L_s < 2 * L) = 300.00$$

From table 10.5, ASCE 41\_17:  $E_{eff} = factor * E_c * I_g = 1.4560E+014$

$$factor = 0.30$$

$$A_g = 440000.00$$

$$\text{Mean concrete strength: } f'_c = (f'_{c\_jacket} * Area\_jacket + f'_{c\_core} * Area\_core) / Area\_section = 30.00$$

$$N = 17779.344$$

$$E_c * I_g = E_{c\_jacket} * I_{g\_jacket} + E_{c\_core} * I_{g\_core} = 4.8532E+014$$

Calculation of Yielding Moment  $M_y$

Calculation of  $\phi / y$  and  $M_y$  according to Annex 7 -

Assuming neutral axis within flange ( $y < t/d$ , compression zone rectangular) with:

flange width,  $b = 750.00$

web width,  $bw = 400.00$

flange thickness,  $t = 400.00$

$$y = \text{Min}(y_{ten}, y_{com})$$

$$y_{ten} = 2.1455196E-006$$

$$\text{with } ((10.1), ASCE 41-17) f_y = \text{Min}(f_y, 1.25 * f_y * (I_b / I_d)^{2/3}) = 243.3535$$

$$d = 707.00$$

$$y = 0.19784983$$

$$A = 0.01023354$$

$$B = 0.00454395$$

$$\text{with } pt = 0.00214476$$

$$pc = 0.00416509$$

$$pv = 0.00378591$$

$$N = 17779.344$$

$$b = 750.00$$

$$\rho = 0.06082037$$

$$y_{comp} = 1.5202265E-005$$

with  $f_c = 30.00$

$$E_c = 25742.96$$

$$y = 0.19516753$$

$$A = 0.01001583$$

$$B = 0.00440616$$

$$\text{with } E_s = 200000.00$$



CONFIRMATION:  $y = 0.19594836 < t/d$

Calculation of ratio  $l_b/l_d$

Lap Length:  $l_d/l_{d,min} = 0.17384865$

$l_b = 300.00$

$l_d = 1725.639$

Calculation of  $l$  according to (25.4.3.2), ACI 318-14, using mean values for all the section re-bars.

$l_{d,min}$  from (25.4.3.2) is multiplied 2 times to account for smooth re-bars (10.3.5, ASCE 41-17)

$= 1$

$d_b = 16.66667$

Mean strength value of all re-bars:  $f_y = 625.00$

Mean concrete strength:  $f_c' = (f_c'_{jacket} \cdot \text{Area}_{jacket} + f_c'_{core} \cdot \text{Area}_{core}) / \text{Area}_{section} = 30.00$ , but  $f_c'^{0.5} \leq 8.3$  MPa (22.5.3.1, ACI 318-14)

$t = 1.00$

$s = 0.80$

$e = 1.00$

$c_b = 25.00$

$K_{tr} = 1.7174$

$A_{tr} = \text{Min}(A_{tr_x}, A_{tr_y}) = 257.6106$

where  $A_{tr_x}$ ,  $A_{tr_y}$  are the sum of the area of all stirrup legs along X and Y local axis

$s = \text{Max}(s_{external}, s_{internal}) = 250.00$

$n = 24.00$

End Of Calculation of Shear Capacity for element: column JLC1 of floor 1

At local axis: 2

Integration Section: (b)

## Calculation No. 14

column C1, Floor 1



Limit State: Collapse Prevention (data interpolation between analysis steps 1 and 2)

Analysis: Uniform +X

Check: Chord rotation capacity ( $\phi$ )

Edge: End

Local Axis: (2)



Start Of Calculation of Shear Capacity ratio for element: column JLC1 of floor 1

At Shear local axis: 3

(Bending local axis: 2)

Section Type: rcjlc

#### Constant Properties

Knowledge Factor,  $\gamma = 1.00$

Mean strength values are used for both shear and moment calculations.

Consequently:

Jacket

New material of Primary Member: Concrete Strength,  $f_c = f_{cm} = 30.00$

New material of Primary Member: Steel Strength,  $f_s = f_{sm} = 625.00$

Concrete Elasticity,  $E_c = 25742.96$

Steel Elasticity,  $E_s = 200000.00$

Existing Column

New material of Primary Member: Concrete Strength,  $f_c = f_{cm} = 30.00$

New material of Primary Member: Steel Strength,  $f_s = f_{sm} = 625.00$

Concrete Elasticity,  $E_c = 25742.96$

Steel Elasticity,  $E_s = 200000.00$

#####

Note: Especially for the calculation of moment strengths,

the above steel re-bar strengths are multiplied by 1.25 according to R18.6.5, ACI 318-14

Jacket

New material: Steel Strength,  $f_s = 1.25 \cdot f_{sm} = 781.25$

Existing Column

New material: Steel Strength,  $f_s = 1.25 \cdot f_{sm} = 781.25$

#####

Max Height,  $H_{max} = 750.00$

Min Height,  $H_{min} = 400.00$

Max Width,  $W_{max} = 750.00$

Min Width,  $W_{min} = 400.00$

Jacket Thickness,  $t_j = 100.00$

Cover Thickness,  $c = 25.00$

Mean Confinement Factor overall section = 1.27105

Element Length,  $L = 3000.00$

Primary Member

Smooth Bars

Ductile Steel

With Detailing for Earthquake Resistance (including stirrups closed at 135°)

Longitudinal Bars With Ends Lapped Starting at the End Sections

Lap Length  $l_o = 300.00$

No FRP Wrapping

#### Stepwise Properties

At local axis: 3

EDGE -A-

Shear Force,  $V_a = -0.00017144$

EDGE -B-

Shear Force,  $V_b = 0.00017144$

BOTH EDGES

Axial Force,  $F = -16273.608$

Longitudinal Reinforcement Area Distribution (in 2 divisions)

-Tension:  $A_{sl} = 0.00$

-Compression:  $A_{slc} = 5353.274$

Longitudinal Reinforcement Area Distribution (in 3 divisions)

-Tension:  $A_{sl,ten} = 1137.257$

-Compression:  $A_{sl,com} = 2208.54$

-Middle:  $A_{sl,mid} = 2007.478$

Calculation of Shear Capacity ratio ,  $V_e/V_r = 0.32266369$

Member Controlled by Flexure ( $V_e/V_r < 1$ )

Calculation of Shear Demand from fig. R18.6.5, ACI 318-14  $V_e = (M_{pr1} + M_{pr2})/l_n = 335307.657$

with

$M_{pr1} = \text{Max}(M_{u1+}, M_{u1-}) = 5.0296E+008$

$M_{u1+} = 2.3387E+008$ , is the ultimate moment strength at the edge 1 of the member in the actual moment direction which is defined for the static loading combination

$M_{u1-} = 5.0296E+008$ , is the ultimate moment strength at the edge 1 of the member in the opposite moment direction which is defined for the static loading combination

$M_{pr2} = \text{Max}(M_{u2+}, M_{u2-}) = 5.0296E+008$

$M_{u2+} = 2.3387E+008$ , is the ultimate moment strength at the edge 2 of the member in the actual moment direction which is defined for the static loading combination

$M_{u2-} = 5.0296E+008$ , is the ultimate moment strength at the edge 2 of the member in the opposite moment direction which is defined for the static loading combination

-----  
Calculation of  $M_{u1+}$   
-----

-----  
Calculation of ultimate curvature  $\phi_u$  according to 4.1, Biskinis/Fardis 2013:

$\phi_u = 4.8099118E-006$

$M_u = 2.3387E+008$   
-----

with full section properties:

$b = 750.00$

$d = 707.00$

$d' = 43.00$

$v = 0.00102301$

$N = 16273.608$

$f_c = 30.00$

$\phi_c$  (5A.5, TBDY) = 0.002

Final value of  $\phi_u$ :  $\phi_u^* = \text{shear\_factor} * \text{Max}(\phi_u, \phi_c) = 0.01260361$

The Shear\_factor is considered equal to 1 (pure moment strength)

From (5.4b), TBDY:  $\phi_u = 0.01260361$

$\phi_{ue}$  (5.4c) = 0.05179731

$\phi_{ase}$  ((5.4d), TBDY) =  $(\phi_{ase1} * A_{ext} + \phi_{ase2} * A_{int}) / A_{sec} = 0.45746528$

$\phi_{ase1} = \text{Max}(((A_{conf,max1} - A_{noConf1}) / A_{conf,max1}) * (A_{conf,min1} / A_{conf,max1}), 0) = 0.45746528$

The definitions of  $A_{noConf}$ ,  $A_{conf,min}$  and  $A_{conf,max}$  are derived from generalization of the rectangular sections confinement, which is expressed by (5.4d).

The generalization is done according to Mander, J., Priestley, M., and Park, R. (1988)

"Theoretical Stress-Strain Model for Confined Concrete."

J. Struct. Eng., 10.1061/(ASCE)0733-9445(1988)114:8(1804), 1804-1826.

$A_{conf,max1} = 353600.00$  is the confined core area at levels of member with hoops and

is calculated as the area of core enclosed by the center lines of the external perimeter hoops.

$A_{conf,min1} = 293525.00$  is the confined core area at midway between the levels of hoops and

is calculated by reducing all the dimensions of the area  $A_{conf,max1}$  by a length equal to half the clear spacing between external hoops.

$A_{noConf1} = 158733.333$  is the unconfined external core area which is equal to  $b_i^2/6$  as defined at (A.2).

$\phi_{ase2} (> \phi_{ase1}) = \text{Max}(((A_{conf,max2} - A_{noConf2}) / A_{conf,max2}) * (A_{conf,min2} / A_{conf,max2}), 0) = 0.45746528$

The definitions of  $A_{noConf}$ ,  $A_{conf,min}$  and  $A_{conf,max}$  are derived from generalization of the rectangular sections confinement, which is expressed by (5.4d).

The generalization is done according to Mander, J., Priestley, M., and Park, R. (1988)

"Theoretical Stress-Strain Model for Confined Concrete."

J. Struct. Eng., 10.1061/(ASCE)0733-9445(1988)114:8(1804), 1804-1826.

$A_{conf,max2} = 171264.00$  is the confined core area at levels of member with hoops and

is calculated as the area of core enclosed by the center lines of the internal perimeter hoops.

$A_{conf,min2} = 54741.00$  is the confined core area at midway between the levels of hoops and

is calculated by reducing all the dimensions of the area  $A_{conf,max2}$  by a length equal to half the clear spacing between internal hoops.

$A_{noConf2} = 106242.667$  is the unconfined internal core area which is equal to  $b_i^2/6$  as defined at (A.2).

$p_{sh,min} * F_{ywe} = \text{Min}(p_{sh,x} * F_{ywe}, p_{sh,y} * F_{ywe}) = 3.3968$   
-----

$p_{sh,x} * F_{ywe} = p_{sh1} * F_{ywe1} + p_{sh2} * F_{ywe2} = 3.3968$

$p_{sh1}$  ((5.4d), TBDY) =  $L_{stir1} * A_{stir1} / (A_{sec} * s_1) = 0.00367709$

$L_{stir1}$  (Length of stirrups along Y) = 2060.00

$A_{stir1}$  (stirrups area) = 78.53982

$psh2 \text{ (5.4d)} = Lstir2 * Astir2 / (Asec * s2) = 0.00067082$   
 $Lstir2 \text{ (Length of stirrups along Y)} = 1468.00$   
 $Astir2 \text{ (stirrups area)} = 50.26548$

$psh\_y * Fywe = psh1 * Fywe1 + ps2 * Fywe2 = 3.3968$   
 $psh1 \text{ ((5.4d), TBDY)} = Lstir1 * Astir1 / (Asec * s1) = 0.00367709$   
 $Lstir1 \text{ (Length of stirrups along X)} = 2060.00$   
 $Astir1 \text{ (stirrups area)} = 78.53982$   
 $psh2 \text{ ((5.4d), TBDY)} = Lstir2 * Astir2 / (Asec * s2) = 0.00067082$   
 $Lstir2 \text{ (Length of stirrups along X)} = 1468.00$   
 $Astir2 \text{ (stirrups area)} = 50.26548$

$Asec = 440000.00$

$s1 = 100.00$

$s2 = 250.00$

$fywe1 = 781.25$

$fywe2 = 781.25$

$fce = 30.00$

From ((5.A5), TBDY), TBDY:  $cc = 0.00471045$

$c = \text{confinement factor} = 1.27105$

$y1 = 0.00083886$

$sh1 = 0.00268436$

$ft1 = 314.5735$

$fy1 = 262.1446$

$su1 = 0.00268436$

using (30) in Biskinis/Fardis (2013) multiplied with shear\_factor  
and also multiplied by the shear\_factor according to 15.7.1.4, with  
Shear\_factor = 1.00

$lo/lou,min = lb/ld = 0.13907892$

$su1 = 0.4 * esu1\_nominal \text{ ((5.5), TBDY)} = 0.032$

From table 5A.1, TBDY:  $esu1\_nominal = 0.08$ ,

For calculation of  $esu1\_nominal$  and  $y1$ ,  $sh1$ ,  $ft1$ ,  $fy1$ , it is considered  
characteristic value  $fsy1 = fs1/1.2$ , from table 5.1, TBDY.

$y1$ ,  $sh1$ ,  $ft1$ ,  $fy1$ , are also multiplied by  $\text{Min}(1, 1.25 * (lb/ld)^{2/3})$ , from 10.3.5, ASCE 41-17.

with  $fs1 = (fs,jacket * Asl,ten,jacket + fs,core * Asl,ten,core) / Asl,ten = 262.1446$

with  $Es1 = (Es,jacket * Asl,ten,jacket + Es,core * Asl,ten,core) / Asl,ten = 200000.00$

$y2 = 0.00083886$

$sh2 = 0.00268436$

$ft2 = 314.5735$

$fy2 = 262.1446$

$su2 = 0.00268436$

using (30) in Biskinis/Fardis (2013) multiplied with shear\_factor  
and also multiplied by the shear\_factor according to 15.7.1.4, with  
Shear\_factor = 1.00

$lo/lou,min = lb/lb,min = 0.13907892$

$su2 = 0.4 * esu2\_nominal \text{ ((5.5), TBDY)} = 0.032$

From table 5A.1, TBDY:  $esu2\_nominal = 0.08$ ,

For calculation of  $esu2\_nominal$  and  $y2$ ,  $sh2$ ,  $ft2$ ,  $fy2$ , it is considered  
characteristic value  $fsy2 = fs2/1.2$ , from table 5.1, TBDY.

$y1$ ,  $sh1$ ,  $ft1$ ,  $fy1$ , are also multiplied by  $\text{Min}(1, 1.25 * (lb/ld)^{2/3})$ , from 10.3.5, ASCE 41-17.

with  $fs2 = (fs,jacket * Asl,com,jacket + fs,core * Asl,com,core) / Asl,com = 262.1446$

with  $Es2 = (Es,jacket * Asl,com,jacket + Es,core * Asl,com,core) / Asl,com = 200000.00$

$yv = 0.00083886$

$shv = 0.00268436$

$ftv = 314.5735$

$fyv = 262.1446$

$suv = 0.00268436$

using (30) in Biskinis/Fardis (2013) multiplied with shear\_factor  
and also multiplied by the shear\_factor according to 15.7.1.4, with  
Shear\_factor = 1.00

$lo/lou,min = lb/ld = 0.13907892$

$suv = 0.4 * esuv\_nominal \text{ ((5.5), TBDY)} = 0.032$

From table 5A.1, TBDY:  $esuv\_nominal = 0.08$ ,

considering characteristic value  $fsyv = fsv/1.2$ , from table 5.1, TBDY  
For calculation of  $esuv\_nominal$  and  $yv$ ,  $shv$ ,  $ftv$ ,  $fyv$ , it is considered

characteristic value  $fsyv = fsv/1.2$ , from table 5.1, TBDY.

$y1$ ,  $sh1$ ,  $ft1$ ,  $fy1$ , are also multiplied by  $\text{Min}(1, 1.25 * (lb/ld)^{2/3})$ , from 10.3.5, ASCE 41-17.

```

with fsv = (fs,jacket*Asl,mid,jacket + fs,mid*Asl,mid,core)/Asl,mid = 262.1446
with Esv = (Es,jacket*Asl,mid,jacket + Es,mid*Asl,mid,core)/Asl,mid = 200000.00
1 = Asl,ten/(b*d)*(fs1/fc) = 0.0187412
2 = Asl,com/(b*d)*(fs2/fc) = 0.03639521
v = Asl,mid/(b*d)*(fsv/fc) = 0.03308184

```

and confined core properties:

```

b = 690.00
d = 677.00
d' = 13.00
fcc (5A.2, TBDY) = 38.13135
cc (5A.5, TBDY) = 0.00471045
c = confinement factor = 1.27105
1 = Asl,ten/(b*d)*(fs1/fc) = 0.02127357
2 = Asl,com/(b*d)*(fs2/fc) = 0.04131304
v = Asl,mid/(b*d)*(fsv/fc) = 0.03755196

```

Case/Assumption: Unconfined full section - Steel rupture

' satisfies Eq. (4.3)

--->

v < vs,y2 - LHS eq.(4.5) is satisfied

--->

```

su (4.9) = 0.21062322
Mu = MRc (4.14) = 2.3387E+008
u = su (4.1) = 4.8099118E-006

```

Calculation of ratio lb/d

Lap Length: lb/d = 0.13907892

lb = 300.00

ld = 2157.049

Calculation of lb,min according to (25.4.3.2), ACI 318-14, using mean values for all the section re-bars.

ld,min from (25.4.3.2) is multiplied 2 times to account for smooth re-bars (9.1.2, TS500 - No provision in ACI 318)

= 1

db = 16.66667

Mean strength value of all re-bars: fy = 781.25

Mean concrete strength: fc' = (fc'\_jacket\*Area\_jacket + fc'\_core\*Area\_core)/Area\_section = 30.00, but  $fc'^{0.5} \leq 8.3$  MPa (22.5.3.1, ACI 318-14)

t = 1.00

s = 0.80

e = 1.00

cb = 25.00

Ktr = 1.7174

Atr = Min(Atr\_x,Atr\_y) = 257.6106

where Atr\_x, Atr\_y are the sum of the area of all stirrup legs along X and Y loxal axis

s = Max(s\_external,s\_internal) = 250.00

n = 24.00

Calculation of Mu1-

Calculation of ultimate curvature u according to 4.1, Biskinis/Fardis 2013:

u = 5.1201636E-006

Mu = 5.0296E+008

with full section properties:

b = 400.00

d = 707.00

d' = 43.00

v = 0.00191815

N = 16273.608

fc = 30.00

co (5A.5, TBDY) = 0.002

Final value of cu: cu\* = shear\_factor \* Max( cu, cc) = 0.01260361

The Shear\_factor is considered equal to 1 (pure moment strength)

From (5.4b), TBDY:  $c_u = 0.01260361$

$w_e$  (5.4c) = 0.05179731

$a_{se}$  ((5.4d), TBDY) =  $(a_{se1} \cdot A_{ext} + a_{se2} \cdot A_{int}) / A_{sec} = 0.45746528$

$a_{se1} = \text{Max}(((A_{conf,max1} - A_{noConf1}) / A_{conf,max1}) \cdot (A_{conf,min1} / A_{conf,max1}), 0) = 0.45746528$

The definitions of  $A_{noConf}$ ,  $A_{conf,min}$  and  $A_{conf,max}$  are derived from generalization of the rectangular sections confinement, which is expressed by (5.4d).

The generalization is done according to Mander, J., Priestley, M., and Park, R. (1988)

"Theoretical Stress-Strain Model for Confined Concrete."

J. Struct. Eng., 10.1061/(ASCE)0733-9445(1988)114:8(1804), 1804-1826.

$A_{conf,max1} = 353600.00$  is the confined core area at levels of member with hoops and

is calculated as the area of core enclosed by the center lines of the external perimeter hoops.

$A_{conf,min1} = 293525.00$  is the confined core area at midway between the levels of hoops and

is calculated by reducing all the dimensions of the area  $A_{conf,max1}$  by a length equal to half the clear spacing between external hoops.

$A_{noConf1} = 158733.333$  is the unconfined external core area which is equal to  $b_i^2/6$  as defined at (A.2).

$a_{se2} (>= a_{se1}) = \text{Max}(((A_{conf,max2} - A_{noConf2}) / A_{conf,max2}) \cdot (A_{conf,min2} / A_{conf,max2}), 0) = 0.45746528$

The definitions of  $A_{noConf}$ ,  $A_{conf,min}$  and  $A_{conf,max}$  are derived from generalization of the rectangular sections confinement, which is expressed by (5.4d).

The generalization is done according to Mander, J., Priestley, M., and Park, R. (1988)

"Theoretical Stress-Strain Model for Confined Concrete."

J. Struct. Eng., 10.1061/(ASCE)0733-9445(1988)114:8(1804), 1804-1826.

$A_{conf,max2} = 171264.00$  is the confined core area at levels of member with hoops and

is calculated as the area of core enclosed by the center lines of the internal perimeter hoops.

$A_{conf,min2} = 54741.00$  is the confined core area at midway between the levels of hoops and

is calculated by reducing all the dimensions of the area  $A_{conf,max2}$  by a length equal to half the clear spacing between internal hoops.

$A_{noConf2} = 106242.667$  is the unconfined internal core area which is equal to  $b_i^2/6$  as defined at (A.2).

$p_{sh,min} \cdot F_{ywe} = \text{Min}(p_{sh,x} \cdot F_{ywe}, p_{sh,y} \cdot F_{ywe}) = 3.3968$

-----  
 $p_{sh,x} \cdot F_{ywe} = p_{sh1} \cdot F_{ywe1} + p_{sh2} \cdot F_{ywe2} = 3.3968$

$p_{sh1}$  ((5.4d), TBDY) =  $L_{stir1} \cdot A_{stir1} / (A_{sec} \cdot s_1) = 0.00367709$

$L_{stir1}$  (Length of stirrups along Y) = 2060.00

$A_{stir1}$  (stirrups area) = 78.53982

$p_{sh2}$  (5.4d) =  $L_{stir2} \cdot A_{stir2} / (A_{sec} \cdot s_2) = 0.00067082$

$L_{stir2}$  (Length of stirrups along Y) = 1468.00

$A_{stir2}$  (stirrups area) = 50.26548

-----  
 $p_{sh,y} \cdot F_{ywe} = p_{sh1} \cdot F_{ywe1} + p_{sh2} \cdot F_{ywe2} = 3.3968$

$p_{sh1}$  ((5.4d), TBDY) =  $L_{stir1} \cdot A_{stir1} / (A_{sec} \cdot s_1) = 0.00367709$

$L_{stir1}$  (Length of stirrups along X) = 2060.00

$A_{stir1}$  (stirrups area) = 78.53982

$p_{sh2}$  ((5.4d), TBDY) =  $L_{stir2} \cdot A_{stir2} / (A_{sec} \cdot s_2) = 0.00067082$

$L_{stir2}$  (Length of stirrups along X) = 1468.00

$A_{stir2}$  (stirrups area) = 50.26548

-----  
 $A_{sec} = 440000.00$

$s_1 = 100.00$

$s_2 = 250.00$

$f_{ywe1} = 781.25$

$f_{ywe2} = 781.25$

$f_{ce} = 30.00$

From ((5.A5), TBDY), TBDY:  $c_c = 0.00471045$

$c$  = confinement factor = 1.27105

$y_1 = 0.00083886$

$sh_1 = 0.00268436$

$ft_1 = 314.5735$

$fy_1 = 262.1446$

$su_1 = 0.00268436$

using (30) in Biskinis/Fardis (2013) multiplied with shear\_factor

and also multiplied by the shear\_factor according to 15.7.1.4, with

Shear\_factor = 1.00

$l_o/l_{ou,min} = l_b/l_d = 0.13907892$

$su_1 = 0.4 \cdot esu_1_{nominal}$  ((5.5), TBDY) = 0.032

From table 5A.1, TBDY:  $esu_1_{nominal} = 0.08$ ,

For calculation of  $esu_1_{nominal}$  and  $y_1$ ,  $sh_1$ ,  $ft_1$ ,  $fy_1$ , it is considered characteristic value  $fsy_1 = f_s/1.2$ , from table 5.1, TBDY.

$y_1$ ,  $sh_1$ ,  $ft_1$ ,  $fy_1$ , are also multiplied by  $\text{Min}(1, 1.25 \cdot (l_b/l_d)^{2/3})$ , from 10.3.5, ASCE 41-17.

```

with fs1 = (fs,jacket*Asl,ten,jacket + fs,core*Asl,ten,core)/Asl,ten = 262.1446
with Es1 = (Es,jacket*Asl,ten,jacket + Es,core*Asl,ten,core)/Asl,ten = 200000.00
y2 = 0.00083886
sh2 = 0.00268436
ft2 = 314.5735
fy2 = 262.1446
su2 = 0.00268436
using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00
lo/lou,min = lb/lb,min = 0.13907892
su2 = 0.4*esu2_nominal ((5.5), TBDY) = 0.032
From table 5A.1, TBDY: esu2_nominal = 0.08,
For calculation of esu2_nominal and y2, sh2,ft2,fy2, it is considered
characteristic value fsy2 = fs2/1.2, from table 5.1, TBDY.
y1, sh1,ft1,fy1, are also multiplied by Min(1,1.25*(lb/lb,min)^2/3), from 10.3.5, ASCE 41-17.
with fs2 = (fs,jacket*Asl,com,jacket + fs,core*Asl,com,core)/Asl,com = 262.1446
with Es2 = (Es,jacket*Asl,com,jacket + Es,core*Asl,com,core)/Asl,com = 200000.00
yv = 0.00083886
shv = 0.00268436
ftv = 314.5735
fyv = 262.1446
suv = 0.00268436
using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00
lo/lou,min = lb/lb,min = 0.13907892
suv = 0.4*esuv_nominal ((5.5), TBDY) = 0.032
From table 5A.1, TBDY: esuv_nominal = 0.08,
considering characteristic value fsyv = fsv/1.2, from table 5.1, TBDY
For calculation of esuv_nominal and yv, shv,ftv,fyv, it is considered
characteristic value fsyv = fsv/1.2, from table 5.1, TBDY.
y1, sh1,ft1,fy1, are also multiplied by Min(1,1.25*(lb/lb,min)^2/3), from 10.3.5, ASCE 41-17.
with fsv = (fs,jacket*Asl,mid,jacket + fs,mid*Asl,mid,core)/Asl,mid = 262.1446
with Esv = (Es,jacket*Asl,mid,jacket + Es,mid*Asl,mid,core)/Asl,mid = 200000.00
1 = Asl,ten/(b*d)*(fs1/fc) = 0.06824101
2 = Asl,com/(b*d)*(fs2/fc) = 0.03513975
v = Asl,mid/(b*d)*(fsv/fc) = 0.06202846
and confined core properties:
b = 340.00
d = 677.00
d' = 13.00
fcc (5A.2, TBDY) = 38.13135
cc (5A.5, TBDY) = 0.00471045
c = confinement factor = 1.27105
1 = Asl,ten/(b*d)*(fs1/fc) = 0.08384116
2 = Asl,com/(b*d)*(fs2/fc) = 0.04317283
v = Asl,mid/(b*d)*(fsv/fc) = 0.07620839
Case/Assumption: Unconfined full section - Steel rupture
'satisfies Eq. (4.3)
--->
v < vs,y2 - LHS eq.(4.5) is satisfied
--->
su (4.9) = 0.2584548
Mu = MRc (4.14) = 5.0296E+008
u = su (4.1) = 5.1201636E-006

```

Calculation of ratio lb/lb

```

Lap Length: lb/lb = 0.13907892
lb = 300.00
ld = 2157.049
Calculation of lb,min according to (25.4.3.2), ACI 318-14, using mean values for all the section re-bars.
ld,min from (25.4.3.2) is multiplied 2 times to account for smooth re-bars (9.1.2, TS500 - No provision in ACI 318)
= 1
db = 16.66667

```

Mean strength value of all re-bars:  $f_y = 781.25$   
Mean concrete strength:  $f_c' = (f_c'_{\text{jacket}} \cdot \text{Area}_{\text{jacket}} + f_c'_{\text{core}} \cdot \text{Area}_{\text{core}}) / \text{Area}_{\text{section}} = 30.00$ , but  $f_c'^{0.5} \leq 8.3$  MPa (22.5.3.1, ACI 318-14)  
 $t = 1.00$   
 $s = 0.80$   
 $e = 1.00$   
 $cb = 25.00$   
 $K_{tr} = 1.7174$   
 $A_{tr} = \text{Min}(A_{tr\_x}, A_{tr\_y}) = 257.6106$   
where  $A_{tr\_x}$ ,  $A_{tr\_y}$  are the sum of the area of all stirrup legs along X and Y loxal axis  
 $s = \text{Max}(s_{\text{external}}, s_{\text{internal}}) = 250.00$   
 $n = 24.00$

Calculation of  $\mu_{2+}$

Calculation of ultimate curvature  $\mu$  according to 4.1, Biskinis/Fardis 2013:  
 $\mu = 4.8099118\text{E-}006$   
 $\mu = 2.3387\text{E+}008$

with full section properties:

$b = 750.00$   
 $d = 707.00$   
 $d' = 43.00$   
 $v = 0.00102301$   
 $N = 16273.608$   
 $f_c = 30.00$   
 $\alpha (5A.5, \text{TB DY}) = 0.002$   
Final value of  $\mu$ :  $\mu^* = \text{shear\_factor} \cdot \text{Max}(\mu, \alpha) = 0.01260361$   
The Shear\_factor is considered equal to 1 (pure moment strength)  
From (5.4b), TB DY:  $\mu = 0.01260361$   
we (5.4c)  $= 0.05179731$   
 $\alpha_{se} ((5.4d), \text{TB DY}) = (\alpha_{se1} \cdot A_{ext} + \alpha_{se2} \cdot A_{int}) / A_{sec} = 0.45746528$   
 $\alpha_{se1} = \text{Max}(((A_{conf,max1} - A_{noConf1}) / A_{conf,max1}) \cdot (A_{conf,min1} / A_{conf,max1}), 0) = 0.45746528$   
The definitions of  $A_{noConf}$ ,  $A_{conf,min}$  and  $A_{conf,max}$  are derived from generalization of the rectangular sections confinement, which is expressed by (5.4d).  
The generalization is done according to Mander, J., Priestley, M., and Park, R. (1988) "Theoretical Stress-Strain Model for Confined Concrete."  
J. Struct. Eng., 10.1061/(ASCE)0733-9445(1988)114:8(1804), 1804-1826.  
 $A_{conf,max1} = 353600.00$  is the confined core area at levels of member with hoops and is calculated as the area of core enclosed by the center lines of the external perimeter hoops.  
 $A_{conf,min1} = 293525.00$  is the confined core area at midway between the levels of hoops and is calculated by reducing all the dimensions of the area  $A_{conf,max1}$  by a length equal to half the clear spacing between external hoops.  
 $A_{noConf1} = 158733.333$  is the unconfined external core area which is equal to  $b_i^2/6$  as defined at (A.2).  
 $\alpha_{se2} (>= \alpha_{se1}) = \text{Max}(((A_{conf,max2} - A_{noConf2}) / A_{conf,max2}) \cdot (A_{conf,min2} / A_{conf,max2}), 0) = 0.45746528$   
The definitions of  $A_{noConf}$ ,  $A_{conf,min}$  and  $A_{conf,max}$  are derived from generalization of the rectangular sections confinement, which is expressed by (5.4d).  
The generalization is done according to Mander, J., Priestley, M., and Park, R. (1988) "Theoretical Stress-Strain Model for Confined Concrete."  
J. Struct. Eng., 10.1061/(ASCE)0733-9445(1988)114:8(1804), 1804-1826.  
 $A_{conf,max2} = 171264.00$  is the confined core area at levels of member with hoops and is calculated as the area of core enclosed by the center lines of the internal perimeter hoops.  
 $A_{conf,min2} = 54741.00$  is the confined core area at midway between the levels of hoops and is calculated by reducing all the dimensions of the area  $A_{conf,max2}$  by a length equal to half the clear spacing between internal hoops.  
 $A_{noConf2} = 106242.667$  is the unconfined internal core area which is equal to  $b_i^2/6$  as defined at (A.2).  
 $p_{sh,min} \cdot F_{ywe} = \text{Min}(p_{sh,x} \cdot F_{ywe}, p_{sh,y} \cdot F_{ywe}) = 3.3968$

$p_{sh\_x} \cdot F_{ywe} = p_{sh1} \cdot F_{ywe1} + p_{sh2} \cdot F_{ywe2} = 3.3968$   
 $p_{sh1} ((5.4d), \text{TB DY}) = L_{stir1} \cdot A_{stir1} / (A_{sec} \cdot s1) = 0.00367709$   
 $L_{stir1}$  (Length of stirrups along Y) = 2060.00  
 $A_{stir1}$  (stirrups area) = 78.53982  
 $p_{sh2} (5.4d) = L_{stir2} \cdot A_{stir2} / (A_{sec} \cdot s2) = 0.00067082$



Lstir2 (Length of stirrups along Y) = 1468.00  
Astir2 (stirrups area) = 50.26548

psh\_y\*Fywe = psh1\*Fywe1+ps2\*Fywe2 = 3.3968  
psh1 ((5.4d), TBDY) = Lstir1\*Astir1/(Asec\*s1) = 0.00367709  
Lstir1 (Length of stirrups along X) = 2060.00  
Astir1 (stirrups area) = 78.53982  
psh2 ((5.4d), TBDY) = Lstir2\*Astir2/(Asec\*s2) = 0.00067082  
Lstir2 (Length of stirrups along X) = 1468.00  
Astir2 (stirrups area) = 50.26548

Asec = 440000.00  
s1 = 100.00  
s2 = 250.00

fywe1 = 781.25  
fywe2 = 781.25  
fce = 30.00

From ((5.A5), TBDY), TBDY: cc = 0.00471045  
c = confinement factor = 1.27105

y1 = 0.00083886  
sh1 = 0.00268436  
ft1 = 314.5735  
fy1 = 262.1446

su1 = 0.00268436

using (30) in Biskinis/Fardis (2013) multiplied with shear\_factor  
and also multiplied by the shear\_factor according to 15.7.1.4, with  
Shear\_factor = 1.00

lo/lou,min = lb/lb = 0.13907892

su1 = 0.4\*esu1\_nominal ((5.5), TBDY) = 0.032

From table 5A.1, TBDY: esu1\_nominal = 0.08,

For calculation of esu1\_nominal and y1, sh1,ft1,fy1, it is considered  
characteristic value fsy1 = fs1/1.2, from table 5.1, TBDY.

y1, sh1,ft1,fy1, are also multiplied by  $\text{Min}(1, 1.25 \cdot (lb/lb)^{2/3})$ , from 10.3.5, ASCE 41-17.

with fs1 = (fs,jacket\*Asl,ten,jacket + fs,core\*Asl,ten,core)/Asl,ten = 262.1446

with Es1 = (Es,jacket\*Asl,ten,jacket + Es,core\*Asl,ten,core)/Asl,ten = 200000.00

y2 = 0.00083886

sh2 = 0.00268436

ft2 = 314.5735

fy2 = 262.1446

su2 = 0.00268436

using (30) in Biskinis/Fardis (2013) multiplied with shear\_factor  
and also multiplied by the shear\_factor according to 15.7.1.4, with  
Shear\_factor = 1.00

lo/lou,min = lb/lb,min = 0.13907892

su2 = 0.4\*esu2\_nominal ((5.5), TBDY) = 0.032

From table 5A.1, TBDY: esu2\_nominal = 0.08,

For calculation of esu2\_nominal and y2, sh2,ft2,fy2, it is considered  
characteristic value fsy2 = fs2/1.2, from table 5.1, TBDY.

y1, sh1,ft1,fy1, are also multiplied by  $\text{Min}(1, 1.25 \cdot (lb/lb)^{2/3})$ , from 10.3.5, ASCE 41-17.

with fs2 = (fs,jacket\*Asl,com,jacket + fs,core\*Asl,com,core)/Asl,com = 262.1446

with Es2 = (Es,jacket\*Asl,com,jacket + Es,core\*Asl,com,core)/Asl,com = 200000.00

yv = 0.00083886

shv = 0.00268436

ftv = 314.5735

fyv = 262.1446

suv = 0.00268436

using (30) in Biskinis/Fardis (2013) multiplied with shear\_factor  
and also multiplied by the shear\_factor according to 15.7.1.4, with  
Shear\_factor = 1.00

lo/lou,min = lb/lb = 0.13907892

suv = 0.4\*esuv\_nominal ((5.5), TBDY) = 0.032

From table 5A.1, TBDY: esuv\_nominal = 0.08,

considering characteristic value fsyv = fsv/1.2, from table 5.1, TBDY

For calculation of esuv\_nominal and yv, shv,ftv,fyv, it is considered  
characteristic value fsyv = fsv/1.2, from table 5.1, TBDY.

y1, sh1,ft1,fy1, are also multiplied by  $\text{Min}(1, 1.25 \cdot (lb/lb)^{2/3})$ , from 10.3.5, ASCE 41-17.

with fsv = (fs,jacket\*Asl,mid,jacket + fs,mid\*Asl,mid,core)/Asl,mid = 262.1446

```

with Esv = (Esjacket*Asl,mid,jacket + Esmid*Asl,mid,core)/Asl,mid = 200000.00
1 = Asl,ten/(b*d)*(fs1/fc) = 0.0187412
2 = Asl,com/(b*d)*(fs2/fc) = 0.03639521
v = Asl,mid/(b*d)*(fsv/fc) = 0.03308184
and confined core properties:
b = 690.00
d = 677.00
d' = 13.00
fcc (5A.2, TBDY) = 38.13135
cc (5A.5, TBDY) = 0.00471045
c = confinement factor = 1.27105
1 = Asl,ten/(b*d)*(fs1/fc) = 0.02127357
2 = Asl,com/(b*d)*(fs2/fc) = 0.04131304
v = Asl,mid/(b*d)*(fsv/fc) = 0.03755196
Case/Assumption: Unconfined full section - Steel rupture
'satisfies Eq. (4.3)
--->
v < vs,y2 - LHS eq.(4.5) is satisfied
--->
su (4.9) = 0.21062322
Mu = MRc (4.14) = 2.3387E+008
u = su (4.1) = 4.8099118E-006
-----

Calculation of ratio lb/d
-----
Lap Length: lb/d = 0.13907892
lb = 300.00
ld = 2157.049
Calculation of lb,min according to (25.4.3.2), ACI 318-14, using mean values for all the section re-bars.
ld,min from (25.4.3.2) is multiplied 2 times to account for smooth re-bars (9.1.2, TS500 - No provision in ACI 318)
= 1
db = 16.66667
Mean strength value of all re-bars: fy = 781.25
Mean concrete strength: fc' = (fc'_jacket*Area_jacket + fc'_core*Area_core)/Area_section = 30.00, but fc'^0.5 <= 8.3
MPa (22.5.3.1, ACI 318-14)
t = 1.00
s = 0.80
e = 1.00
cb = 25.00
Ktr = 1.7174
Atr = Min(Atr,x,Atr,y) = 257.6106
where Atr,x, Atr,y are the sum of the area of all stirrup legs along X and Y loxal axis
s = Max(sexternal,sinternal) = 250.00
n = 24.00
-----
-----
-----

Calculation of Mu2-
-----
-----

Calculation of ultimate curvature u according to 4.1, Biskinis/Fardis 2013:
u = 5.1201636E-006
Mu = 5.0296E+008
-----

with full section properties:
b = 400.00
d = 707.00
d' = 43.00
v = 0.00191815
N = 16273.608
fc = 30.00
co (5A.5, TBDY) = 0.002
Final value of cu: cu* = shear_factor * Max( cu, cc) = 0.01260361
The Shear_factor is considered equal to 1 (pure moment strength)
From (5.4b), TBDY: cu = 0.01260361

```

$$w_e (5.4c) = 0.05179731$$

$$ase ((5.4d), TBDY) = (ase1 * A_{ext} + ase2 * A_{int}) / A_{sec} = 0.45746528$$

$$ase1 = \text{Max}(((A_{conf,max1} - A_{noConf1}) / A_{conf,max1}) * (A_{conf,min1} / A_{conf,max1}), 0) = 0.45746528$$

The definitions of  $A_{noConf}$ ,  $A_{conf,min}$  and  $A_{conf,max}$  are derived from generalization of the rectangular sections confinement, which is expressed by (5.4d).

The generalization is done according to Mander, J., Priestley, M., and Park, R. (1988)

"Theoretical Stress-Strain Model for Confined Concrete."

J. Struct. Eng., 10.1061/(ASCE)0733-9445(1988)114:8(1804), 1804-1826.

$A_{conf,max1} = 353600.00$  is the confined core area at levels of member with hoops and is calculated as the area of core enclosed by the center lines of the external perimeter hoops.

$A_{conf,min1} = 293525.00$  is the confined core area at midway between the levels of hoops and is calculated by reducing all the dimensions of the area  $A_{conf,max1}$  by a length equal to half the clear spacing between external hoops.

$A_{noConf1} = 158733.333$  is the unconfined external core area which is equal to  $b_i^2/6$  as defined at (A.2).

$$ase2 (>= ase1) = \text{Max}(((A_{conf,max2} - A_{noConf2}) / A_{conf,max2}) * (A_{conf,min2} / A_{conf,max2}), 0) = 0.45746528$$

The definitions of  $A_{noConf}$ ,  $A_{conf,min}$  and  $A_{conf,max}$  are derived from generalization of the rectangular sections confinement, which is expressed by (5.4d).

The generalization is done according to Mander, J., Priestley, M., and Park, R. (1988)

"Theoretical Stress-Strain Model for Confined Concrete."

J. Struct. Eng., 10.1061/(ASCE)0733-9445(1988)114:8(1804), 1804-1826.

$A_{conf,max2} = 171264.00$  is the confined core area at levels of member with hoops and is calculated as the area of core enclosed by the center lines of the internal perimeter hoops.

$A_{conf,min2} = 54741.00$  is the confined core area at midway between the levels of hoops and is calculated by reducing all the dimensions of the area  $A_{conf,max2}$  by a length equal to half the clear spacing between internal hoops.

$A_{noConf2} = 106242.667$  is the unconfined internal core area which is equal to  $b_i^2/6$  as defined at (A.2).

$$psh_{min} * F_{ywe} = \text{Min}(psh_x * F_{ywe}, psh_y * F_{ywe}) = 3.3968$$

$$psh_x * F_{ywe} = psh1 * F_{ywe1} + ps2 * F_{ywe2} = 3.3968$$

$$psh1 ((5.4d), TBDY) = L_{stir1} * A_{stir1} / (A_{sec} * s1) = 0.00367709$$

$L_{stir1}$  (Length of stirrups along Y) = 2060.00

$A_{stir1}$  (stirrups area) = 78.53982

$$psh2 (5.4d) = L_{stir2} * A_{stir2} / (A_{sec} * s2) = 0.00067082$$

$L_{stir2}$  (Length of stirrups along Y) = 1468.00

$A_{stir2}$  (stirrups area) = 50.26548

$$psh_y * F_{ywe} = psh1 * F_{ywe1} + ps2 * F_{ywe2} = 3.3968$$

$$psh1 ((5.4d), TBDY) = L_{stir1} * A_{stir1} / (A_{sec} * s1) = 0.00367709$$

$L_{stir1}$  (Length of stirrups along X) = 2060.00

$A_{stir1}$  (stirrups area) = 78.53982

$$psh2 ((5.4d), TBDY) = L_{stir2} * A_{stir2} / (A_{sec} * s2) = 0.00067082$$

$L_{stir2}$  (Length of stirrups along X) = 1468.00

$A_{stir2}$  (stirrups area) = 50.26548

$$A_{sec} = 440000.00$$

$$s1 = 100.00$$

$$s2 = 250.00$$

$$f_{ywe1} = 781.25$$

$$f_{ywe2} = 781.25$$

$$f_{ce} = 30.00$$

$$\text{From } ((5.A5), TBDY), TBDY: cc = 0.00471045$$

$$c = \text{confinement factor} = 1.27105$$

$$y1 = 0.00083886$$

$$sh1 = 0.00268436$$

$$ft1 = 314.5735$$

$$fy1 = 262.1446$$

$$su1 = 0.00268436$$

using (30) in Biskinis/Fardis (2013) multiplied with shear\_factor and also multiplied by the shear\_factor according to 15.7.1.4, with Shear\_factor = 1.00

$$l_o/l_{ou,min} = l_b/l_d = 0.13907892$$

$$su1 = 0.4 * esu1_{nominal} ((5.5), TBDY) = 0.032$$

From table 5A.1, TBDY:  $esu1_{nominal} = 0.08$ ,

For calculation of  $esu1_{nominal}$  and  $y1$ ,  $sh1$ ,  $ft1$ ,  $fy1$ , it is considered characteristic value  $fsy1 = fs1/1.2$ , from table 5.1, TBDY.

$y1$ ,  $sh1$ ,  $ft1$ ,  $fy1$ , are also multiplied by  $\text{Min}(1, 1.25 * (l_b/l_d)^{2/3})$ , from 10.3.5, ASCE 41-17.

$$\text{with } fs1 = (f_{s,jacket} * A_{sl,ten,jacket} + f_{s,core} * A_{sl,ten,core}) / A_{sl,ten} = 262.1446$$

with  $E_{s1} = (E_{s,jacket} \cdot A_{s,ten,jacket} + E_{s,core} \cdot A_{s,ten,core}) / A_{s,ten} = 200000.00$   
 $y_2 = 0.00083886$   
 $sh_2 = 0.00268436$   
 $ft_2 = 314.5735$   
 $fy_2 = 262.1446$   
 $su_2 = 0.00268436$   
 using (30) in Biskinis/Fardis (2013) multiplied with shear\_factor  
 and also multiplied by the shear\_factor according to 15.7.1.4, with  
 Shear\_factor = 1.00  
 $l_o/l_{ou,min} = l_b/l_{b,min} = 0.13907892$   
 $su_2 = 0.4 \cdot esu_{2,nominal} ((5.5), TBDY) = 0.032$   
 From table 5A.1, TBDY:  $esu_{2,nominal} = 0.08$ ,  
 For calculation of  $esu_{2,nominal}$  and  $y_2, sh_2, ft_2, fy_2$ , it is considered  
 characteristic value  $fs_2 = fs_2/1.2$ , from table 5.1, TBDY.  
 $y_1, sh_1, ft_1, fy_1$ , are also multiplied by  $\text{Min}(1, 1.25 \cdot (l_b/l_d)^{2/3})$ , from 10.3.5, ASCE 41-17.  
 with  $fs_2 = (fs_{jacket} \cdot A_{s,com,jacket} + fs_{core} \cdot A_{s,com,core}) / A_{s,com} = 262.1446$   
 with  $E_{s2} = (E_{s,jacket} \cdot A_{s,com,jacket} + E_{s,core} \cdot A_{s,com,core}) / A_{s,com} = 200000.00$   
 $y_v = 0.00083886$   
 $sh_v = 0.00268436$   
 $ft_v = 314.5735$   
 $fy_v = 262.1446$   
 $suv = 0.00268436$   
 using (30) in Biskinis/Fardis (2013) multiplied with shear\_factor  
 and also multiplied by the shear\_factor according to 15.7.1.4, with  
 Shear\_factor = 1.00  
 $l_o/l_{ou,min} = l_b/l_d = 0.13907892$   
 $suv = 0.4 \cdot esuv_{nominal} ((5.5), TBDY) = 0.032$   
 From table 5A.1, TBDY:  $esuv_{nominal} = 0.08$ ,  
 considering characteristic value  $fs_v = fs_v/1.2$ , from table 5.1, TBDY  
 For calculation of  $esuv_{nominal}$  and  $y_v, sh_v, ft_v, fy_v$ , it is considered  
 characteristic value  $fs_v = fs_v/1.2$ , from table 5.1, TBDY.  
 $y_1, sh_1, ft_1, fy_1$ , are also multiplied by  $\text{Min}(1, 1.25 \cdot (l_b/l_d)^{2/3})$ , from 10.3.5, ASCE 41-17.  
 with  $fs_v = (fs_{jacket} \cdot A_{s,mid,jacket} + fs_{mid} \cdot A_{s,mid,core}) / A_{s,mid} = 262.1446$   
 with  $E_{sv} = (E_{s,jacket} \cdot A_{s,mid,jacket} + E_{s,mid} \cdot A_{s,mid,core}) / A_{s,mid} = 200000.00$   
 $1 = A_{s,ten} / (b \cdot d) \cdot (fs_1 / f_c) = 0.06824101$   
 $2 = A_{s,com} / (b \cdot d) \cdot (fs_2 / f_c) = 0.03513975$   
 $v = A_{s,mid} / (b \cdot d) \cdot (fs_v / f_c) = 0.06202846$   
 and confined core properties:  
 $b = 340.00$   
 $d = 677.00$   
 $d' = 13.00$   
 $f_{cc} (5A.2, TBDY) = 38.13135$   
 $cc (5A.5, TBDY) = 0.00471045$   
 $c = \text{confinement factor} = 1.27105$   
 $1 = A_{s,ten} / (b \cdot d) \cdot (fs_1 / f_c) = 0.08384116$   
 $2 = A_{s,com} / (b \cdot d) \cdot (fs_2 / f_c) = 0.04317283$   
 $v = A_{s,mid} / (b \cdot d) \cdot (fs_v / f_c) = 0.07620839$   
 Case/Assumption: Unconfined full section - Steel rupture  
 ' satisfies Eq. (4.3)  
 --->  
 $v < v_{s,y2}$  - LHS eq.(4.5) is satisfied  
 --->  
 $su (4.9) = 0.2584548$   
 $\mu_u = M_{Rc} (4.14) = 5.0296E+008$   
 $u = su (4.1) = 5.1201636E-006$

#### Calculation of ratio $l_b/l_d$

Lap Length:  $l_b/l_d = 0.13907892$   
 $l_b = 300.00$   
 $l_d = 2157.049$   
 Calculation of  $l_{b,min}$  according to (25.4.3.2), ACI 318-14, using mean values for all the section re-bars.  
 $l_{d,min}$  from (25.4.3.2) is multiplied 2 times to account for smooth re-bars (9.1.2, TS500 - No provision in ACI 318)  
 $= 1$   
 $db = 16.66667$   
 Mean strength value of all re-bars:  $fy = 781.25$

Mean concrete strength:  $fc' = (fc'_{jacket} \cdot Area_{jacket} + fc'_{core} \cdot Area_{core}) / Area_{section} = 30.00$ , but  $fc'^{0.5} \leq 8.3$  MPa (22.5.3.1, ACI 318-14)

$$t = 1.00$$

$$s = 0.80$$

$$e = 1.00$$

$$cb = 25.00$$

$$K_{tr} = 1.7174$$

$$A_{tr} = \text{Min}(A_{tr_x}, A_{tr_y}) = 257.6106$$

where  $A_{tr_x}$ ,  $A_{tr_y}$  are the sum of the area of all stirrup legs along X and Y loxal axis

$$s = \text{Max}(s_{external}, s_{internal}) = 250.00$$

$$n = 24.00$$

Calculation of Shear Strength  $V_r = \text{Min}(V_{r1}, V_{r2}) = 1.0392E+006$

Calculation of Shear Strength at edge 1,  $V_{r1} = 1.0392E+006$

$$V_{r1} = V_{Col} \text{ ((10.3), ASCE 41-17)} = knl \cdot V_{Col0}$$

$$V_{Col0} = 1.0392E+006$$

$$knl = 1 \text{ (zero step-static loading)}$$

NOTE: In expression (10-3) ' $V_s = A_v \cdot f_y \cdot d / s$ ' is replaced by ' $V_s + f \cdot V_f$ ' where  $V_f$  is the contribution of FRPs (11.3), ACI 440).

$$= 1 \text{ (normal-weight concrete)}$$

Mean concrete strength:  $fc' = (fc'_{jacket} \cdot Area_{jacket} + fc'_{core} \cdot Area_{core}) / Area_{section} = 30.00$ , but  $fc'^{0.5} \leq 8.3$  MPa (22.5.3.1, ACI 318-14)

$$M/Vd = 4.00$$

$$\mu_u = 1308.016$$

$$V_u = 0.00017144$$

$$d = 0.8 \cdot h = 600.00$$

$$N_u = 16273.608$$

$$A_g = 300000.00$$

$$\text{From (11.5.4.8), ACI 318-14: } V_s = V_{s,jacket} + V_{s,core} = 1.0138E+006$$

where:

$$V_{s,jacket} = V_{s,j1} + V_{s,j2} = 903207.888$$

$V_{s,j1} = 589048.623$  is calculated for section web jacket, with:

$$d = 600.00$$

$$A_v = 157079.633$$

$$f_y = 625.00$$

$$s = 100.00$$

$V_{s,j1}$  is multiplied by  $Col,j1 = 1.00$

$$s/d = 0.16666667$$

$V_{s,j2} = 314159.265$  is calculated for section flange jacket, with:

$$d = 320.00$$

$$A_v = 157079.633$$

$$f_y = 625.00$$

$$s = 100.00$$

$V_{s,j2}$  is multiplied by  $Col,j2 = 1.00$

$$s/d = 0.3125$$

$$V_{s,core} = V_{s,c1} + V_{s,c2} = 110584.061$$

$V_{s,c1} = 110584.061$  is calculated for section web core, with:

$$d = 440.00$$

$$A_v = 100530.965$$

$$f_y = 625.00$$

$$s = 250.00$$

$V_{s,c1}$  is multiplied by  $Col,c1 = 1.00$

$$s/d = 0.56818182$$

$V_{s,c2} = 0.00$  is calculated for section flange core, with:

$$d = 160.00$$

$$A_v = 100530.965$$

$$f_y = 625.00$$

$$s = 250.00$$

$V_{s,c2}$  is multiplied by  $Col,c2 = 0.00$

$$s/d = 1.5625$$

$$V_f \text{ ((11-3)-(11.4), ACI 440)} = 0.00$$

From (11-11), ACI 440:  $V_s + V_f \leq 873250.061$   
 $bw = 400.00$

Calculation of Shear Strength at edge 2,  $V_{r2} = 1.0392E+006$   
 $V_{r2} = V_{CoI} ((10.3), ASCE 41-17) = knl * V_{CoI0}$   
 $V_{CoI0} = 1.0392E+006$   
 $knl = 1$  (zero step-static loading)

NOTE: In expression (10-3) ' $V_s = A_v * f_y * d / s$ ' is replaced by ' $V_s + f * V_f$ '  
where  $V_f$  is the contribution of FRPs (11.3), ACI 440).

$= 1$  (normal-weight concrete)  
Mean concrete strength:  $f_c' = (f_c'_{jacket} * Area_{jacket} + f_c'_{core} * Area_{core}) / Area_{section} = 30.00$ , but  $f_c'^{0.5} \leq 8.3$   
MPa (22.5.3.1, ACI 318-14)  
 $M/Vd = 4.00$   
 $\mu_u = 1308.016$   
 $V_u = 0.00017144$   
 $d = 0.8 * h = 600.00$   
 $N_u = 16273.608$   
 $A_g = 300000.00$   
From (11.5.4.8), ACI 318-14:  $V_s = V_{sjacket} + V_{s,core} = 1.0138E+006$   
where:  
 $V_{sjacket} = V_{sj1} + V_{sj2} = 903207.888$   
 $V_{sj1} = 589048.623$  is calculated for section web jacket, with:  
 $d = 600.00$   
 $A_v = 157079.633$   
 $f_y = 625.00$   
 $s = 100.00$   
 $V_{sj1}$  is multiplied by  $Col,j1 = 1.00$   
 $s/d = 0.16666667$   
 $V_{sj2} = 314159.265$  is calculated for section flange jacket, with:  
 $d = 320.00$   
 $A_v = 157079.633$   
 $f_y = 625.00$   
 $s = 100.00$   
 $V_{sj2}$  is multiplied by  $Col,j2 = 1.00$   
 $s/d = 0.3125$   
 $V_{s,core} = V_{s,c1} + V_{s,c2} = 110584.061$   
 $V_{s,c1} = 110584.061$  is calculated for section web core, with:  
 $d = 440.00$   
 $A_v = 100530.965$   
 $f_y = 625.00$   
 $s = 250.00$   
 $V_{s,c1}$  is multiplied by  $Col,c1 = 1.00$   
 $s/d = 0.56818182$   
 $V_{s,c2} = 0.00$  is calculated for section flange core, with:  
 $d = 160.00$   
 $A_v = 100530.965$   
 $f_y = 625.00$   
 $s = 250.00$   
 $V_{s,c2}$  is multiplied by  $Col,c2 = 0.00$   
 $s/d = 1.5625$   
 $V_f ((11-3)-(11.4), ACI 440) = 0.00$   
From (11-11), ACI 440:  $V_s + V_f \leq 873250.061$   
 $bw = 400.00$

End Of Calculation of Shear Capacity ratio for element: column JLC1 of floor 1  
At local axis: 3

Start Of Calculation of Shear Capacity ratio for element: column JLC1 of floor 1  
At Shear local axis: 2  
(Bending local axis: 3)

Section Type: rcjics

## Constant Properties

Knowledge Factor,  $\gamma = 1.00$

Mean strength values are used for both shear and moment calculations.

Consequently:

Jacket

New material of Primary Member: Concrete Strength,  $f_c = f_{cm} = 30.00$

New material of Primary Member: Steel Strength,  $f_s = f_{sm} = 625.00$

Concrete Elasticity,  $E_c = 25742.96$

Steel Elasticity,  $E_s = 200000.00$

Existing Column

New material of Primary Member: Concrete Strength,  $f_c = f_{cm} = 30.00$

New material of Primary Member: Steel Strength,  $f_s = f_{sm} = 625.00$

Concrete Elasticity,  $E_c = 25742.96$

Steel Elasticity,  $E_s = 200000.00$

#####

Note: Especially for the calculation of moment strengths,

the above steel re-bar strengths are multiplied by 1.25 according to R18.6.5, ACI 318-14

Jacket

New material: Steel Strength,  $f_s = 1.25 \cdot f_{sm} = 781.25$

Existing Column

New material: Steel Strength,  $f_s = 1.25 \cdot f_{sm} = 781.25$

#####

Max Height,  $H_{max} = 750.00$

Min Height,  $H_{min} = 400.00$

Max Width,  $W_{max} = 750.00$

Min Width,  $W_{min} = 400.00$

Jacket Thickness,  $t_j = 100.00$

Cover Thickness,  $c = 25.00$

Mean Confinement Factor overall section = 1.27105

Element Length,  $L = 3000.00$

Primary Member

Smooth Bars

Ductile Steel

With Detailing for Earthquake Resistance (including stirrups closed at  $135^\circ$ )

Longitudinal Bars With Ends Lapped Starting at the End Sections

Lap Length  $l_o = 300.00$

No FRP Wrapping

## Stepwise Properties

At local axis: 2

EDGE -A-

Shear Force,  $V_a = -0.0001715$

EDGE -B-

Shear Force,  $V_b = 0.0001715$

BOTH EDGES

Axial Force,  $F = -16273.608$

Longitudinal Reinforcement Area Distribution (in 2 divisions)

-Tension:  $A_{sl,t} = 0.00$

-Compression:  $A_{sl,c} = 5353.274$

Longitudinal Reinforcement Area Distribution (in 3 divisions)

-Tension:  $A_{sl,ten} = 1137.257$

-Compression:  $A_{sl,com} = 2208.54$

-Middle:  $A_{sl,mid} = 2007.478$

Calculation of Shear Capacity ratio,  $V_e/V_r = 0.32266369$

Member Controlled by Flexure ( $V_e/V_r < 1$ )

Calculation of Shear Demand from fig. R18.6.5, ACI 318-14  $V_e = (M_{pr1} + M_{pr2})/l_n = 335307.657$

with

$M_{pr1} = \max(\mu_{u1+}, \mu_{u1-}) = 5.0296E+008$

Mu1+ = 2.3387E+008, is the ultimate moment strength at the edge 1 of the member in the actual moment direction which is defined for the static loading combination

Mu1- = 5.0296E+008, is the ultimate moment strength at the edge 1 of the member in the opposite moment direction which is defined for the static loading combination

Mpr2 = Max(Mu2+ , Mu2-) = 5.0296E+008

Mu2+ = 2.3387E+008, is the ultimate moment strength at the edge 2 of the member in the actual moment direction which is defined for the static loading combination

Mu2- = 5.0296E+008, is the ultimate moment strength at the edge 2 of the member in the opposite moment direction which is defined for the static loading combination

Calculation of Mu1+

Calculation of ultimate curvature  $\phi_u$  according to 4.1, Biskinis/Fardis 2013:

$\phi_u = 4.8099118E-006$

Mu = 2.3387E+008

with full section properties:

b = 750.00

d = 707.00

d' = 43.00

v = 0.00102301

N = 16273.608

fc = 30.00

co (5A.5, TBDY) = 0.002

Final value of  $\phi_u$ :  $\phi_u^* = \text{shear\_factor} * \text{Max}(\phi_u, \phi_c) = 0.01260361$

The Shear\_factor is considered equal to 1 (pure moment strength)

From (5.4b), TBDY:  $\phi_u = 0.01260361$

we (5.4c) = 0.05179731

ase ((5.4d), TBDY) =  $(\text{ase1} * A_{\text{ext}} + \text{ase2} * A_{\text{int}}) / A_{\text{sec}} = 0.45746528$

ase1 =  $\text{Max}(((A_{\text{conf,max1}} - A_{\text{noConf1}}) / A_{\text{conf,max1}}) * (A_{\text{conf,min1}} / A_{\text{conf,max1}}), 0) = 0.45746528$

The definitions of  $A_{\text{noConf}}$ ,  $A_{\text{conf,min}}$  and  $A_{\text{conf,max}}$  are derived from generalization of the rectangular sections confinement, which is expressed by (5.4d).

The generalization is done according to Mander, J., Priestley, M., and Park, R. (1988)

"Theoretical Stress-Strain Model for Confined Concrete."

J. Struct. Eng., 10.1061/(ASCE)0733-9445(1988)114:8(1804), 1804-1826.

$A_{\text{conf,max1}} = 353600.00$  is the confined core area at levels of member with hoops and is calculated as the area of core enclosed by the center lines of the external perimeter hoops.

$A_{\text{conf,min1}} = 293525.00$  is the confined core area at midway between the levels of hoops and is calculated by reducing all the dimensions of the area  $A_{\text{conf,max1}}$  by a length equal to half the clear spacing between external hoops.

$A_{\text{noConf1}} = 158733.333$  is the unconfined external core area which is equal to  $b_i^2/6$  as defined at (A.2).

ase2 ( $\geq \text{ase1}$ ) =  $\text{Max}(((A_{\text{conf,max2}} - A_{\text{noConf2}}) / A_{\text{conf,max2}}) * (A_{\text{conf,min2}} / A_{\text{conf,max2}}), 0) = 0.45746528$

The definitions of  $A_{\text{noConf}}$ ,  $A_{\text{conf,min}}$  and  $A_{\text{conf,max}}$  are derived from generalization of the rectangular sections confinement, which is expressed by (5.4d).

The generalization is done according to Mander, J., Priestley, M., and Park, R. (1988)

"Theoretical Stress-Strain Model for Confined Concrete."

J. Struct. Eng., 10.1061/(ASCE)0733-9445(1988)114:8(1804), 1804-1826.

$A_{\text{conf,max2}} = 171264.00$  is the confined core area at levels of member with hoops and is calculated as the area of core enclosed by the center lines of the internal perimeter hoops.

$A_{\text{conf,min2}} = 54741.00$  is the confined core area at midway between the levels of hoops and is calculated by reducing all the dimensions of the area  $A_{\text{conf,max2}}$  by a length equal to half the clear spacing between internal hoops.

$A_{\text{noConf2}} = 106242.667$  is the unconfined internal core area which is equal to  $b_i^2/6$  as defined at (A.2).

$\text{psh,min} * F_{ywe} = \text{Min}(\text{psh,x} * F_{ywe}, \text{psh,y} * F_{ywe}) = 3.3968$

$\text{psh,x} * F_{ywe} = \text{psh1} * F_{ywe1} + \text{ps2} * F_{ywe2} = 3.3968$

$\text{psh1}$  ((5.4d), TBDY) =  $L_{\text{stir1}} * A_{\text{stir1}} / (A_{\text{sec}} * s1) = 0.00367709$

$L_{\text{stir1}}$  (Length of stirrups along Y) = 2060.00

$A_{\text{stir1}}$  (stirrups area) = 78.53982

$\text{psh2}$  (5.4d) =  $L_{\text{stir2}} * A_{\text{stir2}} / (A_{\text{sec}} * s2) = 0.00067082$

$L_{\text{stir2}}$  (Length of stirrups along Y) = 1468.00

$A_{\text{stir2}}$  (stirrups area) = 50.26548

$\text{psh,y} * F_{ywe} = \text{psh1} * F_{ywe1} + \text{ps2} * F_{ywe2} = 3.3968$



$psh1 ((5.4d), TBDY) = Lstir1 * Astir1 / (Asec * s1) = 0.00367709$   
 $Lstir1$  (Length of stirrups along X) = 2060.00  
 $Astir1$  (stirrups area) = 78.53982  
 $psh2 ((5.4d), TBDY) = Lstir2 * Astir2 / (Asec * s2) = 0.00067082$   
 $Lstir2$  (Length of stirrups along X) = 1468.00  
 $Astir2$  (stirrups area) = 50.26548

Asec = 440000.00

s1 = 100.00

s2 = 250.00

fywe1 = 781.25

fywe2 = 781.25

fce = 30.00

From ((5.A5), TBDY), TBDY: cc = 0.00471045

c = confinement factor = 1.27105

y1 = 0.00083886

sh1 = 0.00268436

ft1 = 314.5735

fy1 = 262.1446

su1 = 0.00268436

using (30) in Biskinis/Fardis (2013) multiplied with shear\_factor  
and also multiplied by the shear\_factor according to 15.7.1.4, with  
Shear\_factor = 1.00

lo/lou,min = lb/ld = 0.13907892

su1 = 0.4\*esu1\_nominal ((5.5), TBDY) = 0.032

From table 5A.1, TBDY: esu1\_nominal = 0.08,

For calculation of esu1\_nominal and y1, sh1,ft1,fy1, it is considered  
characteristic value fsy1 = fs1/1.2, from table 5.1, TBDY.

y1, sh1,ft1,fy1, are also multiplied by  $\text{Min}(1, 1.25 * (lb/ld)^{2/3})$ , from 10.3.5, ASCE 41-17.

with fs1 = (fs,jacket\*Asl,ten,jacket + fs,core\*Asl,ten,core)/Asl,ten = 262.1446

with Es1 = (Es,jacket\*Asl,ten,jacket + Es,core\*Asl,ten,core)/Asl,ten = 200000.00

y2 = 0.00083886

sh2 = 0.00268436

ft2 = 314.5735

fy2 = 262.1446

su2 = 0.00268436

using (30) in Biskinis/Fardis (2013) multiplied with shear\_factor  
and also multiplied by the shear\_factor according to 15.7.1.4, with  
Shear\_factor = 1.00

lo/lou,min = lb/lb,min = 0.13907892

su2 = 0.4\*esu2\_nominal ((5.5), TBDY) = 0.032

From table 5A.1, TBDY: esu2\_nominal = 0.08,

For calculation of esu2\_nominal and y2, sh2,ft2,fy2, it is considered  
characteristic value fsy2 = fs2/1.2, from table 5.1, TBDY.

y1, sh1,ft1,fy1, are also multiplied by  $\text{Min}(1, 1.25 * (lb/ld)^{2/3})$ , from 10.3.5, ASCE 41-17.

with fs2 = (fs,jacket\*Asl,com,jacket + fs,core\*Asl,com,core)/Asl,com = 262.1446

with Es2 = (Es,jacket\*Asl,com,jacket + Es,core\*Asl,com,core)/Asl,com = 200000.00

yv = 0.00083886

shv = 0.00268436

ftv = 314.5735

fyv = 262.1446

suv = 0.00268436

using (30) in Biskinis/Fardis (2013) multiplied with shear\_factor  
and also multiplied by the shear\_factor according to 15.7.1.4, with  
Shear\_factor = 1.00

lo/lou,min = lb/ld = 0.13907892

suv = 0.4\*esuv\_nominal ((5.5), TBDY) = 0.032

From table 5A.1, TBDY: esuv\_nominal = 0.08,

considering characteristic value fsyv = fsv/1.2, from table 5.1, TBDY

For calculation of esuv\_nominal and yv, shv,ftv,fyv, it is considered  
characteristic value fsyv = fsv/1.2, from table 5.1, TBDY.

y1, sh1,ft1,fy1, are also multiplied by  $\text{Min}(1, 1.25 * (lb/ld)^{2/3})$ , from 10.3.5, ASCE 41-17.

with fsv = (fs,jacket\*Asl,mid,jacket + fs,mid\*Asl,mid,core)/Asl,mid = 262.1446

with Esv = (Es,jacket\*Asl,mid,jacket + Es,mid\*Asl,mid,core)/Asl,mid = 200000.00

1 = Asl,ten/(b\*d)\*(fs1/fc) = 0.0187412

2 = Asl,com/(b\*d)\*(fs2/fc) = 0.03639521

v = Asl,mid/(b\*d)\*(fsv/fc) = 0.03308184

and confined core properties:

$$b = 690.00$$

$$d = 677.00$$

$$d' = 13.00$$

$$fcc(5A.2, TBDY) = 38.13135$$

$$cc(5A.5, TBDY) = 0.00471045$$

$$c = \text{confinement factor} = 1.27105$$

$$1 = A_{sl,ten}/(b*d)*(f_{s1}/f_c) = 0.02127357$$

$$2 = A_{sl,com}/(b*d)*(f_{s2}/f_c) = 0.04131304$$

$$v = A_{sl,mid}/(b*d)*(f_{sv}/f_c) = 0.03755196$$

Case/Assumption: Unconfined full section - Steel rupture

' satisfies Eq. (4.3)

---->

$v < v_{s,y2}$  - LHS eq.(4.5) is satisfied

---->

$$s_u(4.9) = 0.21062322$$

$$M_u = M_{Rc}(4.14) = 2.3387E+008$$

$$u = s_u(4.1) = 4.8099118E-006$$

Calculation of ratio  $l_b/l_d$

Lap Length:  $l_b/l_d = 0.13907892$

$$l_b = 300.00$$

$$l_d = 2157.049$$

Calculation of  $l_b, \min$  according to (25.4.3.2), ACI 318-14, using mean values for all the section re-bars.

$l_d, \min$  from (25.4.3.2) is multiplied 2 times to account for smooth re-bars (9.1.2, TS500 - No provision in ACI 318)

$$= 1$$

$$d_b = 16.66667$$

$$\text{Mean strength value of all re-bars: } f_y = 781.25$$

$$\text{Mean concrete strength: } f'_c = (f'_c_{\text{jacket}} * \text{Area}_{\text{jacket}} + f'_c_{\text{core}} * \text{Area}_{\text{core}}) / \text{Area}_{\text{section}} = 30.00, \text{ but } f_c^{0.5} \leq 8.3 \text{ MPa (22.5.3.1, ACI 318-14)}$$

$$t = 1.00$$

$$s = 0.80$$

$$e = 1.00$$

$$c_b = 25.00$$

$$K_{tr} = 1.7174$$

$$A_{tr} = \text{Min}(A_{tr,x}, A_{tr,y}) = 257.6106$$

where  $A_{tr,x}$ ,  $A_{tr,y}$  are the sum of the area of all stirrup legs along X and Y loxal axis

$$s = \text{Max}(s_{\text{external}}, s_{\text{internal}}) = 250.00$$

$$n = 24.00$$

Calculation of  $M_{u1}$ -

Calculation of ultimate curvature  $u$  according to 4.1, Biskinis/Fardis 2013:

$$u = 5.1201636E-006$$

$$M_u = 5.0296E+008$$

with full section properties:

$$b = 400.00$$

$$d = 707.00$$

$$d' = 43.00$$

$$v = 0.00191815$$

$$N = 16273.608$$

$$f_c = 30.00$$

$$c_o(5A.5, TBDY) = 0.002$$

$$\text{Final value of } c_u: c_u^* = \text{shear\_factor} * \text{Max}(c_u, c_o) = 0.01260361$$

The Shear\_factor is considered equal to 1 (pure moment strength)

$$\text{From (5.4b), TBDY: } c_u = 0.01260361$$

$$w_e(5.4c) = 0.05179731$$

$$a_{se}((5.4d), TBDY) = (a_{se1} * A_{ext} + a_{se2} * A_{int}) / A_{sec} = 0.45746528$$

$$a_{se1} = \text{Max}(((A_{conf,max1} - A_{noConf1}) / A_{conf,max1}) * (A_{conf,min1} / A_{conf,max1}), 0) = 0.45746528$$

The definitions of  $A_{noConf}$ ,  $A_{conf,min}$  and  $A_{conf,max}$  are derived from generalization

of the rectangular sections confinement, which is expressed by (5.4d).

The generalization is done according to Mander, J., Priestley, M., and Park, R. (1988)

"Theoretical Stress-Strain Model for Confined Concrete."

J. Struct. Eng., 10.1061/(ASCE)0733-9445(1988)114:8(1804), 1804-1826.

$A_{conf,max1} = 353600.00$  is the confined core area at levels of member with hoops and

is calculated as the area of core enclosed by the center lines of the external perimeter hoops.

$A_{conf,min1} = 293525.00$  is the confined core area at midway between the levels of hoops and

is calculated by reducing all the dimensions of the area  $A_{conf,max1}$  by a length equal to half the clear spacing between external hoops.

$A_{noConf1} = 158733.333$  is the unconfined external core area which is equal to  $b_i^2/6$  as defined at (A.2).

$ase2 (>= ase1) = \text{Max}(((A_{conf,max2} - A_{noConf2})/A_{conf,max2}) * (A_{conf,min2}/A_{conf,max2}), 0) = 0.45746528$

The definitions of  $A_{noConf}$ ,  $A_{conf,min}$  and  $A_{conf,max}$  are derived from generalization of the rectangular sections confinement, which is expressed by (5.4d).

The generalization is done according to Mander, J., Priestley, M., and Park, R. (1988)

"Theoretical Stress-Strain Model for Confined Concrete."

J. Struct. Eng., 10.1061/(ASCE)0733-9445(1988)114:8(1804), 1804-1826.

$A_{conf,max2} = 171264.00$  is the confined core area at levels of member with hoops and

is calculated as the area of core enclosed by the center lines of the internal perimeter hoops.

$A_{conf,min2} = 54741.00$  is the confined core area at midway between the levels of hoops and

is calculated by reducing all the dimensions of the area  $A_{conf,max2}$  by a length equal to half the clear spacing between internal hoops.

$A_{noConf2} = 106242.667$  is the unconfined internal core area which is equal to  $b_i^2/6$  as defined at (A.2).

$psh_{min} * F_{ywe} = \text{Min}(psh_x * F_{ywe}, psh_y * F_{ywe}) = 3.3968$

$psh_x * F_{ywe} = psh1 * F_{ywe1} + ps2 * F_{ywe2} = 3.3968$

$psh1$  ((5.4d), TBDY) =  $L_{stir1} * A_{stir1} / (A_{sec} * s1) = 0.00367709$

$L_{stir1}$  (Length of stirrups along Y) = 2060.00

$A_{stir1}$  (stirrups area) = 78.53982

$psh2$  ((5.4d), TBDY) =  $L_{stir2} * A_{stir2} / (A_{sec} * s2) = 0.00067082$

$L_{stir2}$  (Length of stirrups along Y) = 1468.00

$A_{stir2}$  (stirrups area) = 50.26548

$psh_y * F_{ywe} = psh1 * F_{ywe1} + ps2 * F_{ywe2} = 3.3968$

$psh1$  ((5.4d), TBDY) =  $L_{stir1} * A_{stir1} / (A_{sec} * s1) = 0.00367709$

$L_{stir1}$  (Length of stirrups along X) = 2060.00

$A_{stir1}$  (stirrups area) = 78.53982

$psh2$  ((5.4d), TBDY) =  $L_{stir2} * A_{stir2} / (A_{sec} * s2) = 0.00067082$

$L_{stir2}$  (Length of stirrups along X) = 1468.00

$A_{stir2}$  (stirrups area) = 50.26548

$A_{sec} = 440000.00$

$s1 = 100.00$

$s2 = 250.00$

$f_{ywe1} = 781.25$

$f_{ywe2} = 781.25$

$f_{ce} = 30.00$

From ((5.A5), TBDY), TBDY:  $cc = 0.00471045$

$c$  = confinement factor = 1.27105

$y1 = 0.00083886$

$sh1 = 0.00268436$

$ft1 = 314.5735$

$fy1 = 262.1446$

$su1 = 0.00268436$

using (30) in Biskinis/Fardis (2013) multiplied with  $shear\_factor$

and also multiplied by the  $shear\_factor$  according to 15.7.1.4, with

$Shear\_factor = 1.00$

$lo/lo_{min} = lb/ld = 0.13907892$

$su1 = 0.4 * esu1\_nominal$  ((5.5), TBDY) = 0.032

From table 5A.1, TBDY:  $esu1\_nominal = 0.08$ ,

For calculation of  $esu1\_nominal$  and  $y1$ ,  $sh1$ ,  $ft1$ ,  $fy1$ , it is considered

characteristic value  $fsy1 = fs1/1.2$ , from table 5.1, TBDY.

$y1$ ,  $sh1$ ,  $ft1$ ,  $fy1$ , are also multiplied by  $\text{Min}(1, 1.25 * (lb/ld)^{2/3})$ , from 10.3.5, ASCE 41-17.

with  $fs1 = (fs_{jacket} * A_{sl,ten,jacket} + fs_{core} * A_{sl,ten,core}) / A_{sl,ten} = 262.1446$

with  $Es1 = (Es_{jacket} * A_{sl,ten,jacket} + Es_{core} * A_{sl,ten,core}) / A_{sl,ten} = 200000.00$

$y2 = 0.00083886$

$sh2 = 0.00268436$

$ft2 = 314.5735$

```

fy2 = 262.1446
su2 = 0.00268436
    using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
    and also multiplied by the shear_factor according to 15.7.1.4, with
    Shear_factor = 1.00
    lo/lou,min = lb/lb,min = 0.13907892
    su2 = 0.4*esu2_nominal ((5.5), TBDY) = 0.032
    From table 5A.1, TBDY: esu2_nominal = 0.08,
    For calculation of esu2_nominal and y2, sh2,ft2,fy2, it is considered
    characteristic value fsy2 = fs2/1.2, from table 5.1, TBDY.
    y1, sh1,ft1,fy1, are also multiplied by Min(1,1.25*(lb/lb)^ 2/3), from 10.3.5, ASCE 41-17.
    with fs2 = (fs,jacket*Asl,com,jacket + fs,core*Asl,com,core)/Asl,com = 262.1446
    with Es2 = (Es,jacket*Asl,com,jacket + Es,core*Asl,com,core)/Asl,com = 200000.00
    yv = 0.00083886
    shv = 0.00268436
    ftv = 314.5735
    fyv = 262.1446
    suv = 0.00268436
    using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
    and also multiplied by the shear_factor according to 15.7.1.4, with
    Shear_factor = 1.00
    lo/lou,min = lb/lb = 0.13907892
    suv = 0.4*esuv_nominal ((5.5), TBDY) = 0.032
    From table 5A.1, TBDY: esuv_nominal = 0.08,
    considering characteristic value fsyv = fsv/1.2, from table 5.1, TBDY
    For calculation of esuv_nominal and yv, shv,ftv,fyv, it is considered
    characteristic value fsyv = fsv/1.2, from table 5.1, TBDY.
    y1, sh1,ft1,fy1, are also multiplied by Min(1,1.25*(lb/lb)^ 2/3), from 10.3.5, ASCE 41-17.
    with fsv = (fs,jacket*Asl,mid,jacket + fs,mid*Asl,mid,core)/Asl,mid = 262.1446
    with Esv = (Es,jacket*Asl,mid,jacket + Es,mid*Asl,mid,core)/Asl,mid = 200000.00
    1 = Asl,ten/(b*d)*(fs1/fc) = 0.06824101
    2 = Asl,com/(b*d)*(fs2/fc) = 0.03513975
    v = Asl,mid/(b*d)*(fsv/fc) = 0.06202846
    and confined core properties:
    b = 340.00
    d = 677.00
    d' = 13.00
    fcc (5A.2, TBDY) = 38.13135
    cc (5A.5, TBDY) = 0.00471045
    c = confinement factor = 1.27105
    1 = Asl,ten/(b*d)*(fs1/fc) = 0.08384116
    2 = Asl,com/(b*d)*(fs2/fc) = 0.04317283
    v = Asl,mid/(b*d)*(fsv/fc) = 0.07620839

```

Case/Assumption: Unconfined full section - Steel rupture  
 ' satisfies Eq. (4.3)

```

---->
v < vs,y2 - LHS eq.(4.5) is satisfied
---->
su (4.9) = 0.2584548
Mu = MRc (4.14) = 5.0296E+008
u = su (4.1) = 5.1201636E-006

```

#### Calculation of ratio lb/lb

```

Lap Length: lb/lb = 0.13907892
lb = 300.00
lb = 2157.049
Calculation of lb,min according to (25.4.3.2), ACI 318-14, using mean values for all the section re-bars.
lb,min from (25.4.3.2) is multiplied 2 times to account for smooth re-bars (9.1.2, TS500 - No provision in ACI 318)
= 1
db = 16.66667
Mean strength value of all re-bars: fy = 781.25
Mean concrete strength: fc' = (fc'_jacket*Area_jacket + fc'_core*Area_core)/Area_section = 30.00, but fc'^0.5 <= 8.3
MPa (22.5.3.1, ACI 318-14)
t = 1.00
s = 0.80

```

$e = 1.00$   
 $cb = 25.00$   
 $Ktr = 1.7174$   
 $Atr = \text{Min}(Atr_x, Atr_y) = 257.6106$   
 where  $Atr_x, Atr_y$  are the sum of the area of all stirrup legs along X and Y loxal axis  
 $s = \text{Max}(s_{\text{external}}, s_{\text{internal}}) = 250.00$   
 $n = 24.00$

Calculation of  $\mu_{2+}$

Calculation of ultimate curvature  $\mu$  according to 4.1, Biskinis/Fardis 2013:  
 $\mu = 4.8099118E-006$   
 $\mu_u = 2.3387E+008$

with full section properties:

$b = 750.00$   
 $d = 707.00$   
 $d' = 43.00$   
 $v = 0.00102301$   
 $N = 16273.608$   
 $f_c = 30.00$   
 $\alpha (5A.5, \text{TBDY}) = 0.002$

Final value of  $\mu_u$ :  $\mu_u^* = \text{shear\_factor} * \text{Max}(\mu_u, \mu_c) = 0.01260361$

The Shear\_factor is considered equal to 1 (pure moment strength)

From (5.4b), TBDY:  $\mu_u = 0.01260361$

we (5.4c)  $= 0.05179731$

$\alpha_{se} ((5.4d), \text{TBDY}) = (\alpha_{se1} * A_{ext} + \alpha_{se2} * A_{int}) / A_{sec} = 0.45746528$

$\alpha_{se1} = \text{Max}(((A_{conf,max1} - A_{noConf1}) / A_{conf,max1}) * (A_{conf,min1} / A_{conf,max1}), 0) = 0.45746528$

The definitions of  $A_{noConf}$ ,  $A_{conf,min}$  and  $A_{conf,max}$  are derived from generalization of the rectangular sections confinement, which is expressed by (5.4d).

The generalization is done according to Mander, J., Priestley, M., and Park, R. (1988) "Theoretical Stress-Strain Model for Confined Concrete."

J. Struct. Eng., 10.1061/(ASCE)0733-9445(1988)114:8(1804), 1804-1826.

$A_{conf,max1} = 353600.00$  is the confined core area at levels of member with hoops and is calculated as the area of core enclosed by the center lines of the external perimeter hoops.

$A_{conf,min1} = 293525.00$  is the confined core area at midway between the levels of hoops and is calculated by reducing all the dimensions of the area  $A_{conf,max1}$  by a length equal to half the clear spacing between external hoops.

$A_{noConf1} = 158733.333$  is the unconfined external core area which is equal to  $b_i^2/6$  as defined at (A.2).

$\alpha_{se2} (> \alpha_{se1}) = \text{Max}(((A_{conf,max2} - A_{noConf2}) / A_{conf,max2}) * (A_{conf,min2} / A_{conf,max2}), 0) = 0.45746528$

The definitions of  $A_{noConf}$ ,  $A_{conf,min}$  and  $A_{conf,max}$  are derived from generalization of the rectangular sections confinement, which is expressed by (5.4d).

The generalization is done according to Mander, J., Priestley, M., and Park, R. (1988) "Theoretical Stress-Strain Model for Confined Concrete."

J. Struct. Eng., 10.1061/(ASCE)0733-9445(1988)114:8(1804), 1804-1826.

$A_{conf,max2} = 171264.00$  is the confined core area at levels of member with hoops and is calculated as the area of core enclosed by the center lines of the internal perimeter hoops.

$A_{conf,min2} = 54741.00$  is the confined core area at midway between the levels of hoops and is calculated by reducing all the dimensions of the area  $A_{conf,max2}$  by a length equal to half the clear spacing between internal hoops.

$A_{noConf2} = 106242.667$  is the unconfined internal core area which is equal to  $b_i^2/6$  as defined at (A.2).

$psh_{min} * F_{ywe} = \text{Min}(psh_x * F_{ywe}, psh_y * F_{ywe}) = 3.3968$

$psh_x * F_{ywe} = psh1 * F_{ywe1} + psh2 * F_{ywe2} = 3.3968$

$psh1 ((5.4d), \text{TBDY}) = L_{stir1} * A_{stir1} / (A_{sec} * s1) = 0.00367709$

$L_{stir1}$  (Length of stirrups along Y) = 2060.00

$A_{stir1}$  (stirrups area) = 78.53982

$psh2 ((5.4d)) = L_{stir2} * A_{stir2} / (A_{sec} * s2) = 0.00067082$

$L_{stir2}$  (Length of stirrups along Y) = 1468.00

$A_{stir2}$  (stirrups area) = 50.26548

$psh_y * F_{ywe} = psh1 * F_{ywe1} + psh2 * F_{ywe2} = 3.3968$

$psh1 ((5.4d), \text{TBDY}) = L_{stir1} * A_{stir1} / (A_{sec} * s1) = 0.00367709$

Lstir1 (Length of stirrups along X) = 2060.00  
 Astir1 (stirrups area) = 78.53982  
 $psh2 ((5.4d), TBDY) = Lstir2 * Astir2 / (Asec * s2) = 0.00067082$   
 Lstir2 (Length of stirrups along X) = 1468.00  
 Astir2 (stirrups area) = 50.26548

Asec = 440000.00

s1 = 100.00

s2 = 250.00

fywe1 = 781.25

fywe2 = 781.25

fce = 30.00

From ((5.A5), TBDY), TBDY: cc = 0.00471045

c = confinement factor = 1.27105

y1 = 0.00083886

sh1 = 0.00268436

ft1 = 314.5735

fy1 = 262.1446

su1 = 0.00268436

using (30) in Biskinis/Fardis (2013) multiplied with shear\_factor  
 and also multiplied by the shear\_factor according to 15.7.1.4, with  
 Shear\_factor = 1.00

lo/lou,min = lb/ld = 0.13907892

su1 = 0.4\*esu1\_nominal ((5.5), TBDY) = 0.032

From table 5A.1, TBDY: esu1\_nominal = 0.08,

For calculation of esu1\_nominal and y1, sh1,ft1,fy1, it is considered  
 characteristic value fsy1 = fs1/1.2, from table 5.1, TBDY.

y1, sh1,ft1,fy1, are also multiplied by  $\text{Min}(1, 1.25 * (lb/ld)^{2/3})$ , from 10.3.5, ASCE 41-17.

with fs1 = (fs,jacket\*Asl,ten,jacket + fs,core\*Asl,ten,core)/Asl,ten = 262.1446

with Es1 = (Es,jacket\*Asl,ten,jacket + Es,core\*Asl,ten,core)/Asl,ten = 200000.00

y2 = 0.00083886

sh2 = 0.00268436

ft2 = 314.5735

fy2 = 262.1446

su2 = 0.00268436

using (30) in Biskinis/Fardis (2013) multiplied with shear\_factor  
 and also multiplied by the shear\_factor according to 15.7.1.4, with  
 Shear\_factor = 1.00

lo/lou,min = lb/lb,min = 0.13907892

su2 = 0.4\*esu2\_nominal ((5.5), TBDY) = 0.032

From table 5A.1, TBDY: esu2\_nominal = 0.08,

For calculation of esu2\_nominal and y2, sh2,ft2,fy2, it is considered  
 characteristic value fsy2 = fs2/1.2, from table 5.1, TBDY.

y1, sh1,ft1,fy1, are also multiplied by  $\text{Min}(1, 1.25 * (lb/ld)^{2/3})$ , from 10.3.5, ASCE 41-17.

with fs2 = (fs,jacket\*Asl,com,jacket + fs,core\*Asl,com,core)/Asl,com = 262.1446

with Es2 = (Es,jacket\*Asl,com,jacket + Es,core\*Asl,com,core)/Asl,com = 200000.00

yv = 0.00083886

shv = 0.00268436

ftv = 314.5735

fyv = 262.1446

suv = 0.00268436

using (30) in Biskinis/Fardis (2013) multiplied with shear\_factor  
 and also multiplied by the shear\_factor according to 15.7.1.4, with  
 Shear\_factor = 1.00

lo/lou,min = lb/ld = 0.13907892

suv = 0.4\*esuv\_nominal ((5.5), TBDY) = 0.032

From table 5A.1, TBDY: esuv\_nominal = 0.08,

considering characteristic value fsyv = fsv/1.2, from table 5.1, TBDY

For calculation of esuv\_nominal and yv, shv,ftv,fyv, it is considered  
 characteristic value fsyv = fsv/1.2, from table 5.1, TBDY.

y1, sh1,ft1,fy1, are also multiplied by  $\text{Min}(1, 1.25 * (lb/ld)^{2/3})$ , from 10.3.5, ASCE 41-17.

with fsv = (fs,jacket\*Asl,mid,jacket + fs,mid\*Asl,mid,core)/Asl,mid = 262.1446

with Esv = (Es,jacket\*Asl,mid,jacket + Es,mid\*Asl,mid,core)/Asl,mid = 200000.00

1 = Asl,ten/(b\*d)\*(fs1/fc) = 0.0187412

2 = Asl,com/(b\*d)\*(fs2/fc) = 0.03639521

v = Asl,mid/(b\*d)\*(fsv/fc) = 0.03308184

and confined core properties:

$b = 690.00$   
 $d = 677.00$   
 $d' = 13.00$   
 $f_{cc} (5A.2, TBDY) = 38.13135$   
 $cc (5A.5, TBDY) = 0.00471045$   
 $c = \text{confinement factor} = 1.27105$   
 $1 = A_{sl,ten}/(b*d)*(f_{s1}/f_c) = 0.02127357$   
 $2 = A_{sl,com}/(b*d)*(f_{s2}/f_c) = 0.04131304$   
 $v = A_{sl,mid}/(b*d)*(f_{sv}/f_c) = 0.03755196$   
 Case/Assumption: Unconfined full section - Steel rupture  
 ' satisfies Eq. (4.3)

--->  
 $v < v_{s,y2}$  - LHS eq.(4.5) is satisfied  
 --->  
 $su (4.9) = 0.21062322$   
 $Mu = MRc (4.14) = 2.3387E+008$   
 $u = su (4.1) = 4.8099118E-006$

Calculation of ratio  $l_b/l_d$

Lap Length:  $l_b/l_d = 0.13907892$   
 $l_b = 300.00$   
 $l_d = 2157.049$   
 Calculation of  $l_b, \min$  according to (25.4.3.2), ACI 318-14, using mean values for all the section re-bars.  
 $l_d, \min$  from (25.4.3.2) is multiplied 2 times to account for smooth re-bars (9.1.2, TS500 - No provision in ACI 318)  
 $= 1$   
 $db = 16.66667$   
 Mean strength value of all re-bars:  $f_y = 781.25$   
 Mean concrete strength:  $f_c' = (f_c'_{jacket} * Area_{jacket} + f_c'_{core} * Area_{core}) / Area_{section} = 30.00$ , but  $f_c'^{0.5} \leq 8.3$   
 MPa (22.5.3.1, ACI 318-14)  
 $t = 1.00$   
 $s = 0.80$   
 $e = 1.00$   
 $cb = 25.00$   
 $K_{tr} = 1.7174$   
 $A_{tr} = \text{Min}(A_{tr,x}, A_{tr,y}) = 257.6106$   
 where  $A_{tr,x}$ ,  $A_{tr,y}$  are the sum of the area of all stirrup legs along X and Y loxal axis  
 $s = \text{Max}(s_{external}, s_{internal}) = 250.00$   
 $n = 24.00$

Calculation of  $Mu_2$ -

Calculation of ultimate curvature  $u$  according to 4.1, Biskinis/Fardis 2013:  
 $u = 5.1201636E-006$   
 $Mu = 5.0296E+008$

with full section properties:

$b = 400.00$   
 $d = 707.00$   
 $d' = 43.00$   
 $v = 0.00191815$   
 $N = 16273.608$   
 $f_c = 30.00$   
 $co (5A.5, TBDY) = 0.002$   
 Final value of  $cu$ :  $cu^* = \text{shear\_factor} * \text{Max}(cu, cc) = 0.01260361$   
 The Shear\_factor is considered equal to 1 (pure moment strength)  
 From (5.4b), TBDY:  $cu = 0.01260361$   
 $we (5.4c) = 0.05179731$   
 $ase ((5.4d), TBDY) = (ase1 * A_{ext} + ase2 * A_{int}) / A_{sec} = 0.45746528$   
 $ase1 = \text{Max}(((A_{conf,max1} - A_{noConf1}) / A_{conf,max1}) * (A_{conf,min1} / A_{conf,max1}), 0) = 0.45746528$   
 The definitions of  $A_{noConf}$ ,  $A_{conf,min}$  and  $A_{conf,max}$  are derived from generalization of the rectangular sections confinement, which is expressed by (5.4d).

The generalization is done according to Mander, J., Priestley, M., and Park, R. (1988)  
"Theoretical Stress-Strain Model for Confined Concrete."

J. Struct. Eng., 10.1061/(ASCE)0733-9445(1988)114:8(1804), 1804-1826.

$A_{conf,max1} = 353600.00$  is the confined core area at levels of member with hoops and  
is calculated as the area of core enclosed by the center lines of the external perimeter hoops.

$A_{conf,min1} = 293525.00$  is the confined core area at midway between the levels of hoops and  
is calculated by reducing all the dimensions of the area  $A_{conf,max1}$  by a length  
equal to half the clear spacing between external hoops.

$A_{noConf1} = 158733.333$  is the unconfined external core area which is equal to  $b_i^2/6$  as defined at (A.2).

$ase2 (>= ase1) = \text{Max}(((A_{conf,max2} - A_{noConf2})/A_{conf,max2}) * (A_{conf,min2}/A_{conf,max2}), 0) = 0.45746528$

The definitions of  $A_{noConf}$ ,  $A_{conf,min}$  and  $A_{conf,max}$  are derived from generalization  
of the rectangular sections confinement, which is expressed by (5.4d).

The generalization is done according to Mander, J., Priestley, M., and Park, R. (1988)  
"Theoretical Stress-Strain Model for Confined Concrete."

J. Struct. Eng., 10.1061/(ASCE)0733-9445(1988)114:8(1804), 1804-1826.

$A_{conf,max2} = 171264.00$  is the confined core area at levels of member with hoops and  
is calculated as the area of core enclosed by the center lines of the internal perimeter hoops.

$A_{conf,min2} = 54741.00$  is the confined core area at midway between the levels of hoops and  
is calculated by reducing all the dimensions of the area  $A_{conf,max2}$  by a length  
equal to half the clear spacing between internal hoops.

$A_{noConf2} = 106242.667$  is the unconfined internal core area which is equal to  $b_i^2/6$  as defined at (A.2).

$psh_{min} * F_{ywe} = \text{Min}(psh_x * F_{ywe}, psh_y * F_{ywe}) = 3.3968$

$psh_x * F_{ywe} = psh1 * F_{ywe1} + ps2 * F_{ywe2} = 3.3968$

$psh1 ((5.4d), TBDY) = L_{stir1} * A_{stir1} / (A_{sec} * s1) = 0.00367709$

$L_{stir1}$  (Length of stirrups along Y) = 2060.00

$A_{stir1}$  (stirrups area) = 78.53982

$psh2 ((5.4d)) = L_{stir2} * A_{stir2} / (A_{sec} * s2) = 0.00067082$

$L_{stir2}$  (Length of stirrups along Y) = 1468.00

$A_{stir2}$  (stirrups area) = 50.26548

$psh_y * F_{ywe} = psh1 * F_{ywe1} + ps2 * F_{ywe2} = 3.3968$

$psh1 ((5.4d), TBDY) = L_{stir1} * A_{stir1} / (A_{sec} * s1) = 0.00367709$

$L_{stir1}$  (Length of stirrups along X) = 2060.00

$A_{stir1}$  (stirrups area) = 78.53982

$psh2 ((5.4d), TBDY) = L_{stir2} * A_{stir2} / (A_{sec} * s2) = 0.00067082$

$L_{stir2}$  (Length of stirrups along X) = 1468.00

$A_{stir2}$  (stirrups area) = 50.26548

$A_{sec} = 440000.00$

$s1 = 100.00$

$s2 = 250.00$

$f_{ywe1} = 781.25$

$f_{ywe2} = 781.25$

$f_{ce} = 30.00$

From ((5.A5), TBDY), TBDY:  $cc = 0.00471045$

$c = \text{confinement factor} = 1.27105$

$y1 = 0.00083886$

$sh1 = 0.00268436$

$ft1 = 314.5735$

$fy1 = 262.1446$

$su1 = 0.00268436$

using (30) in Biskinis/Fardis (2013) multiplied with shear\_factor  
and also multiplied by the shear\_factor according to 15.7.1.4, with  
 $\text{Shear\_factor} = 1.00$

$l_o/l_{ou,min} = l_b/l_d = 0.13907892$

$su1 = 0.4 * esu1_{nominal} ((5.5), TBDY) = 0.032$

From table 5A.1, TBDY:  $esu1_{nominal} = 0.08$ ,

For calculation of  $esu1_{nominal}$  and  $y1, sh1, ft1, fy1$ , it is considered  
characteristic value  $fsy1 = fs1/1.2$ , from table 5.1, TBDY.

$y1, sh1, ft1, fy1$ , are also multiplied by  $\text{Min}(1, 1.25 * (l_b/l_d)^{2/3})$ , from 10.3.5, ASCE 41-17.

with  $fs1 = (f_{s,jacket} * A_{s,ten,jacket} + f_{s,core} * A_{s,ten,core}) / A_{s,ten} = 262.1446$

with  $Es1 = (E_{s,jacket} * A_{s,ten,jacket} + E_{s,core} * A_{s,ten,core}) / A_{s,ten} = 200000.00$

$y2 = 0.00083886$

$sh2 = 0.00268436$

$ft2 = 314.5735$

$fy2 = 262.1446$



```

su2 = 0.00268436
using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00
lo/lou,min = lb/lb,min = 0.13907892
su2 = 0.4*esu2_nominal ((5.5), TBDY) = 0.032
From table 5A.1, TBDY: esu2_nominal = 0.08,
For calculation of esu2_nominal and y2, sh2,ft2,fy2, it is considered
characteristic value fsy2 = fs2/1.2, from table 5.1, TBDY.
y1, sh1,ft1,fy1, are also multiplied by Min(1,1.25*(lb/lb)^ 2/3), from 10.3.5, ASCE 41-17.
with fs2 = (fs,jacket*Asl,com,jacket + fs,core*Asl,com,core)/Asl,com = 262.1446
with Es2 = (Es,jacket*Asl,com,jacket + Es,core*Asl,com,core)/Asl,com = 200000.00
yv = 0.00083886
shv = 0.00268436
ftv = 314.5735
fyv = 262.1446
suv = 0.00268436
using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00
lo/lou,min = lb/lb = 0.13907892
suv = 0.4*esuv_nominal ((5.5), TBDY) = 0.032
From table 5A.1, TBDY: esuv_nominal = 0.08,
considering characteristic value fsyv = fsv/1.2, from table 5.1, TBDY
For calculation of esuv_nominal and yv, shv,ftv,fyv, it is considered
characteristic value fsyv = fsv/1.2, from table 5.1, TBDY.
y1, sh1,ft1,fy1, are also multiplied by Min(1,1.25*(lb/lb)^ 2/3), from 10.3.5, ASCE 41-17.
with fsv = (fs,jacket*Asl,mid,jacket + fs,mid*Asl,mid,core)/Asl,mid = 262.1446
with Esv = (Es,jacket*Asl,mid,jacket + Es,mid*Asl,mid,core)/Asl,mid = 200000.00
1 = Asl,ten/(b*d)*(fs1/fc) = 0.06824101
2 = Asl,com/(b*d)*(fs2/fc) = 0.03513975
v = Asl,mid/(b*d)*(fsv/fc) = 0.06202846
and confined core properties:
b = 340.00
d = 677.00
d' = 13.00
fcc (5A.2, TBDY) = 38.13135
cc (5A.5, TBDY) = 0.00471045
c = confinement factor = 1.27105
1 = Asl,ten/(b*d)*(fs1/fc) = 0.08384116
2 = Asl,com/(b*d)*(fs2/fc) = 0.04317283
v = Asl,mid/(b*d)*(fsv/fc) = 0.07620839
Case/Assumption: Unconfined full section - Steel rupture
' satisfies Eq. (4.3)
---->
v < vs,y2 - LHS eq.(4.5) is satisfied
---->
su (4.9) = 0.2584548
Mu = MRc (4.14) = 5.0296E+008
u = su (4.1) = 5.1201636E-006
-----

Calculation of ratio lb/lb
-----
Lap Length: lb/lb = 0.13907892
lb = 300.00
lb = 2157.049
Calculation of lb,min according to (25.4.3.2), ACI 318-14, using mean values for all the section re-bars.
lb,min from (25.4.3.2) is multiplied 2 times to account for smooth re-bars (9.1.2, TS500 - No provision in ACI 318)
= 1
db = 16.66667
Mean strength value of all re-bars: fy = 781.25
Mean concrete strength: fc' = (fc'_jacket*Area_jacket + fc'_core*Area_core)/Area_section = 30.00, but fc'^0.5 <= 8.3
MPa (22.5.3.1, ACI 318-14)
t = 1.00
s = 0.80
e = 1.00

```

$$cb = 25.00$$

$$K_{tr} = 1.7174$$

$$A_{tr} = \text{Min}(A_{tr\_x}, A_{tr\_y}) = 257.6106$$

where  $A_{tr\_x}$ ,  $A_{tr\_y}$  are the sum of the area of all stirrup legs along X and Y local axis

$$s = \text{Max}(s_{\text{external}}, s_{\text{internal}}) = 250.00$$

$$n = 24.00$$

$$\text{Calculation of Shear Strength } V_r = \text{Min}(V_{r1}, V_{r2}) = 1.0392\text{E}+006$$

$$\text{Calculation of Shear Strength at edge 1, } V_{r1} = 1.0392\text{E}+006$$

$$V_{r1} = V_{\text{Col}} \text{ ((10.3), ASCE 41-17)} = k_{nl} * V_{\text{Col0}}$$

$$V_{\text{Col0}} = 1.0392\text{E}+006$$

$$k_{nl} = 1 \text{ (zero step-static loading)}$$

NOTE: In expression (10-3) ' $V_s = A_v * f_y * d / s$ ' is replaced by ' $V_s + f * V_f$ ' where  $V_f$  is the contribution of FRPs (11.3), ACI 440).

$$= 1 \text{ (normal-weight concrete)}$$

$$\text{Mean concrete strength: } f'_c = (f'_{c\_jacket} * \text{Area}_{jacket} + f'_{c\_core} * \text{Area}_{core}) / \text{Area}_{\text{section}} = 30.00, \text{ but } f'_c^{0.5} \leq 8.3 \text{ MPa (22.5.3.1, ACI 318-14)}$$

$$M/Vd = 4.00$$

$$\mu_u = 1308.675$$

$$V_u = 0.0001715$$

$$d = 0.8 * h = 600.00$$

$$N_u = 16273.608$$

$$A_g = 300000.00$$

$$\text{From (11.5.4.8), ACI 318-14: } V_s = V_{s,jacket} + V_{s,core} = 1.0138\text{E}+006$$

where:

$$V_{s,jacket} = V_{s,j1} + V_{s,j2} = 903207.888$$

$V_{s,j1} = 314159.265$  is calculated for section web jacket, with:

$$d = 320.00$$

$$A_v = 157079.633$$

$$f_y = 625.00$$

$$s = 100.00$$

$$V_{s,j1} \text{ is multiplied by } Col_{j1} = 1.00$$

$$s/d = 0.3125$$

$V_{s,j2} = 589048.623$  is calculated for section flange jacket, with:

$$d = 600.00$$

$$A_v = 157079.633$$

$$f_y = 625.00$$

$$s = 100.00$$

$$V_{s,j2} \text{ is multiplied by } Col_{j2} = 1.00$$

$$s/d = 0.16666667$$

$$V_{s,core} = V_{s,c1} + V_{s,c2} = 110584.061$$

$V_{s,c1} = 0.00$  is calculated for section web core, with:

$$d = 160.00$$

$$A_v = 100530.965$$

$$f_y = 625.00$$

$$s = 250.00$$

$$V_{s,c1} \text{ is multiplied by } Col_{c1} = 0.00$$

$$s/d = 1.5625$$

$V_{s,c2} = 110584.061$  is calculated for section flange core, with:

$$d = 440.00$$

$$A_v = 100530.965$$

$$f_y = 625.00$$

$$s = 250.00$$

$$V_{s,c2} \text{ is multiplied by } Col_{c2} = 1.00$$

$$s/d = 0.56818182$$

$$V_f \text{ ((11-3)-(11.4), ACI 440)} = 0.00$$

$$\text{From (11-11), ACI 440: } V_s + V_f \leq 873250.061$$

$$bw = 400.00$$

$$\text{Calculation of Shear Strength at edge 2, } V_{r2} = 1.0392\text{E}+006$$

Vr2 = VCol ((10.3), ASCE 41-17) = knl\*VCol0

VCol0 = 1.0392E+006

knl = 1 (zero step-static loading)

NOTE: In expression (10-3) ' $V_s = A_v \cdot f_y \cdot d / s$ ' is replaced by ' $V_s + f \cdot V_f$ '  
where  $V_f$  is the contribution of FRPs (11.3), ACI 440).

= 1 (normal-weight concrete)

Mean concrete strength:  $f_c' = (f_c'_{\text{jacket}} \cdot \text{Area}_{\text{jacket}} + f_c'_{\text{core}} \cdot \text{Area}_{\text{core}}) / \text{Area}_{\text{section}} = 30.00$ , but  $f_c'^{0.5} \leq 8.3$  MPa (22.5.3.1, ACI 318-14)

$M/Vd = 4.00$

$\mu_u = 1308.675$

$V_u = 0.0001715$

$d = 0.8 \cdot h = 600.00$

$N_u = 16273.608$

$A_g = 300000.00$

From (11.5.4.8), ACI 318-14:  $V_s = V_{s,\text{jacket}} + V_{s,\text{core}} = 1.0138\text{E}+006$

where:

$V_{s,\text{jacket}} = V_{s,j1} + V_{s,j2} = 903207.888$

$V_{s,j1} = 314159.265$  is calculated for section web jacket, with:

$d = 320.00$

$A_v = 157079.633$

$f_y = 625.00$

$s = 100.00$

$V_{s,j1}$  is multiplied by  $\text{Col},j1 = 1.00$

$s/d = 0.3125$

$V_{s,j2} = 589048.623$  is calculated for section flange jacket, with:

$d = 600.00$

$A_v = 157079.633$

$f_y = 625.00$

$s = 100.00$

$V_{s,j2}$  is multiplied by  $\text{Col},j2 = 1.00$

$s/d = 0.16666667$

$V_{s,\text{core}} = V_{s,c1} + V_{s,c2} = 110584.061$

$V_{s,c1} = 0.00$  is calculated for section web core, with:

$d = 160.00$

$A_v = 100530.965$

$f_y = 625.00$

$s = 250.00$

$V_{s,c1}$  is multiplied by  $\text{Col},c1 = 0.00$

$s/d = 1.5625$

$V_{s,c2} = 110584.061$  is calculated for section flange core, with:

$d = 440.00$

$A_v = 100530.965$

$f_y = 625.00$

$s = 250.00$

$V_{s,c2}$  is multiplied by  $\text{Col},c2 = 1.00$

$s/d = 0.56818182$

$V_f$  ((11-3)-(11.4), ACI 440) = 0.00

From (11-11), ACI 440:  $V_s + V_f \leq 873250.061$

$b_w = 400.00$

End Of Calculation of Shear Capacity ratio for element: column JLC1 of floor 1  
At local axis: 2

Start Of Calculation of Chord Rotation Capacity for element: column JLC1 of floor 1  
At local axis: 2  
Integration Section: (b)  
Section Type: rcjlcs

Constant Properties

Knowledge Factor, = 1.00

Chord Rotation is generally considered as Deformation-Controlled Action according to Table C7-1, ASCE 41-17.  
Mean strengths are used for Deformation-Controlled Actions according to 7.5.1.3, ASCE 41-17  
Consequently:  
Jacket  
New material of Primary Member: Concrete Strength,  $f_c = f_{cm} = 30.00$   
New material of Primary Member: Steel Strength,  $f_s = f_{sm} = 625.00$   
Concrete Elasticity,  $E_c = 25742.96$   
Steel Elasticity,  $E_s = 200000.00$   
Existing Column  
New material of Primary Member: Concrete Strength,  $f_c = f_{cm} = 30.00$   
New material of Primary Member: Steel Strength,  $f_s = f_{sm} = 625.00$   
Concrete Elasticity,  $E_c = 25742.96$   
Steel Elasticity,  $E_s = 200000.00$   
Max Height,  $H_{max} = 750.00$   
Min Height,  $H_{min} = 400.00$   
Max Width,  $W_{max} = 750.00$   
Min Width,  $W_{min} = 400.00$   
Jacket Thickness,  $t_j = 100.00$   
Cover Thickness,  $c = 25.00$   
Element Length,  $L = 3000.00$   
Primary Member  
Smooth Bars  
Ductile Steel  
With Detailing for Earthquake Resistance (including stirrups closed at  $135^\circ$ )  
Longitudinal Bars With Ends Lapped Starting at the End Sections  
Lap Length  $l_b = 300.00$   
No FRP Wrapping

#### Stepwise Properties

Bending Moment,  $M = -178152.624$   
Shear Force,  $V_2 = 7609.421$   
Shear Force,  $V_3 = -213.4386$   
Axial Force,  $F = -17779.344$   
Longitudinal Reinforcement Area Distribution (in 2 divisions)  
-Tension:  $As_t = 0.00$   
-Compression:  $As_c = 5353.274$   
Longitudinal Reinforcement Area Distribution (in 3 divisions)  
-Tension:  $As_{t,ten} = 1137.257$   
-Compression:  $As_{l,com} = 2208.54$   
-Middle:  $As_{l,mid} = 2007.478$   
Longitudinal External Reinforcement Area Distribution (in 3 divisions)  
-Tension:  $As_{l,ten,jacket} = 829.3805$   
-Compression:  $As_{l,com,jacket} = 1746.726$   
-Middle:  $As_{l,mid,jacket} = 1545.664$   
Longitudinal Internal Reinforcement Area Distribution (in 3 divisions)  
-Tension:  $As_{l,ten,core} = 307.8761$   
-Compression:  $As_{l,com,core} = 461.8141$   
-Middle:  $As_{l,mid,core} = 461.8141$   
Mean Diameter of Tension Reinforcement,  $Db_L = 16.80$

New component: From table 7-7, ASCE 41\_17: Final chord rotation Capacity  $u_R = 1.0^*$   $u = 0.03952104$   
 $u = y + p = 0.03952104$

- Calculation of  $y$  -

$y = (M_y * L_s / 3) / E_{eff} = 0.00054862$  ((4.29), Biskinis Phd))  
 $M_y = 2.8709E+008$   
 $L_s = M/V$  (with  $L_s > 0.1 * L$  and  $L_s < 2 * L$ ) =  $834.6784$   
From table 10.5, ASCE 41\_17:  $E_{eff} = factor * E_c * I_g = 1.4560E+014$   
factor = 0.30  
 $A_g = 440000.00$

Mean concrete strength:  $fc' = (fc'_{jacket} \cdot Area_{jacket} + fc'_{core} \cdot Area_{core}) / Area_{section} = 30.00$

$N = 17779.344$

$Ec \cdot I_g = Ec_{jacket} \cdot I_{g,jacket} + Ec_{core} \cdot I_{g,core} = 4.8532E+014$

#### Calculation of Yielding Moment $M_y$

Calculation of  $y$  and  $M_y$  according to Annex 7 -

Assuming neutral axis within flange ( $y < t/d$ , compression zone rectangular) with:

flange width,  $b = 750.00$

web width,  $b_w = 400.00$

flange thickness,  $t = 400.00$

$y = \text{Min}(y_{ten}, y_{com})$

$y_{ten} = 2.1455196E-006$

with  $((10.1), \text{ASCE 41-17}) f_y = \text{Min}(f_y, 1.25 \cdot f_y \cdot (I_b/I_d)^{2/3}) = 243.3535$

$d = 707.00$

$y = 0.19784983$

$A = 0.01023354$

$B = 0.00454395$

with  $pt = 0.00434791$

$pc = 0.00416509$

$pv = 0.00378591$

$N = 17779.344$

$b = 750.00$

$" = 0.06082037$

$y_{comp} = 1.5202265E-005$

with  $fc = 30.00$

$Ec = 25742.96$

$y = 0.19516753$

$A = 0.01001583$

$B = 0.00440616$

with  $Es = 200000.00$

CONFIRMATION:  $y = 0.19594836 < t/d$

#### Calculation of ratio $I_b/I_d$

Lap Length:  $I_d/I_{d,min} = 0.17384865$

$I_b = 300.00$

$I_d = 1725.639$

Calculation of  $I$  according to (25.4.3.2), ACI 318-14, using mean values for all the section re-bars.

$I_{d,min}$  from (25.4.3.2) is multiplied 2 times to account for smooth re-bars (10.3.5, ASCE 41-17)

$= 1$

$db = 16.66667$

Mean strength value of all re-bars:  $f_y = 625.00$

Mean concrete strength:  $fc' = (fc'_{jacket} \cdot Area_{jacket} + fc'_{core} \cdot Area_{core}) / Area_{section} = 30.00$ , but  $fc'^{0.5} \leq 8.3$  MPa (22.5.3.1, ACI 318-14)

$t = 1.00$

$s = 0.80$

$e = 1.00$

$cb = 25.00$

$K_{tr} = 1.7174$

$A_{tr} = \text{Min}(A_{tr_x}, A_{tr_y}) = 257.6106$

where  $A_{tr_x}$ ,  $A_{tr_y}$  are the sum of the area of all stirrup legs along X and Y local axis

$s = \text{Max}(s_{external}, s_{internal}) = 250.00$

$n = 24.00$

#### - Calculation of $p$ -

From table 10-8:  $p = 0.03897242$

with:



- Columns controlled by inadequate development or splicing along the clear height because  $I_b/I_d < 1$

shear control ratio  $V_y E / V_{col} I_{OE} = 0.32266369$   
 $d = d_{external} = 707.00$   
 $s = s_{external} = 0.00$   
 $t = s_1 + s_2 + 2 * t_f / b_w * (f_{fe} / f_s) = 0.00434791$   
 jacket:  $s_1 = A_{v1} * L_{stir1} / (s_1 * A_g) = 0.00367709$   
 $A_{v1} = 78.53982$ , is the area of every stirrup parallel to loading (shear) direction  
 $L_{stir1} = 2060.00$ , is the total Length of all stirrups parallel to loading (shear) direction  
 $s_1 = 100.00$   
 core:  $s_2 = A_{v2} * L_{stir2} / (s_2 * A_g) = 0.00067082$   
 $A_{v2} = 50.26548$ , is the area of every stirrup parallel to loading (shear) direction  
 $L_{stir2} = 1468.00$ , is the total Length of all stirrups parallel to loading (shear) direction  
 $s_2 = 250.00$   
 The term  $2 * t_f / b_w * (f_{fe} / f_s)$  is implemented to account for FRP contribution  
 where  $f = 2 * t_f / b_w$  is FRP ratio (EC8 - 3, A.4.4.3(6)) and  $f_{fe} / f_s$  normalises  $f$  to steel strength  
 All these variables have already been given in Shear control ratio calculation.  
 For the normalisation  $f_s$  of jacket is used.  
 $NUD = 17779.344$   
 $A_g = 440000.00$   
 $f_{cE} = (f_{c,jacket} * Area_{jacket} + f_{c,core} * Area_{core}) / section\_area = 30.00$   
 $f_{yE} = (f_{y,ext\_Long\_Reinf} * Area_{ext\_Long\_Reinf} + f_{y,int\_Long\_Reinf} * Area_{int\_Long\_Reinf}) / Area_{Tot\_Long\_Rein} = 625.00$   
 $f_{yE} = (f_{y,ext\_Trans\_Reinf} * s_1 + f_{y,int\_Trans\_Reinf} * s_2) / (s_1 + s_2) = 625.00$   
 $\rho_l = Area_{Tot\_Long\_Rein} / (b * d) = 0.01009575$   
 $b = 750.00$   
 $d = 707.00$   
 $f_{cE} = 30.00$

-----  
 End Of Calculation of Chord Rotation Capacity for element: column JLC1 of floor 1  
 At local axis: 2  
 Integration Section: (b)  
 -----

## Calculation No. 15

column C1, Floor 1  
 Limit State: Collapse Prevention (data interpolation between analysis steps 1 and 2)  
 Analysis: Uniform +X  
 Check: Shear capacity  $V_{Rd}$   
 Edge: End  
 Local Axis: (3)



Start Of Calculation of Shear Capacity for element: column JLC1 of floor 1

At local axis: 3

Integration Section: (b)

Section Type: rcjlcs

Constant Properties

Knowledge Factor,  $\gamma = 1.00$

Member Shear Force is generally considered as Force-Controlled Action according to Table C7-1, ASCE 41-17.

Lower-bound strengths are used for Force-Controlled Actions according to 7.5.1.3, ASCE 41-17

Consequently:

Jacket

New material of Primary Member: Concrete Strength,  $f_c = f_{c\_lower\_bound} = 20.00$

New material of Primary Member: Steel Strength,  $f_s = f_{s\_lower\_bound} = 500.00$

Concrete Elasticity,  $E_c = 25742.96$

Steel Elasticity,  $E_s = 200000.00$

Existing Column

New material of Primary Member: Concrete Strength,  $f_c = f_{c\_lower\_bound} = 20.00$

New material of Primary Member: Steel Strength,  $f_s = f_{s\_lower\_bound} = 500.00$

Concrete Elasticity,  $E_c = 25742.96$

Steel Elasticity,  $E_s = 200000.00$

#####

Note: Especially for the calculation of  $\gamma$  for displacement ductility demand, the expected (mean value) strengths are used (7.5.1.3, ASCE 41-17) because bending is considered as Deformation-Controlled Action (Table C7-1, ASCE 41-17).

Jacket

New material: Concrete Strength,  $f_c = f_{cm} = 30.00$

New material: Steel Strength,  $f_s = f_{sm} = 625.00$

Existing Column

New material: Concrete Strength,  $f_c = f_{cm} = 30.00$

New material: Steel Strength,  $f_s = f_{sm} = 625.00$

#####

Max Height,  $H_{max} = 750.00$

Min Height,  $H_{min} = 400.00$

Max Width,  $W_{max} = 750.00$

Min Width,  $W_{min} = 400.00$

Jacket Thickness,  $t_j = 100.00$

Cover Thickness,  $c = 25.00$

Element Length,  $L = 3000.00$

Primary Member

Smooth Bars

Ductile Steel

With Detailing for Earthquake Resistance (including stirrups closed at 135°)

Longitudinal Bars With Ends Lapped Starting at the End Sections

Lap Length  $l_o = l_b = 300.00$

No FRP Wrapping

Stepwise Properties

EDGE -A-

Bending Moment,  $M_a = -459842.936$

Shear Force,  $V_a = 213.4386$   
 EDGE -B-  
 Bending Moment,  $M_b = -178152.624$   
 Shear Force,  $V_b = -213.4386$   
 BOTH EDGES  
 Axial Force,  $F = -17779.344$   
 Longitudinal Reinforcement Area Distribution (in 2 divisions)  
   -Tension:  $A_{st} = 0.00$   
   -Compression:  $A_{sc} = 5353.274$   
 Longitudinal Reinforcement Area Distribution (in 3 divisions)  
   -Tension:  $A_{st,ten} = 1137.257$   
   -Compression:  $A_{sc,com} = 2208.54$   
   -Middle:  $A_{sc,mid} = 2007.478$   
 Mean Diameter of Tension Reinforcement,  $D_{bL,ten} = 16.80$

New component: From table 7-7, ASCE 41\_17: Final Shear Capacity  $V_R = 1.0 \cdot V_n = 984866.462$   
 $V_n ((10.3), ASCE 41-17) = k_n \cdot V_{CoIO} = 984866.462$   
 $V_{CoI} = 984866.462$   
 $k_n = 1.00$   
 $displacement\_ductility\_demand = 1.3707411E-005$

NOTE: In expression (10-3) ' $V_s = A_v \cdot f_y \cdot d / s$ ' is replaced by ' $V_s + f \cdot V_f$ '  
 where  $V_f$  is the contribution of FRPs (11.3), ACI 440).

$= 1$  (normal-weight concrete)  
 Mean concrete strength:  $f'_c = (f'_c\_jacket \cdot Area\_jacket + f'_c\_core \cdot Area\_core) / Area\_section = 20.00$ , but  $f'_c^{0.5} \leq 8.3$   
 MPa (22.5.3.1, ACI 318-14)  
 $M/Vd = 2.00$   
 $M_u = 178152.624$   
 $V_u = 213.4386$   
 $d = 0.8 \cdot h = 600.00$   
 $N_u = 17779.344$   
 $A_g = 300000.00$   
 From (11.5.4.8), ACI 318-14:  $V_s = V_{s,jacket} + V_{s,core} = 811033.559$   
 where:  
 $V_{s,jacket} = V_{s,j1} + V_{s,j2} = 722566.31$   
 $V_{s,j1} = 471238.898$  is calculated for section web jacket, with:  
 $d = 600.00$   
 $A_v = 157079.633$   
 $f_y = 500.00$   
 $s = 100.00$   
 $V_{s,j1}$  is multiplied by  $Col,j1 = 1.00$   
 $s/d = 0.16666667$   
 $V_{s,j2} = 251327.412$  is calculated for section flange jacket, with:  
 $d = 320.00$   
 $A_v = 157079.633$   
 $f_y = 500.00$   
 $s = 100.00$   
 $V_{s,j2}$  is multiplied by  $Col,j2 = 1.00$   
 $s/d = 0.3125$   
 $V_{s,core} = V_{s,c1} + V_{s,c2} = 88467.249$   
 $V_{s,c1} = 88467.249$  is calculated for section web core, with:  
 $d = 440.00$   
 $A_v = 100530.965$   
 $f_y = 500.00$   
 $s = 250.00$   
 $V_{s,c1}$  is multiplied by  $Col,c1 = 1.00$   
 $s/d = 0.56818182$   
 $V_{s,c2} = 0.00$  is calculated for section flange core, with:  
 $d = 160.00$   
 $A_v = 100530.965$   
 $f_y = 500.00$   
 $s = 250.00$   
 $V_{s,c2}$  is multiplied by  $Col,c2 = 0.00$



$s/d = 1.5625$   
 $V_f((11-3)-(11.4), ACI\ 440) = 0.00$   
 From  $(11-11)$ , ACI 440:  $V_s + V_f \leq 713005.69$   
 $bw = 400.00$

displacement ductility demand is calculated as  $\delta / y$

- Calculation of  $\delta / y$  for END B -  
 for rotation axis 2 and integ. section (b)

From analysis, chord rotation  $\theta = 7.5201070E-009$   
 $y = (M_y * L_s / 3) / E_{eff} = 0.00054862 ((4.29), Biskinis\ Phd)$   
 $M_y = 2.8709E+008$   
 $L_s = M/V$  (with  $L_s > 0.1 * L$  and  $L_s < 2 * L$ ) = 834.6784  
 From table 10.5, ASCE 41-17:  $E_{eff} = factor * E_c * I_g = 1.4560E+014$   
 $factor = 0.30$   
 $A_g = 440000.00$   
 Mean concrete strength:  $f'_c = (f'_{c\_jacket} * Area_{jacket} + f'_{c\_core} * Area_{core}) / Area_{section} = 30.00$   
 $N = 17779.344$   
 $E_c * I_g = E_{c\_jacket} * I_{g\_jacket} + E_{c\_core} * I_{g\_core} = 4.8532E+014$

Calculation of Yielding Moment  $M_y$

Calculation of  $\delta / y$  and  $M_y$  according to Annex 7 -

Assuming neutral axis within flange ( $y < t/d$ , compression zone rectangular) with:  
 flange width,  $b = 750.00$   
 web width,  $bw = 400.00$   
 flange thickness,  $t = 400.00$

$y = \text{Min}(y_{ten}, y_{com})$   
 $y_{ten} = 2.1455196E-006$   
 with  $((10.1), ASCE\ 41-17)$   $f_y = \text{Min}(f_y, 1.25 * f_y * (I_b / I_d)^{2/3}) = 243.3535$   
 $d = 707.00$   
 $y = 0.19784983$   
 $A = 0.01023354$   
 $B = 0.00454395$   
 with  $pt = 0.00214476$   
 $pc = 0.00416509$   
 $pv = 0.00378591$   
 $N = 17779.344$   
 $b = 750.00$   
 $" = 0.06082037$   
 $y_{comp} = 1.5202265E-005$   
 with  $f_c = 30.00$   
 $E_c = 25742.96$   
 $y = 0.19516753$   
 $A = 0.01001583$   
 $B = 0.00440616$   
 with  $E_s = 200000.00$   
 CONFIRMATION:  $y = 0.19594836 < t/d$

Calculation of ratio  $I_b / I_d$


Lap Length:  $I_d / I_{d,min} = 0.17384865$   
 $I_b = 300.00$   
 $I_d = 1725.639$   
 Calculation of  $I$  according to (25.4.3.2), ACI 318-14, using mean values for all the section re-bars.  
 $I_{d,min}$  from (25.4.3.2) is multiplied 2 times to account for smooth re-bars (10.3.5, ASCE 41-17)  
 $= 1$   
 $db = 16.66667$

Mean strength value of all re-bars:  $f_y = 625.00$   
Mean concrete strength:  $f_c' = (f_c'_{\text{jacket}} \cdot \text{Area}_{\text{jacket}} + f_c'_{\text{core}} \cdot \text{Area}_{\text{core}}) / \text{Area}_{\text{section}} = 30.00$ , but  $f_c'^{0.5} \leq 8.3$  MPa (22.5.3.1, ACI 318-14)  
 $t = 1.00$   
 $s = 0.80$   
 $e = 1.00$   
 $cb = 25.00$   
 $K_{tr} = 1.7174$   
 $A_{tr} = \text{Min}(A_{tr_x}, A_{tr_y}) = 257.6106$   
where  $A_{tr_x}$ ,  $A_{tr_y}$  are the sum of the area of all stirrup legs along X and Y local axis  
 $s = \text{Max}(s_{\text{external}}, s_{\text{internal}}) = 250.00$   
 $n = 24.00$

End Of Calculation of Shear Capacity for element: column JLC1 of floor 1  
At local axis: 3  
Integration Section: (b)

## Calculation No. 16

column C1, Floor 1  
Limit State: Collapse Prevention (data interpolation between analysis steps 1 and 2)  
Analysis: Uniform +X  
Check: Chord rotation capacity (  $\mu$  )  
Edge: End  
Local Axis: (3)



Start Of Calculation of Shear Capacity ratio for element: column JLC1 of floor 1  
At Shear local axis: 3  
(Bending local axis: 2)  
Section Type: rcjlc

Constant Properties

Knowledge Factor,  $= 1.00$   
Mean strength values are used for both shear and moment calculations.  
Consequently:  
Jacket

New material of Primary Member: Concrete Strength,  $f_c = f_{cm} = 30.00$   
 New material of Primary Member: Steel Strength,  $f_s = f_{sm} = 625.00$   
 Concrete Elasticity,  $E_c = 25742.96$   
 Steel Elasticity,  $E_s = 200000.00$   
 Existing Column  
 New material of Primary Member: Concrete Strength,  $f_c = f_{cm} = 30.00$   
 New material of Primary Member: Steel Strength,  $f_s = f_{sm} = 625.00$   
 Concrete Elasticity,  $E_c = 25742.96$   
 Steel Elasticity,  $E_s = 200000.00$   
 #####  
 Note: Especially for the calculation of moment strengths,  
 the above steel re-bar strengths are multiplied by 1.25 according to R18.6.5, ACI 318-14  
 Jacket  
 New material: Steel Strength,  $f_s = 1.25 \cdot f_{sm} = 781.25$   
 Existing Column  
 New material: Steel Strength,  $f_s = 1.25 \cdot f_{sm} = 781.25$   
 #####  
 Max Height,  $H_{max} = 750.00$   
 Min Height,  $H_{min} = 400.00$   
 Max Width,  $W_{max} = 750.00$   
 Min Width,  $W_{min} = 400.00$   
 Jacket Thickness,  $t_j = 100.00$   
 Cover Thickness,  $c = 25.00$   
 Mean Confinement Factor overall section = 1.27105  
 Element Length,  $L = 3000.00$   
 Primary Member  
 Smooth Bars  
 Ductile Steel  
 With Detailing for Earthquake Resistance (including stirrups closed at 135°)  
 Longitudinal Bars With Ends Lapped Starting at the End Sections  
 Lap Length  $l_o = 300.00$   
 No FRP Wrapping

#### Stepwise Properties

At local axis: 3  
 EDGE -A-  
 Shear Force,  $V_a = -0.00017144$   
 EDGE -B-  
 Shear Force,  $V_b = 0.00017144$   
 BOTH EDGES  
 Axial Force,  $F = -16273.608$   
 Longitudinal Reinforcement Area Distribution (in 2 divisions)  
 -Tension:  $A_{sl,t} = 0.00$   
 -Compression:  $A_{sl,c} = 5353.274$   
 Longitudinal Reinforcement Area Distribution (in 3 divisions)  
 -Tension:  $A_{sl,ten} = 1137.257$   
 -Compression:  $A_{sl,com} = 2208.54$   
 -Middle:  $A_{sl,mid} = 2007.478$

Calculation of Shear Capacity ratio,  $V_e/V_r = 0.32266369$   
 Member Controlled by Flexure ( $V_e/V_r < 1$ )  
 Calculation of Shear Demand from fig. R18.6.5, ACI 318-14  $V_e = (M_{pr1} + M_{pr2})/l_n = 335307.657$   
 with  
 $M_{pr1} = \max(\mu_{u1+}, \mu_{u1-}) = 5.0296E+008$   
 $\mu_{u1+} = 2.3387E+008$ , is the ultimate moment strength at the edge 1 of the member in the actual moment direction  
 which is defined for the static loading combination  
 $\mu_{u1-} = 5.0296E+008$ , is the ultimate moment strength at the edge 1 of the member in the opposite moment  
 direction which is defined for the static loading combination  
 $M_{pr2} = \max(\mu_{u2+}, \mu_{u2-}) = 5.0296E+008$   
 $\mu_{u2+} = 2.3387E+008$ , is the ultimate moment strength at the edge 2 of the member in the actual moment direction  
 which is defined for the static loading combination  
 $\mu_{u2-} = 5.0296E+008$ , is the ultimate moment strength at the edge 2 of the member in the opposite moment

direction which is defined for the the static loading combination

Calculation of  $\mu_{1+}$

Calculation of ultimate curvature  $\mu$  according to 4.1, Biskinis/Fardis 2013:

$$\mu = 4.8099118E-006$$

$$\mu_u = 2.3387E+008$$

with full section properties:

$$b = 750.00$$

$$d = 707.00$$

$$d' = 43.00$$

$$v = 0.00102301$$

$$N = 16273.608$$

$$f_c = 30.00$$

$$\alpha (5A.5, TBDY) = 0.002$$

$$\text{Final value of } \mu_u: \mu_u = \text{shear\_factor} * \text{Max}(\mu_u, \alpha) = 0.01260361$$

The Shear\_factor is considered equal to 1 (pure moment strength)

$$\text{From (5.4b), TBDY: } \mu_u = 0.01260361$$

$$\mu_{ue} (5.4c) = 0.05179731$$

$$\mu_{ase} ((5.4d), TBDY) = (\mu_{ase1} * A_{ext} + \mu_{ase2} * A_{int}) / A_{sec} = 0.45746528$$

$$\mu_{ase1} = \text{Max}(((A_{conf,max1} - A_{noConf1}) / A_{conf,max1}) * (A_{conf,min1} / A_{conf,max1}), 0) = 0.45746528$$

The definitions of  $A_{noConf}$ ,  $A_{conf,min}$  and  $A_{conf,max}$  are derived from generalization of the rectangular sections confinement, which is expressed by (5.4d).

The generalization is done according to Mander, J., Priestley, M., and Park, R. (1988)

"Theoretical Stress-Strain Model for Confined Concrete."

J. Struct. Eng., 10.1061/(ASCE)0733-9445(1988)114:8(1804), 1804-1826.

$A_{conf,max1} = 353600.00$  is the confined core area at levels of member with hoops and is calculated as the area of core enclosed by the center lines of the external perimeter hoops.

$A_{conf,min1} = 293525.00$  is the confined core area at midway between the levels of hoops and is calculated by reducing all the dimensions of the area  $A_{conf,max1}$  by a length equal to half the clear spacing between external hoops.

$$A_{noConf1} = 158733.333 \text{ is the unconfined external core area which is equal to } b^2/6 \text{ as defined at (A.2).}$$
$$\mu_{ase2} (\geq \mu_{ase1}) = \text{Max}(((A_{conf,max2} - A_{noConf2}) / A_{conf,max2}) * (A_{conf,min2} / A_{conf,max2}), 0) = 0.45746528$$

The definitions of  $A_{noConf}$ ,  $A_{conf,min}$  and  $A_{conf,max}$  are derived from generalization of the rectangular sections confinement, which is expressed by (5.4d).

The generalization is done according to Mander, J., Priestley, M., and Park, R. (1988)

"Theoretical Stress-Strain Model for Confined Concrete."

J. Struct. Eng., 10.1061/(ASCE)0733-9445(1988)114:8(1804), 1804-1826.

$A_{conf,max2} = 171264.00$  is the confined core area at levels of member with hoops and is calculated as the area of core enclosed by the center lines of the internal perimeter hoops.

$A_{conf,min2} = 54741.00$  is the confined core area at midway between the levels of hoops and is calculated by reducing all the dimensions of the area  $A_{conf,max2}$  by a length equal to half the clear spacing between internal hoops.

$$A_{noConf2} = 106242.667 \text{ is the unconfined internal core area which is equal to } b^2/6 \text{ as defined at (A.2).}$$
$$p_{sh,min} * F_{ywe} = \text{Min}(p_{sh,x} * F_{ywe}, p_{sh,y} * F_{ywe}) = 3.3968$$

$$p_{sh,x} * F_{ywe} = p_{sh1} * F_{ywe1} + p_{sh2} * F_{ywe2} = 3.3968$$

$$p_{sh1} ((5.4d), TBDY) = L_{stir1} * A_{stir1} / (A_{sec} * s_1) = 0.00367709$$

$$L_{stir1} \text{ (Length of stirrups along Y)} = 2060.00$$

$$A_{stir1} \text{ (stirrups area)} = 78.53982$$

$$p_{sh2} (5.4d) = L_{stir2} * A_{stir2} / (A_{sec} * s_2) = 0.00067082$$

$$L_{stir2} \text{ (Length of stirrups along Y)} = 1468.00$$

$$A_{stir2} \text{ (stirrups area)} = 50.26548$$

$$p_{sh,y} * F_{ywe} = p_{sh1} * F_{ywe1} + p_{sh2} * F_{ywe2} = 3.3968$$

$$p_{sh1} ((5.4d), TBDY) = L_{stir1} * A_{stir1} / (A_{sec} * s_1) = 0.00367709$$

$$L_{stir1} \text{ (Length of stirrups along X)} = 2060.00$$

$$A_{stir1} \text{ (stirrups area)} = 78.53982$$

$$p_{sh2} ((5.4d), TBDY) = L_{stir2} * A_{stir2} / (A_{sec} * s_2) = 0.00067082$$

$$L_{stir2} \text{ (Length of stirrups along X)} = 1468.00$$

$$A_{stir2} \text{ (stirrups area)} = 50.26548$$

$$A_{sec} = 440000.00$$

```

s1 = 100.00
s2 = 250.00
fywe1 = 781.25
fywe2 = 781.25
fce = 30.00
From ((5A.5), TBDY), TBDY: cc = 0.00471045
c = confinement factor = 1.27105
y1 = 0.00083886
sh1 = 0.00268436
ft1 = 314.5735
fy1 = 262.1446
su1 = 0.00268436
using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00
lo/lou,min = lb/lb = 0.13907892
su1 = 0.4*esu1_nominal ((5.5), TBDY) = 0.032
From table 5A.1, TBDY: esu1_nominal = 0.08,
For calculation of esu1_nominal and y1, sh1,ft1,fy1, it is considered
characteristic value fsy1 = fs1/1.2, from table 5.1, TBDY.
y1, sh1,ft1,fy1, are also multiplied by Min(1,1.25*(lb/lb)^ 2/3), from 10.3.5, ASCE 41-17.
with fs1 = (fs,jacket*Asl,ten,jacket + fs,core*Asl,ten,core)/Asl,ten = 262.1446
with Es1 = (Es,jacket*Asl,ten,jacket + Es,core*Asl,ten,core)/Asl,ten = 200000.00
y2 = 0.00083886
sh2 = 0.00268436
ft2 = 314.5735
fy2 = 262.1446
su2 = 0.00268436
using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00
lo/lou,min = lb/lb,min = 0.13907892
su2 = 0.4*esu2_nominal ((5.5), TBDY) = 0.032
From table 5A.1, TBDY: esu2_nominal = 0.08,
For calculation of esu2_nominal and y2, sh2,ft2,fy2, it is considered
characteristic value fsy2 = fs2/1.2, from table 5.1, TBDY.
y1, sh1,ft1,fy1, are also multiplied by Min(1,1.25*(lb/lb)^ 2/3), from 10.3.5, ASCE 41-17.
with fs2 = (fs,jacket*Asl,com,jacket + fs,core*Asl,com,core)/Asl,com = 262.1446
with Es2 = (Es,jacket*Asl,com,jacket + Es,core*Asl,com,core)/Asl,com = 200000.00
yv = 0.00083886
shv = 0.00268436
ftv = 314.5735
fyv = 262.1446
suv = 0.00268436
using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00
lo/lou,min = lb/lb = 0.13907892
suv = 0.4*esuv_nominal ((5.5), TBDY) = 0.032
From table 5A.1, TBDY: esuv_nominal = 0.08,
considering characteristic value fsyv = fsv/1.2, from table 5.1, TBDY
For calculation of esuv_nominal and yv, shv,ftv,fyv, it is considered
characteristic value fsyv = fsv/1.2, from table 5.1, TBDY.
y1, sh1,ft1,fy1, are also multiplied by Min(1,1.25*(lb/lb)^ 2/3), from 10.3.5, ASCE 41-17.
with fsv = (fs,jacket*Asl,mid,jacket + fs,mid*Asl,mid,core)/Asl,mid = 262.1446
with Esv = (Es,jacket*Asl,mid,jacket + Es,mid*Asl,mid,core)/Asl,mid = 200000.00
1 = Asl,ten/(b*d)*(fs1/fc) = 0.0187412
2 = Asl,com/(b*d)*(fs2/fc) = 0.03639521
v = Asl,mid/(b*d)*(fsv/fc) = 0.03308184
and confined core properties:
b = 690.00
d = 677.00
d' = 13.00
fcc (5A.2, TBDY) = 38.13135
cc (5A.5, TBDY) = 0.00471045
c = confinement factor = 1.27105
1 = Asl,ten/(b*d)*(fs1/fc) = 0.02127357

```

$$2 = A_{sl,com}/(b*d)*(f_s2/f_c) = 0.04131304$$

$$v = A_{sl,mid}/(b*d)*(f_{sv}/f_c) = 0.03755196$$

Case/Assumption: Unconfined full section - Steel rupture

' satisfies Eq. (4.3)

---->

$v < v_{s,y2}$  - LHS eq.(4.5) is satisfied

---->

$$s_u(4.9) = 0.21062322$$

$$M_u = M_{Rc}(4.14) = 2.3387E+008$$

$$u = s_u(4.1) = 4.8099118E-006$$

Calculation of ratio  $l_b/l_d$

Lap Length:  $l_b/l_d = 0.13907892$

$$l_b = 300.00$$

$$l_d = 2157.049$$

Calculation of  $l_b, \min$  according to (25.4.3.2), ACI 318-14, using mean values for all the section re-bars.

$l_d, \min$  from (25.4.3.2) is multiplied 2 times to account for smooth re-bars (9.1.2, TS500 - No provision in ACI 318)

$$= 1$$

$$d_b = 16.66667$$

Mean strength value of all re-bars:  $f_y = 781.25$

Mean concrete strength:  $f'_c = (f'_{c,jacket} \cdot Area_{jacket} + f'_{c,core} \cdot Area_{core}) / Area_{section} = 30.00$ , but  $f_c^{0.5} \leq 8.3$  MPa (22.5.3.1, ACI 318-14)

$$t = 1.00$$

$$s = 0.80$$

$$e = 1.00$$

$$c_b = 25.00$$

$$K_{tr} = 1.7174$$

$$A_{tr} = \min(A_{tr,x}, A_{tr,y}) = 257.6106$$

where  $A_{tr,x}$ ,  $A_{tr,y}$  are the sum of the area of all stirrup legs along X and Y loxal axis

$$s = \max(s_{external}, s_{internal}) = 250.00$$

$$n = 24.00$$

Calculation of  $\mu_1$ -

Calculation of ultimate curvature  $u$  according to 4.1, Biskinis/Fardis 2013:

$$u = 5.1201636E-006$$

$$M_u = 5.0296E+008$$

with full section properties:

$$b = 400.00$$

$$d = 707.00$$

$$d' = 43.00$$

$$v = 0.00191815$$

$$N = 16273.608$$

$$f_c = 30.00$$

$$c_o(5A.5, \text{TB DY}) = 0.002$$

$$\text{Final value of } c_u: c_u^* = \text{shear\_factor} * \max(c_u, c_c) = 0.01260361$$

The Shear\_factor is considered equal to 1 (pure moment strength)

$$\text{From (5.4b), TB DY: } c_u = 0.01260361$$

$$w_e(5.4c) = 0.05179731$$

$$a_{se}((5.4d), \text{TB DY}) = (a_{se1} * A_{ext} + a_{se2} * A_{int}) / A_{sec} = 0.45746528$$

$$a_{se1} = \max(((A_{conf,max1} - A_{noConf1}) / A_{conf,max1}) * (A_{conf,min1} / A_{conf,max1}), 0) = 0.45746528$$

The definitions of  $A_{noConf}$ ,  $A_{conf,min}$  and  $A_{conf,max}$  are derived from generalization of the rectangular sections confinement, which is expressed by (5.4d).

The generalization is done according to Mander, J., Priestley, M., and Park, R. (1988)

"Theoretical Stress-Strain Model for Confined Concrete."

J. Struct. Eng., 10.1061/(ASCE)0733-9445(1988)114:8(1804), 1804-1826.

$A_{conf,max1} = 353600.00$  is the confined core area at levels of member with hoops and

is calculated as the area of core enclosed by the center lines of the external perimeter hoops.

$A_{conf,min1} = 293525.00$  is the confined core area at midway between the levels of hoops and

is calculated by reducing all the dimensions of the area  $A_{conf,max1}$  by a length

equal to half the clear spacing between external hoops.

AnoConf1 = 158733.333 is the unconfined external core area which is equal to  $b_i^2/6$  as defined at (A.2).  
 $ase2 (>=ase1) = \text{Max}(((A_{conf,max2}-AnoConf2)/A_{conf,max2})*(A_{conf,min2}/A_{conf,max2}),0) = 0.45746528$

The definitions of AnoConf, Aconf,min and Aconf,max are derived from generalization of the rectangular sections confinement, which is expressed by (5.4d).

The generalization is done according to Mander, J., Priestley, M., and Park, R. (1988)

"Theoretical Stress-Strain Model for Confined Concrete."

J. Struct. Eng., 10.1061/(ASCE)0733-9445(1988)114:8(1804), 1804-1826.

Aconf,max2 = 171264.00 is the confined core area at levels of member with hoops and

is calculated as the area of core enclosed by the center lines of the internal perimeter hoops.

Aconf,min2 = 54741.00 is the confined core area at midway between the levels of hoops and

is calculated by reducing all the dimensions of the area Aconf,max2 by a length

equal to half the clear spacing between internal hoops.

AnoConf2 = 106242.667 is the unconfined internal core area which is equal to  $b_i^2/6$  as defined at (A.2).

$psh,min*Fywe = \text{Min}(psh,x*Fywe, psh,y*Fywe) = 3.3968$

-----  
 $psh_x*Fywe = psh1*Fywe1 + ps2*Fywe2 = 3.3968$

$psh1 ((5.4d), TBDY) = Lstir1*Astir1/(Asec*s1) = 0.00367709$

Lstir1 (Length of stirrups along Y) = 2060.00

Astir1 (stirrups area) = 78.53982

$psh2 ((5.4d) = Lstir2*Astir2/(Asec*s2) = 0.00067082$

Lstir2 (Length of stirrups along Y) = 1468.00

Astir2 (stirrups area) = 50.26548

-----  
 $psh_y*Fywe = psh1*Fywe1 + ps2*Fywe2 = 3.3968$

$psh1 ((5.4d), TBDY) = Lstir1*Astir1/(Asec*s1) = 0.00367709$

Lstir1 (Length of stirrups along X) = 2060.00

Astir1 (stirrups area) = 78.53982

$psh2 ((5.4d), TBDY) = Lstir2*Astir2/(Asec*s2) = 0.00067082$

Lstir2 (Length of stirrups along X) = 1468.00

Astir2 (stirrups area) = 50.26548

-----  
Asec = 440000.00

s1 = 100.00

s2 = 250.00

fywe1 = 781.25

fywe2 = 781.25

fce = 30.00

From ((5.A5), TBDY), TBDY: cc = 0.00471045

c = confinement factor = 1.27105

y1 = 0.00083886

sh1 = 0.00268436

ft1 = 314.5735

fy1 = 262.1446

su1 = 0.00268436

using (30) in Biskinis/Fardis (2013) multiplied with shear\_factor

and also multiplied by the shear\_factor according to 15.7.1.4, with

Shear\_factor = 1.00

lo/lou,min = lb/ld = 0.13907892

su1 = 0.4\*esu1\_nominal ((5.5), TBDY) = 0.032

From table 5A.1, TBDY: esu1\_nominal = 0.08,

For calculation of esu1\_nominal and y1, sh1,ft1,fy1, it is considered characteristic value fsy1 = fs1/1.2, from table 5.1, TBDY.

y1, sh1,ft1,fy1, are also multiplied by  $\text{Min}(1, 1.25*(lb/ld)^{2/3})$ , from 10.3.5, ASCE 41-17.

with fs1 = (fs,jacket\*Asl,ten,jacket + fs,core\*Asl,ten,core)/Asl,ten = 262.1446

with Es1 = (Es,jacket\*Asl,ten,jacket + Es,core\*Asl,ten,core)/Asl,ten = 200000.00

y2 = 0.00083886

sh2 = 0.00268436

ft2 = 314.5735

fy2 = 262.1446

su2 = 0.00268436

using (30) in Biskinis/Fardis (2013) multiplied with shear\_factor

and also multiplied by the shear\_factor according to 15.7.1.4, with

Shear\_factor = 1.00

lo/lou,min = lb/lb,min = 0.13907892

su2 = 0.4\*esu2\_nominal ((5.5), TBDY) = 0.032

From table 5A.1, TBDY: esu2\_nominal = 0.08,

For calculation of  $es_{u2\_nominal}$  and  $y_2$ ,  $sh_2$ ,  $ft_2$ ,  $fy_2$ , it is considered characteristic value  $fs_{y2} = fs_2/1.2$ , from table 5.1, TBDY.

$y_1$ ,  $sh_1$ ,  $ft_1$ ,  $fy_1$ , are also multiplied by  $\text{Min}(1, 1.25 \cdot (lb/ld)^{2/3})$ , from 10.3.5, ASCE 41-17.

with  $fs_2 = (fs_{jacket} \cdot Asl_{com,jacket} + fs_{core} \cdot Asl_{com,core}) / Asl_{com} = 262.1446$

with  $Es_2 = (Es_{jacket} \cdot Asl_{com,jacket} + Es_{core} \cdot Asl_{com,core}) / Asl_{com} = 200000.00$

$y_v = 0.00083886$

$sh_v = 0.00268436$

$ft_v = 314.5735$

$fy_v = 262.1446$

$s_{uv} = 0.00268436$

using (30) in Biskinis/Fardis (2013) multiplied with shear\_factor and also multiplied by the shear\_factor according to 15.7.1.4, with Shear\_factor = 1.00

$lo/lo_{u,min} = lb/ld = 0.13907892$

$s_{uv} = 0.4 \cdot es_{uv\_nominal} ((5.5), TBDY) = 0.032$

From table 5A.1, TBDY:  $es_{uv\_nominal} = 0.08$ ,

considering characteristic value  $fs_{yv} = fs_v/1.2$ , from table 5.1, TBDY

For calculation of  $es_{uv\_nominal}$  and  $y_v$ ,  $sh_v$ ,  $ft_v$ ,  $fy_v$ , it is considered characteristic value  $fs_{yv} = fs_v/1.2$ , from table 5.1, TBDY.

$y_1$ ,  $sh_1$ ,  $ft_1$ ,  $fy_1$ , are also multiplied by  $\text{Min}(1, 1.25 \cdot (lb/ld)^{2/3})$ , from 10.3.5, ASCE 41-17.

with  $fs_v = (fs_{jacket} \cdot Asl_{mid,jacket} + fs_{mid} \cdot Asl_{mid,core}) / Asl_{mid} = 262.1446$

with  $Es_v = (Es_{jacket} \cdot Asl_{mid,jacket} + Es_{mid} \cdot Asl_{mid,core}) / Asl_{mid} = 200000.00$

$1 = Asl_{ten}/(b \cdot d) \cdot (fs_1/f_c) = 0.06824101$

$2 = Asl_{com}/(b \cdot d) \cdot (fs_2/f_c) = 0.03513975$

$v = Asl_{mid}/(b \cdot d) \cdot (fs_v/f_c) = 0.06202846$

and confined core properties:

$b = 340.00$

$d = 677.00$

$d' = 13.00$

$f_{cc} (5A.2, TBDY) = 38.13135$

$cc (5A.5, TBDY) = 0.00471045$

$c = \text{confinement factor} = 1.27105$

$1 = Asl_{ten}/(b \cdot d) \cdot (fs_1/f_c) = 0.08384116$

$2 = Asl_{com}/(b \cdot d) \cdot (fs_2/f_c) = 0.04317283$

$v = Asl_{mid}/(b \cdot d) \cdot (fs_v/f_c) = 0.07620839$

Case/Assumption: Unconfined full section - Steel rupture

' satisfies Eq. (4.3)

--->

$v < v_{s,y2}$  - LHS eq.(4.5) is satisfied

--->

$su (4.9) = 0.2584548$

$Mu = MR_c (4.14) = 5.0296E+008$

$u = su (4.1) = 5.1201636E-006$

-----

Calculation of ratio  $lb/ld$

-----

Lap Length:  $lb/ld = 0.13907892$

$lb = 300.00$

$ld = 2157.049$

Calculation of  $lb_{min}$  according to (25.4.3.2), ACI 318-14, using mean values for all the section re-bars.

$ld_{min}$  from (25.4.3.2) is multiplied 2 times to account for smooth re-bars (9.1.2, TS500 - No provision in ACI 318)

= 1

$db = 16.66667$

Mean strength value of all re-bars:  $fy = 781.25$

Mean concrete strength:  $fc' = (fc'_{jacket} \cdot Area_{jacket} + fc'_{core} \cdot Area_{core}) / Area_{section} = 30.00$ , but  $fc'^{0.5} \leq 8.3$  MPa (22.5.3.1, ACI 318-14)

$t = 1.00$

$s = 0.80$

$e = 1.00$

$cb = 25.00$

$K_{tr} = 1.7174$

$A_{tr} = \text{Min}(A_{tr\_x}, A_{tr\_y}) = 257.6106$

where  $A_{tr\_x}$ ,  $A_{tr\_y}$  are the sum of the area of all stirrup legs along X and Y loxal axis

$s = \text{Max}(s_{external}, s_{internal}) = 250.00$

$n = 24.00$

-----



## Calculation of Mu2+

Calculation of ultimate curvature  $\mu$  according to 4.1, Biskinis/Fardis 2013:

$$\mu = 4.8099118E-006$$

$$Mu = 2.3387E+008$$

with full section properties:

$$b = 750.00$$

$$d = 707.00$$

$$d' = 43.00$$

$$v = 0.00102301$$

$$N = 16273.608$$

$$f_c = 30.00$$

$$co \text{ (5A.5, TBDY)} = 0.002$$

$$\text{Final value of } \mu: \mu = \text{shear\_factor} * \text{Max}(\mu_c, \mu_{cc}) = 0.01260361$$

The Shear\_factor is considered equal to 1 (pure moment strength)

$$\text{From (5.4b), TBDY: } \mu_c = 0.01260361$$

$$\mu_{cc} \text{ (5.4c)} = 0.05179731$$

$$ase \text{ ((5.4d), TBDY)} = (ase1 * A_{ext} + ase2 * A_{int}) / A_{sec} = 0.45746528$$

$$ase1 = \text{Max}(((A_{conf,max1} - A_{noConf1}) / A_{conf,max1}) * (A_{conf,min1} / A_{conf,max1}), 0) = 0.45746528$$

The definitions of  $A_{noConf}$ ,  $A_{conf,min}$  and  $A_{conf,max}$  are derived from generalization of the rectangular sections confinement, which is expressed by (5.4d).

The generalization is done according to Mander, J., Priestley, M., and Park, R. (1988)

"Theoretical Stress-Strain Model for Confined Concrete."

J. Struct. Eng., 10.1061/(ASCE)0733-9445(1988)114:8(1804), 1804-1826.

$A_{conf,max1} = 353600.00$  is the confined core area at levels of member with hoops and

is calculated as the area of core enclosed by the center lines of the external perimeter hoops.

$A_{conf,min1} = 293525.00$  is the confined core area at midway between the levels of hoops and

is calculated by reducing all the dimensions of the area  $A_{conf,max1}$  by a length equal to half the clear spacing between external hoops.

$A_{noConf1} = 158733.333$  is the unconfined external core area which is equal to  $b_i^2/6$  as defined at (A.2).

$$ase2 (>= ase1) = \text{Max}(((A_{conf,max2} - A_{noConf2}) / A_{conf,max2}) * (A_{conf,min2} / A_{conf,max2}), 0) = 0.45746528$$

The definitions of  $A_{noConf}$ ,  $A_{conf,min}$  and  $A_{conf,max}$  are derived from generalization of the rectangular sections confinement, which is expressed by (5.4d).

The generalization is done according to Mander, J., Priestley, M., and Park, R. (1988)

"Theoretical Stress-Strain Model for Confined Concrete."

J. Struct. Eng., 10.1061/(ASCE)0733-9445(1988)114:8(1804), 1804-1826.

$A_{conf,max2} = 171264.00$  is the confined core area at levels of member with hoops and

is calculated as the area of core enclosed by the center lines of the internal perimeter hoops.

$A_{conf,min2} = 54741.00$  is the confined core area at midway between the levels of hoops and

is calculated by reducing all the dimensions of the area  $A_{conf,max2}$  by a length equal to half the clear spacing between internal hoops.

$A_{noConf2} = 106242.667$  is the unconfined internal core area which is equal to  $b_i^2/6$  as defined at (A.2).

$$psh_{min} * F_{ywe} = \text{Min}(psh_x * F_{ywe}, psh_y * F_{ywe}) = 3.3968$$

$$psh_x * F_{ywe} = psh1 * F_{ywe1} + ps2 * F_{ywe2} = 3.3968$$

$$psh1 \text{ ((5.4d), TBDY)} = L_{stir1} * A_{stir1} / (A_{sec} * s1) = 0.00367709$$

$$L_{stir1} \text{ (Length of stirrups along Y)} = 2060.00$$

$$A_{stir1} \text{ (stirrups area)} = 78.53982$$

$$psh2 \text{ (5.4d)} = L_{stir2} * A_{stir2} / (A_{sec} * s2) = 0.00067082$$

$$L_{stir2} \text{ (Length of stirrups along Y)} = 1468.00$$

$$A_{stir2} \text{ (stirrups area)} = 50.26548$$

$$psh_y * F_{ywe} = psh1 * F_{ywe1} + ps2 * F_{ywe2} = 3.3968$$

$$psh1 \text{ ((5.4d), TBDY)} = L_{stir1} * A_{stir1} / (A_{sec} * s1) = 0.00367709$$

$$L_{stir1} \text{ (Length of stirrups along X)} = 2060.00$$

$$A_{stir1} \text{ (stirrups area)} = 78.53982$$

$$psh2 \text{ ((5.4d), TBDY)} = L_{stir2} * A_{stir2} / (A_{sec} * s2) = 0.00067082$$

$$L_{stir2} \text{ (Length of stirrups along X)} = 1468.00$$

$$A_{stir2} \text{ (stirrups area)} = 50.26548$$

$$A_{sec} = 440000.00$$

$$s1 = 100.00$$

$s_2 = 250.00$   
 $fy_{we1} = 781.25$   
 $fy_{we2} = 781.25$   
 $f_{ce} = 30.00$   
 From ((5.A.5), TBDY), TBDY:  $cc = 0.00471045$   
 $c = \text{confinement factor} = 1.27105$   
 $y_1 = 0.00083886$   
 $sh_1 = 0.00268436$   
 $ft_1 = 314.5735$   
 $fy_1 = 262.1446$   
 $su_1 = 0.00268436$   
 using (30) in Biskinis/Fardis (2013) multiplied with shear\_factor  
 and also multiplied by the shear\_factor according to 15.7.1.4, with  
 $\text{Shear\_factor} = 1.00$   
 $lo/lou, \min = lb/ld = 0.13907892$   
 $su_1 = 0.4 * esu_1 \text{ nominal ((5.5), TBDY)} = 0.032$   
 From table 5A.1, TBDY:  $esu_1 \text{ nominal} = 0.08$ ,  
 For calculation of  $esu_1 \text{ nominal}$  and  $y_1, sh_1, ft_1, fy_1$ , it is considered  
 characteristic value  $fsy_1 = fs_1/1.2$ , from table 5.1, TBDY.  
 $y_1, sh_1, ft_1, fy_1$ , are also multiplied by  $\text{Min}(1, 1.25 * (lb/ld)^{2/3})$ , from 10.3.5, ASCE 41-17.  
 with  $fs_1 = (fs_{jacket} * Asl, \text{ten, jacket} + fs_{core} * Asl, \text{ten, core}) / Asl, \text{ten} = 262.1446$   
 with  $Es_1 = (Es_{jacket} * Asl, \text{ten, jacket} + Es_{core} * Asl, \text{ten, core}) / Asl, \text{ten} = 200000.00$   
 $y_2 = 0.00083886$   
 $sh_2 = 0.00268436$   
 $ft_2 = 314.5735$   
 $fy_2 = 262.1446$   
 $su_2 = 0.00268436$   
 using (30) in Biskinis/Fardis (2013) multiplied with shear\_factor  
 and also multiplied by the shear\_factor according to 15.7.1.4, with  
 $\text{Shear\_factor} = 1.00$   
 $lo/lou, \min = lb/lb, \min = 0.13907892$   
 $su_2 = 0.4 * esu_2 \text{ nominal ((5.5), TBDY)} = 0.032$   
 From table 5A.1, TBDY:  $esu_2 \text{ nominal} = 0.08$ ,  
 For calculation of  $esu_2 \text{ nominal}$  and  $y_2, sh_2, ft_2, fy_2$ , it is considered  
 characteristic value  $fsy_2 = fs_2/1.2$ , from table 5.1, TBDY.  
 $y_1, sh_1, ft_1, fy_1$ , are also multiplied by  $\text{Min}(1, 1.25 * (lb/ld)^{2/3})$ , from 10.3.5, ASCE 41-17.  
 with  $fs_2 = (fs_{jacket} * Asl, \text{com, jacket} + fs_{core} * Asl, \text{com, core}) / Asl, \text{com} = 262.1446$   
 with  $Es_2 = (Es_{jacket} * Asl, \text{com, jacket} + Es_{core} * Asl, \text{com, core}) / Asl, \text{com} = 200000.00$   
 $y_v = 0.00083886$   
 $sh_v = 0.00268436$   
 $ft_v = 314.5735$   
 $fy_v = 262.1446$   
 $suv = 0.00268436$   
 using (30) in Biskinis/Fardis (2013) multiplied with shear\_factor  
 and also multiplied by the shear\_factor according to 15.7.1.4, with  
 $\text{Shear\_factor} = 1.00$   
 $lo/lou, \min = lb/ld = 0.13907892$   
 $suv = 0.4 * esuv \text{ nominal ((5.5), TBDY)} = 0.032$   
 From table 5A.1, TBDY:  $esuv \text{ nominal} = 0.08$ ,  
 considering characteristic value  $fsyv = fsv/1.2$ , from table 5.1, TBDY  
 For calculation of  $esuv \text{ nominal}$  and  $y_v, sh_v, ft_v, fy_v$ , it is considered  
 characteristic value  $fsyv = fsv/1.2$ , from table 5.1, TBDY.  
 $y_1, sh_1, ft_1, fy_1$ , are also multiplied by  $\text{Min}(1, 1.25 * (lb/ld)^{2/3})$ , from 10.3.5, ASCE 41-17.  
 with  $fsv = (fs_{jacket} * Asl, \text{mid, jacket} + fs_{mid} * Asl, \text{mid, core}) / Asl, \text{mid} = 262.1446$   
 with  $Es_v = (Es_{jacket} * Asl, \text{mid, jacket} + Es_{mid} * Asl, \text{mid, core}) / Asl, \text{mid} = 200000.00$   
 $1 = Asl, \text{ten} / (b * d) * (fs_1 / f_c) = 0.0187412$   
 $2 = Asl, \text{com} / (b * d) * (fs_2 / f_c) = 0.03639521$   
 $v = Asl, \text{mid} / (b * d) * (fsv / f_c) = 0.03308184$   
 and confined core properties:  
 $b = 690.00$   
 $d = 677.00$   
 $d' = 13.00$   
 $f_{cc} \text{ (5A.2, TBDY)} = 38.13135$   
 $cc \text{ (5A.5, TBDY)} = 0.00471045$   
 $c = \text{confinement factor} = 1.27105$   
 $1 = Asl, \text{ten} / (b * d) * (fs_1 / f_c) = 0.02127357$   
 $2 = Asl, \text{com} / (b * d) * (fs_2 / f_c) = 0.04131304$

$v = A_{sl, mid} / (b \cdot d) \cdot (f_{sv} / f_c) = 0.03755196$   
Case/Assumption: Unconfined full section - Steel rupture  
'satisfies Eq. (4.3)

--->  
 $v < v_{s, y2}$  - LHS eq.(4.5) is satisfied  
--->  
 $su(4.9) = 0.21062322$   
 $Mu = MRc(4.14) = 2.3387E+008$   
 $u = su(4.1) = 4.8099118E-006$

-----  
Calculation of ratio  $l_b / l_d$

-----  
Lap Length:  $l_b / l_d = 0.13907892$   
 $l_b = 300.00$   
 $l_d = 2157.049$   
Calculation of  $l_b, min$  according to (25.4.3.2), ACI 318-14, using mean values for all the section re-bars.  
 $l_d, min$  from (25.4.3.2) is multiplied 2 times to account for smooth re-bars (9.1.2, TS500 - No provision in ACI 318)  
= 1  
 $db = 16.66667$   
Mean strength value of all re-bars:  $f_y = 781.25$   
Mean concrete strength:  $f_c' = (f_c'_{jacket} \cdot Area_{jacket} + f_c'_{core} \cdot Area_{core}) / Area_{section} = 30.00$ , but  $f_c'^{0.5} \leq 8.3$   
MPa (22.5.3.1, ACI 318-14)  
 $t = 1.00$   
 $s = 0.80$   
 $e = 1.00$   
 $cb = 25.00$   
 $K_{tr} = 1.7174$   
 $A_{tr} = \min(A_{tr, x}, A_{tr, y}) = 257.6106$   
where  $A_{tr, x}$ ,  $A_{tr, y}$  are the sum of the area of all stirrup legs along X and Y loxal axis  
 $s = \max(s_{external}, s_{internal}) = 250.00$   
 $n = 24.00$

-----  
Calculation of  $Mu_2$ -  
-----

-----  
Calculation of ultimate curvature  $u$  according to 4.1, Biskinis/Fardis 2013:  
 $u = 5.1201636E-006$   
 $Mu = 5.0296E+008$

-----  
with full section properties:

$b = 400.00$   
 $d = 707.00$   
 $d' = 43.00$   
 $v = 0.00191815$   
 $N = 16273.608$   
 $f_c = 30.00$   
 $\phi(5A.5, TBDY) = 0.002$   
Final value of  $\phi$ :  $\phi_u = shear\_factor \cdot \max(\phi_u, \phi_c) = 0.01260361$   
The Shear\_factor is considered equal to 1 (pure moment strength)  
From (5.4b), TBDY:  $\phi_u = 0.01260361$   
 $\phi_{we}(5.4c) = 0.05179731$   
 $\phi_{ase}((5.4d), TBDY) = (\phi_{ase1} \cdot A_{ext} + \phi_{ase2} \cdot A_{int}) / A_{sec} = 0.45746528$   
 $\phi_{ase1} = \max(((A_{conf, max1} - A_{noConf1}) / A_{conf, max1}) \cdot (A_{conf, min1} / A_{conf, max1}), 0) = 0.45746528$   
The definitions of  $A_{noConf}$ ,  $A_{conf, min}$  and  $A_{conf, max}$  are derived from generalization of the rectangular sections confinement, which is expressed by (5.4d).  
The generalization is done according to Mander, J., Priestley, M., and Park, R. (1988) "Theoretical Stress-Strain Model for Confined Concrete."  
J. Struct. Eng., 10.1061/(ASCE)0733-9445(1988)114:8(1804), 1804-1826.  
 $A_{conf, max1} = 353600.00$  is the confined core area at levels of member with hoops and is calculated as the area of core enclosed by the center lines of the external perimeter hoops.  
 $A_{conf, min1} = 293525.00$  is the confined core area at midway between the levels of hoops and is calculated by reducing all the dimensions of the area  $A_{conf, max1}$  by a length equal to half the clear spacing between external hoops.

AnoConf1 = 158733.333 is the unconfined external core area which is equal to  $b_i^2/6$  as defined at (A.2).  
 $ase2 (>=ase1) = \text{Max}(((A_{conf,max2}-AnoConf2)/A_{conf,max2})*(A_{conf,min2}/A_{conf,max2}),0) = 0.45746528$   
The definitions of AnoConf, Aconf,min and Aconf,max are derived from generalization of the rectangular sections confinement, which is expressed by (5.4d).  
The generalization is done according to Mander, J., Priestley, M., and Park, R. (1988) "Theoretical Stress-Strain Model for Confined Concrete."  
J. Struct. Eng., 10.1061/(ASCE)0733-9445(1988)114:8(1804), 1804-1826.  
Aconf,max2 = 171264.00 is the confined core area at levels of member with hoops and is calculated as the area of core enclosed by the center lines of the internal perimeter hoops.  
Aconf,min2 = 54741.00 is the confined core area at midway between the levels of hoops and is calculated by reducing all the dimensions of the area Aconf,max2 by a length equal to half the clear spacing between internal hoops.  
AnoConf2 = 106242.667 is the unconfined internal core area which is equal to  $b_i^2/6$  as defined at (A.2).  
 $psh,min*Fywe = \text{Min}(psh,x*Fywe, psh,y*Fywe) = 3.3968$

$psh_x*Fywe = psh1*Fywe1 + ps2*Fywe2 = 3.3968$   
 $psh1 ((5.4d), TBDY) = Lstir1*Astir1/(Asec*s1) = 0.00367709$   
Lstir1 (Length of stirrups along Y) = 2060.00  
Astir1 (stirrups area) = 78.53982  
 $psh2 ((5.4d)) = Lstir2*Astir2/(Asec*s2) = 0.00067082$   
Lstir2 (Length of stirrups along Y) = 1468.00  
Astir2 (stirrups area) = 50.26548

$psh_y*Fywe = psh1*Fywe1 + ps2*Fywe2 = 3.3968$   
 $psh1 ((5.4d), TBDY) = Lstir1*Astir1/(Asec*s1) = 0.00367709$   
Lstir1 (Length of stirrups along X) = 2060.00  
Astir1 (stirrups area) = 78.53982  
 $psh2 ((5.4d), TBDY) = Lstir2*Astir2/(Asec*s2) = 0.00067082$   
Lstir2 (Length of stirrups along X) = 1468.00  
Astir2 (stirrups area) = 50.26548

Asec = 440000.00

s1 = 100.00

s2 = 250.00

fywe1 = 781.25

fywe2 = 781.25

fce = 30.00

From ((5.A5), TBDY), TBDY: cc = 0.00471045

c = confinement factor = 1.27105

y1 = 0.00083886

sh1 = 0.00268436

ft1 = 314.5735

fy1 = 262.1446

su1 = 0.00268436

using (30) in Biskinis/Fardis (2013) multiplied with shear\_factor and also multiplied by the shear\_factor according to 15.7.1.4, with Shear\_factor = 1.00

lo/lou,min = lb/ld = 0.13907892

su1 = 0.4\*esu1\_nominal ((5.5), TBDY) = 0.032

From table 5A.1, TBDY: esu1\_nominal = 0.08,

For calculation of esu1\_nominal and y1, sh1,ft1,fy1, it is considered characteristic value fsy1 = fs1/1.2, from table 5.1, TBDY.

y1, sh1,ft1,fy1, are also multiplied by  $\text{Min}(1, 1.25*(lb/ld)^{2/3})$ , from 10.3.5, ASCE 41-17.

with fs1 = (fs,jacket\*Asl,ten,jacket + fs,core\*Asl,ten,core)/Asl,ten = 262.1446

with Es1 = (Es,jacket\*Asl,ten,jacket + Es,core\*Asl,ten,core)/Asl,ten = 200000.00

y2 = 0.00083886

sh2 = 0.00268436

ft2 = 314.5735

fy2 = 262.1446

su2 = 0.00268436

using (30) in Biskinis/Fardis (2013) multiplied with shear\_factor and also multiplied by the shear\_factor according to 15.7.1.4, with Shear\_factor = 1.00

lo/lou,min = lb/lb,min = 0.13907892

su2 = 0.4\*esu2\_nominal ((5.5), TBDY) = 0.032

From table 5A.1, TBDY: esu2\_nominal = 0.08,

For calculation of esu2\_nominal and y2, sh2,ft2,fy2, it is considered

characteristic value  $fsy2 = fs2/1.2$ , from table 5.1, TBDY.  
 $y1, sh1, ft1, fy1$ , are also multiplied by  $\text{Min}(1, 1.25 \cdot (lb/ld)^{2/3})$ , from 10.3.5, ASCE 41-17.  
 with  $fs2 = (fs_{jacket} \cdot Asl_{com,jacket} + fs_{core} \cdot Asl_{com,core}) / Asl_{com} = 262.1446$   
 with  $Es2 = (Es_{jacket} \cdot Asl_{com,jacket} + Es_{core} \cdot Asl_{com,core}) / Asl_{com} = 200000.00$   
 $yv = 0.00083886$   
 $shv = 0.00268436$   
 $ftv = 314.5735$   
 $fyv = 262.1446$   
 $suv = 0.00268436$   
 using (30) in Biskinis/Fardis (2013) multiplied with shear\_factor  
 and also multiplied by the shear\_factor according to 15.7.1.4, with  
 Shear\_factor = 1.00  
 $lo/lou,min = lb/ld = 0.13907892$   
 $suv = 0.4 \cdot esuv_{nominal} ((5.5), TBDY) = 0.032$   
 From table 5A.1, TBDY:  $esuv_{nominal} = 0.08$ ,  
 considering characteristic value  $fsyv = fsv/1.2$ , from table 5.1, TBDY  
 For calculation of  $esuv_{nominal}$  and  $yv, shv, ftv, fyv$ , it is considered  
 characteristic value  $fsyv = fsv/1.2$ , from table 5.1, TBDY.  
 $y1, sh1, ft1, fy1$ , are also multiplied by  $\text{Min}(1, 1.25 \cdot (lb/ld)^{2/3})$ , from 10.3.5, ASCE 41-17.  
 with  $fsv = (fs_{jacket} \cdot Asl_{mid,jacket} + fs_{mid} \cdot Asl_{mid,core}) / Asl_{mid} = 262.1446$   
 with  $Esv = (Es_{jacket} \cdot Asl_{mid,jacket} + Es_{mid} \cdot Asl_{mid,core}) / Asl_{mid} = 200000.00$   
 $1 = Asl_{ten}/(b \cdot d) \cdot (fs1/fc) = 0.06824101$   
 $2 = Asl_{com}/(b \cdot d) \cdot (fs2/fc) = 0.03513975$   
 $v = Asl_{mid}/(b \cdot d) \cdot (fsv/fc) = 0.06202846$   
 and confined core properties:  
 $b = 340.00$   
 $d = 677.00$   
 $d' = 13.00$   
 $fcc (5A.2, TBDY) = 38.13135$   
 $cc (5A.5, TBDY) = 0.00471045$   
 $c = \text{confinement factor} = 1.27105$   
 $1 = Asl_{ten}/(b \cdot d) \cdot (fs1/fc) = 0.08384116$   
 $2 = Asl_{com}/(b \cdot d) \cdot (fs2/fc) = 0.04317283$   
 $v = Asl_{mid}/(b \cdot d) \cdot (fsv/fc) = 0.07620839$   
 Case/Assumption: Unconfined full section - Steel rupture  
 ' satisfies Eq. (4.3)  
 --->  
 $v < vs,y2$  - LHS eq.(4.5) is satisfied  
 --->  
 $su (4.9) = 0.2584548$   
 $Mu = MRc (4.14) = 5.0296E+008$   
 $u = su (4.1) = 5.1201636E-006$   
 -----  
 Calculation of ratio  $lb/ld$   
 -----  
 Lap Length:  $lb/ld = 0.13907892$   
 $lb = 300.00$   
 $ld = 2157.049$   
 Calculation of  $lb,min$  according to (25.4.3.2), ACI 318-14, using mean values for all the section re-bars.  
 $ld,min$  from (25.4.3.2) is multiplied 2 times to account for smooth re-bars (9.1.2, TS500 - No provision in ACI 318)  
 $= 1$   
 $db = 16.66667$   
 Mean strength value of all re-bars:  $fy = 781.25$   
 Mean concrete strength:  $fc' = (fc'_{jacket} \cdot Area_{jacket} + fc'_{core} \cdot Area_{core}) / Area_{section} = 30.00$ , but  $fc'^{0.5} \leq 8.3$   
 MPa (22.5.3.1, ACI 318-14)  
 $t = 1.00$   
 $s = 0.80$   
 $e = 1.00$   
 $cb = 25.00$   
 $Ktr = 1.7174$   
 $Atr = \text{Min}(Atr_x, Atr_y) = 257.6106$   
 where  $Atr_x, Atr_y$  are the sum of the area of all stirrup legs along X and Y loxal axis  
 $s = \text{Max}(s_{external}, s_{internal}) = 250.00$   
 $n = 24.00$

Calculation of Shear Strength  $V_r = \text{Min}(V_{r1}, V_{r2}) = 1.0392\text{E}+006$

Calculation of Shear Strength at edge 1,  $V_{r1} = 1.0392\text{E}+006$

$V_{r1} = V_{\text{Col}} ((10.3), \text{ASCE } 41-17) = k_{nl} * V_{\text{Col}0}$

$V_{\text{Col}0} = 1.0392\text{E}+006$

$k_{nl} = 1$  (zero step-static loading)

NOTE: In expression (10-3) ' $V_s = A_v * f_y * d / s$ ' is replaced by ' $V_s + f * V_f$ ' where  $V_f$  is the contribution of FRPs (11.3), ACI 440).

$= 1$  (normal-weight concrete)

Mean concrete strength:  $f_c' = (f_c'_{\text{jacket}} * \text{Area}_{\text{jacket}} + f_c'_{\text{core}} * \text{Area}_{\text{core}}) / \text{Area}_{\text{section}} = 30.00$ , but  $f_c'^{0.5} \leq 8.3$  MPa (22.5.3.1, ACI 318-14)

$M/Vd = 4.00$

$\mu_u = 1308.016$

$V_u = 0.00017144$

$d = 0.8 * h = 600.00$

$N_u = 16273.608$

$A_g = 300000.00$

From (11.5.4.8), ACI 318-14:  $V_s = V_{s,\text{jacket}} + V_{s,\text{core}} = 1.0138\text{E}+006$

where:

$V_{s,\text{jacket}} = V_{s,j1} + V_{s,j2} = 903207.888$

$V_{s,j1} = 589048.623$  is calculated for section web jacket, with:

$d = 600.00$

$A_v = 157079.633$

$f_y = 625.00$

$s = 100.00$

$V_{s,j1}$  is multiplied by  $\text{Col},j1 = 1.00$

$s/d = 0.16666667$

$V_{s,j2} = 314159.265$  is calculated for section flange jacket, with:

$d = 320.00$

$A_v = 157079.633$

$f_y = 625.00$

$s = 100.00$

$V_{s,j2}$  is multiplied by  $\text{Col},j2 = 1.00$

$s/d = 0.3125$

$V_{s,\text{core}} = V_{s,c1} + V_{s,c2} = 110584.061$

$V_{s,c1} = 110584.061$  is calculated for section web core, with:

$d = 440.00$

$A_v = 100530.965$

$f_y = 625.00$

$s = 250.00$

$V_{s,c1}$  is multiplied by  $\text{Col},c1 = 1.00$

$s/d = 0.56818182$

$V_{s,c2} = 0.00$  is calculated for section flange core, with:

$d = 160.00$

$A_v = 100530.965$

$f_y = 625.00$

$s = 250.00$

$V_{s,c2}$  is multiplied by  $\text{Col},c2 = 0.00$

$s/d = 1.5625$

$V_f ((11-3)-(11.4), \text{ACI } 440) = 0.00$

From (11-11), ACI 440:  $V_s + V_f \leq 873250.061$

$b_w = 400.00$

Calculation of Shear Strength at edge 2,  $V_{r2} = 1.0392\text{E}+006$

$V_{r2} = V_{\text{Col}} ((10.3), \text{ASCE } 41-17) = k_{nl} * V_{\text{Col}0}$

$V_{\text{Col}0} = 1.0392\text{E}+006$

$k_{nl} = 1$  (zero step-static loading)

NOTE: In expression (10-3) ' $V_s = A_v * f_y * d / s$ ' is replaced by ' $V_s + f * V_f$ ' where  $V_f$  is the contribution of FRPs (11.3), ACI 440).

$= 1$  (normal-weight concrete)

Mean concrete strength:  $fc' = (fc'_{jacket} \cdot Area_{jacket} + fc'_{core} \cdot Area_{core}) / Area_{section} = 30.00$ , but  $fc'^{0.5} \leq 8.3$  MPa (22.5.3.1, ACI 318-14)

$M/Vd = 4.00$

$\mu_u = 1308.016$

$V_u = 0.00017144$

$d = 0.8 \cdot h = 600.00$

$N_u = 16273.608$

$A_g = 300000.00$

From (11.5.4.8), ACI 318-14:  $V_s = V_{sjacket} + V_{s,core} = 1.0138E+006$

where:

$V_{sjacket} = V_{sj1} + V_{sj2} = 903207.888$

$V_{sj1} = 589048.623$  is calculated for section web jacket, with:

$d = 600.00$

$A_v = 157079.633$

$f_y = 625.00$

$s = 100.00$

$V_{sj1}$  is multiplied by  $Col,j1 = 1.00$

$s/d = 0.16666667$

$V_{sj2} = 314159.265$  is calculated for section flange jacket, with:

$d = 320.00$

$A_v = 157079.633$

$f_y = 625.00$

$s = 100.00$

$V_{sj2}$  is multiplied by  $Col,j2 = 1.00$

$s/d = 0.3125$

$V_{s,core} = V_{s,c1} + V_{s,c2} = 110584.061$

$V_{s,c1} = 110584.061$  is calculated for section web core, with:

$d = 440.00$

$A_v = 100530.965$

$f_y = 625.00$

$s = 250.00$

$V_{s,c1}$  is multiplied by  $Col,c1 = 1.00$

$s/d = 0.56818182$

$V_{s,c2} = 0.00$  is calculated for section flange core, with:

$d = 160.00$

$A_v = 100530.965$

$f_y = 625.00$

$s = 250.00$

$V_{s,c2}$  is multiplied by  $Col,c2 = 0.00$

$s/d = 1.5625$

$V_f ((11-3)-(11.4), ACI 440) = 0.00$

From (11-11), ACI 440:  $V_s + V_f \leq 873250.061$

$bw = 400.00$

-----

End Of Calculation of Shear Capacity ratio for element: column JLC1 of floor 1

At local axis: 3

-----

Start Of Calculation of Shear Capacity ratio for element: column JLC1 of floor 1

At Shear local axis: 2

(Bending local axis: 3)

Section Type: rcjlc

Constant Properties

-----

Knowledge Factor,  $\phi = 1.00$

Mean strength values are used for both shear and moment calculations.

Consequently:

Jacket

New material of Primary Member: Concrete Strength,  $fc = f_{cm} = 30.00$

New material of Primary Member: Steel Strength,  $f_s = f_{sm} = 625.00$

Concrete Elasticity,  $E_c = 25742.96$

Steel Elasticity,  $E_s = 200000.00$

Existing Column

```

New material of Primary Member: Concrete Strength,  $f_c = f_{cm} = 30.00$ 
New material of Primary Member: Steel Strength,  $f_s = f_{sm} = 625.00$ 
Concrete Elasticity,  $E_c = 25742.96$ 
Steel Elasticity,  $E_s = 200000.00$ 
#####
Note: Especially for the calculation of moment strengths,
the above steel re-bar strengths are multiplied by 1.25 according to R18.6.5, ACI 318-14
Jacket
New material: Steel Strength,  $f_s = 1.25 \cdot f_{sm} = 781.25$ 
Existing Column
New material: Steel Strength,  $f_s = 1.25 \cdot f_{sm} = 781.25$ 
#####
Max Height,  $H_{max} = 750.00$ 
Min Height,  $H_{min} = 400.00$ 
Max Width,  $W_{max} = 750.00$ 
Min Width,  $W_{min} = 400.00$ 
Jacket Thickness,  $t_j = 100.00$ 
Cover Thickness,  $c = 25.00$ 
Mean Confinement Factor overall section = 1.27105
Element Length,  $L = 3000.00$ 
Primary Member
Smooth Bars
Ductile Steel
With Detailing for Earthquake Resistance (including stirrups closed at 135°)
Longitudinal Bars With Ends Lapped Starting at the End Sections
Lap Length  $l_o = 300.00$ 
No FRP Wrapping
-----

Stepwise Properties
-----
At local axis: 2
EDGE -A-
Shear Force,  $V_a = -0.0001715$ 
EDGE -B-
Shear Force,  $V_b = 0.0001715$ 
BOTH EDGES
Axial Force,  $F = -16273.608$ 
Longitudinal Reinforcement Area Distribution (in 2 divisions)
  -Tension:  $As_t = 0.00$ 
  -Compression:  $As_c = 5353.274$ 
Longitudinal Reinforcement Area Distribution (in 3 divisions)
  -Tension:  $As_{t,ten} = 1137.257$ 
  -Compression:  $As_{l,com} = 2208.54$ 
  -Middle:  $As_{l,mid} = 2007.478$ 
-----
-----

Calculation of Shear Capacity ratio ,  $V_e/V_r = 0.32266369$ 
Member Controlled by Flexure ( $V_e/V_r < 1$ )
Calculation of Shear Demand from fig. R18.6.5, ACI 318-14  $V_e = (M_{pr1} + M_{pr2})/l_n = 335307.657$ 
with
 $M_{pr1} = \text{Max}(Mu_{1+} , Mu_{1-}) = 5.0296E+008$ 
   $Mu_{1+} = 2.3387E+008$ , is the ultimate moment strength at the edge 1 of the member in the actual moment direction
  which is defined for the static loading combination
   $Mu_{1-} = 5.0296E+008$ , is the ultimate moment strength at the edge 1 of the member in the opposite moment
  direction which is defined for the static loading combination
 $M_{pr2} = \text{Max}(Mu_{2+} , Mu_{2-}) = 5.0296E+008$ 
   $Mu_{2+} = 2.3387E+008$ , is the ultimate moment strength at the edge 2 of the member in the actual moment direction
  which is defined for the the static loading combination
   $Mu_{2-} = 5.0296E+008$ , is the ultimate moment strength at the edge 2 of the member in the opposite moment
  direction which is defined for the the static loading combination
-----

Calculation of  $Mu_{1+}$ 
-----

```



Calculation of ultimate curvature  $\phi_u$  according to 4.1, Biskinis/Fardis 2013:

$$\phi_u = 4.8099118E-006$$

$$\mu_u = 2.3387E+008$$

with full section properties:

$$b = 750.00$$

$$d = 707.00$$

$$d' = 43.00$$

$$\nu = 0.00102301$$

$$N = 16273.608$$

$$f_c = 30.00$$

$$\phi_{co} (5A.5, TBDY) = 0.002$$

$$\text{Final value of } \phi_{cu}: \phi_{cu}^* = \text{shear\_factor} * \text{Max}(\phi_{cu}, \phi_{cc}) = 0.01260361$$

The Shear\_factor is considered equal to 1 (pure moment strength)

$$\text{From (5.4b), TBDY: } \phi_{cu} = 0.01260361$$

$$\phi_{we} (5.4c) = 0.05179731$$

$$\phi_{ase} ((5.4d), TBDY) = (\phi_{ase1} * A_{ext} + \phi_{ase2} * A_{int}) / A_{sec} = 0.45746528$$

$$\phi_{ase1} = \text{Max}(((A_{conf,max1} - A_{noConf1}) / A_{conf,max1}) * (A_{conf,min1} / A_{conf,max1}), 0) = 0.45746528$$

The definitions of  $A_{noConf}$ ,  $A_{conf,min}$  and  $A_{conf,max}$  are derived from generalization of the rectangular sections confinement, which is expressed by (5.4d).

The generalization is done according to Mander, J., Priestley, M., and Park, R. (1988)

"Theoretical Stress-Strain Model for Confined Concrete."

J. Struct. Eng., 10.1061/(ASCE)0733-9445(1988)114:8(1804), 1804-1826.

$A_{conf,max1} = 353600.00$  is the confined core area at levels of member with hoops and is calculated as the area of core enclosed by the center lines of the external perimeter hoops.

$A_{conf,min1} = 293525.00$  is the confined core area at midway between the levels of hoops and is calculated by reducing all the dimensions of the area  $A_{conf,max1}$  by a length equal to half the clear spacing between external hoops.

$A_{noConf1} = 158733.333$  is the unconfined external core area which is equal to  $b_i^2/6$  as defined at (A.2).

$$\phi_{ase2} (> \phi_{ase1}) = \text{Max}(((A_{conf,max2} - A_{noConf2}) / A_{conf,max2}) * (A_{conf,min2} / A_{conf,max2}), 0) = 0.45746528$$

The definitions of  $A_{noConf}$ ,  $A_{conf,min}$  and  $A_{conf,max}$  are derived from generalization of the rectangular sections confinement, which is expressed by (5.4d).

The generalization is done according to Mander, J., Priestley, M., and Park, R. (1988)

"Theoretical Stress-Strain Model for Confined Concrete."

J. Struct. Eng., 10.1061/(ASCE)0733-9445(1988)114:8(1804), 1804-1826.

$A_{conf,max2} = 171264.00$  is the confined core area at levels of member with hoops and is calculated as the area of core enclosed by the center lines of the internal perimeter hoops.

$A_{conf,min2} = 54741.00$  is the confined core area at midway between the levels of hoops and is calculated by reducing all the dimensions of the area  $A_{conf,max2}$  by a length equal to half the clear spacing between internal hoops.

$A_{noConf2} = 106242.667$  is the unconfined internal core area which is equal to  $b_i^2/6$  as defined at (A.2).

$$\phi_{psh,min} * F_{ywe} = \text{Min}(\phi_{psh,x} * F_{ywe}, \phi_{psh,y} * F_{ywe}) = 3.3968$$

$$\phi_{psh,x} * F_{ywe} = \phi_{psh1} * F_{ywe1} + \phi_{ps2} * F_{ywe2} = 3.3968$$

$$\phi_{psh1} ((5.4d), TBDY) = L_{stir1} * A_{stir1} / (A_{sec} * s_1) = 0.00367709$$

$$L_{stir1} \text{ (Length of stirrups along Y)} = 2060.00$$

$$A_{stir1} \text{ (stirrups area)} = 78.53982$$

$$\phi_{psh2} (5.4d) = L_{stir2} * A_{stir2} / (A_{sec} * s_2) = 0.00067082$$

$$L_{stir2} \text{ (Length of stirrups along Y)} = 1468.00$$

$$A_{stir2} \text{ (stirrups area)} = 50.26548$$

$$\phi_{psh,y} * F_{ywe} = \phi_{psh1} * F_{ywe1} + \phi_{ps2} * F_{ywe2} = 3.3968$$

$$\phi_{psh1} ((5.4d), TBDY) = L_{stir1} * A_{stir1} / (A_{sec} * s_1) = 0.00367709$$

$$L_{stir1} \text{ (Length of stirrups along X)} = 2060.00$$

$$A_{stir1} \text{ (stirrups area)} = 78.53982$$

$$\phi_{psh2} ((5.4d), TBDY) = L_{stir2} * A_{stir2} / (A_{sec} * s_2) = 0.00067082$$

$$L_{stir2} \text{ (Length of stirrups along X)} = 1468.00$$

$$A_{stir2} \text{ (stirrups area)} = 50.26548$$

$$A_{sec} = 440000.00$$

$$s_1 = 100.00$$

$$s_2 = 250.00$$

$$f_{ywe1} = 781.25$$

$$f_{ywe2} = 781.25$$

$$f_{ce} = 30.00$$

From (5A.5, TBDY), TBDY:  $cc = 0.00471045$   
 $c = \text{confinement factor} = 1.27105$   
 $y1 = 0.00083886$   
 $sh1 = 0.00268436$   
 $ft1 = 314.5735$   
 $fy1 = 262.1446$   
 $su1 = 0.00268436$   
 using (30) in Biskinis/Fardis (2013) multiplied with shear\_factor  
 and also multiplied by the shear\_factor according to 15.7.1.4, with  
 $\text{Shear\_factor} = 1.00$   
 $lo/lou,min = lb/ld = 0.13907892$   
 $su1 = 0.4*esu1\_nominal ((5.5), TBDY) = 0.032$   
 From table 5A.1, TBDY:  $esu1\_nominal = 0.08$ ,  
 For calculation of  $esu1\_nominal$  and  $y1, sh1, ft1, fy1$ , it is considered  
 characteristic value  $fsy1 = fs1/1.2$ , from table 5.1, TBDY.  
 $y1, sh1, ft1, fy1$ , are also multiplied by  $\text{Min}(1, 1.25*(lb/ld)^{2/3})$ , from 10.3.5, ASCE 41-17.  
 with  $fs1 = (fs,jacket*Asl,ten,jacket + fs,core*Asl,ten,core)/Asl,ten = 262.1446$   
 with  $Es1 = (Es,jacket*Asl,ten,jacket + Es,core*Asl,ten,core)/Asl,ten = 200000.00$   
 $y2 = 0.00083886$   
 $sh2 = 0.00268436$   
 $ft2 = 314.5735$   
 $fy2 = 262.1446$   
 $su2 = 0.00268436$   
 using (30) in Biskinis/Fardis (2013) multiplied with shear\_factor  
 and also multiplied by the shear\_factor according to 15.7.1.4, with  
 $\text{Shear\_factor} = 1.00$   
 $lo/lou,min = lb/lb,min = 0.13907892$   
 $su2 = 0.4*esu2\_nominal ((5.5), TBDY) = 0.032$   
 From table 5A.1, TBDY:  $esu2\_nominal = 0.08$ ,  
 For calculation of  $esu2\_nominal$  and  $y2, sh2, ft2, fy2$ , it is considered  
 characteristic value  $fsy2 = fs2/1.2$ , from table 5.1, TBDY.  
 $y1, sh1, ft1, fy1$ , are also multiplied by  $\text{Min}(1, 1.25*(lb/ld)^{2/3})$ , from 10.3.5, ASCE 41-17.  
 with  $fs2 = (fs,jacket*Asl,com,jacket + fs,core*Asl,com,core)/Asl,com = 262.1446$   
 with  $Es2 = (Es,jacket*Asl,com,jacket + Es,core*Asl,com,core)/Asl,com = 200000.00$   
 $yv = 0.00083886$   
 $shv = 0.00268436$   
 $ftv = 314.5735$   
 $fyv = 262.1446$   
 $suv = 0.00268436$   
 using (30) in Biskinis/Fardis (2013) multiplied with shear\_factor  
 and also multiplied by the shear\_factor according to 15.7.1.4, with  
 $\text{Shear\_factor} = 1.00$   
 $lo/lou,min = lb/ld = 0.13907892$   
 $suv = 0.4*esuv\_nominal ((5.5), TBDY) = 0.032$   
 From table 5A.1, TBDY:  $esuv\_nominal = 0.08$ ,  
 considering characteristic value  $fsyv = fsv/1.2$ , from table 5.1, TBDY  
 For calculation of  $esuv\_nominal$  and  $yv, shv, ftv, fyv$ , it is considered  
 characteristic value  $fsyv = fsv/1.2$ , from table 5.1, TBDY.  
 $y1, sh1, ft1, fy1$ , are also multiplied by  $\text{Min}(1, 1.25*(lb/ld)^{2/3})$ , from 10.3.5, ASCE 41-17.  
 with  $fsv = (fs,jacket*Asl,mid,jacket + fs,mid*Asl,mid,core)/Asl,mid = 262.1446$   
 with  $Es_v = (Es,jacket*Asl,mid,jacket + Es,mid*Asl,mid,core)/Asl,mid = 200000.00$   
 $1 = Asl,ten/(b*d)*(fs1/fc) = 0.0187412$   
 $2 = Asl,com/(b*d)*(fs2/fc) = 0.03639521$   
 $v = Asl,mid/(b*d)*(fsv/fc) = 0.03308184$   
 and confined core properties:  
 $b = 690.00$   
 $d = 677.00$   
 $d' = 13.00$   
 $fcc (5A.2, TBDY) = 38.13135$   
 $cc (5A.5, TBDY) = 0.00471045$   
 $c = \text{confinement factor} = 1.27105$   
 $1 = Asl,ten/(b*d)*(fs1/fc) = 0.02127357$   
 $2 = Asl,com/(b*d)*(fs2/fc) = 0.04131304$   
 $v = Asl,mid/(b*d)*(fsv/fc) = 0.03755196$   
 Case/Assumption: Unconfined full section - Steel rupture  
 ' satisfies Eq. (4.3)

---

$v < v_{s,y2}$  - LHS eq.(4.5) is satisfied

---->

$$s_u(4.9) = 0.21062322$$

$$\mu_u = M_{Rc}(4.14) = 2.3387E+008$$

$$u = s_u(4.1) = 4.8099118E-006$$

Calculation of ratio  $I_b/I_d$

$$\text{Lap Length: } I_b/I_d = 0.13907892$$

$$I_b = 300.00$$

$$I_d = 2157.049$$

Calculation of  $I_{b,min}$  according to (25.4.3.2), ACI 318-14, using mean values for all the section re-bars.

$I_{d,min}$  from (25.4.3.2) is multiplied 2 times to account for smooth re-bars (9.1.2, TS500 - No provision in ACI 318)

$$= 1$$

$$d_b = 16.66667$$

$$\text{Mean strength value of all re-bars: } f_y = 781.25$$

$$\text{Mean concrete strength: } f'_c = (f'_{c,jacket} \cdot \text{Area}_{jacket} + f'_{c,core} \cdot \text{Area}_{core}) / \text{Area}_{section} = 30.00, \text{ but } f'_c^{0.5} \leq 8.3 \text{ MPa (22.5.3.1, ACI 318-14)}$$

$$t = 1.00$$

$$s = 0.80$$

$$e = 1.00$$

$$c_b = 25.00$$

$$K_{tr} = 1.7174$$

$$A_{tr} = \text{Min}(A_{tr,x}, A_{tr,y}) = 257.6106$$

where  $A_{tr,x}$ ,  $A_{tr,y}$  are the sum of the area of all stirrup legs along X and Y local axis

$$s = \text{Max}(s_{external}, s_{internal}) = 250.00$$

$$n = 24.00$$

Calculation of  $\mu_{u1}$ -

Calculation of ultimate curvature  $\mu_u$  according to 4.1, Biskinis/Fardis 2013:

$$u = 5.1201636E-006$$

$$\mu_u = 5.0296E+008$$

with full section properties:

$$b = 400.00$$

$$d = 707.00$$

$$d' = 43.00$$

$$v = 0.00191815$$

$$N = 16273.608$$

$$f'_c = 30.00$$

$$\alpha_0(5A.5, \text{TBDY}) = 0.002$$

$$\text{Final value of } \mu_u: \mu_u^* = \text{shear\_factor} \cdot \text{Max}(\mu_u, \alpha_0) = 0.01260361$$

The Shear\_factor is considered equal to 1 (pure moment strength)

$$\text{From (5.4b), TBDY: } \mu_u = 0.01260361$$

$$\mu_{ue}(5.4c) = 0.05179731$$

$$\mu_{ase}((5.4d), \text{TBDY}) = (\mu_{ase1} \cdot A_{ext} + \mu_{ase2} \cdot A_{int}) / A_{sec} = 0.45746528$$

$$\mu_{ase1} = \text{Max}(((A_{conf,max1} - A_{noConf1}) / A_{conf,max1}) \cdot (\mu_{ase,min1} / A_{conf,max1}), 0) = 0.45746528$$

The definitions of  $A_{noConf}$ ,  $A_{conf,min}$  and  $A_{conf,max}$  are derived from generalization of the rectangular sections confinement, which is expressed by (5.4d).

The generalization is done according to Mander, J., Priestley, M., and Park, R. (1988)

"Theoretical Stress-Strain Model for Confined Concrete."

J. Struct. Eng., 10.1061/(ASCE)0733-9445(1988)114:8(1804), 1804-1826.

$A_{conf,max1} = 353600.00$  is the confined core area at levels of member with hoops and is calculated as the area of core enclosed by the center lines of the external perimeter hoops.

$A_{conf,min1} = 293525.00$  is the confined core area at midway between the levels of hoops and is calculated by reducing all the dimensions of the area  $A_{conf,max1}$  by a length equal to half the clear spacing between external hoops.

$A_{noConf1} = 158733.333$  is the unconfined external core area which is equal to  $b^2/6$  as defined at (A.2).

$$\mu_{ase2} (\geq \mu_{ase1}) = \text{Max}(((A_{conf,max2} - A_{noConf2}) / A_{conf,max2}) \cdot (\mu_{ase,min2} / A_{conf,max2}), 0) = 0.45746528$$

The definitions of  $A_{noConf}$ ,  $A_{conf,min}$  and  $A_{conf,max}$  are derived from generalization of the rectangular sections confinement, which is expressed by (5.4d).

The generalization is done according to Mander, J., Priestley, M., and Park, R. (1988)  
"Theoretical Stress-Strain Model for Confined Concrete."

J. Struct. Eng., 10.1061/(ASCE)0733-9445(1988)114:8(1804), 1804-1826.

$A_{conf,max2} = 171264.00$  is the confined core area at levels of member with hoops and  
is calculated as the area of core enclosed by the center lines of the internal perimeter hoops.

$A_{conf,min2} = 54741.00$  is the confined core area at midway between the levels of hoops and  
is calculated by reducing all the dimensions of the area  $A_{conf,max2}$  by a length  
equal to half the clear spacing between internal hoops.

$A_{noConf2} = 106242.667$  is the unconfined internal core area which is equal to  $b_i^2/6$  as defined at (A.2).  
 $p_{sh,min} \cdot F_{ywe} = \text{Min}(p_{sh,x} \cdot F_{ywe}, p_{sh,y} \cdot F_{ywe}) = 3.3968$

$p_{sh,x} \cdot F_{ywe} = p_{sh1} \cdot F_{ywe1} + p_{s2} \cdot F_{ywe2} = 3.3968$

$p_{sh1} ((5.4d), \text{TBDY}) = L_{stir1} \cdot A_{stir1} / (A_{sec} \cdot s_1) = 0.00367709$

$L_{stir1}$  (Length of stirrups along Y) = 2060.00

$A_{stir1}$  (stirrups area) = 78.53982

$p_{sh2} (5.4d) = L_{stir2} \cdot A_{stir2} / (A_{sec} \cdot s_2) = 0.00067082$

$L_{stir2}$  (Length of stirrups along Y) = 1468.00

$A_{stir2}$  (stirrups area) = 50.26548

$p_{sh,y} \cdot F_{ywe} = p_{sh1} \cdot F_{ywe1} + p_{s2} \cdot F_{ywe2} = 3.3968$

$p_{sh1} ((5.4d), \text{TBDY}) = L_{stir1} \cdot A_{stir1} / (A_{sec} \cdot s_1) = 0.00367709$

$L_{stir1}$  (Length of stirrups along X) = 2060.00

$A_{stir1}$  (stirrups area) = 78.53982

$p_{sh2} ((5.4d), \text{TBDY}) = L_{stir2} \cdot A_{stir2} / (A_{sec} \cdot s_2) = 0.00067082$

$L_{stir2}$  (Length of stirrups along X) = 1468.00

$A_{stir2}$  (stirrups area) = 50.26548

$A_{sec} = 440000.00$

$s_1 = 100.00$

$s_2 = 250.00$

$f_{ywe1} = 781.25$

$f_{ywe2} = 781.25$

$f_{ce} = 30.00$

From ((5.A5), TBDY), TBDY:  $c_c = 0.00471045$

$c = \text{confinement factor} = 1.27105$

$y_1 = 0.00083886$

$sh_1 = 0.00268436$

$ft_1 = 314.5735$

$fy_1 = 262.1446$

$su_1 = 0.00268436$

using (30) in Biskinis/Fardis (2013) multiplied with shear\_factor  
and also multiplied by the shear\_factor according to 15.7.1.4, with  
Shear\_factor = 1.00

$l_o/l_{ou,min} = l_b/l_d = 0.13907892$

$su_1 = 0.4 \cdot esu1_{nominal} ((5.5), \text{TBDY}) = 0.032$

From table 5A.1, TBDY:  $esu1_{nominal} = 0.08$ ,

For calculation of  $esu1_{nominal}$  and  $y_1, sh_1, ft_1, fy_1$ , it is considered  
characteristic value  $fsy_1 = fs_1/1.2$ , from table 5.1, TBDY.

$y_1, sh_1, ft_1, fy_1$ , are also multiplied by  $\text{Min}(1, 1.25 \cdot (l_b/l_d)^{2/3})$ , from 10.3.5, ASCE 41-17.

with  $fs_1 = (f_{s,jacket} \cdot A_{sl,ten,jacket} + f_{s,core} \cdot A_{sl,ten,core}) / A_{sl,ten} = 262.1446$

with  $Es_1 = (E_{s,jacket} \cdot A_{sl,ten,jacket} + E_{s,core} \cdot A_{sl,ten,core}) / A_{sl,ten} = 200000.00$

$y_2 = 0.00083886$

$sh_2 = 0.00268436$

$ft_2 = 314.5735$

$fy_2 = 262.1446$

$su_2 = 0.00268436$

using (30) in Biskinis/Fardis (2013) multiplied with shear\_factor  
and also multiplied by the shear\_factor according to 15.7.1.4, with  
Shear\_factor = 1.00

$l_o/l_{ou,min} = l_b/l_{b,min} = 0.13907892$

$su_2 = 0.4 \cdot esu2_{nominal} ((5.5), \text{TBDY}) = 0.032$

From table 5A.1, TBDY:  $esu2_{nominal} = 0.08$ ,

For calculation of  $esu2_{nominal}$  and  $y_2, sh_2, ft_2, fy_2$ , it is considered  
characteristic value  $fsy_2 = fs_2/1.2$ , from table 5.1, TBDY.

$y_1, sh_1, ft_1, fy_1$ , are also multiplied by  $\text{Min}(1, 1.25 \cdot (l_b/l_d)^{2/3})$ , from 10.3.5, ASCE 41-17.

with  $fs_2 = (f_{s,jacket} \cdot A_{sl,com,jacket} + f_{s,core} \cdot A_{sl,com,core}) / A_{sl,com} = 262.1446$

with  $Es_2 = (E_{s,jacket} \cdot A_{sl,com,jacket} + E_{s,core} \cdot A_{sl,com,core}) / A_{sl,com} = 200000.00$

```

yv = 0.00083886
shv = 0.00268436
ftv = 314.5735
fyv = 262.1446
suv = 0.00268436
using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00
lo/lou,min = lb/ld = 0.13907892
suv = 0.4*esuv_nominal ((5.5), TBDY) = 0.032
From table 5A.1, TBDY: esuv_nominal = 0.08,
considering characteristic value fsyv = fsv/1.2, from table 5.1, TBDY
For calculation of esuv_nominal and yv, shv,ftv,fyv, it is considered
characteristic value fsyv = fsv/1.2, from table 5.1, TBDY.
y1, sh1,ft1,fy1, are also multiplied by Min(1,1.25*(lb/ld)^2/3), from 10.3.5, ASCE 41-17.
with fsv = (fs,jacket*Asl,mid,jacket + fs,mid*Asl,mid,core)/Asl,mid = 262.1446
with Esv = (Es,jacket*Asl,mid,jacket + Es,mid*Asl,mid,core)/Asl,mid = 200000.00
1 = Asl,ten/(b*d)*(fs1/fc) = 0.06824101
2 = Asl,com/(b*d)*(fs2/fc) = 0.03513975
v = Asl,mid/(b*d)*(fsv/fc) = 0.06202846
and confined core properties:
b = 340.00
d = 677.00
d' = 13.00
fcc (5A.2, TBDY) = 38.13135
cc (5A.5, TBDY) = 0.00471045
c = confinement factor = 1.27105
1 = Asl,ten/(b*d)*(fs1/fc) = 0.08384116
2 = Asl,com/(b*d)*(fs2/fc) = 0.04317283
v = Asl,mid/(b*d)*(fsv/fc) = 0.07620839
Case/Assumption: Unconfined full section - Steel rupture
' satisfies Eq. (4.3)
--->
v < vs,y2 - LHS eq.(4.5) is satisfied
--->
su (4.9) = 0.2584548
Mu = MRc (4.14) = 5.0296E+008
u = su (4.1) = 5.1201636E-006
-----

Calculation of ratio lb/ld
-----

Lap Length: lb/ld = 0.13907892
lb = 300.00
ld = 2157.049
Calculation of lb,min according to (25.4.3.2), ACI 318-14, using mean values for all the section re-bars.
ld,min from (25.4.3.2) is multiplied 2 times to account for smooth re-bars (9.1.2, TS500 - No provision in ACI 318)
= 1
db = 16.66667
Mean strength value of all re-bars: fy = 781.25
Mean concrete strength: fc' = (fc'_jacket*Area_jacket + fc'_core*Area_core)/Area_section = 30.00, but fc'^0.5 <= 8.3
MPa (22.5.3.1, ACI 318-14)
t = 1.00
s = 0.80
e = 1.00
cb = 25.00
Ktr = 1.7174
Atr = Min(Atr_x,Atr_y) = 257.6106
where Atr_x, Atr_y are the sum of the area of all stirrup legs along X and Y loxal axis
s = Max(s_external,s_internal) = 250.00
n = 24.00
-----

Calculation of Mu2+
-----

```

Calculation of ultimate curvature  $\phi_u$  according to 4.1, Biskinis/Fardis 2013:

$$u = 4.8099118E-006$$

$$Mu = 2.3387E+008$$

with full section properties:

$$b = 750.00$$

$$d = 707.00$$

$$d' = 43.00$$

$$v = 0.00102301$$

$$N = 16273.608$$

$$f_c = 30.00$$

$$\alpha (5A.5, TBDY) = 0.002$$

$$\text{Final value of } \phi_u: \phi_u^* = \text{shear\_factor} * \text{Max}(\phi_u, \phi_c) = 0.01260361$$

The Shear\_factor is considered equal to 1 (pure moment strength)

$$\text{From (5.4b), TBDY: } \phi_u = 0.01260361$$

$$\text{we (5.4c) } = 0.05179731$$

$$\text{ase ((5.4d), TBDY) } = (\text{ase1} * A_{\text{ext}} + \text{ase2} * A_{\text{int}}) / A_{\text{sec}} = 0.45746528$$

$$\text{ase1} = \text{Max}(((A_{\text{conf,max1}} - A_{\text{noConf1}}) / A_{\text{conf,max1}}) * (A_{\text{conf,min1}} / A_{\text{conf,max1}}), 0) = 0.45746528$$

The definitions of  $A_{\text{noConf}}$ ,  $A_{\text{conf,min}}$  and  $A_{\text{conf,max}}$  are derived from generalization of the rectangular sections confinement, which is expressed by (5.4d).

The generalization is done according to Mander, J., Priestley, M., and Park, R. (1988)

"Theoretical Stress-Strain Model for Confined Concrete."

J. Struct. Eng., 10.1061/(ASCE)0733-9445(1988)114:8(1804), 1804-1826.

$A_{\text{conf,max1}} = 353600.00$  is the confined core area at levels of member with hoops and

is calculated as the area of core enclosed by the center lines of the external perimeter hoops.

$A_{\text{conf,min1}} = 293525.00$  is the confined core area at midway between the levels of hoops and

is calculated by reducing all the dimensions of the area  $A_{\text{conf,max1}}$  by a length

equal to half the clear spacing between external hoops.

$A_{\text{noConf1}} = 158733.333$  is the unconfined external core area which is equal to  $b_i^2/6$  as defined at (A.2).

$$\text{ase2 } (>= \text{ase1}) = \text{Max}(((A_{\text{conf,max2}} - A_{\text{noConf2}}) / A_{\text{conf,max2}}) * (A_{\text{conf,min2}} / A_{\text{conf,max2}}), 0) = 0.45746528$$

The definitions of  $A_{\text{noConf}}$ ,  $A_{\text{conf,min}}$  and  $A_{\text{conf,max}}$  are derived from generalization of the rectangular sections confinement, which is expressed by (5.4d).

The generalization is done according to Mander, J., Priestley, M., and Park, R. (1988)

"Theoretical Stress-Strain Model for Confined Concrete."

J. Struct. Eng., 10.1061/(ASCE)0733-9445(1988)114:8(1804), 1804-1826.

$A_{\text{conf,max2}} = 171264.00$  is the confined core area at levels of member with hoops and

is calculated as the area of core enclosed by the center lines of the internal perimeter hoops.

$A_{\text{conf,min2}} = 54741.00$  is the confined core area at midway between the levels of hoops and

is calculated by reducing all the dimensions of the area  $A_{\text{conf,max2}}$  by a length

equal to half the clear spacing between internal hoops.

$A_{\text{noConf2}} = 106242.667$  is the unconfined internal core area which is equal to  $b_i^2/6$  as defined at (A.2).

$$\text{psh,min} * F_{ywe} = \text{Min}(\text{psh,x} * F_{ywe}, \text{psh,y} * F_{ywe}) = 3.3968$$

$$\text{psh,x} * F_{ywe} = \text{psh1} * F_{ywe1} + \text{ps2} * F_{ywe2} = 3.3968$$

$$\text{psh1 ((5.4d), TBDY) } = \text{Lstir1} * \text{Astir1} / (A_{\text{sec}} * s1) = 0.00367709$$

$$\text{Lstir1 (Length of stirrups along Y) } = 2060.00$$

$$\text{Astir1 (stirrups area) } = 78.53982$$

$$\text{psh2 (5.4d) } = \text{Lstir2} * \text{Astir2} / (A_{\text{sec}} * s2) = 0.00067082$$

$$\text{Lstir2 (Length of stirrups along Y) } = 1468.00$$

$$\text{Astir2 (stirrups area) } = 50.26548$$

$$\text{psh,y} * F_{ywe} = \text{psh1} * F_{ywe1} + \text{ps2} * F_{ywe2} = 3.3968$$

$$\text{psh1 ((5.4d), TBDY) } = \text{Lstir1} * \text{Astir1} / (A_{\text{sec}} * s1) = 0.00367709$$

$$\text{Lstir1 (Length of stirrups along X) } = 2060.00$$

$$\text{Astir1 (stirrups area) } = 78.53982$$

$$\text{psh2 ((5.4d), TBDY) } = \text{Lstir2} * \text{Astir2} / (A_{\text{sec}} * s2) = 0.00067082$$

$$\text{Lstir2 (Length of stirrups along X) } = 1468.00$$

$$\text{Astir2 (stirrups area) } = 50.26548$$

$$A_{\text{sec}} = 440000.00$$

$$s1 = 100.00$$

$$s2 = 250.00$$

$$f_{ywe1} = 781.25$$

$$f_{ywe2} = 781.25$$

$$f_{ce} = 30.00$$

$$\text{From ((5.A5), TBDY), TBDY: } \phi_c = 0.00471045$$

```

c = confinement factor = 1.27105
y1 = 0.00083886
sh1 = 0.00268436
ft1 = 314.5735
fy1 = 262.1446
su1 = 0.00268436
using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00
lo/lou,min = lb/ld = 0.13907892
su1 = 0.4*esu1_nominal ((5.5), TBDY) = 0.032
From table 5A.1, TBDY: esu1_nominal = 0.08,
For calculation of esu1_nominal and y1, sh1,ft1,fy1, it is considered
characteristic value fsy1 = fs1/1.2, from table 5.1, TBDY.
y1, sh1,ft1,fy1, are also multiplied by Min(1,1.25*(lb/ld)^ 2/3), from 10.3.5, ASCE 41-17.
with fs1 = (fs,jacket*Asl,ten,jacket + fs,core*Asl,ten,core)/Asl,ten = 262.1446
with Es1 = (Es,jacket*Asl,ten,jacket + Es,core*Asl,ten,core)/Asl,ten = 200000.00
y2 = 0.00083886
sh2 = 0.00268436
ft2 = 314.5735
fy2 = 262.1446
su2 = 0.00268436
using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00
lo/lou,min = lb/lb,min = 0.13907892
su2 = 0.4*esu2_nominal ((5.5), TBDY) = 0.032
From table 5A.1, TBDY: esu2_nominal = 0.08,
For calculation of esu2_nominal and y2, sh2,ft2,fy2, it is considered
characteristic value fsy2 = fs2/1.2, from table 5.1, TBDY.
y1, sh1,ft1,fy1, are also multiplied by Min(1,1.25*(lb/ld)^ 2/3), from 10.3.5, ASCE 41-17.
with fs2 = (fs,jacket*Asl,com,jacket + fs,core*Asl,com,core)/Asl,com = 262.1446
with Es2 = (Es,jacket*Asl,com,jacket + Es,core*Asl,com,core)/Asl,com = 200000.00
yv = 0.00083886
shv = 0.00268436
ftv = 314.5735
fyv = 262.1446
suv = 0.00268436
using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
and also multiplied by the shear_factor according to 15.7.1.4, with
Shear_factor = 1.00
lo/lou,min = lb/ld = 0.13907892
suv = 0.4*esuv_nominal ((5.5), TBDY) = 0.032
From table 5A.1, TBDY: esuv_nominal = 0.08,
considering characteristic value fsyv = fsv/1.2, from table 5.1, TBDY
For calculation of esuv_nominal and yv, shv,ftv,fyv, it is considered
characteristic value fsyv = fsv/1.2, from table 5.1, TBDY.
y1, sh1,ft1,fy1, are also multiplied by Min(1,1.25*(lb/ld)^ 2/3), from 10.3.5, ASCE 41-17.
with fsv = (fs,jacket*Asl,mid,jacket + fs,mid*Asl,mid,core)/Asl,mid = 262.1446
with Esv = (Es,jacket*Asl,mid,jacket + Es,mid*Asl,mid,core)/Asl,mid = 200000.00
1 = Asl,ten/(b*d)*(fs1/fc) = 0.0187412
2 = Asl,com/(b*d)*(fs2/fc) = 0.03639521
v = Asl,mid/(b*d)*(fsv/fc) = 0.03308184
and confined core properties:
b = 690.00
d = 677.00
d' = 13.00
fcc (5A.2, TBDY) = 38.13135
cc (5A.5, TBDY) = 0.00471045
c = confinement factor = 1.27105
1 = Asl,ten/(b*d)*(fs1/fc) = 0.02127357
2 = Asl,com/(b*d)*(fs2/fc) = 0.04131304
v = Asl,mid/(b*d)*(fsv/fc) = 0.03755196
Case/Assumption: Unconfined full section - Steel rupture
'satisfies Eq. (4.3)
--->
v < vs,y2 - LHS eq.(4.5) is satisfied

```

```

--->
su (4.9) = 0.21062322
Mu = MRc (4.14) = 2.3387E+008
u = su (4.1) = 4.8099118E-006
-----

Calculation of ratio lb/ld
-----
Lap Length: lb/ld = 0.13907892
lb = 300.00
ld = 2157.049
Calculation of lb,min according to (25.4.3.2), ACI 318-14, using mean values for all the section re-bars.
ld,min from (25.4.3.2) is multiplied 2 times to account for smooth re-bars (9.1.2, TS500 - No provision in ACI 318)
= 1
db = 16.66667
Mean strength value of all re-bars: fy = 781.25
Mean concrete strength: fc' = (fc'jacket*Areajacket + fc'core*Areacore)/Areasection = 30.00, but fc'0.5 ≤ 8.3
MPa (22.5.3.1, ACI 318-14)
t = 1.00
s = 0.80
e = 1.00
cb = 25.00
Ktr = 1.7174
Atr = Min(Atr_x, Atr_y) = 257.6106
where Atr_x, Atr_y are the sum of the area of all stirrup legs along X and Y local axis
s = Max(sexternal, sinternal) = 250.00
n = 24.00
-----

Calculation of Mu2-
-----

Calculation of ultimate curvature u according to 4.1, Biskinis/Fardis 2013:
u = 5.1201636E-006
Mu = 5.0296E+008
-----

with full section properties:
b = 400.00
d = 707.00
d' = 43.00
v = 0.00191815
N = 16273.608
fc = 30.00
co (5A.5, TBDY) = 0.002
Final value of cu: cu* = shear_factor * Max( cu, cc) = 0.01260361
The Shear_factor is considered equal to 1 (pure moment strength)
From (5.4b), TBDY: cu = 0.01260361
we (5.4c) = 0.05179731
ase ((5.4d), TBDY) = (ase1*Aext+ase2*Aint)/Asec = 0.45746528
ase1 = Max(((Aconf,max1-AnoConf1)/Aconf,max1)*(Aconf,min1/Aconf,max1),0) = 0.45746528
The definitions of AnoConf, Aconf,min and Aconf,max are derived from generalization
of the rectangular sections confinement, which is expressed by (5.4d).
The generalization is done according to Mander, J., Priestley, M., and Park, R. (1988)
"Theoretical Stress-Strain Model for Confined Concrete."
J. Struct. Eng., 10.1061/(ASCE)0733-9445(1988)114:8(1804), 1804-1826.
Aconf,max1 = 353600.00 is the confined core area at levels of member with hoops and
is calculated as the area of core enclosed by the center lines of the external perimeter hoops.
Aconf,min1 = 293525.00 is the confined core area at midway between the levels of hoops and
is calculated by reducing all the dimensions of the area Aconf,max1 by a length
equal to half the clear spacing between external hoops.
AnoConf1 = 158733.333 is the unconfined external core area which is equal to bi2/6 as defined at (A.2).
ase2 (>=ase1) = Max(((Aconf,max2-AnoConf2)/Aconf,max2)*(Aconf,min2/Aconf,max2),0) = 0.45746528
The definitions of AnoConf, Aconf,min and Aconf,max are derived from generalization
of the rectangular sections confinement, which is expressed by (5.4d).
The generalization is done according to Mander, J., Priestley, M., and Park, R. (1988)

```



"Theoretical Stress-Strain Model for Confined Concrete."

J. Struct. Eng., 10.1061/(ASCE)0733-9445(1988)114:8(1804), 1804-1826.

$A_{conf,max2} = 171264.00$  is the confined core area at levels of member with hoops and is calculated as the area of core enclosed by the center lines of the internal perimeter hoops.

$A_{conf,min2} = 54741.00$  is the confined core area at midway between the levels of hoops and is calculated by reducing all the dimensions of the area  $A_{conf,max2}$  by a length equal to half the clear spacing between internal hoops.

$A_{noConf2} = 106242.667$  is the unconfined internal core area which is equal to  $b_i^2/6$  as defined at (A.2).  
 $psh_{min} * F_{ywe} = \text{Min}(psh_x * F_{ywe}, psh_y * F_{ywe}) = 3.3968$

$psh_x * F_{ywe} = psh1 * F_{ywe1} + ps2 * F_{ywe2} = 3.3968$   
 $psh1$  ((5.4d), TBDY) =  $L_{stir1} * A_{stir1} / (A_{sec} * s1) = 0.00367709$   
 $L_{stir1}$  (Length of stirrups along Y) = 2060.00  
 $A_{stir1}$  (stirrups area) = 78.53982  
 $psh2$  (5.4d) =  $L_{stir2} * A_{stir2} / (A_{sec} * s2) = 0.00067082$   
 $L_{stir2}$  (Length of stirrups along Y) = 1468.00  
 $A_{stir2}$  (stirrups area) = 50.26548

$psh_y * F_{ywe} = psh1 * F_{ywe1} + ps2 * F_{ywe2} = 3.3968$   
 $psh1$  ((5.4d), TBDY) =  $L_{stir1} * A_{stir1} / (A_{sec} * s1) = 0.00367709$   
 $L_{stir1}$  (Length of stirrups along X) = 2060.00  
 $A_{stir1}$  (stirrups area) = 78.53982  
 $psh2$  ((5.4d), TBDY) =  $L_{stir2} * A_{stir2} / (A_{sec} * s2) = 0.00067082$   
 $L_{stir2}$  (Length of stirrups along X) = 1468.00  
 $A_{stir2}$  (stirrups area) = 50.26548

$A_{sec} = 440000.00$

$s1 = 100.00$

$s2 = 250.00$

$f_{ywe1} = 781.25$

$f_{ywe2} = 781.25$

$f_{ce} = 30.00$

From ((5.A5), TBDY), TBDY:  $cc = 0.00471045$

$c$  = confinement factor = 1.27105

$y1 = 0.00083886$

$sh1 = 0.00268436$

$ft1 = 314.5735$

$fy1 = 262.1446$

$su1 = 0.00268436$

using (30) in Biskinis/Fardis (2013) multiplied with shear\_factor and also multiplied by the shear\_factor according to 15.7.1.4, with Shear\_factor = 1.00

$lo/lo_{min} = lb/ld = 0.13907892$

$su1 = 0.4 * esu1_{nominal}$  ((5.5), TBDY) = 0.032

From table 5A.1, TBDY:  $esu1_{nominal} = 0.08$ ,

For calculation of  $esu1_{nominal}$  and  $y1$ ,  $sh1$ ,  $ft1$ ,  $fy1$ , it is considered characteristic value  $fsy1 = fs1/1.2$ , from table 5.1, TBDY.

$y1$ ,  $sh1$ ,  $ft1$ ,  $fy1$ , are also multiplied by  $\text{Min}(1, 1.25 * (lb/ld)^{2/3})$ , from 10.3.5, ASCE 41-17.

with  $fs1 = (fs_{jacket} * A_{sl,ten,jacket} + fs_{core} * A_{sl,ten,core}) / A_{sl,ten} = 262.1446$

with  $Es1 = (Es_{jacket} * A_{sl,ten,jacket} + Es_{core} * A_{sl,ten,core}) / A_{sl,ten} = 200000.00$

$y2 = 0.00083886$

$sh2 = 0.00268436$

$ft2 = 314.5735$

$fy2 = 262.1446$

$su2 = 0.00268436$

using (30) in Biskinis/Fardis (2013) multiplied with shear\_factor and also multiplied by the shear\_factor according to 15.7.1.4, with Shear\_factor = 1.00

$lo/lo_{min} = lb/lb_{min} = 0.13907892$

$su2 = 0.4 * esu2_{nominal}$  ((5.5), TBDY) = 0.032

From table 5A.1, TBDY:  $esu2_{nominal} = 0.08$ ,

For calculation of  $esu2_{nominal}$  and  $y2$ ,  $sh2$ ,  $ft2$ ,  $fy2$ , it is considered characteristic value  $fsy2 = fs2/1.2$ , from table 5.1, TBDY.

$y1$ ,  $sh1$ ,  $ft1$ ,  $fy1$ , are also multiplied by  $\text{Min}(1, 1.25 * (lb/ld)^{2/3})$ , from 10.3.5, ASCE 41-17.

with  $fs2 = (fs_{jacket} * A_{sl,com,jacket} + fs_{core} * A_{sl,com,core}) / A_{sl,com} = 262.1446$

with  $Es2 = (Es_{jacket} * A_{sl,com,jacket} + Es_{core} * A_{sl,com,core}) / A_{sl,com} = 200000.00$

$yv = 0.00083886$

```

shv = 0.00268436
ftv = 314.5735
fyv = 262.1446
suv = 0.00268436
    using (30) in Biskinis/Fardis (2013) multiplied with shear_factor
    and also multiplied by the shear_factor according to 15.7.1.4, with
    Shear_factor = 1.00
    lo/lo,min = lb/ld = 0.13907892
    suv = 0.4*esuv_nominal ((5.5), TBDY) = 0.032
    From table 5A.1, TBDY: esuv_nominal = 0.08,
    considering characteristic value fsyv = fsv/1.2, from table 5.1, TBDY
    For calculation of esuv_nominal and yv, shv,ftv,fyv, it is considered
    characteristic value fsyv = fsv/1.2, from table 5.1, TBDY.
    y1, sh1,ft1,fy1, are also multiplied by Min(1,1.25*(lb/ld)^2/3), from 10.3.5, ASCE 41-17.
    with fsv = (fs,jacket*Asl,mid,jacket + fs,mid*Asl,mid,core)/Asl,mid = 262.1446
    with Esv = (Es,jacket*Asl,mid,jacket + Es,mid*Asl,mid,core)/Asl,mid = 200000.00
    1 = Asl,ten/(b*d)*(fs1/fc) = 0.06824101
    2 = Asl,com/(b*d)*(fs2/fc) = 0.03513975
    v = Asl,mid/(b*d)*(fsv/fc) = 0.06202846
and confined core properties:
b = 340.00
d = 677.00
d' = 13.00
fcc (5A.2, TBDY) = 38.13135
cc (5A.5, TBDY) = 0.00471045
    c = confinement factor = 1.27105
    1 = Asl,ten/(b*d)*(fs1/fc) = 0.08384116
    2 = Asl,com/(b*d)*(fs2/fc) = 0.04317283
    v = Asl,mid/(b*d)*(fsv/fc) = 0.07620839
Case/Assumption: Unconfined full section - Steel rupture
' satisfies Eq. (4.3)
--->
v < vs,y2 - LHS eq.(4.5) is satisfied
--->
su (4.9) = 0.2584548
Mu = MRc (4.14) = 5.0296E+008
u = su (4.1) = 5.1201636E-006
-----

Calculation of ratio lb/ld
-----
Lap Length: lb/ld = 0.13907892
lb = 300.00
ld = 2157.049
Calculation of lb,min according to (25.4.3.2), ACI 318-14, using mean values for all the section re-bars.
ld,min from (25.4.3.2) is multiplied 2 times to account for smooth re-bars (9.1.2, TS500 - No provision in ACI 318)
= 1
db = 16.66667
Mean strength value of all re-bars: fy = 781.25
Mean concrete strength: fc' = (fc'_jacket*Area_jacket + fc'_core*Area_core)/Area_section = 30.00, but fc'^0.5 <= 8.3
MPa (22.5.3.1, ACI 318-14)
t = 1.00
s = 0.80
e = 1.00
cb = 25.00
Ktr = 1.7174
Atr = Min(Atr_x,Atr_y) = 257.6106
where Atr_x, Atr_y are the sum of the area of all stirrup legs along X and Y loxal axis
s = Max(s_external,s_internal) = 250.00
n = 24.00
-----
-----
-----
Calculation of Shear Strength Vr = Min(Vr1,Vr2) = 1.0392E+006
-----
Calculation of Shear Strength at edge 1, Vr1 = 1.0392E+006

```

$Vr1 = VCol \text{ ((10.3), ASCE 41-17)} = knl * VCol0$

$VCol0 = 1.0392E+006$

$knl = 1$  (zero step-static loading)

NOTE: In expression (10-3) ' $V_s = A_v * f_y * d / s$ ' is replaced by ' $V_s + f * V_f$ '  
where  $V_f$  is the contribution of FRPs (11.3), ACI 440).

$= 1$  (normal-weight concrete)

Mean concrete strength:  $f'_c = (f'_{c\_jacket} * Area\_jacket + f'_{c\_core} * Area\_core) / Area\_section = 30.00$ , but  $f'_c^{0.5} \leq 8.3$  MPa (22.5.3.1, ACI 318-14)

$M/Vd = 4.00$

$\mu_u = 1308.675$

$V_u = 0.0001715$

$d = 0.8 * h = 600.00$

$N_u = 16273.608$

$A_g = 300000.00$

From (11.5.4.8), ACI 318-14:  $V_s = V_{s,jacket} + V_{s,core} = 1.0138E+006$

where:

$V_{s,jacket} = V_{s,j1} + V_{s,j2} = 903207.888$

$V_{s,j1} = 314159.265$  is calculated for section web jacket, with:

$d = 320.00$

$A_v = 157079.633$

$f_y = 625.00$

$s = 100.00$

$V_{s,j1}$  is multiplied by  $Col,j1 = 1.00$

$s/d = 0.3125$

$V_{s,j2} = 589048.623$  is calculated for section flange jacket, with:

$d = 600.00$

$A_v = 157079.633$

$f_y = 625.00$

$s = 100.00$

$V_{s,j2}$  is multiplied by  $Col,j2 = 1.00$

$s/d = 0.16666667$

$V_{s,core} = V_{s,c1} + V_{s,c2} = 110584.061$

$V_{s,c1} = 0.00$  is calculated for section web core, with:

$d = 160.00$

$A_v = 100530.965$

$f_y = 625.00$

$s = 250.00$

$V_{s,c1}$  is multiplied by  $Col,c1 = 0.00$

$s/d = 1.5625$

$V_{s,c2} = 110584.061$  is calculated for section flange core, with:

$d = 440.00$

$A_v = 100530.965$

$f_y = 625.00$

$s = 250.00$

$V_{s,c2}$  is multiplied by  $Col,c2 = 1.00$

$s/d = 0.56818182$

$V_f \text{ ((11-3)-(11.4), ACI 440)} = 0.00$

From (11-11), ACI 440:  $V_s + V_f \leq 873250.061$

$bw = 400.00$

Calculation of Shear Strength at edge 2,  $Vr2 = 1.0392E+006$

$Vr2 = VCol \text{ ((10.3), ASCE 41-17)} = knl * VCol0$

$VCol0 = 1.0392E+006$

$knl = 1$  (zero step-static loading)

NOTE: In expression (10-3) ' $V_s = A_v * f_y * d / s$ ' is replaced by ' $V_s + f * V_f$ '  
where  $V_f$  is the contribution of FRPs (11.3), ACI 440).

$= 1$  (normal-weight concrete)

Mean concrete strength:  $f'_c = (f'_{c\_jacket} * Area\_jacket + f'_{c\_core} * Area\_core) / Area\_section = 30.00$ , but  $f'_c^{0.5} \leq 8.3$  MPa (22.5.3.1, ACI 318-14)

$M/Vd = 4.00$

$\mu_u = 1308.675$

$V_u = 0.0001715$

$d = 0.8 \cdot h = 600.00$   
 $Nu = 16273.608$   
 $Ag = 300000.00$   
 From (11.5.4.8), ACI 318-14:  $V_s = V_{s,jacket} + V_{s,core} = 1.0138E+006$   
 where:  
 $V_{s,jacket} = V_{s,j1} + V_{s,j2} = 903207.888$   
 $V_{s,j1} = 314159.265$  is calculated for section web jacket, with:  
 $d = 320.00$   
 $A_v = 157079.633$   
 $f_y = 625.00$   
 $s = 100.00$   
 $V_{s,j1}$  is multiplied by  $Col,j1 = 1.00$   
 $s/d = 0.3125$   
 $V_{s,j2} = 589048.623$  is calculated for section flange jacket, with:  
 $d = 600.00$   
 $A_v = 157079.633$   
 $f_y = 625.00$   
 $s = 100.00$   
 $V_{s,j2}$  is multiplied by  $Col,j2 = 1.00$   
 $s/d = 0.16666667$   
 $V_{s,core} = V_{s,c1} + V_{s,c2} = 110584.061$   
 $V_{s,c1} = 0.00$  is calculated for section web core, with:  
 $d = 160.00$   
 $A_v = 100530.965$   
 $f_y = 625.00$   
 $s = 250.00$   
 $V_{s,c1}$  is multiplied by  $Col,c1 = 0.00$   
 $s/d = 1.5625$   
 $V_{s,c2} = 110584.061$  is calculated for section flange core, with:  
 $d = 440.00$   
 $A_v = 100530.965$   
 $f_y = 625.00$   
 $s = 250.00$   
 $V_{s,c2}$  is multiplied by  $Col,c2 = 1.00$   
 $s/d = 0.56818182$   
 $V_f ((11-3)-(11.4), ACI 440) = 0.00$   
 From (11-11), ACI 440:  $V_s + V_f \leq 873250.061$   
 $bw = 400.00$

-----  
 End Of Calculation of Shear Capacity ratio for element: column JLC1 of floor 1  
 At local axis: 2  
 -----

-----  
 Start Of Calculation of Chord Rotation Capacity for element: column JLC1 of floor 1  
 At local axis: 3  
 Integration Section: (b)  
 Section Type: rcjlc

Constant Properties

-----  
 Knowledge Factor,  $\phi = 1.00$   
 Chord Rotation is generally considered as Deformation-Controlled Action according to Table C7-1, ASCE 41-17.  
 Mean strengths are used for Deformation-Controlled Actions according to 7.5.1.3, ASCE 41-17  
 Consequently:  
 Jacket  
 New material of Primary Member: Concrete Strength,  $f_c = f_{cm} = 30.00$   
 New material of Primary Member: Steel Strength,  $f_s = f_{sm} = 625.00$   
 Concrete Elasticity,  $E_c = 25742.96$   
 Steel Elasticity,  $E_s = 200000.00$   
 Existing Column  
 New material of Primary Member: Concrete Strength,  $f_c = f_{cm} = 30.00$   
 New material of Primary Member: Steel Strength,  $f_s = f_{sm} = 625.00$   
 Concrete Elasticity,  $E_c = 25742.96$   
 Steel Elasticity,  $E_s = 200000.00$

Max Height, Hmax = 750.00  
 Min Height, Hmin = 400.00  
 Max Width, Wmax = 750.00  
 Min Width, Wmin = 400.00  
 Jacket Thickness, tj = 100.00  
 Cover Thickness, c = 25.00  
 Element Length, L = 3000.00  
 Primary Member  
 Smooth Bars  
 Ductile Steel  
 With Detailing for Earthquake Resistance (including stirrups closed at 135°)  
 Longitudinal Bars With Ends Lapped Starting at the End Sections  
 Lap Length lb = 300.00  
 No FRP Wrapping

#### Stepwise Properties

Bending Moment, M = 293212.583  
 Shear Force, V2 = 7609.421  
 Shear Force, V3 = -213.4386  
 Axial Force, F = -17779.344  
 Longitudinal Reinforcement Area Distribution (in 2 divisions)  
   -Tension: Aslt = 0.00  
   -Compression: Aslc = 5353.274  
 Longitudinal Reinforcement Area Distribution (in 3 divisions)  
   -Tension: Asl,ten = 1137.257  
   -Compression: Asl,com = 2208.54  
   -Middle: Asl,mid = 2007.478  
 Longitudinal External Reinforcement Area Distribution (in 3 divisions)  
   -Tension: Asl,ten,jacket = 829.3805  
   -Compression: Asl,com,jacket = 1746.726  
   -Middle: Asl,mid,jacket = 1545.664  
 Longitudinal Internal Reinforcement Area Distribution (in 3 divisions)  
   -Tension: Asl,ten,core = 307.8761  
   -Compression: Asl,com,core = 461.8141  
   -Middle: Asl,mid,core = 461.8141  
 Mean Diameter of Tension Reinforcement, DbL = 16.80

New component: From table 7-7, ASCE 41\_17: Final chord rotation Capacity  $u_R = 1.0^*$   $u = 0.0391696$   
 $u = y + p = 0.0391696$

- Calculation of  $y$  -

$y = (M_y * L_s / 3) / E_{eff} = 0.00019718$  ((4.29), Biskinis Phd))  
 $M_y = 2.8709E+008$   
 $L_s = M/V$  (with  $L_s > 0.1 * L$  and  $L_s < 2 * L$ ) = 300.00  
 From table 10.5, ASCE 41\_17:  $E_{eff} = factor * E_c * I_g = 1.4560E+014$   
 $factor = 0.30$   
 $A_g = 440000.00$   
 Mean concrete strength:  $fc' = (fc'_{jacket} * Area_{jacket} + fc'_{core} * Area_{core}) / Area_{section} = 30.00$   
 $N = 17779.344$   
 $E_c * I_g = E_{c,jacket} * I_{g,jacket} + E_{c,core} * I_{g,core} = 4.8532E+014$

Calculation of Yielding Moment  $M_y$

Calculation of  $y$  and  $M_y$  according to Annex 7 -

Assuming neutral axis within flange ( $y < t/d$ , compression zone rectangular) with:  
 flange width, b = 750.00  
 web width, bw = 400.00

flange thickness,  $t = 400.00$

$y = \text{Min}(y_{\text{ten}}, y_{\text{com}})$   
 $y_{\text{ten}} = 2.1455196\text{E-}006$   
with ((10.1), ASCE 41-17)  $f_y = \text{Min}(f_y, 1.25*f_y*(l_b/d)^{2/3}) = 243.3535$   
 $d = 707.00$   
 $y = 0.19784983$   
 $A = 0.01023354$   
 $B = 0.00454395$   
with  $p_t = 0.00434791$   
 $p_c = 0.00416509$   
 $p_v = 0.00378591$   
 $N = 17779.344$   
 $b = 750.00$   
 $" = 0.06082037$   
 $y_{\text{comp}} = 1.5202265\text{E-}005$   
with  $f_c = 30.00$   
 $E_c = 25742.96$   
 $y = 0.19516753$   
 $A = 0.01001583$   
 $B = 0.00440616$   
with  $E_s = 200000.00$   
CONFIRMATION:  $y = 0.19594836 < t/d$

Calculation of ratio  $l_b/d$

Lap Length:  $l_d/l_d, \text{min} = 0.17384865$   
 $l_b = 300.00$   
 $l_d = 1725.639$   
Calculation of  $l$  according to (25.4.3.2), ACI 318-14, using mean values for all the section re-bars.  
 $l_d, \text{min}$  from (25.4.3.2) is multiplied 2 times to account for smooth re-bars (10.3.5, ASCE 41-17)  
 $= 1$   
 $db = 16.66667$   
Mean strength value of all re-bars:  $f_y = 625.00$   
Mean concrete strength:  $f'_c = (f'_c_{\text{jacket}}*Area_{\text{jacket}} + f'_c_{\text{core}}*Area_{\text{core}})/Area_{\text{section}} = 30.00$ , but  $f_c^{0.5} \leq 8.3$  MPa (22.5.3.1, ACI 318-14)  
 $t = 1.00$   
 $s = 0.80$   
 $e = 1.00$   
 $cb = 25.00$   
 $K_{tr} = 1.7174$   
 $A_{tr} = \text{Min}(A_{tr_x}, A_{tr_y}) = 257.6106$   
where  $A_{tr_x}, A_{tr_y}$  are the sum of the area of all stirrup legs along X and Y local axis  
 $s = \text{Max}(s_{\text{external}}, s_{\text{internal}}) = 250.00$   
 $n = 24.00$

- Calculation of  $p$  -

From table 10-8:  $p = 0.03897242$

with:

- Columns controlled by inadequate development or splicing along the clear height because  $l_b/d < 1$   
shear control ratio  $V_y E / V_{CoI} E = 0.32266369$   
 $d = d_{\text{external}} = 707.00$   
 $s = s_{\text{external}} = 0.00$   
-  $t = s_1 + s_2 + 2*tf/bw*(f_{fe}/f_s) = 0.00434791$   
jacket:  $s_1 = A_{v1}*L_{\text{stir1}}/(s_1*Ag) = 0.00367709$   
 $A_{v1} = 78.53982$ , is the area of every stirrup parallel to loading (shear) direction  
 $L_{\text{stir1}} = 2060.00$ , is the total Length of all stirrups parallel to loading (shear) direction  
 $s_1 = 100.00$   
core:  $s_2 = A_{v2}*L_{\text{stir2}}/(s_2*Ag) = 0.00067082$   
 $A_{v2} = 50.26548$ , is the area of every stirrup parallel to loading (shear) direction  
 $L_{\text{stir2}} = 1468.00$ , is the total Length of all stirrups parallel to loading (shear) direction  
 $s_2 = 250.00$   
The term  $2*tf/bw*(f_{fe}/f_s)$  is implemented to account for FRP contribution

where  $f = 2 \cdot t_f / b_w$  is FRP ratio (EC8 - 3, A.4.4.3(6)) and  $f_{fe}/f_s$  normalises  $f$  to steel strength

All these variables have already been given in Shear control ratio calculation.

For the normalisation  $f_s$  of jacket is used.

$$N_{UD} = 17779.344$$

$$A_g = 440000.00$$

$$f_{cE} = (f_{c\_jacket} \cdot Area\_jacket + f_{c\_core} \cdot Area\_core) / section\_area = 30.00$$

$$f_{yE} = (f_{y\_ext\_Long\_Reinf} \cdot Area\_ext\_Long\_Reinf + f_{y\_int\_Long\_Reinf} \cdot Area\_int\_Long\_Reinf) / Area\_Tot\_Long\_Rein = 625.00$$

$$f_{yE} = (f_{y\_ext\_Trans\_Reinf} \cdot s_1 + f_{y\_int\_Trans\_Reinf} \cdot s_2) / (s_1 + s_2) = 625.00$$

$$\rho_l = Area\_Tot\_Long\_Rein / (b \cdot d) = 0.01009575$$

$$b = 750.00$$

$$d = 707.00$$

$$f_{cE} = 30.00$$

-----  
End Of Calculation of Chord Rotation Capacity for element: column JLC1 of floor 1

At local axis: 3

Integration Section: (b)

-----